

# ANNEXURE

## CHECKLISTS & TIPS FOR ENERGY EFFICIENCY IN THERMAL UTILITIES

### Boilers

- Preheat combustion air with waste heat.  
*(22°C reduction in flue gas temperature increases boiler efficiency by 1%)*
- Use variable speed drives on large boiler combustion air fans with variable flows.
- Burn wastes if permitted.
- Insulate exposed heated oil tanks.
- Clean burners, nozzles, strainers, etc.
- Inspect oil heaters for proper oil temperature.
- Close burner air and/or stack dampers when the burner is off to minimize heat loss up the stack.
- Improve oxygen trim control (e.g. -- limit excess air to less than 10% on clean fuels).  
*(5% reduction in excess air increases boiler efficiency by 1% or: 1% reduction of residual oxygen in stack gas increases boiler efficiency by 1%)*
- Automate/optimize boiler blowdown. Recover boiler blowdown heat.
- Use boiler blowdown to help warm the back-up boiler.
- Optimize deaerator venting.
- Inspect door gaskets.
- Inspect for scale and sediment on the water side.  
*(A 1 mm thick scale (deposit) on the water side could increase fuel consumption by 5 to 8%.)*
- Inspect for soot, flyash, and slag on the fire side.  
*(A 3 mm thick soot deposition on the heat transfer surface can cause an increase in fuel consumption to the tune of 2.5%)*
- Optimize boiler water treatment.
- Add an economizer to preheat boiler feedwater using exhaust heat.
- Recycle steam condensate.
- Study part-load characteristics and cycling costs to determine the most-efficient mode for operating multiple boilers.
- Consider multiple or modular boiler units instead of one or two large boilers.
- Establish a boiler efficiency-maintenance program. Start with an energy audit and follow-up, then make a boiler efficiency-maintenance program a part of your continuous energy management program.

### Steam System

- Fix steam leaks and condensate leaks.  
*(A 3 mm diameter hole on a pipe line carrying 7 Kg/cm<sup>2</sup> steam would waste 33 Kilo litres of fuel oil per year)*

- Accumulate work orders for repair of steam leaks that can't be fixed during the heating season due to system shutdown requirements. Tag each such leak with a durable tag with a good description.
- Use back pressure steam turbines to produce lower steam pressures.
- Use more-efficient steam desuperheating methods.
- Ensure process temperatures are correctly controlled.
- Maintain lowest acceptable process steam pressures.
- Reduce hot water wastage to drain.
- Remove or blank off all redundant steam piping.
- Ensure condensate is returned or re-used in the process.  
*(6°C raise in feed water temperature by economiser/condensate recovery corresponds to a 1% saving in fuel consumption, in boiler)*
- Preheat boiler feed-water.
- Recover boiler blowdown.
- Check operation of steam traps.
- Remove air from indirect steam using equipment  
*(0.25 mm thick air film offers the same resistance to heat transfer as a 330 mm thick copper wall)*
- Inspect steam traps regularly and repair malfunctioning traps promptly.
- Consider recovery of vent steam (e.g. -- on large flash tanks).
- Use waste steam for water heating.
- Use an absorption chiller to condense exhaust steam before returning the condensate to the boiler.
- Use electric pumps instead of steam ejectors when cost benefits permit
- Establish a steam efficiency-maintenance program. Start with an energy audit and follow-up, then make a steam efficiency-maintenance program a part of your continuous energy management program.

## **Furnaces**

- Check against infiltration of air: Use doors or air curtains
- Monitor O<sub>2</sub> /CO<sub>2</sub>/CO and control excess air to the optimum level
- Improve burner design, combustion control and instrumentation.
- Ensure that the furnace combustion chamber is under slight positive pressure
- Use ceramic fibres in the case of batch operations
- Match the load to the furnace capacity
- Retrofit with heat recovery device
- Investigate cycle times and reduce
- Provide temperature controllers
- Ensure that flame does not touch the stock

## Insulation

- Repair damaged insulation.  
*(A bare steam pipe of 150 mm diameter and 100 m length, carrying saturated steam at 8 kg/cm<sup>2</sup> would waste 25,000 litres furnace oil in a year)*
- Insulate any hot or cold metal or insulation.
- Replace wet insulation.
- Use an infrared gun to check for cold wall areas during cold weather or hot wall areas during hot weather.
- Ensure that all insulated surfaces are clad with aluminum
- Insulate all flanges, valves and couplings
- Insulate open tanks  
*(70% heat losses can be reduced by floating a layer of 45 mm diameter polypropylene (plastic) balls on the surface of 90°C hot liquid/condensate)*

## Waste heat recovery

- Recover heat from flue gas, engine cooling water, engine exhaust, low pressure waste steam, drying oven exhaust, boiler blowdown, etc.
- Recover heat from incinerator off-gas.
- Use waste heat for fuel oil heating, boiler feedwater heating, outside air heating, etc.
- Use chiller waste heat to preheat hot water.
- Use heat pumps.
- Use absorption refrigeration.
- Use thermal wheels, run-around systems, heat pipe systems, and air-to-air exchangers.