

GULBARGA ELECTRICITY SUPPLY COMPANY LIMITED

(A Government of Karnataka Enterprise)

E-mail: ceetpgescom@gmail.com



Corporate Office,
GESCOM, Kalaburagi
Pin Code.585 102.

No. GESCOM/CEE(O)/SEE (Tech)/EEE(Tech)/AEE-2(Tech)/AE-2(Tech)/2021-22/40871-75 Date: 14 JAN 2022

Encl:

To,

The Director,
Bureau of Energy Efficiency,
4th Floor, Sewa Bhawan, R.K. Puram,
New Delhi-110066.


Sir,

Sub:- Submission of Periodic Energy Audit Report of GESCOM for the 2nd quarter of FY:21-22. reg.

Ref:- Manner and Intervals for conduct of energy audit in DISCOMs Regulations-2021 Dtd: 06. 10.2021.

With reference to the above subject, I am here with submitting the Periodic Energy Audit Report of GESCOM for the 2nd quarter of FY:21-22 (From July-21 to Sept-21) conducted as per the Clause 4.2.(a) of Manner and Intervals for Conduct of Energy Audit in Electricity Distribution Companions Regulation, 2021 for your kind information and needful.

Yours faithfully,


Chief Engineer (Electy),
(Operations)
Corporate Office,
GESCOM, Kalaburagi.

Copy to:

- 1) Under Secretary to GoK, Energy Dept, 2nd floor, Vikasa Saudha, Bengaluru.
- 2) Additional Director PCKL, Nodal Officer for Energy Audit, 5th Floor, Kaveri Bhavan, Bengaluru.
- 3) SPS to Managing Director/ Director (Technical) GESCOM Kalaburagi.
MF/OC

General Information

1	Name of the DISCOM	Gulbarga Electricity Supply Company Limited (GESCOM)		
2	i) Year of Establishment	01-06-2002		
	ii) Government/Public/Private	Government		
3	DISCOM's Contact details & Address			
i	City/Town/Village	Gulbarga		
ii	District	Gulbarga		
iii	State	Karnataka	Pin	585102
iv	Telephone	08472-256842	Fax	256842
4	Registered Office			
i	Company's Chief Executive Name	Sri. Rahul T Pandve		
ii	Designation	Managing Director		
iii	Address	Station Road, Gulbarga		
iv	City/Town/Village	Gulbarga	P.O.	
v	District	Gulbarga		
vi	State	Karnataka	Pin	
vii	Telephone		Fax	
5	Nodal Officer Details*			
i	Nodal Officer Name (Designated at DISCOM's)	Sri. Laxman Chavan		
ii	Designation	Chief Engineer Electy (Operations)		
iii	Address	Station Road, Gulbarga		
iv	City/Town/Village	Gulbarga	P.O.	
v	District	Gulbarga		
vi	State	Karnataka	Pin	
vii	Telephone		Fax	
6	Energy Manager Details*			
i	Name	Dodda Basappa A		
ii	Designation	Assistant Engineer	Whether EA or EM	EM
iii	EA/EM Registration No.	EM-7976		
iv	Telephone		Fax	
v	Mobile	8328514237	E-mail ID	dodda1386@gmail.com
7	Period of Information			
	Year of (FY) information including Date and Month (Start & End)	1st July, 2021 - 30th September, 2021		

Performance Summary of Electricity Distribution Companies

1	Period of Information Year of (FY) information including Date and Month (Start & End)	1st July, 2021 - 30th September, 2021	
2	Technical Details		
(a)	Energy Input Details		
(i)	Input Energy Purchase (From Generation Source)	Million kwh	2452.10
(ii)	Net input energy (at DISCOM Periphery after adjusting the transmission losses and energy traded)	Million kwh	1931.06
(iii)	Total Energy billed (is the Net energy billed, adjusted for energy traded))	Million kwh	1715.67
(b)	Transmission and Distribution (T&D) loss Details	Million kwh	215.39
		%	11.15
	Collection Efficiency	%	101%
(c)	Aggregate Technical & Commercial Loss	%	10%

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal


 Name of Authorised Signatory: *Esthi. Lakshmi*
 Name of the ~~Discom~~ **Engineer (Ele.), Operation**
 Full Address:- **Corporate Office,**
GESCOM, Kalaburagi,

Signature:-

Name of Energy Manager*: *Dodda Basappa A*

Registration Number: EM-7976

Seal

A. Summary of energy input & infrastructure

S.No	Parameters	Period From July 2021 To September 2021	Remarks (Source of data)
A.1	Input Energy purchased (MU)	2452.1	PTC Section
A.2	Transmission loss (%)	3%	PTC Section
A.3	Transmission loss (MU)	75.8	PTC Section
A.4	Energy sold outside the periphery(MU)	167.2	PTC Section
A.5	Open access sale (MU)	40.45	PTC Section
A.6	EHT sale	226.45	MRT Section
A.7	Net input energy (received at DISCOM periphery or at distribution point)-(MU)	1913.06	MRT Section
A.8	Is 100% metering available at 66/33 kV (Select yes or no from list)	Yes	
A.9	Is 100% metering available at 11 kV (Select yes or no from list)	Yes	
A.10	% of metering available at DT	75%	TP Section
A.11	% of metering available at consumer end	81%	
A.12	No of feeders at 66kV voltage level	28	66kV Feeders pertains to KPTCL
A.13	No of feeders at 33kV voltage level	147	SCADA Section
A.14	No of feeders at 11kV voltage level	2163	SCADA Section
A.15	No of LT feeders level	116285	MIS Section
A.16	Line length (ckt. km) at 66kV voltage level	NA	66kV Feeders pertains to KPTCL
A.17	Line length (ckt. km) at 33kV voltage level	2806.53	MIS Section
A.18	Line length (ckt. km) at 11kV voltage level (Excluding UG Cable)	71656.53	MIS Section
A.19	Line length (km) at LT level (Excluding A Cable)	89845.68	MIS Section
A.20	Length of Aerial Bunched Cables	2448.5	
A.21	Length of Underground Cables	107.88	
A.22	HT/LT ratio	0.80	

B. Meter reading of input energy at injection points

S.No	Zone	Circle	Voltage Level (KVA)	Feeder Name	Meter S.No	Period from...to...			Sales	Remarks (Source of data)
						CT/PT ratio	Import (MU)	Export (MU)		
B.1	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Gulbarga (N)		400/1	6.52	0.00		
B.2	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Gulbarga (N)		800/2	3.91	0.00		
B.3	Kalaburagi	Kalaburagi	110/11 KV Bank-3	Gulbarga (N)		800/1	7.19	0.00		
B.4	Kalaburagi	Kalaburagi	110/11 KV Bank-4	Gulbarga (N)		800/1	6.91	0.00		
B.5	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Gulbarga (S)		800/1	5.02	0.00		
B.6	Kalaburagi	Kalaburagi	110/11 KV Bank-3	Gulbarga (S)		600/1	6.17	0.00		
B.7	Kalaburagi	Kalaburagi	110/11 KV Bank-4	Gulbarga (S)		800/1	8.13	0.00		
B.8	Kalaburagi	Kalaburagi	110/11 KV Bank-5	Gulbarga (S)		800/1	4.23	0.00		
B.9	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Gulbarga (W)		800/1	6.18	0.00		
B.10	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Gulbarga (W)		600/1	6.47	0.00		
B.11	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Kapnoor Gulbarga		800/1	5.29	0.00		
B.12	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Gulbarga(U)		800/1	7.02	0.00		
B.13	Kalaburagi	Kalaburagi	110/11 KV Bank-4	Gulbarga(U)		800/1	2.84	0.00		
B.14	Kalaburagi	Kalaburagi	110/11 KV Bank-3	Gulbarga(U)		400/1	3.52	0.00		
B.15	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Gulbarga(U)		400/1	3.44	0.00		
B.16	Kalaburagi	Kalaburagi	110/33 KV Bank-2 kalgi	Gulbarga (N)		400/1	10.29	0.00		
B.17	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Gulbarga (W)		400/1	9.80	0.00		
B.18	Kalaburagi	Kalaburagi	110/33 KV Bank-2	Gulbarga (W)		400/1	6.67	0.00		
B.19	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Gulbarga (N)		400/1	18.31	0.00		
B.20	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Afzalpur		800/1	6.19	0.00		
B.21	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Afzalpur		800/1	0.28	0.00		
B.22	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Afzalpur		800/1	5.11	0.00		
B.23	Kalaburagi	Kalaburagi	110/11 KV Bank-3	Afzalpur		800/1	2.21	0.00		
B.24	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Afzalpur		400/1	4.40	0.00		
B.25	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Karejgi		600/1	2.60	0.00		
B.26	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Karejgi		600/1	4.06	0.00		
B.27	Kalaburagi	Kalaburagi	110/33 KV Bank	Karejgi		400/1	6.62	0.00		
B.28	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Aland		800/1	6.56	0.00		
B.29	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Aland		200/1	4.42	0.00		
B.30	Kalaburagi	Kalaburagi	110/33 KV Bank-2	Aland		400/1	6.82	0.00		
B.31	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Kapnoor Gulbarga		800/1	2.91	0.00		
B.32	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Kadganchi		800/1	4.12	0.00		
B.33	Kalaburagi	Kalaburagi	110/11KV Bank-1	Mediyal		600/1A	2.84	0.00		
B.34	Kalaburagi	Kalaburagi	110/33KV Bank-1	Mediyal		200/1/1	2.04	0.00		
B.35	Kalaburagi	Kalaburagi	110/11KV Bank-2	Mediyal		600/1	2.99	0.00		
B.36	Kalaburagi	Kalaburagi	110/11 KV Bank-2 (New)	Mahaagon		800/1	2.27	0.00		
B.37	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Mahaagon		800/1	1.76	0.00		
B.38	Kalaburagi	*Kalaburagi	110/33 KV Bank-2	Mahaagon		200/1	6.13	0.00		
B.39	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Margutti		800/1	2.73	0.00		
B.40	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Farthabad		600/1	4.44	0.00		
B.41	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Farthabad		600/1	1.18	0.00		

B. Meter reading of Input energy at Injection points

S.No	Zone	Circle	Voltage Level (KVA)	Feeder Name	Meter S.No	Period from...to...		Sales	Remarks (Source of data)
						CT/PT ratio	Import (MU)		
B.42	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Chowdapur		800/1	5.68	0.00	
B.43	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Chowdapur		200/1	10.53	0.00	
B.44	Kalaburagi	Kalaburagi	110/11KV BANK-1	Ghattarga		600/1	3.13	0.00	
B.45	Kalaburagi	Kalaburagi	110/11KV BANK-2	Ghattarga		600/1	0.23	0.00	
B.46	Kalaburagi	Kalaburagi	110/11kv BANK-1	Nandoor kesaratagi		600/1	0.43	0.00	
B.47	Kalaburagi	Kalaburagi	110/11kv BANK-2	Nandoor kesaratagi		600/1	2.88	0.00	
B.48	Kalaburagi	Kalaburagi	33 kv M/s Global Exotium Renewable Solution Pvt. Ltd. Jidga - To KPTCL	110 KV Aland		175/1 A	0.25	0.00	
B.49	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Jewargi		800/1	3.82	0.00	
B.50	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Jewargi		800/1	4.82	0.00	
B.51	Kalaburagi	Kalaburagi	110/33 KV Bank-1 (33 KV Yedrami)	Jewargi		200/1	0.81	0.00	
B.52	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Mandewal		100/1	3.42	0.00	
B.53	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Mandewal		400/1	3.86	0.00	
B.54	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Shahabed		1200/1	7.82	0.00	
B.55	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Shahabed		2000/1	3.38	0.00	
B.56	Kalaburagi	Kalaburagi	110/11 Bank - 1 -	Wadi		800/1	8.29	0.00	
B.57	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Chittapur		200/1	3.44	0.00	
B.58	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Chittapur		200/1	1.66	0.00	
B.59	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Chittapur		400/1	5.79	0.00	
B.60	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Korwar Temple		600/1	1.23	0.00	
B.61	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Korwar Temple		200/1	5.77	0.00	
B.62	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Yadrami		800/1	3.98	0.00	
B.63	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Yadrami		600/1	5.48	0.00	
B.64	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Nalwar		300/1	2.86	0.00	
B.65	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Nalwar		200/1	3.87	0.00	
B.66	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Chowdapur		200/1	10.53	0.00	
B.67	Kalaburagi	Kalaburagi	110 KV Orient Cements, Chittapur	Sedam		150/1 A	6.59	0.00	
B.68	Kalaburagi	Kalaburagi	M/s Jaypee Cements	Sedam		150/5 A	0.18	0.00	
B.69	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Chincholi		800/1	5.82	0.00	
B.70	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Chincholi		400/1	8.28	0.00	
B.71	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Chincholi		200/1	2.08	0.00	
B.72	Kalaburagi	Kalaburagi	110/11 Bank-1	Kurkunta		800/1	1.57	0.00	
B.73	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Sedam		800/1	4.65	0.00	
B.74	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Sedam		800/1	3.98	0.00	
B.75	Kalaburagi	Kalaburagi	110/33 KV Bank-2	sedam		400/1	7.46	0.00	
B.76	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Chittapur		400/1	5.79	0.00	
B.77	Kalaburagi	Kalaburagi	110/33 KV Bank	Mahagaon (Ratkal Feeder)		200/1	2.80	0.00	
B.78	Kalaburagi	Kalaburagi	110/11KV Bank-1	Gurmitkal		600/1	4.09	0.00	
B.79	Kalaburagi	Kalaburagi	M/s. Rajasthan Cements Maikhed HTP-3	Sedam		150/1	0.01	0.00	

B. Meter reading of input energy at injection points

S.No	Zone	Circle	Voltage Level (KVA)	Feeder Name	Period from...to...			Remarks (Source of data)	
					Meter S.No	CT/PT ratio	Import (MU)		Export (MU)
B.80	Kalaburagi	Kalaburagi	M/s. Vasavadatta Cements Malkhed HTP-4	Sedam		125/1	0.00	0.00	
B.81	Kalaburagi	Kalaburagi	M/s Chettinad cement Corporation EHT-5	Chincholi		175/1	0.01	0.00	
B.82	Kalaburagi	Kalaburagi	M/s Chettinad cement Corporation EHT-5	Chincholi		175/1	2.44	0.00	
B.83	Kalaburagi	Kalaburagi	110 KV Malkhed Railway Station HTP-14	Sedam		100/1	6.36	0.00	
B.84	Kalaburagi	Kalaburagi	110 KV M/s South India Cements Malkhed HTP-5	Sedam		75/1	4.27	0.00	
B.85	Kalaburagi	Kalaburagi	110 KV Vicat sagar Cements, Chitrasal Chincholi HTP-6	Sedam		50/1 A	1.78	0.00	
B.86	Kalaburagi	Kalaburagi	Shree Cements Ltd	Sedam		0	23.79	0.00	
B.87	Kalaburagi	Kalaburagi	33 kv Matrix Agro Pvt Ltd to kptcd	Chincholi		175/1 A	5.84	0.00	
B.88	Kalaburagi	Kalaburagi	110/33KV Bank-1	Gurmitkal		400/1	5.70	0.00	
B.89	Kalaburagi	Kalaburagi	110/11KV Bank-1	Phanapur		600/1	4.57	0.00	
B.90	Kalaburagi	Kalaburagi	110/11KV Bank-2	Khanapur		400/1	1.63	0.00	
B.91	Kalaburagi	Kalaburagi	110/33KV Bank-1	Yhanapur		400/1	2.66	0.00	
B.92	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Shahapur		400/1	6.67	0.00	
B.93	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Shahapur		800/1	7.14	0.00	
B.94	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Shahapur		400/1	2.31	0.00	
B.95	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Shorapur		600/1	0.57	0.00	
B.96	Kalaburagi	Kalaburagi	110/33 KV Bank-2	Shorapur		400/1	6.13	0.00	
B.97	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Shorapur		800/A1	7.05	0.00	
B.98	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Shorapur		200/1	3.55	0.00	
B.99	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Yadgir		800/1	8.02	0.00	
B.100	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Yadgir		400/1	6.39	0.00	
B.101	Kalaburagi	Kalaburagi	110/11 KV Bank-3	Yadgir		400/1	2.91	0.00	
B.102	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Kankal		800/1	2.96	0.00	
B.103	Kalaburagi	Kalaburagi	110/11 KV bank-II	Kankal		400/1	2.03	0.00	
B.104	Kalaburagi	Kalaburagi	110/33 KV bank-II	Kankal		600/1	2.59	0.00	
B.105	Kalaburagi	Kalaburagi	110/11KV Bank-1	Saidapur		300/1	2.66	0.00	
B.106	Kalaburagi	Kalaburagi	110/11KV Bank-2	Saidapur		600/1	3.18	0.00	
B.107	Kalaburagi	Kalaburagi	110/33KV Bank-2	Saidapur		400/1	2.32	0.00	
B.108	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Kembbhavi		600/1	3.71	0.00	
B.109	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Kembbhavi		600/1	5.60	0.00	
B.110	Kalaburagi	Kalaburagi	110/33 KV Bank-1	Kembbhavi		400/1	1.89	0.00	
B.111	Kalaburagi	Kalaburagi	110/11 KV Bank-1	Shahapur 220 KV		800/1	2.86	0.00	
B.112	Kalaburagi	Kalaburagi	110/11 KV Bank-2	Shahapur 220 KV		800/1	2.17	0.00	
B.113	Kalaburagi	Kalaburagi	110/11KV Bank	Wadgera		600/1	4.82	0.00	
B.114	Kalaburagi	Kalaburagi	110/33 KV Bank	Wadgera		400/1	3.01	0.00	
B.115	Kalaburagi	Kalaburagi	110/11KV Bank-1	Hunasgi		800/1	5.07	0.00	
B.116	Kalaburagi	Kalaburagi	110/33KV Bank-2	Hunasgi		400/1	6.42	0.00	

B. Meter reading of input energy at injection points

S.No	Zone	Circle	Voltage Level (KVA)	Fender Name	Period from...to...			Remarks (Source of data)	
					Meter S.No	CT/PT ratio	Import (MU)		Export (MU)
B.117	Kalaburagi	Kalaburagi	Kembhavi US	Shorapur					
B.118	Kalaburagi	Kalaburagi	Mudnal Railway Traction	Shorapur			6.83	0.00	
B.119	Kalaburagi	Kalaburagi	11 KV Shahapur (BPCL) to kptcl D-9 Naganatagi MHS to kptcl	Yadgir	300/1	0.48		0.00	
B.120	Kalaburagi	Kalaburagi	33 KV BPCL Rajankollur to kptcl	Yadgir	50/1	1.46		0.00	
B.121	Kalaburagi	Kalaburagi	33 KV Shahapur (Bhoruka)	Yadgir	300/1	2.87		0.00	
B.122	Kalaburagi	Kalaburagi	33 KV Devindrappa M biradar vipp-17 TO KPTCL	Yadgir	175/1	0.80		0.00	
B.123	Kalaburagi	Kalaburagi	33 KV SRS Energy(P) Ltd., Kadrapur to kptcl	wadagere	240/1	2.69		0.00	
B.124	Kalaburagi	Kalaburagi	33kv M/s Bomal Hydro Electric company Limited YIPP-11 To KPTCL	Yadgir	20/1	0.21		0.00	
B.125	Kalaburagi	Kalaburagi	33KV M/s South West Hydro power Ltd. To KPTCL	Yadgir	150/1	1.26		0.00	
B.126	Kalaburagi	Kalaburagi	33KV M/s Bhavana Hydro Electric Limited. to KPTCL	Yadgir	240/1	0.01		0.00	
B.127	Kalaburagi	Kalaburagi	33KV M/s H S Mallikarjun To KPTCL	Yadgir	175/1	0.74		0.00	
B.128	Kalaburagi	Kalaburagi	33kv matrix Green Energy pvt.ltd to KPTCL	110 kv wadagera	200/1	3.35		0.00	
B.129	Kalaburagi	Kalaburagi	33kv m/s Shorapur solar power ltd to KPTCL	400/33 kv Shorapur		0.01		0.00	
B.130	Kalaburagi	Bidar	110/11 KV Bank-1	Bhalki	800/1	1.85		0.00	
B.131	Kalaburagi	Bidar	110/11 KV Bank-2	Bhalki	800/1	2.74		0.00	
B.132	Kalaburagi	Bidar	110/11 KV Bank-3	Bhalki	400/1	3.10		0.00	
B.133	Kalaburagi	Bidar	110/33 KV Bank	Bhalki	400/1	10.98		0.00	
B.134	Kalaburagi	Bidar	110/11 KV Bank-1	Chidri	800/1	3.21		0.00	
B.135	Kalaburagi	Bidar	110/11 KV Bank-1	Chidri	800/1	5.08		0.00	
B.136	Kalaburagi	Bidar	110/11 KV Bank-1	Chidri	800/1	3.85		0.00	
B.137	Kalaburagi	Bidar	110/11 KV Bank-2	Chidri	800/1	6.90		0.00	
B.138	Kalaburagi	Bidar	110/11 KV Bank-2	Chidri	800/1	5.37		0.00	
B.139	Kalaburagi	Bidar	110/11 KV Bank-3	Chidri	500/1	9.72		0.00	
B.140	Kalaburagi	Bidar	110/11 KV Bank-1	Habsikote	800/1	5.18		0.00	
B.141	Kalaburagi	Bidar	110/11 KV Bank-2	Habsikote	800/1	5.65		0.00	
B.142	Kalaburagi	Bidar	110/11 KV Bank-1	Kolhar	800/1	5.61		0.00	
B.143	Kalaburagi	Bidar	110/33 KV Bank-1	Kolhar	600//	15.68		0.00	
B.144	Kalaburagi	Bidar	110/11 KV Bank-3	Kolhar	800/1	10.87		0.00	
B.145	Kalaburagi	Bidar	110/11 KV Bank-4	Kolhar	600/1	3.56		0.00	
B.146	Kalaburagi	Bidar	110/11 KV Bank-1	Kolhar	200/1	2.44		0.00	
B.147	Kalaburagi	Bidar	110/11 KV Bank-2	Santhpur	800/1	0.35		0.00	
B.148	Kalaburagi	Bidar	110/33 KV Bank-1	Santhpur	400/1	1.70		0.00	
B.149	Kalaburagi	Bidar	110/11 KV Bank-1	Santhpur	200/1	2.11		0.00	
B.150	Kalaburagi	Bidar	110/33 KV Bank-1 (B)	Ladha	200/1	6.48		0.00	

B. Meter reading of input energy at injection points

S.No	Zone	Circle	Voltage Level (KVA)	Feeder Name	Period from...to...			Sales	Remarks (Source of data)
					Meter S.No	CT/PT ratio	Import (MU)		
B.151	Kalaburagi	Bidar	110/11 KV Bank-1	Janwada		600/1	3.74	0.00	
B.152	Kalaburagi	Bidar	110/33 KV Bank-1	Janwada		400/1	3.72	0.00	
B.153	Kalaburagi	Bidar	110/11 KV Bank-1	Kamthana		600/1	3.99	0.00	
B.154	Kalaburagi	Bidar	110/33 KV Bank-1	Kamthana		200/1	1.69	0.00	
B.155	Kalaburagi	Bidar	110/11 KV BANK-1	Dongargaon		100/1	1.40	0.00	
B.156	Kalaburagi	Bidar	110/33 KV BANK-1	Dongargaon		200/1	8.33	0.00	
B.157	Kalaburagi	Bidar	110/11 KV Bank-1	M'ekalli		200/1	3.17	0.00	
B.158	Kalaburagi	Bidar	110/33 KV Bank-1	M'ekalli		200/1	5.62	0.00	
B.159	Kalaburagi	Bidar	110/11 KV Bank-1	Kamal Nagar		300/1	4.28	0.00	
B.160	Kalaburagi	Bidar	110/33 KV Bank-1	Kamal Nagar		300/1	3.07	0.00	
B.161	Kalaburagi	Bidar	110/11 KV Bank-1	220 KV Halbarga		800/1	0.66	0.00	
B.162	Kalaburagi	Bidar	110/11 KV Bank-1	Yaktapur		600/1	2.20	0.00	
B.163	Kalaburagi	Bidar	110/11 KV Bank-2	Yaktapur		600/1	1.45	0.00	
B.164	Kalaburagi	Bidar	110/33KV Bank-1(K.Chincholi)	Dabalgundi		200/1	4.49	0.00	
B.165	Kalaburagi	Bidar	11 KV M/s Vedasi Green Energy Pvt Ltd GIPP-09 To KPTCL	Habsikote		125/1	0.79	0.00	
B.166	Kalaburagi	Bidar	11 KV M/s Sharada Doddi Solar GIPP-16 To KPTCL	Habsikote		60/1	0.30	0.00	
B.167	Kalaburagi	Bidar	M/s Sharada Construction PVT Ltd Solar Power Plant to KPTCL GIPP-06	Santhipur		200/1	1.97	0.00	
B.168	Kalaburagi	Bidar	M/s Sharada Construction PVT Ltd Solar Power Plant to KPTCL GIPP-07	Santhipur		200/1	1.46	0.00	
B.169	Kalaburagi	Bidar	11 KV Vensol Energy Pvt Ltd GIPP-10 To KPTCL	Halbarga		200/1	1.05	0.00	
B.170	Kalaburagi	Bidar	M/s Clearsky Solar Pvt Ltd To KPTCL	Santhipur		75/1-1A	1.16	0.00	
B.171	Kalaburagi	Bidar	M/s Aurad Solar Pvt Ltd To KPTCL	Santhipur		75/1-1A	1.06	0.00	
B.172	Kalaburagi	Bidar	33kv M/s chirasthayee saurya limited GIPP-20 to KPTCL	Manni 110kv		250/1-1A	3.70	0.00	
B.173	Kalaburagi	Bidar	33kv M/s E.5 solar system pvt ltd GIPP-20 TO KPTCL	Kamthana		250/1	3.67	0.00	
B.174	Kalaburagi	Bidar	33KVM/S Manvel solar pvt ltd Janwada	110KV MUSS JANWADA		200/1-1A	4.76	0.00	
B.175	Kalaburagi	Bidar	110/11 KV Bank-1	Humnabad 110 KV		800/1	5.82	0.00	
B.176	Kalaburagi	Bidar	110/11 KV Bank-2	Humnabad 110 KV		400/1	3.66	0.00	
B.177	Kalaburagi	Bidar	110/33 KV Bank-1	Humnabad 110 KV		400/1	6.41	0.00	
B.178	Kalaburagi	Bidar	110/33 KV Bank-2	Humnabad 110 KV		200/1	3.77	0.00	
B.179	Kalaburagi	Bidar	110/11 KV Bank-1	Humnabad 220 KV		600/1	9.22	0.00	
B.180	Kalaburagi	Bidar	110/11 KV Bank-2	M'ekalli		400/1	3.36	0.00	
B.181	Kalaburagi	Bidar	110/11 KV Bank-1	Sastapur 110KV		800/1	3.99	0.00	
B.182	Kalaburagi	Bidar	110/11 KV Bank-2	Sastapur 110KV		800/1	4.00	0.00	
B.183	Kalaburagi	Bidar	110/33 KV Bank-1	Sastapur 110KV		200/1	3.90	0.00	
B.184	Kalaburagi	Bidar	110/33 KV Bank-2	Sastapur 110KV		200/1	5.77	0.00	

B. Meter reading of Input energy at injection points

S.No	Zone	Circle	Voltage Level (KVA)	Feeder Name	Period from...to...			Remarks (Source of data)	
					Meter S.No	CT/PT ratio	Import (MU)		Export (MU)
B.185	Kalaburagi	Bidar	110/11 KV Bank-1	Manthal		600/1	0.71	0.00	
B.186	Kalaburagi	Bidar	110/11 KV Bank-2	Manthal		300/1	2.05	0.00	
B.187	Kalaburagi	Bidar	110/33 KV Bank	Manthal		1000/1	5.15	0.00	
B.188	Kalaburagi	Bidar	110/11 KV Bank-1	Chittaguppa		800/1	4.30	0.00	
B.189	Kalaburagi	Bidar	110/11 KV Bank-2	Chittaguppa		800/1	2.91	0.00	
B.190	Kalaburagi	Bidar	110/11 KV Bank-1	Rajeshwar		600/1	2.24	0.00	
B.191	Kalaburagi	Bidar	110/11 KV Bank-2	Rajeshwar		600/1	2.69	0.00	
B.192	Kalaburagi	Bidar	110/11 KV Bank-1	Hallikhed		600/1	2.90	0.00	
B.193	Kalaburagi	Bidar	110/11 KV Bank-2	Hallikhed		600/2	3.68	0.00	
B.194	Kalaburagi	Bidar	110/33 KV Bank-1	Hallikhed		200/1	1.45	0.00	
B.195	Kalaburagi	Bidar	110/11 KV Bank-1	Nirma		600/1	2.81	0.00	
B.196	Kalaburagi	Bidar	110/11 KV Bank-2	Nirma		600/1	3.17	0.00	
B.197	Kalaburagi	Bidar	110/11kv Bank-1	Dabalgundi		100/1	2.74	0.00	
B.198	Kalaburagi	Bidar	M/s Bidar Solar Power Plant to KPTCL	Manna-E-Rheli		200/1	2.82	0.00	
B.199	Kalaburagi	Bidar	M/s K.K Rao Green Energy Pvt Ltd Solar Power Plant. to KPTCL GIPP-08	Chitguppa		160/1	0.90	0.00	
B.200	Kalaburagi	Bidar	11 kv NTPP Pvt Ltd to KPTCL	Rajeshwar		125/1	0.78	0.00	
B.201	Kalaburagi	Bidar	11 kv Vensol Energy Pvt Ltd GIPP-11 TO KPTCL	Nirma		200/1	1.08	0.00	
B.202	Kalaburagi	Bidar	11kv M/s satyadsepa pharmaceuticals Ltd chittaguppa	110KV Chittaguppa		0	1.62	0.00	
B.203	Ballari	Raichur	110/11 KV Bank-1	APMC Raichur 110 KV		800/1	0.79	0.00	
B.204	Ballari	Raichur	110/11 KV Bank-2	APMC Raichur 110 KV		800/1	9.02	0.00	
B.205	Ballari	Raichur	110/11 KV Bank-3	APMC Raichur 110 KV		400/1	3.30	0.00	
B.206	Ballari	Raichur	110/33 KV Bank-1	APMC Raichur 110 KV		400/1	9.26	0.00	
B.207	Ballari	Raichur	110/11 KV Bank-1	Raichur 220 KV R/S		800/1	5.36	0.00	
B.208	Ballari	Raichur	110/11 KV Bank-2	Raichur 220 KV R/S		800/1	7.44	0.00	
B.209	Ballari	Raichur	110/11 KV Bank-3	Raichur 220 KV R/S		800/1	11.93	0.00	
B.210	Ballari	Raichur	110/11 KV bank-1	Maliyabad		400/1	7.13	0.00	
B.211	Ballari	Raichur	110/11 KV bank-1	vadavatti		600/1	6.65	0.00	
B.212	Ballari	Raichur	110/11 KV bank-2	vadavatti		600/1	8.06	0.00	
B.213	Ballari	Raichur	110/11 KV Bank-1	Deodurga		800/1	5.99	0.00	
B.214	Ballari	Raichur	110/11 KV Bank-2	Deodurga		400/1	1.25	0.00	
B.215	Ballari	Raichur	110/33 KV Bank-1	Deodurga		400/1	8.04	0.00	
B.216	Ballari	Raichur	110/33 KV Bank-2	Deodurga		400/1	9.14	0.00	
B.217	Ballari	Raichur	110/11KV Bank-1	Chicksugur		600/1	6.02	0.00	
B.218	Ballari	Raichur	110/11KV Bank-2	Chicksugur		400/1	2.79	0.00	
B.219	Ballari	Raichur	110/11KV Bank-3	Chicksugur		400/1	4.66	0.00	
B.220	Ballari	Raichur	110/33 KV Bank-1	Chicksugur		200/1	2.42	0.00	
B.221	Ballari	Raichur	110/11 kv Bank-1	Gabbur		800/1	4.05	0.00	
B.222	Ballari	Raichur	110/11 KV Bank-1	Kavital		800/1	4.87	0.00	
B.223	Ballari	Raichur	110/11 KV Bank-2	Kavital		800/1	3.26	0.00	

B. Meter reading of input energy at injection points

S.No	Zone	Circle	Voltage Level (KVA)	Feeder Name	Meter S.No	Period from...to...		Sales	Remarks (Source of data)
						CT/PT ratio	Import (MU)		
B.224	Ballari	Raichur	110/11KV Bank-I	Kurdi Cross		600/1	3.93	0.00	
B.225	Ballari	Raichur	110/33KV Bank-I	Kurdi Cross		400/1	7.52	0.00	
B.226	Ballari	Raichur	110/11 KV Bank-1	Manvi		800/1	11.85	0.00	
B.227	Ballari	Raichur	110/11 KV Bank-2	Manvi		600/1	3.76	0.00	
B.228	Ballari	Raichur	110/11 KV Bank-1	Madalapur		600/1	2.86	0.00	
B.229	Ballari	Raichur	110/11 KV Bank-2	Madalapur		800/1	3.05	0.00	
B.230	Ballari	Raichur	110/11 KV Bank-1	Waikamdinni		600/1	2.93	0.00	
B.231	Ballari	Raichur	110/11KV BANK-2	Walkamdinni		800/1	2.22	0.00	
B.232	Ballari	Raichur	110/11 kv Bank-1	Sirwar		800/1	7.03	0.00	
B.233	Ballari	Raichur	110/11 KV bank-1	Alkod		800/1	3.45	0.00	
B.234	Ballari	Raichur	110/11 KV bank-2	Alkod		800/1	0.02	0.00	
B.235	Ballari	Raichur	110/11 KV bank-2	Maliyabad		400/1	3.18	0.00	
B.236	Ballari	Raichur	110/11 KV bank-1	Byagwat		600/1	2.99	0.00	
B.237	Ballari	Raichur	110/11 KV Bank-I	Shakthi Nagar		800/1	2.69	0.00	
B.238	Ballari	Raichur	110/11 KV bank-II	Shakthi Nagar		800/1	6.53	0.00	
B.239	Ballari	Raichur	110/11 KV bank-II	Matnari		600/1	4.82	0.00	
B.240	Ballari	Raichur	110/11 kv Bank-I	Gallag		600/1	4.17	0.00	
B.241	Ballari	Raichur	110/11 KV Bank-I	Googal		600/1	2.57	0.00	
B.242	Ballari	Raichur	110/11kv bank-I	Mallat		800/1A	4.27	0.00	
B.243	Ballari	Raichur	110/11 KV Bank-1	Yeragera(110kv)			3.58	0.00	
B.244	Ballari	Raichur	110/11KV Bank-2	Yeragera(110kv)			4.52	0.00	
B.245	Ballari	Raichur	110/33 KV Bank-1	Yeragera(110kv)			3.16	0.00	
B.246	Ballari	Raichur	110/11 KV Bank-1	Yapaldinni			4.61	0.00	
B.247	Ballari	Raichur	110/11KV BANK-2	Yapaldinni			4.31	0.00	
B.248	Ballari	Raichur	110/33 KV Bank-2	Raichur 220 KV R/S		400/1	6.70	0.00	
B.249	Ballari	Raichur	110/33 KV Bank-1	Walkamdinni		100/1	2.75	0.00	
B.250	Ballari	Raichur	110/11kv Bank	110 KV Adavi Amreshwar		800/1	1.78	0.00	
B.251	Ballari	Raichur	11 KV M/s Yapaldinni to KPTCL	221 kv Raichur		100/1	0.53	0.00	
B.252	Ballari	Raichur	33 KV M/s Manchikonda Agro Tech Pvt. Ltd to KPTCL	110 kv chicksugur		100/1	3.86	0.00	
B.253	Ballari	Raichur	33 KV M/s P. Somachandra Solar Power Plant to KPTCL	110 kv chicksugur		250/1	4.83	0.00	
B.254	Ballari	Raichur	11 KV M/s Sirwar Renewable Energy Pvt Ltd to KPTCL	110 kv Sirwar		150/1	0.73	0.00	
B.255	Ballari	Raichur	110/11 KV Bank-2	Hatti		800/1	6.05	0.00	
B.256	Ballari	Raichur	110/11 KV Bank-1	Lingasugur 220 KV		400/1	0.64	0.00	
B.257	Ballari	Raichur	110/11 KV Bank-2	Lingasugur 220 KV		200/1	6.45	0.00	
B.258	Ballari	Raichur	110/33 KV Bank-1	Lingasugur 220 KV		200/1	2.64	0.00	
B.259	Ballari	Raichur	110/33 KV Bank-2	Lingasugur 220 KV		200/1	2.67	0.00	
B.260	Ballari	Raichur	110/33 KV Bank-3	Lingasugur 220 KV		200/1	3.95	0.00	
B.261	Ballari	Raichur	110/11 kv Bank-1	Mudgal		600/1	4.58	0.00	

B. Meter reading of input energy at injection points

S.No	Zone	Circle	Voltage Level (KVA)	Feeder Name	Period from...to...			Remarks (Source of data)	
					Meter S.No	CT/PT ratio	Import (MTU)		
B.262	Ballari	Raichur	110/11 KV Bank-2	Mudgal		800/1	1.07	0.00	
B.263	Ballari	Raichur	110/33 KV Bank-1	Mudgal		400/1	6.64	0.00	
B.264	Ballari	Raichur	110/11 KV Bank-1	Muddapur		600/1A	4.83	0.00	
B.265	Ballari	Raichur	110/11 KV Bank-1	Sindhanoor		200/5	4.06	0.00	
B.266	Ballari	Raichur	110/11 KV Bank-2	Sindhanoor		800/5	3.70	0.00	
B.267	Ballari	Raichur	110/11 KV Bank-3	Sindhanoor		300/5	5.51	0.00	
B.268	Ballari	Raichur	110/33 KV Bank-1	Sindhanoor		400/1	5.28	0.00	
B.269	Ballari	Raichur	110/33 KV Bank-2	Sindhanoor		400/1	5.44	0.00	
B.270	Ballari	Raichur	110/33 KV Bank-1	Sindhanoor		600/1	4.05	0.00	
B.271	Ballari	Raichur	110/11 KV bank-1	Gurugunta		800/1	3.84	0.00	
B.272	Ballari	Raichur	110/11 KV bank-2	Mukkunda		800/1	2.58	0.00	
B.273	Ballari	Raichur	110/11 KV bank-1	Mukkunda		600/1	3.98	0.00	
B.274	Ballari	Raichur	110/11 KV bank-2	Dhadesugur		600/1	1.68	0.00	
B.275	Ballari	Raichur	110/11 KV bank-1	Dhadesugur		600/1	5.44	0.00	
B.276	Ballari	Raichur	110/11 KV bank-1	Maski		600/1	5.13	0.00	
B.277	Ballari	Raichur	110/11 KV bank-1	Turvihal		100/1	1.82	0.00	
B.278	Ballari	Raichur	110/11 KV bank-1	Turvihal		800/1	0.19	0.00	
B.279	Ballari	Raichur	110/11KV Bank-1	220KV R/S Sindanoor		600/1	2.25	0.00	
B.280	Ballari	Raichur	110/11 KV Bank-2	Bayyapur		100/1	12.02	0.00	
B.281	Ballari	Raichur	110KV M/s Hatti Gold Mines Co. Ltd HEHT-1	Hatti		200/1A	2.59	0.00	
B.282	Ballari	Koppal	33kv m/s Matrix Green energy put ltd TO KPTCL	220kv R/s Raichur		600/1	2.54	0.00	
B.283	Ballari	Koppal	110/33 KV Bank-1	Bevoor		400/1	3.25	0.00	
B.284	Ballari	Koppal	110/33 KV Bank-1	Bevoor		400/1	3.23	0.00	
B.285	Ballari	Koppal	110/11KV Bank-1	Bevoor		1200/1	12.16	0.00	
B.286	Ballari	Koppal	110/11 KV Bank-2	Koppal		800/1	4.86	0.00	
B.287	Ballari	Koppal	110/33 KV Bank-2	Koppal		400/1	7.60	0.00	
B.288	Ballari	Koppal	110/33 KV Bank-2	Koppal		400/1	12.93	0.00	
B.289	Ballari	Koppal	110/11 KV Bank-1	Kushitag		600/1	3.69	0.00	
B.290	Ballari	Koppal	110/11 KV Bank-2	Ginjigera		600/1	7.40	0.00	
B.291	Ballari	Koppal	110/33 KV Bank-1	Ginjigera		200/1	7.12	0.00	
B.292	Ballari	Koppal	110/11KV Bank-1	Ginjigera		800/1	2.08	0.00	
B.293	Ballari	Koppal	110/11 KV Bank-2	Yelburga		800/1	2.59	0.00	
B.294	Ballari	Koppal	110/33 KV Bank-1	Yelburga		400/1	5.81	0.00	
B.295	Ballari	Koppal	110/33KV Bank-2	Yelburga		400/1	7.52	0.00	
B.296	Ballari	Koppal	110/11KV Bank-1	Ganadal		600/1	3.33	0.00	
B.297	Ballari	Koppal	110/11KV Bank-2	Ganadal		600/1	3.02	0.00	
B.298	Ballari	Koppal	110/11 KV bank-1	Betagera		800/1	4.41	0.00	
B.299	Ballari	Koppal	110/11 KV bank-2	Betagera		800/1	2.48	0.00	
B.300	Ballari	Koppal	110/33 KV bank-1	Betagera		400/1	3.28	0.00	
B.301	Ballari	Koppal	110/11 KV bank-1	Kerehalli		600/1	3.03	0.00	

B. Meter reading of input energy at injection points

S.No	Zone	Circle	Voltage Level (KVA)	Feeder Name	Meter S.No	Period from...to...			Remarks (Source of data)
						CT/PT ratio	Import (MU)	Export (MU)	
B.302	Bailari	Koppal	110/11 KV bank-2	Kerehalli		600/1	3.29	0.00	
B.303	Bailari	Koppal	110/33 KV bank-1	Kerehalli		400/1	5.38	0.00	
B.304	Bailari	Koppal	110/11 KV bank-1	Halavati		800/1	1.32	0.00	
B.305	Bailari	Koppal	110/11KV Bank-1	220 kv Munirabad PH		400/1	3.44	0.00	
B.306	Bailari	Koppal	110/11KV Bank-1	Managaluru		600/1	2.70	0.00	
B.307	Bailari	Koppal	110/11KV Bank-2	Managaluru		600/1	3.36	0.00	
B.308	Bailari	Koppal	110/11KV Bank-1	Kuknoor		600/1	1.57	0.00	
B.309	Bailari	Koppal	110/11KV Bank-2	Kuknoor		600/1	2.90	0.00	
B.310	Bailari	Raichur	111 KV M/s Kirloskar Ferus India Ltd. Bevinhalli MHT-18	Lingsugur		75/1	3.97	0.00	
B.311	Bailari	Raichur	220 KV M/s Kalyani Ferus India P.Ltd Ginigeru MHT-20	Lingsugur		75/1	26.81	0.00	
B.312	Bailari	Raichur	M/s. Praxair (India) P.Ltd Genigera (MRB) MHT-34	Guddadahalli		100/5	27.51	0.00	
B.313	Bailari	Raichur	M/s Ultra Tech cement 220kv, Ginigera	Guddadahalli		25/1	7.90	0.00	
B.314	Bailari	Raichur	MSP Ltd, Halwarthy	Guddadahalli		50/1	16.26	0.00	
B.315	Bailari	Raichur	Mukkunda Limited	Guddadahalli		60/1	19.12	0.00	
B.316	Bailari	Raichur	X India Steels Ltd Kunikera Koppal 220kv.	Lingsugur		125/1	9.20	0.00	
B.317	Bailari	Koppal	220 kv HRG Alloys Pvt. Ltd Kasanakandi	Lingapura		50/1	8.56	0.00	
B.318	Bailari	Koppal	M/s Mukund Sumi spl Steels Pvt Ltd	220 kv Munirabad			6.35	0.00	
B.319	Bailari	Koppal	33 KV Madhav Solar Bay-1 LGS-40 to KPTCL	110 kv Bevoor Export		200/1	1.78	0.00	
B.320	Bailari	Koppal	33 KV Madhav Solar Bay-2 LGS-41 to KPTCL	110 kv Bevoor Export			1.84	0.00	
B.321	Bailari	Koppal	11 kv Guttur Solar Power LLP, #823, Hosalingapur DEGUSFS-GSP-02 to KPTCL	110 kv Bevoor Export			0.38	0.00	
B.322	Bailari	Koppal	33 kv M/s V R Patil Vividh Vidyut Nirman Pvt Ltd, DEGUSFS- VBP-01, Gurukrupa, Hoslingapur to KPTCL	110 kv Bevoor Export			1.16	0.00	
B.323	Bailari	Koppal	33 kv M/s Shringowda & Chandragiri Power Infra LLP to KPTCL	110 kv Kerehalli Export			0.68	0.00	
B.324	Bailari	Koppal	11 kv M/s Pratibha Solar Power LLP DEGUSFS-PSP-01to KPTCL	110 kv Koppal Export			0.36	0.00	
B.325	Bailari	Koppal	33 kv M/s Kavlt Green Energ Pvt Ltd to KPTCL	110 kv Bevoor Export			1.92	0.00	
B.326	Bailari	Koppal	33 kv M/s koppal Solar Power Projects Pvt.Ltd to KPTCL	110 kv Kerehalli Export			0.64	0.00	
B.327	Bailari	Koppal	33kv m/s Estern solar energy pvt ltd yeliburga to KPTCL	110kv yeliburga		200/1	1.49	0.00	
B.328	Bailari	Koppal	33kv M/s JK Petroenergy pvt Ltd to KPTCL	110KV Betgera		200/1A	4.37	0.00	

B. Meter reading of input energy at injection points

S.No	Zone	Circle	Voltage Level (KVA)	Feeder Name	Period from ...to...			Remarks (Source of data)	
					Meter S.No.	CT/PT ratio	Import (MU)		
					Export (MU)	Sales			
B.329	Ballari	Koppal	33kv M/s P Balasubby Shetty Power & Steel	110KV Gimgigera		75/1A	1.13	0.00	
B.330	Ballari	Koppal	110/11KV Bank-1	Gangavati		800/1	14.32	0.00	
B.331	Ballari	Koppal	110/11KV Bank-3	Gangavati		800/1	5.60	0.00	
B.332	Ballari	Koppal	110/11 KV Bank-4	Gangavati		800/1	4.31	0.00	
B.333	Ballari	Koppal	110/33 KV Bank-1	Gangavati		400/1	3.69	0.00	
B.334	Ballari	Koppal	110/11KV Bank-1	Kanakagiri		600/1	5.66	0.00	
B.335	Ballari	Koppal	110/11KV Bank-2	Kanakagiri		600/1	5.75	0.00	
B.336	Ballari	Koppal	110/33 KV Bank-1	Kanakagiri		400/1	2.47	0.00	
B.337	Ballari	Koppal	110/11KV Bank-1	Kanakagiri		800/1	5.15	0.00	
B.338	Ballari	Koppal	110/11 KV Bank-2	Karatagi		800/1	3.48	0.00	
B.339	Ballari	Koppal	110/11 KV Bank-3	Karatagi		1200/1	4.03	0.00	
B.340	Ballari	Koppal	110/11KV Bank-1	Kushtagi		800/1	4.72	0.00	
B.341	Ballari	Koppal	110/11KV Bank-2	Kushtagi		800/1	5.31	0.00	
B.342	Ballari	Koppal	110/11 KV Bank-3	Kushtagi		600/1	1.11	0.00	
B.343	Ballari	Koppal	110/33 KV Bank - 1 Dohal	Kushtagi		400/1	4.73	0.00	
B.344	Ballari	Koppal	110/11KV Bank-1	Sreerama Nagar		800/1	3.92	0.00	
B.345	Ballari	Koppal	110/11KV Bank-2	Sreerama Nagar		800/1	6.33	0.00	
B.346	Ballari	Koppal	110/11KV Bank-1	Venkatgiri		800/1	4.67	0.00	
B.347	Ballari	Koppal	110/11KV Bank-II	Venkatgiri		800/1	7.84	0.00	
B.348	Ballari	Koppal	110/11 KV Bank-I	Hanumsagar		800/1	2.81	0.00	
B.349	Ballari	Koppal	110/11 KV Bank-2	Hanumsagar		200/1	2.43	0.00	
B.350	Ballari	Koppal	110/33 KV Bank-1	Hanumsagar		200/1	2.61	0.00	
B.351	Ballari	Koppal	110/11KV Bank-I	Hiregannagara		600/1	2.83	0.00	
B.352	Ballari	Koppal	110/11 KV bank-I	Hannunnal		800/1	1.60	0.00	
B.353	Ballari	Koppal	110/11 KV bank-II	Hannunnal		800/1	3.12	0.00	
B.354	Ballari	Koppal	110/11 KV Bank-I	Navali		600/1A	2.52	0.00	
B.355	Ballari	Koppal	110/11 KV bank-II	Navali		600/1A	5.52	0.00	
B.356	Ballari	Koppal	110/11 KV Bank-I	Yeradona		600/1A	7.22	0.00	
B.357	Ballari	Koppal	110/11 KV Bank-I	Bennur		600/1A	5.58	0.00	
B.358	Ballari	Koppal	110/11 KV bank-1	Mallapur		600/1-1-1A	4.17	0.00	
B.359	Ballari	Koppal	33 KV Indra Power Energies, Chikkajantekal to KPTCL	Gangavati Import		150/1	4.04	0.00	
B.360	Ballari	Koppal	11 KV Sri Krishna Minerals, Hanumsagar Wind Mills, Kushtagi Tal, LGS-17 to KPTCL	Munirabad Export		300/1	0.10	0.00	
B.361	Ballari	* Koppal	11 kv M/s Doddannavar Brothers renamed as Hexa Wind Hanumsagar Wind Mills, Kushtagi Tal, LGS-18 to KPTCL	Munirabad Export		100/1	0.22	0.00	

B. Meter reading of input energy at injection points

S.No	Zone	Circle	Voltage Level (KVA)	Feeder Name	Meter S.No	Period from...to...			Remarks (Source of data)
						CT/PT ratio	Import (MU)	Export (MU)	
B.362	Bailari	Koppal	11 kv Sri Krishna Minerals, Hanumsagar Wind Mills, Kushtagi Tal, LGS-19 to KPTCL	Munirabad Export		120/1	0.32	0.00	
B.363	Bailari	Koppal	33 kv M/s Indo wind Energy to KPTCL	110 kv Hanumsagar		150/1	0.56	0.00	
B.364	Bailari	Koppal	33kv TATA power solar system ltd to KPTCL	110KV Kanakgiri		350/1A	7.61	0.00	
B.365	Bailari	Bailari	110/11 KV Bank-1	Sankalpura		1200/1	13.04	0.00	
B.366	Bailari	Bailari	110/11 KV Bank-3	Sankalpura		1200/1	6.43	0.00	
B.367	Bailari	Bailari	110/33KV Bank	GSD Munirabad		400/1	18.44	0.00	
B.368	Bailari	Bailari	110/11 KV Bank-1	Kampili		600/1	5.36	0.00	
B.369	Bailari	Bailari	110/11 KV Bank-2	Kampili		800/1	4.53	0.00	
B.370	Bailari	Bailari	110/33 KV Bank-1	Kampili		200/1-1-1	9.61	0.00	
B.371	Bailari	Bailari	110/11 KV Bank-1	Kamalapura		600/1	6.70	0.00	
B.372	Bailari	Bailari	110/11 KV Bank-2	Kamalapura		600/1	4.38	0.00	
B.373	Bailari	Bailari	66/11 KV Bank-2	Venklapura		600/1	4.01	0.00	
B.374	Bailari	Bailari	66/11 KV Bank-2	Venklapura		600/1	3.17	0.00	
B.375	Bailari	Bailari	110/11kv Bank-1	Metri Devlapur		600/1	3.63	0.00	
B.376	Bailari	Bailari	110 kv JSW Steel (W/s) EHT-34	GSD Munirabad		25/1-1 A	5.20	0.00	
B.377	Bailari	Bailari	110 kv M/s RBSSN Mines Pvt Ltd, Sanklapur - EHT-28	Shankalapur		75/1	2.30	0.00	
B.378	Bailari	Bailari	110 kv Star Metallics Vyasankere VHT-20	GSD Munirabad		200/1-1A	1.80	0.00	
B.379	Bailari	Bailari	220 kv HKT Mining Hospet (BMM Ispat Unit-1) DNEHT-15	Lingapur		50/1	0.05	0.00	
B.380	Bailari	Bailari	M/S south westrn Railway Karigpur	110/11kv Sanklapur		200/1-1A	0.37	0.00	
B.381	Bailari	Bailari	11 kv M/s Vatsala Bailari Solar Project Pvt Ltd to KPTCL	Kampili		100/1 A	0.84	0.00	
B.382	Bailari	Bailari	11 kv M/s Sai pet performance upparhalli to KPTCL	Metri s/s		175/1	1.66	0.00	
B.383	Bailari	Bailari	66/11 KV Bank-1	Chikkajoggi Hally		800/1	3.16	0.00	
B.384	Bailari	Bailari	66/11 KV Bank-2	Chikkajoggi Hally		600/1	4.92	0.00	
B.385	Bailari	Bailari	66/11kv Bank-1	Banavikal		400/1	1.78	0.00	
B.386	Bailari	Bailari	66/11kv Bank-2	Banavikal		400/1	1.06	0.00	
B.387	Bailari	Bailari	66/11 KV Bank-1	Gudekote		300/1	2.30	0.00	
B.388	Bailari	Bailari	66/11 KV Bank-2	Gudekote		330/1A	3.03	0.00	
B.389	Bailari	Bailari	66/11 KV Bank-1	H.B.Halli		800/1	6.15	0.00	
B.390	Bailari	Bailari	66/11 KV Bank-2	H.B.Halli		400/1	5.01	0.00	

B. Meter reading of input energy at injection points

S.No	Zone	Circle	Voltage Level (KVA)	Feeder Name	Period from...to...			Sales	Remarks (Source of data)
					Meter S.No	CT/PT ratio	Import (MTU)		
8.391	Ballari	Ballari	66/11 KV Bank-3	H.B.Halli		800/1	2.91	0.00	
8.392	Ballari	Ballari	66/11 KV Bank-1	Morigere		400/1	0.62	0.00	
8.393	Ballari	Ballari	66/11 KV Bank-2	Morigere		400/1	0.05	0.00	
8.394	Ballari	Ballari	66/11 KV Bank-1	Hadagali		400/1	2.43	0.00	
8.395	Ballari	Ballari	66/11 KV Bank-2	Hadagali		400/1	5.70	0.00	
8.396	Ballari	Ballari	66/11 KV Bank-3	Hadagali		400/1	3.39	0.00	
8.397	Ballari	Ballari	66/11 KV Bank-4	Hadagali		400/1	1.55	0.00	
8.398	Ballari	Ballari	66/11 KV Bank-1	Hampasagara		300/1	2.48	0.00	
8.399	Ballari	Ballari	66/11 KV Bank-2	Hampasagara		400/1	2.27	0.00	
8.400	Ballari	Ballari	66/11 KV Bank-1	Kogali		400/1	2.08	0.00	
8.401	Ballari	Ballari	66/11 KV Bank-2	Kogali		600/1	1.92	0.00	
8.402	Ballari	Ballari	66/11 KV Bank-1	Hanasi		400/1	3.56	0.00	
8.403	Ballari	Ballari	66/11 KV Bank-2	Hanasi		400/1	1.99	0.00	
8.404	Ballari	Ballari	66/11 KV Bank-1	Hirehadagali		600/1	3.39	0.00	
8.405	Ballari	Ballari	66/11 KV Bank-2	Hirehadagali		600/1	3.71	0.00	
8.406	Ballari	Ballari	66/11 KV Bank-1	Hossalli		400/1	4.13	0.00	
8.407	Ballari	Ballari	66/11 KV Bank-1	Itagi		400/1	3.43	0.00	
8.408	Ballari	Ballari	66/11 KV Bank-2	Itagi		800/1	2.97	0.00	
8.409	Ballari	Ballari	66/11 KV Bank-1	Kottur		400/1	4.83	0.00	
8.410	Ballari	Ballari	66/11 KV Bank-2	Kottur		400/1	4.30	0.00	
8.411	Ballari	Ballari	66/11 KV Bank-1	Kudligi		800/1	3.71	0.00	
8.412	Ballari	Ballari	66/11 KV Bank-2	Kudligi		400/1	3.38	0.00	
8.413	Ballari	Ballari	66/11 KV Bank-3	Kudligi		300/1	2.60	0.00	
8.414	Ballari	Ballari	66/11 KV Bank-1	Tambrahalli		400/1	3.71	0.00	
8.415	Ballari	Ballari	66/11 KV Bank-2	Tambrahalli		800/1	3.96	0.00	
8.416	Ballari	Ballari	66/11 KV Bank-1	Uppanayakanahalli		800/1A	3.31	0.00	
8.417	Ballari	Ballari	66/11 KV Bank-2	Uppanayakanahalli		800/1A	4.33	0.00	
8.418	Ballari	Ballari	66/11 KV Bank-1	Ujjani		600/1	2.35	0.00	
8.419	Ballari	Ballari	66/11 KV Bank-2	Ujjani			1.94	0.00	
8.420	Ballari	Ballari	66/11 KV Bank-1	Sovenahalli		800/1	2.31	0.00	
8.421	Ballari	Ballari	66/11 KV Bank-2	Sovenahalli		600/1	2.60	0.00	
8.422	Ballari	Ballari	66/11KV Bank-1	Giriyapur		100/1	5.21	0.00	
8.423	Ballari	Ballari	66/11KV Bank-2	Giriyapur		600/1	0.85	0.00	
8.424	Ballari	Ballari	66/11KV Bank-1	Magala		600/1	2.74	0.00	
8.425	Ballari	Ballari	66/11KV Bank-1	Hosagundi		600/1	2.70	0.00	
8.426	Ballari	Ballari	66/11KV Bank-1	Mylara		600/1	3.61	0.00	
8.427	Ballari	Ballari	66/11KV Bank-2	Mylara		600/1	4.53	0.00	
8.428	Ballari	Ballari	66/11KV Bank-1	Bachigonahalli		600/1	1.81	0.00	
8.429	Ballari	Ballari	66/11KV Bank-1	Harvi		600/1	1.77	0.00	
8.430	Ballari	Ballari	66/11KV Bank-1	Badeladaku		400/1	0.74	0.00	
8.431	Ballari	Koppal	220 KV M/s SLR metallics Pvt Ltd, Lokappana Holla - TOD LKEHT-11	Munirebad		100/1-1A	29.28	0.00	

B. Meter reading of Input energy at injection points

S.No	Zone	Circle	Voltage Level (KVA)	Feeder Name	Meter S.No	Period from...to...		Export (MU)	Sales	Remarks (Source of data)
						CT/PT ratio	Import (MU)			
B.432	Ballari	Koppal	66 kv M/s KNNL LIS Rajavala- EHT-GU-02	Munirabad		35/-1-1A	1.52	0.00		
B.433	Ballari	Koppal	66 kv M/s KNNL US Rajavala- EHT-RJ-01	Munirabad		50/1A	1.62	0.00		
B.434	Ballari	Ballari	66kv KNNL LIS Division-2	Malgala		50/1A	0.59	0.00		
B.435	Ballari	Ballari	11 kv Niketan Solar Solution to KPTCL	66 kv Moregere		200/1	1.19	0.00		
B.436	Ballari	Ballari	11 kv N H Renewable Energy Pvt Ltd to KPTCL	66 kv Moregere		200/1	0.36	0.00		
B.437	Ballari	Ballari	11kv m/s cambria solar pvt.ltd (generation) to KPTCL	66 kv Moregere		200/1	1.22	0.00		
B.438	Ballari	Ballari	11kv m/s spangle energy pvt.ltd (generation) to KPTCL	66 kv Moregere		125/1	0.70	0.00		
B.439	Ballari	Ballari	110/11 KV Bank -1	Allipur		1200 / 1	19.76	0.00		
B.440	Ballari	Ballari	110/11 KV Bank -1	Ballari (N)		1200/1	4.79	0.00		
B.441	Ballari	Ballari	110/11 KV Bank -4	Ballari (N)		1200/1	11.87	0.00		
B.442	Ballari	Ballari	110/11 KV Bank -1	Ballari (S)		801 / 1	4.22	0.00		
B.443	Ballari	Ballari	110/11 KV Bank -2	Ballari (S)		800/1	9.03	0.00		
B.444	Ballari	Ballari	110/11 KV Bank -3	Ballari (S)			7.95	0.00		
B.445	Ballari	Ballari	110/11KV Bank	Somasamudra		600/1A	7.52	0.00		
B.446	Ballari	Ballari	110/11KV Bank-2	Bisihalli		800/1	8.16	0.00		
B.447	Ballari	Ballari	220kv R/S Allipura	M/S South western Railway		200/1-1-1A	3.30	0.00		
B.448	Ballari	Ballari	66/11 kv bank-1	Chortur			2.97	0.00		
B.449	Ballari	Ballari	66/11 kv Bank-2	Chortur		200/1	3.18	0.00		
B.450	Ballari	Ballari	110/11 KV Bank -1	Donimalai		800 / 1	1.80	0.00		
B.451	Ballari	Ballari	110/33 KV Bank -1	Donimalai		400/1	12.10	0.00		
B.452	Ballari	Ballari	110/11 KV Bank-1	Moka		800/1	0.18	0.00		
B.453	Ballari	Ballari	110/11 KV Bank-2	Moka		800/1	5.83	0.00		
B.454	Ballari	Ballari	110/33 KV Bank-1	Moka		200/1	3.59	0.00		
B.455	Ballari	Ballari	110/11KV Bank-1	Sirguppa		800 / 1	3.32	0.00		
B.456	Ballari	Ballari	110/11 KV Bank-2	Sirguppa		800 / 1	14.87	0.00		
B.457	Ballari	Ballari	110/11 KV Bank-3	Sirguppa		800 / 1A	8.61	0.00		
B.458	Ballari	Ballari	110/33 KV Bank	Sirguppa		400/1	3.50	0.00		
B.459	Ballari	Ballari	110/11kv bank-1	sirigere cross		800/1A	5.74	0.00		
B.460	Ballari	Ballari	110/11kv bank-2	sirigere cross		800/1A	4.83	0.00		
B.461	Ballari	Ballari	110/11 KV Bank-1	Toragal		1200/1	5.98	0.00		
B.462	Ballari	Ballari	110/11 KV Bank-2	Toragal		1200/1	5.30	0.00		
B.463	Ballari	Ballari	110/33 kv Bank	Toragal		400/1	14.92	0.00		
B.464	Ballari	Ballari	110/11 KV Bank-2	Kurgod		1200/1	9.75	0.00		
B.465	Ballari	Ballari	110/11 KV Bank-1	Kurgod		1200/1	6.29	0.00		
B.466	Ballari	Ballari	110/11 KV Bank-3	Kurgod		1200/1	2.05	0.00		

B. Meter reading of Input energy at injection points

S.No	Zone	Circle	Voltage Level (KVA)	Feeder Name	Period from...to...			Remarks (Source of data)	
					Meter S.No	CT/PT ratio	Import (MU)		Export (MU)
B.467	Ballari	Ballari	110/33 KV Bank-1	Kurgod		400/1	6.52	0.00	
B.468	Ballari	Ballari	110/11 KV Bank-1	Tekkalkota		800/1	4.69	0.00	
B.469	Ballari	Ballari	110/11 KV Bank-2	Tekkalkota		800/1	7.71	0.00	
B.470	Ballari	Ballari	110/33 KV Bank-1	Tekkalkota		400/1	9.57	0.00	
B.471	Ballari	Ballari	110/33 KV Bank -1	Somatsamudra		200/1A	2.14	0.00	
B.472	Ballari	Ballari	110/11KV Bank-1	P/D Halli		600/1A	2.24	0.00	
B.473	Ballari	Ballari	110/33KV Bank-1	Bisihalli		400/1	0.84	0.00	
B.474	Ballari	Ballari	110/11KV Bank-1	Kudhithi		800/1	5.87	0.00	
B.475	Ballari	Ballari	110/11KV Bank-1	Halkundi		600/1	7.30	0.00	
B.476	Ballari	Ballari	110 KV M/s - ACC Ltd., Kudathini, EHT-6 Ballari(Fromkptcl)	Allipur		80/1	9.20	0.00	
B.477	Ballari	Ballari	111 KV M/s SATHAVAHANA ISPAT Ltd. EHT-05 (from kptcl)	M/s Sathavahana		300/1	0.24	0.00	
B.478	Ballari	Ballari	110 KV VRKP Sponge & Power Plant, Ballari	M/s Hottur Steels Bellary		75/1A	11.70	0.00	
B.479	Ballari	Ballari	110 KV M/s BASAI Steels Pvt Ltd	P D Halli		100/1-1	12.10	0.00	
B.480	Ballari	Ballari	110 KV NMDC Ltd	110 KV Donimalai		75/1-1A	5.04	0.00	
B.481	Ballari	Ballari	33KV M/s KMMI Steel Ltd Yerabahalali Village Sandur Tq. Ballari Dist. From KPTCL MRB-24 to KPTCL	Torangal		150/1-1A	0.18	0.00	
B.482	Ballari	Ballari	33 KV BPCL (SLS Power Industries Ltd) Loc: Mannur Sugur, Sirguppe Tq, Ballari Dist MRB-06 Line-2 to KPTCL	Tekkalkota		100/1	1.18	0.00	
B.483	Ballari	Ballari	11 KV Solar (T G Yerriswamy). To KPTCL	Kurgodu		200/1	0.66	0.00	
B.484	Ballari	Ballari	11 KV M/s Mounya Seelam Solar IPP to KPTCL	P.D.Halli		200/1	1.09	0.00	
B.485	Ballari	Ballari	11 KV M/s Phanendra Babu Solar IPP to KPTCL	P.D.Halli		200/1	1.06	0.00	
B.486	Ballari	Ballari	smt. H. KAMALAKSHI to KPTCL	Moka		60/1-1A	0.19	0.00	
B.487	Ballari	Ballari	Railway Traction				0.00	15.08	
B.488	Ballari	Ballari	Open Accesses Sale				0.00	177.13	
B.489	Ballari	Ballari	Wheeling & Banking				0.00	40.45	
B.490	Ballari	Ballari	Station Auxiliary				0.00	1.09	
B.1001					Total (MU)		2146.82	233.75	
B.1002					Net input energy at DISCOM periphery (MU)		1913.06		

GULBARGA ELECTRICITY SUPPLY CO.

Abstract showing the details of 33KV Feeders in GESCOM

SL.No	Name of O&M Divisions	No. of 33 feeders
1	Kalaburgi-csc	14
2	Kalaburgi-1	8
3	Kalaburgi-2	12
4	Sedam	13
5	Yadgir	19
6	Bdar	19
7	Humnabad	10
8	Raichur Urban	1
9	Raichur Rural	12
10	Sindhaur	22
11	Gangavathi	5
12	Koppal	6
13	Hospet Urban	2
14	Hospet Rural	2
15	Bellary Urban	0
16	Bellary Rural	11
	Total	156

Note: The details is enclosed as per the information taken from O&M Division

Statement Showing the details of 33 Feeders coming under GESCOM Jurisdiction

Annexure-A

Sl. No	Name of Zone	Name of Circle	O&M Division	O&M Sub-Division	Name of Taluk	Name of 220/110/66/33KV Sub-station	Name of 33KV feeders	Type of Category
1			O&M Urban Division Hospet	Sub-Division Hospet	Hospet	220/110/33/11KV RS Munirabad	33KV Hospet	-
2			O&M Urban Division Hospet	Sub-Division Hospet	Hospet	220/110/33/11KV RS Munirabad	33KV Gangavathi	
3			O&M Rural Division Hospet	Sub-Division Hospet	Hospet	110/33/11KV Muss Kampili	33KV Ittigi	-
4			O&M Rural Division Hospet	Sub-Division Hospet	Hospet	110/33/11KV Muss Kampili	33KV Kampili	-
5			O&M Rural Division Ballari	Sub-Division Ballari	Sandur	110/33/11KV Muss Donamalai	33KV Sandur	-
6			O&M Rural Division Ballari	Sub-Division Ballari	Sandur	110/33/11KV Muss Donamalai	33KV KIOM	
7			O&M Rural Division Ballari	Sub-Division Ballari	Sandur	110/33/11KV Muss Tornagallu	33KV Vitalapur	-
8	O&M Zone Bellary	O&M Circle Ballari	O&M Rural Division Ballari	Sub-Division Ballari	Ballari	110/33/11KV Muss Moka	33KV Erragudi	-
9			O&M Rural Division Ballari	Sub-Division Ballari	Ballari	110/33/11KV Muss Kurugodu	33KV Emniganur	-
10			O&M Rural Division Ballari	Sub-Division Ballari	Ballari	110/33/11KV Muss Shreedhargada	33KV Gududur	-
11			O&M Rural Division Ballari	Sub-Division Ballari	Ballari	110/33/11KV Muss Bisalahalli	33KV Rupangudi	-
12			O&M Rural Division Ballari	Sub-Division Ballari	Siruguppa	110/33/11KV Muss Tekkalkote	33KV Tekkalkote	-
13			O&M Rural Division Ballari	Sub-Division Ballari	Siruguppa	110/33/11KV Muss Tekkalkote	33KV Kanur	-
14			O&M Rural Division Ballari	Sub-Division Ballari	Siruguppa	110/33/11KV Muss Tekkalkote	33/11KV Rudrapada	-
15			O&M Rural Division Ballari	Sub-Division Ballari	Siruguppa	110/33/11KV Muss Siruguppa	33/11KV Hatchohalli	-
16	Ballari	Ballari	Koppal	Munirabad	Munirabad	220KV RS Munirabad Power House	33KV Koppal	Industrial
17							Madana hipparga	
18					Ballari	110KV C/C Aland	Khajuri	

Statement Showing the details of 33 Feeders coming under GESCOM Jurisdiction

Annexure-A

Sl. No	Name of Zone	Name of Circle	O&M Division	O&M Sub-Division	Name of Taluk	Name of 220/110/66/33KV Sub-station	Name of 33KV feeders	Type of Category
19							Tadakkal	
20							Sarasamba	
21					Aland	110KV S/S Madiyal	Nimbarga	
22							V K Salgar	
23	Transmission Zone, Kalaburagi	Transmission Circle, Kalaburagi	Kalaburagi CSC		Kamalapur	110KV S/S Mahagaon	Ratkal	
24							Kamalapur	
25							Jambga	
26					Kalaburagi	110KV S/S Kalaburagi (North)	Azadpur	
27							44 GIS	
28							GIS Tengli Layout	
29							Chaidapur	
30					Kalaburagi	110KV S/S Kalaburagi (West)	GIS Shanti Nagar	
31	Kalaburagi	Kalaburagi	Kalaburagi Dvin-2	O&M Sub division 110KV S/S Jewargi	Jewargi	110/33-11 KV S/S Jewargi	33 KV Yedrami	
32	Kalaburagi	Kalaburagi	Kalaburagi Dvin-2	O&M Sub division 110KV S/S Jewargi	Jewargi	110/33-11 KV S/S Jewargi	Idle	
33	Kalaburagi	Kalaburagi	Kalaburagi Dvin-2	O&M Sub division 110KV S/S Jewargi	Yadrami	110/33-11 KV S/S Yadrami	33 KV Malli	
34	Kalaburagi	Kalaburagi	Kalaburagi Dvin-2	O&M Sub division 110KV S/S Jewargi	Yadrami	110/33-11 KV S/S Yadrami	33KV JAMIKHANDI LIS	
35	Kalaburagi	Kalaburagi	Kalaburagi Dvin-2	O&M Sub division 110KV S/S Jewargi	Jewargi	110/33-11 KV S/S Mandewal	33 KV Mallabad	
36	Kalaburagi	Kalaburagi	Kalaburagi Dvin-2	O&M Sub division 110KV S/S Jewargi	Jewargi	110/33-11 KV S/S Mandewal	33 KV Nelogi	

Statement Showing the details of 33 Feeders coming under GESCOM Jurisdiction

Annexure-A

Sl. No	Name of Zone	Name of Circle	O&M Division	O&M Sub-Division	Name of Taluk	Name of 220/110/66/33KV Sub-station	Name of 33KV feeders	Type of Category
37	Kalaburagi	Kalaburagi	Kalaburagi Dvin-2	110/33/11KV Chittapur	Chittapur	110/33-11 KV S/S Chittapur	33 KV Alolli	
38	Kalaburagi	Kalaburagi	Kalaburagi Dvin-2	110/33/11KV Chittapur	Chittapur	110/33-11 KV S/S Chittapur	33KV Maikhed	
39	Kalaburagi	Kalaburagi	Kalaburagi Dvin-2	O&M Sub division 110KV S/S Kalagi	Kalagi	110/33-11 KV S/S Korwar Temple	33KV Gundgurti	
40	Kalaburagi	Kalaburagi	Kalaburagi Dvin-2	O&M Sub division 110KV S/S Kalagi	Kalagi	110/33-11 KV S/S Korwar Temple	33KV Kalagi	Pertains to GESCOM
41	Kalaburagi	Kalaburagi	Kalaburagi Dvin-2	110/33/11KV Chittapur	Chittapur	110/33-11 KV S/S Nalwar	33KV Tarakash	
42	Kalaburagi	Kalaburagi	Kalaburagi Dvin-2	110/33/11KV Chittapur	Chittapur	110/33-11 KV S/S Nalwar	33KV Sannati	
43	Kalaburagi	Kalaburagi	Kalaburagi Dvin-1	O&M Sub division 110KV S/S Afzalpur	Afzalpur	110/33-11 KV S/S Afzalpur	F133 KV Chowdapur	
44	Kalaburagi	Kalaburagi	Kalaburagi Dvin-1	O&M Sub division 110KV S/S Afzalpur	Afzalpur	110/33-11 KV S/S Afzalpur	F2 33 KV Ballundagi	
45	Kalaburagi	Kalaburagi	Kalaburagi Dvin-1	O&M Sub division 110KV S/S Afzalpur	Afzalpur	110/33-11 KV S/S Afzalpur	F3 33 KV Jasper	
46	Kalaburagi	Kalaburagi	Kalaburagi Dvin-1	O&M Sub division 110KV S/S Afzalpur	Afzalpur	110/33-11KV S/S Karajagi	33 KV Manoor	
47	Kalaburagi	Kalaburagi	Kalaburagi Dvin-1	O&M Sub division 110KV S/S Afzalpur	Afzalpur	110/33-11KV S/S Karajagi	33 KV udachan	
48	Kalaburagi	Kalaburagi	Kalaburagi Dvin-1	O&M Sub division 110KV S/S Afzalpur	Afzalpur	110/33-11KV S/S Chowdapur	33KV Akaigi	
49	Kalaburagi	Kalaburagi	Kalaburagi Dvin-1	O&M Sub division 110KV S/S Afzalpur	Afzalpur	110/33-11KV S/S Chowdapur	Idle	
50	Kalaburagi	Kalaburagi	Yadgir	Yadgir	Yadgir	110/33/11KV Kanapur	33KV , Thanagundi	
51	Kalaburagi	Kalaburagi	Yadgir	Yadgir	Yadgir	110/33/11KV Yadagiri	33KV Hattikumi	
52	Kalaburagi	Kalaburagi	Yadgir	Yadgir	Yadgir	110/33/11KV Yadagiri	33KV , Balichakra	
53	Kalaburagi	Kalaburagi	Yadgir	Yadgir	Yadgir	110/33/11KV Saidapur	33KV Kadechuru	
54	Kalaburagi	Kalaburagi	Yadgir	Yadgir	Yadgir	110/33/11KV Nalwar	33KV Yeragola	

Statement Showing the details of 33 Feeders coming under GESCO Jurisdiction

Annexure-A

Sl. No	Name of Zone	Name of Circle	O&M Division	O&M Sub-Division	Name of Taluk	Name of Sub-station	Name of 33KV feeders	Type of Category
55	Kalaburagi	Kalaburagi	Yadgir	Gurmitkal	Gurmitkal	110/33/11KV Saidepur	33KV, Baddepalli	
56	Kalaburagi	Kalaburagi	Yadgir	Gurmitkal	Gurmitkal	110/33/11KV Konkali	33KV, Gajarkot	
57	Kalaburagi	Kalaburagi	Yadgir	Gurmitkal	Gurmitkal	110/33/11KV Konkali	33KV, Jalgram	
58	Kalaburagi	Kalaburagi	Yadgir	Shahapur	Shahapur	110/33/11KV Wadegera	33KV, Wadegera	
59	Kalaburagi	Kalaburagi	Yadgir	Shahapur	Shahapur	110/33/11KV Wadegera	33KV Bendegumbili	
60	Kalaburagi	Kalaburagi	Yadgir	Shahapur	Shahapur	110/33/11KV Shahapur	33KV Sagar	
61	Kalaburagi	Kalaburagi	Yadgir	Shahapur	Shahapur	110/33/11KV Shahapur	33KV Gogi	
62	Kalaburagi	Kalaburagi	Yadgir	Shahapur	Shahapur	110/33/11KV Kembhavi	33KV, Charnal	
63	Kalaburagi	Kalaburagi	Yadgir	Hunasagi	Hunasagi	110/33/11KV Kembhavi	33KV, Hunasagi	
64	Kalaburagi	Kalaburagi	Yadgir	Hunasagi	Hunasagi	33/11KV Hunasagi	33KV, Kodekal	
65	Kalaburagi	Kalaburagi	Yadgir	Shorapur	Shorapur	110/33/11KV Shorapur	33KV, Kakkera	
66	Kalaburagi	Kalaburagi	Yadgir	Shorapur	Shorapur	110/33/11KV Shorapur	33KV Pet-Ammapura	
67	Kalaburagi	Kalaburagi	Yadgir	Shorapur	Shorapur	110/33/11KV Shorapur	33KV Suguru	
68	Kalaburagi	Kalaburagi	Yadgir	Shorapur	Shorapur	110/33/11KV Shorapur	33KV Thippanatagi	
69	Kalaburagi	Kalaburagi	Sedam	Sedam	Sedam	110kv muss chinchelli	33KV, Malkhed	
70	Kalaburagi	Kalaburagi	Sedam	Sedam	Sedam	110kv muss Sedam	33KV Kodla	
71	Kalaburagi	Kalaburagi	Sedam	Sedam	Sedam	110kv muss Sedam	33KV, Mudhol	
72*	Kalaburagi	Kalaburagi	Sedam	Sedam	Sedam	110kv muss Gurmitkal	33KV, Tolmamdi	

Statement Showing the details of 33 Feeders coming under GESCOM Jurisdiction

Annexure-A

Sl. No	Name of Zone	Name of Circle	O&M Division	O&M Sub-Division	Name of Taluk	Name of 220/110/66/33KV Sub-station	Name of 33KV feeders	Type of Category
73	Kalaburagi	Kalaburagi	Sedam	Sedam	Sedam	110kv muss Sedam	33KV, Koikunda	
74	Kalaburagi	Kalaburagi	Sedam	Chincholli	Chincholli	110kv muss chincholli	33KV, Nidgunda	
75	Kalaburagi	Kalaburagi	Sedam	Chincholli	Chincholli	110kv muss mahagaon	33KV, Ratkal	
76	Kalaburagi	Kalaburagi	Sedam	Chincholli	Chincholli	110kv muss chincholli	33KV, Sulepet	
77	Kalaburagi	Kalaburagi	Sedam	Chincholli	Chincholli	110kv muss chincholli	33KV, Chimanchood	
78	Kalaburagi	Kalaburagi	Sedam	Chincholli	Chincholli	110kv muss chincholli	33KV, Miriyani	
79	Kalaburagi	Kalaburagi	Sedam	Chincholli	Chincholli	110kv muss chincholli	33KV, Konchavarum	
80	Kalaburagi	Kalaburagi	Sedam	Chincholli	Chincholli	110kv muss chincholli	33KV, Ainapur	
81			O&M Urban Division Raichur	O&M Urban Sub-Division Raichur	Raichur	110/33/11KV Muss AMPC.	33kv Jawaharnagar	
82					Raichur	110/33/11KV Muss Kurdi Cross.	33kv Gillesugur	
83					Raichur	220/110/33/11KV Receiving Station Raichur .	33kv Yapalinni	
84					Raichur	220/110/33/11KV Receiving Station Raichur .	33kv Kalamala	
85				O&M Rural Sub-Division	Raichur	110/33/11KV Muss AMPC.	33kv Chandrabanda	
86					Raichur	110/33/11KV Muss Yeragera.	33kv Idapnur	
87					Raichur	220/110/33/11KV Receiving Station Raichur .	33/11kv Marnadado	
88			O&M Rural Division Raichur	O&M Sub-Division Ma Marwi	Devadurga	110/33/11KV Muss Kurdi Cross.	33/11kv Rajabanda	
89					Devadurga	110/33/11KV Muss Devadurga.	33/11kv Arakera	
90					Devadurga	110/33/11KV Muss Devadurga.	33/11kv Jalahalli	

Statement Showing the details of 33 Feeders coming under GESCOM Jurisdiction

Annexure-A

Sl. No	Name of Zone	Name of Circle	O&M Division	O&M Sub-Division	Name of Taluk	Name of 220/110/66/33KV Sub-station	Name of 33KV feeders	Type of Category
91				O&M Sub-Division Dev	Devadurga	110/33/11KV Muss Devadurga.	33/11KV Gandhal	-
92					Devadurga	110/33/11KV Muss Devadurga.	33/11KV K.Erabgera	-
93	O&M Zone Bel	O&M Circle Rai			Devadurga	110/33/11KV Muss Devadurga.	33/11KV Koppa	-
94					Lingasugur	220/110/33/11KV Muss Lingasugur.	33/11KV Bayyapur	-
95					Lingasugur	110/33/11KV Muss Mudgal.	33/11KV Nagalapur	-
96				O&M Sub-Division Ling	Lingasugur	220/110/33/11KV Muss Lingasugur.	33/11KV Mavinabhavi	-
97					Lingasugur	220/110/33/11KV Muss Lingasugur.	33/11KV Eachnal	-
98					Lingasugur	220/110/33/11KV Muss Lingasugur.	33/11KV Rodalbanda	-
99					Maski	110/33/11KV Muss Mudgal.	33/11KV Medikinal	-
100			O&M Division Sindhanur	O&M Sub-Division Mar	Maski	110/33/11KV Muss Turvihal.	33/11KV Gunda	-
101					Maski	110/33/11KV Muss Walkamdinni.	33/11KV Balaganur	-
102					Sindhanur	110/33/11KV Muss Sindhanur.	33/11KV Walabellary	-
103					Sindhanur	110/33/11KV Muss Sindhanur.	33/11KV Gorebal	-
104			O&M Sub-Division Sind	O&M Sub-Division Sind	Sindhanur	110/33/11KV Muss Sindhanur.	33/11KV Kurkunda	-
105						110/33/11KV Muss Sindhanur.	Dhaesugur	-
106					Sindhanur	110/33/11KV Muss Walkamdinni.	33/11KV Gonwar	-
107							Bayyapura	-
108	Balfari	Balfari	O&M Division Sindhanur				Rodalbanda	

Statement Showing the details of 33 Feeders coming under GESCOM Jurisdiction

Annexure-A								
Sl. No	Name of Zone	Name of Circle	O&M Division	O&M Sub-Division	Name of Taluk	Name of 220/110/66/33KV Sub-station	Name of 33KV feeders	Type of Category
109							Navali	
110							Anehosur	
111	Ballari	Raichur	O&M Division Sindhanur	Lingasuguru	Lingasugur	110KV S/s Mudagal	Nagalapura	
112	Ballari	Raichur	O&M Division Sindhanur	Sindhanuru	Sindhanur	110KV S/s Turvihala	Gunda	
113	Ballari	Koppal	Gangavathi	Kushtagi	Kushtagi	220KV R/s Kushtagi	Dotihala	
114							Hirevalakunta and Tavaragera	
115	Ballari	Koppal	Gangavathi	Kushtagi	Kushtagi	110KV S/s Hanumasagara	Chalagera	
116							Kukanoor	
117	Ballari	Koppal	Koppala	Yelburga	Yelburga	110KV S/s Yelburga	Vajrabandi	
118							Bandi	
119	Ballari	Koppal	Gangavathi	Gangavathi	Kanakagiri	110KV S/s Kanakagiri	Musalapura	
120	Ballari	Koppal	Koppala	Yelburga	Yelburga	110KV S/s Bevooru	Chilakmukhi	
121	Ballari	Koppal	Koppala	Koppala	Koppala	110KV S/s Koppala	Mangaluru	
122							Hiresindogi	
123							Kempatagar	
124	Ballari	Koppal	Koppala	Koppala	Koppala	110KV S/s Kerehalli	Kukanapalli	
125	Ballari	Koppal	Koppala	Koppala	Koppala	110KV S/s Ginigera	Cocacola	
126	Ballari	Koppal	Koppala	Koppala	Koppala	110KV S/s Betaigera	Alwandi	

Statement Showing the details of 33 Feeders coming under GESCOM Jurisdiction

Annexure-A

Sl. No	Name of Zone	Name of Circle	O&M Division	O&M Sub-Division	Name of Taluk	Name of 220/110/66/33KV Sub-station	Name of 33KV feeders	Type of Category
127	Ballari	Koppal	Gangavathi	Gangavathi	Gangavathi	110KV S/s Gangavathi	Kampili	
128					Kamalnagar	33/11Kamalnagar	Kamalnagar	-
129						33/11Aurad	Aurad	-
130				Aurad	Aurad	33/11 Kherda(B)	Kherda(B)	-
131						33/11 Mudhol(B)	Mudhol(B)	-
132						33/11 Wadgaon	Wadgaon	-
133				Kamthana	Bidar	33/11 Kamathana	Kamathana	-
134	Kalaburgi	Bidar	Bidar			33/11 Bagdal	Bagdal	-
135						33/11 Bhathambra	Bhathambra	-
136						33/11 Mehkar	Mehkar	-
137						33/11 Halbarga	Halbarga	-
138						33/11 K.Chincholi	K.Chincholi	-
139					Bhaliki	33/11 Alandi	Alandi	-
140						33/11 Byalhalli	Byalhalli	-
141						33/11 Nittur(B)	Nittur(B)	-
142						33/11 Lakhangaon	Lakhangaon	-
143			Bidar			33/11 Chinkod	Chinkod	-
144				Bidar		33/11 Chickpet	Chickpet	-

Statement Showing the details of 33 Feeders coming under GESCOM Jurisdiction

Annexure-A

Sl No	Name of Zone	Name of Circle	O&M Division	O&M Sub-Division	Name of Taluk	Name of 220/110/66/33KV Sub-station	Name of 33KV feeders	Type of Category
145	Kalaburgi	Bidar	Humnabad	Humnabad	Humnabad	33/11 Circle office	Circle office	-
146						33/11 Manhalli	Manhalli	-
147						33/11 Ghatbora	Ghatbora	-
148						33/11 Hudgi	Hudgi	-
149						33/11 B.Kalyan	B.Kalyan	-
150						33/11 Basavakalyan IPDS	B.Kalyan	-
151						33/11 Mudbi	Mudbi	-
152						33/11 Bhoaga	Bhoaga	-
153						33/11 Morkhandi	Morkhandi	-
154						33/11 Muchlamb	Muchlamb	-
155						33/11 Hulsoor	Hulsoor	-
156						33/11 Bemalkheda	Bemalkheda	-

PQM: Format 1(a) Categorywise abstract for the month of November-2021

SL No	Division Name	Category							Total
		U	IND	WS	NJY	EIP	RURAL		
1	KALABURAGI CSC	69	2	0	0	0	0	0	71
2	KALABURAGI-1	9	18	4	73	105	0	0	209
3	KALABURAGI-2	12	6	3	45	44	0	0	110
4	SEDAM	6	4	1	44	31	3	3	89
5	YADGIR	22	5	11	62	86	7	7	193
6	BIDAR	30	4	13	66	85	2	2	200
7	HUMNABAD	10	7	3	40	67	1	1	128
Kalaburagi Zone		158	46	35	330	418	13	13	1000
8	RAICHUR URBAN	19	8	1	0	0	0	0	28
9	RAICHUR RURAL	14	13	2	81	105	0	0	215
10	SINDHNOOR	10	3	10	58	78	2	2	161
11	KOPPAL	12	5	4	35	90	0	0	146
12	GANAGAVTHI	17	6	4	29	81	6	6	143
13	BALLARI URBAN	23	4	2	0	0	0	0	29
14	BALLARI RURAL	24	16	4	41	80	0	0	165
15	HOSPET URBAN	28	3	2	12	30	0	0	75
16	HOSPET RURAL	8	2	6	55	128	0	0	199
Ballari Zone		155	60	35	311	592	8	8	1161
TOTAL		313	106	70	641	1010	21	21	2161

Form-Details of Input Infrastructure

1	Parameters	Total	Covered during in audit	Verified by Auditor in Sample Check	Remarks (Source of data)
i	Number of circles	5	5	5	
ii	Number of divisions	16	16	16	
iii	Number of sub-divisions	53	53	53	
iv	Number of feeders	2484	2162	2162	TP Section
v	Number of DTs	116285	116285	116285	TP Section
vi	Number of consumers	3367029	3367029	3367029	
2	Parameters	66kV and above	33kV	11/22kV	LT
a. i.	Number of conventional metered consumers	0	0	2194	2949439
ii	Number of consumers with 'smart' meters	0	0	0	0
iii	Number of consumers with 'smart prepaid' meters	0	0	0	0
iv	Number of consumers with 'AMR' meters	289	20	0	0
v	Number of consumers with 'non-smart prepaid' meters	0	0	0	0
vi	Number of unmetered consumers	0	0	0	415087
vii	Number of total consumers	289	20	2194	3364536
b.i.	Number of conventionally metered Distribution Transformers	289	20	2194	116285
ii	Number of DTs with communicable meters	0	0	0	0
iii	Number of unmetered DTs	0	0	0	13602
iv	Number of total Transformers	289	20	2194	129887
c.i.	Number of metered feeders	174	147	2163	116285
ii	Number of feeders with communicable meters	0	0	0	0
iii	Number of unmetered feeders	0	0	0	0
iv	Number of total feeders	174	147	2163	116285
d.	Line length (ct. km)	NA	2806.53	71656.53	89843.68
e.	Length of Aerial Bunched Cables	0	0	0	2448.5
f.	Length of Underground Cables	0	0	107.88	0

Sl. No.	Voltage level	Particulars	MU	Reference	Remarks (Source of data)	
I	66kV and above	Long-Term Conventional	661.43 ✓	Includes input energy for franchisees		
		Medium Conventional	0			
		Short Term Conventional	0			
		Banking	0			
		Long-Term Renewable energy	5.31 ✓			
		Medium and Short-Term RE	0			
		Captive, open access input	0			Any power wheeled for any purchase other than sale to DISCOM. Does not include input for franchisees.
		Sale of surplus power	0			
		Quantum of inter-state transmission loss	20.9			As confirmed by SLDC, RLDC, etc.
		Power procured from inter-state sources	667 ✓			Based on data from Form 5
		Power at state transmission boundary	646			
		Long-Term Conventional	495 ✓			
		Medium Conventional	0			
Short Term Conventional	0					
Banking	0					
Long-Term Renewable energy	1260.65 ✓					
Medium and Short-Term RE	0					
Captive, open access input	0					
Sale of surplus power	0.00%					
Quantum of intra-state transmission loss	55 ✓					
Power procured from intra-state sources	1,811					
Input in DISCOM wires network	2,423					
Renewable Energy Procurement	0					
Small capacity conventional/ biomass/ hydro plants Procurement	0					
Captive, open access input	0					
Renewable Energy Procurement	0					
Small capacity conventional/ biomass/ hydro plants Procurement	29.4 ✓					
Sales Migration Input	0					
Renewable Energy Procurement	0					
Sales Migration Input	0					
Energy Embedded within DISCOM wires network	29.4					
Total Energy Available/ Input	2,452 ✓					
II						
III						
IV	33kV					
V	11 kV					
VI	LT					
VII						
VIII						

4	Voltage level	Energy Sales Particulars	MU	Reference
i	LT Level	DISCOM' consumers	1,399	Include sales to consumers in franchisee areas, un-metered consumers
		Demand from open access, captive	0	Non DISCOM's sales
		Embedded generation used at LT level	0	Demand from embedded generation at LT level
		Sale at LT level	1,399	
		Quantum of LT level losses	105	Based on pro-rata calculation
		Energy input at LT level	1,504	
		DISCOM' consumers	90	Include sales to consumers in franchisee areas, un-metered consumers
		Demand from open access, captive	0	Non DISCOM's sales
		Embedded generation at 11 kV level used	0	Demand from embedded generation at 11kV level
		Sales at 11 kV level	90	
ii	11 kV Level	Quantum of Losses at 11 kV	2	
		Energy input at 11 kV level	92	
		DISCOM' consumers	8	Include sales to consumers in franchisee areas, un-metered consumers
		Demand from open access, captive	0	Non DISCOM's sales
		Embedded generation at 33 kV or below level	0	This is DISCOM and OA demand met via energy generated at same voltage level
		Sales at 33 kV level	8	
		Quantum of Losses at 33 kV	0.320	
		Energy input at 33kV Level	9	
		DISCOM' consumers	217.81197	Include sales to consumers in franchisee areas, un-metered consumers
		Demand from open access, captive	192	Open Access Sale and Railway Traction Sale
iii	> 33 kV	Cross border sale of energy	157	Outside Periphery sale
		Sale to other DISCOMs	0	
		Wheeling and Banking	40	
		Energy input at > 33kV Level	624	
		Sales at 66kV and above (EHV)	618	
		Total Energy Requirement	2,229	
		Total Energy Sales	2,115	

Energy Accounting Summary

5	DISCOM	Input (in MU)	Sale (in MU)	Loss (in MU)	Loss %
i	LT	1,504	1,399	105	6.98
ii	11 kv	92	90	2	2.17
iii	33 kv	9	8	0.32	3.66
iv	> 33 kv	624	618	6.508031	1.04
6	Open Access, Captive	Input (in MU)	Sale (in MU)	Loss (in MU)	Loss %
i	LT	-	-	-	-
ii	11 kv	-	-	-	-
iii	33 kv	-	-	-	-
iv	> 33 kv	-	-	-	-

Loss Estimation for DISCOM

T&D loss	337
D loss	261
T&D loss (%)	15.11648964
D loss (%)	11.71590506

Details of Division Wise Losses

2nd Quarter (From July 2021 to Sept 2021)

Name of Division	Circle code	Consumer profile										Energy parameters					Losses			Commercial Parameter			AT & C loss (%)
		Consumer category		No of connection		Total Number of connections (Nos)	% of number of connections	Input energy (MJ)	Metered energy		Billed energy (MJ)		% of energy consumption	T&D loss (MJ)	T&D loss (%)	Billed Amount in Rs. Crore	Collected Amount in Rs. Crore	Collection efficiency					
		No of Connection metered (Nos)	No of connection Un-metered (Nos)	Metered energy	Unmetered/assessment energy				Total energy														
1	Kaduragi Urban	Residential	181597	0	181597	78.50%	55.28	0.00	55.28	61.53%	17.34	41.78	111%	0.03	0.03	100%	4%						
		Agricultural	0	97	97	0.04%	0.00	0.04	0.05%	0.00	0.00	0.00	0.00	0.00	0.00	100%							
		Commercial/Industrial-LT	44875	0	44875	19.40%	14.47	0.00	14.47	16.13%	15.04	17.79	118%	15.8626	15.8626	100%							
		Commercial/Industrial-HT	139	0	139	0.06%	9.25	0.00	9.25	10.29%	9.01	10.58	117%	9.01	10.58	117%							
		Others	4620	0	4620	2.00%	10.79	0.00	10.79	12.01%	7.89	8.70	110%	7.89	8.70	110%							
Sub-total		231212	97	231329	100.00%	105.70	89.79	89.83	100.00%	69.11	78.37	113%	15.8626	15.8626	100%	4%							
2	Kaduragi Division-II	Residential	178463	0	178463	68.19%	20.57	3.08	23.64	19.79%	15.29	16.43	107%	39.54	39.37	100%	13%						
		Agricultural	0	52896	52896	20.24%	0.00	65.78	65.78	54.63%	8.23	8.58	104%	8.23	8.58	104%							
		Commercial/Industrial-LT	22181	0	22181	8.49%	8.55	0.00	8.55	7.15%	8.93	9.31	104%	8.93	9.31	104%							
		Commercial/Industrial-HT	216	0	216	0.08%	8.41	0.00	8.41	7.04%	11.94	7.14	60%	11.94	7.14	60%							
		Others	7588	0	7588	2.90%	13.61	0.00	13.61	11.39%	83.93	81.23	97%	83.93	81.23	97%							
Sub-total		208448	52896	261344	100.00%	132.36	51.13	68.35	100.00%	12.8721	10%	10%	12.8721	10%	10%	13%							
3	Kaduragi Division-II	Residential	336942	0	336942	77.50%	20.25	0.00	20.25	31.94%	16.13	16.59	103%	16.13	16.59	103%	6%						
		Agricultural	0	17261	17261	10.01%	0.00	25.10	25.10	39.58%	7.23	7.79	108%	7.23	7.79	108%							
		Commercial/Industrial-LT	18576	0	18576	10.29%	7.75	0.00	7.75	12.23%	5.34	5.99	111%	5.34	5.99	111%							
		Commercial/Industrial-HT	48	0	48	0.03%	2.11	0.00	2.11	3.32%	7.27	7.49	103%	7.27	7.49	103%							
		Others	2150	0	2150	4.25%	8.20	0.00	8.20	12.94%	5.38404	5.38404	100%	5.38404	5.38404	100%							
Sub-total		154814	17261	172075	100.00%	68.79	88.31	35.10	100.00%	49.57	50.38	101%	49.57	50.38	101%	6%							
4	Sedam	Residential	101646	0	101646	79.28%	12.40	0.00	12.40	19.57%	8.53	8.63	101%	8.53	8.63	101%	6%						
		Agricultural	0	11129	11129	8.24%	0.00	16.34	16.34	25.76%	9.88	9.86	100%	9.88	9.86	100%							
		Commercial/Industrial-LT	14756	0	14756	11.19%	4.27	0.00	4.27	6.23%	4.17	4.35	104%	4.17	4.35	104%							
		Commercial/Industrial-HT	37	0	37	0.03%	25.07	0.00	25.07	39.58%	21.48	22.54	105%	21.48	22.54	105%							
		Others	334	0	334	0.26%	3.30	0.00	3.30	8.36%	4.75	3.48	73%	4.75	3.48	73%							
Sub-total		116273	11129	127402	100.00%	67.56	47.04	16.34	100.00%	48.81	48.87	100%	48.81	48.87	100%	6%							
5	Yadgi	Residential	229728	0	229728	75.70%	30.43	0.00	30.43	34.50%	23.58	22.60	103%	23.58	22.60	103%	11%						
		Agricultural	0	36679	36679	12.09%	0.00	64.88	64.88	52.24%	37.07	35.75	96%	37.07	35.75	96%							
		Commercial/Industrial-LT	35945	0	35945	11.85%	10.51	0.00	10.51	8.86%	10.50	11.26	107%	10.50	11.26	107%							
		Commercial/Industrial-HT	101	0	101	0.03%	4.70	0.00	4.70	3.79%	3.49	4.09	117%	3.49	4.09	117%							
		Others	3019	0	3019	0.94%	13.67	0.00	13.67	11.03%	11.31	9.75	82%	11.31	9.75	82%							
Sub-total		266797	36679	303476	100.00%	140.59	59.31	64.88	100.00%	16.3962	12%	13%	16.3962	12%	13%	13%							
6	Bider	Residential	235221	0	235221	73.04%	40.56	0.00	40.56	30.33%	17.68	30.24	109%	17.68	30.24	109%	16%						
		Agricultural	0	47785	47785	13.28%	0.00	38.52	38.52	28.79%	23.32	23.23	100%	23.32	23.23	100%							
		Commercial/Industrial-LT	41514	0	41514	12.80%	11.11	0.00	11.11	8.30%	11.26	12.66	112%	11.26	12.66	112%							
		Commercial/Industrial-HT	179	0	179	0.05%	20.79	0.00	20.79	15.54%	12.91	13.40	104%	12.91	13.40	104%							
		Others	2162	0	2162	0.71%	22.80	0.00	22.80	17.05%	21.02	10.96	52%	21.02	10.96	52%							
Sub-total		279276	47785	327061	100.00%	149.86	55.26	38.52	100.00%	16.0882	11%	16%	16.0882	11%	16%	16%							
7	Hunnabail	Residential	140462	0	140462	66.29%	22.31	0.00	22.31	25.51%	15.16	16.42	108%	15.16	16.42	108%	17%						
		Agricultural	0	40539	40539	19.13%	0.00	33.00	33.00	27.74%	20.02	19.03	100%	20.02	19.03	100%							
		Commercial/Industrial-LT	27975	0	27975	13.20%	6.23	0.00	6.23	7.15%	6.55	7.16	109%	6.55	7.16	109%							
		Commercial/Industrial-HT	78	0	78	0.04%	11.07	0.00	11.07	12.68%	7.35	7.74	105%	7.35	7.74	105%							
		Others	2848	0	2848	1.34%	14.83	0.00	14.83	16.96%	11.93	4.47	37%	11.93	4.47	37%							
Sub-total		171863	40539	211902	100.00%	96.12	54.44	33.00	100.00%	8.6755	9%	17%	8.6755	9%	17%	17%							
8	Ballari Urban	Residential	122145	0	122145	78.68%	34.74	0.00	34.74	59.13%	23.35	24.18	104%	23.35	24.18	104%	10%						
		Agricultural	0	102	102	0.15%	0.00	1.60	1.60	2.72%	0.96	0.93	96%	0.96	0.93	96%							
		Commercial/Industrial-LT	26073	0	26073	16.80%	10.15	0.00	10.15	17.27%	10.41	10.83	104%	10.41	10.83	104%							
		Commercial/Industrial-HT	138	0	138	0.09%	6.59	0.00	6.59	11.21%	6.45	6.04	175%	6.45	6.04	175%							
		Others	6582	0	6582	4.24%	3.68	0.00	3.68	9.67%	3.69	3.80	103%	3.69	3.80	103%							
Sub-total		154930	102	155241	100.00%	69.22	37.16	1.60	100.00%	10.4636	15%	10%	10.4636	15%	10%	10%							

DCC Section

2nd Quarter (from July 2021 to Sept. 2021)

Name of Division	Circle code	Consumer profile				Energy parameters				Losses		Commercial Parameters			AT & C loss (%)	
		Consumer category	No of Connections metered (Nos)	No of connection Un-metered (Nos)	Total Number of connections (Nos)	% of number of connections	Input energy (MU)	Metered energy	Unmetered/assessment energy	Total energy	% of energy consumption	T&D loss (MU)	T&D loss (%)	Billed Amount in Rs. Crore		Collected Amount in Rs. Crore
9 Ballari Rural		Residential	207488	0	207488	76.54%		26.69	0.00	26.69	35.08%			18.05	19.30	107%
		Agricultural	0	37635	37635	13.83%		0.00	68.01	68.01	38.43%			40.73	41.07	101%
		Commercial/Industrial-LT	25305	0	25305	9.29%		206.38	9.53	0.00	9.53	5.38%		9.23	10.43	133%
		Commercial/Industrial-HT	373	0	373	0.14%			53.80	0.00	53.80	29.27%		48.33	53.72	111%
		Others	1697	0	1697	0.62%			20.95	0.00	20.95	11.84%		20.31	13.94	64%
Sub-total		214063	37635	274288	100.00%	206.38	108.97	88.01	176.99	100.00%	29.3957	14%	116.64	117.46	101%	
10 Hospet Urban		Residential	177811	0	177811	79.24%		23.59	0.00	23.59	30.90%			16.49	17.85	108%
		Agricultural	0	11142	11142	6.91%		0.00	24.16	24.16	31.64%			14.34	13.90	97%
		Commercial/Industrial-LT	20874	0	20874	12.94%		85.61	6.04	0.00	6.04	7.91%		6.51	7.27	112%
		Commercial/Industrial-HT	170	0	170	0.11%			14.18	0.00	14.18	18.57%		13.88	14.43	104%
		Others	1294	0	1294	0.80%			8.39	0.00	8.39	10.98%		7.84	8.21	105%
Sub-total		190349	11142	161294	100.00%	85.61	52.20	24.36	76.36	100.00%	9.25086	11%	59.05	61.66	104%	
11 Hospet Rural		Residential	162802	0	162802	71.42%		12.97	3.77	16.74	12.48%			11.87	12.47	105%
		Agricultural	0	41409	41409	18.16%		0.00	94.43	94.43	70.41%			56.14	54.11	96%
		Commercial/Industrial-LT	21062	0	21062	9.24%		154.01	5.17	0.05	5.21	3.89%		5.29	5.66	107%
		Commercial/Industrial-HT	46	0	46	0.02%			2.98	0.00	2.98	1.76%		7.71	8.14	106%
		Others	2645	0	2645	1.16%			15.04	0.31	15.35	11.45%		15.37	6.04	39%
Sub-total		186555	41409	227964	100.00%	154.01	85.57	98.55	134.11	100.00%	19.8932	13%	96.38	86.42	90%	
12 Raichur Urban		Residential	74935	0	74935	79.91%		20.01	0.00	20.01	42.46%			13.86	14.29	103%
		Agricultural	0	406	406	0.43%		0.00	2.20	2.20	4.66%			1.33	1.32	100%
		Commercial/Industrial-LT	16497	0	16497	17.59%		90.71	5.44	0.00	5.44	11.54%		5.68	5.93	105%
		Commercial/Industrial-HT	243	0	243	0.26%			14.70	0.00	14.70	31.20%		13.62	14.06	103%
		Others	1692	0	1692	1.80%			4.78	0.00	4.78	10.14%		8.20	5.40	138%
Sub-total		93867	406	93773	100.00%	50.71	46.93	2.20	47.13	100.00%	3.38805	7%	38.04	41.39	107%	
13 Raichur Rural		Residential	348677	0	348677	70.30%		15.87	0.00	15.87	10.12%			11.77	12.43	106%
		Agricultural	0	32239	32239	16.11%		0.00	107.06	107.06	68.26%			65.19	64.45	99%
		Commercial/Industrial-LT	20312	0	20312	11.61%		176.86	6.19	0.00	6.19	3.94%		6.13	6.93	113%
		Commercial/Industrial-HT	216	0	216	0.11%			15.63	0.00	15.63	9.95%		16.40	17.33	106%
		Others	3754	0	3754	1.89%			12.13	0.00	12.13	7.73%		10.70	6.05	57%
Sub-total		367874	32239	400113	100.00%	176.86	49.79	107.06	156.85	100.00%	20.0077	11%	110.18	107.18	97%	
14 Sedhanoor		Residential	159567	0	159567	75.24%		24.57	0.00	24.57	23.11%			16.47	16.98	103%
		Agricultural	0	25785	25785	12.30%		0.00	51.18	51.18	48.15%			29.52	30.33	103%
		Commercial/Industrial-LT	24226	0	24226	11.42%		120.19	7.52	0.00	7.52	7.07%		7.55	7.78	103%
		Commercial/Industrial-HT	81	0	81	0.04%			15.63	0.00	15.63	14.04%		12.38	13.12	106%
		Others	2416	0	2416	1.15%			7.42	0.00	7.42	6.96%		6.14	6.87	112%
Sub-total		186306	25785	212091	100.00%	320.19	55.12	91.18	106.29	100.00%	13.897	12%	72.06	75.09	104%	
15 Kropal		Residential	140514	0	140514	70.45%		17.88	0.00	17.88	12.55%			12.27	13.01	106%
		Agricultural	0	31594	31594	17.79%		0.00	66.06	66.06	66.30%			40.04	40.86	102%
		Commercial/Industrial-LT	21350	0	21350	10.67%		156.72	6.68	0.00	6.68	4.69%		6.70	7.40	110%
		Commercial/Industrial-HT	181	0	181	0.09%			41.09	0.00	41.09	29.20%		55.11	58.37	106%
		Others	1995	0	1995	1.00%			10.19	0.00	10.19	7.15%		8.21	7.23	88%
Sub-total		164440	35594	200034	100.00%	156.72	76.44	66.06	142.50	100.00%	14.2174	9%	122.32	127.07	104%	
16 Gangavathi		Residential	153148	0	153148	71.42%		22.47	0.00	22.47	16.67%			15.63	15.95	102%
		Agricultural	0	29189	29189	13.61%		0.00	82.32	82.32	60.90%			49.13	49.88	102%
		Commercial/Industrial-LT	25694	0	25694	11.98%		190.38	7.45	0.00	7.45	5.51%		7.40	7.90	106%
		Commercial/Industrial-HT	256	0	256	0.12%			13.88	0.00	13.88	10.27%		12.64	13.40	106%
		Others	6150	0	6150	2.87%			9.05	0.00	9.05	6.69%		6.96	15.29	220%
Sub-total		185248	29189	214437	100.00%	150.38	52.85	83.32	135.17	100.00%	15.2080	10%	92.45	102.41	110.78%	

2nd Quarter (From July-2021 to Sept-2021)

Sl. No.	Name of Division	Circle code	Consumer profile				Energy parameters				Losses			Commercial Parameter			AT & C loss (%)	
			Consumer category	Nit of Connection metered (Nos)	No of connection Un-metered (Nos)	Total Number of connections (Nos)	% of number of connections	Input energy (MU)	Measured energy	Unmetered/assessed energy	Total energy	% of energy consumption	T&D loss (MU)	T&D loss (%)	Billed Amount in Rs. Crore	Collected Amount in Rs. Crore		Collection Efficiency
17	Total		249541	0	415087	415087	73.97%	1933.06	400.59	790.17	407.44	23.75%	215.30	1.1%	274.34	296.60	106.56%	10%
			409638	0	409638	409638	12.17%	1933.06	0.00	790.17	790.17	43.14%	215.30	1.1%	444.16	441.98	99.42%	
			2503	0	2503	2503	0.07%	1933.06	257.85	0.00	257.85	15.03%			127.71	140.13	109.27%	10%
			49160	0	49160	49160	1.46%	1933.06	182.83	0.31	183.13	10.67%			255.43	274.45	107.45%	
18	At company level		2953542	415087	3367029	3367029	100.00%	1933.06	968.31	747.37	1715.67	100.00%	215.385	11.17%	1265.15	1274.47	100.74%	10%

** Note - It shall be mandatory to record the energy supplied separately for each category of consumers which is being provided a separate rate of subsidy in the tariff, by the state government, so that the subsidy due for the electricity distribution company is quarterly calculated by multiplying the energy supplied to each of such category of consumers by the applicable rate of subsidy notified by the state government.

Sl. No.	Parameter
1	Please enter name of circle
2	Please enter circle code
3	Please enter numeric value or 0
4	Formula protected

I/We undertake that the information supplied in this document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal

Signature: *[Handwritten Signature]*
 Name of Authorized Signatory: **Sri. Lakshman Chavva**
 Name of the DISCOM: **Chief Engineer (Ele.) Operations, Corporate Office, ESCOM, Kalaburagi.**
 Full Address: **ESCOM, Kalaburagi.**

Seal

Signature: *[Handwritten Signature]*
 Name of Energy Manager: **Doddla Basappa A**
 Registration Number: **EM-7976**

DCB Section

From July 2021 to September 2021

S. No.	Type of Consumers	Category of Consumers (EHT/HT/LT/Others)	Voltage Level	No. Of Consumers	Total Consumption (In MU)	Remarks (Source of data)
1	Domestic	LT	230/415 Volts	2490595	404.12	DCB Section
2	Commercial	LT	230/415 Volts	294620	83.67	
3	IP Sets	LT	230/415 Volts	412199	713.74	
4	Hor. & Nur. & Coffee/Tea & Rubber (Metered)	LT	230/415 Volts	0	0.00	
5	Hor. & Nur. & Coffee/Tea & Rubber (Flat)	LT	230/415 Volts	2888	1.59	
6	Heating and Motive Power	LT	230/415 Volts	70304	43.42	
7	Water Supply	LT	230/415 Volts	28738	92.60	
8	Public Lighting	LT	230/415 Volts	15362	53.55	
9	HT Water Supply	HT	11 KV	173	26.37	
10	HT Industrial	HT		1796	234.49	
11	Industrial (Small)	HT		0	0.00	
12	Industrial (Medium)	HT		0	0.00	
13	HT Commercial	HT		440	15.32	
14	Applicable to Government Hospitals & Hospitals	HT		264	8.03	
15	Lift Irrigation Schemes/Lift Irrigation Societies	HT		444	24.83	
16	HT Residential Apartments Applicable to all areas	HT		46	3.31	
17	Mixed Load			0	0.00	
18	Government Offices and department			0	0.00	
19	Others-1 Temporary	LT	230/415 Volts	49108	6.36	
20	Others-2 Temporary	HT		52	4.25	
21	Others-3 (If any, specify in remarks)			0	0.00	
	Total			3367029	1715.67	