



# **Annual Energy Audit Report**

## **FY 2022-23**



**M/s Kanan Devan Hills Plantations (KDHP) Company**

**Private Limited**

**Reg no: DIS0083KL**

**KDHP House, Munnar**

**Idukki District-Kerala -685612.**

*Prepared by*



**Centre for Energy Environment & Productivity**

**1039, 26th Street, H Block, Ponni Colony,**

**Anna Nagar, Chennai 600040**

**Ph: +91 9444882553 / 8668115663 E-Mail: ceepnagesh@gmail.com**

**July 2023**

## ACKNOWLEDGEMENTS

---

Bureau of Energy Efficiency (BEE) through its extraordinary gazette notification on 06<sup>th</sup> October 2021 made the regulation: Manner and Intervals for Conduct of Energy Audit in electricity distribution companies) Regulations, 2021. Through this every electricity distribution company shall conduct an annual energy audit for every financial year and submit the annual energy audit report to the Bureau and respective State Designated Agency (Energy Management Centre, Govt of Kerala) within a period of four months from the expiry of the relevant financial year.

Centre for Energy Environment and Productivity (CEEP) places on record its sincere thanks to M/s Kanan Devan Hills Plantations (KDHP) Company Private Limited for entrusting the task of conducting Energy audit for its DISCOM during June - July 2023.

We would also like to thank the following officials of M/s Kanan Devan Hills Plantations (KDHP) Company Private Limited, KDHP House, Munnar Idukki District-Kerala -685612. for their proactive support and courtesy extended to the CEEP team during the study and all other staff for their cooperation and support given during the whole process.

- |                       |                         |
|-----------------------|-------------------------|
| 1. Mr. Mathew Abraham | Managing Director       |
| 2. Mr. Raju Warriar   | Sr. Manager             |
| 3. Mr. R. Jayaraman   | Executive - Engineering |



30/08/2023

**J Nagesh Kumar**

Director/AEA 0133

Centre for Energy Environment & Productivity

1039, 26th Street, H Block, Ponni Colony,

Anna Nagar, Chennai 600040

tallkumar@gmail.com, ceepnagesh@gmail.com

Centre for Energy, Environment and Productivity  
Plot No. 1039, 26th Street, H-Block,  
Ponni Colony, Anna Nagar, Chennai - 600 040.  
PH : 044 2616 3463, 9444882553

## ENERGY AUDIT TEAM

Table 1: Energy audit team

| Sr No               | Name                | Qualification   | EM/EA/AEA/<br>Registration No | Experience<br>(In Years) |
|---------------------|---------------------|---|-------------------------------|--------------------------|
| <b>Team Leader</b>  |                     |   |                               |                          |
| 1                   | Mr. J Nagesh Kumar  | • Accredited Energy Auditor                                 | AEA-0133                      | 30                       |
| <b>Team Members</b> |                     |   |                               |                          |
| 2                   | Mr. Sunil kumar V K | • Certified Energy Auditor<br>• Sector Expert               | EA - 3642                     | 40                       |
| 3                   | Mr. Ashok K M P     | • Certified Energy Auditor<br>• M. E. (Energy Engineering)  | EA- 34760/22                  | 8                        |
| 4                   | Ms. Della David     | • Certified Energy Auditor<br>• M. Tech (Power electronics) | EA -34867/22                  | 13                       |
| 5                   | Ms. Keerthana K     | • Project Engineer  | NIL                           | 3                        |
| 6                   | Ms. Neema Joy       | • Project Engineer  | NIL                           | 2                        |

## TABLE OF CONTENTS

|   |     |
|---|-----|
| ACKNOWLEDGEMENTS.....   | 2   |
| ENERGY AUDIT TEAM.....  | 3   |
| TABLE OF CONTENTS.....  | 4   |
| LIST OF TABLES.....   | 5   |
| LIST OF FIGURES.....  | 7   |
| EXECUTIVE SUMMARY.....  | 9   |
| 1. PERFORMANCE SUMMARY.....   | 9   |
| 2. ENERGY CONSERVATION MEASURES SUMMARY.....                          | 9   |
| 3. GENERAL OBSERVATIONS AND SUGGESTIONS.....                          | 10  |
| BACKGROUND.....   | 10  |
| 1. ABOUT BEE.....   | 10  |
| 2. EXTANT OF REGULATIONS - DISCOM.....                                | 10  |
| 3. PURPOSE OF AUDIT AND ACCOUNTING REPORT.....                        | 11  |
| 4. PERIOD OF ENERGY AUDIT AND ACCOUNTING.....                         | 12  |
| 5. PROGRESS IN COMPLIANCE TO PREREQUISITES TO ENERGY ACCOUNTING.....  | 12  |
| DISCOM INTRODUCTION AND OVERVIEW.....                                 | 13  |
| 1. NAME AND ADDRESS OF DESIGNATED CONSUMER.....                       | 13  |
| 2. ENERGY AUDIT CELL.....   | 13  |
| 3. SUMMARY PROFILE OF DISCOM – FORM-1.....                            | 14  |
| 4. ASSET MAPPING OF DISCOM.....                                       | 18  |
| 5. ENERGY CONSERVATION MEASURES SUMMARY.....                          | 43  |
| ENERGY FLOW ANALYSIS.....   | 46  |
| 1. ENERGY FLOW.....   | 46  |
| 2. VALIDATION OF METERED DATA.....                                    | 47  |
| 3. VALIDATION OF ENERGY FLOW DATA.....                                | 50  |
| LOSS & SUBSIDY COMPUTATION.....                                       | 57  |
| 1. ENERGY ACCOUNTS ANALYSIS FOR PREVIOUS YEARS- FY 2021-22.....       | 57  |
| 2. ENERGY ACCOUNTS ANALYSIS FOR PRESENT YEAR- FY 2022-23.....         | 58  |
| 3. TECHNICAL LOSSES.....  | 60  |
| 4. HT/LT RATIO.....   | 92  |
| 5. SUBSIDY COMPUTATION AND ANALYSIS.....                              | 93  |
| 6. TREND ANALYSIS.....  | 93  |
| ENERGY AUDIT FINDINGS.....  | 94  |
| 1 COMPLIANCE TO BEE REGULATIONS.....                                  | 94  |
| 2 NOTES OF THE EA/EM ALONG WITH QUERIES AND REPLIES TO DATA GAPS..... | 99  |
| CONCLUSION AND ACTION PLANS.....                                      | 100 |
| 1 CRITICAL COMMENTS AND ANALYSIS BY ENERGY AUDITOR.....               | 100 |
| 2 ENERGY CONSERVATION MEASURES.....                                   | 101 |
| ANNEXURE: COLLECTED DATA.....   | 106 |



|   |     |
|---|-----|
| 1. ABOUT THE ACCREDITED ENERGY AUDIT FIRM.....          | 106 |
| 2. CHECKLIST PREPARED BY AUDITING FIRM.....             | 107 |
| 3. APPROACH, SCOPE & METHODOLOGY OF ENERGY AUDIT.....   | 108 |
| 4. INFRASTRUCTURE DETAILS.....                          | 117 |
| 5. ELECTRICAL DISTRIBUTION SYSTEM.....                  | 119 |
| 6. POWER PURCHASE DETAILS.....                          | 126 |
| 7. SINGLE LINE DIAGRAM.....                             | 128 |
| 8. CATEGORY OF SERVICE DETAILS.....                     | 130 |
| 9. FIELD VERIFICATION DATA.....                         | 138 |
| 10. LIST OF DOCUMENTS VERIFIED WITH EACH PARAMETER..... | 148 |
| 11. DETAILED FORMATS TO BE ANNEXED.....                 | 149 |
| 12. ABBREVIATIONS.....                                  | 162 |

## LIST OF TABLES

|   |    |
|---|----|
| TABLE 1: ENERGY AUDIT TEAM.....   | 3  |
| TABLE 2: SUMMARY OF DISCOM – FORM-1.....                                  | 9  |
| TABLE 3: ENERGY CONSERVATION MEASURES.....                                | 9  |
| TABLE 4: GENERAL OBSERVATIONS AND SUGGESTIONS.....                        | 10 |
| TABLE 5: PERIOD OF ENERGY AUDIT & ACCOUNTING – AS PER BEE GUIDELINES..... | 12 |
| TABLE 6: PROGRESS IN ENERGY ACCOUNTING.....                               | 12 |
| TABLE 7: NAME AND ADDRESS OF DESIGNATED CONSUMER.....                     | 13 |
| TABLE 8: ENERGY AUDIT CELL.....   | 13 |
| TABLE 9: SUMMARY OF DISCOM – FORM-1.....                                  | 14 |
| TABLE 10: T & D LOSS – SUMMARISED – FEEDER WISE.....                      | 14 |
| TABLE 11: MAJOR ENERGY PARAMETERS – KDHP DISCOM.....                      | 16 |
| TABLE 12: METERED READING OF INPUT ENERGY.....                            | 17 |
| TABLE 13: HT LINE DISTANCE – PULLIVASAL FEEDER.....                       | 18 |
| TABLE 14: POLE MAPPING – GEOGRAPHICAL LOCATION – PULLIVASAL FEEDER.....   | 18 |
| TABLE 15: HT LINE DISTANCE – ITD FEEDER.....                              | 20 |
| TABLE 16: POLE MAPPING – GEOGRAPHICAL LOCATION – ITD FEEDER.....          | 21 |
| TABLE 17: HT LINE DISTANCE – NEYAMAKAD FEEDER.....                        | 23 |
| TABLE 18: POLE MAPPING – GEOGRAPHICAL LOCATION – NEYAMAKAD FEEDER.....    | 24 |
| TABLE 19: HT LINE DISTANCE – NETTIGUDI FEEDER.....                        | 28 |
| TABLE 20: POLE MAPPING – GEOGRAPHICAL LOCATION – NETTIGUDI FEEDER.....    | 29 |
| TABLE 21: HT LINE DISTANCE – TOWN FEEDER.....                             | 32 |
| TABLE 22: POLE MAPPING – GEOGRAPHICAL LOCATION – TOWN FEEDER.....         | 33 |
| TABLE 23: ENERGY EFFICIENT TRANSFORMER – INSTALLED IN LAST 3 YEARS.....   | 43 |
| TABLE 24: ENERGY CONSERVATION MEASURES - SUMMARY.....                     | 45 |
| TABLE 25: CONSUMPTION VARIATION AMONG THE CONSUMERS.....                  | 47 |
| TABLE 26: KSEBL INCOMER METER – DEVIATION WITH PQ ANALYSER.....           | 48 |

|  |     |
|--|-----|
| TABLE 27: DEVIATION OF FEEDER METERS .....                                     | 48  |
| TABLE 28: ADJUSTED COMMERCIAL LOSS.....  | 49  |
| TABLE 29: OBSERVATIONS & RECOMMENDATION – ENERGY CONSUMPTION PROFILE .....     | 54  |
| TABLE 30: ENERGY SOLD OUTSIDE THE PERIPHERY.....                               | 55  |
| TABLE 31: FEEDER WISE SALES DATA FY 2022-23 .....                              | 56  |
| TABLE 32: SUMMARY OF DISCOM – FY 2021-22 .....                                 | 57  |
| TABLE 33: AT & C LOSS – FY 2021-22 .....                                       | 57  |
| TABLE 34: DIVISION WISE LOSSES .....   | 58  |
| TABLE 35: AT & C LOSS – FY 2022-23 .....                                       | 59  |
| TABLE 36: HT OH LINE – FEEDER WISE.....  | 60  |
| TABLE 37: HT OH LINE LOSS – NYAMAKAD FEEDER.....                               | 61  |
| TABLE 38: HT OH LINE LOSS – NETTIGUDI FEEDER.....                              | 67  |
| TABLE 39: HT OH LINE LOSS – MADUPATTY FEEDER.....                              | 70  |
| TABLE 40: HT OH LINE LOSS – ITD FEEDER.....                                    | 73  |
| TABLE 41: HT OH LINE LOSS – TOWN FEEDER.....                                   | 74  |
| TABLE 42: HT OH LINE LOSS – PULLIVASAL FEEDER.....                             | 76  |
| TABLE 43: LT OH LINE – FEEDER WISE.....  | 77  |
| TABLE 44: LT OH LINE DETAILS – FEEDER WISE.....                                | 77  |
| TABLE 45: LT CABLE, LT OH LINE & TRANSFORMER LOSS – NEYAMAKAD FEEDER.....      | 78  |
| TABLE 46: LT CABLE, LT OH LINE & TRANSFORMER LOSS – ITD FEEDER.....            | 80  |
| TABLE 47: LT CABLE, LT OH LINE & TRANSFORMER LOSS – NETTIGUDI FEEDER .....     | 81  |
| TABLE 48: LT CABLE, LT OH LINE & TRANSFORMER LOSS – MADUPATTY FEEDER .....     | 83  |
| TABLE 49: LT UG CABLE, LT OH LINE & TRANSFORMER LOSS – TOWN FEEDER.....        | 86  |
| TABLE 50: LT UG CABLE, LT OH LINE & TRANSFORMER LOSS – PULLIVASAL FEEDER ..... | 87  |
| TABLE 51: T & D LOSS – PULLIVASAL FEEDER .....                                 | 88  |
| TABLE 52: T & D LOSS – ITD FEEDER.....   | 88  |
| TABLE 53: T & D LOSS – TOWN FEEDER.....  | 89  |
| TABLE 54: T & D LOSS – NETTIGUDI FEEDER .....                                  | 89  |
| TABLE 55: T & D LOSS – NYAMAKAD FEEDER.....                                    | 90  |
| TABLE 56: T & D LOSS – MADUPATTY FEEDER.....                                   | 90  |
| TABLE 57: T & D LOSS – SUMMARISED – FEEDER WISE.....                           | 92  |
| TABLE 58: HISTORICAL ENERGY ACCOUNTS/LOSS OF THE DISCOM.....                   | 93  |
| TABLE 59: DISTRIBUTION LOSS – KDHP METHOD APPROVED BY KSERC.....               | 100 |
| TABLE 60: ANALYSIS ON T&D LOSSES.....  | 101 |
| TABLE 61 : HT OVERHEAD LINES DETAILS.....                                      | 101 |
| TABLE 62 : ECM 01.....   | 103 |
| TABLE 63 : LT OVERHEAD LINES DETAILS.....                                      | 104 |
| TABLE 64 : ECM 02.....   | 105 |
| TABLE 65: CONTACT DETAILS OF AEA & CEA.....                                    | 106 |
| TABLE 66: ACTIVITY CHART – ENERGY AUDIT.....                                   | 108 |

|   |     |
|---|-----|
| TABLE 67: EQUIPMENT LIST .....  | 116 |
| TABLE 68: INFRASTRUCTURE DETAILS.....   | 117 |
| TABLE 69: SWITCHING STATION – 11 KV CABLE DETAILS .....                         | 119 |
| TABLE 70: KDHP DISTRIBUTION – OH LINE DETAILS.....                              | 120 |
| TABLE 71: FEEDER WISE TRANSFORMER DATA .....                                    | 120 |
| TABLE 72: AVERAGE PURCHASE COST – DISCOM.....                                   | 127 |
| TABLE 73: ACS- ARR GAP.....   | 127 |
| TABLE 74: DETAILS OF CONSUMERS AND CONSUMPTION .....                            | 130 |
| TABLE 75: DIVISION WISE STATUS OF DT LEVEL METERING .....                       | 131 |
| TABLE 76: DT WISE LOSSES.....   | 132 |
| TABLE 77: INCOMER MEASUREMENT DATA .....  | 138 |
| TABLE 78: CURRENT HARMONICS LIMIT (IEEE 519-2014) .....                         | 142 |
| TABLE 79: VOLTAGE HARMONICS LIMIT (IEEE 519-2014).....                          | 142 |
| TABLE 80: STANDARD LIMITS AS PER THE IEEE 519-2014 – AT KDHP INCOMER.....       | 142 |
| TABLE 81: HARMONICS VALUES – KDHP INCOMER.....                                  | 143 |
| TABLE 82: OBSERVATIONS & RECOMMENDATION – ELECTRICAL NETWORK CONFIGURATION..... | 144 |
| TABLE 83: SAMPLE FEEDER WISE CONSUMER LIST – FOR REFERENCE ONLY .....           | 147 |
| TABLE 84: LIST OF DOUCUMENTS VERIFIED .....                                     | 148 |
| TABLE 85: ENERGY BILL SUMMARY – FY 2022-23.....                                 | 153 |

## LIST OF FIGURES

|   |     |
|---|-----|
| FIGURE 1: ENERGY FLOW DIAGRAM - KDHP .....                              | 15  |
| FIGURE 2: PULLIVASAL FEEDER.....  | 19  |
| FIGURE 3: ITD FEEDER.....   | 22  |
| FIGURE 4: NEYAMAKAD FEEDER.....   | 27  |
| FIGURE 5: NETTIGUDI FEEDER .....  | 31  |
| FIGURE 6: TOWN FEEDER.....  | 35  |
| FIGURE 7: MADUPATTY FEEDER .....  | 42  |
| FIGURE 8: ENERGY FLOW DIAGRAM - KDHP .....                              | 46  |
| FIGURE 9: DEMAND VARIATION – FY 2022-23 .....                           | 51  |
| FIGURE 10: ENERGY CONSUMPTION ANALYSIS .....                            | 52  |
| FIGURE 11: POWER FACTOR – FY 2022-23.....                               | 53  |
| FIGURE 12: HISTORICAL T & D LOSS WITH AUDITED DATA.....                 | 93  |
| FIGURE 13: SCHEMATIC REPRESENTATION OF TECHNICAL LOSSES .....           | 112 |
| FIGURE 14: GRID MAP – 11 KV DISTRIBUTION LINE.....                      | 125 |
| FIGURE 15: SLD – FROM PULLIVASAL POWER HOUSE- AT SWITCHING STATION..... | 128 |
| FIGURE 16: FROM CHITHIRAPURAM – AT SWITCHING STATION – INCOMER 3.....   | 129 |
| FIGURE 17: POWER VARIATIONS – CONTINUOUS LOGGED DATA.....               | 139 |
| FIGURE 18: DEMAND VARIATIONS – CONTINUOUS LOGGED DATA .....             | 140 |
| FIGURE 19: RMD – REAL TIME .....  | 140 |

|  |     |
|--|-----|
| <i>FIGURE 20: POWER FACTOR – VARIATIONS</i> .....            | 141 |
| <i>FIGURE 21: VOLTAGE HARMONIC SPECTRUM</i> .....            | 143 |
| <i>FIGURE 22: CURRENT HARMONIC SPECTRUM</i> .....            | 143 |
| <i>FIGURE 23: BALANCE SHEET FY 2021-22</i> .....             | 149 |
| <i>FIGURE 24: P&amp;L SHEET FY 2021-22</i> .....             | 150 |
| <i>FIGURE 25: KSEB BILL – MARCH 2023 – SAMPLE COPY</i> ..... | 151 |

## EXECUTIVE SUMMARY

### 1. PERFORMANCE SUMMARY

The performance summary of KDHP as DISCOM as per the FY 2022-23 is given in the following table. The table below **incorporates the feedback energy (Energy sold outside the periphery) for the T&D loss calculation.**

TABLE 2: SUMMARY OF DISCOM – FORM-1

| Performance Summary of Electricity Distribution Companies |  |                                  |         |
|---|--|----------------------------------|---------|
| <b>1</b>  | Period of Information<br>Year of (FY) information including Date and Month (Start & End) | 1st Apr, 2022 - 31st March, 2023 |         |
| <b>2</b>  | <b>Technical Details</b>   |                                  |         |
| <b>(a)</b>  | <b>Energy Input Details</b>  |                                  |         |
| (i)   | Input Energy Purchase<br>(From Generation Source)  | Million kWh                      | 54.118  |
| (ii)  | Net input energy (at DISCOM Periphery including sale outside periphery)                  | Million kWh                      | 59.048  |
| (iii)   | Total Energy billed (is the Net energy billed, adjusted for energy traded)               | Million kWh                      | 54.011  |
| <b>(b)</b>  | Transmission and Distribution (T&D) loss (Billing efficiency)                            | Million kWh                      | 5.038   |
|   |  | %                                | 8.53    |
|   | Collection Efficiency  | %                                | 99.673% |
| <b>(c)</b>  | Aggregate Technical & Commercial Loss  | %                                | 8.83%   |

### 2. ENERGY CONSERVATION MEASURES SUMMARY

The KDHP can consider several possible measures for energy conservation to reduce their distribution loss to their best value as summarised in the executive summary.

TABLE 3: ENERGY CONSERVATION MEASURES

| EC M No | Energy Efficiency Measures          | Annual Electricity Savings | Annual Financial Savings | Investment  | Fixed interest rate | Cash inflow | Net present value | Internal rate of return |
|---------|-------------------------------------|----------------------------|--------------------------|-------------|---------------------|-------------|-------------------|-------------------------|
|         |                                     | MU                         | (Rs)                     | (Rs)        | %                   | Years       | Rs                | %                       |
| 1       | Reconductoring of HT overhead lines | 0.734                      | 35,25,291                | 4,72,32,000 | 6                   | 16          | 12,93,035         | 6.25%                   |
| 2       | Reconductoring of LT overhead lines | 1.275                      | 61,22,303                | 2,14,14,400 | 6                   | 5           | 43,74,967         | 13.23%                  |

### 3. GENERAL OBSERVATIONS AND SUGGESTIONS

TABLE 4: GENERAL OBSERVATIONS AND SUGGESTIONS

| Observation   | Suggestions   | Benefits   |
|---|---|--|
| Some of the HT consumers are having metered at the secondary/LV side.   | As per the CEA metering regulation, HT consumers shall meter at the HV side with CT/PT, 0.2s class TOD meter.   | The actual transformer loss will get gauged in the bill which will reduce the KDHP overall T&D loss.   |
| Estimated that Distribution transformers are more than 40 years old (Around 30 nos) and re-winded several times during its life time.   | If any of failure of transformers in future, the no load loss of the same after rewinding is to be measured and ascertain the life cycle cost with new energy efficient transformers. No load loss of transformers after rewinding shall be logged and records shall be kept for future analysis. | By replacing the old re-winded transformers, with energy efficient ones, the overall T&D loss will reduce.   |
| Registered maximum demand in past months was always above the contract demand (9 MVA) in KDHP. However, with the present 3nos of 11 kV feeders, 9 MVA is maximum allowed demand as per the regulations. | Increase the contract demand to 12 MVA by increasing the voltage level to 33 kV.<br>For this, KDHP is in the process of installing 33 kV substation near to the town.   | The HT line loss up to the town area will reduce (exactly 2.8 km) along with the reduction in the excess demand charges. This will also capable to cater the future consumer loads in the Munnar area. |

## BACKGROUND

### 1. ABOUT BEE

The Government of India has set up Bureau of Energy Efficiency (BEE) on 1st March 2002 under the provision of the Energy Conservation Act, 2001. The mission of Bureau of Energy Efficiency is to assist in developing policies and strategies with a thrust on self-regulation and market principles with the primary objective of reducing energy intensity of the Indian economy within the overall framework of the Energy Conservation Act, 2001. This will be achieved with active participation of all stakeholders, resulting into accelerated and sustained adoption of energy efficiency in all sectors.

### 2. EXTANT OF REGULATIONS - DISCOM

Under the notification S.O. 3445 (E) dated 28 Sept 2020, all entities having distribution license are notified as Designated Consumers. Notification is read as "All entities having issued distribution license by State/Joint Electricity Regulatory Commission under the Electricity Act, 2003 (36 of 2003)" are notified as Designated Consumers (DCs). After this notification, all the DISCOMs will be governed under the various provisions of Energy Conservation Act, such as Appointment of

Energy Manager, Energy Accounting & Auditing, identification of Energy Losses Category wise, Implementation of energy conservation & efficiency measures etc.

The amendment is expected to help DISCOMs to monitor their performance parameters and bring in transparency in the Distribution sector through professional inputs. It will also assist in developing projects for reducing the electricity losses by DISCOMs and implementing effective solutions. The amendment is expected to improve the financial state of the DISCOMs.

In exercise of the powers conferred by clause (g) of sub-section (2) of section 58, read with clause (q) of sub-section (2) of section 13 of the Energy Conservation Act, 2001 (52 of 2001), the Bureau of Energy Efficiency, thus made the following regulations:

- 3 **Named as** Bureau of Energy Efficiency (Manner and Intervals for Conduct of Energy Audit in electricity distribution companies) Regulations, 2021.
- 4 These regulations shall apply to all electricity distribution companies specified as designated consumer.
- 5 They shall come into force on the date of their publication in the Official Gazette. (No: CG-DL-E-08102021-230245 Dated 06 October 2021).

### ***3. PURPOSE OF AUDIT AND ACCOUNTING REPORT***

---

Energy accounting and a consequent annual energy audit would help to identify areas of high loss and pilferage, and thereafter focus efforts to take corrective action. Energy Accounting means accounting of all energy inflows at various voltage levels in the distribution periphery of the network, including renewable energy generation and open access consumers, and energy consumption by the end consumers.

Owing to the impact of energy auditing on the entire distribution and retail supply business and absence of an existing framework with dedicated focus on the same, it was imperative to develop a set of comprehensive guidelines that all Distribution utilities across India can follow and adhere to.



#### 4. PERIOD OF ENERGY AUDIT AND ACCOUNTING

The table below shows the frequency of energy audit and energy accounting as per the BEE guidelines.

Table 5: Period of Energy Audit & Accounting – as per BEE guidelines

| Particulars       | Frequency  | Submission date  | Whom to submit | Who should submit         |
|-------------------|------------|--|----------------|---------------------------|
| Energy audit      | Every year | Within a period of 4 months from the expiry of the relevant financial year | BEE & SDA      | Accredited energy auditor |
| Energy accounting | Quarterly  | 45 days from the quarter   | BEE & SDA      | Certified energy manager  |

KDHP has initiated the energy audit in the month of July 2023 in order to submit the Energy audit report by 31<sup>st</sup> July 2023 as per the vide notification letter no: 11-10/5/2020-EC dated 27<sup>th</sup> October 2021 by the Ministry of Power. Thus, the KDHP entrusted the work to CEEP and the latter started the field study by late July - field study for 03 days - and draft report submitted in the month of August 2023.

#### 5. PROGRESS IN COMPLIANCE TO PREREQUISITES TO ENERGY ACCOUNTING

Table 6: Progress in energy accounting

| Quarter  | Submission date           | Ref no      |
|--|---------------------------|-------------|
| 1 <sup>st</sup> Quarter – 1 <sup>st</sup> April 2022 to 30 <sup>th</sup> June 2022 | 29 <sup>th</sup> Nov 2022 | EG-10/3089  |
| 2 <sup>nd</sup> quarter – 1 <sup>st</sup> July 2022 to 30 <sup>th</sup> Sept'2022  | 29 <sup>th</sup> Nov 2022 | EG-10/3089  |
| 3 <sup>rd</sup> Quarter - 1st Oct'2022 to 31st Dec'2022                            | 15 <sup>th</sup> Feb 2023 | EG-10/ 3837 |
| 4 <sup>th</sup> Quarter – 1 <sup>st</sup> Jan 2023 to 31 <sup>st</sup> Mar 2023    | 12 <sup>th</sup> May 2023 | EG – 10/394 |

## DISCOM INTRODUCTION AND OVERVIEW

### 1. NAME AND ADDRESS OF DESIGNATED CONSUMER

Table 7: Name and address of designated consumer

| General Details  | Description   |
|--|---|
| Registered Office address with telephone, fax nos. & e-mail  | <b>M/s Kanan Devan Hills Plantations (KDHP) Company Private Limited,</b><br>KDHP House, Munnar, Idukki District-Kerala -685612.<br>Ph: 04868 255002   |
| Company Chief executive name & details   | <b>Mr. Mathew Abraham</b><br><b>Managing Director</b><br>M/s Kanan Devan Hills Plantations (KDHP) Company Private Limited, KDHP House, Munnar, Idukki District-Kerala -685612<br>Ph: 04868 255002   |
| Authorized signatory of DC (Nodal Officer)   | <b>Mr. Raju U Warrior</b><br><b>Head - Engineering department</b><br>M/s Kanan Devan Hills Plantations (KDHP) Company Private Limited, KDHP House, Munnar, Idukki District-Kerala -685612<br>Ph: 04868 255101   |
| Energy Manager's Name, (Designated) Designation, Registration No., Address, Mobile, Telephone, Fax nos. & e-mail | <b>Mr. R. Jayaraman (Designated)</b><br>Executive – Engineering<br>M/s Kanan Devan Hills Plantations (KDHP) Company Private Limited, KDHP House, Munnar, Idukki District-Kerala -685612.<br>Mob: 9446130623<br>Ph: 04868 255107<br>Email: jayaraman.r@kdhptea.co.in |

### 2. ENERGY AUDIT CELL

Table 8: Energy audit cell

| Sr | Member of EAC               | Name           | Designation                   | Mobile number | Email                      |
|----|-----------------------------|----------------|-------------------------------|---------------|----------------------------|
| 1  | Nodal officer               | Raju U Warrior | Head - Engineering department | 04868 255101  | raju.warriar@kdhptea.co.in |
| 2  | Energy manager (designated) | R. Jayaraman   | Executive – Engineering       | 9446130623    | jayaraman.r@kdhptea.co.in  |
| 3  | IT manager                  | S. Edvin       | DGM Systems                   | 9249419895    | edwin.s@kdhptea.co.in      |
| 4  | Financial manager           | Sachin Prabu   | Deputy manager finance        | 9072888315    | sachin.prabu@kdhptea.co.in |

### 3. SUMMARY PROFILE OF DISCOM - FORM-1

The performance summary of KDHP as DISCOM as per the FY 2022-23 is given in the following table. The table below **incorporates the feedback energy (Energy sold outside the periphery) for the T&D loss calculation.**

Table 9: Summary of DISCOM – Form-1

| Performance Summary of Electricity Distribution Companies |  |                                  |         |
|---|--|----------------------------------|---------|
| <b>1</b>  | Period of Information<br>Year of (FY) information including Date and Month (Start & End) | 1st Apr, 2022 - 31st March, 2023 |         |
| <b>2</b>  | <b>Technical Details</b>   |                                  |         |
| <b>(a)</b>  | <b>Energy Input Details</b>  |                                  |         |
| (i)   | Input Energy Purchase<br>(From Generation Source)  | Million kWh                      | 54.118  |
| (ii)  | Net input energy (at DISCOM Periphery including sale outside periphery)                  | Million kWh                      | 59.048  |
| (iii)   | Total Energy billed (is the Net energy billed, adjusted for energy traded)               | Million kWh                      | 54.011  |
| <b>(b)</b>  | Transmission and Distribution (T&D) loss (Billing efficiency)                            | Million kWh                      | 5.038   |
|   |  | %                                | 8.53    |
|   | Collection Efficiency  | %                                | 99.673% |
| <b>(c)</b>  | Aggregate Technical & Commercial Loss  | %                                | 8.83%   |

The feeder wise T&D loss of the KDHP distribution system, **while considering the feedback energy (Energy outside the periphery)** is given in the following table:

Table 10: T & D loss – Summarised – feeder wise

| Feeder       | Energy transmitted Measured | T & D Loss (Estimated) | Commercial and other losses (Estimated) | Total loss (estimated) | Total loss (after error correction) | Energy Sales (Measured) | T&D loss |
|--------------|-----------------------------|------------------------|---|------------------------|-------------------------------------|-------------------------|----------|
|              | kWh                         | kWh                    | kWh                                     | kWh                    | kWh                                 | kWh                     | %        |
| Pullivasal   | 32,09,760                   | 1,59,394               | 6,560                                   | 1,65,954               | 1,65,954                            | 30,43,806               | 4.97     |
| ITD          | 98,80,776                   | 6,59,446               | 0                                       | 6,59,446               | 4,96,910                            | 93,83,866               | 6.67     |
| Town         | 99,46,400                   | 15,49,173              | 0                                       | 15,49,173              | 12,90,193                           | 86,56,207               | 15.58    |
| Nettigudi    | 1,05,78,900                 | 7,24,538               | 8,671                                   | 7,33,209               | 7,33,209                            | 98,45,691               | 6.85     |
| Neyamakad    | 1,11,24,064                 | 4,69,518               | 6,61,949                                | 11,31,467              | 11,31,467                           | 99,92,597               | 4.22     |
| Madupatty    | 1,49,80,826                 | 9,77,460               | 11,04,909                               | 20,82,369              | 20,82,369                           | 1,28,98,457             | 6.52     |
| <b>Total</b> | <b>59.72 MU</b>             | <b>4.54 MU</b>         | <b>1.78 MU</b>                          | <b>6.32 MU</b>         | <b>5.90 MU</b>                      | <b>53.82 MU</b>         |          |

**Note:**

- Considered only 6 feeders for the T&D loss analysis out of 7 feeders.
- **The 7<sup>th</sup> feeder which is called Station, is only having an annual consumption of 0.005MU which is too negligible to have any significant difference, which is being neglected during the T&D loss evaluation.**

- $Total\ loss = T\ \&\ D\ loss + Commercial\ loss$
- $Total\ loss\ corrected = Total\ loss\ after\ including\ feeder\ meter\ error$
- *Therefore: Commercial loss = 2.98% which can be accounted to the following losses:*
  1. *Error in the meter reading,*
  2. *Interruption losses and*
  3. *Tree touching losses in the HT/LT overhead cables.*

Energy flow diagram is given below in figure:




Figure 1: Energy flow diagram - KDHP

- *Input energy = the energy received at the KDHP for distribution including Feedback energy.*
- *Metered energy = energy metered at the consumer end*
- *Feedback energy = Energy sold outside the periphery*
- *T&D losses = Net losses*

**FORM INPUT ENERGY**

The table below shows the **major energy parameters for the FY 2022-23**

Table 11: Major energy parameters – KDHP DISCOM

| <b>Form-Input energy (Details of Input energy &amp; Infrastructure)</b> |   |   |  |
|---|---|---|--|
| <b>A. Summary of energy input &amp; Infrastructure</b>                  |   |   |  |
| <b>S. No</b>  | <b>Parameters</b>   | <b>Period from April 2022 to March 2023</b> | <b>Remarks (Source of data)</b>        |
| A.1   | Input Energy purchased (MU)   | 49.080                                      | Electricity bill                       |
| A.2   | Transmission loss (%)   | 0%  | Metering at the DISCOM periphery       |
| A.3   | Transmission loss (MU)  | 0   |  |
| A.4   | Energy sold outside the periphery (MU)  | 4.93  | Feedback energy - Tsoft                |
| A.5   | Open access sale (MU)   | 0   |  |
| A.6   | EHT sale  | 0   |  |
| A.7   | Net input energy (received at DISCOM periphery or at distribution point)-(MU) | 59.048                                      | Total Feeder Input – from Tsoft        |
| A.8   | Is 100% metering available at 66/33 kV (Select yes or no from list)           | No  |  |
| A.9   | Is 100% metering available at 11 kV (Select yes or no from list)              | Yes   |  |
| A.10  | % of metering available at DT   | 47%   | 63 out of 133 DT – physically measured |
|   | Total number of DT (Nos)  | 133   |  |
| A.11  | Total number of consumers (Nos)   | 16583                                       |  |
|   | Number of HT consumers (Nos)  | 36  |  |
|   | Number of LT consumers (Nos)  | 16547                                       |  |
| A.12  | % of metering available at consumer end                                       | 100%  |  |
| A.13  | No of feeders at 66kV voltage level   | 0   |  |
| A.14  | No of feeders at 33kV voltage level   | 0   |  |
| A.15  | No of feeders at 11kV voltage level   | 7   |  |
| A.16  | No of LT feeders' level   | 0   | Not available                          |
| A.17  | Line length (ckt. km) at 66kV voltage level                                   | 0   |  |
| A.18  | Line length (ckt. km) at 33kV voltage level                                   | 0   |  |
| A.19  | Line length (ckt. km) at 11kV voltage level                                   | 180.23                                      | Measured through HT line mapping       |
| A.20  | Line length (km) at LT level  | 193.8                                       | Measured through LT line mapping       |
| A.21  | Length of Aerial Bunched Cables   | 0   |  |
| A.22  | Length of Underground Cables  | 4.525                                       | From SLD                               |
| A.23  | HT/LT ratio   | 1:1.075                                     |  |

Table 12: Metered reading of input energy

| B. Meter reading of Input energy at injection points |   |        |                    |                 |  |   |   |                                     |   |  |                                     |                                      |             |             |             |                           |  |
|--|---|--------|--------------------|-----------------|--|---|---|-------------------------------------|---|--|-------------------------------------|--------------------------------------|-------------|-------------|-------------|---------------------------|--|
| S.No   | Zone                                      | Circle | Voltage Level (KV) | Feeder Name     | Feeder Metering Status (Metered/unmetered/AMI/AMR) | Status of Meter (Functional/Non-functional) | Metering Date                                   | Feeder Type (Agri/Industrial/Mixed) | Status of Communication                             |  |                                     | Period from April 2022 to March 2023 |             |             |             | Remarks (Source of data)  |  |
|  |   |        |                    |                 |  |   | Date of last actual meter reading/communication |                                     | % data received through automatically if feeder AMR | Number of hours when meter was unable to communicate in period | Total Number of hours in the period | Meter S.No                           | CT/PT ratio | Import (MU) | Export (MU) |                           |  |
| B.1  | KDHP                                      | KDHP   | 11                 | HR 1 & 2        | AMI  | Functioning                                 | 31-03-2023                                      | Mixed                               | 0   | 0  | NA                                  | KSE98355                             | 500/5       | 46.089      | -           | Switching station records |  |
| B.2  |   | KDHP   | 11                 | Pipeline (HR-3) | AMI  | Functioning                                 | 31-03-2023                                      | Mixed                               | 0   | 0  | NA                                  | 16116905                             | 200/5       | 8.700       | -           | Switching station         |  |
| B.3  |   | KDHP   | 11                 | Madupatty       | AMI  | Functioning                                 | 31-03-2023                                      | Mixed                               | 0   | 0  | NA                                  | 16088095                             | 200/5       | 4.259       | -           | Madupatty hydel           |  |
| B.1001   | Total (MU)                                |        |                    |                 |  |   |   |                                     |   |  |                                     |                                      |             | 59.048      | 0.00        |                           |  |
| B.1002   | Net input energy at DISCOM periphery (MU) |        |                    |                 |  |   |   |                                     |   |  |                                     |                                      | 59.048      |             |             |                           |  |

#### 4. ASSET MAPPING OF DISCOM

##### MAPPING - DT & 11 KV OH LINE

Mapping of the transformer, pole and 11 kV consumers were done to evaluate the distance which helps to calculate the HT line loss in KDHP.

GPS mapping was made using the Google map/ GPS meter collecting the latitude and longitude, and later projected into the relevant free software by naming the specific pole, DT and 11 kV consumer with serial numbers. The GPS mapping of HT lines done for 6 feeders out of 7, (station feeder was negligible) and the details are analyzed in this section.

##### FEEDER WISE MAPPING

Feeder wise HT line mapping is given below in charts in representation purpose and the distance of the DT from the switching station is given in the table below.

##### ➤ Pullivasal feeder

The following table shows the HT line distance in the 11 kV lines.

Table 13: HT line distance – Pullivasal feeder

| Route (From-To)                         | Cable type | Distance (km) |
|---|------------|---------------|
| Switching station - Attukad             | 7/14 ACSR  | 0.999         |
| Switching station - Node-1              | 7/14 Cu    | 0.252         |
| Node-1- Divan shrine                    | 7/14 ACSR  | 0.355         |
| Node-1-Pullivasal packeting             | 7/14 ACSR  | 0.447         |
| Pullivasal packeting-Pullivasal factory | 7/14 Cu    | 0.05          |
| Pullivasal packeting - Alla kovil trfr  | 7/14 ACSR  | 0.306         |
| <b>Total – 11 KV line length</b>        |            | <b>2.409</b>  |

The following table shows the important geographical location in Pullivasal feeder and its label mapped.

Table 14: Pole mapping – geographical location – Pullivasal feeder

| Point (Longitude, latitude) | name                  | label |
|-----------------------------|-----------------------|-------|
| POINT (77.056219 10.053957) | Switching station     | 0     |
| POINT (77.056354 10.054035) | Post 1                | P1    |
| POINT (77.063693 10.048943) | Attukad               | 2     |
| POINT (77.054891 10.052098) | Node-1                | N1    |
| POINT (77.056936 10.049611) | Divan shrine          | 4     |
| POINT (77.052431 10.048873) | Pallivasal Packeting  | 5     |
| POINT (77.052549 10.048435) | Pallivasal factory    | 6     |
| POINT (77.04983 10.047851)  | Allakovil transformer | 7     |






Figure 2: Pullivasal feeder

➤ **ITD feeder**

The following table shows the 11 kV line distance in the ITD feeder.

Table 15: HT line distance – ITD feeder

| <b>Route (From-To)</b>           | <b>Cable type</b> | <b>Distance (km)</b> |
|----------------------------------|-------------------|----------------------|
| Switching station-Node-1         | Mink              | 1.597                |
| Node-1-Node-2                    | Mink              | 3.931                |
| Node-2-Node-3                    | Racoon            | 0.214                |
| Node-3-Tata BSS                  | Racoon            | 0.025                |
| Node-3-Nallathani west divsn     | Racoon            | 0.086                |
| Node-2-ITD factory               | Mink              | 0.249                |
| ITD factory - Vermi compost      | 3/12 Cu           | 1.035                |
| Vermicompost - Node-4            | 3/12 Cu           | 1.24                 |
| Node-4-Kallar factory divsn      | No-8 Cu           | 0.17                 |
| Node-4- Kallar factory           | 3/12 Cu           | 0.0634               |
| kallar factory divsn-Node X      | No-8 Cu           | 1.69                 |
| Node X - Hospital bungalow       | No-8 Cu           | 0.295                |
| Node X - JE divsn                | No-8 Cu           | 1.582                |
| Node-1-Node-6                    | Racoon            | 1.471                |
| Node-6-Node-7                    | 3/12 Cu           | 0.533                |
| Node-7-Seven mally godown        | 3/12 Cu           | 0.103                |
| Node-7-Parvathi                  | 3/12 Cu           | 1.015                |
| Parvathi - Node-8                | 3/12 Cu           | 0.728                |
| Node-8-nadiar                    | 3/12 Cu           | 0.272                |
| Node-8-Kurumalai                 | 3/12 Cu           | 1.042                |
| Kurumalai - ITD pump             | 3/12 Cu           | 0.72                 |
| Node-6-Node-9                    | Racoon            | 0.804                |
| Node-9-Upper seven malai pump    | 7/12 Cu           | 0.189                |
| Node-9-Node-10                   | Racoon            | 0.351                |
| Node-10-Upper seven malai        | 7/14 ACSR         | 0.164                |
| Node-10-Node-11                  | Racoon            | 0.493                |
| Node-11-Ottupara                 | 3/12 Cu           | 0.77                 |
| Node-11-Node-12                  | Racoon            | 1.046                |
| Node-12-Latchmi east             | 7/14 ACSR         | 0.725                |
| Node-12-Node-13                  | Racoon            | 1.202                |
| Node-13-Letchmi factory          | 7/14 ACSR         | 0.065                |
| Node-13-Letchmi factory divsn    | Mink              | 0.161                |
| Node-13-Node-15                  | Racoon            | 1.584                |
| Node-15-Feedback to KSEB         | 7/14 ACSR         | 0.119                |
| Node-15-Letchmi viriparrai       | 7/14 ACSR         | 3.565                |
| <b>Total – 11 kV line length</b> |                   | <b>29.2994</b>       |

The following table shows the important geographical location in ITD feeder and its label mapped.

Table 16: Pole mapping – geographical location – ITD feeder

| Point (Longitude, Latitude) | name                      | label |
|-----------------------------|---------------------------|-------|
| POINT (77.056106 10.05425)  | Switching station         | 0     |
| POINT (77.057627 10.060088) | Post-1                    | P1    |
| POINT (77.058212 10.061171) | Post-2                    | P2    |
| POINT (77.058529 10.065404) | Post-3                    | P3    |
| POINT (77.057567 10.068182) | Node 1                    | N1    |
| POINT (77.051751 10.084131) | Post4                     | P4    |
| POINT (77.035731 10.093789) | Node-2                    | N2    |
| POINT (77.036927 10.095325) | Node-3                    | N3    |
| POINT (77.036954 10.095551) | Tata BSS                  | 1     |
| POINT (77.037657 10.095621) | Nullathanni West Division | 2     |
| POINT (77.034114 10.095375) | ITD factory               | 3     |
| POINT (77.024937 10.097594) | Vermi compost             | 4     |
| POINT (77.014213 10.094034) | Node-4                    | N4    |
| POINT (77.01283 10.093331)  | Kallar factory divsn      | 5     |
| POINT (77.013637 10.093973) | Kallar factory            | 8     |
| POINT (76.997448 10.09229)  | Node-X                    | NX    |
| POINT (76.997184 10.089631) | Hospital bungalow         | 7     |
| POINT (76.983522 10.088541) | JE Divsn                  | 6     |
| POINT (77.04427 10.06637)   | Node 6                    | N6    |
| POINT (77.04461 10.07118)   | Node 7                    | N7    |
| POINT (77.045553 10.071112) | Seven mally godown        | 9     |
| POINT (77.043542 10.080295) | Parvathi                  | 10    |
| POINT (77.03961 10.0856)    | Node-8                    | N8    |
| POINT (77.041957 10.086388) | Nadiar                    | 11    |
| POINT (77.030626 10.088698) | Kurumalai                 | 12    |
| POINT (77.024309 10.090491) | ITD pump                  | 13    |
| POINT (77.03694 10.06615)   | Node-9                    | N9    |
| POINT (77.036013 10.064702) | Upper seven malai pump    | 14    |
| POINT (77.033933 10.065045) | Node-10                   | N10   |
| POINT (77.033709 10.066515) | Upper seven malai         | 15    |
| POINT (77.029442 10.065188) | Node-11                   | N11   |
| POINT (77.028984 10.05825)  | Ottupara                  | 16    |
| POINT (77.0199 10.06549)    | Node 12                   | N12   |
| POINT (77.019217 10.072013) | Letchmi east              | 17    |
| POINT (77.008969 10.066412) | Node-13                   | N13   |
| POINT (77.008976 10.067004) | Letchmi factory           | 18    |
| POINT (77.008036 10.067532) | Letchmi factory divs      | 19    |
| POINT (76.994514 10.066324) | Node-15                   | N15   |
| POINT (76.994095 10.065336) | Feedback to KSEB          | F1    |
| POINT (76.96406 10.07765)   | Letchmi viriparrai        | 20    |




Figure 3: ITD feeder

➤ **Neyamakad feeder**

The following table shows the 11 kV line distance in the Neyamakad feeder.

Table 17: HT line distance – Neyamakad feeder

| Route (From-To)             | Cable type | Distance (km) |
|-----------------------------|------------|---------------|
| Node-1- Nallathanni factory | Racoon     | 0.448         |
| Node-2-Node-3               | Dog        | 0.966         |
| Node-3 - Tea Museum         | 3/12 Cu    | 0.093         |
| Node-3- DYSP bungalow       | Racoon     | 0.961         |
| DYSP bungalow- Node-4       | Racoon     | 0.706         |
| Node-4 - Periyavurrai lower | 7/14 ACSR  | 0.991         |
| Node-4- Node-5              | Racoon     | 0.387         |
| Node-5-Node-6               | Racoon     | 0.501         |
| Node-5-Sholamalai           | 7/14 ACSR  | 1.201         |
| Node-6-Node-7               | 3/12 Cu    | 0.12          |
| Node-7-Periyavurrai factory | 3/12 Cu    | 0.015         |
| Node-7-Anamudi              | 7/14 ACSR  | 1.314         |
| Node-6-Node-8               | Racoon     | 0.865         |
| Node-8- Kanniar bungalow    | No.8 Cu    | 0.113         |
| Node-8-Node-9               | Racoon     | 0.949         |
| Node-9-Node-10              | 7/14 ACSR  | 0.8           |
| node-10-Kannimalai top      | 7/14 ACSR  | 1.613         |
| Node-10-Kannimalai lower    | 7/14 ACSR  | 0.009         |
| Node-9-Node-11              | Racoon     | 0.067         |
| Node-11-Kanniamalai factory | 7/14 Cu    | 0.106         |
| Node-12-Node-13             | Racoon     | 0.75          |
| Node-13-Node-14             | 7/14 ACSR  | 0.504         |
| Node-14-Nymakad bungalow    | 7/14 ACSR  | 0.131         |
| NOde-14 Nyamakad east       | 7/14 ACSR  | 0.604         |
| Node-13-Node-15             | Racoon     | 3.466         |
| Node-15- Vagavurrai top     | 7/14 ACSR  | 0.104         |
| Node-15-Node-16             | Racoon     | 1.509         |
| Node-16-Vagavurrai lower    | 7/14 ACSR  | 0.03          |
| Node-16-Node-17             | Racoon     | 0.843         |
| Node-17-Node-18             | 3/12 CU    | 0.132         |
| Node-18-Vagavurrai bazar    | Racoon     | 0.118         |
| Node-18-Node-19             | 3/12 Cu    | 0.375         |
| Node-19 - Thaliar bungalow  | 3/12 Cu    | 0.207         |
| Node-19-Node-20             | 3/12 Cu    | 0.562         |
| Node-20-Thaliar divsn       | 7/14 ACSR  | 0.051         |
| Node-20 Thaliar factory     | 3/12 Cu    | 0.525         |
| Node-17-Node-21             | Racoon     | 1.011         |
| Node-21-Manager bungalow    | 3/12 Cu    | 0.0567        |
| Node-21-Node-22             | Racoon     | 0.267         |
| Node-22-Vagavurrai factory  | 7/14 ACSR  | 0.102         |

| Route (From-To)                       | Cable type | Distance (km)  |
|---------------------------------------|------------|----------------|
| Vagavurrai factory - factory division | 7/14 ACSR  | 0.22           |
| Vagavurrai factory - vagavurrai naval | 7/14 ACSR  | 1.497          |
| Vagavurrai naval- Vagavurrai luckam   | 7/14 ACSR  | 0.733          |
| Node-11-Node-23                       | 3/12 Cu    | 1.24           |
| Node-23-Rajamalai west BSNL           | 7/14 ACSR  | 0.063          |
| Node-12-Node-23                       | 3/12 Cu    | 0.5            |
| Node-12-Node-24                       | 3/12 CU    | 0.46           |
| Node-24- Forest                       | 7/14 ACSR  | 0.235          |
| Node-24-Node-25                       | 3/12 Cu    | 0.553          |
| Node-25-Node-26                       | 3/12 Cu    | 0.532          |
| Node-26-Kadalaar bunglow              | 7/14 ACSR  | 0.165          |
| Node-26-Node-27                       | 3/12 Cu    | 1.702          |
| Node-27-Kadalaar hospital             | No-8 Cu    | 0.435          |
| Kadalaar hospital- factory division   | 3/12 CU    | 1.338          |
| Kadalaar factory divsn - factory      | 3/12 Cu    | 0.028          |
| Node-25-Node-29                       | 3/12 Cu    | 0.437          |
| Node-29- Rajamalai park               | 3/12 Cu    | 0.022          |
| Node-29- Wireless station             | 3/12 CU    | 1.004          |
| Wireless station- rajamalai divsn     | no-8 Cu    | 1.685          |
| Rajamalai divsn - pettimudi           | 3/12 Cu    | 1.004          |
| Switching station - Node-1            | DOG        | 5.124          |
| Node-1-Node-2                         | Dog        | 0.631          |
| Node-2- Srishti                       | 7/14 ACSR  | 0.261          |
| <b>Total - 11 kV line length</b>      |            | <b>43.4417</b> |

The following table shows the important geographical location in Neyamakad feeder and its label mapped.

Table 18: Pole mapping – geographical location – Neyamakad feeder

| Point (Longitude, latitude) | name                 | label |
|-----------------------------|----------------------|-------|
| POINT (77.035238 10.091585) | Node-1               | N1    |
| POINT (77.034228 10.095515) | Nallathani factory   | 2     |
| POINT (77.040967 10.092189) | Node-2               | N2    |
| POINT (77.049583 10.094029) | Node-3               | N3    |
| POINT (77.050324 10.094443) | Tea museum           | 3     |
| POINT (77.0582 10.095645)   | DYSP bunglow         | 4     |
| POINT (77.05812 10.102025)  | Node-4               | N4    |
| POINT (77.067083 10.100842) | Periyavurrai lower   | 5     |
| POINT (77.058286 10.105527) | Node-5               | N5    |
| POINT (77.058013 10.11005)  | Node-6               | N6    |
| POINT (77.048316 10.110036) | Sholamalai           | 6     |
| POINT (77.059078 10.110278) | Node-7               | N7    |
| POINT (77.058942 10.110281) | Periyavurrai factory | 7     |
| POINT (77.070854 10.108038) | Anamudi              | 8     |

| <b>Point (Longitude, latitude)</b> | <b>name</b>                 | <b>label</b> |
|------------------------------------|-----------------------------|--------------|
| POINT (77.056598 10.117744)        | Node-8                      | N8           |
| POINT (77.057631 10.117728)        | Kanniar bunglow             | 9            |
| POINT (77.055919 10.1263)          | Node-9                      | N9           |
| POINT (77.063201 10.12684)         | Node-10                     | N10          |
| POINT (77.077876 10.125683)        | Kannimalai top              | 10           |
| POINT (77.063214 10.126921)        | Kannimalai lower            | 11           |
| POINT (77.056089 10.126889)        | Node-11                     | N11          |
| POINT (77.057054 10.126877)        | Kannimalai factory          | 12           |
| POINT (77.053001 10.142317)        | Node-12                     | N12          |
| POINT (77.058432 10.146438)        | Node-13                     | N13          |
| POINT (77.06277 10.144905)         | Node-14                     | N14          |
| POINT (77.063875 10.144442)        | Nymakad bunglow             | 13           |
| POINT (77.067116 10.14154)         | Nymakad east                | 14           |
| POINT (77.083467 10.1656)          | Node-15                     | N15          |
| POINT (77.083976 10.164802)        | Vagavurrai top              | 15           |
| POINT (77.094699 10.173498)        | Node-16                     | N16          |
| POINT (77.094904 10.173315)        | vagavurrai lower            | 16           |
| POINT (77.101003 10.169121)        | Node-17                     | N17          |
| POINT (77.101586 10.168073)        | Node-18                     | N18          |
| POINT (77.102182 10.168967)        | Vagavurrai bazar            | 17           |
| POINT (77.104281 10.165987)        | Node-19                     | N19          |
| POINT (77.102462 10.165477)        | Thaliar bunglow             | 18           |
| POINT (77.104022 10.16091)         | Node-20                     | N20          |
| POINT (77.104477 10.161024)        | Thaliar division            | 20           |
| POINT (77.102165 10.15653)         | Thaliar factory             | 19           |
| POINT (77.103176 10.174948)        | Post-4                      | P4           |
| POINT (77.105765 10.176369)        | Node-21                     | N21          |
| POINT (77.105295 10.176583)        | Manager bunglow             | 21           |
| POINT (77.10614 10.178756)         | Feedback-2 marayur          | F2           |
| POINT (77.106801 10.178105)        | Vagavurrai factory          | 22           |
| POINT (77.108806 10.178187)        | Vagavurrai factory division | 23           |
| POINT (77.120471 10.185247)        | Vagavurrai naval            | 24           |
| POINT (77.123458 10.191181)        | Vagavurrai luckam           | 25           |
| POINT (77.053877 10.137877)        | Node-23                     | N23          |
| POINT (77.053298 10.13786)         | Rajamalai west BSNL         | 26           |
| POINT (77.048904 10.14322)         | Node-24                     | N24          |
| POINT (77.050417 10.144732)        | Forest                      | 27           |
| POINT (77.043874 10.14277)         | Node-25                     | N25          |
| POINT (77.04138 10.141797)         | Post-5                      | P5           |
| POINT (77.041244 10.139644)        | Node-26                     | N26          |
| POINT (77.040917 10.138187)        | Kadalaar bunglow            | 28           |
| POINT (77.033895 10.126081)        | Node-27                     | N27          |
| POINT (77.032573 10.129793)        | Kadalaar hospital           | 29           |
| POINT (77.020959 10.133532)        | Kadalaar factory division   | 30           |
| POINT (77.021027 10.133285)        | Kadalaar factory            | 31           |



|                             |                    |     |
|-----------------------------|--------------------|-----|
| POINT (77.039931 10.143395) | Node-29            | N29 |
| POINT (77.03974 10.143316)  | Rajamalai park     | 32  |
| POINT (77.031271 10.14637)  | REP (wireless) stn | 33  |
| POINT (77.018922 10.155454) | Rajamalai division | 34  |
| POINT (77.012112 10.161538) | Pettimudi          | 35  |
| POINT (77.056264 10.05429)  | Switching station  | 0   |
| POINT (77.057627 10.060088) | Post-1             | P1  |
| POINT (77.058212 10.061171) | Post-2             | P2  |
| POINT (77.058529 10.065404) | Post-3             | P3  |
| POINT (77.041383 10.094516) | Srishti            | 1   |




Figure 4: Neyamakad feeder

➤ **Nettigudi feeder**

The following table shows the 11 kV line distance in the Nettigudi feeder.

Table 19: HT line distance – Nettigudi feeder

| Route (From-To)                  | Cable type | Distance (km) |
|----------------------------------|------------|---------------|
| Switching station- Node-1        | Racoon     | 2.651         |
| Node-1-Node-2                    | Racoon     | 0.343         |
| Node-2- Chokanad south           | 7/12 Cu    | 0.076         |
| Node-2-Node-3                    | Racoon     | 1.101         |
| Node-4-Node-5                    | Racoon     | 0.361         |
| Node-5-Node-6                    | Racoon     | 0.1024        |
| Node-6-KWA Feedback              | Racoon     | 0.446         |
| Node-3-Chokanad east             | N0 8 CU    | 1.045         |
| Node-4- Chokanad K Kai           | 7/14 ACSR  | 0.36          |
| Node-3-Chokanad north            | 7/14 ACSR  | 1.107         |
| Node-5-Alisa craig               | 7/14 ACSR  | 0.716         |
| Node-6-Ladbrock                  | 7/14 ACSR  | 0.033         |
| KWA feedback- Node-8             | Racoon     | 0.334         |
| Node-8-Earlston                  | 7/12 Cu    | 0.226         |
| Node-8-Forest                    | 3/12 Cu    | 0.13          |
| Forest-Node-9                    | 3/12 Cu    | 0.884         |
| Node-9-KSEB feedback             | 3/12 Cu    | 0.168         |
| Node-9-Node-10                   | 3/12 Cu    | 1.541         |
| Node-10-Lockhart factory         | No-8Cu     | 0.101         |
| Node-10-Lockhart colony          | 7/12 ACSR  | 0.757         |
| Node-11-Node-17                  | Racoon     | 0.123         |
| Node-12-Gunderle manager         | 3/12 Cu    | 0.01          |
| Node-12-Node-13                  | 3/12 Cu    | 1.167         |
| Node-13-Gunderle factory divsn   | 7/14 ACSR  | 0.0087        |
| Node-13-Node-14                  | 3/12 Cu    | 0.346         |
| Node-14 - Gunderle factory       | 3/12 Cu    | 0.038         |
| Node-14-Node-15                  | 3/12 Cu    | 1.268         |
| Node-15-BSNL                     | 7/14 ACSR  | 0.138         |
| Node-15-Node-16                  | 3/12 Cu    | 0.401         |
| Node-16-Silent valley divsn      | 7/14 ACSR  | 0.239         |
| Node-16-Silent valley office     | 3/12Cu     | 1.097         |
| Node-17-Gunderle lower           | 7/14 ACSR  | 0.0668        |
| Node-17-Node-18                  | Racoon     | 0.519         |
| Node-18-Gunderle center          | 7/14 ACSR  | 0.059         |
| Node-18-Node-19                  | Racoon     | 0.711         |
| Node-19-GUnderle top             | 7/14 Cu    | 0.142         |
| Node-19-Node-20                  | 7/14 Cu    | 1.087         |
| Node-20-Node-21                  | 3/12 Cu    | 0.799         |
| Node-21-Devikulam middle         | 7/12 Cu    | 0.053         |
| Node-21-Node-22                  | 3/12 Cu    | 0.989         |
| Node-22-Devikulam factory        | 3/12Cu     | 0.035         |
| Node-22- Devikulam factory divsn | 7/14 ACSR  | 0.0559        |
| Node-20-Node-23                  | 7/14 Cu    | 1.871         |

|                                   |           |                |
|-----------------------------------|-----------|----------------|
| Node-23-Devikulam ODK             | 7/14 ACSR | 0.09           |
| Node-23-Periyakanal PH divsn      | 3/12 Cu   | 1.92           |
| Periyakanal Ph Divsn - Node-24    | 3/12 Cu   | 0.629          |
| Node-24-Ayur county               | 7/12 ACSR | 0.183          |
| Node-24-Node-25                   | 7/14 CU   | 1.191          |
| Node-25-Periyakanal Factory divsn | 3/12 Cu   | 0.077          |
| Node-25-Periyakanal factory       | 7/14 Cu   | 0.095          |
| Node-3-Node-4                     | Racoon    | 0.239          |
| Node-11-Node-12                   | 3/12 Cu   | 1.052          |
| Node-8-Node-11                    | Racoon    | 3.296          |
| <b>Total - 11 kV line length</b>  |           | <b>32.4778</b> |

The following table shows the important geographical location in Nettigudi feeder and its label mapped.

Table 20: Pole mapping – geographical location – Nettigudi feeder

| Point (Longitude, Latitude) | name              | label |
|-----------------------------|-------------------|-------|
| POINT (77.073322 10.06827)  | Node-1            | N1    |
| POINT (77.072928 10.068345) | Chokanad factory  | 1     |
| POINT (77.056264 10.05429)  | Switching station | 0     |
| POINT (77.057627 10.060088) | Post-1            | P1    |
| POINT (77.058212 10.061171) | Post-2            | P2    |
| POINT (77.060037 10.061869) | Post-3            | P3    |
| POINT (77.063407 10.063946) | Post-4            | P4    |
| POINT (77.066954 10.066567) | Post-5            | P5    |
| POINT (77.076409 10.068811) | Node-2            | N2    |
| POINT (77.075749 10.069031) | Chokanad south    | 2     |
| POINT (77.079836 10.069593) | Post-6            | P6    |
| POINT (77.086296 10.070569) | Node-3            | N3    |
| POINT (77.088449 10.070897) | Node-4            | N4    |
| POINT (77.091583 10.071894) | Node-5            | N5    |
| POINT (77.092377 10.072382) | Node -6           | N6    |
| POINT (77.095981 10.074258) | kWA feedback      | F1    |
| POINT (77.086818 10.061129) | Chokanad east     | 3     |
| POINT (77.088745 10.069228) | Post 8            | P8    |
| POINT (77.09022 10.068689)  | Chokanad K Kai    | 5     |
| POINT (77.085672 10.076794) | Post-7            | P7    |
| POINT (77.081953 10.077531) | Chokanad north    | 4     |
| POINT (77.090014 10.078181) | Alisa craig       | 6     |
| POINT (77.092394 10.072083) | Ladbrock          | 7     |
| POINT (77.099023 10.074395) | Node-8            | N8    |
| POINT (77.101008 10.073823) | Earlston          | 8     |
| POINT (77.099762 10.073476) | Forest            | 9     |
| POINT (77.106477 10.069049) | Node-9            | N9    |
| POINT (77.107143 10.068293) | Post-9            | P9    |
| POINT (77.107205 10.067777) | KSEB feedback     | 10    |

|                             |                           |      |
|-----------------------------|---------------------------|------|
| POINT (77.109637 10.055465) | Node-10                   | N10  |
| POINT (77.109169 10.054673) | Lockhart factory          | 12   |
| POINT (77.112005 10.049033) | Lockhart colony           | 11   |
| POINT (77.128314 10.081142) | Node-11                   | N11  |
| POINT (77.137218 10.077591) | Node-12                   | N12  |
| POINT (77.129124 10.080371) | Node-17                   | N17  |
| POINT (77.137202 10.07768)  | Gunderle manager          | 13   |
| POINT (77.138827 10.074873) | Post-10                   | P10  |
| POINT (77.146204 10.073733) | Node-13                   | N13  |
| POINT (77.146281 10.073755) | Gunderle factory divn     | 14   |
| POINT (77.148957 10.072203) | Node-14                   | N14  |
| POINT (77.149057 10.072534) | Gunderle factory          | 15   |
| POINT (77.160263 10.069767) | Node-15                   | N15  |
| POINT (77.161501 10.069995) | BSNL                      | 16   |
| POINT (77.163486 10.071498) | Node-16                   | N16  |
| POINT (77.164028 10.0694)   | Silent valley divn        | 17   |
| POINT (77.170147 10.078903) | Silent valley office      | 18   |
| POINT (77.128551 10.080578) | Gunderle lower            | 19   |
| POINT (77.127884 10.07584)  | Node-18                   | N18  |
| POINT (77.127347 10.075901) | Gunderle center           | 20   |
| POINT (77.126862 10.069493) | Node-19                   | N19  |
| POINT (77.12683 10.068207)  | Gunderle top              | 21   |
| POINT (77.131116 10.063566) | Post-12                   | P12  |
| POINT (77.132994 10.061812) | Node-20                   | N20  |
| POINT (77.129247 10.055611) | Node-21                   | N-21 |
| POINT (77.129649 10.055342) | Devikulam middle          | 22   |
| POINT (77.122731 10.049414) | Node-22                   | N-22 |
| POINT (77.122914 10.049154) | Devikulam factory         | 24   |
| POINT (77.122229 10.049629) | Devikulam factory divsn   | 23   |
| POINT (77.144723 10.049517) | Node-23                   | N23  |
| POINT (77.144768 10.050335) | Devikulam ODK             | 25   |
| POINT (77.146296 10.04841)  | Post 13                   | P13  |
| POINT (77.15195 10.041476)  | Post 14                   | P14  |
| POINT (77.156208 10.03648)  | Periyakanal PH divsn      | 26   |
| POINT (77.160964 10.0333)   | Node-24                   | N24  |
| POINT (77.160901 10.031759) | Post-15                   | P15  |
| POINT (77.160787 10.031771) | Ayur county               | 27   |
| POINT (77.168847 10.025889) | Node-25                   | N25  |
| POINT (77.169476 10.026206) | Periyakanal factory divsn | 28   |
| POINT (77.169368 10.025197) | Periyakanal factory       | 29   |




Figure 5: Nettigudi feeder

➤ **Town feeder**

The following table shows the 11 kV line distance in the Town feeder.

Table 21: HT line distance – Town feeder

| Route (From-To)                     | label     | Distance (km) |
|-------------------------------------|-----------|---------------|
| Switching station - Node-1          | Racoon    | 1.734         |
| Node-1-Old munnar tea testing       | 3/12 Cu   | 0.053         |
| Node-1-Node-2                       | 7/14 Cu   | 0.521         |
| Node-2-Casa montana                 | 7/14 ACSR | 0.107         |
| Node-2-Node-3                       | 7/14 Cu   | 0.094         |
| Node-3-Node-4                       | 7/12 Cu   | 0.166         |
| Node-4-Munnar palace                | 7/12 Cu   | 0.021         |
| Node-4- High range club             | 7/12 Cu   | 0.234         |
| Node-3-node-5                       | 7/14 Cu   | 0.054         |
| Node-5-Node-7                       | 7/14 Cu   | 0.384         |
| Node-7-Node-8                       | 7/14 Cu   | 0.047         |
| Node-8-Node-10                      | 7/14 Cu   | 0.744         |
| Node-5-Node-6                       | 7/14 Cu   | 0.0467        |
| Node-6-Poopada                      | 7/14 Cu   | 0.191         |
| Node-6-MS hotel                     | 7/14 Cu   | 0.0776        |
| Node-7-Workshop club                | 7/12 ACSR | 0.0805        |
| Node-8-EVM                          | 3/12 Cu   | 0.128         |
| EVM-Node-9                          | 3/12 Cu   | 0.0609        |
| Node-9-Workshop                     | 3/12 Cu   | 0.0165        |
| Node-9-Shikshak sadan               | 7/14 ACSR | 0.08          |
| Node-10-RO                          | 3/12 Cu   | 0.0146        |
| Node-10-Node-11                     | 7/14 Cu   | 0.141         |
| Node-11-Node-12                     | 7/14 ACSR | 0.217         |
| Node-12-Tea County                  | 7/14 ACSR | 0.156         |
| Node-12-Node-13                     | 7/14 ACSR | 0.401         |
| Node-13-Teachers quarters           | 7/14 ACSR | 0.19          |
| Node-13-Grahamsland pump            | 7/14 ACSR | 1.215         |
| Teachers' quarters KWA pump         | 7/14 ACSR | 0.205         |
| KWA pump-Botanical Garden           | 7/14 ACSR | 0.169         |
| Node-11-Node-14                     | 7/14 Cu   | 0.111         |
| Node-14-Eastend                     | 7/14 ACSR | 0.0567        |
| Node-14-Node-15                     | 7/14 Cu   | 0.164         |
| Node-15-BSNL                        | Racoon    | 0.206         |
| Node-15-Town                        | 7/14 Cu   | 0.061         |
| Node-15-Node-16                     | 7/14 ACSR | 0.149         |
| Node-16-Node-17                     | 7/12 Cu   | 0.747         |
| Node-17-Nirmala society             | 7/12 Cu   | 0.335         |
| Node-17- GH                         | No-8 Cu   | 0.231         |
| Node-16 - KSEB                      | 7/14 ACSR | 0.339         |
| KSEB - Node-18                      | 7/14 ACSR | 0.0265        |
| Node-18- Feedback KSEB              | 7/14 ACSR | 0.036         |
| Node-18-Node-19                     | 7/14 ACSR | 0.455         |
| Node-19-OCR                         | 7/14 ACSR | 0.026         |
| Node-19- Munnar engineering college | 7/14 ACSR | 0.147         |
| <b>Total – 11 kV line length</b>    |           | <b>10.639</b> |



The following table shows the important geographical location in Town feeder and its label mapped.

Table 22: Pole mapping – geographical location – Town feeder

| <b>Point (Longitude, Latitude)</b> | <b>name</b>                 | <b>label</b> |
|------------------------------------|-----------------------------|--------------|
| POINT (77.056264 10.05429)         | Switching station           | 0            |
| POINT (77.057627 10.060088)        | Post-1                      | P1           |
| POINT (77.058212 10.061171)        | Post-2                      | P2           |
| POINT (77.059084 10.065243)        | Post-3                      | P3           |
| POINT (77.060096 10.069503)        | Node-1                      | N1           |
| POINT (77.060579 10.069438)        | Old munnar tea tasting      | 1            |
| POINT (77.061854 10.072979)        | Post-4                      | P4           |
| POINT (77.06213 10.073753)         | Node-2                      | N2           |
| POINT (77.061276 10.073722)        | Post-5                      | P5           |
| POINT (77.061275 10.073842)        | Casa montana                | 2            |
| POINT (77.062438 10.074553)        | Node-3                      | N3           |
| POINT (77.063831 10.073963)        | Node-4                      | N4           |
| POINT (77.063958 10.074109)        | Munnar palace (Grand plaza) | 4            |
| POINT (77.065121 10.072282)        | High range club             | 3            |
| POINT (77.062662 10.074988)        | Node-5                      | N5           |
| POINT (77.063297 10.076859)        | Post-6                      | P6           |
| POINT (77.063415 10.078354)        | Node-7                      | N7           |
| POINT (77.063231 10.078741)        | Node-8                      | N8           |
| POINT (77.062108 10.085379)        | Node-10                     | N10          |
| POINT (77.062297 10.075206)        | Node-6                      | N6           |
| POINT (77.060667 10.075819)        | Poopada                     | 5            |
| POINT (77.061718 10.074801)        | MS hotel                    | 6            |
| POINT (77.064143 10.078253)        | Workshop club               | 7            |
| POINT (77.062101 10.078431)        | EVM                         | 8            |
| POINT (77.061838 10.078916)        | Node-9                      | N9           |
| POINT (77.061949 10.079017)        | Workshop                    | 9            |
| POINT (77.061718 10.07963)         | Shikshak sadan              | 10           |
| POINT (77.061987 10.085324)        | RO                          | 11           |
| POINT (77.061371 10.086433)        | Node-11                     | N11          |
| POINT (77.063319 10.086054)        | Node-12                     | N12          |
| POINT (77.064673 10.086506)        | Tea county                  | 12           |
| POINT (77.066978 10.086149)        | Node-13                     | N13          |
| POINT (77.06745 10.08591)          | Post-7                      | P7           |
| POINT (77.068532 10.085384)        | Teachers quarters           | 14           |
| POINT (77.078061 10.086526)        | Grahamsland pump            | 13           |
| POINT (77.070125 10.084413)        | KWA pump                    | 15           |
| POINT (77.071103 10.084187)        | Post-8                      | P8           |
| POINT (77.071386 10.08373)         | Botanical garden            | 16           |
| POINT (77.061953 10.087259)        | Node-14                     | N14          |
| POINT (77.062467 10.087201)        | Eastend                     | 17           |
| POINT (77.060454 10.087308)        | Node-15                     | N15          |
| POINT (77.059363 10.086913)        | Post-9                      | P9           |
| POINT (77.059628 10.08625)         | BSNL                        | 18           |
| POINT (77.0599 10.087396)          | Town                        | 19           |
| POINT (77.061617 10.088009)        | Node-16                     | N16          |

|                             |                            |     |
|-----------------------------|----------------------------|-----|
| POINT (77.060492 10.089264) | Post-10                    | P10 |
| POINT (77.060043 10.090406) | Post-11                    | P11 |
| POINT (77.058989 10.089915) | Post-12                    | P12 |
| POINT (77.056435 10.090851) | Node-17                    | N17 |
| POINT (77.054469 10.092259) | Post-13                    | P13 |
| POINT (77.054031 10.09181)  | Nirmala society            | 20  |
| POINT (77.05559 10.08894)   | GH                         | 21  |
| POINT (77.064652 10.088607) | KSEB                       | 22  |
| POINT (77.064882 10.088683) | Node-18                    | N18 |
| POINT (77.065181 10.088813) | Feedback KSEB              | F1  |
| POINT (77.066098 10.08926)  | Post-14                    | P14 |
| POINT (77.067622 10.091599) | Node-19                    | N19 |
| POINT (77.067402 10.091684) | OCR                        | 24  |
| POINT (77.067567 10.092932) | Munnar engineering college | 25  |




Figure 6: Town feeder

➤ **MADUPATTI FEEDER**

The following table shows the 11 kV line distance in the Madupatti feeder.

| name                                      | label     | Distance |
|---|-----------|----------|
| Switching station - Node-1                | Racoon    | 2.656    |
| Node-1- Westwood                          | Racoon    | 0.228    |
| Node-1-Node-2                             | Racoon    | 1.105    |
| Node-2 - Grahmsland office                | Racoon    | 0.921    |
| Grahamslan office - Post11                | Racoon    | 0.064    |
| Post-11 Node-3                            | Racoon    | 0.662    |
| Node- Grahmsland bazaar                   | 7/14 ACSR | 0.202    |
| Node-4 - Grahamsland bungalows            | 7/12 ACSR | 0.016    |
| Node-5 KKD church                         | 7/14 ACSR | 0.0067   |
| Node-6 HR School                          | 7/14 ACSR | 0.018    |
| Node-6 - Node-7                           | Racoon    | 0.563    |
| Node-7- Node-8                            | 3/12 Cu   | 0.85     |
| Node-8- Madupatty division                | 7/14 ACSR | 1.088    |
| Node8 - node-9                            | 7/14 ACSR | 0.254    |
| Node-9 - R&D complex                      | 7/14 ACSR | 0.61     |
| Node-9 - R& D lab                         | 7/14 ACSR | 0.971    |
| Node-9 - Node-10                          | No6 Cu    | 1.558    |
| Node-10 - Thenmalay asst manager bungalow | 7/14 ACSR | 0.889    |
| Node-10 - Node-11                         | No-6 CU   | 1.093    |
| Node-11 - Thenmalar factory divsn         | 7/14 ACSR | 0.012    |
| Node-11- Node-12                          | No6 Cu    | 0.276    |
| Node-12 - Thenmalay new divsn             | 7/14 ACSR | 1.618    |
| Node-12 Tenmalay factory                  | No-6 Cu   | 0.067    |
| Node-7 - node-13                          | Racoon    | 0.186    |
| Node-13 Madupatty factory                 | 7/14 ACSR | 0.045    |
| Node-13- node-14                          | Mink      | 0.222    |
| Node-14 - Madupatty divsn                 | 7/14 ACSR | 0.012    |
| Node-14- Node-15                          | Mink      | 0.372    |
| Node-15 Madupatty dam feedback            | Mink      | 0.025    |
| Node-15 - Madupatty hydel                 | Mink      | 0.092    |
| Node-13-Node-16                           | Racoon    | 0.155    |
| Node-16 - Nettimadu divsn                 | 7/14 ACSR | 0.297    |
| Node-16- Node-17                          | Racoon    | 1.839    |
| Node-17 - High tech KLD board             | Racoon    | 0.224    |
| Node-17-Node-18                           | Racoon    | 0.34     |
| Node-18 - Indo swiss project              | 3/12 Cu   | 0.02     |
| Node-18-Node-19                           | Racoon    | 0.451    |
| Node-19-Node-20                           | 3/12 Cu   | 2.249    |
| Node-20- Gundumalay factory               | 7/14 ACSR | 0.048    |
| Node-20-Node-21                           | 7/14 ACSR | 0.362    |
| Node-21 - gundumalay factory divsn        | 7/14 ACSR | 0.032    |
| Node-21-Node-22                           | 3/12 Cu   | 1.167    |
| Node-22 - Gunduamaly benmore              | 7/14 ACSR | 0.087    |
| Node-22- Node-23                          | 7/14 ACSR | 0.817    |
| Node-23-Node-24                           | 7/12 ACSR | 0.711    |

|                                    |           |       |
|------------------------------------|-----------|-------|
| Node-24- Gundumalay southpara      | 7/14 ACSR | 0.038 |
| Node-24- Node-25                   | 7/14 ACSR | 0.729 |
| Node-25- Gundumalay new divsn      | 7/14 ACSR | 0.973 |
| Node-25 - Gundumalay BSNL          | 7/14 ACSR | 0.687 |
| Node-23-Node-26                    | 7/14 ACSR | 0.936 |
| Node-26- Gundumalay upper          | 7/14 ACSR | 0.072 |
| Node-26-Node-27                    | 7/14 ACSR | 0.201 |
| Node-27 - Gundumalay lower         | 3/12 Cu   | 0.915 |
| Node-27- Gundumalay kadugu         | 7/14 ACSR | 1.607 |
| Node-19-Node-28                    | Racoon    | 0.902 |
| Node-28-Node-29                    | 7/14 ACSR | 0.882 |
| Node-29- New pump indo swiss       | 7/14 ACSR | 0.52  |
| Node-29-Node-31                    | Racoon    | 0.582 |
| Node-31- Ecopoint                  | 7/14 ACSR | 0.121 |
| Node-31-Node-32                    | Racoon    | 0.937 |
| Node-32- East divsn pachakkad      | 7/14 ACSR | 0.264 |
| Node-32-Node-33                    | Racoon    | 2.23  |
| Node-32-Node-35                    | Racoon    | 0.251 |
| Node-35-Pudukkadi                  | 7/14 ACSR | 0.007 |
| Node-35-Node-36                    | Racoon    | 2.058 |
| Node-36-Feedback dam LT            | 7/14 ACSR | 0.195 |
| Node-36-Node-37                    | 7/14 ACSR | 1.702 |
| Node-37- Yelappaty divsn           | 7/12 ACSR | 0.235 |
| Node-37- Yelapatty factory         | 7/14 ACSR | 0.093 |
| Node-36-Node-43                    | 7/14 Cu   | 1.863 |
| Node-36-Node-38                    | 7/14 ACSR | 1.024 |
| Node-38-Kundalay office            | 7/14 ACSR | 0.011 |
| Node-38-Node-39                    | 7/14 ACSR | 0.145 |
| Node-39-node-40                    | 7/14 ACSR | 1.086 |
| Node-39- Theerthamalay             | 7/14 ACSR | 1.35  |
| Node-33-Node-34                    | 7/14 ACSR | 1.031 |
| Node-34-Kundalay colony feedback   | 7/14 ACSR | 0.022 |
| Node-34-Kundalay naturals          | 7/14 ACSR | 0.495 |
| Node-40-Node-41                    | 7/14 ACSR | 0.688 |
| Node-41-Old factory                | 7/14 ACSR | 0.117 |
| Node-41- Node-42                   | 7/14 ACSR | 0.754 |
| Node-42- Top division              | 7/14 ACSR | 0.667 |
| Node-42-PR divsn                   | 7/14 ACSR | 1.937 |
| Node-40-Chunduvarrai factory       | 7/12 Cu   | 1.314 |
| Node-43-Kundalay club              | No.8 Cu   | 0.977 |
| Node-43-Node-44                    | 3/12 Cu   | 0.966 |
| node-44-chittivurrai pump          | 7/12 ACSR | 1.231 |
| Node-44-Node-45                    | No-6 Cu   | 0.702 |
| Node-45-Chittivurrai factory       | No6 CU    | 0.04  |
| Node-45-Node-46                    | 7/14 ACSR | 0.255 |
| Node-46-Chittivurrai factory divsn | 7/12 ACSR | 0.325 |
| Node-46-Node-47                    | 7/14 ACSR | 0.515 |
| Node-47-Chittivurrai new division  | 7/14 ACSR | 0.035 |
| Node-47-Node-48                    | 7/14 ACSR | 0.786 |

|                                  |           |        |
|----------------------------------|-----------|--------|
| Node-48-Chittivurrai OC divsn    | 7/14 ACSR | 0.0026 |
| Node-48-Vattavada feedback       | 7/14 ACSR | 0.0037 |
| Node-29-Node-30                  | 7/14 ACSR | 0.665  |
| Node-30-Aruvikkad Divsn          | 7/12 ACSR | 0.144  |
| Node-30-Aruvikkad factory        | 7/12 ACSR | 0.103  |
| Node-2 - Microwave               | 7/14 ACSR | 0.093  |
| <b>Total - 11 kV line length</b> |           | 61.965 |

The following table shows the important geographical location in Madupatti feeder and its label mapped.

| Point (Longitude, Latitude) | name                     | label |
|-----------------------------|--------------------------|-------|
| POINT (77.056264 10.05429)  | Switching station        | 0     |
| POINT (77.057627 10.060088) | Post-1                   | P1    |
| POINT (77.058212 10.061171) | Post-2                   | P2    |
| POINT (77.059084 10.065243) | Post-3                   | P3    |
| POINT (77.060096 10.069503) | Post-4                   | P4    |
| POINT (77.061854 10.072979) | Post-5                   | P5    |
| POINT (77.06213 10.073753)  | Post-6                   | P6    |
| POINT (77.062438 10.074553) | Post-7                   | P7    |
| POINT (77.062662 10.074988) | Post-8                   | P8    |
| POINT (77.063603 10.075464) | Post-9                   | P9    |
| POINT (77.064791 10.075687) | Node-1                   | N1    |
| POINT (77.065188 10.074352) | Post-10                  | P10   |
| POINT (77.064567 10.074069) | Westwood                 | 1     |
| POINT (77.073432 10.080844) | Node-2                   | N2    |
| POINT (77.081062 10.084349) | Grahamsland office       | 3     |
| POINT (77.081598 10.084594) | Post-11                  | P11   |
| POINT (77.086002 10.08869)  | Node-3                   | N3    |
| POINT (77.08453 10.088426)  | Post-12                  | P12   |
| POINT (77.084177 10.088462) | Grahamsland bazaar       | 4     |
| POINT (77.091834 10.090431) | Node-4                   | N4    |
| POINT (77.09171 10.090348)  | Grahamsland bungalows    | 5     |
| POINT (77.100888 10.095196) | Node-5                   | N5    |
| POINT (77.100835 10.095226) | KKD church               | 6     |
| POINT (77.101711 10.095549) | Kuttiyar valley feedback | F1    |
| POINT (77.105147 10.097478) | Post-13                  | P13   |
| POINT (77.112623 10.101776) | Node-6                   | N6    |
| POINT (77.112678 10.101617) | HR school                | 7     |
| POINT (77.116954 10.104515) | Node-7                   | N7    |
| POINT (77.117494 10.112186) | Node-8                   | N8    |
| POINT (77.109064 10.117385) | Madupatty top divsn      | 8     |
| POINT (77.118334 10.114332) | Node-9                   | N9    |
| POINT (77.123571 10.112446) | R&D complex              | 9     |
| POINT (77.122733 10.119704) | Post-14                  | P14   |
| POINT (77.124612 10.119702) | R&D lab                  | 10    |

|                             |                                |     |
|-----------------------------|--------------------------------|-----|
| POINT (77.119604 10.118725) | Post-15                        | P15 |
| POINT (77.114646 10.126877) | Node-10                        | N10 |
| POINT (77.118311 10.131393) | Post-16                        | P16 |
| POINT (77.120526 10.131872) | Tenmalay Asst manager bungalow | 10  |
| POINT (77.106454 10.132515) | Node-11                        | N11 |
| POINT (77.106456 10.132402) | Tenmalay factory divsb         | 11  |
| POINT (77.103936 10.132603) | Node-12                        | N12 |
| POINT (77.097847 10.137271) | Post-17                        | P17 |
| POINT (77.094516 10.141457) | Post-18                        | P18 |
| POINT (77.093736 10.142938) | Tenmalay new divsn             | 12  |
| POINT (77.103709 10.132039) | Tenmalay factory               | 13  |
| POINT (77.118496 10.103795) | Node-13                        | N13 |
| POINT (77.118727 10.104135) | Madupatty factory              | 14  |
| POINT (77.119625 10.105471) | Node-14                        | N14 |
| POINT (77.119727 10.105424) | Madupatty divsn                | 15  |
| POINT (77.119959 10.105669) | Post-19                        | P19 |
| POINT (77.122911 10.106223) | Node-15                        | N15 |
| POINT (77.122994 10.106012) | Madupatty dam feedback         | F2  |
| POINT (77.123744 10.106114) | Madupatty hydel                | 16  |
| POINT (77.119775 10.103184) | Node-16                        | N16 |
| POINT (77.121702 10.101295) | Nettimadu divsn                | 17  |
| POINT (77.135148 10.109863) | Node-17                        | N17 |
| POINT (77.136917 10.108831) | High tech KLD board            | 18  |
| POINT (77.137119 10.112248) | Node-18                        | N18 |
| POINT (77.136946 10.112184) | Indo swiss project             | 19  |
| POINT (77.140074 10.115097) | Node-19                        | N19 |
| POINT (77.134158 10.121015) | Post-21                        | P21 |
| POINT (77.141155 10.125622) | Post-22                        | P22 |
| POINT (77.140727 10.129283) | Node-20                        | N20 |
| POINT (77.140494 10.129655) | Gundumalay factory             | 20  |
| POINT (77.141368 10.132498) | Node-21                        | N21 |
| POINT (77.141144 10.132683) | Gundumalay factory divsn       | 21  |
| POINT (77.139775 10.142939) | Node-22                        | N22 |
| POINT (77.138977 10.142954) | Gundumalay benmore             | 22  |
| POINT (77.135175 10.148753) | Node-23                        | N23 |
| POINT (77.129367 10.14588)  | Node-24                        | N24 |
| POINT (77.129033 10.145766) | Gundumalay south para          | 23  |
| POINT (77.122813 10.147048) | Node-25                        | N25 |
| POINT (77.113937 10.146657) | Gundumalay new divsn           | 25  |
| POINT (77.122285 10.153244) | Gundumalay BSNL                | 24  |
| POINT (77.13488 10.157218)  | Node-26                        | N26 |
| POINT (77.134321 10.157574) | Gundumalay upper               | 26  |
| POINT (77.134691 10.159033) | Node-27                        | N27 |
| POINT (77.131647 10.166739) | Gundumalay lower               | 27  |
| POINT (77.139203 10.172863) | Gundumalay kadugu              | 28  |
| POINT (77.146325 10.120405) | Node-28                        | N28 |

|                             |                              |     |
|-----------------------------|------------------------------|-----|
| POINT (77.152023 10.114764) | Node-29                      | N29 |
| POINT (77.151674 10.114434) | New pump indo swiss          | 29  |
| POINT (77.153771 10.119739) | Node-31                      | N31 |
| POINT (77.15267 10.119847)  | Ecopoint                     | 32  |
| POINT (77.160987 10.124289) | Node-32                      | N32 |
| POINT (77.162862 10.122783) | East divsn pachakkad         | 33  |
| POINT (77.178188 10.135131) | Node-33                      | N33 |
| POINT (77.180058 10.136447) | Node-35                      | N35 |
| POINT (77.180075 10.136509) | Pudukkadi                    | 35  |
| POINT (77.181477 10.137879) | Post-23                      | P23 |
| POINT (77.197968 10.140834) | Node-36                      | N36 |
| POINT (77.197778 10.142591) | Feedback dam LT              | F4  |
| POINT (77.19925 10.131266)  | Post-24                      | P24 |
| POINT (77.203567 10.127434) | Node-37                      | N37 |
| POINT (77.205451 10.12642)  | Yelapatty divsn              | 36  |
| POINT (77.203996 10.126707) | Yelapatty factory            | 37  |
| POINT (77.214974 10.141016) | Node-43                      | N43 |
| POINT (77.192318 10.148214) | Node-38                      | N38 |
| POINT (77.192296 10.148313) | Kundalay office              | 38  |
| POINT (77.193041 10.149315) | Node-39                      | N39 |
| POINT (77.195444 10.153409) | Post-26                      | P26 |
| POINT (77.198377 10.157581) | Node 40                      | N40 |
| POINT (77.185392 10.153868) | Post-25                      | P25 |
| POINT (77.182475 10.155606) | Theerthamalay                | 39  |
| POINT (77.175086 10.143934) | Node-34                      | N34 |
| POINT (77.17489 10.14399)   | Kundalay colony Feedback     | F3  |
| POINT (77.174439 10.148366) | Kundalay naturals            | 34  |
| POINT (77.203009 10.161782) | Node-41                      | N41 |
| POINT (77.203555 10.162698) | Old factory                  | 41  |
| POINT (77.202644 10.16289)  | Post-28                      | P28 |
| POINT (77.206898 10.166663) | Node-42                      | N42 |
| POINT (77.212879 10.167805) | Top divsn                    | 43  |
| POINT (77.201384 10.183309) | PR divsn                     | 42  |
| POINT (77.209429 10.155737) | Post-27                      | P27 |
| POINT (77.209517 10.15651)  | Chunduvarrai factory         | 40  |
| POINT (77.215445 10.145544) | Post-29                      | P29 |
| POINT (77.214081 10.147689) | Post-30                      | P30 |
| POINT (77.215362 10.148894) | Kundalay club                | 44  |
| POINT (77.222619 10.136658) | Node-44                      | N44 |
| POINT (77.227946 10.126857) | Chittivurrai pump (MC divsn) | 45  |
| POINT (77.228537 10.139095) | Node-45                      | N45 |
| POINT (77.228909 10.139087) | Chittivurrai factory         | 46  |
| POINT (77.228427 10.141405) | Node-46                      | N46 |
| POINT (77.230727 10.13955)  | Chittivurrai factory divsn   | 47  |
| POINT (77.231851 10.144598) | Node-47                      | N47 |
| POINT (77.231796 10.144278) | Chittivurrai new division    | 48  |



|                             |                       |     |
|-----------------------------|-----------------------|-----|
| POINT (77.236835 10.149711) | Node-48               | N48 |
| POINT (77.236859 10.149709) | Chittivurrai OC divsn | 49  |
| POINT (77.236857 10.149737) | Vattavada feedback    | F5  |
| POINT (77.155662 10.109943) | Node-30               | N30 |
| POINT (77.155205 10.108718) | Aruvikkad divsn       | 30  |
| POINT (77.156546 10.109604) | Aruvikkad factory     | 31  |
| POINT (77.07427 10.08068)   | Microwave             | 2   |




Figure 7: Madupatty feeder

## 5. ENERGY CONSERVATION MEASURES SUMMARY

### LIST OF ENERGY CONSERVATION PROPOSED FOR FUTURE

The KDHP can consider several possible measures for energy conservation to reduce their distribution loss to their best value as summarised below.

#### ➤ Installation of energy efficient Transformer

KDHP has initiated to install Energy efficient transformers from FY 2022-23 in different feeders which was mainly for the new consumers or divisions in the plant. The transformer details and locations are given in the table below:

TABLE 23: ENERGY EFFICIENT TRANSFORMER – INSTALLED IN LAST 3 YEARS

| Location          | KVA | Energy efficiency level |
|-------------------|-----|-------------------------|
| Grahamsland       | 63  | 02                      |
| ITD               | 100 | 02                      |
| Vagavurrai lakham | 63  | 02                      |
| Casa mountana     | 163 | 02                      |
| Madupatty divsn   | 63  | 02                      |

The further increase in the installation by purchasing new energy efficient ones, replacing the old ones (more than 40 years old, estimated 30 numbers) will reduce transformer loss along with the distribution loss.

#### ➤ Replacement of energy meters with prepaid meter

KDHP has been following the conventional metering method during the period of FY 2022-23, however it changed to the instant billing method – **spot metering** - using the tablet and printing machine which interlinked with their TSoft – software for electricity department during March 2022.

During the conventional method, the overall time for completion of the bill cycle was high and reduces the billing efficiency. The present spot metering will also have implications on the collection efficiency while considering the monthly analysis.

The next stage that the KDHP can initiate is installing the prepaid meters, which will increase the customer satisfaction level, that will reduce the time for the whole billing process, and will also enable the consumer to monitor the consumption pattern & top-up the balance. The system once implemented would be unique in the industry and which will ultimately benefit the stakeholders.

### ➤ Reconductoring of HT overhead lines

KDHP conducted a detail reconductoring of main HT 11 kV line in 5 out of 7 feeders replacing Copper cables with Racoon or Mink in the year 2012-13. This has reduced the overall loss from the 21% to 12% range as per the records of KDHP. Furthermore, company installed either Racoon/mink for the HT lines in the later years.

Still 66% of the total HT overhead lines in KDHP are of either 7/14 ACSR or Copper which corresponds to 118.2 km out of the total HT line length of 180.23 km. This predominantly contributes to the HT overhead line losses. By replacing the same with DOG conductor throughout, the KDHP can have the following savings:

| Particulars              | Units       | Values |
|--------------------------|-------------|--------|
| Annual Energy savings    | MU          | 0.734  |
| Annual financial savings | Rs in lakhs | 35.25  |
| Estimated investment     | Rs in lakhs | 472.32 |
| Simple payback period    | Months      | 161    |

- **Detailed analysis given in the Annexure-1**

### ➤ Reconductoring of LT overhead lines

Presently the whole LT overhead lines in KDHP are ACSR or Copper type conductors. total LT line length in the system is 193.8 km. The resistance per line length for these type conductors are comparatively high and hence the results in high LT overhead line losses. In KDHP, the LT overhead line losses share the major part of technical losses in almost all the feeders.

In order to reduce the LT overhead line losses, it is proposed to do reconductoring for the specified length of LT overhead lines with Rabbit conductor. The summary of the savings is given in the table below.

| Particulars              | Units       | Values |
|--------------------------|-------------|--------|
| Annual Energy savings    | MU          | 1.28   |
| Annual financial savings | Rs in lakhs | 61.22  |
| Estimated investment     | Rs in lakhs | 214.14 |
| Simple payback period    | Months      | 42     |

- **Detailed analysis given in the Annexure-1**

➤ **Summary of energy conservation measures**

Table 24: Energy conservation measures - summary

| EC M No | Energy Efficiency Measures          | Annual Electricity Savings | Annual Financial Savings | Investment  | Fixed interest rate | Cash inflow | Net present value | Internal rate of return |
|---------|-------------------------------------|----------------------------|--------------------------|-------------|---------------------|-------------|-------------------|-------------------------|
|         |                                     | MU                         | (Rs)                     | (Rs)        | %                   | Years       | Rs                | %                       |
| 1       | Reconductoring of HT overhead lines | 0.734                      | 35,25,291                | 4,72,32,000 | 6                   | 16          | 12,93,035         | 6.25%                   |
| 2       | Reconductoring of LT overhead lines | 1.275                      | 61,22,303                | 2,14,14,400 | 6                   | 5           | 43,74,967         | 13.23%                  |

➤ **General observations and suggestions**

| Observation   | Suggestions   | Benefits   |
|---|---|--|
| Some of the HT consumers are having metered at the secondary/LV side.   | As per the CEA metering regulation, HT consumers shall meter at the HV side with CT/PT, 0.2s class TOD meter.   | The actual transformer loss will get gauged in the bill which will reduce the KDHP overall T&D loss.   |
| Estimated that Distribution transformers are more than 40 years old (Around 30 nos) and re-winded several times during its life time.   | If any of failure of transformers in future, the no load loss of the same after rewinding is to be measured and ascertain the life cycle cost with new energy efficient transformers. No load loss of transformers after rewinding shall be logged and records shall be kept for future analysis. | By replacing the old re-winded transformers, with energy efficient ones, the overall T&D loss will reduce.   |
| Registered maximum demand in past months was always above the contract demand (9 MVA) in KDHP. However, with the present 3nos of 11 kV feeders, 9 MVA is maximum allowed demand as per the regulations. | Increase the contract demand to 12 MVA by increasing the voltage level to 33 kV. For this, KDHP is in the process of installing 33 kV substation near to the town.  | The HT line loss up to the town area will reduce (exactly 2.8 km) along with the reduction in the excess demand charges. This will also capable to cater the future consumer loads in the Munnar area. |

### ***LIST OF ENERGY CONSERVATION MEASURES ADOPTED/TAKEN***

- **Power factor Improvement:** Power factor has been improved to 0.99 from 0.95 by improving the consumer side powerfactor. Also, an incentive of Rs 41.61 lakhs was received during the FY 2022-23 by maintaining a commendable power factor of 0.99, which significantly improved from the registered power factor of 0.95 in the preceding FY 2021-22.

## **ENERGY FLOW ANALYSIS**

### ***1. ENERGY FLOW***

The basic energy flow in the DISCOM is given in the chart below.




Figure 8: Energy flow diagram - KDHP

- *Input energy = the energy received at the KDHP for distribution including Feedback energy.*
- *Metered energy = energy metered at the consumer end*
- *Feedback energy = Energy sold outside the periphery*
- *T&D losses = Net losses*

## 2. VALIDATION OF METERED DATA

The validation of data includes the KSEB metering and feeder meters in the switching station of the KDHP. The following tables will provide the validation of the metering by comparing with the calibrated power analysers.

### COMMERCIAL LOSSES

The estimated commercial losses/non-technical losses in the DISCOM during the FY 2022-23 was 2.98%. This can mainly attribute to the following things.

1. KDHP has been following the “spot metering” to raise bills on its electricity consumers and issue the same to them immediately thereof to the consumers at their doorsteps to facilitate timely receipt of bills by the consumers. The changes in the date of reading can result in the difference in the annual final reading of consumers.
2. Meter error is mainly accounting to the difference in the class of CT. All the consumer meters were 0.5s class however the incomer meters at the switching station and the Madupatty feeder was 0.2s class.

Also, the meter damages in the consumers can lead to insufficient reading which leads to the unaccounted losses.

Observed high consumption variation in the following consumers from the 2021-22 FY to 2022-23 FY in the ITD and Town feeder which could have led to the variation in the difference in sales and actual consumption.

Will require detail measurement and verification for the following list of consumer meters to check for its functioning

Table 25: Consumption variation among the consumers

| Consumer name            | Type of consumer | FY 2022-23 | FY 2021-22 | Increase in consumption |       |
|--------------------------|------------------|------------|------------|-------------------------|-------|
|                          |                  | kWh/annum  | kWh/annum  | Ratio                   | %     |
| KTDC-KTDC HOTEL          | HT               | 320088     | 229564     | 1.39                    | 28.28 |
| EEND-Eastend Hotel       | HT               | 384330     | 146694     | 2.62                    | 61.83 |
| EVMH-EVM Hotels          | HT               | 187758     | 99656      | 1.88                    | 46.92 |
| GRPL-Grand Plaza         | HT               | 135543     | 86528      | 1.57                    | 36.16 |
| MSHT-MS HOTELS           | HT               | 128862     | 45616      | 2.82                    | 64.60 |
| ECOL-ENGINEERING COLLEGE | HT               | 44634      | 36000      | 1.24                    | 19.34 |
| CASA-Casa Mountana Hotel | HT               | 51784      | 32490      | 1.59                    | 37.26 |

3. Tree touching and its related interruption can lead to heavy current surge to the ground. This can be account as losses due to non-technical as it is unaccountable.

Metering deviation was done in sample basis in order to derive an energy balance between purchase and sale. The energy meters at incomer and few HT/LT consumer energy meters provided in the KDHP was cross checked using calibrated meters like Krykard ALM 35/ ALM 31.

### DEVIATION OF METERING

➤ **Deviation of incomer meters**

The KSEBL incomer energy meters at the switching station were verified with the panel meters and the power quality analysers and given in the table below.

Table 26: KSEBL incomer meter – deviation with PQ analyser

| Sl no | Meter          | Hours of measurement | KSEBL meter | Panel reading | Power analyser reading | KSEBL meter vs Power analyser | Panel meter vs Power analyser |
|-------|----------------|----------------------|-------------|---------------|------------------------|-------------------------------|-------------------------------|
|       |                | Hours                | kWh         | kWh           | kWh                    | %                             | %                             |
| 1     | Income r-1 & 2 | 24                   | 107370.0    | 110066.0      | 107150.1               | <b>0.2</b>                    | <b>2.7</b>                    |
| 2     | Income r-3     | 24                   | 62320       | 64294.8       | 62545.7                | <b>-0.4</b>                   | <b>2.8</b>                    |

➤ **Deviation of feeder meters**

Table 27: Deviation of feeder meters

| Sl no | Feeder name | Hours of measurement | Panel reading | Average PF | Power analyser reading | Difference in consumption | % of error |
|-------|-------------|----------------------|---------------|------------|------------------------|---------------------------|------------|
|       |             | Hours                | kWh           |            | kWh                    | kWh                       |            |
| 1     | ITD         | 24                   | 31062.0       | 0.98 lag   | 30701.5                | 360.512                   | 1.2        |
| 2     | Madupatty   | 24                   | 15107.0       | 0.82 lead  | 14172.5                | 934.5                     | 0.9        |
| 3     | Nettigudi   | 24                   | 36446.0       | 0.98 lag   | 35900.2                | 545.791                   | 0.1        |
| 4     | Neyamakad   | 24                   | 57666.7       | 0.98 lead  | 57175.2                | 491.51                    | 1.6        |
| 5     | Pullivasal  | 24                   | 15979.8       | 0.98 lag   | 16712.0                | -732.16                   | -0.82      |
| 6     | Town        | 24                   | 25571         | 0.98 lag   | 25273.1                | 297.9                     | 2.81       |

- Error in the meters found in all the feeders except the Nettigudi.
- The commercial loss will reduce with the additions of this error to the input energy which is analysed in the following section.



➤ **Commercial loss balance**

Here the reduction in commercial loss in each feeder considering the error in feeder input meter is analyzed and tabulated. The commercial loss reduced in the following listed feeders and total loss.

Table 28: Adjusted commercial loss

| Feeder     | % of error in Feeder input meter | Present commercial loss | Adjusted commercial loss | Present total loss | Corrected total loss |
|------------|----------------------------------|-------------------------|--------------------------|--------------------|----------------------|
|            | %                                | %                       | %                        | %                  | %                    |
| ITD        | 1.17                             | -1.35                   | -2.52                    | 5.03               | 7.55                 |
| Madupatty  | 0.9                              | 7.38                    | 6.48                     | 13.9               | 7.42                 |
| Neymakad   | 1.57                             | 5.95                    | 4.38                     | 10.17              | 5.79                 |
| Pullivasal | -0.82                            | 0.2                     | 1.02                     | 5.17               | 4.15                 |
| Town       | 2.81                             | -3.6                    | -6.41                    | 12.97              | 19.38                |

- **Reduction in the commercial loss was from 2.984% to 0.59% with the error correction in the feeder input meters.**
- *The difference in the panel meter reading with the calibrated power analyser was mainly due to the difference in the CT class. Thus, the present meter can still continue to function, however, while calculating the T&D loss, the % of error in the above table shall include.*

### 3. VALIDATION OF ENERGY FLOW DATA

The section provides the details of energy purchased and sold in the DISCOM during the FY 2022-23.

#### INCOMER - AT SWITCHING STATION

KDHPCL procures electricity from KSEB Ltd for the supply to its consumers and for its own consumption. KDHP receives the power as 11 kV from the KSEBL (Kerala state electricity board limited) as **Part-C: BULK SUPPLY - EHT TARIFF APPLICABLE TO SMALL LICENSEES** category. The rates specified in this schedule (Part C) are exclusive of Electricity Duty and/or surcharge, other cess, taxes, minimum fees, duties and other impositions. Thus, only the demand and energy charges are applicable for the electricity cost.

#### ➤ BASELINE DATA

The basic details of the bill and KDHP distribution are as follows:

| Base Line Data – FY 2022-23 |   |  |
|-----------------------------|---|--|
| 1                           | Electricity provider  | KSEBL  |
| 2                           | Supply Voltage  | 11 kV  |
| 3                           | Tariff  | BULK SUPPLY – EHT TARIFF APPLICABLE TO SMALL LICENSEES |
| 4                           | Consumer number   | LCN 21/1014  |
| 5                           | Section office  | Chithirapuram  |
| 6                           | Contract demand (kVA)   | 9000   |
| 7                           | Maximum demand registered (kVA)- (including feedback demand)                                  | 12,479   |
| 8                           | Billed demand - maximum (kVA)- (excluding feedback demand)                                    | 10644  |
| 9                           | Average monthly electricity consumption (MU) – KDHP   | 4.51   |
| 10                          | Annual unit consumption (MU) – KDHP   | 54.12  |
| 11                          | Average power factor  | 0.98   |
| 12                          | Tariff Rate of energy charges (Rs / kWh)  | 5.3  |
| 13                          | Demand charge (Rs / kVA)  | 380  |
| 14                          | Excess demand charge (Rs/kVA)   | 190  |
| Other details               |   |  |
| 15                          | Number of incoming feeders – From KSEBL - 11 kV (Nos)   | 03 (Chithirapuram – 1no, Pullivasal-02 nos)            |
| 16                          | Number of KDHP Distribution Feeders – 11 kV (Nos)   | 07   |
| 17                          | Feedback points – To KSEBL (Nos)  | 15   |
| 18                          | Number of transformers under KDHP   | 133  |
| 19                          | Line length at 11 kV voltage level (km)   | 180.23   |
| 20                          | Line length at LT voltage level (km)  | 193.8  |
| 21                          | HT/LT ratio   | 1:1.075  |
| 22                          | Input energy source under KDHP distribution area – capacity – Type of station – Voltage level | Madupatty – 2 MW – Hydel – 11 kV                       |
| 23                          | Number of consumers – March 2023  | 16583  |
| 24                          | Connected load (MW)   | 34.03  |
| 25                          | Number of HT consumers  | 36   |
| 26                          | Number of LT consumers  | 16547  |

➤ **DEMAND ANALYSIS**

**DEMAND TARIFF STRUCTURE**

As per the Kerala State Electricity regulatory commission (KSERC) tariff order dated 24/03/2022, Billing Demand (BD) shall be the Recorded Maximum Demand (RMD) for the month in kVA or 75% of Contract Demand (CD) whichever is higher in 30 minutes interval period. However the demand calculation for the KDHP is different due to the multiple feedback points (Selling outside the periphery) and one generating station. The demand calculation for the KDHP by the KSEBL is given below.

|                               |   |
|-------------------------------|---|
| Recorded maximum demand (RMD) | <ul style="list-style-type: none"> <li>• Pullivasal - at switching station (A)</li> <li>• Madupatty - Generating station (B)</li> </ul> |
| HT feedback                   | <ul style="list-style-type: none"> <li>• Vagavurrai HT feedback RMD (C)</li> <li>• Vagavurrai HT Feedback Energy (D)</li> </ul>         |
| LT feedback                   | <ul style="list-style-type: none"> <li>• LT Feedback energy (E)</li> <li>• LT Feedback MD (F) = (C/D)*E</li> </ul>                      |
| Net feedback RMD              | • G = F + C   |
| Billing demand - BD           | • BD = A + B - G  |
| Billing demand charge         | • Demand charges = BD x 380 Rs/kVA  |

**DEMAND REGISTERED - FY 2022-23**

This section analyses the trend for the billing demand (BD), the Contract Demand (CD) & 75% of the contract demand over the FY 2022-23.




Figure 9: Demand variation – FY 2022-23

➤ **ENERGY CONSUMPTION ANALYSIS**

**Energy Calculation Method**

As per the Kerala State Electricity regulatory commission (KSERC) tariff order no: 0476/DD(T)/2020/KSERC dated 24/03/2022, TOD tariff is applicable to Bulk consumer - Small licensees. Though the KDHP has multiple feedback points (selling outside the periphery) and generating station in the distribution section, the calculation for billed energy is different.

The calculation method for the energy charges is mentioned below.

|   |   |
|---|---|
| Energy consumption                              | •Pullivasal - at switching station (A)<br>•Madupatty - Generating station (B) |
| HT feedback                                     | •Vagavurrai HT Feedback Energy (C)  |
| LT feedback                                     | •LT Feedback energy (D)   |
| Net feedback energy                             | •E = C + D  |
| Net Feedback energy including Transmission loss | •F = E x 104% (4% transmission loss)  |
| Chargeable energy                               | •G = A + B - F  |
| Energy charges                                  | •Energy charges = G x 5.3 Rs/kWh  |

**Unit Consumed – FY 2022-23**

This section analyses the trend for the unit consumption by the KDHP and the feedback energy over the period FY 2022-23.




Figure 10: Energy consumption analysis

➤ **POWER FACTOR ANALYSIS**

**Power factor calculation method**

As per the Kerala State Electricity regulatory commission (KSERC) tariff order no: 0476/DD(T)/2020/KSERC dated 24/03/2022, power factor incentive/disincentives were applicable to Bulk consumer - Small licensees. The calculation method for the Power factor is mentioned below.

|                             |  |
|-----------------------------|--|
| Active Energy consumption   | •Denoted as (A)  |
| Apparent Energy consumption | •Denoted as (B)  |
| Power factor                | • $PF = A \div B$  |
| Power factor incentive      | •For every increase of 0.01 from the 0.95 lagging, 0.5% of the energy charge will be provided as incentive.                  |
| PF disincentive             | •For every decrease of 0.01 in the range of 0.95 to 0.90, 0.5% of the energy charge.<br>•Less than 0.90 1% of energy charge. |

**Power factor registered in FY 2022-23**

This section examines the Power factor trend and the corresponding power factor incentive acquired during the period FY 2022-23




Figure 11: Power factor – FY 2022-23

➤ **OBSERVATIONS AND RECOMMENDATION – ENERGY CONSUMPTION PROFILE**

Table 29: Observations &amp; Recommendation – Energy Consumption Profile

| Observation  | Recommendation   | Benefit  |
|--|--|--|
| <b>Demand charges reduction by Power factor improvement</b>  |  |  |
| <p>Power factor was registered at 0.99 during the FY 2022-23.</p> <p>The PF was good considering the FY 2021-22 which was in the range of 0.95.</p> <p>An incentive of Rs 41.61 lakhs received in the FY 2022-23 for maintaining good PF in the DISCOM.</p>  | <ul style="list-style-type: none"> <li>Maintain the PF in this range for the incentive.</li> </ul>   | <ul style="list-style-type: none"> <li>Power factor incentive</li> </ul>   |
| <b>Single metering system at the main incomer – at Pullivasal switching station</b>  |  |  |
| <p>The Pullivasal (at switching station) has two KSEBL incomers which has two independent TOD meters. Also, the Madupatty hydel input demand measures separately. The maximum demand is found by adding separately the registered value of demand in the independent TOD meters at the end of the month.</p> | <ul style="list-style-type: none"> <li>02 Pullivasal incoming energy meters and 01 Madupatty generating station energy meter is to be synchronised with respect to time. The net maximum demand in a month shall be the summation of three meters in 30 min time interval.</li> <li>A continuous monitoring system shall provide for the measurement of demand in 30 min interval for the three meters.</li> </ul> | <ul style="list-style-type: none"> <li>This will reduce the MD in the range of 500 to 1000 kVA per month, which will have an estimated annual savings of Rs 27.36 lakhs (Average 600 kVA/ month @ Rs 380/kVA)</li> </ul> |

**ENERGY SOLD OUTSIDE THE PERIPHERY (FEEDBACK)**

The table presented below outlines the energy distributed to locations outside the periphery. It also indicates the specific points at which this energy is fed back from each feeder.

Table 30: Energy sold outside the periphery

| Feeder Name      | ITD                       | Neymakad              |                           | Nettigudi     |                 |                 |                       | Town        |                         |                         | Madupatty     |              |                           |             |                               |
|------------------|---------------------------|-----------------------|---------------------------|---------------|-----------------|-----------------|-----------------------|-------------|-------------------------|-------------------------|---------------|--------------|---------------------------|-------------|-------------------------------|
| Name of Point    | HARIGEN COLONY (LETC HMI) | VAGAV URRAI FEED BACK | Edamal akudy (Pettim udi) | RA HEAD WORKS | DEVI KULAM PUMP | DEVIK ULAM TOWN | ALL INDI A RADIO (FM) | PHE COLONY  | LT FEED BACK (QUARTERS) | HARIGEN COLONY (MUNNAR) | MADUPATTY DAM | KUNDALAY DAM | HARIGEN COLONY (KUNDALAY) | VATTA VADA  | Kuttiyar Valley (Korand akad) |
| Unit             | MU                        | MU                    | MU                        | MU            | MU              | MU              | MU                    | MU          | MU                      | MU                      | MU            | MU           | MU                        | MU          | MU                            |
| Apr-22           | 0.05                      | 0.01                  | 0.002                     | 0.012         | 0.01            | 0.06            | 0.00                  | 0.01        | 0.00006                 | 0.12                    | 0.01          | 0.003        | 0.01                      | 0.07        | 0.001                         |
| May-22           | 0.06                      | 0.03                  | 0.002                     |               | 0.01            | 0.07            | 0.00                  | 0.01        | 0.00008                 | 0.13                    | 0.01          | 0.003        | 0.01                      | 0.08        | 0.001                         |
| Jun-22           | 0.05                      | 0.08                  | 0.002                     |               | 0.01            | 0.06            | 0.00                  | 0.01        | 0.00007                 | 0.13                    | 0.01          | 0.003        | 0.01                      | 0.07        | 0.001                         |
| Jul-22           | 0.04                      | 0.10                  | 0.002                     | 0.0003        | 0.01            | 0.07            | 0.00                  | 0.01        | 0.00007                 | 0.14                    | 0.01          | 0.003        | 0.01                      | 0.06        | 0.001                         |
| Aug-22           | 0.05                      | 0.05                  | 0.002                     |               | 0.01            | 0.07            | 0.00                  | 0.01        | 0.00007                 | 0.13                    | 0.01          | 0.003        | 0.01                      | 0.07        | 0.001                         |
| Sep-22           | 0.05                      | 0.02                  | 0.002                     | 0.0012        | 0.01            | 0.06            | 0.01                  | 0.01        | 0.00006                 | 0.13                    | 0.01          | 0.003        | 0.01                      | 0.07        | 0.004                         |
| Oct-22           | 0.05                      | 0.005                 | 0.002                     |               | 0.01            | 0.07            | 0.01                  | 0.01        | 0.00006                 | 0.13                    | 0.01          | 0.003        | 0.01                      | 0.08        | 0.01                          |
| Nov-22           | 0.06                      | 0.02                  | 0.002                     |               | 0.01            | 0.07            | 0.00                  | 0.01        | 0.00007                 | 0.13                    | 0.01          | 0.002        | 0.01                      | 0.08        | 0.01                          |
| Dec-22           | 0.06                      | 0.01                  | 0.002                     |               | 0.01            | 0.08            | 0.00                  | 0.01        | 0.00006                 | 0.14                    | 0.01          | 0.003        | 0.01                      | 0.09        | 0.01                          |
| Jan-23           | 0.07                      | 0.02                  | 0.002                     |               | 0.01            | 0.07            | 0.00                  | 0.01        | 0.00006                 | 0.14                    | 0.01          | 0.003        | 0.01                      | 0.09        | 0.01                          |
| Feb-23           | 0.06                      | 0.02                  | 0.002                     |               | 0.01            | 0.06            | 0.00                  | 0.01        | 0.00006                 | 0.12                    | 0.01          | 0.003        | 0.01                      | 0.08        | 0.01                          |
| Mar-23           | 0.06                      | 0.005                 | 0.002                     |               | 0.01            | 0.07            | 0.00                  | 0.01        | 0.00006                 | 0.14                    | 0.01          | 0.003        | 0.01                      | 0.08        | 0.01                          |
| <b>Total</b>     | <b>0.66</b>               | <b>0.37</b>           | <b>0.02</b>               | <b>0.01</b>   | <b>0.14</b>     | <b>0.81</b>     | <b>0.05</b>           | <b>0.07</b> | <b>0.00008</b>          | <b>1.59</b>             | <b>0.14</b>   | <b>0.03</b>  | <b>0.07</b>               | <b>0.91</b> | <b>0.05</b>                   |
| <b>Net Total</b> | <b>4.930</b>              |                       |                           |               |                 |                 |                       |             |                         |                         |               |              |                           |             |                               |

**FEEDER WISE SALES DATA**

The following table presents the units sold by the DISCOM during the fiscal year 2022-23, depicting the energy consumption of consumers categorized by feeder.

Table 31: Feeder wise sales data FY 2022-23

| Particulars      | Unit       | Pallivasal         | ITD              | Neymakad         | Nettigudi        | Madupatty          | Town             |
|------------------|------------|--------------------|------------------|------------------|------------------|--------------------|------------------|
| Apr-22           | kWh        | 2,96,860           | 8,46,714         | 8,36,450         | 7,05,441         | 8,96,165           | 5,27,162         |
| May-22           | kWh        | 3,70,221           | 8,04,388         | 11,35,966        | 9,20,955         | 11,86,051          | 5,92,221         |
| Jun-22           | kWh        | 2,95,091           | 8,30,836         | 7,74,574         | 7,99,417         | 10,61,621          | 6,13,966         |
| Jul-22           | kWh        | 2,56,331           | 7,29,732         | 7,02,758         | 7,56,239         | 8,31,338           | 5,77,338         |
| Aug-22           | kWh        | 1,84,669           | 6,70,252         | 5,83,504         | 6,22,778         | 6,73,374           | 5,54,477         |
| Sep-22           | kWh        | 2,70,930           | 7,63,851         | 7,95,548         | 7,56,511         | 10,99,039          | 5,14,532         |
| Oct-22           | kWh        | 2,51,880           | 7,31,760         | 7,32,235         | 7,20,051         | 10,90,792          | 5,99,865         |
| Nov-22           | kWh        | 2,14,702           | 8,41,970         | 8,04,201         | 7,89,953         | 9,83,689           | 6,22,618         |
| Dec-22           | kWh        | 2,43,313           | 7,28,034         | 7,32,334         | 7,39,765         | 10,77,828          | 6,21,688         |
| Jan-23           | kWh        | 2,43,788           | 5,89,166         | 7,65,714         | 6,01,821         | 9,94,766           | 6,68,135         |
| Feb-23           | kWh        | 1,98,791           | 5,35,787         | 8,32,497         | 6,73,170         | 8,39,236           | 6,40,481         |
| Mar-23           | kWh        | 2,17,230           | 7,49,356         | 9,03,636         | 7,42,231         | 9,60,488           | 5,59,733         |
| <b>Total</b>     | <b>kWh</b> | <b>30,43,806</b>   | <b>88,21,846</b> | <b>95,99,417</b> | <b>88,28,332</b> | <b>1,16,94,387</b> | <b>70,92,216</b> |
| <b>Net Total</b> | <b>kWh</b> | <b>4,90,80,004</b> |                  |                  |                  |                    |                  |



## LOSS & SUBSIDY COMPUTATION

### 1. ENERGY ACCOUNTS ANALYSIS FOR PREVIOUS YEARS- FY 2021-22

The performance summary of KDHP as DISCOM as per the FY 2021-22 is given in the following table.

Table 32: Summary of DISCOM – FY 2021-22

| Performance Summary of Electricity Distribution Companies |  |                                  |        |
|---|--|----------------------------------|--------|
| <b>1</b>  | Period of Information<br>Year of (FY) information including Date and Month (Start & End) | 1st Apr, 2021 - 31st March, 2022 |        |
| <b>2</b>  | <b>Technical Details</b>   |                                  |        |
| <b>(a)</b>  | <b>Energy Input Details</b>  |                                  |        |
| (i)   | Input Energy Purchase<br>(From Generation Source)  | Million kWh                      | 48.41  |
| (ii)  | Net input energy (at DISCOM Periphery including sale outside periphery)                  | Million kWh                      | 53.07  |
| (iii)   | Total Energy billed (is the Net energy billed, adjusted for energy traded)               | Million kWh                      | 48.05  |
| <b>(b)</b>  | Transmission and Distribution (T&D) loss (Billing efficiency)                            | Million kWh                      | 5.02   |
|   |  | %                                | 9.45   |
|   | Collection Efficiency  | %                                | 97.62% |
| <b>(c)</b>  | Aggregate Technical & Commercial Loss  | %                                | 11.61% |

As the collection efficiency is 97.62% the AT&C loss of KDHP registered was 11.61% during the FY 2021-22.

Table 33: AT & C loss – FY 2021-22

| S. No            | Name of circle | Period from April 2021 to March 2022 |                   |                |                         |               |              |                            |                               |                       |                 |
|------------------|----------------|--------------------------------------|-------------------|----------------|-------------------------|---------------|--------------|----------------------------|-------------------------------|-----------------------|-----------------|
|                  |                | Consumer profile                     | Energy parameters |                |                         | Losses        |              | Commercial Parameter       |                               |                       | AT & C loss (%) |
|                  |                | Consumer category                    | Input energy (MU) | Metered energy | % Of energy consumption | T&D loss (MU) | T&D loss (%) | Billed Amount in Rs. Crore | Collected Amount in Rs. Crore | Collection Efficiency |                 |
| 1                | KDHP           | Residential                          | 53.07             | 7.70           | 16%                     | 5.02          | 9.45%        | 3.60                       | 3.51                          | 97.50%                | 11.61%          |
|                  |                | Agricultural                         |                   | 0.013          | 0.03%                   |               |              | 0.00                       | 0.00                          | 100%                  |                 |
|                  |                | Commercial/Industrial-LT             |                   | 2.60           | 5%                      |               |              | 2.64                       | 2.47                          | 93.67%                |                 |
|                  |                | Commercial/Industrial-HT             |                   | 30.48          | 63%                     |               |              | 21.67                      | 21.44                         | 98.93%                |                 |
|                  |                | Others                               |                   | 7.260          | 15%                     |               |              | 2.07                       | 1.84                          | 89.12%                |                 |
| <b>Sub-total</b> |                | <b>53.07</b>                         | <b>48.05</b>      | <b>100%</b>    | <b>5.02</b>             | <b>9.45%</b>  | <b>29.98</b> | <b>29.26</b>               | <b>97.62%</b>                 |                       |                 |

## 2. ENERGY ACCOUNTS ANALYSIS FOR PRESENT YEAR- FY 2022-23

### CATEGORY OF DIVISION WISE LOSSES - FY 2022-23

The consumer details, energy parameter and the overall circle wise T&D Losses are mentioned in the table below:

Table 34: Division wise losses

| Division Wise Losses                          |                          |                                |                                   |                                   |                            |                   |                    |                             |               |                         |               |              |
|---|--------------------------|--------------------------------|-----------------------------------|-----------------------------------|----------------------------|-------------------|--------------------|-----------------------------|---------------|-------------------------|---------------|--------------|
| Period From 1st April 2022 to 31st March 2023 |                          |                                |                                   |                                   |                            |                   |                    |                             |               |                         |               |              |
| Name of circle                                | Consumer profile         |                                |                                   |                                   |                            | Energy parameters |                    |                             |               |                         | Losses        |              |
|   | Consumer category        | No of connection metered (Nos) | No of connection Un-metered (Nos) | Total Number of connections (Nos) | % of number of connections | Input energy (MU) | Billed energy (MU) |                             |               | % of energy consumption | T&D loss (MU) | T&D loss (%) |
|   |                          |                                |                                   |                                   |                            |                   | Metered energy     | Unmetered/assessment energy | Total energy  |                         |               |              |
| KDHP  | Residential              | 14010                          | 0                                 | 14010                             | 84.48%                     | 59.048            | 7.80               | 0                           | 7.80          | 14%                     | 5.038         | 8.53%        |
|   | Agricultural             | 7                              | 0                                 | 7                                 | 0.04%                      |                   | 0.016              | 0                           | 0.016         | 0.03%                   |               |              |
|   | Commercial/Industrial-LT | 1317                           | 0                                 | 1317                              | 7.94%                      |                   | 3.99               | 0                           | 3.99          | 7%                      |               |              |
|   | Commercial/Industrial-HT | 31                             | 0                                 | 31                                | 0.19%                      |                   | 34.30              | 0                           | 34.30         | 64%                     |               |              |
|   | Others + Feedback        | 1218                           | 0                                 | 1218                              | 7.34%                      |                   | 7.90               | 0                           | 7.90          | 15%                     |               |              |
| <b>Sub-total</b>                              |                          | <b>16583</b>                   | <b>0</b>                          | <b>16583</b>                      | <b>100%</b>                | <b>59.048</b>     | <b>54.011</b>      | <b>0.00</b>                 | <b>54.011</b> | <b>100%</b>             | <b>5.038</b>  | <b>8.53%</b> |

#### Methodology for T&D loss computation:

- $T\&D\ Losses\ (MU)\ of\ a\ circle = Sum\ of\ Input\ Energy\ of\ the\ circle\ (MU) - Sum\ of\ Metered\ energy\ of\ all\ categories\ within\ the\ circle\ (MU) - Feedback\ Energy\ (MU)$
- $T\&D\ Losses\ in\ \% = \frac{T\&D\ Losses\ (MU)}{Input\ Energy\ to\ the\ circle\ (MU)} * 100$
- $T\&D\ Losses\ (MU)\ of\ a\ DISCOM = \frac{Sum\ of\ circlewise\ T\&D\ Losses\ (MU)}{Cumulative\ Sum\ of\ Input\ Energy\ (MU)\ to\ all\ circle} * 100$

### AGGREGATE TECHNICAL & COMMERCIAL (AT&C) LOSS:

Aggregate Technical & Commercial Loss (AT&C Loss) is defined as the summation of all technical as well as commercial power loss that occurs due to electrical power flow through sub-transmission and distribution network.

Technical Loss is defined as the summation of power loss through 33 kV, 11 kV line and LT line loss including transformer loss and others.

Commercial Loss is defined as the summation of power loss occurring due to theft/ pilferage, deficient meter, inefficiency in billing & unrealized revenue due to collection inefficiency.

#### **Computation of AT& C Loss:**

Aggregate Technical & Commercial Loss (AT&C) is computed from the actual meter readings of the meter installed at various locations in the system.

- **Overall Billing Efficiency (%)** = Total Sale in MU/ Total input in MU
- **Overall Collection Efficiency (%)** = Total Collection Received (Rs. in Crs.) / Total Billing to Consumers (Rs. in Crs.)
- **AT & C Loss (%)** = {(1- Collection Efficiency %)x T&D loss%}

As the collection efficiency is 99.67% the AT&C loss of KDHP registered was 8.83% during the FY 2022-23.

Table 35: AT & C loss – FY 2022-23

| S<br>·<br>N<br>o | Name<br>of<br>circle | Period From 1st April 2022 to 31st March 2023 |                         |                   |                               |                     |                    |                                     |  |                          |                       |
|------------------|----------------------|---|-------------------------|-------------------|-------------------------------|---------------------|--------------------|-------------------------------------|--|--------------------------|-----------------------|
|                  |                      | Consumer<br>profile                           | Energy parameters       |                   |                               | Losses              |                    | Commercial Parameter                |  |                          | AT &<br>C loss<br>(%) |
|                  |                      | Consumer<br>category                          | Input<br>energy<br>(MU) | Metered<br>energy | % Of<br>energy<br>consumption | T&D<br>loss<br>(MU) | T&D<br>loss<br>(%) | Billed<br>Amount<br>in Rs.<br>Crore | Collected<br>Amount<br>in Rs.<br>Crore | Collection<br>Efficiency |                       |
| 1                | KDHP                 | Residential                                   | 59.048                  | 7.80              | 14%                           | 5.038               | 8.53%              | 3.7656                              | 3.7841                                 | 100.49%                  |                       |
|                  |                      | Agricultural                                  |                         | 0.016             | 0.03%                         |                     |                    | 0.0049                              | 0.0049                                 | 100.00%                  |                       |
|                  |                      | Commercial/<br>Industrial-LT                  |                         | 3.99              | 7%                            |                     |                    | 3.9026                              | 3.9073                                 | 100.12%                  |                       |
|                  |                      | Commercial/<br>Industrial-HT                  |                         | 34.30             | 64%                           |                     |                    | 25.3352                             | 25.3174                                | 99.93%                   |                       |
|                  |                      | Others  |                         | 7.90              | 15%                           |                     |                    | 2.4389                              | 2.3176                                 | 95.03%                   |                       |
| <b>Sub-total</b> |                      | <b>59.048</b>                                 | <b>54.011</b>           | <b>100%</b>       | <b>5.038</b>                  | <b>8.53%</b>        | <b>35.45</b>       | <b>35.33</b>                        | <b>99.67%</b>                          | <b>8.83<br/>%</b>        |                       |

### 3. TECHNICAL LOSSES

Technical losses are subdivided into three categories:

1. HT OH line & cable losses
2. Transformer loading & losses
3. LT OH line & cable losses

#### HT LINE LOSS CALCULATION

The HT overhead line length is measured with the help of GPS mapping. The details of mapping are given in the following section. The summarized HT OH line length in each feeder is given in the table below.

Table 36: HT OH line – feeder wise

| Feeder Name                    | Type of overhead line |              |             |              |             |             |             |             |              |             |
|--------------------------------|-----------------------|--------------|-------------|--------------|-------------|-------------|-------------|-------------|--------------|-------------|
|                                | Dog                   | Raccoon      | Mink        | 7/14 ACSR    | 7/12 ACSR   | No:6 Cu     | No:8 Cu     | 7/12 Cu     | 3/12 Cu      | 7/14 Cu     |
|                                | Line Length in km     |              |             |              |             |             |             |             |              |             |
| Pullivasal                     |                       |              |             | 2.11         |             |             |             |             |              | 0.30        |
| ITD                            |                       | 7.28         | 5.94        | 4.64         |             |             | 3.74        | 0.19        | 7.52         |             |
| Town                           |                       | 1.94         |             | 3.98         | 0.08        |             | 0.23        | 1.50        | 0.27         | 2.64        |
| Nettigudi                      |                       | 10.23        |             | 2.87         | 0.94        |             | 1.15        | 0.36        | 12.55        | 4.39        |
| Nyamakad                       | 6.72                  | 12.85        |             | 10.63        |             | 3.74        | 2.23        |             | 10.91        | 0.11        |
| Madupatty                      |                       | 16.35        | 0.71        | 28.08        | 2.77        |             | 0.98        | 1.31        | 6.17         | 1.86        |
| <b>Total</b>                   | <b>6.72</b>           | <b>48.64</b> | <b>6.65</b> | <b>52.30</b> | <b>3.79</b> | <b>3.74</b> | <b>8.32</b> | <b>3.36</b> | <b>37.42</b> | <b>9.29</b> |
| <b>% of total length</b>       | <b>3.7</b>            | <b>27.0</b>  | <b>3.7</b>  | <b>29.0</b>  | <b>2.1</b>  | <b>2.1</b>  | <b>4.6</b>  | <b>1.9</b>  | <b>20.8</b>  | <b>5.2</b>  |
| <b>Total HT OH Line Length</b> | <b>180.23</b>         |              |             |              |             |             |             |             |              |             |

### ➤ FEEDER WISE HT OH LINE LOSS

Feeder wise HT OH Line loss calculation is given in the tables below. The calculations are based on month wise unit consumption and converted to yearly in the summary section.

#### 3.1..1. Nyamakad Feeder

Table 37: HT OH line loss – Nyamakad feeder

| Map no | Transformer/HT consumer name      | Distance from switching station | Adjusted distance as per cable type for HT consumers | Energy transmitted through HT line | Cable type | R/km   | Average current | HT OH line loss | HT OH loss |
|--------|-----------------------------------|---------------------------------|--|------------------------------------|------------|--------|-----------------|-----------------|------------|
|        |                                   |                                 | km   | kWh/Month                          |            | ohm    | Amps            | kWh             | %          |
| 1      | Srishti                           | 6.017                           | 5.124  | 11687.67                           | 7/14 ACSR  | 0.5595 | 0.87            | 4.68            | 0.040      |
| 2      | Nallathani factory                | 5.572                           | 5.124  | 8464                               | DOG        | 0.2792 | 0.63            | 1.225           | 0.0145     |
|        |                                   |                                 | 0.448  | 8464                               | Racoon     | 0.3712 | 0.63            | 0.142           | 0.0017     |
| 3      | Tea museum                        | 6.814                           | 6.721  | 29871                              | DOG        | 0.2792 | 2.51            | 25.589          | 0.0857     |
|        |                                   |                                 | 0.093  | 29871                              | 3/12 Cu    | 5.41   | 2.51            | 6.861           | 0.0230     |
| 4      | DYSP bungalow                     | 7.682                           | 6.721  | 141                                | DOG        | 0.2792 | 0.01            | 0.001           | 0.0004     |
|        |                                   |                                 | 0.961  | 141                                | Racoon     | 0.3712 | 0.01            | 0.000           | 0.0001     |
| 5      | Periyavurrai lower (Top)          | 9.378                           | 6.721  | 13615                              | DOG        | 0.2792 | 1.15            | 5.316           | 0.0390     |
|        |                                   |                                 | 1.666  | 13615                              | Racoon     | 0.3712 | 1.15            | 1.752           | 0.0129     |
|        |                                   |                                 | 0.991  | 13615                              | 7/14 ACSR  | 0.5595 | 1.15            | 1.571           | 0.0115     |
| 6      | Sholamalai                        | 9.975                           | 6.721  | 8746                               | DOG        | 0.2792 | 0.74            | 2.194           | 0.0251     |
|        |                                   |                                 | 2.053  | 8746                               | Racoon     | 0.3712 | 0.74            | 0.891           | 0.0102     |
|        |                                   |                                 | 1.201  | 8746                               | 7/14 ACSR  | 0.5595 | 0.74            | 0.785           | 0.0090     |
| s      | Periyavurrai factory (solamallai) | 9.408                           | 6.721  | 230863                             | DOG        | 0.2792 | 16.83           | 1148.1          | 0.4973     |
|        |                                   |                                 | 2.554  | 230863                             | Racoon     | 0.3712 | 16.83           | 580.0           | 0.2512     |
|        |                                   |                                 | 0.133  | 230863                             | 3/12 Cu    | 5.41   | 16.83           | 440.2           | 0.1907     |
| 8      | Anamudi                           | 10.708                          | 6.721  | 10671                              | DOG        | 0.2792 | 0.90            | 3.266           | 0.0306     |
|        |                                   |                                 | 2.554  | 10671                              | Racoon     | 0.3712 | 0.90            | 1.650           | 0.0155     |

| Map no | Transformer/HT consumer name  | Distance from switching station | Adjusted distance as per cable type for HT consumers | Energy transmitted through HT line | Cable type | R/km   | Average current | HT OH line loss | HT OH loss |
|--------|-------------------------------|---------------------------------|--|------------------------------------|------------|--------|-----------------|-----------------|------------|
|        |                               |                                 | km   | kWh/Month                          |            | ohm    | Amps            | kWh             | %          |
|        |                               |                                 | 0.119  | 10671                              | 3/12 Cu    | 5.41   | 0.90            | 1.120           | 0.0105     |
|        |                               |                                 | 1.3  | 10671                              | 7/14 ACSR  | 0.5595 | 0.90            | 1.266           | 0.0119     |
| 9      | Kanniar bungalow              | 10.253                          | 6.721  | 651                                | DOG        | 0.2792 | 0.05            | 0.012           | 0.0019     |
|        |                               |                                 | 3.419  | 651                                | Racoon     | 0.3712 | 0.05            | 0.008           | 0.0013     |
|        |                               |                                 | 0.113  | 651                                | No.8 Cu    | 2.36   | 0.05            | 0.002           | 0.0003     |
| 10     | Kannimalai top - KMFD         | 13.502                          | 6.721  | 4226                               | DOG        | 0.2792 | 0.36            | 0.512           | 0.0121     |
|        |                               |                                 | 4.368  | 4226                               | Racoon     | 0.3712 | 0.36            | 0.443           | 0.0105     |
|        |                               |                                 | 2.413  | 4226                               | 7/14 ACSR  | 0.5595 | 0.36            | 0.368           | 0.0087     |
| 11     | Kannimalai lower              | 11.898                          | 6.721  | 9654                               | DOG        | 0.2792 | 0.81            | 2.673           | 0.0277     |
|        |                               |                                 | 4.368  | 9654                               | Racoon     | 0.3712 | 0.81            | 2.309           | 0.0239     |
|        |                               |                                 | 0.809  | 9654                               | 7/14 ACSR  | 0.5595 | 0.81            | 0.645           | 0.0067     |
| 12     | Kannimalai factory (KMTD TOP) | 11.261                          | 6.721  | 188619                             | DOG        | 0.2792 | 13.75           | 766.4           | 0.4063     |
|        |                               |                                 | 4.435  | 188619                             | Racoon     | 0.3712 | 13.75           | 672.3           | 0.3564     |
|        |                               |                                 | 0.105  | 188619                             | 7/14 Cu    | 8.79   | 13.75           | 376.9           | 0.1998     |
| 13     | Nymakad bungalow              | 14.279                          | 6.721  | 8195                               | DOG        | 0.2792 | 0.60            | 1.446           | 0.0177     |
|        |                               |                                 | 4.435  | 8195                               | Racoon     | 0.3712 | 0.60            | 1.269           | 0.0155     |
|        |                               |                                 | 1.739  | 8195                               | 3/12 Cu    | 5.41   | 0.60            | 7.252           | 0.0885     |
|        |                               |                                 | 0.749  | 8195                               | Racoon     | 0.3712 | 0.60            | 0.214           | 0.0026     |
|        |                               |                                 | 0.635  | 8195                               | 7/14 ACSR  | 0.5595 | 0.60            | 0.274           | 0.0033     |
| 14     | Nymakad east (Office)         | 14.752                          | 6.721  | 7664                               | DOG        | 0.2792 | 0.56            | 1.265           | 0.0165     |
|        |                               |                                 | 4.435  | 7664                               | Racoon     | 0.3712 | 0.56            | 1.110           | 0.0145     |
|        |                               |                                 | 1.739  | 7664                               | 3/12 Cu    | 5.41   | 0.56            | 6.343           | 0.0828     |
|        |                               |                                 | 0.749  | 7664                               | Racoon     | 0.3712 | 0.56            | 0.187           | 0.0024     |
|        |                               |                                 | 1.108  | 7664                               | 7/14 ACSR  | 0.5595 | 0.56            | 0.418           | 0.0055     |
| 15     | Vagavurrai top                | 17.214                          | 6.721  | 2246                               | DOG        | 0.2792 | 0.19            | 0.145           | 0.0064     |
|        |                               |                                 | 4.435  | 2246                               | Racoon     | 0.3712 | 0.19            | 0.127           | 0.0057     |

| Map no | Transformer/HT consumer name | Distance from switching station | Adjusted distance as per cable type for HT consumers | Energy transmitted through HT line | Cable type | R/km   | Average current | HT OH line loss | HT OH loss |
|--------|------------------------------|---------------------------------|--|------------------------------------|------------|--------|-----------------|-----------------|------------|
|        |                              |                                 | km   | kWh/Month                          |            | ohm    | Amps            | kWh             | %          |
|        |                              |                                 | 1.739  | 2246                               | 3/12 Cu    | 5.41   | 0.19            | 0.726           | 0.0323     |
|        |                              |                                 | 4.215  | 2246                               | Racoon     | 0.3712 | 0.19            | 0.121           | 0.0054     |
|        |                              |                                 | 0.104  | 2246                               | 7/14 ACSR  | 0.5595 | 0.19            | 0.004           | 0.0002     |
| 16     | Vagavurrai lower             | 18.649                          | 6.721  | 3234                               | DOG        | 0.2792 | 0.27            | 0.300           | 0.0093     |
|        |                              |                                 | 4.435  | 3234                               | Racoon     | 0.3712 | 0.27            | 0.263           | 0.0081     |
|        |                              |                                 | 1.739  | 3234                               | 3/12 Cu    | 5.41   | 0.27            | 1.504           | 0.0465     |
|        |                              |                                 | 5.724  | 3234                               | Racoon     | 0.3712 | 0.27            | 0.340           | 0.0105     |
|        |                              |                                 | 0.03   | 3234                               | 7/14 ACSR  | 0.5595 | 0.27            | 0.003           | 0.0001     |
| 17     | Vagavurrai bazar             | 19.712                          | 6.721  | 473                                | DOG        | 0.2792 | 0.04            | 0.006           | 0.0014     |
|        |                              |                                 | 4.435  | 449                                | Racoon     | 0.3712 | 0.04            | 0.005           | 0.0011     |
|        |                              |                                 | 1.739  | 449                                | 3/12 Cu    | 5.41   | 0.04            | 0.029           | 0.0065     |
|        |                              |                                 | 6.567  | 449                                | Racoon     | 0.3712 | 0.04            | 0.007           | 0.0017     |
|        |                              |                                 | 0.132  | 449                                | 3/12 Cu    | 5.41   | 0.04            | 0.002           | 0.0005     |
|        |                              |                                 | 0.118  | 449                                | Racoon     | 0.3712 | 0.04            | 0.000           | 0.0000     |
| 18     | Thaliar bungalow             | 20.175                          | 6.721  | 4008                               | DOG        | 0.2792 | 0.34            | 0.461           | 0.0115     |
|        |                              |                                 | 4.435  | 4008                               | Racoon     | 0.3712 | 0.34            | 0.404           | 0.0101     |
|        |                              |                                 | 1.739  | 4008                               | 3/12 Cu    | 5.41   | 0.34            | 2.309           | 0.0576     |
|        |                              |                                 | 6.567  | 4008                               | Racoon     | 0.3712 | 0.34            | 0.598           | 0.0149     |
|        |                              |                                 | 0.713  | 4008                               | 3/12 Cu    | 5.41   | 0.34            | 0.947           | 0.0236     |
| 19     | Thaliar factory              | 21.055                          | 6.721  | 85072                              | DOG        | 0.2792 | 7.16            | 207.6           | 0.2440     |
|        |                              |                                 | 4.435  | 85072                              | Racoon     | 0.3712 | 7.16            | 182.1           | 0.2140     |
|        |                              |                                 | 1.739  | 85072                              | 3/12 Cu    | 5.41   | 7.16            | 1040.6          | 1.2232     |
|        |                              |                                 | 6.567  | 85072                              | Racoon     | 0.3712 | 7.16            | 269.6           | 0.3169     |
|        |                              |                                 | 1.593  | 85072                              | 3/12 Cu    | 5.41   | 7.16            | 953.2           | 1.1205     |
| 20     | Thaliar division             | 20.581                          | 6.721  | 6731                               | DOG        | 0.2792 | 0.57            | 1.299           | 0.0193     |
|        |                              |                                 | 4.435  | 6731                               | Racoon     | 0.3712 | 0.57            | 1.140           | 0.0169     |
|        |                              |                                 | 1.739  | 6731                               | 3/12 Cu    | 5.41   | 0.57            | 6.515           | 0.0968     |

| Map no | Transformer/HT consumer name            | Distance from switching station | Adjusted distance as per cable type for HT consumers | Energy transmitted through HT line | Cable type | R/km   | Average current | HT OH line loss | HT OH loss |
|--------|---|---------------------------------|--|------------------------------------|------------|--------|-----------------|-----------------|------------|
|        |   |                                 | 6.567  | 6731                               | Racoon     | 0.3712 | 0.57            | 1.688           | 0.0251     |
|        |   |                                 | km   | kWh/Month                          |            | ohm    | Amps            | kWh             | %          |
|        |   |                                 | 1.068  | 6731                               | 3/12 Cu    | 5.41   | 0.57            | 4.001           | 0.0594     |
|        |   |                                 | 0.051  | 6731                               | 7/14 ACSR  | 0.5595 | 0.57            | 0.020           | 0.0003     |
| 21     | Manager bungalow - vagavurrai           | 20.529                          | 6.721  | 527                                | DOG        | 0.2792 | 0.04            | 0.154           | 0.0293     |
|        |   |                                 | 4.435  | 527                                | Racoon     | 0.3712 | 0.04            | 0.007           | 0.0013     |
|        |   |                                 | 1.739  | 527                                | 3/12 Cu    | 5.41   | 0.04            | 0.002           | 0.0004     |
|        |   |                                 | 7.578  | 527                                | Racoon     | 0.3712 | 0.04            | 0.012           | 0.0023     |
|        |   |                                 | 0.056  | 527                                | 3/12 Cu    | 5.41   | 0.04            | 0.001           | 0.0002     |
| 22     | Vagavurrai factory                      | 20.842                          | 6.721  | 93755                              | DOG        | 0.2792 | 7.89            | 252.08          | 0.2689     |
|        |   |                                 | 4.435  | 93755                              | Racoon     | 0.3712 | 7.89            | 221.15          | 0.2359     |
|        |   |                                 | 1.739  | 93755                              | 3/12 Cu    | 5.41   | 7.89            | 1263.82         | 1.3480     |
|        |   |                                 | 7.845  | 93755                              | Racoon     | 0.3712 | 7.89            | 391.19          | 0.4173     |
|        |   |                                 | 0.102  | 93755                              | 7/14 ACSR  | 0.5595 | 7.89            | 7.666           | 0.0082     |
| 23     | Vagavurrai factory division             | 21.061                          | 6.721  | 20310                              | DOG        | 0.2792 | 1.71            | 11.83           | 0.0582     |
|        |   |                                 | 4.435  | 20310                              | Racoon     | 0.3712 | 1.71            | 10.38           | 0.0511     |
|        |   |                                 | 1.739  | 20310                              | 3/12 Cu    | 5.41   | 1.71            | 59.31           | 0.2920     |
|        |   |                                 | 7.845  | 20310                              | Racoon     | 0.3712 | 1.71            | 18.36           | 0.0904     |
|        |   |                                 | 0.321  | 20310                              | 7/14 ACSR  | 0.5595 | 1.71            | 1.132           | 0.0056     |
| 24     | Vagavurrai naval                        | 22.558                          | 6.721  | 2736                               | DOG        | 0.2792 | 0.23            | 0.215           | 0.0078     |
|        |   |                                 | 4.435  | 2736                               | Racoon     | 0.3712 | 0.23            | 0.188           | 0.0069     |
|        |   |                                 | 1.739  | 2736                               | 3/12 Cu    | 5.41   | 0.23            | 1.076           | 0.0393     |
|        |   |                                 | 7.845  | 2736                               | Racoon     | 0.3712 | 0.23            | 0.333           | 0.0122     |
|        |   |                                 | 1.818  | 2736                               | 7/14 ACSR  | 0.5595 | 0.23            | 0.116           | 0.0043     |
| 25     | Vagavurrai+ luckam - naval division new | 23.291                          | 6.721  | 4947                               | DOG        | 0.2792 | 0.42            | 0.702           | 0.0142     |
|        |   |                                 | 4.435  | 4947                               | Racoon     | 0.3712 | 0.42            | 0.616           | 0.0124     |
|        |   |                                 | 1.739  | 4947                               | 3/12 Cu    | 5.41   | 0.42            | 3.519           | 0.0711     |



| Map no | Transformer/HT consumer name | Distance from switching station | Adjusted distance as per cable type for HT consumers | Energy transmitted through HT line | Cable type | R/km   | Average current | HT OH line loss | HT OH loss |
|--------|------------------------------|---------------------------------|--|------------------------------------|------------|--------|-----------------|-----------------|------------|
|        |                              |                                 | 7.845  | 4947                               | Racoon     | 0.3712 | 0.42            | 1.089           | 0.0220     |
|        |                              |                                 | km   | kWh/Month                          |            | ohm    | Amps            | kWh             | %          |
|        |                              |                                 | 2.449  | 4947                               | 7/14 ACSR  | 0.5595 | 0.42            | 0.512           | 0.0104     |
| 26     | Rajamalai west BSNL          | 12.4588                         | 6.721  | 1274                               | DOG        | 0.2792 | 0.11            | 0.047           | 0.0037     |
|        |                              |                                 | 4.435  | 1274                               | Racoon     | 0.3712 | 0.11            | 0.041           | 0.0032     |
|        |                              |                                 | 1.239  | 1274                               | 3/12 Cu    | 5.41   | 0.11            | 0.166           | 0.0131     |
|        |                              |                                 | 0.0638   | 1274                               | 7/14 ACSR  | 0.5595 | 0.11            | 0.001           | 0.0001     |
| 27     | Forest (NYFT)                | 13.589                          | 6.721  | 1134                               | DOG        | 0.2792 | 0.10            | 0.037           | 0.0033     |
|        |                              |                                 | 4.435  | 1134                               | Racoon     | 0.3712 | 0.10            | 0.032           | 0.0029     |
|        |                              |                                 | 2.198  | 1134                               | 3/12 Cu    | 5.41   | 0.10            | 0.234           | 0.0206     |
|        |                              |                                 | 0.235  | 1134                               | 7/14 ACSR  | 0.5595 | 0.10            | 0.003           | 0.0002     |
| 28     | Kadalaar bunglow (east)      | 14.604                          | 6.721  | 3584                               | DOG        | 0.2792 | 0.30            | 0.368           | 0.0103     |
|        |                              |                                 | 4.435  | 3584                               | Racoon     | 0.3712 | 0.30            | 0.323           | 0.0090     |
|        |                              |                                 | 3.283  | 3584                               | 3/12 Cu    | 5.41   | 0.30            | 3.486           | 0.0973     |
|        |                              |                                 | 0.165  | 3584                               | 7/14 ACSR  | 0.5595 | 0.30            | 0.018           | 0.0005     |
| 29     | Kadalaar hospital            | 16.576                          | 6.721  | 979                                | DOG        | 0.2792 | 0.08            | 0.027           | 0.0028     |
|        |                              |                                 | 4.435  | 979                                | Racoon     | 0.3712 | 0.08            | 0.024           | 0.0025     |
|        |                              |                                 | 4.985  | 979                                | 3/12 Cu    | 5.41   | 0.08            | 0.395           | 0.0403     |
|        |                              |                                 | 0.435  | 979                                | No-8 Cu    | 2.36   | 0.08            | 0.015           | 0.0015     |
| 30     | Kadalaar factory division    | 17.914                          | 6.721  | 5856                               | DOG        | 0.2792 | 0.49            | 0.984           | 0.0168     |
|        |                              |                                 | 4.435  | 5856                               | Racoon     | 0.3712 | 0.49            | 0.863           | 0.0147     |
|        |                              |                                 | 4.985  | 5856                               | 3/12 Cu    | 5.41   | 0.49            | 14.136          | 0.2414     |
|        |                              |                                 | 0.435  | 5856                               | No-8 Cu    | 2.36   | 0.49            | 0.538           | 0.0092     |
|        |                              |                                 | 1.338  | 5856                               | 3/12 Cu    | 5.41   | 0.49            | 3.794           | 0.0648     |
| 31     | Kadalaar factory             | 17.942                          | 6.721  | 31533                              | DOG        | 0.2792 | 2.76            | 30.843          | 0.0978     |
|        |                              |                                 | 4.435  | 31533                              | Racoon     | 0.3712 | 2.76            | 27.059          | 0.0858     |
|        |                              |                                 | 4.985  | 31533                              | 3/12 Cu    | 5.41   | 2.76            | 443.27          | 1.4057     |
|        |                              |                                 | 0.435  | 31533                              | No-8 Cu    | 2.36   | 2.76            | 16.87           | 0.0535     |

| Map no | Transformer/HT consumer name      | Distance from switching station | Adjusted distance as per cable type for HT consumers<br>km | Energy transmitted through HT line<br>kWh/Month | Cable type | R/km<br>ohm | Average current<br>Amps | HT OH line loss<br>kWh | HT OH loss<br>% |
|--------|-----------------------------------|---------------------------------|--|---|------------|-------------|-------------------------|------------------------|-----------------|
|        |                                   |                                 | 1.366  | 31533   | 3/12 Cu    | 5.41        | 2.76                    | 121.47                 | 0.3852          |
| 32     | Rajamalai park - NVPT             | 14.366                          | 6.721  | 1167  | DOG        | 0.2792      | 0.10                    | 0.039                  | 0.0033          |
|        |                                   |                                 | 4.435  | 1167  | Racoon     | 0.3712      | 0.10                    | 0.034                  | 0.0029          |
|        |                                   |                                 | 3.21   | 1167  | 3/12 Cu    | 5.41        | 0.10                    | 0.361                  | 0.0310          |
| 33     | REP (wireless) stn (Sanghumallai) | 15.348                          | 6.721  | 625   | DOG        | 0.2792      | 0.05                    | 0.011                  | 0.0018          |
|        |                                   |                                 | 4.435  | 625   | Racoon     | 0.3712      | 0.05                    | 0.010                  | 0.0016          |
|        |                                   |                                 | 4.192  | 625   | 3/12 Cu    | 5.41        | 0.05                    | 0.135                  | 0.0217          |
| 34     | Rajamalai division                | 17.033                          | 6.721  | 6298  | DOG        | 0.2792      | 0.53                    | 1.138                  | 0.0181          |
|        |                                   |                                 | 5.177  | 6298  | Racoon     | 0.3712      | 0.53                    | 1.165                  | 0.0185          |
|        |                                   |                                 | 11.156   | 6298  | 3/12 Cu    | 5.41        | 0.53                    | 36.59                  | 0.5809          |
|        |                                   |                                 | 1.685  | 6298  | No-8 Cu    | 2.36        | 0.53                    | 2.411                  | 0.0383          |
| 35     | Pettimudi division                | 18.037                          | 6.721  | 5366  | DOG        | 0.2792      | 0.45                    | 0.826                  | 0.0154          |
|        |                                   |                                 | 4.435  | 5366  | Racoon     | 0.3712      | 0.45                    | 0.725                  | 0.0135          |
|        |                                   |                                 | 4.192  | 5366  | 3/12 Cu    | 5.41        | 0.45                    | 9.981                  | 0.1860          |
|        |                                   |                                 | 1.685  | 5366  | No-8 Cu    | 2.36        | 0.45                    | 1.750                  | 0.0326          |
|        |                                   |                                 | 1.004  | 5366  | 3/12 Cu    | 5.41        | 0.45                    | 2.391                  | 0.0445          |

## 3.1..2. Nettigudi feeder

Table 38: HT OH Line loss – Nettigudi feeder

| Map no | Transformer/consumer name | Distance From Switching Station | Adjusted distance as per cable type for HT consumers | Energy transmitted through HT line | Cable type | R/km   | Average current | HT OH line loss | HT OH loss |
|--------|---------------------------|---------------------------------|--|------------------------------------|------------|--------|-----------------|-----------------|------------|
|        |                           |                                 | km   | kWh                                |            | ohm    | A               | kWh             | %          |
| 1      | Chokanad factory          | 2.694                           | 2.651  | 254678                             | Racoon     | 0.3712 | 35.552          | 1791.04         | 0.7033     |
|        |                           |                                 | 0.043  | 254678                             | 7/12 Cu    | 5.41   | 35.552          | 423.40          | 0.1663     |
| 2      | Chokanad south (fac div)  | 3.07                            | 2.994  | 20826                              | Racoon     | 0.3712 | 1.822           | 7.97            | 0.0383     |
|        |                           |                                 | 0.076  | 20826                              | 7/12 Cu    | 5.41   | 1.822           | 2.95            | 0.0142     |
| 3      | Chokanad east             | 5.14                            | 4.095  | 5145                               | Racoon     | 0.3712 | 0.433           | 0.61            | 0.0120     |
|        |                           |                                 | 1.045  | 5145                               | No.8 Cu    | 2.36   | 0.433           | 1.00            | 0.0194     |
| 4      | Chokanad north            | 5.202                           | 4.095  | 8021                               | Racoon     | 0.3712 | 0.675           | 1.49            | 0.0186     |
|        |                           |                                 | 1.107  | 8021                               | 7/14 ACSR  | 0.5595 | 0.675           | 0.61            | 0.0076     |
| 5      | Chokanad K Kai            | 4.692                           | 4.333  | 4167                               | Racoon     | 0.3712 | 0.304           | 0.32            | 0.0077     |
|        |                           |                                 | 0.359  | 4167                               | 7/14 ACSR  | 0.5595 | 0.304           | 0.04            | 0.0010     |
| 6      | Alisa craig               | 5.409                           | 4.693  | 2503                               | Racoon     | 0.3712 | 0.211           | 0.17            | 0.0067     |
|        |                           |                                 | 0.716  | 2503                               | 7/14 ACSR  | 0.5595 | 0.211           | 0.04            | 0.0015     |
| 7      | Ladbrock                  | 4.828                           | 4.795  | 1857                               | Racoon     | 0.3712 | 0.135           | 0.07            | 0.0038     |
|        |                           |                                 | 0.033  | 1857                               | 7/14 ACSR  | 0.5595 | 0.135           | 0.00            | 0.0000     |
| 8      | Earlston                  | 5.8                             | 5.574  | 1579                               | Racoon     | 0.3712 | 0.115           | 0.06            | 0.0037     |
|        |                           |                                 | 0.226  | 1579                               | 7/12 Cu    | 5.41   | 0.115           | 0.03            | 0.0022     |
| 9      | Forest                    | 5.703                           | 5.574  | 981                                | Racoon     | 0.3712 | 0.072           | 0.02            | 0.0023     |
|        |                           |                                 | 0.129  | 981                                | 3/12 Cu    | 5.41   | 0.072           | 0.01            | 0.0008     |
| 11     | Lockhart colony           | 8.885                           | 5.574  | 16823                              | Racoon     | 0.3712 | 1.226           | 6.72            | 0.0400     |
|        |                           |                                 | 2.554  | 16823                              | 3/12 Cu    | 5.41   | 1.226           | 44.89           | 0.2668     |
|        |                           |                                 | 0.757  | 16823                              | 7/12 ACSR  | 0.5595 | 1.226           | 1.38            | 0.0082     |
| 12     | Lockhart factory          | 8.229                           | 5.574  | 72932                              | Racoon     | 0.3712 | 7.975           | 284.25          | 0.3897     |
|        |                           |                                 | 2.554  | 72932                              | 3/12 Cu    | 5.41   | 7.975           | 1898.21         | 2.6027     |
|        |                           |                                 | 0.101  | 72932                              | No.8 Cu    | 2.36   | 7.975           | 32.75           | 0.0449     |

| Map no | Transformer/consumer name    | Distance From Switching Station | Adjusted distance as per cable type for HT consumers | Energy transmitted through HT line | Cable type | R/km   | Average current | HT OH line loss | HT OH loss |
|--------|------------------------------|---------------------------------|--|------------------------------------|------------|--------|-----------------|-----------------|------------|
|        |                              |                                 | km   | kWh                                |            | ohm    | A               | kWh             | %          |
| 13     | Gunderle manager bungalow    | 13.228                          | 8.87   | 669                                | Racoon     | 0.3712 | 0.049           | 0.02            | 0.0025     |
|        |                              |                                 | 4.358  | 669                                | 3/12 Cu    | 5.41   | 0.049           | 0.12            | 0.0181     |
| 14     | Gunderle factory divn        | 14.392                          | 8.87   | 10683                              | Racoon     | 0.3712 | 0.779           | 4.31            | 0.0404     |
|        |                              |                                 | 5.514  | 10683                              | 3/12 Cu    | 5.41   | 0.779           | 39.08           | 0.3658     |
|        |                              |                                 | 0.008  | 10683                              | 7/14 ACSR  | 0.5595 | 0.779           | 0.01            | 0.0001     |
| 15     | Gunderle factory             | 14.767                          | 8.87   | 174808                             | Racoon     | 0.3712 | 20.335          | 1960.64         | 1.1216     |
|        |                              |                                 | 5.897  | 174808                             | 3/12 Cu    | 5.41   | 20.335          | 18997.44        | 10.868     |
| 16     | BSNL (silent valley)         | 16.135                          | 8.87   | 1469                               | Racoon     | 0.3712 | 0.107           | 0.08            | 0.0056     |
|        |                              |                                 | 7.127  | 1469                               | 3/12 Cu    | 5.41   | 0.107           | 0.95            | 0.0650     |
|        |                              |                                 | 0.138  | 1469                               | 7/14 ACSR  | 0.5595 | 0.107           | 0.00            | 0.0001     |
| 17     | Silent valley divn (North)   | 16.637                          | 8.87   | 14295                              | Racoon     | 0.3712 | 1.042           | 7.72            | 0.0540     |
|        |                              |                                 | 7.528  | 14295                              | 3/12 Cu    | 5.41   | 1.042           | 95.54           | 0.6683     |
|        |                              |                                 | 0.239  | 14295                              | 7/14 ACSR  | 0.5595 | 1.042           | 0.31            | 0.0022     |
| 18     | Silent valley office (South) | 17.495                          | 8.87   | 4557                               | Racoon     | 0.3712 | 0.332           | 0.78            | 0.0172     |
|        |                              |                                 | 8.625  | 4557                               | 3/12 Cu    | 5.41   | 0.332           | 11.12           | 0.2441     |
| 19     | Gunderle lower (Nettigudi)   | 9.059                           | 8.993  | 4599                               | Racoon     | 0.3712 | 0.335           | 0.81            | 0.0176     |
|        |                              |                                 | 0.066  | 4599                               | 7/14 ACSR  | 0.5595 | 0.335           | 0.01            | 0.0002     |
| 20     | Gunderle center (middle)     | 9.571                           | 9.512  | 6459                               | Racoon     | 0.3712 | 0.471           | 1.69            | 0.0262     |
|        |                              |                                 | 0.059  | 6459                               | 7/14 ACSR  | 0.5595 | 0.471           | 0.02            | 0.0002     |
| 21     | Gunderle top                 | 10.364                          | 10.222   | 5001                               | Racoon     | 0.3712 | 0.365           | 1.09            | 0.0218     |
|        |                              |                                 | 0.142  | 5001                               | 7/14 Cu    | 8.79   | 0.365           | 0.36            | 0.0072     |
| 22     | Devikulam middle             | 12.161                          | 10.222   | 2931                               | Racoon     | 0.3712 | 0.214           | 0.37            | 0.0128     |
|        |                              |                                 | 1.087  | 2931                               | 7/14 Cu    | 8.79   | 0.214           | 0.94            | 0.0322     |
|        |                              |                                 | 0.799  | 2931                               | 3/12 Cu    | 5.41   | 0.214           | 0.43            | 0.0145     |
|        |                              |                                 | 0.053  | 2931                               | 7/12 Cu    | 5.41   | 0.214           | 0.03            | 0.0010     |
| 23     | Devikulam factory divsn      | 13.156                          | 10.222   | 10058                              | Racoon     | 0.3712 | 0.733           | 4.41            | 0.0438     |
|        |                              |                                 | 1.087  | 10058                              | 7/14 Cu    | 8.79   | 0.733           | 11.10           | 0.1103     |

| Map no | Transformer/consumer name | Distance From Switching Station | Adjusted distance as per cable type for HT consumers | Energy transmitted through HT line | Cable type | R/km   | Average current | HT OH line loss | HT OH loss |
|--------|---------------------------|---------------------------------|--|------------------------------------|------------|--------|-----------------|-----------------|------------|
|        |                           |                                 | km   | kWh                                |            | ohm    | A               | kWh             | %          |
|        |                           |                                 | 1.788  | 10058                              | 3/12 Cu    | 5.41   | 0.733           | 11.23           | 0.1117     |
|        |                           |                                 | 0.059  | 10058                              | 7/14 ACSR  | 0.5595 | 0.733           | 0.04            | 0.0004     |
| 24     | Devikulam factory         | 13.132                          | 10.222   | 29249                              | Racoon     | 0.3712 | 3.198           | 83.84           | 0.2866     |
|        |                           |                                 | 1.087  | 29249                              | 7/14 Cu    | 8.79   | 3.198           | 211.12          | 0.7218     |
|        |                           |                                 | 1.823  | 29249                              | 3/12 Cu    | 5.41   | 3.198           | 217.91          | 0.7450     |
| 25     | Devikulam ODK             | 13.27                           | 10.222   | 3336                               | Racoon     | 0.3712 | 0.243           | 0.48            | 0.0145     |
|        |                           |                                 | 2.958  | 3336                               | 7/14 Cu    | 8.79   | 0.243           | 3.32            | 0.0996     |
|        |                           |                                 | 0.09   | 3336                               | 7/14 ACSR  | 0.5595 | 0.243           | 0.01            | 0.0002     |
| 26     | Periyakanal PH divsn      | 15.1                            | 10.222   | 3964                               | Racoon     | 0.3712 | 0.289           | 0.68            | 0.0173     |
|        |                           |                                 | 2.958  | 3964                               | 7/14 Cu    | 8.79   | 0.289           | 4.69            | 0.1183     |
|        |                           |                                 | 1.92   | 3964                               | 3/12 Cu    | 5.41   | 0.289           | 1.87            | 0.0473     |
| 27     | Ayur county               | 15.911                          | 10.222   | 23151                              | Racoon     | 0.3712 | 2.025           | 33.62           | 0.1452     |
|        |                           |                                 | 2.958  | 23151                              | 7/14 Cu    | 8.79   | 2.025           | 230.35          | 0.9950     |
|        |                           |                                 | 2.548  | 23151                              | 3/12 Cu    | 5.41   | 2.025           | 122.12          | 0.5275     |
|        |                           |                                 | 0.183  | 23151                              | 7/12 ACSR  | 0.5595 | 2.025           | 0.91            | 0.0039     |
| 28     | Periyakanal factory divsn | 16.996                          | 10.222   | 22180                              | Racoon     | 0.3712 | 1.940           | 30.86           | 0.1391     |
|        |                           |                                 | 2.958  | 22180                              | 7/14 Cu    | 8.79   | 1.940           | 211.44          | 0.9533     |
|        |                           |                                 | 2.548  | 22180                              | 3/12 Cu    | 5.41   | 1.940           | 112.10          | 0.5054     |
|        |                           |                                 | 1.191  | 22180                              | 7/14 Cu    | 8.79   | 1.940           | 85.14           | 0.3838     |
|        |                           |                                 | 0.077  | 22180                              | 3/12 Cu    | 5.41   | 1.940           | 3.39            | 0.0153     |
| 29     | Periyakanal factory       | 17.014                          | 10.222   | 50636                              | Racoon     | 0.3712 | 11.074          | 670.06          | 1.3233     |
|        |                           |                                 | 2.958  | 50636                              | 7/14 Cu    | 8.79   | 11.074          | 4591.53         | 9.0678     |
|        |                           |                                 | 2.548  | 50636                              | 3/12 Cu    | 5.41   | 11.074          | 2434.26         | 4.8074     |
|        |                           |                                 | 1.286  | 50636                              | 7/14 Cu    | 8.79   | 11.074          | 1996.18         | 3.9423     |

## 3.1..3. Madupatty feeder

Table 39: HT OH Line loss – Madupatty feeder

| Map no | Transformer/HT consumer name                  | Distance From switching station | Adjusted distance as per cable type for HT consumers | Energy transmitted through HT line | Cable type | R/km   | Average current | HT OH line loss | HT OH loss |
|--------|---|---------------------------------|--|------------------------------------|------------|--------|-----------------|-----------------|------------|
|        |   | km                              | km   | kWh/Month                          |            | ohm    | Amps            | kWh/month       | %          |
| 1      | Westwood                                      | 2.885                           | 2.885  | 2722.40                            | Racoon     | 0.3712 | 0.229           | 0.12            | 0.0045     |
| 2      | Microwave                                     | 3.855                           | 3.855  | 2950.58                            | Racoon     | 0.3712 | 0.248           | 0.19            | 0.0065     |
| 3      | Grahamsland office                            | 4.6828                          |  | 12057.13                           | Racoon     | 0.3712 | 1.014           | 3.86            | 0.0320     |
| 4      | Grahamsland bazaar                            | 5.612                           |  | 209.56                             | Racoon     | 0.3712 | 0.018           | 0.001           | 0.0007     |
| 5      | Grahamsland bungalows (Velmudi)               | 6.093                           |  | 4667.44                            | 7/12 ACSR  | 0.5595 | 0.393           | 0.75            | 0.0162     |
| 6      | KKD church - korandikad                       | 7.206                           |  | 24077.97                           | 7/14 ACSR  | 0.5595 | 2.025           | 23.71           | 0.0985     |
| 7      | HR school                                     | 8.696                           |  | 16107.32                           | 7/14 ACSR  | 0.5595 | 1.355           | 0.04            | 0.0003     |
| 8      | Madupatty top divsn                           | 11.178                          |  | 5553.55                            | 7/14 ACSR  | 0.5595 | 0.467           | 0.29            | 0.0053     |
| 9      | R&D complex                                   | 12.043                          |  | 4190.49                            | 7/14 ACSR  | 0.5595 | 0.367           | 0.33            | 0.0078     |
| 10     | R&D lab                                       | 13.014                          | 9.24   | 6965                               | Racoon     | 0.3712 | 0.609           | 2.38            | 0.0342     |
|        |   |                                 | 2.192  | 6965                               | 3/12 Cu    | 5.41   | 0.609           | 8.24            | 0.1183     |
|        |   |                                 | 1.582  | 6965                               | 7/14 ACSR  | 0.5595 | 0.609           | 0.62            | 0.0088     |
| 10     | Thenmalay Asst manager bungalow (Hospital dn) | 13.879                          |  | 6417.64                            | 7/14 ACSR  | 0.5595 | 0.540           | 0.320           | 0.0050     |
| 11     | Tenmalay factory divsb                        | 14.095                          |  | 9974.88                            | 7/14 ACSR  | 0.5595 | 0.839           | 0.018           | 0.0002     |
| 12     | Tenmalay new divsn                            | 15.977                          |  | 2555.93                            | 7/14 ACSR  | 0.5595 | 0.215           | 0.10            | 0.0040     |
| 13     | Tenmalay factory                              | 14.426                          | 9.24   | 73398.42                           | Racoon     | 0.3712 | 6.486           | 270.09          | 0.3680     |
|        |   |                                 | 2.192  | 73398.42                           | 3/12 Cu    | 5.41   | 6.486           | 933.82          | 1.2723     |
|        |   |                                 | 2.927  | 73398.42                           | No-6 Cu    | 1.44   | 6.486           | 331.90          | 0.4522     |
|        |   |                                 | 0.067  | 73398.42                           | 7/14 ACSR  | 0.5595 | 6.486           | 2.95            | 0.0040     |
| 14     | Madupatty factory                             | 9.472                           | 9.24   | 296224.17                          | Racoon     | 0.3712 | 26.993          | 4678.44         | 1.5794     |
|        |   |                                 | 0.232  | 296224.17                          | 7/14 ACSR  | 0.5595 | 26.993          | 177.06          | 0.0598     |

| Map no | Transformer/HT consumer name        | Distance From switching station | Adjusted distance as per cable type for HT consumers | Energy transmitted through HT line | Cable type       | R/km          | Average current | HT OH line loss | HT OH loss |
|--------|-------------------------------------|---------------------------------|--|------------------------------------|------------------|---------------|-----------------|-----------------|------------|
|        |                                     | km                              | km   | kWh/Month                          |                  | ohm           | Amps            | kWh/month       | %          |
| 15     | Madupatty divsn                     | 9.661                           |  | 14500.63                           | 7/14 ACSR        | 0.5595        | 1.257           | 3.62            | 0.0250     |
| 17     | Nettimadu divsn                     | 9.878                           |  | 8749.17                            | 7/14 ACSR        | 0.5595        | 0.736           | 3.75            | 0.0429     |
| 18     | High tech KLD board - 2             | 11.645                          | 9.24   | 4963.83                            | Racoon           | 0.3712        | 0.418           | 1.12            | 0.0226     |
|        |                                     |                                 | 0.341  | 4963.8333                          | Racoon           | 0.3712        | 0.418           | 0.04            | 0.0008     |
|        |                                     |                                 | 2.064  | 4963.8333                          | 7/14 ACSR        | 0.5595        | 0.418           | 0.38            | 0.0076     |
| 19     | Indo swiss project                  | 11.781                          | 11.781   | 23190.67                           | Racoon           | 0.3712        | 1.951           | 35.94           | 0.1550     |
| 20     | Gundumalay factory                  | 14.51                           | 12.211   | 120579.17                          | Racoon           | 0.3712        | 11.103          | 1046.11         | 0.8676     |
|        |                                     |                                 | 2.299  | 120579.17                          | 3/12 Cu          | 5.41          | 11.103          | 2870.49         | 2.3806     |
| 21     | Gundumalay factory divsn            | 14.87                           |  | 5502.33                            | <b>7/14 ACSR</b> | <b>0.5595</b> | 0.463           | 16.81           | 0.3055     |
| 22     | Gundumalay benmore                  | 16.093                          |  | 3043.18                            | <b>7/14 ACSR</b> | <b>0.5595</b> | 0.256           | 23.24           | 0.7636     |
| 23     | Gundumalay south para (Top div)     | 17.572                          |  | 4988.32                            | <b>7/12 ACSR</b> | <b>0.5595</b> | 0.420           | 9.17            | 0.1838     |
| 24     | Gundumalay BSNL                     | 18.95                           |  | 1041.58                            | 7/14 ACSR        | 0.5595        | 0.088           | 0.41            | 0.0396     |
| 25     | Gundumalay new divsn                | 19.235                          |  | 2067.64                            | 7/14 ACSR        | 0.5595        | 0.174           | 1.64            | 0.0791     |
| 26     | Gundumalay upper                    | 17.919                          |  | 3896.57                            | 7/14 ACSR        | 0.5595        | 0.328           | 5.64            | 0.1447     |
| 27     | Gundumalay lower                    | 18.963                          |  | 2845.24                            | <b>3/12 Cu</b>   | <b>5.41</b>   | 0.239           | 3.63            | 0.1275     |
| 28     | Gundumalay kadugu                   | 19.654                          |  | 1142.32                            | 7/14 ACSR        | 0.5595        | 0.096           | 0.44            | 0.0387     |
| 29     | New pump indo swiss (irrigation)    | 14.048                          | 14.048   | 3497.36                            | Racoon           | 0.3712        | 0.306           | 1.09            | 0.0311     |
| 30     | Aruvikkad divsn                     | 14.806                          |  | 13000.96                           | 7/12 ACSR        | 0.5595        | 1.094           | 15.02           | 0.1155     |
| 31     | Aruvikkad factory                   | 14.764                          | 13.996   | 43770.75                           | Racoon           | 0.3712        | 3.989           | 154.72          | 0.3535     |
|        |                                     |                                 | 0.768  | 43770.75                           | 7/12 ACSR        | 0.5595        | 3.989           | 12.80           | 0.0292     |
| 32     | Ecopoint                            | 14.699                          |  | 311.58                             | 7/14 ACSR        | 0.5595        | 0.026           | 0.01            | 0.0023     |
| 33     | East divsn pachakkad                | 15.78                           |  | 3388.05                            | 7/14 ACSR        | 0.5595        | 0.285           | 1.04            | 0.0306     |
| 34     | Kundalay naturals (medicinal plant) | 19.276                          |  | 3005.47                            | 7/14 ACSR        | 0.5595        | 0.263           | 6.72            | 0.2235     |
| 35     | Pudukkadi                           | 18.008                          |  | 3419.51                            | 7/14 ACSR        | 0.5595        | 0.288           | 6.68            | 0.1954     |

| Map no | Transformer/HT consumer name    | Distance From switching station | Adjusted distance as per cable type for HT consumers | Energy transmitted through HT line | Cable type | R/km   | Average current | HT OH line loss | HT OH loss |
|--------|---------------------------------|---------------------------------|--|------------------------------------|------------|--------|-----------------|-----------------|------------|
|        |                                 | km                              | km   | kWh/Month                          |            | ohm    | Amps            | kWh/month       | %          |
| 36     | Yelapatty divsn                 | 21.996                          |  | 34582.02                           | 7/12 ACSR  | 0.5595 | 2.909           | 155.90          | 0.4508     |
| 37     | Yelapatty factory               | 21.854                          | 20.059   | 34205.67                           | Racoon     | 0.3712 | 3.435           | 164.44          | 0.4807     |
|        |                                 |                                 | 1.795  | 34205.67                           | 7/14 ACSR  | 0.5595 | 3.435           | 22.18           | 0.0648     |
| 38     | Kundalay office                 | 21.094                          |  | 6004.38                            | 7/14 ACSR  | 0.5595 | 0.505           | 4.42            | 0.0736     |
| 39     | Theerthamalay                   | 22.579                          |  | 2410.84                            | 7/14 ACSR  | 0.5595 | 0.203           | 0.8             | 0.0326     |
| 40     | Chunduvarrai factory            | 23.628                          | 20.059   | 173786.67                          | Racoon     | 0.3712 | 15.356          | 3287.02         | 1.8914     |
|        |                                 |                                 | 2.255  | 173786.67                          | 7/14 ACSR  | 0.5595 | 15.356          | 556.97          | 0.3205     |
|        |                                 |                                 | 1.314  | 173786.67                          | 7/14 Cu    | 8.3    | 15.356          | 4814.58         | 2.7704     |
| 41     | Old factory                     | 23.119                          |  | 9453.95                            | 7/14 ACSR  | 0.5595 | 0.827           | 9.98            | 0.1055     |
| 42     | PR divsn                        | 25.694                          |  | 2411.66                            | 7/14 ACSR  | 0.5595 | 0.203           | 0.94            | 0.0391     |
| 43     | Top divsn                       | 24.423                          |  | 4599.84                            | 7/14 ACSR  | 0.5595 | 0.387           | 3.20            | 0.0695     |
| 44     | Kundalay club                   | 22.9                            |  | 81.75                              | No 8 CU    | 2.36   | 0.007           | 0.003           | 0.0032     |
| 45     | Chittivurrai pump (MC divsn)    | 24.119                          |  | 2608.53                            | 7/12 ACSR  | 0.5595 | 0.219           | 3.00            | 0.1149     |
| 46     | Chittivurrai factory            | 23.631                          | 20.059   | 9663.75                            | Racoon     | 0.3712 | 1.293           | 26.91           | 0.2784     |
| 47     | Chittivurrai factory divsn      | 24.17                           |  | 13677.49                           | 7/12 ACSR  | 0.5595 | 1.150           | 84.26           | 0.6160     |
| 48     | New Pump (Chittivurrai new div) | 24.396                          |  | 1406.81                            | 7/14 ACSR  | 0.5595 | 0.118           | 0.90            | 0.0636     |
| 49     | Chittivurrai OC divsn           | 25.148                          |  | 5537.11                            | 7/14 ACSR  | 0.5595 | 0.466           | 14.07           | 0.2540     |



## 3.1..4. ITD feeder

Table 40: HT OH line loss – ITD feeder

| Map no | Transformer/HT consumer name    | Distance from switching station | Energy transmitted through HT line<br>kWh/Month | Cable type           | R/km<br>ohm | Average current<br>Amps | HT OH line loss<br>kWh/month | HT OH loss<br>% |
|--------|---------------------------------|---------------------------------|---|----------------------|-------------|-------------------------|------------------------------|-----------------|
| 1      | Tata BSS                        | 5.767                           | 6560.00   | Racoon               | 0.3712      | 0.574                   | 1.55                         | 0.02            |
| 2      | Nullathanni West Division       | 5.828                           | 9191.02   | Racoon               | 0.3712      | 0.804                   | 3.05                         | 0.03            |
| 3      | ITD factory                     | 5.777                           | 387013.47                                       | Mink 6 + 1/3.66 ACSR | 0.4545      | 28.213                  | 3912.44                      | 1.01            |
| 4      | Vermi compost                   | 6.812                           | 390.75  | 3/12 Cu              | 5.41        | 0.028                   | 0.01                         | 0.004           |
| 5      | Kallar factory divsn            | 8.221                           | 16306.20  | No.8                 | 2.36        | 1.189                   | 41.92                        | 0.26            |
| 6      | JE Divsn (Null kallu pathu new) | 11.491                          | 1171.01   | No.8                 | 2.36        | 0.085                   | 0.36                         | 0.03            |
| 7      | Hospital bungalow (Kallar West) | 10.205                          | 9329.36   | No.8                 | 2.36        | 0.680                   | 19.99                        | 0.21            |
| 8      | Kallar factory                  | 8.114                           | 129917.00                                       | 3/12 Cu              | 5.41        | 9.471                   | 2563.88                      | 1.97            |
| 9      | Seven mally godown (Nagermudi)  | 3.704                           | 11675.18  | 3/12 Cu              | 5.41        | 0.851                   | 7.17                         | 0.06            |
| 10     | Parvathi                        | 4.615                           | 5964.93   | 3/12 Cu              | 5.41        | 0.435                   | 3.88                         | 0.07            |
| 11     | Nadiar                          | 5.614                           | 21234.96  | 3/12 Cu              | 5.41        | 1.548                   | 77.88                        | 0.37            |
| 12     | Kurumalai                       | 6.385                           | 6410.00   | 3/12 Cu              | 5.41        | 0.467                   | 9.00                         | 0.14            |
| 13     | ITD pump                        | 7.105                           | 8818.33   | 3/12 Cu              | 5.41        | 0.643                   | 34.31                        | 0.4             |
| 15     | Upper seven malai               | 4.386                           | 12213.68  | 7/14 ACSR            | 0.5595      | 0.890                   | 2.84                         | 0.02            |
| 16     | Ottupara                        | 5.483                           | 11421.21  | 3/12 Cu              | 5.41        | 0.833                   | 8.85                         | 0.08            |
| 17     | Letchmi east                    | 6.485                           | 4802.31   | 7/14 ACSR            | 0.5595      | 0.350                   | 0.96                         | 0.02            |
| 18     | Letchmi factory                 | 7.027                           | 101860.75                                       | 7/14 ACSR            | 0.5595      | 7.501                   | 265.39                       | 0.26            |
| 19     | Letchmi factory divs            | 7.187                           | 27964.24  | Mink                 | 0.4545      | 2.039                   | 24.12                        | 0.09            |
| 20     | Letchmi viriparrai              | 12.111                          | 6466.08   | 7/14 ACSR            | 0.5595      | 0.471                   | 2.62                         | 0.04            |

## 3.1..5. Town feeder

Table 41: HT OH Line loss – Town feeder

| Map no | Transformer/HT consumer name | Distance From switching station | Adjusted distance as per cable type for HT connections | Energy transmitted through HT line | Cable type | R/km   | Average current | HT OH line loss | HT OH loss |
|--------|------------------------------|---------------------------------|--|------------------------------------|------------|--------|-----------------|-----------------|------------|
|        |                              | km                              | km   | kWh/Month                          |            | ohm    | Amps            | kWh/month       | %          |
| 1      | Old munnar tea tasting       | 1.791                           |  | 19549                              | 3/12 Cu    | 5.41   | 1.425           | 4.09            | 0.02       |
| 2      | Casa montana                 | 2.424                           | 1.738  | 4315                               | Racoon     | 0.3712 | 0.315           | 0.14            | 0.003      |
|        |                              |                                 | 0.58   | 4315                               | 7/14 Cu    | 8.79   | 0.315           | 1.09            | 0.03       |
|        |                              |                                 | 0.106  | 4315                               | 7/14 ACSR  | 0.5595 | 0.315           | 0.01            | 0.0003     |
| 3      | High range club              | 2.811                           |  | 5694                               | 7/12 Cu    | 5.41   | 0.415           | 3.25            | 0.06       |
| 4      | Munnar palace (Grand Plaza)  | 2.599                           | 1.738  | 11295                              | Racoon     | 0.3712 | 0.823           | 0.94            | 0.01       |
|        |                              |                                 | 0.674  | 11295                              | 7/14 Cu    | 8.79   | 0.823           | 8.68            | 0.08       |
|        |                              |                                 | 0.187  | 11295                              | 7/12 Cu    | 5.41   | 0.823           | 1.48            | 0.01       |
| 5      | Poopada                      | 2.703                           |  | 32742                              | 7/14 Cu    | 8.79   | 2.387           | 112.32          | 0.34       |
| 6      | MS hotel                     | 2.589                           | 1.738  | 10739                              | Racoon     | 0.3712 | 0.783           | 0.85            | 0.01       |
|        |                              |                                 | 0.851  | 10739                              | 7/14 Cu    | 8.79   | 0.783           | 9.90            | 0.09       |
| 7      | Workshop club                | 2.93                            |  | 24921                              | 7/12 ACSR  | 0.5595 | 1.817           | 74.60           | 0.30       |
| 8      | EVM                          | 3.025                           | 1.738  | 15647                              | Racoon     | 0.3712 | 1.141           | 26.42           | 0.17       |
|        |                              |                                 | 1.159  | 15647                              | 7/14 Cu    | 8.79   | 1.141           | 28.63           | 0.18       |
|        |                              |                                 | 0.128  | 15647                              | 3/12 Cu    | 5.41   | 1.141           | 1.95            | 0.01       |
| 9      | Workshop                     | 3.101                           |  | 54903                              | 3/12 Cu    | 5.41   | 4.002           | 413.02          | 0.75       |
| 10     | Shikshak sadan               | 3.165                           |  | 32682                              | 7/12 ACSR  | 0.5595 | 2.383           | 145.84          | 0.45       |
| 11     | RO                           | 3.655                           |  | 17135                              | 3/12 Cu    | 5.41   | 1.249           | 58.81           | 0.34       |
| 12     | Tea county-KTDC              | 4.155                           | 1.738  | 26674                              | Racoon     | 0.3712 | 1.945           | 5.27            | 0.02       |
|        |                              |                                 | 1.917  | 26674                              | 7/14 Cu    | 8.79   | 1.945           | 137.62          | 0.52       |
|        |                              |                                 | 0.5  | 26674                              | 7/14 ACSR  | 0.5595 | 1.945           | 2.28            | 0.01       |
| 13     | Grahamsland pump - petrol    | 5.615                           |  | 2023                               | 7/14 ACSR  | 0.5595 | 0.147           | 0.60            | 0.03       |

| Map no | Transformer/HT consumer name | Distance From switching station | Adjusted distance as per cable type for HT connections | Energy transmitted through HT line | Cable type | R/km   | Average current | HT OH line loss | HT OH loss |
|--------|------------------------------|---------------------------------|--|------------------------------------|------------|--------|-----------------|-----------------|------------|
|        |                              | km                              | km   | kWh/Month                          |            | ohm    | Amps            | kWh/month       | %          |
| 14     | Teacher's quarters           | 4.59                            |  | 63257                              | 7/14 ACSR  | 0.5595 | 4.611           | 558.33          | 0.88       |
| 15     | KWA pump                     | 4.795                           |  | 14325                              | 7/14 ACSR  | 0.5595 | 1.044           | 28.90           | 0.20       |
| 16     | Botanical garden             | 4.964                           |  | 2915                               | 7/14 ACSR  | 0.5595 | 0.213           | 1.206           | 0.04       |
| 17     | Eastend                      | 3.949                           |  | 38120                              | 7/14 ACSR  | 0.5595 | 2.779           | 327.3           | 0.86       |
| 18     | BSNL                         | 4.263                           |  | 28890                              | Racoon     | 0.3712 | 2.106           | 202.2           | 0.70       |
| 19     | Town                         | 4.118                           |  | 33736                              | 7/14 Cu    | 8.79   | 2.459           | 8.03            | 0.02       |
| A1     | Residency                    | 4.206                           |  | 28475                              | 7/14 ACSR  | 0.5595 | 2.076           | 196.5           | 0.69       |
| A2     | Eastend hotel                | 4.206                           | 1.738  | 32027                              | Racoon     | 0.3712 | 2.335           | 7.60            | 0.02       |
|        |                              |                                 | 2.319  | 32027                              | 7/14 Cu    | 8.79   | 2.335           | 240.01          | 0.75       |
|        |                              |                                 | 0.149  | 32027                              | 7/14 ACSR  | 0.5595 | 2.335           | 0.98            | 0.00       |
| 20     | Nirmala society - NUSD       | 5.287                           |  | 30122                              | 7/12 Cu    | 5.41   | 2.196           | 280.8           | 0.93       |
| 21     | GH                           | 5.183                           | 1.738  | 34613                              | Racoon     | 0.3712 | 2.523           | 8.87            | 0.03       |
|        |                              |                                 | 2.319  | 34613                              | 7/14 Cu    | 8.79   | 2.523           | 280.33          | 0.81       |
|        |                              |                                 | 0.149  | 34613                              | 7/14 ACSR  | 0.5595 | 2.523           | 1.15            | 0.003      |
|        |                              |                                 | 0.747  | 34613                              | 7/12 Cu    | 5.41   | 2.523           | 55.58           | 0.16       |
|        |                              |                                 | 0.23   | 34613                              | No.8 Cu    | 2.36   | 2.523           | 7.46            | 0.02       |
| 22     | KSEB                         | 4.545                           |  | 46604                              | 7/14 ACSR  | 0.5595 | 3.397           | 531.105         | 1.14       |
| 24     | OCR                          | 5.051                           |  | 3091                               | 7/14 ACSR  | 0.5595 | 0.225           | 2.37            | 0.08       |
| 25     | Munnar engineering college   | 5.173                           | 1.738  | 3720                               | Racoon     | 0.3712 | 0.271           | 0.05            | 0.001      |
|        |                              |                                 | 2.319  | 3720                               | 7/14 Cu    | 8.79   | 0.271           | 1.73            | 0.05       |
|        |                              |                                 | 0.149  | 3720                               | 7/14 ACSR  | 0.5595 | 0.271           | 0.01            | 0.0002     |
|        |                              |                                 | 0.967  | 3720                               | 7/14 ACSR  | 0.5595 | 0.271           | 0.05            | 0.001      |

### 3.1..6. Pullivasal feeder

Table 42: HT OH Line loss – Pullivasal feeder

| Map no | Pole/transformer/metre | Distance from switching station | Energy transmitted through HT line | Cable type | R/km | Average current | HT OH line loss | HT OH loss |
|--------|------------------------|---------------------------------|------------------------------------|------------|------|-----------------|-----------------|------------|
|        |                        | km                              | kWh/Month                          |            | ohm  | Amps            | kWh/month       | %          |
| 2      | Attukad                | 0.999                           | 30757.54                           | 7/14 Cu    | 8.3  | 2.242           | 90.04           | 0.29       |
| 4      | Devon Shire            | 0.605                           | 20756.2                            | 7/14 Cu    | 8.3  | 1.891           | 38.80           | 0.19       |
| 5      | Pallivasal Packeting   | 0.698                           | 37352.3                            | 7/14 Cu    | 8.3  | 3.404           | 144.98          | 0.39       |
| 6      | Pallivasal factory     | 0.748                           | 131531.0                           | 7/14 Cu    | 8.3  | 12.751          | 2180.26         | 1.66       |
| 7      | Allakovil transformer  | 1.004                           | 43125.99                           | 7/14 Cu    | 8.3  | 3.144           | 177.91          | 0.41       |

#### Sample Calculations: Attukad Transformer

- Average monthly kWh = 30757.54 kWh
- Power factor = 1 (Measured from DT meter)
- System line voltage (V) = 11 kV
- Resistance  $\Omega$ /km, for 7/14 Cu (R) = 8.3  $\Omega$
- Line Length, (l) = 0.999 km
- Average Current, I (A) =  $\frac{\text{Average monthly kWh}}{30 \times 24 \times \sqrt{3} \times \text{system line voltage} \times \text{Power factor}}$

$$\text{Average Current, } I \text{ (A)} = \frac{30757.54}{30 \times 24 \times \sqrt{3} \times 11 \times 1} = 2.242A$$

- HT line loss per month (kWh) =  $\frac{3 \times I^2 \times R \times l \times 24 \times 30}{1000}$

$$\text{HT line loss per month (kWh)} = \frac{3 \times 2.242^2 \times 8.3 \times 0.999 \times 24 \times 30}{1000} = 90.04 \text{ kWh}$$

### **TRANSFORMER & LT LINE LOSS CALCULATION**

- A. The Transformer loss & LT line length loss in feeder wise is summarized in this section.
- B. The LT line length is measured with the help of GPS mapping and KDHP measured LT line length.
- C. The transformer rated no load & load loss taken as per the IS 2026 standard.
- D. LT cable length and details are measured physically from the site.

The LT OH line length as per the feeder wise is given in table below.

*Table 43: LT OH line – feeder wise*

| Feeder                     | Pullivasal | ITD  | Town | Nettigudi | Nyamakad | Madupatty | Total        |
|----------------------------|------------|------|------|-----------|----------|-----------|--------------|
| <b>LT Line Length (km)</b> | 6.9        | 37.5 | 18.5 | 34.3      | 31.4     | 65.2      | <b>193.8</b> |

*Table 44: LT OH line Details – feeder wise*

| Feeder Name                       | Type of LT overhead line |             |            |            |            |            |
|-----------------------------------|--------------------------|-------------|------------|------------|------------|------------|
|                                   | ACSR                     | 7/14 ACSR   | 3/12 Cu    | Cu 8       | No 10 Cu   | No 8 Cu    |
|                                   | <b>Line Length in km</b> |             |            |            |            |            |
| Pullivasal                        |                          | 5.274       | 1.476      |            | 0.15       |            |
| ITD                               | 1.938                    | 30.415      | 0.081      | 0.595      | 4.013      | 0.458      |
| Town                              | 3.036                    | 6.552       | 4.931      |            | 3.981      |            |
| Nettigudi                         | 3.998                    | 25.288      | 2.534      | 0.258      | 2.212      |            |
| Nyamakad                          | 3.998                    | 21.322      | 2.86       | 1.535      | 1.391      | 0.294      |
| Madupatty                         | 8.176                    | 44.165      | 4.585      | 0.929      | 7.345      |            |
| Total                             | 21.15                    | 133.02      | 16.47      | 3.32       | 19.09      | 0.75       |
| <b>Percentage of total length</b> | <b>10.9</b>              | <b>68.6</b> | <b>8.5</b> | <b>1.7</b> | <b>9.9</b> | <b>0.4</b> |
| <b>Total LT Line Length</b>       | <b>193.8</b>             |             |            |            |            |            |

### 3.1.1 FEEDER WISE TRANSFORMER AND LT LINE LOSS

Feeder wise Transformer and LT OH Line & UG cable loss calculation is given in the tables below. The calculations are based on month wise unit consumption and converted to yearly in the summary section.

#### 4.1.1 Nyamakad feeder

Table 45: LT cable, LT OH line & Transformer loss – Neyamakad feeder

| Map no | Pole/transformer/ metre           | LT OH line                            |                 |                 |                 | LT UG cable   |      |      |       |                 |                    |               | Transformer loss |                    |                  |                  |                    |
|--------|-----------------------------------|---------------------------------------|-----------------|-----------------|-----------------|---------------|------|------|-------|-----------------|--------------------|---------------|------------------|--------------------|------------------|------------------|--------------------|
|        |                                   | Energy transmitted through LT OH line | Average current | LT OH line loss | LT OH line loss | Size of cable | R un | Core | R/k m | Average current | LT Cable line loss | LT Cable loss | Capacity of DT   | % of loading - Avg | Transformer loss | Transformer loss | Transformer loss % |
|        |                                   | kWh/Month                             | Amps            | kWh/month       | %               | Sq mm         | nos  | nos  | ohm   | Amps            | kWh/month          | %             | kVA              | %                  | kW               | kWh/month        | %                  |
| 3      | Tea museum                        | 24532                                 | 49.18           | 4854.18         | 19.8            | 240           | 1    | 3.5  | 0.16  | 58.9            | 24.0               | 0.08          | 150              | 29.9               | 0.64             | 460              | 1.6                |
| 4      | DYSP bunglow                      | 69                                    | 0.14            | 0.00            | 0.002           | 70            | 1    | 3.5  | 0.603 | 0.1             | 0.0004             | 0.001         | 5                | 1.9                | 0.10             | 72               | 104.3              |
| 5      | Periyavurrai lower (Top)          | 11613                                 | 23.28           | 1631.63         | 14.0            | 70            | 1    | 3.5  | 0.603 | 26.6            | 13.8               | 0.10          | 63               | 29.5               | 0.49             | 356              | 2.7                |
| 6      | Sholamalai                        | 7634                                  | 15.30           | 789.61          | 10.3            | 70            | 1    | 3.5  | 0.603 | 16.9            | 11.1               | 0.13          | 63               | 18.8               | 0.43             | 311              | 3.7                |
| 7      | Periyavurrai factory (solamallai) | 7469                                  | 14.97           | 71.99           | 1.0             | 70            | 1    | 3.5  | 0.603 | 15.1            | 8.9                | 0.12          | 1000             | 32.2               | 1.91             | 1379             | 0.3                |
| 8      | Anamudi                           | 9406                                  | 18.86           | 927.61          | 9.9             | 70            | 1    | 3.5  | 0.603 | 20.7            | 11.2               | 0.11          | 63               | 23.0               | 0.45             | 327              | 3.2                |
| 9      | Kanniar bunglow                   | 510                                   | 1.02            | 0.42            | 0.1             | 70            | 1    | 3.5  | 0.603 | 1.0             | 0.020              | 0.004         | 15               | 4.8                | 0.20             | 141              | 27.6               |
| 10     | Kannimalai top - KMFD             | 3681                                  | 7.38            | 256.16          | 7.0             | 70            | 1    | 3.5  | 0.603 | 7.9             | 1.2                | 0.03          | 63               | 8.8                | 0.40             | 287              | 7.3                |
| 11     | Kannimalai lower                  | 8017                                  | 16.07           | 1296.12         | 16.2            | 120           | 1    | 3.5  | 0.36  | 18.7            | 10.8               | 0.12          | 100              | 13.1               | 0.46             | 329              | 3.5                |
| 12     | Kannimalai factory (KMTD TOP)     | 4053                                  | 8.12            | 25.97           | 0.6             | 70            | 1    | 3.5  | 0.603 | 8.2             | 2.6                | 0.06          | 750              | 35.0               | 1.82             | 1308             | 0.3                |
| 13     | Nymakad bunglow                   | 7267                                  | 14.57           | 610.88          | 8.4             | 70            | 1    | 3.5  | 0.603 | 15.8            | 9.7                | 0.12          | 63               | 17.6               | 0.43             | 307              | 3.9                |
| 14     | Nymakad east (Office)             | 6499                                  | 13.03           | 851.75          | 13.1            | 70            | 1    | 3.5  | 0.603 | 14.7            | 8.5                | 0.12          | 63               | 16.4               | 0.42             | 304              | 4.1                |

| Map no | Pole/transformer/ metre                 | LT OH line                            |                 |                 |                 | LT UG cable   |     |      |       |                 |                    |               | Transformer loss |                    |                  |                  |                    |
|--------|---|---------------------------------------|-----------------|-----------------|-----------------|---------------|-----|------|-------|-----------------|--------------------|---------------|------------------|--------------------|------------------|------------------|--------------------|
|        |   | Energy transmitted through LT OH line | Average current | LT OH line loss | LT OH line loss | Size of cable | R   | Core | R/km  | Average current | LT Cable line loss | LT Cable loss | Capacity of DT   | % of loading - Avg | Transformer loss | Transformer loss | Transformer loss % |
|        |   | kWh/Month                             | Amps            | kWh/month       | %               | Sq mm         | nos | nos  | ohm   | Amps            | kWh/month          | %             | kVA              | %                  | kW               | kWh/month        | %                  |
| 15     | Vagavurrai top                          | 1948                                  | 3.90            | 16.06           | 0.8             | 70            | 1   | 3.5  | 0.603 | 3.9             | 0.4                | 0.02          | 63               | 4.4                | 0.39             | 282              | 14.4               |
| 16     | Vagavurrai lower                        | 2857                                  | 5.73            | 90.85           | 3.2             | 70            | 1   | 3.5  | 0.603 | 5.9             | 1.4                | 0.05          | 63               | 6.6                | 0.40             | 285              | 9.6                |
| 17     | Vagavurrai bazar                        | 163                                   | 0.33            | 0.02            | 0.01            | 70            | 1   | 3.5  | 0.603 | 0.3             | 0.002              | 0.001         | 100              | 0.2                | 0.43             | 310              | 189.8              |
| 18     | Thaliar bunglow                         | 3694                                  | 7.41            | 24.87           | 0.7             | 70            | 1   | 3.5  | 0.603 | 7.5             | 2.2                | 0.06          | 63               | 8.3                | 0.40             | 287              | 7.7                |
| 20     | Thaliar division                        | 5793                                  | 11.61           | 617.22          | 10.7            | 95            | 1   | 3.5  | 0.456 | 12.9            | 2.4                | 0.04          | 100              | 9.0                | 0.44             | 319              | 5.0                |
| 21     | Manager bunglow - vagavurrai            | 452                                   | 0.91            | 0.02            | 0.01            | 70            | 1   | 3.5  | 0.603 | 0.9             | 0.016              | 0.004         | 5                | 12.7               | 0.10             | 75               | 16.6               |
| 23     | Vagavurrai factory division             | 16574                                 | 33.23           | 3324.29         | 20.1            | 120           | 1   | 3.5  | 0.36  | 39.9            | 12.4               | 0.06          | 100              | 27.9               | 0.55             | 399              | 2.0                |
| 24     | Vagavurrai naval                        | 2266                                  | 4.54            | 136.72          | 6.0             | 50            | 1   | 3.5  | 0.82  | 4.8             | 0.8                | 0.03          | 150              | 2.2                | 0.46             | 332              | 13.8               |
| 25     | Vagavurrai+ luckam - naval division new | 4547                                  | 9.12            | 105.06          | 2.3             | 50            | 1   | 3.5  | 0.82  | 9.3             | 4.6                | 0.10          | 63               | 10.4               | 0.40             | 290              | 6.2                |
| 26     | Rajamalai west BSNL                     | 1128                                  | 2.26            | 1.54            | 0.1             | 35            | 1   | 3.5  | 1.063 | 2.3             | 0.4                | 0.03          | 15               | 11.0               | 0.20             | 144              | 12.7               |
| 27     | Forest (NYFT)                           | 931                                   | 1.87            | 0.52            | 0.1             | 70            | 1   | 3.5  | 0.603 | 1.9             | 0.1                | 0.01          | 25               | 5.2                | 0.28             | 203              | 21.8               |
| 28     | Kadalaar bunglow (east)                 | 3226                                  | 6.47            | 71.34           | 2.2             | 50            | 1   | 3.5  | 0.82  | 6.6             | 1.2                | 0.04          | 63               | 7.3                | 0.40             | 285              | 8.7                |
| 29     | Kadalaar hospital                       | 666                                   | 1.34            | 2.81            | 0.4             | 50            | 1   | 3.5  | 0.82  | 1.3             | 0.048              | 0.01          | 100              | 0.9                | 0.43             | 310              | 46.3               |
| 30     | Kadalaar factory division               | 5152                                  | 10.33           | 385.45          | 7.5             | 70            | 1   | 3.5  | 0.603 | 11.1            | 2.4                | 0.04          | 100              | 7.8                | 0.44             | 317              | 5.7                |
| 33     | REP (wireless) stn (Sanghumallai)       | 483                                   | 0.97            | 0.86            | 0.2             | 70            | 1   | 3.5  | 0.603 | 1.0             | 0.0                | 0.00          | 15               | 4.7                | 0.20             | 141              | 29.1               |
| 34     | Rajamalai division                      | 5521                                  | 11.07           | 497.94          | 9.0             | 70            | 1   | 3.5  | 0.603 | 12.1            | 4.7                | 0.08          | 50               | 16.9               | 0.38             | 275              | 4.6                |
| 35     | Pettimudi & Edamalakudi feedback        | 4708                                  | 9.44            | 362.16          | 7.7             | 70            | 1   | 3.5  | 0.603 | 10.2            | 4.0                | 0.08          | 63               | 11.3               | 0.41             | 292              | 5.8                |

## 4.1.2 ITD feeder

Table 46: LT cable, LT OH line &amp; Transformer loss – ITD feeder

| Map no | Transformer                     | LT OH line         |                 |                 |                 | LT UG Cable line |     |      |      |                 |                    |               | Transformer loss |                    |                  |                  |                    |
|--------|---------------------------------|--------------------|-----------------|-----------------|-----------------|------------------|-----|------|------|-----------------|--------------------|---------------|------------------|--------------------|------------------|------------------|--------------------|
|        |                                 | Energy transmitted | Average current | LT OH line loss | LT OH line loss | Size of cable    | Run | Core | R/km | Average current | LT Cable line loss | LT Cable loss | Capacity of DT   | % of loading - Avg | Transformer loss | Transformer loss | Transformer loss % |
|        |                                 | kWh/Month          | Amps            | kWh/month       | %               | Sq mm            | nos | nos  | ohm  | Amps            | kWh/month          | %             | kVA              | %                  | Watts            | kWh/month        | %                  |
| 2      | Nullathanni West Division       | 7186               | 14.41           | 1687            | 23.5            | 95               | 1   | 3.5  | 0.46 | 17.8            | 3.12               | 0.04          | 63               | 19.77              | 0.44             | 314.6            | 3.54               |
| 3      | ITD factory                     | 28448              | 57.03           | 2155            | 7.6             | 70               | 1   | 3.5  | 0.60 | 61.4            | 73.54              | 0.24          | 1000             | 54.03              | 2.67             | 1920.6           | 0.25               |
| 5      | Kallar factory divsn            | 12899              | 25.86           | 3020            | 23.4            | 70               | 1   | 3.5  | 0.60 | 31.9            | 19.90              | 0.12          | 100              | 22.36              | 0.51             | 367.2            | 2.30               |
| 6      | JE Divsn (Null kallu pathu new) | 870                | 1.74            | 20              | 2.3             | 70               | 1   | 3.5  | 0.60 | 1.8             | 0.06               | 0.01          | 63               | 1.98               | 0.39             | 281.1            | 31.6               |
| 7      | Hospital bunglow (Kallar West)  | 7071               | 14.17           | 1936            | 27.4            | 70               | 1   | 3.5  | 0.60 | 18.1            | 6.37               | 0.07          | 63               | 20.28              | 0.44             | 316.3            | 3.51               |
| 9      | Seven mally godown (Nagermudi)  | 8628               | 17.30           | 2612            | 30.3            | 70               | 1   | 3.5  | 0.60 | 22.5            | 99.20              | 0.88          | 63               | 25.25              | 0.47             | 335.9            | 2.96               |
| 10     | Parvathi                        | 4722               | 9.47            | 945             | 20.0            | 70               | 1   | 3.5  | 0.60 | 11.4            | 3.36               | 0.06          | 63               | 12.63              | 0.41             | 294.6            | 5.20               |
| 11     | Nadiar                          | 15209              | 30.49           | 5598            | 36.8            | 120              | 1   | 3.5  | 0.36 | 41.7            | 20.29              | 0.10          | 100              | 29.22              | 0.57             | 407.9            | 1.96               |
| 12     | Kurumalai                       | 5111               | 10.25           | 1106            | 21.6            | 70               | 1   | 3.5  | 0.60 | 12.5            | 3.04               | 0.05          | 25               | 34.91              | 0.26             | 189.4            | 3.05               |
| 15     | Upper seven malai               | 8674               | 17.39           | 3187            | 36.7            | 70               | 1   | 3.5  | 0.60 | 23.8            | 11.05              | 0.09          | 63               | 26.44              | 0.47             | 341.2            | 2.87               |
| 16     | Ottupara                        | 8367               | 16.77           | 2711            | 32.4            | 70               | 1   | 3.5  | 0.60 | 22.2            | 9.64               | 0.09          | 63               | 24.69              | 0.46             | 333.5            | 3.01               |
| 17     | Letchmi east                    | 3946               | 7.91            | 565             | 14.3            | 70               | 1   | 3.5  | 0.60 | 9.0             | 1.07               | 0.02          | 63               | 10.05              | 0.40             | 289.5            | 6.42               |
| 19     | Letchmi factory divs            | 16983              | 34.05           | 10471           | 61.7            | 95               | 1   | 3.5  | 0.46 | 55.0            | 29.84              | 0.11          | 100              | 38.56              | 0.67             | 480.9            | 1.75               |
| 20     | Letchmi viriparrai              | 5076               | 10.18           | 1091            | 21.5            | 70               | 1   | 3.5  | 0.60 | 12.4            | 1.99               | 0.03          | 63               | 13.60              | 0.41             | 296.8            | 4.81               |



## 4.1.3 Nettigudi feeder

Table 47: LT cable, LT OH line &amp; Transformer loss – Nettigudi feeder

| Map no | Transformer                     | LT OH line                      |                 |                 |                 | LT UG cable   |     |      |       |                 |                    |               | Transformer loss |                    |                  |                  |                    |
|--------|---------------------------------|---------------------------------|-----------------|-----------------|-----------------|---------------|-----|------|-------|-----------------|--------------------|---------------|------------------|--------------------|------------------|------------------|--------------------|
|        |                                 | Energy transmitted – LT OH line | Average current | LT OH line loss | LT OH line loss | Size of cable | Run | Core | R/km  | Average current | LT Cable line loss | LT Cable loss | Capacity of DT   | % of loading - Avg | Transformer loss | Transformer loss | Transformer loss % |
|        |                                 | kWh/Month                       | Amps            | kWh/month       | %               | Sq mm         | nos | nos  | ohm   | Amps            | kWh/month          | %             | kVA              | %                  | kW               | kWh              | %                  |
| 2      | Chokanad south (fac div)        | 18653                           | 43.1            | 1681.7          | 9.02            | 95            | 1   | 3.5  | 0.456 | 40.8            | 32.74              | 0.16          | 63               | 45.36              | 0.64             | 458.5            | 2.25               |
| 3      | Chokanad east (Puthukad) + East | 4372                            | 10.1            | 480.3           | 10.99           | 70            | 1   | 3.5  | 0.603 | 9.7             | 2.46               | 0.05          | 63               | 10.81              | 0.40             | 290.9            | 5.99               |
| 4      | Chokanad north (vattakad)       | 7482                            | 17.3            | 225.5           | 3.01            | 70            | 1   | 3.5  | 0.603 | 15.5            | 7.77               | 0.10          | 63               | 17.18              | 0.43             | 306.3            | 3.97               |
| 5      | Chokanad K Kai                  | 3763                            | 8.7             | 114.1           | 3.03            | 50            | 1   | 3.5  | 0.821 | 7.8             | 2.14               | 0.06          | 63               | 8.64               | 0.40             | 287.2            | 7.40               |
| 6      | Alisa craig                     | 2172                            | 5.0             | 48.1            | 2.22            | 70            | 1   | 3.5  | 0.603 | 4.5             | 0.64               | 0.03          | 63               | 4.94               | 0.39             | 282.9            | 12.74              |
| 7      | Ladbrock                        | 1566                            | 3.6             | 2.4             | 0.15            | 50            | 1   | 3.5  | 0.821 | 3.1             | 0.18               | 0.01          | 75               | 2.93               | 0.40             | 288.8            | 18.41              |
| 8      | Earlston                        | 1428                            | 3.3             | 3.5             | 0.25            | 70            | 1   | 3.5  | 0.603 | 2.9             | 0.16               | 0.01          | 20               | 10.04              | 0.20             | 147.3            | 10.29              |
| 9      | Forest                          | 778                             | 1.8             | 0.6             | 0.08            | 50            | 1   | 3.5  | 0.821 | 1.6             | 0.17               | 0.02          | 25               | 4.37               | 0.28             | 202.6            | 26.02              |
| 11     | Lockhart colony                 | 14269                           | 35.1            | 1856.3          | 13.01           | 50            | 1   | 3.5  | 0.821 | 32.3            | 37.07              | 0.23          | 315              | 7.27               | 0.92             | 660.2            | 4.08               |
| 13     | Gunderle manager bungalow       | 387                             | 0.9             | 0.6             | 0.15            | 50            | 1   | 3.5  | 0.821 | 0.8             | 0.03               | 0.01          | 63               | 0.90               | 0.39             | 280.9            | 72.40              |
| 14     | Gunderle factory divn           | 10042                           | 23.2            | 308.7           | 3.07            | 70            | 1   | 3.5  | 0.603 | 20.8            | 5.61               | 0.05          | 63               | 23.06              | 0.45             | 326.8            | 3.16               |
| 16     | BSNL (silent valley)            | 1319                            | 3.1             | 2.8             | 0.21            | 25            | 1   | 3.5  | 1.405 | 2.7             | 0.43               | 0.03          | 15               | 14.24              | 0.20             | 146.2            | 11.06              |
| 17     | Silent valley divn (North)      | 11143                           | 27.1            | 2771.0          | 24.87           | 95            | 1   | 3.5  | 0.456 | 27.9            | 15.33              | 0.11          | 63               | 31.34              | 0.51             | 365.6            | 2.62               |
| 18     | Silent valley office (South)    | 4028                            | 9.3             | 214.3           | 5.32            | 95            | 1   | 3.5  | 0.456 | 8.5             | 1.07               | 0.03          | 100              | 5.95               | 0.44             | 313.7            | 7.39               |

| Map no | Transformer                | LT OH line                      |                 |                 |                 | LT UG cable   |     |      |       |                 |                    |               | Transformer loss |                    |                  |                  |                    |
|--------|----------------------------|---------------------------------|-----------------|-----------------|-----------------|---------------|-----|------|-------|-----------------|--------------------|---------------|------------------|--------------------|------------------|------------------|--------------------|
|        |                            | Energy transmitted – LT OH line | Average current | LT OH line loss | LT OH line loss | Size of cable | Run | Core | R/ km | Average current | LT Cable line loss | LT Cable loss | Capacity of DT   | % of loading - Avg | Transformer loss | Transformer loss | Transformer loss % |
|        |                            | kWh/ Month                      | Amps            | kWh/ month      | %               | Sq mm         | nos | nos  | ohm   | Amps            | kWh/month          | %             | kVA              | %                  | kW               | kWh              | %                  |
| 19     | Gunderle lower (Nettigudi) | 4022                            | 9.3             | 286.7           | 7.13            | 50            | 1   | 3.5  | 0.821 | 8.6             | 1.32               | 0.03          | 63               | 9.60               | 0.40             | 288.8            | 6.70               |
| 20     | Gunderle center (middle)   | 5381                            | 13.1            | 775.4           | 14.41           | 70            | 1   | 3.5  | 0.603 | 12.3            | 4.96               | 0.08          | 63               | 14.00              | 0.41             | 297.7            | 4.83               |
| 21     | Gunderle top               | 4330                            | 10.0            | 377.6           | 8.72            | 70            | 1   | 3.5  | 0.603 | 9.4             | 2.90               | 0.06          | 63               | 10.49              | 0.40             | 290.3            | 6.16               |
| 22     | Devikulam middle           | 2628                            | 6.1             | 18.5            | 0.71            | 70            | 1   | 3.5  | 0.603 | 5.3             | 0.73               | 0.03          | 63               | 5.90               | 0.39             | 283.8            | 10.72              |
| 23     | Devikulam factory divsn    | 8723                            | 20.2            | 999.1           | 11.45           | 70            | 1   | 3.5  | 0.603 | 19.5            | 4.95               | 0.05          | 100              | 13.65              | 0.46             | 331.1            | 3.40               |
| 25     | Devikulam ODK              | 2935                            | 6.8             | 114.5           | 3.90            | 70            | 1   | 3.5  | 0.603 | 6.1             | 0.97               | 0.03          | 63               | 6.79               | 0.40             | 284.8            | 9.33               |
| 26     | Periyakanal PH divsn       | 3487                            | 8.1             | 189.1           | 5.42            | 70            | 1   | 3.5  | 0.603 | 7.4             | 0.71               | 0.02          | 63               | 8.19               | 0.40             | 286.6            | 7.79               |
| 27     | Ayur county                | 20514                           | 49.9            | 1795.4          | 8.75            | 300           | 3   | 3.5  | 0.13  | 44.7            | 33.70              | 0.15          | 400              | 7.92               | 1.12             | 807.8            | 3.62               |
| 28     | Periyakanal factory divsn  | 19969                           | 48.6            | 1779.7          | 8.91            | 120           | 1   | 3.5  | 0.36  | 43.6            | 14.78              | 0.07          | 100              | 30.53              | 0.58             | 417.0            | 1.92               |

## 4.1..4 Madupatty feeder

Table 48: LT cable, LT OH line &amp; Transformer loss – Madupatty feeder

| Map no | Transformer                                   | LT OH line         |                 |                 |                 | LT UG cable   |     |      |       |                 |                    |               | Transformer    |                    |                  |                  |                    |
|--------|---|--------------------|-----------------|-----------------|-----------------|---------------|-----|------|-------|-----------------|--------------------|---------------|----------------|--------------------|------------------|------------------|--------------------|
|        |   | Energy transmitted | Average current | LT OH line loss | LT OH line loss | Size of cable | Run | Core | R/km  | Average current | LT Cable line loss | LT Cable loss | Capacity of DT | % Of loading - Avg | Transformer loss | Transformer loss | Transformer loss % |
|        |   | kWh/ Month         | Amps            | kWh/ month      | %               | Sq mm         | nos | nos  | ohm   | Amps            | kWh/ month         | %             | kVA            | %                  | kW               | kWh/ month       | %                  |
| 1      | Westwood                                      | 2390               |                 |                 |                 | 70            | 1   | 3.5  | 0.603 | 5.528           | 0.52               | 0.0217        | 160            | 2.18               | 0.46             | 332              | 13.9               |
| 2      | Microwave                                     |                    |                 |                 |                 |               |     |      |       |                 |                    |               | 25             | 16.98              | 0.30             | 216              | 7.1                |
| 3      | Grahamsland office                            | 9214               | 21.3            | 2462            | 26.7            | 70            | 2   | 3.5  | 0.6   | 27.0            | 41.2               | 0.35          | 63             | 26.09              | 0.47             | 340              | 2.9                |
| 4      | Grahamsland bazaar                            | 191                | 0.4             | 1               | 0.5             | 70            | 1   | 3.5  | 0.6   | 0.4             | 0.0                | 0.01          | 5              | 5.60               | 0.03             | 18               | 9.4                |
| 5      | Grahamsland bungalows (Velmudi)               | 3718               | 14.9            | 656             | 17.6            | 50            | 2   | 3.5  | 0.8   | 10.1            | 3.9                | 0.09          | 63             | 9.85               | 0.40             | 289              | 6.6                |
| 6      | KKD church - korandikad                       | 14733              | 34.1            | 8743            | 59.3            | 95            | 1   | 3.5  | 0.5   | 54.3            | 62.9               | 0.27          | 63             | 54.63              | 0.75             | 539              | 2.3                |
| 7      | HR school                                     | 15090              | 45.4            | 620             | 4.1             | 150           | 2   | 3.5  | 0.3   | 36.3            | 32.8               | 0.21          | 150            | 15.34              | 0.51             | 365              | 2.3                |
| 8      | Madupatty top divsn                           | 4717               | 10.9            | 538             | 11.4            | 50            | 2   | 3.5  | 0.8   | 12.2            | 5.7                | 0.11          | 63             | 12.21              | 0.41             | 294              | 5.6                |
| 9      | R&D complex                                   | 3577               | 10.8            | 324             | 9.1             | 120           | 2   | 3.5  | 0.4   | 9.0             | 2.2                | 0.06          | 63             | 9.06               | 0.40             | 288              | 7.4                |
| 10     | Thenmalay Asst manager bungalow (Hospital dn) | 5221               | 15.7            | 891             | 17.1            | 50            | 2   | 3.5  | 0.8   | 14.1            | 7.7                | 0.13          | 63             | 14.05              | 0.41             | 298              | 4.9                |
| 11     | Tenmalay factory divsb                        | 8101               | 18.7            | 1533            | 18.9            | 95            | 2   | 3.5  | 0.5   | 22.3            | 10.6               | 0.11          | 100            | 13.40              | 0.46             | 330              | 3.4                |
| 12     | Tenmalay new divsn                            | 2240               | 5.2             | 104             | 4.6             | 70            | 1   | 3.5  | 0.6   | 5.4             | 1.7                | 0.07          | 25             | 13.16              | 0.29             | 210              | 9.0                |
| 15     | Madupatty divsn                               | 11081              | 25.6            | 3023            | 27.3            | 95            | 1   | 3.5  | 0.8   | 32.6            | 24.5               | 0.17          | 63             | 32.45              | 0.52             | 372              | 2.6                |
| 17     | Nettimadu divsn                               | 7096               | 16.4            | 1338            | 18.9            | 240           | 2   | 3.5  | 0.2   | 19.5            | 1.7                | 0.02          | 63             | 19.37              | 0.44             | 313              | 3.7                |

| Map no | Transformer                         | LT OH line         |                 |                 |                 | LT UG cable   |     |      |      |                 |                    |               | Transformer    |                    |                  |                  |                    |
|--------|-------------------------------------|--------------------|-----------------|-----------------|-----------------|---------------|-----|------|------|-----------------|--------------------|---------------|----------------|--------------------|------------------|------------------|--------------------|
|        |                                     | Energy transmitted | Average current | LT OH line loss | LT OH line loss | Size of cable | Run | Core | R/km | Average current | LT Cable line loss | LT Cable loss | Capacity of DT | % Of loading - Avg | Transformer loss | Transformer loss | Transformer loss % |
|        |                                     | kWh/ Month         | Amps            | kWh/ month      | %               | Sq mm         | nos | nos  | ohm  | Amps            | kWh/ month         | %             | kVA            | %                  | kW               | kWh/ month       | %                  |
| 21     | Gundumalay factory divsn            | 4498               | 10.4            | 685             | 15.2            | 95            | 2   | 3.5  | 0.5  | 12.0            | 3.7                | 0.07          | 100            | 7.20               | 0.44             | 316              | 6.1                |
| 22     | Gundumalay benmore                  | 2617               | 6.1             | 140             | 5.3             | 70            | 1   | 3.5  | 0.6  | 6.4             | 1.8                | 0.07          | 63             | 6.14               | 0.39             | 284              | 10.3               |
| 23     | Gundumalay south para               | 4294               | 9.9             | 400             | 9.3             | 50            | 2   | 3.5  | 0.8  | 9.4             | 3.4                | 0.07          | 63             | 10.90              | 0.40             | 291              | 6.2                |
| 24     | Gundumalay BSNL                     |                    |                 |                 |                 | 95            | 1   | 3.5  | 0.5  | 2.0             | 0.1                | 0.01          | 15             | 8.55               | 0.20             | 143              | 16.2               |
| 25     | Gundumalay new divsn                | 1739               | 4.0             | 122             | 7.0             | 70            | 1   | 3.5  | 0.6  | 4.3             | 0.3                | 0.02          | 25             | 10.44              | 0.29             | 207              | 11.1               |
| 26     | Gundumalay upper                    | 3324               | 7.7             | 285             | 8.6             | 70            | 1   | 3.5  | 0.6  | 8.3             | 1.2                | 0.03          | 63             | 8.38               | 0.40             | 287              | 7.9                |
| 27     | Gundumalay lower                    | 2441               | 5.6             | 119             | 4.9             | 70            | 1   | 3.5  | 0.6  | 5.9             | 1.0                | 0.04          | 63             | 5.94               | 0.39             | 284              | 11.1               |
| 28     | Gundumalay kadugu                   | 978                | 2.3             | 21              | 2.1             | 50            | 1   | 3.5  | 0.8  | 2.3             | 0.2                | 0.02          | 15             | 9.74               | 0.20             | 143              | 14.3               |
| 29     | New pump indo swiss (irrigation)    | 915                | 7.3             | 48              | 1.5             |               |     |      |      |                 |                    |               | 163            | 2.84               | 0.46             | 332              | 10.5               |
| 30     | Aruvikkad divsn                     | 9831               | 22.7            | 2803            | 28.5            | 95            | 1   | 3.5  | 0.5  | 29.2            | 18.2               | 0.14          | 100            | 18.50              | 0.48             | 349              | 2.8                |
| 32     | Ecopoint                            | 31                 | 0.1             | 0               | 0.1             | 50            | 2   | 3.5  | 0.8  | 0.1             | 0.0                | 0.00          | 63             | 0.07               | 0.39             | 281              | 912.4              |
| 33     | East divsn pachakkad                | 2877               | 6.7             | 224             | 7.8             | 70            | 1   | 3.5  | 0.6  | 7.2             | 1.4                | 0.05          | 63             | 7.20               | 0.40             | 285              | 9.2                |
| 34     | Kundalay naturals (medicinal plant) | 2660               | 6.2             | 11              | 0.4             | 50            | 2   | 3.5  | 0.8  | 6.2             | 1.5                | 0.05          | 150            | 2.61               | 0.46             | 332              | 12.4               |
| 35     | Pudukkadi                           | 2917               | 6.7             | 217             | 7.4             | 70            | 1   | 3.5  | 0.6  | 7.2             | 1.5                | 0.05          | 63             | 6.98               | 0.40             | 285              | 9.1                |
| 36     | Yelapatty divsn                     | 18671              | 43.2            | 15165           | 81.2            | 185           | 2   | 3.5  | 0.3  | 78.3            | 151.9              | 0.45          | 100            | 49.69              | 0.83             | 594              | 1.7                |

| Map no | Transformer                  | LT OH line         |                 |                 |                 | LT UG cable   |     |      |      |                 |                    |               | Transformer    |                    |                  |                  |                    |
|--------|------------------------------|--------------------|-----------------|-----------------|-----------------|---------------|-----|------|------|-----------------|--------------------|---------------|----------------|--------------------|------------------|------------------|--------------------|
|        |                              | Energy transmitted | Average current | LT OH line loss | LT OH line loss | Size of cable | Run | Core | R/km | Average current | LT Cable line loss | LT Cable loss | Capacity of DT | % Of loading - Avg | Transformer loss | Transformer loss | Transformer loss % |
|        |                              | kWh/ Month         | Amps            | kWh/ month      | %               | Sq mm         | nos | nos  | ohm  | Amps            | kWh/ month         | %             | kVA            | %                  | kW               | kWh/ month       | %                  |
| 38     | Kundalay office              | 5054               | 11.7            | 654             | 12.9            | 120           | 1   | 3.5  | 0.4  | 13.2            | 1.2                | 0.02          | 63             | 12.71              | 0.41             | 295              | 5.2                |
| 39     | Theerthamalay                | 2088               | 4.8             | 39              | 1.9             | 50            | 2   | 3.5  | 0.8  | 4.9             | 0.9                | 0.04          | 75             | 3.98               | 0.39             | 282              | 13.3               |
| 41     | Old factory                  | 7490               | 17.3            | 1627            | 21.7            | 70            | 2   | 3.5  | 0.6  | 21.1            | 20.0               | 0.22          | 63             | 20.35              | 0.44             | 317              | 3.5                |
| 42     | PR divsn                     | 2069               | 4.8             | 59              | 2.9             | 70            | 1   | 3.5  | 0.6  | 4.9             | 1.1                | 0.05          | 63             | 4.74               | 0.39             | 283              | 13.3               |
| 43     | Top divsn                    | 3967               | 9.2             | 342             | 8.6             | 70            | 1   | 3.5  | 0.6  | 10.0            | 2.8                | 0.06          | 63             | 9.60               | 0.40             | 289              | 6.7                |
| 44     | Kundalay club                | 10                 | 0.0             | 0               | 0.0             | 35            | 1   | 3.5  | 1.1  | 0.0             | 0.0                | 0.00          | 5              | 0.30               | 0.10             | 72               | 738.4              |
| 45     | Chittivurrai pump (MC divsn) | 2316               | 5.4             | 9               | 0.4             | 50            | 2   | 3.5  | 0.8  | 5.4             | 1.1                | 0.05          | 63             | 5.18               | 0.39             | 283              | 12.2               |
| 47     | Chittivurrai factory divsn   | 9866               | 22.8            | 3450            | 35.0            | 70            | 1   | 3.5  | 0.6  | 30.8            | 10.7               | 0.08          | 100            | 18.89              | 0.49             | 351              | 2.6                |
| 48     | New Pump (Chittivurrai new)  | 1094               | 2.5             | 3               | 0.3             | 70            | 1   | 3.5  | 0.6  | 2.5             | 0.1                | 0.01          | 100            | 1.69               | 0.43             | 310              | 28.3               |
| 49     | Chittivurrai OC divsn        | 4676               | 10.8            | 564             | 12.1            | 70            | 1   | 3.5  | 0.6  | 12.1            | 4.1                | 0.08          | 63             | 11.80              | 0.41             | 293              | 5.6                |

## 4.1..5 Town feeder

Table 49: LT UG cable, LT OH line &amp; Transformer loss – Town feeder

| Map no | Transformer name           | LT OH line         |                 |                 |                 | LT UG cable   |     |      |      |                 |                    |               | Transformer    |                    |                  |                  |                    |
|--------|----------------------------|--------------------|-----------------|-----------------|-----------------|---------------|-----|------|------|-----------------|--------------------|---------------|----------------|--------------------|------------------|------------------|--------------------|
|        |                            | Energy transmitted | Average current | LT OH line loss | LT OH line loss | Size of cable | Run | Core | R/km | Average current | LT Cable line loss | LT Cable loss | Capacity of DT | % of loading - Avg | Transformer loss | Transformer loss | Transformer loss % |
|        |                            | kWh/Month          | Amps            | kWh/month       | %               | Sq mm         | nos | nos  | ohm  | Amps            | kWh/month          | %             | kVA            | %                  | Watts            | kWh/month        | %                  |
| 1      | Old munnar tea tasting     | 15984              | 32.04           | 3091.70         | 19.34           | 185           | 2   | 3.5  | 0.21 | 44.12           | 92.3               | 0.48          | 150            | 18.68              | 0.53             | 381.5            | 1.99               |
| 3      | High range club            | 5188               | 10.40           | 191.86          | 3.70            | 95            | 3   | 3.5  | 0.45 | 12.44           | 19.6               | 0.36          | 63             | 12.53              | 0.41             | 294.4            | 5.45               |
| 5      | Poopada                    | 24397              | 48.91           | 7058.57         | 28.93           | 95            | 3   | 3.5  | 0.46 | 72.76           | 813.5              | 2.59          | 150            | 31.45              | 0.66             | 473.6            | 1.47               |
| 7      | Workshop club              | 19131              | 38.35           | 4340.25         | 22.69           | 70            | 3   | 3.5  | 0.60 | 54.29           | 993.2              | 4.23          | 100            | 35.77              | 0.63             | 457.0            | 1.87               |
| 9      | Workshop                   | 40651              | 81.49           | 8998.93         | 22.14           | 70            | 3   | 3.5  | 0.60 | 114.85          | 4444.6             | 8.95          | 300            | 26.36              | 1.12             | 808.1            | 1.49               |
| 10     | Shikshak sadan             | 24484              | 49.08           | 7109.05         | 29.04           | 120           | 1   | 3.5  | 0.36 | 73.08           | 539.9              | 1.71          | 250            | 18.79              | 0.76             | 549.8            | 1.71               |
| 11     | RO                         | 14231              | 28.53           | 1911.51         | 13.43           | 95            | 3   | 3.5  | 0.46 | 37.34           | 623.4              | 3.86          | 150            | 16.34              | 0.51             | 369.7            | 2.20               |
| 13     | Grahamslan d pump - petrol |                    |                 |                 |                 | 95            | 1   | 3.5  | 0.46 | 4.02            | 4.0                | 0.23          | 63             | 4.04               | 0.39             | 282.2            | 16.22              |
| 14     | Teacher's quarters         | 44871              | 89.95           | 16568.11        | 36.92           | 185           | 2   | 3.5  | 0.21 | 142.12          | 1104.6             | 1.80          | 200            | 45.72              | 0.99             | 713.7            | 1.14               |
| 15     | KWA pump                   |                    |                 |                 |                 | 95            | 1   | 3.5  | 0.46 | 32.17           | 61.1               | 0.44          | 100            | 20.42              | 0.50             | 357.6            | 2.56               |
| 16     | Botanical garden           |                    |                 |                 |                 | 95            | 1   | 3.5  | 0.46 | 6.09            | 0.4                | 0.01          | 63             | 6.11               | 0.39             | 284.0            | 10.79              |
| 17     | Eastend                    | 30714              | 61.57           | 6392.95         | 20.81           | 95            | 1   | 3.5  | 0.45 | 85.84           | 358.1              | 0.96          | 100            | 54.77              | 0.91             | 655.2            | 1.75               |
| 18     | BSNL                       |                    |                 |                 |                 | 120           | 1   | 3.5  | 0.36 | 64.92           | 393.2              | 1.40          | 200            | 20.80              | 0.60             | 433.2            | 1.52               |
| 19     | Town                       | 88366              | 177.15          | 32749.60        | 37.06           | 95            | 1   | 3.5  | 0.45 | 75.76           | 278.9              | 0.85          | 300            | 16.10              | 0.98             | 707.7            | 2.14               |
| A1     | Residency                  | 21888              | 43.88           | 5681.82         | 25.96           | 70            | 1   | 3.5  | 0.60 | 63.77           | 263.6              | 0.96          | 63             | 64.59              | 0.89             | 641.3            | 2.30               |

| Map no | Transformer name       | LT OH line         |                 |                 |                 | LT UG cable   |     |      |      |                 |                    |               | Transformer    |                    |                  |                  |                    |
|--------|------------------------|--------------------|-----------------|-----------------|-----------------|---------------|-----|------|------|-----------------|--------------------|---------------|----------------|--------------------|------------------|------------------|--------------------|
|        |                        | Energy transmitted | Average current | LT OH line loss | LT OH line loss | Size of cable | Run | Core | R/km | Average current | LT Cable line loss | LT Cable loss | Capacity of DT | % of loading - Avg | Transformer loss | Transformer loss | Transformer loss % |
|        |                        | kWh/Month          | Amps            | kWh/month       | %               | Sq mm         | nos | nos  | ohm  | Amps            | kWh/month          | %             | kVA            | %                  | Watts            | kWh/month        | %                  |
| 20     | Nirmala society - NUSD | 25035              | 50.19           | 3413.06         | 13.63           | 70            | 5   | 3.5  | 0.60 | 65.81           | 1222.0             | 4.30          | 150            | 28.92              | 0.63             | 451.6            | 1.52               |
| 21     | GH                     | 5933               | 11.90           | 110.77          | 1.87            | 70            | 5   | 3.5  | 0.60 | 13.98           | 55.2               | 0.91          | 250            | 19.92              | 0.78             | 558.1            | 1.64               |
| 22     | KSEB                   | 40568              | 81.33           | 5178.17         | 12.76           | 185           | 2   | 3.5  | 0.21 | 105.82          | 306.2              | 0.67          | 200            | 33.66              | 0.77             | 551.7            | 1.20               |

#### 4.1.6 Pullivasal feeder

Table 50: LT UG cable, LT OH line & Transformer loss – Pullivasal feeder

| Map no | Transformer           | LT OH line         |                 |                 |                 | LT UG cable   |     |      |      |                 |                    |               | Transformer    |                    |                  |                  |                    |
|--------|-----------------------|--------------------|-----------------|-----------------|-----------------|---------------|-----|------|------|-----------------|--------------------|---------------|----------------|--------------------|------------------|------------------|--------------------|
|        |                       | Energy transmitted | Average current | LT OH line loss | LT OH line loss | Size of cable | Run | Core | R/km | Average current | LT Cable line loss | LT Cable loss | Capacity of DT | % of loading - Avg | Transformer loss | Transformer loss | Transformer loss % |
|        |                       | kWh/Month          | Amps            | kWh/month       | %               | Sq mm         | nos | nos  | ohm  | Amps            | kWh/month          | %             | kVA            | %                  | Watts            | kWh/month        | %                  |
| 2      | Attukad               | 26919              | 54              | 3069            | 11              | 70            | 2   | 3.50 | 0.60 | 60.12           | 235.37             | 0.78          | 100            | 44.19              | 0.74             | 535              | 1.77               |
| 7      | Allakovil transformer | 36853              | 74              | 5259            | 14              | 70            | 2   | 3.50 | 0.60 | 84.43           | 464.18             | 1.10          | 160            | 38.90              | 0.76             | 549              | 1.29               |

### ***LOSSES DUE TO CIRCUIT INTERRUPTING DEVICES***

Circuit-interrupting devices are switches, relays, circuit breakers, and fuses. Each of these devices is designed to carry and interrupt certain levels of current. Making and breaking the current carrying conductors in the transmission path with a minimum of arcing is one of the most important characteristics of this device. Relays can sense abnormal voltages, currents, and frequency and are designed to protect the system.

Generally, the losses due to the above account between 0.1% - 0.2% of the load. However, in the case of KDHP, this loss may be assumed as 0.2% (max value), considering the size and complexity of the network.

### ***TECHNICAL LOSSES - SUMMARY***

The technical losses comprising all the section above is estimated in feeder wise and given in the following tables.

#### ➤ **Pullivasal feeder**

Table 51: T & D loss – Pullivasal feeder

| Particulars                             | Calculation          | Values            |               | Remarks   |
|---|----------------------|-------------------|---------------|---|
| Energy Transmitted                      | A                    | 32,09,760 kWh     |               | Measured at the Switching station – from KDHP Tsoft |
| HT Cable Losses                         | B                    | 51 kWh            | 0.0016 %      | Calculated with line length                         |
| HT Overhead line losses                 | C                    | 31,584 kWh        | 0.98 %        | Calculated with line length                         |
| Transformer Losses                      | D                    | 13,004 kWh        | 0.41 %        | Estimated with rated load loss values               |
| LT Overhead line losses                 | E                    | 99,942 kWh        | 3.11 %        | Calculated with line length                         |
| LT Cable losses                         | F                    | 8,395 kWh         | 0.26 %        | Calculated with line length                         |
| Loss due to Fuses, Busway & switchgears | G                    | 6,420 kWh         | 0.20 %        | Estimated as per standard                           |
| <b>Total T&amp;D losses</b>             | <b>H = Sum (B:G)</b> | <b>159394 kWh</b> | <b>4.97 %</b> |   |
| Available Power for sales               | I = A - H            | 30,50,366 kWh     |               |   |
| Actual power sales                      | J                    | 30,43,806 kWh     |               | From KDHP Tsoft                                     |
| Total Commercial and other losses       | K = I - J            | 6560 kWh          | 0.20 %        |   |
| <b>Estimated Total loss</b>             | <b>L = K + H</b>     | <b>165954 kWh</b> | <b>5.17 %</b> |   |

#### ➤ **ITD feeder\***

Table 52: T & D loss – ITD feeder

| Particulars             | Calculation | Values        |          | Remarks   |
|-------------------------|-------------|---------------|----------|---|
| Energy Transmitted      | A           | 98,80,776 kWh |          | Measured at the Switching station – from KDHP Tsoft |
| HT Cable Losses         | B           | 612 kWh       | 0.0062 % | Calculated with line length                         |
| HT Overhead line losses | C           | 83,763 kWh    | 0.85 %   | Calculated with line length                         |



|                                   |                      |                   |               |                                       |
|-----------------------------------|----------------------|-------------------|---------------|---------------------------------------|
| Transformer Losses                | D                    | 77,404 kWh        | 0.78 %        | Estimated with rated load loss values |
| LT Overhead line losses           | E                    | 4,45,261 kWh      | 4.51 %        | Calculated with line length           |
| LT Cable losses                   | F                    | 3,389 kWh         | 0.03 %        | Calculated with line length           |
| Loss due to Fuses & switchgears   | G                    | 19,762 kWh        | 0.20 %        | Estimated as per standard             |
| <b>Total T&amp;D losses</b>       | <b>H = Sum (B:G)</b> | <b>630191 kWh</b> | <b>6.38 %</b> |                                       |
| Available Power for sales         | I = A - H            | 9250585 kWh       |               |                                       |
| Actual power sales                | J                    | 9383866 kWh       |               | From KDHP Tsoft                       |
| Total Commercial and other losses | K = I - J            | -133281 kWh       | -1.35 %       |                                       |
| <b>Estimated total loss</b>       | <b>L = K + H</b>     | <b>496910 kWh</b> | <b>5.03 %</b> |                                       |

\*Observed difference in available power for sales and actual power sales even though the losses are similar in the feeder. This could be due to error in the consumer meter which reads higher consumption than the actual.

➤ **Town feeder\***

Table 53: T & D loss – Town feeder

| Particulars                       | Calculation          | Values             |                | Remarks   |
|-----------------------------------|----------------------|--------------------|----------------|---|
| Energy Transmitted                | A                    | 9946400 kWh        |                | Measured at the Switching station – from KDHP Tsoft |
| HT Cable Losses                   | B                    | 384 kWh            | 0.0039 %       | Calculated with line length                         |
| HT Overhead line losses           | C                    | 45,340 kWh         | 0.4558 %       | Calculated with line length                         |
| Transformer Losses                | D                    | 1,11,057 kWh       | 1.1166 %       | Estimated with rated load loss values               |
| LT Overhead line losses           | E                    | 12,33,556 kWh      | 12.4020 %      | Calculated with line length                         |
| LT Cable losses                   | F                    | 1,38,943 kWh       | 1.3969 %       | Calculated with line length                         |
| Loss due to Fuses & switchgears   | G                    | 19,893 kWh         | 0.20 %         | Estimated as per standard                           |
| <b>Total T&amp;D losses</b>       | <b>H = Sum (B:G)</b> | <b>1549173 kWh</b> | <b>15.58 %</b> |   |
| Available Power for sales         | I = A - H            | 8397227 kWh        |                |   |
| Actual power sales                | J                    | 8656207 kWh        |                | From KDHP Tsoft                                     |
| Total Commercial and other losses | K = I - J            | -258980 kWh        | -2.60 %        |   |
| <b>Estimated total loss</b>       | <b>L = K + H</b>     | <b>1290193 kWh</b> | <b>12.97 %</b> |   |

\*observed difference in available power for sales and actual power sales even though the losses are similar in the feeder. This could be due to error in the consumer meter which reads higher consumption than the actual.

➤ **Nettigudi feeder**

Table 54: T & D loss – Nettigudi feeder

| Particulars        | Calculation | Values          |        | Remarks   |
|--------------------|-------------|-----------------|--------|---|
| Energy Transmitted | A           | 1,05,78,900 kWh |        | Measured at the Switching station – from KDHP Tsoft |
| HT Cable Losses    | B           | 695 kWh         | 0.01 % | Calculated with line length                         |

|  |                      |                     |               |                                       |
|--|----------------------|---------------------|---------------|---------------------------------------|
| HT Overhead line losses                  | C                    | 440335 kWh          | 4.16 %        | Calculated with line length           |
| Transformer Losses                       | D                    | 91749 kWh           | 0.87 %        | Estimated with rated load loss values |
| LT Overhead line losses                  | E                    | 168552 kWh          | 1.59 %        | Calculated with line length           |
| LT Cable losses                          | F                    | 2050 kWh            | 0.02 %        | Calculated with line length           |
| Loss due to Fuses & switchgears          | G                    | 21158 kWh           | 0.20 %        | Estimated as per standard             |
| <b>Total T&amp;D losses</b>              | <b>H = Sum (B:G)</b> | <b>724538 kWh</b>   | <b>6.85 %</b> |                                       |
| Available Power for sales                | I = A - H            | 98,54,362 kWh       |               |                                       |
| Actual power sales                       | J                    | 98,45,691 kWh       |               | From KDHP Tsoft                       |
| <b>Total Commercial and other losses</b> | <b>K = I - J</b>     | 8,671 kWh           | <b>0.08%</b>  |                                       |
| <b>Estimated total loss</b>              | <b>L = K + H</b>     | <b>7,33,209 kWh</b> | <b>6.93%</b>  |                                       |

➤ **Nyamakad feeder**

Table 55: T & D loss – Nyamakad feeder

| Particulars                       | Calculation          | Values               |               | Remarks   |
|-----------------------------------|----------------------|----------------------|---------------|---|
| Energy Transmitted                | A                    | 1,11,24,064 kWh      |               | Measured at the Switching station – from KDHP Tsoft |
| HT Cable Losses                   | B                    | 749 kWh              | 0.0067 %      | Calculated with line length                         |
| HT Overhead line losses           | C                    | 1,16,501 kWh         | 1.0473 %      | Calculated with line length                         |
| Transformer Losses                | D                    | 1,24,894 kWh         | 1.1227 %      | Estimated with rated load loss values               |
| LT Overhead line losses           | E                    | 2,03,449 kWh         | 1.8289 %      | Calculated with line length                         |
| LT Cable losses                   | F                    | 1,678 kWh            | 0.0151 %      | Calculated with line length                         |
| Loss due to Fuses & switchgears   | G                    | 22,248 kWh           | 0.20 %        | Estimated as per standard                           |
| <b>Total T&amp;D losses</b>       | <b>H = Sum (B:G)</b> | <b>4,69,518 kWh</b>  | <b>4.22%</b>  |   |
| Available Power for sales         | I = A - H            | 1,06,54,546 kWh      |               |   |
| Actual power sales                | J                    | 99,92,597 kWh        |               | From KDHP Tsoft                                     |
| Total Commercial and other losses | K = I - J            | 6,61,949 kWh         | 5.95 %        |   |
| <b>Estimated total loss</b>       | <b>L = K + H</b>     | <b>11,31,467 kWh</b> | <b>10.17%</b> |   |

➤ **Madupatty feeder**

Table 56: T & D loss – Madupatty feeder

| Particulars        | Calculation | Values          |          | Remarks  |
|--------------------|-------------|-----------------|----------|--|
| Energy Transmitted | A           | 1,49,80,826 kWh |          | Combined value of Switching station & 2MW Madupatty generating station – from KDHP Tsoft |
| HT Cable Losses    | B           | 1,227 kWh       | 0.0082 % | Calculated with line length  |

|                                   |                      |                      |               |                                       |
|-----------------------------------|----------------------|----------------------|---------------|---------------------------------------|
| HT Overhead line losses           | C                    | 2,37,886 kWh         | 1.5879 %      | Calculated with line length           |
| Transformer Losses                | D                    | 1,36,680 kWh         | 0.9124 %      | Estimated with rated load loss values |
| LT Overhead line losses           | E                    | 5,66,622 kWh         | 3.7823 %      | Calculated with line length           |
| LT Cable losses                   | F                    | 5,082 kWh            | 0.0339 %      | Calculated with line length           |
| Loss due to Fuses & switchgears   | G                    | 29,962 kWh           | 0.20 %        | Estimated as per standard             |
| <b>Total T&amp;D losses</b>       | <b>H = Sum (B:G)</b> | <b>9,77,460 kWh</b>  | <b>6.52 %</b> |                                       |
| Available Power for sales         | I = A - H            | 1,40,03,366 kWh      |               |                                       |
| Actual power sales                | J                    | 1,28,98,457 kWh      |               | From KDHP Tsoft                       |
| Total Commercial and other losses | K = I - J            | 11,04,909 kWh        | 7.38 %        |                                       |
| <b>Estimated total loss</b>       | <b>L = K + H</b>     | <b>20,82,369 kWh</b> | <b>13.90%</b> |                                       |

➤ **Summarisation of all feeders**

Table 57: T & D loss – Summarised – feeder wise

| Feeder       | Energy transmitted | T & D loss       | Commercial and other losses | Energy sales       | T&D loss    | Total loss  |
|--------------|--------------------|------------------|-----------------------------|--------------------|-------------|-------------|
|              | kWh                | kWh              | kWh                         | kWh                | %           | %           |
| Pullivasal   | 32,09,760          | 1,59,394         | 6,560                       | 30,43,806          | 4.97        | 5.17        |
| ITD          | 98,80,776          | 659445.7         | 0                           | 93,83,866          | 6.67        | 5.03        |
| Town         | 99,46,400          | 1549173          | 0                           | 86,56,207          | 15.58       | 12.97       |
| Nettigudi    | 1,05,78,900        | 7,24,538         | 8,671                       | 98,45,691          | 6.85        | 6.93        |
| Nyamakad     | 1,11,24,064        | 4,69,518         | 6,61,949                    | 99,92,597          | 4.22        | 10.17       |
| Madupatty    | 1,49,80,826        | 9,77,460         | 11,04,909                   | 1,28,98,457        | 6.52        | 13.90       |
| <b>Total</b> | <b>5,97,20,726</b> | <b>45,39,529</b> | <b>17,82,089</b>            | <b>5,38,20,624</b> | <b>7.60</b> | <b>9.88</b> |

- **All the above calculations are considering the transmitted feedback energy (Energy sold outside the periphery) through the KDHP distribution system.**
- **Total loss = T & D loss + Commercial loss**
- **Therefore, Commercial loss = 2.984% which can be accounted to the following ones:**
  - 1. Error in the meter reading**
  - 2. Manual error in reading**
  - 3. Interruption losses, and**
  - 4. Tree touching losses in the HT/LT overhead cables.**
- **During energy audit period, auditors attempted to verify the error in the meters by analysing the HT meter reading of few consumers and feeder meters at the switching station using the power quality analysers and hereby summarised in commercial losses section.**

#### **4. HT/LT RATIO**

The total length of the LT line from the transformer to the consumer end at the period of audit is 193.8 km. In that, the OH cable were 189.3 km and the UG cable were 4.5 km long.

The total 11kV HT line length from the switching station to the DT or HT consumers are 180.23 km, where the installed ones are ACSR and Copper cables of various sizes.

HT/LT ratio is the total distance of HT line to the LT lines in a system. The HT/LT ratio has calculated with respect to the total LT line where;

HT:LT = 1: 1.075, which approximately equal to the recommended level of 1:1.

Considering the terrain of KDHP the value is optimum. KDHP also were in continuous process replacing the LT lines with new HT lines and installation transformers at tail ends with the increase in population or divisions.

## 5. SUBSIDY COMPUTATION AND ANALYSIS

The DISCOM did not received subsidy from any government or government institutions on any category during the FY 2022-23.

## 6. TREND ANALYSIS

The historical energy accounts/loss of the KDHP DISCOM is tabulated below.

Table 58: Historical energy accounts/loss of the DISCOM

| Particulars          | 1. T&D Losses analysis for 2020-21 |                          |                        |              | 2. T&D Losses analysis for 2021-22 |                          |                        |              |
|----------------------|------------------------------------|--------------------------|------------------------|--------------|------------------------------------|--------------------------|------------------------|--------------|
|                      | Input energy (MU)                  | Total Billed energy (MU) | Total energy Loss (MU) | T&D losses % | Input energy (MU)                  | Total Billed energy (MU) | Total energy Loss (MU) | T&D losses % |
| <b>DISCOM - KDHP</b> | 57.26                              | 50.97                    | 6.29                   | <b>10.98</b> | 53.07                              | 48.05                    | 5.02                   | <b>9.45</b>  |

The graphical representation of the losses for the three years (including audit period FY 2022-23) is given in the figure below.




Figure 12: Historical T & D loss with audited data

- The T&D loss % shows a constant decrease from the FY 2020-21 to FY 2022-23 even though the input energy to the DISCOM is higher in the audited FY.
- While analyzing the consumption, transmission & sale pattern of energy, observed that the decrease in the loss mainly due to the reduction in the short circuits by proper tree pruning, by replacing the consumer meters if it's damaged in record time and by replacing the electromechanical/static meter with the electronic meter. The KSEB feedback at 11kV is observed to be directly proportional to the T&D loss % and the Madupatty generation units is inversely proportional to the T&D loss %.

## ENERGY AUDIT FINDINGS

### 1 COMPLIANCE TO BEE REGULATIONS

The compliance status of DISCOM to various provisions of BEE Regulations 2021 is analysed and presented below.

| Clause No | Clause Details  | Subclause Details   | Present Status   | Action plan/ comments by DISCOM                   |
|-----------|---|---|--|---|
| 3         | Intervals of time for conduct of annual energy audit        | a. Conducted an annual energy audit for every financial year and submitted the annual energy audit report to the Bureau and respective State Designated Agency and also made available on the website of the electricity distribution company within a period of four months from the expiry of the relevant financial year | a. Annual energy audit for all the FY including FY 2022-23 being conducted. Report will be submitted to BEE and SDA. Report will also be uploaded onto KDHP website. | Reports will be uploaded to the DISCOM site asap. |
| 4         | Intervals of time for conduct of periodic energy accounting | a. All feeder wise, circle wise and division wise periodic energy accounting is conducted by the energy manager of the electricity distribution company for each quarter of the financial year.   | a. Periodic energy accounting for Q1 & Q2 FY 20-21 have been prepared by the DC.   |   |
|           |   | b. Submitted the periodic energy accounting report to the Bureau and respective State Designated Agency and also made available on the website of electricity distribution company within forty-five days from the date of the periodic energy accounting.  | b. Periodic energy accounting for Q1 & Q2 FY 20-21 have been prepared by the DC. DC has to upload the energy accounting reports onto the website of DC               |   |
|           |   | c. Electricity distribution company conducted its first periodic energy accounting, for the last quarter of the financial year immediately preceding the date of such commencement (i.e. 6th October 2021).   | c. DC has submitted its first periodic energy accounting for Q1 & Q2 FY20-21.  |   |
|           |   | d. Electricity distribution company conducted its subsequent periodic energy accounting for each quarter of the financial year for a period of two  | d. The DC used to submit the periodic energy auditing  |   |

|                  |   |  |  |   |
|------------------|---|--|--|---|
|                  |   | financial years from the date of such commencement, and submit the periodic energy accounting report within sixty days from the date of periodic energy accounting   | reports as per the Energy Audit regulations.   |   |
| <b>Clause No</b> | <b>Clause Details</b>   | <b>Subclause Details</b>   | <b>Present Status</b>  | <b>Action plan/ comments by DISCOM</b>                        |
| 5                | Pre-requisites for annual energy audit and periodic energy accounting | a. Identification and mapping of all of the electrical network assets  | a. Mapping of HT line and transformers conducted by the AEA and LT lines are mapped by the DISCOM.   |   |
|                  |   | b. Identification and mapping of high tension and low-tension consumers  | b. All the HT and LT consumers have been mapped.   |   |
|                  |   | c. Development and implementation of information technology enabled energy accounting and audit system, including associated software.   | c. DC has energy accounting and audit system however yet to implement into their software. DC uses T-Soft which is an internal software for the same.  | The existing software will be modified to implement the same. |
|                  |   | d. Electricity distribution company ensures the installation of functional meters for all consumers, transformers and feeders. Meter installation is done in a phased manner within a period of three financial years from the date of the commencement of these regulations in accordance with the trajectory set out in the First Schedule | d. All 11kV feeders have been metered. All consumers have been metered under the DISCOM. As of audit period (31 <sup>st</sup> July 2023) of the total 133 distribution transformers, 63 distribution transformers have been metered. | Rest of the DT meters will be installed in time bound manner. |
|                  |   | d1. 100% Communicable Feeder Metering integrated with AMI, by 31st December 2022 along with replacement of existing non- communicable feeder meters.   | d.1. 100% of the feeders are having DLMS (Device Language Message Specification Communicable Meters).  |   |
|                  |   | d2. All Distribution Transformers (other than HVDS DT up to 25kVA and other DTs below 25 kVA) shall be metered with communicable meters.   | d.2. DISCOM yet to start the work to install communicable meters for rest of the DT.   | Plans to do the work in phased manner                         |

|                  |                       |   |  |  |
|------------------|-----------------------|---|--|--|
|                  |                       | Communicable DT Metering for the following areas/ consumers to be completed by December 2023 and in balance areas by December 2025: 100% Communicable Feeder Metering integrated with AMI, by 31st December 2022 along with replacement of existing non-communicable feeder meters. | Feeder metering is integrated and results are available in their software.   |  |
| <b>Clause No</b> | <b>Clause Details</b> | <b>Subclause Details</b>  | <b>Present Status</b>  | <b>Action plan/ comments by DISCOM</b>                   |
|                  |                       | d.2.1. All Electricity Divisions of 500 AMRUT cities, with AT&C Losses > 15%  | d.2.1. Not Relevant for DC.  |  |
|                  |                       | d.2.2. All Union Territories (for areas with technical difficulty, non-communicable meters may be installed)  | d.2.2. Not Relevant for DC   |  |
|                  |                       | d.2.3. All Industrial and Commercial consumers  | d.2.3. DC has installed 36 communicable metering-AMI (HT consumers) and 16547 meters with non-communicable ones (LT, industrial and commercial). | Plans to do the remaining installations in phased manner |
|                  |                       | d.2.4. All Government offices at Block level and above  | D2.4. DC intends to install, communicable meters with AMI for Government offices.  | Plans to do the work in phased manner                    |
|                  |                       | d.2.5. Other high loss areas i.e. rural areas with losses more than 25% and urban areas with losses more than 15%   | d.2.5. The whole DISCOM comes under the Rural area and thus not relevant for DC.   |  |
|                  |                       | d.3. Prepaid Smart Consumer Metering to be completed for all directly connected meters and AMR in case of other meters, by December 2023 in the following areas:  |  |  |
|                  |                       | d.3.1. All Electricity Divisions of 500 AMRUT cities, with AT&C Losses > 15%;   | d.3.1. Not applicable as AT&C loss is less than 15%.   |  |



| Clause No       | Clause Details | Subclause Details   | Present Status  | Action plan/ comments by DISCOM                               |          |         |                 |       |       |       |             |     |     |     |  |  |
|-----------------|----------------|---|---|---|----------|---------|-----------------|-------|-------|-------|-------------|-----|-----|-----|--|--|
|                 |                | d.3.2. All Union Territories (for areas with technical difficulty, prepaid meters to be installed);   | d.3.2. Not Relevant for DC.   |   |          |         |                 |       |       |       |             |     |     |     |  |  |
|                 |                | d.3.3. All Industrial and Commercial consumers;   | d.3.3. DC intends to install consumer meters with AMI for commercial and industrial consumers.  | Plans to do the work in phased manner                         |          |         |                 |       |       |       |             |     |     |     |  |  |
|                 |                | d.3.4. All Government offices at Block level and above;   | d.3.4. yet to initiate the work   | Plans to do the work in phased manner                         |          |         |                 |       |       |       |             |     |     |     |  |  |
|                 |                | d.3.5. Other high loss areas i.e. rural areas with losses more than 25% and urban areas with losses more than 15%.  | d.3.5. Not applicable as T&D loss is less than 15%  |   |          |         |                 |       |       |       |             |     |     |     |  |  |
|                 |                | d4. Consumer Metering: 98% by FY 2022-23 99% by FY 2023-24  | d4. 100% of the consumers are metered.  |   |          |         |                 |       |       |       |             |     |     |     |  |  |
|                 |                | d.5. Targets for functional meters.<br><table border="1"> <thead> <tr> <th>Meter</th> <th>FY 22-23</th> <th>FY 23-24</th> <th>FY24-25</th> </tr> </thead> <tbody> <tr> <td>Feeder metering</td> <td>98.5%</td> <td>99.5%</td> <td>99.5%</td> </tr> <tr> <td>DT metering</td> <td>90%</td> <td>95%</td> <td>98%</td> </tr> </tbody> </table> | Meter   | FY 22-23  | FY 23-24 | FY24-25 | Feeder metering | 98.5% | 99.5% | 99.5% | DT metering | 90% | 95% | 98% | d5. 100% of the feeders are metered. 47% of the DT are metered. 100% of the consumers are metered. | DT metering will start in phased manner. |
| Meter           | FY 22-23       | FY 23-24  | FY24-25   |   |          |         |                 |       |       |       |             |     |     |     |  |  |
| Feeder metering | 98.5%          | 99.5%   | 99.5%   |   |          |         |                 |       |       |       |             |     |     |     |  |  |
| DT metering     | 90%            | 95%   | 98%   |   |          |         |                 |       |       |       |             |     |     |     |  |  |
|                 |                | e. e1. All distribution transformers (other than high voltage distribution system up to 25kVA and other distribution system below 25 kVA) is metered with communicable meters.  | e.1. DC yet to start the work   | DT metering will start in phased manner.                      |          |         |                 |       |       |       |             |     |     |     |  |  |
|                 |                | e.2. And existing non-communicable distribution transformer meters is replaced with communicable meters and integrated with advanced metering infrastructure.   | e.2. Yet to start the work  | DT metering will start in phased manner.                      |          |         |                 |       |       |       |             |     |     |     |  |  |
|                 |                | e. Electricity distribution company has established an information technology enabled system to create energy accounting reports without any manual interference and such systems may be within a period of three years from the date of the  | f. DC has energy accounting and audit system however yet to implement into their software. DC uses T-Soft which is an internal software for the same. | The existing software will be modified to implement the same. |          |         |                 |       |       |       |             |     |     |     |  |  |

|                  |   |  |   |  |
|------------------|---|--|---|--|
|                  |   | commencement of these regulations in case of urban and priority area consumers; and within five years from the date of the commencement of these regulations in case of rural consumers  |   |  |
| <b>Clause No</b> | <b>Clause Details</b>   | <b>Subclause Details</b>   | <b>Present Status</b>   | <b>Action plan/ comments by DISCOM</b> |
|                  |   | g. Electricity distribution company has a centralized energy accounting and audit cell comprising of—<br>(i) a nodal officer, an energy manager and an information technology manager, having professional experience of not less than five years; and (ii) a financial manager having professional experience of not less than five years | g. DISCOM has energy audit cell. List is mentioned in the audit report. Energy manager is designated one. |  |
| 6                | Reporting requirements for annual energy audit and periodic energy accounting | a. Electricity distribution company has a nodal officer, who is a full time employee of the electricity distribution company in the rank of the Chief Engineer or above, for the purpose of reporting of the annual energy audit and periodic energy accounting and communicate the same to the Bureau.                                    | a. The DC is complying with this requirement  |  |
|                  |   | b. Electricity distribution company ensures that the energy accounting data is generated from a metering system or till such time the metering system is not in place, by an agreed method of assumption as may be prescribed by the State Commission  | b. DC has already had software system for keeping historical records.                                     |  |
|                  |   | c. Metering of distribution transformers at High Voltage Distribution System up to 25KVA is done on cluster meter installed by the electricity distribution company  | c. Not yet done   | Plans to do the work in phased manner  |

| Clause No | Clause Details | Subclause Details   | Present Status   | Action plan/comments by DISCOM |
|-----------|----------------|---|--|--------------------------------|
|           |                | d. The energy accounting and audit system and software is developed to create monthly, quarterly and yearly energy accounting reports.  | d. The DC has software's for energy accounting and audit and the software's are having the capability to create monthly, quarterly and yearly energy accounting reports. |                                |
|           |                | e. Electricity distribution company has provided the details of the information technology system in place as specified in clause (f) of regulation 5 that ensures minimal manual intervention in creating the energy accounting reports and any manual intervention of any nature, in respect of the period specified therein, shall be clearly indicated in the periodic energy accounting report | e. The DC has software's for energy accounting and audit and the software's are having the capability to create monthly, quarterly and yearly energy accounting reports. |                                |

## ***2 NOTES OF THE EA/EM ALONG WITH QUERIES AND REPLIES TO DATA GAPS***

There were no queries raised by the AEA to DISCOM during the period of MEA FY 2022-23

## CONCLUSION AND ACTION PLANS

### 1 CRITICAL COMMENTS AND ANALYSIS BY ENERGY AUDITOR

#### ABOUT LOSS EVALUATION

The Distribution loss % calculation in KDHP is slightly different from other DISCOMs. The KSERC has accepted the formula which KDHP have adopted for the loss calculation due to the following reasons.

1. Multiple points where **feedback energy** fed back to KSEBL, who is the supplier of electricity to KDHP.
2. The distribution loss calculated by the KSEBL for the transmission of feedback energy is 4% instead of the actual value.

#### About Feedback energy:

Feedback is the energy wheeled through the system of KDHPCL for the consumers of KSEB Ltd (Energy sold outside the periphery). Since the feedback is wheeled through the distribution lines of KDHPCL, the same is considered for the computation of distribution loss for the submission to Kerala State Electricity Regulatory Commission (KSERC).

For KDHP, the distribution loss computed in the following way, considering the example of 2022-23 FY.

TABLE 59: Distribution loss – KDHP method approved by KSERC

| No | Equation     | Particulars                      | Units | 2022-23 |
|----|--------------|----------------------------------|-------|---------|
| 1  |              | Gross energy flows in the system | MU    | 59.048  |
| 2  |              | KSEBL feedback energy            | MU    | 4.930   |
| 3  | <b>1 - 2</b> | Energy purchased                 | MU    | 54.118  |
| 4  |              | Energy sales to the consumers    | MU    | 49.080  |
| 5  | <b>3 - 4</b> | Distribution loss                | MU    | 5.038   |
| 6  | <b>5 ÷ 1</b> | Distribution loss                | %     | 8.53    |

Where;

- *Gross energy > The energy metered at the 11 kV input lines (Pullivasal + Madupatty) at the KDHP incomer*
- *Feedback energy > The energy received by the KSEBL (Energy sold outside the periphery) after passing through the KDHP OH lines.*
- *Energy purchased > The actual energy of KDHPCL.*
- *Energy sales to the consumers > The energy that is sold to its consumers by KDHPCL.*

### ***11KV FEEDER METERING AND ENERGY AUDIT***

The DISCOM has 100% metering for all the 11 kV feeders and has provided energy input and consumption/ sale data of all the 11 KV feeders (11 kV feeders – 07 nos). The process of checking the functioning and calibration of the 11 KV feeder meters is an on-going process and is monitored by KDHP itself.

### ***ANALYSIS ON T&D LOSSES AND AT&C LOSSES***

**% of losses – Aggregate:** - The overall Technical Loss (T&D Loss) is 8.53% and overall AT&C Loss is 8.83% for FY 2022-23. This reflects an overall collection efficiency of 99.673%. The detailed HT, LT and Transformer losses with respect to the input energy is shown in table below.

*Table 60: Analysis on T&D losses*

| <b>Particulars</b>  | <b>Units</b> | <b>Values</b> |
|---|--------------|---------------|
| Total energy requirement                                      | MU           | 59.048        |
| Total energy sales  | MU           | 54.011        |
| <b>Quantum of losses at HT level</b>                          | <b>MU</b>    | <b>1.227</b>  |
|   | <b>%</b>     | <b>2.0781</b> |
| <b>Quantum of LT level losses (LT and Transformer losses)</b> | <b>MU</b>    | <b>3.810</b>  |
|   | <b>%</b>     | <b>6.4531</b> |

- HT & LT level losses in the DISCOM is estimated through the line & transformer mapping.

## ***2 ENERGY CONSERVATION MEASURES***

### ***RECONDUCTORING OF HT OVERHEAD LINES***

#### **Background**

Presently 66% of the total HT overhead lines in KDHP are of either 7/14 ACSR or Copper which corresponds to 118.2 km out of the total HT line length of 180.23 km. This predominantly contributes to the HT overhead line losses. Previously, reconductoring has been done in the HT overhead lines with Racoon and Mink and this may be kept as such. The details of the HT overhead lines in KDHP are summarized in the table given below

*TABLE 61 : HT OVERHEAD LINES DETAILS*

| <b>OH Line type</b> | <b>Distance in km</b> | <b>Resistance of the line <math>\Omega</math>/km</b> |
|---------------------|-----------------------|--|
| 7/14 ACSR           | 52.3                  | 0.5595   |
| 7/12 ACSR           | 3.79                  | 0.5595   |
| No:6 Cu             | 3.74                  | 1.44   |

|         |       |        |
|---------|-------|--------|
| No:8 Cu | 8.32  | 2.36   |
| 7/12 Cu | 3.36  | 5.41   |
| 3/12 Cu | 37.42 | 5.41   |
| 7/14 Cu | 9.29  | 8.79   |
| Racoon  | 48.64 | 0.3712 |
| Mink    | 6.65  | 0.4545 |
| DOG     | 6.72  | 0.2792 |

### **Proposal**

1. In order to reduce the HT overhead line losses, it is proposed to do reconductoring for the HT overhead lines of ACSR and Copper type with DOG.
2. The resistance per line length for DOG type conductor is 0.2792  $\Omega$ /km which is considerably less than that of ACSR and Copper type conductors which will reduce the power loss through HT overhead line and thereby the net power losses in the system. Estimated reduction in energy loss is 70% of the present losses.
3. The detailed calculation for savings and financial viability is shown in the table given below.

**Calculation**

TABLE 62 : ECM 01

| Particulars  | Units  | ITD                | Pullivasal | Town      | Nyamakad  | Nettigudi | Madupatty   |
|--|--------|--------------------|------------|-----------|-----------|-----------|-------------|
| Present HT Line loss                                 | kWh    | 88047              | 19965      | 32412     | 162909    | 568217    | 166578      |
| Estimated HT line loss after reconductoring with DOG | kWh    | 45447              | 672        | 2507      | 87032     | 75784     | 92249       |
| Annual Savings                                       | kWh    | 42599              | 19294      | 29904     | 75876     | 492433    | 74329       |
| HT line Distance to be reconducted with DOG          | km     | 16.08              | 2.4        | 8.7       | 23.8      | 22.2      | 44.9        |
| Energy charges                                       | Rs/kWh | 4.8                | 4.8        | 4.8       | 4.8       | 4.8       | 4.8         |
| Reconductoring charges as per KDHP estimate          | Rs/km  | 4,00,000           | 4,00,000   | 4,00,000  | 4,00,000  | 4,00,000  | 4,00,000    |
| Annual Financial savings                             | Rs     | 2,04,476           | 92,609     | 1,43,541  | 3,64,206  | 23,63,679 | 3,56,780    |
| Investment cost                                      | Rs     | 64,32,000          | 9,60,000   | 34,80,000 | 95,20,000 | 88,80,000 | 1,79,60,000 |
| Net Annual Financial Savings                         | Rs     | <b>35,25,291</b>   |            |           |           |           |             |
| Net Investment                                       | Rs     | <b>4,72,32,000</b> |            |           |           |           |             |
| Simple Pay Back Period                               | Months | <b>161</b>         |            |           |           |           |             |

## ***RECONDUCTORING OF LT OVERHEAD LINES***

---

### ***Background***

Presently the whole LT overhead lines in KDHP are ACSR or Copper type conductors. total LT line length in the system is 193.8 km. The resistance per line length for these type conductors are comparatively high and hence the results in high LT overhead line losses. In KDHP, the LT overhead line losses share the major part of technical losses in almost all the feeders. The details of present LT overhead lines are summarized in the table given below.

*TABLE 63 : LT OVERHEAD LINES DETAILS*

| <b>OH Line type</b> | <b>Distance in km</b> | <b>Resistance of the line <math>\Omega</math>/km</b> |
|---------------------|-----------------------|--|
| 7/14 ACSR           | 133.02                | 0.5595   |
| ACSR                | 21.15                 | 0.5595   |
| 3/12 Cu             | 16.47                 | 5.41   |
| No:8 Cu             | 4.07                  | 2.36   |
| No:10 Cu            | 19.09                 | 3.64   |

### ***Proposal***

1. In order to reduce the LT overhead line losses, it is proposed to do reconductoring for the specified length of LT overhead lines with Rabbit conductor.
2. The resistance per line length for Rabbit type conductor is 0.5524  $\Omega$ /km which is considerably less than the present overhead conductors which will reduce the power loss through LT overhead line and thereby the net power losses in the system. Estimated reduction in energy loss is 54% of the present losses.
3. The detailed calculation for savings and financial viability of the same, along with the distance of LT overhead line to be reconducted are mentioned in the table given below.



TABLE 64 : ECM 02

| Particulars                                    | Units         | ITD                | Pullivasal | Town      | Nyamakad  | Nettigudi | Madupatty |
|--|---------------|--------------------|------------|-----------|-----------|-----------|-----------|
| Present LT Overhead Line loss                  | kWh           | 411826             | 88091      | 804889    | 467561    | 134378    | 453593    |
| Estimated LT line loss after reconductoring    | kWh           | 181013             | 34908      | 369713    | 242506    | 53499     | 203219    |
| Annual Savings                                 | kWh           | 230813             | 53183      | 435176    | 225055    | 80879     | 250374    |
| LT line Distance to be reconducted with Rabbit | km            | 37.5               | 0.922      | 9.25      | 21        | 14.2      | 24.2      |
| Energy charges                                 | Rs/kWh        | 4.8                | 4.8        | 4.8       | 4.8       | 4.8       | 4.8       |
| Reconductoring charges as per KDHP estimate    | Rs/km         | 2,00,000           | 2,00,000   | 2,00,000  | 2,00,000  | 2,00,000  | 2,00,000  |
| Annual Financial savings                       | Rs            | 11,07,901          | 2,55,279   | 20,88,843 | 10,80,266 | 3,88,217  | 12,01,796 |
| Investment cost                                | Rs            | 75,00,000          | 1,84,400   | 18,50,000 | 42,00,000 | 28,40,000 | 48,40,000 |
| <b>Net Annual Financial Savings</b>            | <b>Rs</b>     | <b>61,22,303</b>   |            |           |           |           |           |
| <b>Net Investment</b>                          | <b>Rs</b>     | <b>2,14,14,400</b> |            |           |           |           |           |
| <b>Simple Pay Back Period</b>                  | <b>Months</b> | <b>42</b>          |            |           |           |           |           |

## ANNEXURE: COLLECTED DATA

### 1. ABOUT THE ACCREDITED ENERGY AUDIT FIRM

Centre for Energy Environment and Productivity (CEEP) is an Empanelled Accredited Energy Auditing Firm (EAEA) recognised by BEE. Consulting and training in the areas of energy audit, ISO 50001, cleaner production and environmental management,

Empaneled Accredited Energy Auditor with Bureau of Energy Efficiency (BEE) which have wide experience in the energy audit sector and have conducted the same in Chemical, Textile, Steel and DISCOM.

#### NAME AND DETAILS OF ENERGY MANAGER/AEA

M/s Kanan Devan Hills Plantations (KDHP) Company Private Limited, KDHP House, Munnar Idukki District-Kerala -685612 does not have a BEE Certified Energy Manager, however, Mr. R Jayaraman will be the signatory for all BEE activities.

On behalf of Centre for Energy Environment and Productivity (CEEP), Mr. Ashok K M P (CEA 34760/22) signed the quarterly Energy accounting report for the financial year 2022-23 and will be sign for the upcoming FY 2023-24.

The contact details of Accredited energy auditor and Energy manager from CEEP is given in the table below.

TABLE 65: CONTACT DETAILS OF AEA & CEA

| Sr No | Name                | Certification               | EM/EA/AEA/Registration No | Phone no                  | Email                     |
|-------|---------------------|-----------------------------|---------------------------|---------------------------|---------------------------|
| 1     | Mr. J Nagesh Kumar  | • Accredited Energy Auditor | AEA-0133                  | 9444882553,<br>8668115663 | ceepnagesh@gmail.com      |
| 2     | Mr. Sunil kumar V K | • Sector Expert             | EA - 3642                 | 9497752463                | vkilothsunil@gmail.com    |
| 3     | Mr. Ashok K M P     | • Certified Energy Auditor  | EA-34760/22               | 7356111991                | ashokkmp@gmail.com        |
| 4     | Ms. Della David     | • Certified Energy Auditor  | EA 34867/22               | 7356111992                | delladavid19984@gmail.com |

## ***2. CHECKLIST PREPARED BY AUDITING FIRM***

---

1. KSEB bill –FY 2022-23 – April to March
2. Truing up & ARR Document –FY
3. Bill collection data as per the performa for the FY
4. Annual financial statement – P&L – balance sheet
5. Electricity Transmission and consumption data: Both FY (year wise)
  1. Substation meter reading
  2. Feeder meter readings -
  3. DT meter reading – corresponding feeder wise
  4. HT consumer meter reading & PF - corresponding feeder wise
  5. LT consumer meter reading
  6. Solar export data – unit, location, size of the plant, voltage level, metering type (net or gross), feeder name, consumer no:
6. Transformer details
  1. Incomer transformer data
  2. Feeder wise transformer data (HT and DT separately)
  3. Name plate details of transformers
  4. No load and Copper loss of transformers
7. Energy Meter data
  1. Feeder meter & DT meter – serial no., type of meter
  2. Consumer meter – type & its number
8. HT network diagram (GRID Map)
9. Incomer substation single line diagram
10. Cable details
  1. HT cable – type, location, size, length
  2. LT cable – type, location, size, length
  3. HT & LT overhead line – type
11. Street light – number, location (estimate)
12. Quarterly Performa sheet submitted during the last FY to BEE

### 3. APPROACH, SCOPE & METHODOLOGY OF ENERGY AUDIT

#### PERIOD OF AUDIT

The energy audit field study was carried out during the period from 30<sup>th</sup> July 2023 to 01<sup>st</sup> Aug 2023 for the field study is given in the table below.

Table 66: Activity chart – Energy audit

| ACTIVITIES   | 30 <sup>th</sup> July | 31 <sup>st</sup> July | 01 <sup>st</sup> Aug |
|--|-----------------------|-----------------------|----------------------|
| <ul style="list-style-type: none"> <li>Kick-off meeting with the concerned DISCOM officials</li> <li>Data collection</li> <li>site survey plan</li> </ul>  |                       |                       |                      |
| <ul style="list-style-type: none"> <li>Site survey</li> <li>11kV HT line mapping</li> <li>DT mapping</li> <li>Feeder wise measurement at switching station.</li> <li>Metering deviations of major HT consumers.</li> </ul> |                       |                       |                      |
| <ul style="list-style-type: none"> <li>Verification of T&amp;D Losses, other Calculation</li> <li>Finalization of form</li> </ul>  |                       |                       |                      |

#### SCOPE OF AUDIT

- Study and validation of the methodology adopted, data source and its accuracy of the energy audit works carried out for internal as well as external reporting in the following areas.
  - 11 kV level for study of 11 kV distribution loss in 06 feeders.
    - Losses incurred in individual 11 kV feeders
    - Calculation of technical loss of 11 kV line
  - Sample LT level study of Distribution transformer and LT distribution loss.
    - Losses incurred in LT line of different 11/0.433 kV distribution transformer in each feeder on 10% sample basis.
    - Calculation of technical loss of LT line with actual LT line data.
    - Selection of the distribution transformer shall be based on the differentiated consumer pattern, length of the distribution lines, old lines etc.
- Collection and Review of the energy related data of last Financial Year (FY) in the Proforma by visiting the DISCOM physically.
- Verification of existing pattern of energy distribution across periphery of electricity distribution company

4. Collection and verification of energy flow data of electricity distribution company at all applicable voltage level of distribution network.
5. Collection of data on energy received and distributed by DISCOM and verify the accuracy of data
6. Collection & analysis the data and prepare the same with report;
7. Input energy details:
  - a) Collection of input energy from recorded system meter reading
  - b) All the inputs points of transmission system
  - c) Details provided by transmission unit
  - d) System loading and Captures infrastructure details (i.e., no of circle, division, sub-division, feeders, DTs, & Consumers).
8. Parameters for computation of distribution losses:
  - a) Details of open access, HT sale, LT sale and transmission losses
  - b) Number of consumers category wise in each circle
  - c) Consumers connected load category wise in each circle
  - d) Details of billed and un-billed energy category wise of each circle
  - e) Metered and un-metered details.
  - f) Boundary meter details
  - g) Energy Cost and Tariff data
  - h) Source of energy Supply (e.g., electricity from grid or self-generation), including generation from renewables;
  - i) Energy supplied to Open Access Consumers which is directly purchased by Open Access Consumers from any supplier other than electricity distribution company
9. Monitoring and verifications of input energy and consumption pattern at various voltage levels
10. Identify the areas of energy leakage, wastage or inefficient use;
11. Identify high loss-making areas/networks, for initiating target based corrective action;
12. Identify overloaded segments of the network for necessary capacity additions.
13. Computation of agriculture consumption (approved by SERC)
14. Methodology for loss computation various losses.
15. Computation of Average Billing Rate (ABR)
  - a) Total revenue billed category wise.
  - b) Category wise ABR with tariff subsidy.
  - c) Category wise ABR without tariff subsidy.
  - d) Collection Efficiency (Category wise) and computation of AT&C loss.

16. Observe and compile various Energy Conservation (ENCON) options implemented by the DISCOM and prepared report containing details of expenditure made by DC along with saving and payback period.
17. Recommendations to facilitate energy audit, energy accounting and improve energy efficiency
18. Study the details of loss/gain of DISCOM, analysis of Average Cost of Supply (ACS) and Average Revenue realized (ARR) gap, details of energy charges/Power purchase cost along with the financial analysis.
19. Current System Metering Status at various voltage level of DISCOM
  - a) Status of Functional meters for all consumers, transformers and feeders.
  - b) Status of default meters (non-functional meters) for all consumers, transformers and feeders
20. Current status of pre-requisites mentioned in regulations.
21. Copies of relevant authentic and certified documents should support the report. Each document should be sealed and signed by DISCOM authorized representative as well as by agency's AEA.
22. Prepare final report of DISCOM as per the scope of work and as per the regulation of Energy Audit, 2021, in a standard format duly indexed, covering profile of the unit and its details of energy related data w.r.t. DISCOMs Sector, analytical & Statistical details and any other relevant information.

## ***METHODOLOGY***

---

In order to meet requirements of the scope of Work, CEEP, adopted the following phase wise approach for completion of the assignment

### **Phase 1 – Pre-audit phase**

- a. Kick off meeting with DISCOM officials.

The following were the agenda during the kick off meeting.

- Introduction of the team
- Briefing of energy audit – Schedule of plan & execution
- Discussion about data collection format.
- Discussion on the scope of energy audit

After detailed deliberations following points were discussed.

- KDHP will provide the transportation facility for the field measurement.
- KDHP will provide a single person of contact for the energy audit assistance who has access to the T Soft (KDHP internal software).
- KDHP will provide an engineer in the field who has knowledge on the distribution lines

- b. Assigning of team members.
- c. Collection and Review of the energy related data

## **Phase 2 – Audit phase**

### **Field survey:**

- a. The field survey had been conducted for HT lines and transformers of the designated area as representative data for compiling a comprehensive and diligent assessment.
- b. A detail route plan of the distribution network had been also ascertained by way of segmenting data through walk down surveys along 11kV incoming feeder and corresponding 11kV feeders were also surveyed.
- c. Hourly load analysis was done for all the six feeders and feeder energy meters were calibrated against the power analyzer.
- d. HT lines & Transformers are mapped using the Global positioning system (GPS).
- e. HT line length and partial LT line length were identified using the GPS.
- f. The consumption data, type of cable, transformer details etc were collected from the DISCOM and verified with the field data.
- g. Analysis of various types of losses in the system was done. Various losses in the system are as listed below.

### **Technical Losses:**

- HT (11 kV) line losses
- Distribution transformer losses (Iron & Copper losses).
- L.T. Line losses
- HT and LT cable losses

### **Miscellaneous technical losses**

- Losses due to loose jump connections in the line
- Losses due to short circuits & earth faults Losses in service mains of installations.
- Losses incurred in CT'S of energy meters.
- Losses incurred in old static energy meters.




Figure 13: Schematic representation of technical losses

### Commercial losses

- Mistakes in the billing.
- Meters not recording (MNR)
- Meters not recording correctly
- Meters by-passed due to defects/ intentionally.
- Meters not read & billed.
- Theft and pilferage.

### Phase 3 – Post audit phase

After the identification of various loss reduction initiatives based on the HT & LT distribution detailed analysis was carried out in this phase of the study to prepare a strategy for loss reduction. Under this strategy, detailed steps are defined for loss measurement, energy audit and loss verification as well. A Final Report was prepared after discussion with KDHP officials. Submitted the report with complete database and techno economic analysis.



## CALCULATIONS INVOLVED IN LOSS ANALYSIS

Technical losses occur in the system due to cables, overhead lines, transformers and other equipment in the substation. The losses in cables and overhead lines depends on the length, type of the cable/overhead line as well as the current passing through it.

The length of the overhead lines could be determined after mapping HT/LT lines and transformers using GPS and the type of overhead line was identified. The type of HT/LT cables, its length, were collected during the field visit. The energy consumption pattern during the previous 12 months for all HT consumers and LT consumers (under each distribution transformer) were analyzed and average monthly energy consumption was noted.

### A. LT Losses

For LT side, the average monthly energy consumption is noted (at the transformer secondary side). The **LT overhead line losses** are calculated as per the formula given below

$$LT \text{ line losses per month } \left( \frac{kWh}{month} \right) = 3I_L^2 * R_L * d * 24 * 30 \dots\dots\dots (1)$$

Where:  $I_L$  = average value of current passing through the LT overhead line (A)

$R_L$  = Resistance/km of the LT overhead line ( $\Omega$ /km)

$d$  = mean length of the LT overhead line (km)

The value of  $I_L$  can be calculated from the total average monthly kWh consumption of all consumers under a single Distribution Transformer as per the following equation

$$I_L = \frac{\text{Total Average monthly kWh consumption under each Distribution Transformer } \left( \frac{kWh}{month} \right) * 1000}{\sqrt{3} * 400 * 24 * 30} \dots\dots\dots (2)$$

Now, Energy transmitted from the pole of the distribution transformer (DT) is given by

$$\begin{aligned} \text{Energy transmitted from the pole of DT } \left( \frac{kWh}{month} \right) = \\ \text{Total energy consumption under each DT } \left( \frac{kWh}{month} \right) + \text{LT line losses } \left( \frac{kWh}{month} \right) \dots\dots\dots (3) \end{aligned}$$

**LT cable line losses** are calculated as follows:

$$LT \text{ cable losses per month } \left( \frac{kWh}{month} \right) = \frac{3I_c^2 * R_c * d * 24 * 30}{1000} \dots\dots\dots (4)$$

Where:  $I_c$  = average value of current passing through the LT cable (A)

$R_c$  = Resistance/km of the LT cable ( $\Omega$ /km)

d = length of the LT cable (km)

The value of  $I_{c\ can}$  can be calculated from the total average monthly energy transmitted from the pole of each Distribution Transformer as per the following equation

$$I_c = \frac{\text{Total Average monthly energy transmitted from pole of each Distribution Transformer (kWh/month)} * 1000}{\sqrt{3} * 400 * 24 * 30} \dots\dots(5)$$

Now, the energy at the secondary side of each distribution transformer is given by

$$\begin{aligned} \text{Energy at the secondary side of each DT } \left( \frac{kWh}{month} \right) = \\ \text{Total energy transmitted from pole of each DT } \left( \frac{kWh}{month} \right) + \text{LT cable losses } \left( \frac{kWh}{month} \right) \dots\dots\dots(6) \end{aligned}$$

**B. Transformer losses**

The major losses in a transformer are accounted as Core losses and Copper losses. Core losses are independent of the transformer loading whereas Copper losses depends on the loading factor. The transformer losses are given by the formula as

$$\text{Transformer losses } \left( \frac{kWh}{month} \right) = \frac{(P_{core} + x^2 * P_{Cu}) * 24 * 30}{1000} \dots\dots\dots(7)$$

Where:  $P_{core}$  = Transformer core losses (W)

$P_{Cu}$  = Transformer Copper losses (W)

x, Transformer loading factor = Total average monthly Energy at the transformer secondary (kWh/month)/ (Average monthly Power Factor\* Transformer capacity in kVA)

Thus, the total energy transmitted the HT side of each distribution transformer is given by the equation

$$\begin{aligned} \text{Total average monthly energy transmitted from the transformer primary } \left( \frac{kWh}{month} \right) = \\ \text{Average monthly energy transmitted from the transformer secondary } \left( \frac{kWh}{month} \right) + \\ \text{Transformer losses } \left( \frac{kWh}{month} \right) \dots\dots\dots(8) \end{aligned}$$

**C. HT losses**

For HT consumers the average monthly energy at the transformer HT side is available and the HT overhead line loss was calculated as per follows:

$$\text{HT line loss per month } \left( \frac{\text{kWh}}{\text{month}} \right) = 3I^2 * R * D * 24 * 30 \dots\dots\dots(9)$$

Where: I = average value of current passing through the overhead line (A)

R = Resistance/km of the HT overhead line ( $\Omega$ /km)

D = length of the overhead line (km)

The value of average current is found from the average monthly energy consumption recorded at the HT side as  $I = \frac{\text{average monthly kWh recorded at HT metering side}}{24*30*11*\sqrt{3}} \dots\dots\dots(10)$

For LT consumers under distribution transformer the energy transmitted from the HT side of each distribution transformer is calculated as per equation (9)

$$\begin{aligned} & \text{Total monthly average energy transmitted from the pole at switching station } \left( \frac{\text{kWh}}{\text{month}} \right) = \\ & \text{Total monthly average energy transmitted from the transformer primary } \left( \frac{\text{kWh}}{\text{month}} \right) + \\ & \text{Total monthly average HT overhead line losses } \left( \frac{\text{kWh}}{\text{month}} \right) \dots\dots\dots(11) \end{aligned}$$

**HT Cable losses** is given by equation (12) as follows

$$\text{HT cable losses } \left( \frac{\text{kWh}}{\text{month}} \right) = 3 I_T^2 * R_{HTcable} * D_c * 24 * 30 \dots\dots\dots(12)$$

Where: I<sub>T</sub> = average current through the HT cable (A)

R<sub>HTcable</sub> = Resistance/km of HT cable ( $\Omega$ /km)

D<sub>c</sub> = length of HT Cable from incomer to Pole at switching station

The total monthly average energy transmitted from the feeder incomer =

$$\begin{aligned} & \text{The total monthly average energy transmitted from the feeder incomer (kWh/month)} \\ & = \text{Total monthly average energy transmitted from the pole at switching station} \\ & + \text{HT cable losses} \end{aligned}$$

**D. Feeder Meter Calibration**

Continuous logging was done at each feeder for a period of 24 hours during a normal working day. The energy transmitted from each feeder was recorded using power analyzer and it is compared against the power analyzer readings. Percentage of error in the feeder side energy meter was found using the formula shown below.

$$\% \text{ of error} = \frac{(\text{Feeder energy meter reading} - \text{Power analyser reading}) * 100}{\text{Power analyser reading}}$$

### ***LIST OF INSTRUMENTS***

The instruments used for the measurements and analysis as a part of electrical distribution audit were as follows:

*Table 67: Equipment list*

| <b>Equipment/software name</b>  | <b>Make</b> | <b>Model</b>           | <b>Purpose</b>   |
|---------------------------------|-------------|------------------------|--|
| Portable load manager           | Krykard     | 1. ALM 31<br>2. ALM 35 | Load and distribution loss analysis, Meter deviation                     |
| Global positioning system meter | Garmin      | Etrex 10               | For mapping the HT lines and to have the coordinates of the transformers |
| Easy GPS software               |             |                        | For mapping the co-ordinates   |

#### 4. INFRASTRUCTURE DETAILS

The infrastructure details of the KDHP DISCOM are given below as per the Performa filled out and verified by the accredited energy auditor.

Table 68: Infrastructure details

| Form-Details of Input Infrastructure |  |                       |                         |                                     |                          |
|--------------------------------------|--|-----------------------|-------------------------|-------------------------------------|--------------------------|
| 1                                    | Parameters   | Total                 | Covered during in audit | Verified by Auditor in Sample Check | Remarks (Source of data) |
| i                                    | Number of circles  | 1                     | 1                       | 1                                   |                          |
| ii                                   | Number of divisions  | 1                     | 1                       | 1                                   |                          |
| iii                                  | Number of sub-divisions                                    | 1                     | 1                       | 1                                   |                          |
| iv                                   | Number of feeders  | 7                     | 7                       | 7                                   |                          |
| v                                    | Number of DTs  | 133                   | 133                     | 133                                 | Including HT consumers   |
| vi                                   | Number of consumers  | 16583                 | 16583                   | 16583                               |                          |
| <b>2</b>                             | <b>Parameters</b>  | <b>66kV and above</b> | <b>33kV</b>             | <b>11/22kV</b>                      | <b>LT</b>                |
| a. i.                                | Number of conventional metered consumers                   | -                     | -                       | -                                   | 6613                     |
| ii                                   | Number of consumers with 'smart' meters                    | -                     | -                       | -                                   | -                        |
| iii                                  | Number of consumers with 'smart prepaid' meters            | -                     | -                       | -                                   | -                        |
| iv                                   | Number of consumers with 'AMR' meters                      | -                     | -                       | -                                   | -                        |
| v                                    | Number of consumers with 'non-smart prepaid' meters        | -                     | -                       | 36                                  | 9934                     |
| vi                                   | Number of unmetered consumers                              | -                     | -                       | -                                   | -                        |
| vii                                  | <b>Number of total consumers</b>                           | -                     | -                       | 36                                  | 16547                    |
| b.i.                                 | Number of conventionally metered Distribution Transformers | -                     | -                       | -                                   | 63                       |
| ii                                   | Number of DTs with communicable meters                     | -                     | -                       | -                                   | -                        |
| iii                                  | Number of unmetered DTs                                    | -                     | -                       | -                                   | 70                       |
| iv                                   | <b>Number of total Transformers</b>                        |                       |                         | -                                   | 133                      |
| c.i.                                 | Number of metered feeders                                  |                       |                         | -                                   |                          |
| ii                                   | Number of feeders with communicable meters                 |                       |                         | 7                                   |                          |
| iii                                  | Number of unmetered feeders                                |                       |                         | -                                   |                          |
| iv                                   | <b>Number of total feeders</b>                             |                       |                         | 7                                   |                          |
| d.                                   | Line length (ct km)  |                       |                         | 180.23                              | 193.8                    |
| e.                                   | Length of Aerial Bunched Cables                            |                       |                         | -                                   | -                        |
| f.                                   | Length of Underground Cables                               |                       |                         | 0.405                               | 4.525                    |

| 3                                | Voltage level | Particulars  | MU            | Reference  | Remarks (Source of data) |
|----------------------------------|---------------|--|---------------|--|--------------------------|
| v                                | 11 kV         | Renewable Energy Procurement                                   | 0             |  |                          |
|                                  |               | Small capacity conventional/ biomass/ hydro plants Procurement | 54.12         | Purchase unit excluding feedback   |                          |
|                                  |               | Sales Migration Input  | 4.93          |  | Feedback                 |
| vi                               | LT            | Renewable Energy Procurement                                   | 0             |  |                          |
|                                  |               | Sales Migration Input  | 0             |  |                          |
| vii                              |               | <b>Energy Embedded within DISCOM wires network</b>             | 59.048        |  |                          |
| viii                             |               | <b>Total Energy Available/ Input</b>                           | 59.048        |  |                          |
| 4                                | Voltage level | Energy Sales Particulars                                       | MU            | Reference  |                          |
| i                                | LT Level      | DISCOM' consumers  | 13.98         | Include sales to consumers in franchisee areas, unmetered consumers (Total LT sales)   |                          |
|                                  |               | Demand from open access, captive                               | 0.00          | Non DISCOM's sales   |                          |
|                                  |               | Embedded generation used at LT level                           | 0.0237        | Demand from embedded generation at LT level  |                          |
|                                  |               | Sale at LT level   | 13.98         |  |                          |
|                                  |               | Quantum of LT level losses                                     | 3.81          | Included the LT OH line length, LT cable, Switch gear, Commercial & Transformer losses |                          |
|                                  |               | Energy Input at LT level                                       | 17.79         |  |                          |
| ii                               | 11 kV Level   | DISCOM' consumers  | 35.10         | Include sales to consumers in franchisee areas, unmetered consumers (HT sales)         |                          |
|                                  |               | Demand from open access, captive                               | 4.93          | Non DISCOM's sales   | Feedback                 |
|                                  |               | Embedded generation at 11 kV level used                        | 0.001         | Demand from embedded generation at 11 kV level   |                          |
|                                  |               | <b>Sales at 11 kV level</b>                                    | 40.03         |  |                          |
|                                  |               | Quantum of Losses at 11 kV                                     | 1.227         |  |                          |
|                                  |               | Energy input at 11 kV level                                    | 41.26         |  |                          |
| <b>Total Energy Requirement</b>  |               |  | <b>59.048</b> |  |                          |
| <b>Total Energy Sales</b>        |               |  | <b>54.011</b> |  |                          |
| <b>Energy Accounting Summary</b> |               |  |               |  |                          |
| 5                                | DISCOM        | Input (in MU)  | Sale (in MU)  | Loss (in MU)   | Loss %                   |
| i                                | LT            |  |               |  |                          |
| ii                               | 11 kV         | 59.048   | 54.011        | 5.038  | 8.53                     |

| Loss Estimation for DISCOM |       |
|----------------------------|-------|
| T&D loss (MU)              | 5.038 |
| D loss                     | 5.038 |
| T&D loss (%)               | 8.53  |
| D loss (%)                 | 8.53  |

## 5. ELECTRICAL DISTRIBUTION SYSTEM

M/s Kanan Devan Hill Plantations Company Private Limited (hereinafter referred to as KDHPCL, the petitioner or the licensee) is the distribution licensee supplying electricity in its license area at Munnar. KDHPCL procures electricity from KSEB Ltd for the supply to its consumers and for its own consumption.

### ELECTRICAL NETWORK CONFIGURATION

The Kanan Devan Hills Plantations Limited (KDHP) receives power at supply voltage of 11 kV from KSEBL through three incomers – two from Pullivasal feeder & One from Chithirapuram section.

The 11-kV supply from KSEBL is received at the 11-kV switching station located at the Pullivasal area, in KDHP Munnar. The received power is distributed to the consumers through seven numbers of 11 kV feeders. KDHP also receives power from the KSEBL owned and operated Madupatty 2MW hydro generating station which is inputted into the Madupatty feeder.

The KSEBL metering is done at two locations:

1. At the 11kV incomer 1 & 2 common CT/PT and Incomer -3 CT/PT (Two TOD meters at switching station) and the value generated at two meters are summed up.
2. Madupatty Bidirectional meter.

The metered energy is transmitted to the switching station in Pullivasal using underground cables. The power then transmitted to consumers through 7 feeders through cables and overhead lines. The total number of DT under the KDHP is 133 nos', including the HT consumers.

#### 1. Details of cables and overhead lines - summary

The details of 11 kV cable used at the switching station is given below. The data was taken from the Single line diagram of the switching station.

Table 69: Switching Station – 11 kV Cable Details

| From              | To                     | Cable size    | Run | Core | Cable length (m) | R/km (ohm) |
|-------------------|------------------------|---------------|-----|------|------------------|------------|
| Incomer 1 &2      | Switching station      | 300 sqmm XLPE | 2   | 3    | 50               | 0.13       |
| Incomer 3         | Switching station      | 300 sqmm XLPE | 1   | 3    | 60               | 0.13       |
| Switching station | ITD feeder pole        | 240 sqmm XLPE | 1   | 3    | 45               | 0.16       |
| Switching station | Station transformer    | 240 sqmm XLPE | 1   | 3    | 30               | 0.16       |
| Switching station | Nyamakad feeder pole   | 240 sqmm XLPE | 1   | 3    | 50               | 0.16       |
| Switching station | Pullivasal feeder pole | 240 sqmm XLPE | 1   | 3    | 40               | 0.16       |
| Switching station | Madupatty feeder pole  | 240 sqmm XLPE | 1   | 3    | 50               | 0.16       |
| Switching station | Town feeder pole       | 300 sqmm XLPE | 1   | 3    | 40               | 0.13       |
| Switching station | Nettigudi feeder pole  | 300 sqmm XLPE | 1   | 3    | 40               | 0.13       |

The details of OH lines used in the KDHP distribution system is given in the table below. The HT line length was measured using the GPS mapping and LT line length was measured from the existing values of the KDHP data for the relatively new transformers.

Table 70: KDHP Distribution – OH line details

| Name                           | Type   | Voltage level (kV) | Overall, Dia (mm) | Measured length (km)  | R/km (ohm) |
|--------------------------------|--------|--------------------|-------------------|-----------------------|------------|
| Dog                            | ACSR   | 11                 | 14.15             | 6.72                  | 0.2792     |
| Raccoon                        | ACSR   | 11                 | 12.27             | 48.64                 | 0.3712     |
| Mink                           | ACSR   | 11                 | 10.98             | 6.65                  | 0.4545     |
| 7/14 ACSR                      | ACSR   | 11                 | 13.7              | 52.30                 | 0.5595     |
| 7/12 ACSR                      | ACSR   | 11                 | 11.7              | 3.79                  | 0.5595     |
| No:6 Cu                        | Copper | 11                 | 4.11              | 3.74                  | 1.44       |
| No:8 Cu                        | Copper | 11                 | 3.26              | 8.32                  | 2.36       |
| 7/12 Cu                        | Copper | 11                 | 2.05              | 3.36                  | 5.41       |
| 3/12 Cu                        | Copper | 11                 | 2.05              | 37.42                 | 5.41       |
| 7/14 Cu                        | Copper | 11                 | 1.63              | 9.29                  | 8.79       |
| <b>Total HT OH line length</b> |        |                    |                   | <b>180.23</b>         |            |
| Name                           | Type   | Voltage level (kV) | Overall, Dia (mm) | Estimated length (km) | R/km (ohm) |
| Squirrel                       | ACSR   | 0.415              | 6.33              | 145                   | 1.394      |
| Weasel                         | ACSR   | 0.415              | 7.77              | 16.4                  | 0.9291     |
| 3/12 Cu                        | Copper | 0.415              | 2.05              | 12.2                  | 5.41       |
| No:8 Cu                        | Copper | 0.415              | 3.26              | 4.1                   | 2.36       |
| No: 10 Cu                      | Copper | 0.415              | NA                | 16.1                  | 2.36       |
| <b>Total LT OH line length</b> |        |                    |                   | <b>193.8</b>          |            |

The details of Transformers (HT consumers & DT) in feeder wise that has been audited under the DISCOM is listed below;

Table 71: Feeder wise transformer data

| <b>PULLIVASAL FEEDER</b>                 |                 |  |                 |
|--|-----------------|--|-----------------|
| HT Transformer                           | Capacity in kVA | Distribution Transformer                           | Capacity in kVA |
| Pullivasal Factory                       | 750             | Pullivasal Packeting                               | 500             |
| Devon Shrine                             | 200             | Allah Kovil (factory Div)                          | 160             |
|  |                 | Athakad  | 100             |
| <b>Total no of HT Consumers</b>          | <b>2</b>        | <b>Total no of Distribution Transformers</b>       | <b>3</b>        |
| <b>Total Capacity of HT Transformers</b> | <b>950</b>      | <b>Total Capacity of distribution Transformers</b> | <b>760</b>      |
| <b>ITD FEEDER</b>                        |                 |  |                 |
| HT Transformer                           | Capacity in kVA | Distribution Transformer                           | Capacity in kVA |



|  |                        |  |                        |
|--|------------------------|--|------------------------|
| Kallar Factory                           | 400                    | Kallar Factory Division                            | 100                    |
| ITD Factory - 2 nos                      | 1000                   | JE Division (new Div)                              | 63                     |
| Letchmi Factory                          | 630                    | Upper Seven Mallai Pump (sprinkler irrigation)     | 163                    |
| Tata BSS                                 | 200                    | Letchmi Viriparai                                  | 63                     |
|  |                        | Letchmi East                                       | 63                     |
|  |                        | Letchmi Factory Division                           | 100                    |
|  |                        | Ottupara   | 63                     |
|  |                        | ITD Pump   | 63                     |
|  |                        | Upper Sevenmalay                                   | 63                     |
|  |                        | Sevenmalay Godown (Nagermudi)                      | 63                     |
|  |                        | Paravathi  | 63                     |
|  |                        | Nadiar   | 100                    |
|  |                        | Kurumallay   | 25                     |
|  |                        | Hospital Bungalow (Kallar West)                    | 63                     |
|  |                        | Nullathanni West Division                          | 63                     |
|  |                        | Vermi Compost                                      | 63                     |
| <b>Total no of HT Consumers</b>          | <b>4</b>               | <b>Total no of Distribution Transformers</b>       | <b>16</b>              |
| <b>Total Capacity of HT Transformers</b> | <b>2230</b>            | <b>Total Capacity of distribution Transformers</b> | <b>1118</b>            |
| <b>TOWN FEEDER</b>                       |                        |  |                        |
| <b>HT Transformer</b>                    | <b>Capacity in kVA</b> | <b>Distribution Transformer</b>                    | <b>Capacity in kVA</b> |
| Casa Montana                             | 163                    | Old Munnar (tea tasting)                           | 100                    |
| Munnar Palace (Grand Plaza)              | 160                    | Poopada  | 150                    |
| MS Hotels                                | 160                    | Shikshak Sadan                                     | 250                    |
| EVM                                      | 200                    | Workshop Club                                      | 100                    |
| KTDC                                     | 400                    | RO   | 150                    |
| Engineering College                      | 250                    | KSEB   | 250                    |
| Eastend Hotel                            | 100                    | OCR  | 63                     |
| GH                                       | 250                    | Grahamsland Pump                                   | 63                     |
|  |                        | Teachers Quarters                                  | 100                    |
|  |                        | BSNL   | 200                    |
|  |                        | Botanical Garden                                   | 63                     |
|  |                        | Town   | 100                    |
|  |                        | Residency  | 63                     |
|  |                        | Nirmala Society                                    | 150                    |
|  |                        | Workshop Transformer                               | 100                    |
|  |                        | High Range Club                                    | 100                    |
|  |                        | KWA Pump (water supply)                            | 100                    |
|  |                        | Eastend  | 100                    |
| <b>Total no of HT Consumers</b>          | <b>8</b>               | <b>Total no of Distribution Transformers</b>       | <b>18</b>              |
| <b>Total Capacity of HT Transformers</b> | <b>1683</b>            | <b>Total Capacity of distribution Transformers</b> | <b>2202</b>            |
| <b>NETTIGUDI FEEDER</b>                  |                        |  |                        |
| <b>HT Transformer</b>                    | <b>Capacity in kVA</b> | <b>Distribution Transformer</b>                    | <b>Capacity in kVA</b> |
| Chokanad Factory                         | 1000                   | Chokanad South (fac div)                           | 63                     |
| Periyakanal Factory                      | 400                    | Chokanad East (puthukad)                           | 63                     |
| Devikulam Factory                        | 400                    | Ladbrock   | 75                     |
| Lockhart Factory                         | 315                    | Chokanad North (vattakad)                          | 63                     |

|  |                        |  |                        |
|--|------------------------|--|------------------------|
| Gudera Factory                           | 750                    | Chokonad K K Division                              | 63                     |
|  |                        | Periyakanal Division                               | 100                    |
|  |                        | Ayur County  | 400                    |
|  |                        | Periyakanal PH(top) Division                       | 63                     |
|  |                        | Devikulam ODK Division                             | 63                     |
|  |                        | Devikulam Middle                                   | 63                     |
|  |                        | Devikulam Factory Division                         | 100                    |
|  |                        | Lockhart Colony                                    | 63                     |
|  |                        | Ailsa Craig  | 63                     |
|  |                        | Earlston   | 20                     |
|  |                        | Forest (Central Nursery)                           | 25                     |
|  |                        | Gudera Top   | 63                     |
|  |                        | Gudera Center (middle)                             | 63                     |
|  |                        | Gudera Lower (Nettigudi)                           | 63                     |
|  |                        | GuderaManager                                      | 63                     |
|  |                        | Gudera Factory Division                            | 63                     |
|  |                        | BSNL (Silent valley)                               | 15                     |
|  |                        | Silent Valley Division (North)                     | 63                     |
|  |                        | Silent Valley office (South)                       | 100                    |
| <b>Total no of HT Consumers</b>          | <b>5</b>               | <b>Total no of Distribution Transformers</b>       | <b>23</b>              |
| <b>Total Capacity of HT Transformers</b> | <b>2865</b>            | <b>Total Capacity of distribution Transformers</b> | <b>1780</b>            |
| <b>NYAMAKAD FEEDER</b>                   |                        |  |                        |
| <b>HT Transformer</b>                    | <b>Capacity in kVA</b> | <b>Distribution Transformer</b>                    | <b>Capacity in kVA</b> |
| Periavurrai Factory                      | 1000                   | Tea Museum   | 150                    |
| Kadalar Factory                          | 315                    | DYSP Bunglaw                                       | 5                      |
| Kannimalai Factory                       | 750                    | Anamudi  | 63                     |
| Vagavurrai Factory                       | 630                    | Periavurrai lower division (Top)                   | 63                     |
| Thalayar Factory                         | 500                    | Sollamalai   | 63                     |
| Nullathani Factory                       | 315                    | Kanniar Bunglaw                                    | 15                     |
| Shrishti                                 | 150                    | Nyamakad Bunglaw                                   | 63                     |
|  |                        | Nyamakada East (Office)                            | 63                     |
|  |                        | Forest (rajamalai)                                 | 25                     |
|  |                        | Rajamala Park                                      | 63                     |
|  |                        | Rajamala Division                                  | 50                     |
|  |                        | Pettimudi  | 63                     |
|  |                        | Rajamalai West BSNL                                | 15                     |
|  |                        | Kadalar Factory Division                           | 100                    |
|  |                        | Kadalar hospital                                   | 100                    |
|  |                        | Kadalar Bunglaw (East)                             | 63                     |
|  |                        | Kannimalai Lower Division                          | 100                    |
|  |                        | Kannimalai Top                                     | 63                     |
|  |                        | Vagavurrai Factory Division                        | 100                    |
|  |                        | Vagavurrai Luckom                                  | 63                     |
|  |                        | Vagavurrai Naval                                   | 150                    |
|  |                        | Thalayar Factory Division                          | 100                    |
|  |                        | Thalayar Bunglaw                                   | 63                     |
|  |                        | Vagavurrai Top                                     | 63                     |
|  |                        | REP station (sangumalai)                           | 15                     |
|  |                        | Vagavurrai Bazar                                   | 100                    |
|  |                        | Manager Bunglaw                                    | 5                      |
|  |                        | Vagavurrai Lower                                   | 63                     |

|  |                        |  |                        |
|--|------------------------|--|------------------------|
| <b>Total no of HT Consumers</b>          | <b>7</b>               | <b>Total no of Distribution Transformers</b>       | <b>28</b>              |
| <b>Total Capacity of HT Transformers</b> | <b>3660</b>            | <b>Total Capacity of distribution Transformers</b> | <b>1849</b>            |
| <b>MADUPATTY FEEDER</b>                  |                        |  |                        |
| <b>HT Transformer</b>                    | <b>Capacity in kVA</b> | <b>Distribution Transformer</b>                    | <b>Capacity in kVA</b> |
| Aruvikad Factory                         | 250                    | Aruvikad Division                                  | 100                    |
| Chundubarai Factory 1                    | 630                    | Pachakad East                                      | 63                     |
| Chundubarai Factory 2                    | 500                    | Kundale Cattle shed                                | 5                      |
| Chittivurrai factory                     | 250                    | Eco Point  | 63                     |
| Yelapetty Factory                        | 315                    | Kundale Club                                       | 5                      |
| Gundumalay Factory                       | 1000                   | Chittivurrai O.C Division                          | 63                     |
| Thenmalai Factory                        | 500                    | Chittivurrai new pump (kundale pump)               | 100                    |
| R&D Lab                                  | 63                     | Chittivurrai Factory Division                      | 100                    |
| Hi Tech KLD Board                        | 200                    | Chittivurrai pump (new div)                        | 63                     |
| Madupatty Factory                        | 1000                   | Yelapetty Division                                 | 100                    |
| Indo Swiss                               |                        | Chundubarai old Factory                            | 63                     |
|  |                        | Chundubarai top division                           | 63                     |
|  |                        | PR Division  | 63                     |
|  |                        | Kundale office                                     | 63                     |
|  |                        | Theerthamalai                                      | 75                     |
|  |                        | Puthukadi  | 63                     |
|  |                        | Netimadu Division                                  | 63                     |
|  |                        | KKD Church   | 63                     |
|  |                        | Grahamsland Office                                 | 63                     |
|  |                        | Gundumalay New Division                            | 25                     |
|  |                        | Gundumalai BSNL (sothuara BSNL)                    | 15                     |
|  |                        | Gundumalay Sothupara                               | 63                     |
|  |                        | Gundumalay Benmore                                 | 63                     |
|  |                        | Gundumalay lower                                   | 63                     |
|  |                        | Gundumalay upper                                   | 63                     |
|  |                        | Gundumalay Kadugu                                  | 15                     |
|  |                        | Gundumalay Factory division                        | 100                    |
|  |                        | Thenmalai Asst Manager Bunglaw (hospital div)      | 63                     |
|  |                        | Thenmalai Factory Division                         | 100                    |
|  |                        | Thenmalai New Division                             | 25                     |
|  |                        | R&D Complex  | 63                     |
|  |                        | Madupetty Godown (Fac Div/Packeting)               | 315                    |
|  |                        | Madupetty Top Division                             | 63                     |
|  |                        | High Range School                                  | 150                    |
|  |                        | Grahamsland Bunglaw (Velmudi)                      | 63                     |
|  |                        | Microwave  | 25                     |
|  |                        | Westwood Hotel                                     | 160                    |
|  |                        | Grahamsland Bazar                                  | 5                      |
|  |                        | Kundaly Naturals (medicinal Plant)                 | 150                    |
|  |                        | New pump indo swiss                                | 163                    |
| <b>Total no of HT Consumers</b>          | <b>10</b>              | <b>Total no of Distribution Transformers</b>       | <b>40</b>              |
| <b>Total Capacity of HT Transformers</b> | <b>4708</b>            | <b>Total Capacity of distribution Transformers</b> | <b>2680</b>            |
| <b>Net HT Consumers</b>                  | <b>36</b>              |  |                        |
| <b>Net Distribution Transformers</b>     | <b>128</b>             |  |                        |

|  |              |  |  |
|--|--------------|--|--|
| <b>Net Capacity of HT Transformers (kVA)</b>           | <b>16096</b> |  |  |
| <b>Net Capacity of Distribution Transformers (kVA)</b> | <b>10389</b> |  |  |

GRID MAP




Figure 14: Grid Map – 11 kV distribution line

## **6. POWER PURCHASE DETAILS**

---

### ***POWER ALLOCATION***

---

The State Government of Kerala allocates the energy available from various sources among the state DISCOM's to ensure balanced financial viability and fairly uniform tariff for various categories of consumers in different parts of the state. The allocation is also to ensure payment of power purchase cost including transmission and other related expenses. The point of connection charges shall be paid by DISCOM proportionate to energy allocation of each source. The KDHP has only single source of power – KSEBL – which is owned and operated by the Kerala State Government. The power purchase capacity of the KDHP as per the Power purchase agreement is 09 MW.

### ***AVERAGE BILLING RATE (ABR):***

---

ABR for a consumer category is determined by dividing total expected revenue from the category by total expected sale to that category. Mathematically, it can be represented as:

$$ABR \text{ of a category of consumer} = \frac{\text{Total Expected revenue from a category}}{\text{Total Sale of power to that category}}$$

The ABR (Average rate /kWh) of each category as per the audited sheet of KDHP is given below. The net average rate/unit is given as Rs 6.91/kWh.

**Note:**

- *There is no tariff subsidy for the DISCOM consumers as per the KSERC regulations*
- *ABR value received from the KDHP accounts based on the estimated purchase cost.*
- *Once the Trueing up and the annual accounts completed actual value will be different from the present reported one.*

### ***AVERAGE POWER PURCHASE COST PER UNIT:***

---

Average per unit cost power purchase for a consumer category is determined by dividing total unit purchase cost from the category by total input purchase in units. Mathematically, it can be represented as:

$$APC \text{ of a category of consumer} = \frac{\text{Total Purchase cost from a category}}{\text{Total input purchase units}}$$

The net average power purchase cost per unit of the DISCOM is available from the Trueing up document and summarised in the table below.

Table 72: Average purchase cost – DISCOM

| FY      | Total input energy purchased (MU)** | Total purchase cost (Rs lakhs) | APC (Rs/unit) |
|---------|-------------------------------------|--------------------------------|---------------|
| 2020-21 | 48.14                               | 2689.53                        | 5.59          |
| 2021-22 | 48.4                                | 2695.88                        | 5.57          |
| 2022-23 | NA                                  | NA                             | NA            |

\*\*Total input energy purchased (MU) = Input energy (MU) at the KDHP – feedback energy (MU)

- **Source:** Audited balance sheet and financial year statement 2020-21 & 2021-22
- **Audited balance sheet of FY 2022-23** not yet finished while submitting the energy audit report.

### **ACS – ARR GAP ANALYSIS**

The Average cost of supply (ACS) and the average revenue realised (ARR) is conducted in the DISCOM during the energy audit and summarized in the below table and chart.

Table 73: ACS- ARR gap

|         | Input energy (MU)** | Total expenditure (Rs in lakhs) | Total revenue (Rs) | ACS (Rs/kWh) | ARR (Rs/kWh) | ACS - ARR gap (Rs/kWh) |
|---------|---------------------|---------------------------------|--------------------|--------------|--------------|------------------------|
| 2020-21 | 48.14               | 2967.88                         | 2884.83            | 6.17         | 5.99         | -0.17                  |
| 2021-22 | 48.4                | 2,992.30                        | 2,955.48           | 6.18         | 6.11         | -0.08                  |
| 2022-23 | NA                  | NA                              | NA                 | NA           | NA           | NA                     |

\*\*Total input energy purchased (MU) = Input energy (MU) at the KDHP – feedback energy (MU)

- **Source:** Audited balance sheet and financial year statement 2020-21 & 2021-22
- **Audited balance sheet of FY 2022-23** not yet finished while submitting the energy audit report.

### 7. SINGLE LINE DIAGRAM

#### FROM PULLIVASAL POWER HOUSE - INCOMER 1&2




Figure 15: SLD – From Pullivasal power house- at switching station



**FROM CHITHIRAPURAM SECTION - INCOMER 3**




Figure 16: From Chithirapuram – at switching station – Incomer 3

## 8. CATEGORY OF SERVICE DETAILS

### DETAILS OF CONSUMERS AND CONSUMPTION

The details of consumers and consumption is given in the table below:

Table 74: Details of consumers and consumption

| Summary of Energy                             |   |   |                            |                 |                           |                          |
|---|---|---|----------------------------|-----------------|---------------------------|--------------------------|
| Period from 1st April 2022 to 31st March 2023 |   |   |                            |                 |                           |                          |
| S. No   | Type of Consumers                                   | Category of Consumers (EHT/HT/LT /Others) | Voltage Level (In Voltage) | No of Consumers | Total Consumption (In MU) | Remarks (Source of data) |
| 1   | Domestic  | LT  | 0.415                      | 14010           | 7.80                      | T-soft - KDHP s/w        |
| 2   | Commercial  | LT  | 0.415                      | 1224            | 3.40                      | T-soft - KDHP s/w        |
| 3   | IP Sets   |   |                            |                 |                           |                          |
| 4   | Hor. & Nur. & Coffee/Tea & Rubber (Metered)         |   |                            |                 |                           |                          |
| 5   | Hor. & Nur. & Coffee/Tea & Rubber (Flat)            |   |                            |                 |                           |                          |
| 6   | Heating and Motive Power                            |   |                            |                 |                           |                          |
| 7   | Water Supply  |   |                            |                 |                           |                          |
| 8   | Public Lighting                                     | LT  | 0.415                      | 265             | 0.39                      | T-soft - KDHP s/w        |
| 9   | HT Water Supply                                     |   |                            |                 |                           |                          |
| 10  | HT Industrial                                       | HT  | 11                         | 22              | 32.26                     | T-soft - KDHP s/w        |
| 11  | Industrial (Small)                                  | LT  | 0.415                      | 93              | 0.59                      | T-soft - KDHP s/w        |
| 12  | Industrial (Medium)                                 |   |                            |                 |                           |                          |
| 13  | HT Commercial                                       | HT  | 11                         | 9               | 2.05                      |                          |
| 14  | Applicable to Government Hospitals & Hospitals      | HT  | 11                         | 1               | 0.045                     | T-soft - KDHP s/w        |
| 15  | Lift Irrigation Schemes/Lift Irrigation Societies   | HT Others                                 | 11                         | 4               | 0.75                      | T-soft - KDHP s/w        |
| 16  | HT Res. Apartments Applicable to all areas          |   |                            |                 |                           |                          |
| 17  | Mixed Load  |   |                            |                 |                           |                          |
| 18  | Government offices and department                   |   |                            |                 |                           |                          |
| 19  | Feedback energy – Energy sold outside the periphery | HT/LT                                     | 11/0.415                   |                 | 4.93                      | T-soft - KDHP s/w        |
| 20  | Agriculture   | LT  | 0.415                      | 7               | 0.016                     | T-soft - KDHP s/w        |
| 21  | LT General  | LT  | 0.415                      | 948             | 1.78                      | T-soft - KDHP s/w        |
|   | <b>Total</b>  |   |                            | <b>16583</b>    | <b>54.011</b>             |                          |

***DIVISION WISE STATUS OF DT LEVEL METERING***

The division wise status of DT level metering is given in the table below.

Table 75: Division wise status of DT level metering

| <b>a. Division wise status of DT level metering</b> |             |               |             |                          |                     |                            |                            |  |   |  |
|---|-------------|---------------|-------------|--------------------------|---------------------|----------------------------|----------------------------|--|---|--|
| Zone name   | Circle name | Division name | Feeder name | Total no of DT on feeder | No of unmetered DTs | No of metered DTs          |                            |  | No. of DTs with functional meters       |  |
|   |             |               |             |                          |                     | AMR metered (communicable) | AMI metered (communicable) | Non-AMR / AMI metered (non-communicable) | Communicating (Total No out of 7 and 8) | Non-communicating (Total No. out of 7,8 and 9) |
| 1   | 2           | 3             | 4           | 5=(6+7+8+9)              | 6                   | 7                          | 8                          | 9  | 10                                      | 11   |
| KDHP  | KDHP        | KDHP          | Nayamakad   | 31                       | 16                  |                            |                            | 15                                       |   | 15   |
| KDHP  | KDHP        | KDHP          | Madupatty   | 41                       | 25                  |                            |                            | 16                                       |   | 16   |
| KDHP  | KDHP        | KDHP          | Nettigudi   | 24                       | 12                  |                            |                            | 12                                       |   | 12   |
| KDHP  | KDHP        | KDHP          | Town        | 18                       | 9                   |                            |                            | 9  |   | 9  |
| KDHP  | KDHP        | KDHP          | ITD         | 16                       | 8                   |                            |                            | 8  |   | 8  |
| KDHP  | KDHP        | KDHP          | Pullivasal  | 3                        | 0                   |                            |                            | 3  |   | 3  |

**DETAILS OF DT WISE LOSSES**

The details of DT wise losses as per the Performa is given in the table below.

Table 76: DT wise losses

| b. Details of DT-wise losses |           |             |                                   |                   |   |  |   |   |                            |                   |                    |                     |                     |
|------------------------------|-----------|-------------|-----------------------------------|-------------------|---|--|---|---|----------------------------|-------------------|--------------------|---------------------|---------------------|
| Sub-station ID               | Feeder ID | Feeder Name | DT Id no                          | DT Capacity (kVA) | Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed) | Type of metering (Unmetered/AMI/AMR/Other) | Status of meter (functional/non-functional) | % of data received automatically (if AMI/AMR) | No. of connected consumers | Input Energy (MU) | Billed Energy (MU) | Loss of Energy (MU) | % Loss              |
|                              |           | 1           | 2                                 |                   |   |  |   |   | 3                          | 4                 | 5                  | 6 = 4-5             | (7) = [(6)/(4)]*100 |
|                              |           | Pullivasal  | Pullivasal Estate                 | 750               | Industrial  |  |   |   |                            |                   |                    |                     |                     |
|                              |           | Pullivasal  | Pullivasal Packeting Centre (PPC) | 500               | Industrial  |  |   |   |                            |                   |                    |                     |                     |
|                              |           | Pullivasal  | DEVONSHIRE GREENS                 | 200               | Mixed   |  |   |   |                            |                   |                    |                     |                     |
|                              |           | Pullivasal  | Athukadu dn.                      | 100               | Domestic  |  |   |   |                            |                   |                    |                     |                     |
|                              |           | Pullivasal  | Allakovil transformer             | 160               | Domestic  | Metered                                    |   |   |                            |                   |                    |                     |                     |
|                              |           | ITD         | Tata BSS                          | 200               | Mixed   |  |   |   |                            |                   |                    |                     |                     |
|                              |           | ITD         | Instant Tea Division (ITD)        | 1000              | Industrial  |  |   |   |                            |                   |                    |                     |                     |
|                              |           | ITD         | KALAAR                            | 400               | Industrial  |  |   |   |                            |                   |                    |                     |                     |
|                              |           | ITD         | LETCHMI                           | 630               | Industrial  |  |   |   |                            |                   |                    |                     |                     |
|                              |           | ITD         | Vermi compost                     | 63                | Domestic  |  |   |   |                            |                   |                    |                     |                     |
|                              |           | ITD         | Nullatanni West Division          | 63                | Domestic  |  |   |   |                            |                   |                    |                     |                     |
|                              |           | ITD         | Kallar Factory Divi               | 100               | Domestic  | Metered                                    |   |   |                            |                   |                    |                     |                     |
|                              |           | ITD         | JE Divsn                          | 63                | Domestic  |  |   |   |                            |                   |                    |                     |                     |
|                              |           | ITD         | Hospital Bungalow(Kallar West)    | 63                | Domestic  |  |   |   |                            |                   |                    |                     |                     |
|                              |           | ITD         | Sevenmalay Godown (Nagermudi)     | 63                | Domestic  |  |   |   |                            |                   |                    |                     |                     |

|  |          |                                 |      |            |         |  |  |  |  |  |  |  |  |
|--|----------|---------------------------------|------|------------|---------|--|--|--|--|--|--|--|--|
|  | ITD      | Paravathi                       | 63   | Domestic   |         |  |  |  |  |  |  |  |  |
|  | ITD      | Nadiar                          | 100  | Domestic   |         |  |  |  |  |  |  |  |  |
|  | ITD      | Kurumallai                      | 25   | Domestic   |         |  |  |  |  |  |  |  |  |
|  | ITD      | UpperSevenmallaiPump(Sprinkler) | 163  | Domestic   |         |  |  |  |  |  |  |  |  |
|  | ITD      | Upper Sevenmallay               | 63   | Domestic   |         |  |  |  |  |  |  |  |  |
|  | ITD      | Ottaparai                       | 63   | Domestic   |         |  |  |  |  |  |  |  |  |
|  | ITD      | Letchmi East                    | 63   | Domestic   |         |  |  |  |  |  |  |  |  |
|  | ITD      | Letchmi Factory Div             | 100  | Domestic   |         |  |  |  |  |  |  |  |  |
|  | ITD      | Letchmi viriparai               | 63   | Domestic   | Metered |  |  |  |  |  |  |  |  |
|  | Nyamakad | Shristi Complex                 | 150  | Mixed      |         |  |  |  |  |  |  |  |  |
|  | Nyamakad | Nullatanni Withering Factory    | 315  | Industrial |         |  |  |  |  |  |  |  |  |
|  | Nyamakad | PERIAVURRAI                     | 1000 | Industrial |         |  |  |  |  |  |  |  |  |
|  | Nyamakad | KANNIAMALLAY                    | 750  | Industrial |         |  |  |  |  |  |  |  |  |
|  | Nyamakad | Talliar                         | 500  | Industrial |         |  |  |  |  |  |  |  |  |
|  | Nyamakad | VAGAVURRAI                      | 630  | Industrial |         |  |  |  |  |  |  |  |  |
|  | Nyamakad | KADALAAR                        | 315  | Industrial |         |  |  |  |  |  |  |  |  |
|  | Nyamakad | Tea Museum                      | 150  | Mixed      |         |  |  |  |  |  |  |  |  |
|  | Nyamakad | DYSP bunglaw                    | 5    | Domestic   |         |  |  |  |  |  |  |  |  |
|  | Nyamakad | Periavurrai lower(top)          | 63   | Domestic   |         |  |  |  |  |  |  |  |  |
|  | Nyamakad | Sholamalai                      | 63   | Domestic   | Metered |  |  |  |  |  |  |  |  |
|  | Nyamakad | Anamudi                         | 63   | Domestic   | Metered |  |  |  |  |  |  |  |  |
|  | Nyamakad | Kanniar Bunglaw                 | 15   | Domestic   |         |  |  |  |  |  |  |  |  |
|  | Nyamakad | Kannimalai top                  | 63   | Domestic   | Metered |  |  |  |  |  |  |  |  |
|  | Nyamakad | Kannimalai lower                | 100  | Domestic   | Metered |  |  |  |  |  |  |  |  |
|  | Nyamakad | Nyamakad blow                   | 63   | Domestic   | Metered |  |  |  |  |  |  |  |  |
|  | Nyamakad | Nyamakad east (office)          | 63   | Domestic   | Metered |  |  |  |  |  |  |  |  |
|  | Nyamakad | Vagavurrai top                  | 63   | Domestic   |         |  |  |  |  |  |  |  |  |
|  | Nyamakad | Vagavurrai lower                | 63   | Domestic   |         |  |  |  |  |  |  |  |  |
|  | Nyamakad | Vagavurrai bazar                | 100  | Domestic   |         |  |  |  |  |  |  |  |  |
|  | Nyamakad | Thalayar blow                   | 63   | Domestic   |         |  |  |  |  |  |  |  |  |

|  |  |           |                               |      |            |         |  |  |  |  |  |  |  |
|--|--|-----------|-------------------------------|------|------------|---------|--|--|--|--|--|--|--|
|  |  | Nyamakad  | thalayar division             | 100  | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Nyamakad  | manager blow                  | 5    | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Nyamakad  | vag fac div                   | 100  | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Nyamakad  | vag naval                     | 150  | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Nyamakad  | vag luckom                    | 63   | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Nyamakad  | Rajamalai west bsnl           | 15   | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Nyamakad  | forest (rajamalai)            | 25   | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Nyamakad  | kadalar blow (east)           | 63   | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Nyamakad  | kadalar hospital              | 100  | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Nyamakad  | kadalar fac div               | 100  | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Nyamakad  | Rajamalai park                | 63   | Mixed      | Metered |  |  |  |  |  |  |  |
|  |  | Nyamakad  | wireless station (sangumalai) | 15   | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Nyamakad  | Rajamalai div                 | 50   | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Nyamakad  | Pettimudi                     | 63   | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Nettigudi | Chokanad Factory              | 1000 | Industrial |         |  |  |  |  |  |  |  |
|  |  | Nettigudi | Lockhart Factory              | 315  | Industrial |         |  |  |  |  |  |  |  |
|  |  | Nettigudi | Guderal Factory               | 750  | Industrial |         |  |  |  |  |  |  |  |
|  |  | Nettigudi | Devikulam Factory             | 400  | Industrial |         |  |  |  |  |  |  |  |
|  |  | Nettigudi | Periyakanal Factory           | 400  | Industrial |         |  |  |  |  |  |  |  |
|  |  | Nettigudi | Chokanad South (fac div)      | 63   | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Nettigudi | Chokanad East (puthukad)      | 63   | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Nettigudi | Chokanad North (vattakad)     | 63   | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Nettigudi | Chokonad K K Division         | 63   | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Nettigudi | Ailsa Craig                   | 63   | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Nettigudi | Ladbrock                      | 75   | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Nettigudi | Earlston                      | 20   | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Nettigudi | Forest (Central Nursery)      | 25   | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Nettigudi | Lockhart Colony               | 63   | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Nettigudi | GuderalManager                | 63   | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Nettigudi | Guderal Factory Division      | 63   | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Nettigudi | BSNL (Silent valley)          | 15   | Domestic   |         |  |  |  |  |  |  |  |

|  |           |                                |     |          |         |  |  |  |  |  |  |  |  |
|--|-----------|--------------------------------|-----|----------|---------|--|--|--|--|--|--|--|--|
|  | Nettigudi | Silent Valley Division (North) | 63  | Domestic |         |  |  |  |  |  |  |  |  |
|  | Nettigudi | Silent Valley office (South)   | 100 | Domestic |         |  |  |  |  |  |  |  |  |
|  | Nettigudi | Guderdale Lower (Nettigudi)    | 63  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Nettigudi | Guderdale Center (middle)      | 63  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Nettigudi | Guderdale Top                  | 63  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Nettigudi | Devikulam Middle               | 63  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Nettigudi | Devikulam Factory Division     | 100 | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Nettigudi | Devikulam ODK Division         | 63  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Nettigudi | Periyakanal PH(top) Division   | 63  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Nettigudi | Ayur County                    | 400 | Mixed    |         |  |  |  |  |  |  |  |  |
|  | Nettigudi | Periyakanal Division           | 100 | Domestic |         |  |  |  |  |  |  |  |  |
|  | Town      | CASA-Casa Mountana Hotel       | 163 | Mixed    |         |  |  |  |  |  |  |  |  |
|  | Town      | GRAND PLAZA MUNNAR             | 160 | Mixed    |         |  |  |  |  |  |  |  |  |
|  | Town      | M.S.HOTELS                     | 160 | Mixed    |         |  |  |  |  |  |  |  |  |
|  | Town      | EVM Hotels                     | 200 | Mixed    |         |  |  |  |  |  |  |  |  |
|  | Town      | KTDC Tea county                | 400 | Mixed    |         |  |  |  |  |  |  |  |  |
|  | Town      | Eastend Hotel                  | 100 | Mixed    |         |  |  |  |  |  |  |  |  |
|  | Town      | General Hospital               | 250 | Mixed    |         |  |  |  |  |  |  |  |  |
|  | Town      | ECOL-ENGINEERING COLLEGE       | 250 | Domestic |         |  |  |  |  |  |  |  |  |
|  | Town      | Old Munnar (tea tasting)       | 100 | Domestic |         |  |  |  |  |  |  |  |  |
|  | Town      | High Range Club                | 100 | Domestic |         |  |  |  |  |  |  |  |  |
|  | Town      | Poopada                        | 150 | Domestic |         |  |  |  |  |  |  |  |  |
|  | Town      | Workshop Club                  | 100 | Domestic |         |  |  |  |  |  |  |  |  |
|  | Town      | Workshop Transformer'          | 100 | Domestic |         |  |  |  |  |  |  |  |  |
|  | Town      | Shikshak Sadan                 | 250 | Domestic |         |  |  |  |  |  |  |  |  |
|  | Town      | RO                             | 150 | Domestic |         |  |  |  |  |  |  |  |  |
|  | Town      | Grahamsland Pump               | 63  | Domestic |         |  |  |  |  |  |  |  |  |
|  | Town      | Teachers Quarters              | 100 | Domestic |         |  |  |  |  |  |  |  |  |
|  | Town      | KWA Pump                       | 100 | Domestic |         |  |  |  |  |  |  |  |  |
|  | Town      | Botanical Garden               | 63  | Domestic |         |  |  |  |  |  |  |  |  |
|  | Town      | Eastend                        | 100 | Domestic |         |  |  |  |  |  |  |  |  |

|  |  |           |   |      |            |         |  |  |  |  |  |  |  |
|--|--|-----------|---|------|------------|---------|--|--|--|--|--|--|--|
|  |  | Town      | BSNL  | 200  | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Town      | Town  | 100  | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Town      | Residency   | 63   | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Town      | Nirmala Society(scientific Div)                     | 150  | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Town      | General Hospital                                    |      | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Town      | KSEB  | 250  | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Town      | OCR   | 63   | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Madupatty | R&D lab   | 63   | Mixed      |         |  |  |  |  |  |  |  |
|  |  | Madupatty | Tenmalay factory                                    | 500  | Industrial |         |  |  |  |  |  |  |  |
|  |  | Madupatty | Madupatty factory                                   | 1000 | Industrial |         |  |  |  |  |  |  |  |
|  |  | Madupatty | Madupatty hydel                                     |      |            | Metered |  |  |  |  |  |  |  |
|  |  | Madupatty | High tech KLD board                                 | 200  | Industrial |         |  |  |  |  |  |  |  |
|  |  | Madupatty | Indo swiss project                                  |      | Industrial |         |  |  |  |  |  |  |  |
|  |  | Madupatty | Gundumalay factory                                  | 1000 | Industrial |         |  |  |  |  |  |  |  |
|  |  | Madupatty | Aruvikkad factory                                   | 250  | Industrial |         |  |  |  |  |  |  |  |
|  |  | Madupatty | Yelapatty factory                                   | 315  | Industrial |         |  |  |  |  |  |  |  |
|  |  | Madupatty | Chunduvarrai factory                                | 630  | Industrial |         |  |  |  |  |  |  |  |
|  |  | Madupatty | Chittivurrai factory                                | 250  | Industrial |         |  |  |  |  |  |  |  |
|  |  | Madupatty | WestWood Hotel                                      | 160  | Mixed      |         |  |  |  |  |  |  |  |
|  |  | Madupatty | Microwave   | 25   | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Madupatty | Grahamsland Office                                  | 63   | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Madupatty | Grahamsland Bazar                                   | 5    | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Madupatty | Grahamsland Bunglaw (Velmudi)                       | 63   | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Madupatty | KKD Church (Korandikad dn)                          | 63   | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Madupatty | High Range School                                   | 150  | Mixed      |         |  |  |  |  |  |  |  |
|  |  | Madupatty | Madupatty Top Dn.                                   | 63   | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Madupatty | R & D Complex                                       | 63   | Domestic   |         |  |  |  |  |  |  |  |
|  |  | Madupatty | Thenmalai AsstManager<br>Bunglaw(Hospital Division) | 63   | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Madupatty | Thenmalai Factory Dn                                | 100  | Domestic   | Metered |  |  |  |  |  |  |  |
|  |  | Madupatty | Thenmalai New Division                              | 25   | Domestic   | Metered |  |  |  |  |  |  |  |



|  |           |  |     |          |         |  |  |  |  |  |  |  |  |
|--|-----------|--|-----|----------|---------|--|--|--|--|--|--|--|--|
|  | Madupatty | Madupetty Godown                       | 315 | Domestic |         |  |  |  |  |  |  |  |  |
|  | Madupatty | Netimadu Division                      | 63  | Domestic |         |  |  |  |  |  |  |  |  |
|  | Madupatty | Gundumallay Factory dvn                | 100 | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | GUNDUMALLAY Benmure                    | 63  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | Gundumalay Sothupara (Top Dn)          | 63  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | Gundumalay BSNL(Sothuparai BSNL tower) | 15  | Domestic |         |  |  |  |  |  |  |  |  |
|  | Madupatty | Gundumalay New Dn                      | 25  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | Gundumalay Upper Dn                    | 63  | Domestic |         |  |  |  |  |  |  |  |  |
|  | Madupatty | Gundumalay Lower Dn                    | 63  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | Gundumalay Kadugu                      | 15  | Domestic |         |  |  |  |  |  |  |  |  |
|  | Madupatty | New pump indo swiss (irrigation)       | 163 | Domestic |         |  |  |  |  |  |  |  |  |
|  | Madupatty | Aruvikad Division                      | 100 | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | Eco Point                              | 63  | Domestic |         |  |  |  |  |  |  |  |  |
|  | Madupatty | East divsn pachakkad                   | 63  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | Kundaly Naturals (medicinalPlant)      | 150 | Domestic |         |  |  |  |  |  |  |  |  |
|  | Madupatty | Puthukadi                              | 63  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | Yelapetty                              | 100 | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | Kundale office                         | 63  | Domestic |         |  |  |  |  |  |  |  |  |
|  | Madupatty | Theerthamalai                          | 75  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | Chundubarai Old factory                | 63  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | PR Division`                           | 63  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | Top DN(CHUNDAVURRAI)                   | 63  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | Kundale Club                           | 5   | Domestic |         |  |  |  |  |  |  |  |  |
|  | Madupatty | Chittivurrai Factory Div               | 100 | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | Chittivurri pump (new Div)             | 100 | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | Chittivurrai OC Division               | 63  | Domestic | Metered |  |  |  |  |  |  |  |  |
|  | Madupatty | KUNDALAY Cattle shed                   | 5   | Domestic |         |  |  |  |  |  |  |  |  |

**Note: The DT level input energy is not recorded by the DISCOM that results in non-evaluation of DT level losses.**

## 9. FIELD VERIFICATION DATA

### ENERGY & POWER QUALITY ANALYSIS) - AT SWITCHING STATION

The objective of this section is to establish how the facility is performing in terms of energy consumption and the quality of power at the switching station.

#### ➤ Incomer 1 & 2, 3 - Measurement Evaluation

The continuous power measurement of incomer feeders (Pullivasal feeder 1&2, chithirapuram feeder no-3) conducted using the Krykard ALM 35 and ALM 31 series power quality analysers. The incomer side was logged for 24 hours and measured data is summarized in the following table. The measurement-averaging period was 02 minutes. The measurement was done on 30<sup>th</sup> & 31<sup>st</sup> July 2023.

The summary of measured parameters of the transformer is given in the table below.

Table 77: Incomer Measurement Data

| Incomer Name           |       | Incomer 1&2                                   | Incomer 3                                     |   |
|------------------------|-------|---|---|---|
| Date of measurement    |       | 30 <sup>th</sup> & 31 <sup>st</sup> July 2023 | 30 <sup>th</sup> & 31 <sup>st</sup> July 2023 |   |
| Basic Parameters       |       |   |   | Remarks   |
| Parameters             | Units | Incomer 1&2                                   | Incomer 3                                     |   |
| Voltage line (kV)      | Min   | 9.89  | 0   | Power failure in Incomer-3 for a period of 05 minutes |
|                        | Avg   | 10.49   | 10.49   |   |
|                        | Max   | 11.06   | 11.1  |   |
| Current (A)            | Min   | 99.52   | 0   | Power failure in Incomer-3 for a period of 05 minutes |
|                        | Avg   | 237.4   | 141.7   |   |
|                        | Max   | 632.88  | 193.6   |   |
| Frequency (Hz)         | Min   | 49.8  | 49.29   |   |
|                        | Avg   | 50  | 50  |   |
|                        | Max   | 50.18   | 50.18   |   |
| Energy Parameters      |       |   |   |   |
| Parameters             | Units | Incomer 1&2                                   | Incomer 3                                     |   |
| Energy consumed (kWh)  | Total | 104969.46                                     | 62545.77                                      |   |
| Energy received (kVAh) | Total | 106341.27                                     | 63701.76                                      |   |
| Power factor           |       | 0.986   | 0.98  |   |
| Active power (kW)      | Min   | 1896.6  | 0   | Power failure in Incomer-3 for a period of 05 minutes |
|                        | Avg   | 4232.6  | 2522  |   |
|                        | Max   | 6165.8  | 3330.8  |   |
| Apparent power (kVA)   | Min   | 1914.3  | 0   |   |
|                        | Avg   | 4287.9  | 2568.6  |   |
|                        | Max   | 6257.1  | 3363.4  |   |
| Reactive power (kVAr)  | Min   | -604.4  | 0   | Power failure in Incomer-3 for a period of 05 minutes |
|                        | Avg   | 129.4   | 612.8   |   |

|                                 |              |                        |                  |                |
|---------------------------------|--------------|------------------------|------------------|----------------|
|                                 | Max          | 596.3                  | 847.3            |                |
| <b>Power quality parameters</b> |              |                        |                  |                |
| <b>Parameters</b>               | <b>Units</b> | <b>Incomer 1&amp;2</b> | <b>Incomer 3</b> | <b>Remarks</b> |
| Voltage imbalance %             | Min          | 0.5                    | 0.1              |                |
|                                 | Avg          | 0.59                   | 0.29             |                |
|                                 | Max          | 0.7                    | 0.5              |                |
| Current imbalance %             | Min          | 0.5                    | 1                |                |
|                                 | Avg          | 1.26                   | 2.19             |                |
|                                 | Max          | 2.2                    | 4.5              |                |
| THDv %                          | Min          | 0.3                    | 1.3              |                |
|                                 | Avg          | 0.62                   | 1.66             |                |
|                                 | Max          | 1.1                    | 2.1              |                |
| THDa %                          | Min          | 1.1                    | 0.7              |                |
|                                 | Avg          | 2.4                    | 1.7              |                |
|                                 | Max          | 6.4                    | 5.9              |                |

➤ **Electrical Parameters - Profile**

**10.1.1 Power Variations - Incomer**




Figure 17: Power variations – continuous logged data

**10.1.2 Demand Variations - Incomer**




Figure 18: Demand variations – continuous logged data




Figure 19: RMD – Real time

- The maximum demand registered in 30-minute cycle in the continuous logging of 24-hour measurement at Pullivasal switching station after summing up the two incomer metering points was 9298 kVA (9.29 MVA) at 20:00 hours.

**10.1.3 Power Factor Variations - Incomer**




Figure 20: Power factor – variations

## ➤ Power Quality

Harmonics study revolves around the use of non-linear loads that are connected to electric power systems including static power converters, arc discharge devices, saturated magnetic devices and to a lesser degree, rotating machines. Static power converters of electric power are the largest non-linear loads and are used in industry for a variety of purposes such as electro- chemical power supplies, adjustable speed drives, and uninterruptible power supplies.

Table 78: CURRENT HARMONICS LIMIT (IEEE 519-2014)

| Maximum harmonic current distortion<br>in percent of $I_L$ |                 |                  |                  |                  |                     |      |
|--|-----------------|------------------|------------------|------------------|---------------------|------|
| Individual harmonic order (odd harmonics) <sup>a, b</sup>  |                 |                  |                  |                  |                     |      |
| $I_{sc}/I_L$   | $3 \leq h < 11$ | $11 \leq h < 17$ | $17 \leq h < 23$ | $23 \leq h < 35$ | $35 \leq h \leq 50$ | TDD  |
| $< 20^c$   | 4.0             | 2.0              | 1.5              | 0.6              | 0.3                 | 5.0  |
| $20 < 50$  | 7.0             | 3.5              | 2.5              | 1.0              | 0.5                 | 8.0  |
| $50 < 100$   | 10.0            | 4.5              | 4.0              | 1.5              | 0.7                 | 12.0 |
| $100 < 1000$   | 12.0            | 5.5              | 5.0              | 2.0              | 1.0                 | 15.0 |
| $> 1000$   | 15.0            | 7.0              | 6.0              | 2.5              | 1.4                 | 20.0 |

<sup>a</sup>Even harmonics are limited to 25% of the odd harmonic limits above.  
<sup>b</sup>Current distortions that result in a dc offset, e.g., half-wave converters, are not allowed.  
<sup>c</sup>All power generation equipment is limited to these values of current distortion, regardless of actual  $I_{sc}/I_L$ .  
 where  
 $I_{sc}$  = maximum short-circuit current at PCC  
 $I_L$  = maximum demand load current (fundamental frequency component) at the PCC under normal load operating conditions

Table 79: VOLTAGE HARMONICS LIMIT (IEEE 519-2014)

| Voltage distortion limits     |                                 |                                      |
|-------------------------------|---------------------------------|--------------------------------------|
| Bus voltage at PCC            | Individual voltage distortion % | Total voltage harmonics distortion % |
| $V \leq 01$ kV                | 5.0                             | 8.0                                  |
| $01$ kV $< V \leq 69$ kV      | 3.0                             | 5.0                                  |
| $69.001$ kV $< V \leq 161$ kV | 1.5                             | 2.5                                  |
| $161.001$ kV and above        | 1.0                             | 1.5                                  |

Harmonic limits at the KDHP incomer is given in the table below:

Table 80: Standard limits as per the IEEE 519-2014 – at KDHP incomer

|   |   |               |
|---|---|---------------|
| 2. Normal range of $I_{sc}/I_L$ at KDHP incomer         | - | <b>&lt;20</b> |
| 3. Maximum standard Total demand distortion – current   | - | 5%            |
| 4. Maximum standard Total harmonic distortion – voltage | - | 5%            |

Harmonic values at the KDHP incomer are given in the table below:

Table 81: Harmonics values – KDHP incomer

| Particulars   | THDv max | THDa max | Remarks                  |
|---------------|----------|----------|--------------------------|
|               | %        | %        |                          |
| Incomer 1 & 2 | 1.1      | 6.4      | Higher current harmonics |
| Incomer 3     | 2.1      | 5.9      | Higher current harmonics |

10.1..1 Harmonic spectrum

➤ Voltage harmonic spectrum:




Figure 21: Voltage harmonic spectrum

➤ Current harmonic spectrum:




Figure 22: Current harmonic spectrum

## **OBSERVATIONS AND RECOMMENDATION – ELECTRICAL NETWORK CONFIGURATION**

*Table 82: Observations & recommendation – electrical network configuration*

| Observation  | Recommendation   | Benefit   |
|--|--|---|
| <b>Overhead lines (OH) and cables</b>  |  |   |
| <ul style="list-style-type: none"> <li>31.1 % in the total 11 kV cable is of ACSR type which corresponds to 56.09 km out of 180.23 km.</li> <li>Also 34.6% of the total 11 kV is Cu which corresponds to 62.13 out of 180.23 km.</li> </ul>  | <ul style="list-style-type: none"> <li>Replace these OH 11 kV lines with DOG which has a resistance of 0.2792 ohms/km.</li> </ul>  | <ul style="list-style-type: none"> <li>This will reduce the distribution loss as well as energy consumption.</li> </ul>   |
| <b>Incomer measurement evaluation</b>  |  |   |
| <ul style="list-style-type: none"> <li><b>Real time Demand</b> variation shows that the maximum demand registered at Peak period (6pm – 10pm) was 9.29 MVA which is an excess of the contract demand 9 MVA.</li> <li>The real time data does not consider the Madupatty generation input which is 2 MW.</li> </ul> | <ul style="list-style-type: none"> <li>This shows that the contract demand needs to increase. However, the present switching station does not cater as it is 11 kV and require to substitute with 33 kV new substation in order to increase the demand.</li> <li>The construction of a new 33 kV substation is in progress during the period of audit. The proposed site was near to town to reduce the line length of 2.5 kms.</li> </ul> | <ul style="list-style-type: none"> <li>This will avoid the excess demand charges and more importantly will be able to cater the future loads in the Munnar area.</li> </ul> |
| <b>Energy &amp; power quality analysis</b>   |  |   |
| <ul style="list-style-type: none"> <li>Average total current harmonic distortion at the incomer is in the range of 1 to 3%.</li> <li>Average total voltage harmonic distortion at the incomer is in the range of 0.3 to 1.11%.</li> </ul>  | <ul style="list-style-type: none"> <li>The current THD values are within the IEEE 519 standard limit (&lt;5%).</li> <li>The voltage THD values are within the IEEE 519 standard limit (&lt;3%)</li> </ul>  | <ul style="list-style-type: none"> <li>NIL</li> </ul>   |



## PICTURES

### ➤ Different types of energy meters used in KDHP



Static TOD meter mostly used for HT consumers (Industries) under the KDHP



TOD meter mostly used for HT consumers under the KDHP



TOD meter mostly used for HT consumers under the KDHP

➤ **General photos**



Distribution Transformer sample



Switching station yard

### **SAMPLES OF TSOFT DATA**

These are the data collection format that received from the T soft (KDHP software) for the energy audit data preparation.

*Table 83: Sample feeder wise consumer list – for reference only*

| Feeder wise Consumer list: for the month 202301 |                  |                  |                 |                        |              |                        |             |                         |                |      |     |     |
|---|------------------|------------------|-----------------|------------------------|--------------|------------------------|-------------|-------------------------|----------------|------|-----|-----|
| Feeder  | Transformer Type | Transformer Name | Estate Name     | Division Name          | Category     | Sub Category           | Consumer No | Consumer Name           | Connected Load | Jan  | Feb | Mar |
| FDR7-ITD Feeder                                 | Step Down        | KLFD-Factory dn. | E06-NULLATA NNI | A-Null - O N East      | Low Tension  | LT-I (Domestic) HT - I | 10519       | MAH ABIR SINGH          | 1              |      |     | 18  |
| FDR7-ITD Feeder                                 | Step Down        | KLFD-Factory dn. | E06-NULLATA NNI | F-Kala - Factory House | High Tension | (Industrial)           | 15728       | KALARARAJA              | 1E+05          | #### | ### |     |
| FDR7-ITD Feeder                                 | Step Down        | KLFD-Factory dn. | E06-NULLATA NNI | F-Kala - Factory House | Low Tension  | LT-I (Domestic)        | 10443       | NATA RAJA               | 1              | 20   | 40  | 39  |
| FDR7-ITD Feeder                                 | Step Down        | KLFD-Factory dn. | E06-NULLATA NNI | F-Kala - Factory House | Low Tension  | LT-I (Domestic)        | 10473       | M RAJ                   | 1              | 100  | 40  | 60  |
| FDR7-ITD Feeder                                 | Step Down        | KLFD-Factory dn. | E06-NULLATA NNI | F-Kala - Factory House | Low Tension  | LT-I (Domestic)        | 10500       | RAJA N                  | 1              | 35   | 44  | 25  |
| FDR7-ITD Feeder                                 | Step Down        | KLFD-Factory dn. | E06-NULLATA NNI | F-Kala - Factory House | Low Tension  | LT-I (Domestic)        | 10549       | KUMAR PAUL OSE - (2458) | 1              | 39   | 42  | 32  |
| FDR7-ITD Feeder                                 | Step Down        | KLFD-Factory dn. | E06-NULLATA NNI | F-Kala - Factory House | Low Tension  | LT-I (Domestic)        | 10554       | 2458                    | 1              | 25   | 18  | 7   |
| FDR7-ITD Feeder                                 | Step Down        | KLFD-Factory dn. | E06-NULLATA NNI | F-Kala - Factory House | Low Tension  | LT-I (Domestic)        | 10559       | PREMALATHA              | 1              | 50   | 64  | 40  |

## **10. LIST OF DOCUMENTS VERIFIED WITH EACH PARAMETER**

The following are the documents verified during Annual Energy Audit:

*Table 84: List of Documents verified*


| <b>FY 2022-23 Data Verification</b>    |  |   |
|--|--|---|
| <b>Sl No</b>                           | <b>Name</b>                                    | <b>Name Supporting Document</b>                         |
| <b>Input Energy</b>                    |  |   |
| 1                                      | Input Energy (MU)                              | Electricity bill of FY April 2022-March 2023 from KSEBL |
| <b>Feederwise Losses</b>               |  |   |
| 2                                      | Feederwise Energy Accounting                   | T-soft - KDHP s/w                                       |
| 3                                      | No of connection metered (Nos)                 | T-soft - KDHP s/w                                       |
| 4                                      | No of connection Unmetered (Nos)               | T-soft - KDHP s/w                                       |
| 5                                      | Connected Load Metered (MW)                    | T-soft - KDHP s/w                                       |
| 6                                      | Connected Load Unmetered (MW)                  | T-soft - KDHP s/w                                       |
| 7                                      | Input Energy (MU)                              | T-soft - KDHP s/w                                       |
| 8                                      | Metered energy (MU)                            | T-soft - KDHP s/w                                       |
| 9                                      | Unmetered energy/Assessment Energy (MU)        | T-soft - KDHP s/w                                       |
| 10                                     | T&D Losses (MU)                                | T-soft - KDHP s/w                                       |
| 11                                     | Collected Amount                               | T-soft - KDHP s/w                                       |
| 12                                     | AT&C Loss                                      | T-soft - KDHP s/w                                       |
| <b>Details of Input Energy Sources</b> |  |   |
| 13                                     | Generation at Transmission Periphery (Details) | T-soft - KDHP s/w                                       |
| 14                                     | Embedded Generation in DISCOM Area             | T-soft - KDHP s/w                                       |

## 11. DETAILED FORMATS TO BE ANNEXED

## BALANCE SHEET - FY 2021-22

| Form D BS   |   |       |   |                   |         |
|---|---|-------|---|-------------------|---------|
| Balance Sheet at the end of the year                              |   |       |   |                   |         |
| Name of Distribution Business/Licensee<br>Licensed Area of Supply |   |       | Kanan Devan Hills Plantations Company Private Limited<br>Munnar |                   |         |
| Rs. In lakh   |   |       |   |                   |         |
| S.No.   | Particulars   | Ref   | Previous Year   | Current Year      | Remarks |
|   |   |       | Actual<br>2020/21   | Actual<br>2021/22 |         |
| 1   | 2   | 3     | 4   | 5                 | 6       |
|   | Sources of Funds:   |       |   |                   |         |
|   | (A) Capital Funds:  |       |   |                   |         |
|   | Share Capital (Govt. equity)  |       | -   | -                 |         |
|   | Reserves & Surplus  |       | (1,000.31)  | (1,031.80)        |         |
|   | Total (A)   |       | (1,000.31)  | (1,031.80)        |         |
|   | (B) Loans:  |       |   |                   |         |
|   | Loan from State Government  |       | -   | -                 |         |
|   | Loan from others:   |       |   |                   |         |
|   | - Secured   |       | -   | -                 |         |
|   | - Unsecured   |       | -   | -                 |         |
|   | Total (B)   |       | -   | -                 |         |
|   | (C) Contribution, grants & subsidies towards cost of capital assets     | D 3.5 | 7.89  | 7.89              |         |
|   | Grand total of sources of funds (A+B+C)                                 |       | (992.42)  | (1,023.91)        |         |
|   | Application of Funds:   |       |   |                   |         |
|   | A) Fixed assets   |       |   |                   |         |
|   | a) Gross fixed assets   | D 3.5 | 427.85  | 431.76            |         |
|   | b) Less accumulated depreciation  | D 3.5 | 218.57  | 241.53            |         |
|   | c) Net Fixed assets ((a)-(b))   |       | 209.28  | 190.23            |         |
|   | d) Capital works in progress  | D 4.1 | 9.55  | 16.34             |         |
|   | e) Assets not in use  |       | -   | -                 |         |
|   | f) Deferred costs   |       | -   | -                 |         |
|   | g) Intangible assets  |       | -   | -                 |         |
|   | h) Investments  |       | -   | -                 |         |
|   | Total (c)+(d)+(e)+(f)+(g)+(h)   |       | 218.83  | 206.57            |         |
|   | B) Subsidy receivable from Government                                   |       | -   | -                 |         |
|   | Contribution receivable from State Government towards pension liability |       | -   | -                 |         |
|   | C) Net Current Assets   |       |   |                   |         |
|   | (1) Current assets, loans and advances                                  |       |   |                   |         |
|   | a) Deposit with KSEB  |       | 247.28  | 247.28            |         |
|   | b) Receivables against Sale of Power                                    |       | 112.71  | 51.25             |         |
|   | c) Cash & bank balances   |       | -   | -                 |         |
|   | d) Loans and advances   |       | -   | -                 |         |
|   | e) Interest receivable  |       | 116.28  | 116.28            |         |
|   | f) Prepaid expenses   |       | 0.52  | -                 |         |
|   | Total (C) (1)   |       | 476.79  | 414.81            |         |
|   | (2) Current liabilities & provisions                                    |       |   |                   |         |
|   | a) Security Deposits from Consumers                                     |       | 230.25  | 196.29            |         |
|   | b) Borrowings for working capital                                       |       | -   | -                 |         |
|   | c) Payments due on capital liabilities                                  |       | -   | -                 |         |
|   | d) Current Account Balances with other operations                       |       | 1,197.07  | 1,189.67          |         |
|   | e) Other current liabilities  |       | 260.72  | 259.33            |         |
|   | Total (C) (2)   |       | 1,688.04  | 1,645.28          |         |
|   | Net Current Assets (C(1) - C(2))  |       | (1,211.25)  | (1,230.48)        |         |
|   | Grand Total of Application of funds (A)+(B)+(C)                         |       | (992.42)  | (1,023.91)        |         |

In terms of our Report attached

For Deloitte Haskins & Sells LLP  
Chartered Accountants

Krishna Prakash E  
Partner

Coimbatore, November 2, 2022.


For Kanan Devan Hills Plantations  
Company Private Limited
  
P M Srikumar  
Executive Director & CFO  
Munnar, November 2, 2022.



FIGURE 23: BALANCE SHEET FY 2021-22




**PROFIT & LOSS STATEMENT - FY 2021-22**

| Form D P&L                             |   |          |   |                                |         |
|--|---|----------|---|--------------------------------|---------|
| Profit & Loss Account                  |   |          |   |                                |         |
| Name of Distribution Business/Licensee |   |          | Kanan Devan Hills Plantations Company Private Limited |                                |         |
| Licensed Area of Supply                |   |          | Munnar  |                                |         |
| Rs. In lakh                            |   |          |   |                                |         |
| S. No.                                 | Particulars   | Ref      | Previous Year Actual<br>2020/21                       | Current Year Actual<br>2021/22 | Remarks |
| 1                                      | 2   | 3        | 4   | 5                              | 6       |
|  | <b>I. INCOME</b>  |          |   |                                |         |
|  | a. Revenue from Sale of Power   | D 2.1    | 2,884.83  | 2,955.48                       |         |
|  | b. Revenue Subsidies and Grants   |          | -   | -                              |         |
|  | c. Other Income   | D 2.4    | 11.66   | 5.33                           |         |
|  | Total (a+b+c)   |          | 2,896.49  | 2,960.81                       |         |
|  | <b>II. EXPENDITURE</b>  |          |   |                                |         |
|  | a. Repairs and Maintenance  | D 3.4(c) | 48.55   | 52.84                          |         |
|  | b. Employee Cost  | D 3.4(a) | 166.07  | 172.12                         |         |
|  | c. Administration and General Expenses                                      | D 3.4(b) | 10.34   | 17.33                          |         |
|  | d. Depreciation   | D 3.5    | 22.71   | 22.96                          |         |
|  | e. Interest and Finance charges   | D 3.7    | 17.73   | 18.78                          |         |
|  | f. Subtotal ( a+b+c+d+e)  |          | 265.40  | 284.03                         |         |
|  | g. Less Capitalised Expenses:   |          |   |                                |         |
|  | - Interest & Finance Charges  |          | -   | -                              |         |
|  | - Other Expenses  |          | -   | -                              |         |
|  | h. Other Debits   | D 4.3    | 12.95   | 14.08                          |         |
|  | i. Extra Ordinary Items   |          | -   | -                              |         |
|  | j. Purchase of power  | D 3.1    | 2,689.53  | 2,694.19                       |         |
|  | k. Generation of Power  |          | -   | -                              |         |
|  | Total Expenditure (f-g+h+i+j+k)   |          | 2,967.88  | 2,992.30                       |         |
|  | Return on Net Fixed Assets  | D 3.8    | -   | -                              |         |
|  | III. Profit/(Loss) before Tax (I-II)  |          | (71.39)   | (31.49)                        |         |
|  | IV. Provision for Income Tax  |          | -   | -                              |         |
|  | V. Net Prior period credits / (Charges)                                     |          | -   | -                              |         |
|  | VI. Surplus/(Deficit)   |          | (71.39)   | (31.49)                        |         |
|  | VII. Net Assets at the beginning of the year (Less consumer's Contribution) |          | 219.38  | 201.39                         |         |
|  | VIII. Rate of Return (VI/VII)   |          | -33%  | -16%                           |         |

In terms of our Report attached

For Deloitte Haskins & Sells LLP  
Chartered AccountantsKrishna Prakash E  
Partner

Coimbatore, November 2, 2022.

For Kanan Devan Hills Plantations  
Company Private Limited  
P M Srikrishnan,  
Executive Director & CFO

Munnar, November 2, 2022.



FIGURE 24: P&amp;L SHEET FY 2021-22

**ELECTRICITY BILL - KSEBL**

**KERALA STATE ELECTRICITY BOARD LIMITED**  
Office of the Special Officer(Revenue), Paltoom, Thiruvananthapuram  
**DEMAND NOTICE FOR MARCH 2023**  
(As per CHAPTER VII OF KERALA ELECTRICITY SUPPLY CODE -2014)

|                         |                       |                      |                             |
|-------------------------|-----------------------|----------------------|-----------------------------|
| Con. No. 1356150003999  | Bill Date 06-Mar-2023 | Due Date 13-Mar-2023 | B# No 11028111053732 Ver: 0 |
| Tariff Licensee: KDHPCL | Last Date 25-Mar-2023 | CD 25227840          | BG 71840563                 |

**KANAN DEVAN HILLS PLANTATIONS COMPANY PVT. LTD**  
Munnar Workshop,  
Munnar P. O.,  
Idukki 685612.,  
Mobile no-9461306230

LCN :21/1014

SBI Virtual A/c No(IFSC Code:SBIN0070493),KSEBHT1C1014  
Multiple Reading Billing  
Other Consumption/Deducted Normal kWh:390509.0/Peak kWh:0.0/Oil/Peak kWh:0.0  
Consumer GSTIN\_ID -KSEB (LJGST ID-32AAECK2277NBZ1  
TDS u/s 194Q 24602.69

|                             |                           |                                      |                                    |
|-----------------------------|---------------------------|--------------------------------------|------------------------------------|
| Areas as on 31-Jan-2023     |                           | Date of Previous Reading 31-Jan-2023 | Email: engineering.munnar@kdhptea. |
| Disputed                    | Undisputed                | Date of Present Reading 28-Feb-2023  | Supply Voltage 11 kV EHT           |
| Contract Demand(KVA) 8000.0 | 75% of CD (KVA) 6750.0    | 130% of CD (KVA) 11700.0             | Connected Load (KW) 0              |
| Average                     |                           | Billing Type Non-DPS                 | Section Chithirapuram              |
| MD (KVA) 11614.15           | Consumption (KWh) 4876443 | PF 0.97                              | Circle Thodupuzha                  |

**Reading Details of meter 5779m-Working (KVA,KWh,KVAh & KVArh) for 02-2023**

| 1. Energy Consumption(KWh) |      |      |         | 3. Energy Consumption(KVArh) Lag and kVArh (Lead) |       |      |      |         |        |             |      |        |        |
|----------------------------|------|------|---------|---|-------|------|------|---------|--------|-------------|------|--------|--------|
| Zone                       | FR   | IR   | MF      | Units   | Zone  | FR   | IR   | MF      | Units  | FR          | IR   | Units  |        |
| 1                          | 0.00 | 0.00 | 100.000 | 2559620   | 1     | 0.00 | 0.00 | 100.000 | 160700 | 0.00        | 0.00 | 117800 |        |
| 2                          | 0.00 | 0.00 | 100.000 | 815160  | 2     | 0.00 | 0.00 | 100.000 | 0      | 0.00        | 0.00 | 0      |        |
| 3                          | 0.00 | 0.00 | 100.000 | 977520  | 3     | 0.00 | 0.00 | 100.000 | 0      | 0.00        | 0.00 | 0      |        |
| Total                      |      |      |         | 4352300   | Total |      |      |         | 160700 | kVArh(Lead) |      |        | 117800 |

| 2. Energy Consumption(KVAh) |      |      |         | 4. Demand (KVA)       |                        |    |    |        |
|-----------------------------|------|------|---------|-----------------------|------------------------|----|----|--------|
| Zone                        | FR   | IR   | MF      | Units                 | Zone                   | FR | MF | Units  |
| 1                           | 0.00 | 0.00 | 100.000 | 2229340               | 1                      |    |    | 117.75 |
| 2                           | 0.00 | 0.00 | 100.000 | 820480                | 2                      |    |    | 87.02  |
| 3                           | 0.00 | 0.00 | 100.000 | 988720                | 3                      |    |    | 65.43  |
| Total                       |      |      |         | 4038540               | 5.Factory Lighting 0.0 |    |    |        |
| Ave.PF=kWh/KVAh 0.95        |      |      |         | 6.Colony Lighting 0.0 |                        |    |    |        |
|                             |      |      |         | 7.Generator 0         |                        |    |    |        |

**INVOICE**

| Unit                                     | Rate    | Amount (Rs) | Amount             |
|--|---------|-------------|--------------------|
| <b>1.Total Demand Charge</b>             |         |             |                    |
| a. Demand Charge                         | 11775.0 | 380.000     | 3541980.00         |
| b.                                       | 0.0     | 380.000     | 0.00               |
| c.                                       | 0.0     | 380.000     | 0.00               |
| d. Excess Demand Charge                  | 2775    | 190.000     | 60990.00           |
| e.                                       |         | 190.000     | 0.00               |
| f.                                       |         | 190.000     | 0.00               |
| Sub Total (a+b+c+d+e+f)                  |         |             | 3602970.00         |
| <b>2.Total Energy Charges</b>            |         |             |                    |
| a. Energy charges                        | 3961791 | 5.30000     | 20997492.30        |
| b.                                       |         | 7.95000     | 0.00               |
| c.                                       |         | 3.97500     | 0.00               |
| Sub Total(a+b+c)                         |         |             | 20997492.30        |
| 3.PF Incentive / Disincentive            |         |             | -419949.85         |
| Total Energy Charge                      |         |             | 20577542.45        |
| <b>4.Energy Charges on Lighting load</b> |         |             |                    |
| a. Factory Lighting                      |         | 0           | 0.1                |
| b. Colony Lighting                       |         | 0           | 0.1                |
| Sub Total(a+b)                           |         |             | 0.00               |
| 5.Electricity Duty                       |         | 20997492    | 0.100              |
| 6.Ele. Surcharge                         |         | 4352300     | 0.025              |
| 7.Duty on self generated energy          |         | 0           | 0.012              |
| 8.Penalty for non-segn. of light load    |         |             | 0.00               |
| 9. Plus/Minus (Round off)                |         |             | -0.45              |
| UnDisputed Arr Amount                    |         |             |                    |
| Less 1. Advance / Credit                 |         |             | 0.00               |
| 2. CD Interest                           |         |             | 0.00               |
| 3. CD Refund                             |         |             | 0.00               |
| <b>Net Payable</b>                       |         |             | <b>24180512.00</b> |

(Rupees Two Crore Forty One Lakh Eighty Thousand Five Hundred Twelve Only)

E & O.E. Balance Advance at Credit, if any

*Verified by Special Officer*

As per Regulation 130 of Kerala Electricity Supply Code 2014 any complaint regarding accuracy of a bill shall be first taken up with the officer designated to issue the bill (Special Officer(Revenue)). Please follow our official Facebook page fb.com/ksebl for information & announcements.(Please see the instructions overleaf)

SPECIAL OFFICER (REVENUE)

1356150003999      11028111053732      Rs.24180512.00      March 2023

KANAN DEVAN HILLS PLANTATIONS COMPANY PVT. LTD.

DD/Payment Instruction      Name of the      Date      Signature

FIGURE 25: KSEB BILL – MARCH 2023 – SAMPLE COPY

**ELECTRICITY BILL - CALCULATION SHEET**

| Kanan Devan Hills Plantations Company Private Limited |   |               |                    |
|---|---|---------------|--------------------|
| Calculation sheet for FEB-2023                        |   |               |                    |
| Sl.   | Description                             | Unit          | Value              |
| 1   | Contract Demand(KVA)                    |               | 9000               |
| 2   | 75% OF CONTRACT DEMAND KVA              |               | 6750               |
| Record Maximum Demand(KVA)                            |   |               |                    |
|   | 1)Pullivasal                            |               | 9951               |
|   | 2)Madupatty                             |               | 1824               |
| <b>Total(KVA)</b>                                     |   |               | <b>11775</b>       |
| Energy Consumption(Kwh.)                              |   |               |                    |
|   | 1)Pullivasal                            |               | 3996580            |
|   | 2)Madupatty                             |               | 354560             |
| <b>Total(Kwh)</b>                                     |   |               | <b>4351140</b>     |
| H.T Feed Back-Vagavurrai                              |   |               |                    |
|   | Energy (Kwh.)                           |               | 17160              |
|   | Energy Including 4%(Kwh)                |               | 17846              |
|   | Feed Back Maximum Demand(KVA)           |               | 899                |
| L.T Feed Back Points(Kwh.)                            |   |               |                    |
|   | 1)Madupatty Dam                         | 39.6          | 13070              |
|   | 2)Headworks                             |               |                    |
|   | 3)Kundalay Dam                          | 10.8          | 3181               |
|   | 4)Harijan Colony-Kundalay               | 22.7          | 6239               |
|   | 5)PHE Colony-Munnar                     | 27.6          | 5760               |
|   | 6)Harijan Colony-Munnar                 | 412.2         | 113900             |
|   | 7)Devikulam Water Authority             | 34.4          | 9672               |
|   | 8)Devikulam Colony                      | 191.4         | 64176              |
|   | 9)AIR Devikulam                         | 18            | 3528               |
|   | 10)Chittavurrai(Vattavada)              | 262.8         | 79384              |
|   | 11)Harijan Colony-Letchmi               | 135           | 50644              |
|   | 12)Direct Feedback to KSEB              | 3             | 60                 |
|   | 13)Edamalakudi(pettimudi) C.MD          | 84            | 1600               |
|   | 14)Kutiar valy(Korandakad) C.MD         | 314           | 6000               |
|   | <b>Total</b>                            | <b>1555.5</b> | <b>357214</b>      |
|   | 4% loss                                 |               | 371503             |
|   | 15)Marayoor                             | 898.8         | 17846              |
|   | <b>Total Feed Back Consumption(Kwh)</b> | <b>2454</b>   | <b>389349</b>      |
|   | KDHP Consumption                        | 9321          | 3961791            |
|   | <b>KDHP Bill</b>                        | <b>Rate</b>   | <b>Total</b>       |
|   | <b>MD Charge</b>                        | 380           | 3602970            |
|   | <b>Energy Charges</b>                   | 5.3           | 20997492.3         |
|   | <b>Less Power Factor Incentive</b>      | 0.99          | 419949.84          |
|   | <b>Total</b>                            |               | <b>24180512.46</b> |
|   | <b>TDS Charges</b>                      |               | <b>24181</b>       |
|   | <b>Total Payable</b>                    |               | <b>24156331.46</b> |



**MONTHLY ENERGY BILL DETAILS - FY 2022-23**

Table 85: Energy bill summary – FY 2022-23

| KANAN DEVAN HILLS PLANTATIONS<br>COMPANY PVT LTD |             | CONTRACT DEMAND = 9000 KVA |                |             |             |             | LICENSEE: KDHPCL |             |             | Consumer No: LCN: 21/014 |             |             | Total<br>(MU) |
|--|-------------|----------------------------|----------------|-------------|-------------|-------------|------------------|-------------|-------------|--------------------------|-------------|-------------|---------------|
| Particulars                                      | Apr-22      | May-22                     | Jun-22         | Jul-22      | Aug-22      | Sep-22      | Oct-22           | Nov-22      | Dec-22      | Jan-23                   | Feb-23      | Mar-23      |               |
| <b>75% OF CONTRACT DEMAND</b>                    | 6,750       | 6,750                      | 6,750          | 6,750       | 6,750       | 6,750       | 6,750            | 6,750       | 6,750       | 6,750                    | 6,750       | 6,750       |               |
| <b>kVA Normal</b>                                | 11,150      | 12,479                     | 11,674         | 10,516      | 11,036      | 12,175      | 11,813           | 10,711      | 12,309      | 10,902                   | 11,775      | 11,083      |               |
| <b>kVA Peak</b>                                  | 6,274       | 6,972                      | 7,056          | 6,728       | 5,618       | 6,520       | 6,934            | 7,160       | 6,758       | 6,474                    | 5,902       | 6,292       |               |
| <b>kVA Off Peak</b>                              | 4,874       | 6,938                      | 5,566          | 5,022       | 4,112       | 4,694       | 5,282            | 5,876       | 5,542       | 4,950                    | 4,830       | 4,472       |               |
| <b>RMD (Pullivasal + Madupatty)</b>              | 11,150      | 12,479                     | 11,674         | 10,516      | 11,036      | 12,175      | 11,813           | 10,711      | 12,309      | 10,902                   | 11,775      | 11,083      |               |
| <b>Net feedback RMD</b>                          | 2,715       | 1,835                      | 2,981          | 2,348       | 2,342       | 2,105       | 3,179            | 2,698       | 2,461       | 2,716                    | 2,454       | 2,939       |               |
| <b>Billing Demand</b>                            | 8,435       | 10,644                     | 8,693          | 8,168       | 8,694       | 10,070      | 8,634            | 8,013       | 9,848       | 8,186                    | 9,321       | 8,144       |               |
| <b>Demand Charges</b>                            | 28,67,900   | 36,18,960                  | 33,03,360      | 31,03,840   | 33,03,720   | 38,26,600   | 32,80,920        | 30,44,940   | 37,42,240   | 31,10,680                | 35,41,980   | 30,94,720   |               |
| <b>Excess Demand</b>                             | -           | 1,644                      | -              | -           | -           | 1,070       | -                | -           | 848         | -                        | 321         | -           |               |
| <b>Excess Demand Charge</b>                      |             | 2,79,480                   |                |             |             | 2,03,300    |                  |             | 1,61,120    |                          | 60,990      |             |               |
| <b>Total Demand Charges</b>                      | 28,67,900   | 38,98,440                  | 33,03,360      | 31,03,840   | 33,03,720   | 40,29,900   | 32,80,920        | 30,44,940   | 39,03,360   | 31,10,680                | 36,02,970   | 30,94,720   |               |
| <b>Total kWh - Billed energy</b>                 | 48,08,620   | 60,34,520                  | 52,26,960      | 45,55,820   | 40,80,760   | 49,40,540   | 49,82,640        | 50,78,780   | 51,31,720   | 47,64,240                | 43,51,140   | 50,92,440   | <b>54.118</b> |
| <b>Feedback kWh</b>                              | 3,64,937    | 4,07,317                   | 4,35,887       | 4,55,962    | 4,15,115    | 3,73,775    | 3,94,009         | 4,00,278    | 4,36,368    | 4,51,174                 | 3,89,349    | 4,06,054    | <b>4.93</b>   |
| <b>Total kWh - metered energy</b>                | 44,43,683   | 56,27,203                  | 47,91,073      | 40,99,858   | 36,65,645   | 45,66,765   | 45,88,631        | 46,78,502   | 46,95,352   | 43,13,066                | 39,61,791   | 46,86,386   | <b>59.048</b> |
| <b>Total kWh Charges</b>                         | 2,13,29,678 | 2,70,10,574                | 2,34,69,631.40 | 2,17,29,247 | 1,94,27,919 | 2,42,03,855 | 2,43,19,744      | 2,47,96,061 | 2,48,85,366 | 2,28,59,250              | 2,09,97,492 | 2,48,37,846 |               |
| <b>PF</b>  | 0.95        | 0.95                       | 0.95           | 0.95        | 0.95        | 0.95        | 0.95             | 0.99        | 0.95        | 0.95                     | 0.95        | 0.95        |               |
| <b>PF incentive/Penalty</b>                      |             |                            |                | -4,34,585   | -3,88,558   | -4,84,077   | -4,86,395        | -4,95,921   | -4,97,707   | -4,57,185                | -4,19,950   | -4,96,756   |               |
| <b>GRAND TOTAL</b>                               | 2,41,97,578 | 3,09,09,014                | 2,67,72,991    | 2,43,98,502 | 2,23,43,080 | 2,77,49,677 | 2,71,14,269      | 2,73,45,079 | 2,82,91,019 | 2,55,12,745              | 2,41,80,512 | 2,74,35,810 |               |

**SIGNED PERFORMA****12.6.1 General information**

| General Information |   |   |  |
|---------------------|---|---|--|
| 1                   | Name of the DISCOM  | KANAN DEVAN HILLS PLANTATIONS COMPANY PRIVATE LIMITED |  |
| 2                   | i) Year of Establishment  | 2007  |  |
|                     | ii) Government/Public/Private                                   | PRIVATE   |  |
| 3                   | DISCOM's Contact details & Address                              |   |  |
| i                   | City/Town/Village   | MUNNAR  |  |
| ii                  | District  | IDUKKI  |  |
| iii                 | State   | KERALA  | Pin 685612   |
| iv                  | Telephone   | 04868 255000  | Fax  |
| 4                   | Registered Office   |   |  |
| i                   | Company's Chief Executive Name                                  | K.MATHEW ABRAHAM                                      |  |
| ii                  | Designation   | MANAGING DIRECTOR                                     |  |
| iii                 | Address   | K.D.H.P HOUSE,  |  |
| iv                  | City/Town/Village   | MUNNAR TOWN   | P.O. MUNNAR  |
| v                   | District  | IDUKKI  |  |
| vi                  | State   | KERALA  | Pin 685612   |
| vii                 | Telephone   | 04868 255000  | Fax  |
| 5                   | Nodal Officer Details*  |   |  |
| i                   | Nodal Officer Name (Designated at DISCOM's)                     | RAJU U. WARRIER                                       |  |
| ii                  | Designation   | HEAD - ENGINEERING DEPARTMENT                         |  |
| iii                 | Address   | KDHP HOUSE  |  |
| iv                  | City/Town/Village   | MUNNAR  | P.O. MUNNAR  |
| v                   | District  | IDUKKI  |  |
| vi                  | State   | KERALA  | Pin 685612   |
| vii                 | Telephone   | 04868 255101  | Fax  |
| 6                   | Energy Manager Details*   |   |  |
| i                   | Name  | Mr. R. JAYARAMAN                                      |  |
| ii                  | Designation   | EXECUTIVE   | Whether EA or EM EM  |
| iii                 | EA/EM Registration No.  |   |  |
| iv                  | Telephone   | 04868 255107  | Fax  |
| v                   | Mobile  | 9446130623  | E-mail ID <a href="mailto:jayaraman.r@kdhptea.co.in">jayaraman.r@kdhptea.co.in</a> |
| 7                   | Period of Information   |   |  |
|                     | Year of (FY) information including Date and Month (Start & End) | 01st April 2022 - 31st March 2023                     |  |


**J Nagesh Kumar**

Director/AEA 0133

Centre for Energy Environment &amp; Productivity

**Centre for Energy, Environment and Productivity**  
 Plot No. 1039, 26th Street, H-Block,  
 Ponni Colony, Anna Nagar, Chennai - 600 040.  
 PH : 044 2616 3483, 9444882553

## 12.6.2 Performance Summary of DISCOM – Form-1

| Performance Summary of Electricity Distribution Companies |  |                                   |         |
|---|--|-----------------------------------|---------|
| 1   | Period of Information<br>Year of (FY) information including Date and Month (Start & End)         | 01st April 2022 - 31st March 2023 |         |
| 2   | <b>Technical Details</b>   |                                   |         |
| (a)   | <b>Energy Input Details</b>  |                                   |         |
| (i)   | Input Energy Purchase<br>(From Generation Source)  | Million kwh                       | 54.118  |
| (ii)  | Net input energy (at DISCOM Periphery after adjusting the transmission losses and energy traded) | Million kwh                       | 59.048  |
| (iii)   | Total Energy billed (is the Net energy billed, adjusted for energy traded)                       | Million kwh                       | 54.011  |
| (b)   | Transmission and Distribution (T&D) loss Details   | Million kwh                       | 5.038   |
|   | Collection Efficiency  | %                                 | 8.53    |
|   |  | %                                 | 99.673% |
| (c)   | Aggregate Technical & Commercial Loss  | %                                 | 8.83%   |

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal

Name of Authorised Signatory

Name of the DISCOM:

Full Address:-

Seal

Signature:-

Name of energy manager:

Registration Number



J Nagesh Kumar

Director/AEA 0133

Centre for Energy Environment & Productivity

Centre for Energy, Environment and Productivity  
Plot No. 1039, 26th Street, H-Block,  
Ponni Colony, Anna Nagar, Chennai - 600 040.  
PH : 044 2616 3483, 9444882553

12.6.3 Details of Division wise losses

| Details of Division Wise Losses (See note below)** |                  |             |                  |   |                                |                                   |                                   |                            |                             |                                |                           |                     |                   |                    |                             |              |                         |               |              |                            |                               |                       |                 |
|--|------------------|-------------|------------------|---|--------------------------------|-----------------------------------|-----------------------------------|----------------------------|-----------------------------|--------------------------------|---------------------------|---------------------|-------------------|--------------------|-----------------------------|--------------|-------------------------|---------------|--------------|----------------------------|-------------------------------|-----------------------|-----------------|
| Division Wise Losses                               |                  |             |                  |   |                                |                                   |                                   |                            |                             |                                |                           |                     |                   |                    |                             |              |                         |               |              |                            |                               |                       |                 |
| S.No   | Name of circle   | Circle code | Name of Division | Consumer profile                              |                                |                                   |                                   |                            |                             |                                |                           |                     |                   | Energy parameters  |                             |              |                         | Losses        |              | Commercial Parameter       |                               |                       | AT & C loss (%) |
|  |                  |             |                  | Period From 1st April 2022 to 31st March 2023 |                                |                                   |                                   |                            |                             |                                |                           |                     |                   | Billed energy (MU) |                             |              |                         | T&D loss (MU) | T&D loss (%) | Billed Amount in Rs. Crore | Collected Amount in Rs. Crore | Collection Efficiency |                 |
|  |                  |             |                  | Consumer category                             | No of connection metered (Nos) | No of connection Un-metered (Nos) | Total Number of connections (Nos) | % of number of connections | Connected Load metered (MW) | Connected Load Un-metered (MW) | Total Connected Load (MW) | % of connected load | Input energy (MU) | Metered energy     | Unmetered/assessment energy | Total energy | % of energy consumption |               |              |                            |                               |                       |                 |
| 1  | KDHP             | KDHP        | KDHP             | Residential                                   | 14010                          | 0                                 | 14010                             | 84.48%                     | 16.45                       | 0                              | 16.45                     | 48.33%              | 59.048            | 7.80               | 0                           | 7.80         | 14%                     | 5.038         | 8.53%        | 3.7656                     | 3.7841                        | 100.49%               |                 |
|  |                  |             |                  | Agricultural                                  | 7                              | 0                                 | 7                                 | 0.04%                      | 0.04                        | 0                              | 0.04                      | 0.13%               |                   | 0.016              | 0                           | 0.016        | 0.03%                   |               |              | 0.0049                     | 0.0049                        | 100.00%               |                 |
|  |                  |             |                  | Commercial/Industrial-LT                      | 1317                           | 0                                 | 1317                              | 7.94%                      | 4.94                        | 0                              | 4.94                      | 14.51%              |                   | 3.99               | 0                           | 3.99         | 7%                      |               |              | 3.9026                     | 3.9073                        | 100.12%               |                 |
|  |                  |             |                  | Commercial/Industrial-HT                      | 31                             | 0                                 | 31                                | 0.19%                      | 9.69                        | 0                              | 9.69                      | 28.46%              |                   | 34.30              | 0                           | 34.30        | 64%                     |               |              | 25.3352                    | 25.3174                       | 99.93%                |                 |
|  |                  |             |                  | Others + feedback                             | 1218                           | 0                                 | 1218                              | 7.34%                      | 2.92                        | 0                              | 2.92                      | 8.57%               |                   | 7.90               | 0                           | 7.90         | 15%                     |               |              | 2.4389                     | 2.3176                        | 95.03%                |                 |
|  |                  |             |                  | Sub-total                                     | 16583                          | 0                                 | 16583                             | 100%                       | 34.03                       | 0                              | 34.03                     | 100%                |                   | 59.048             | 54.011                      | 0.00         | 54.011                  |               |              | 100%                       | 5.038                         | 8.53%                 |                 |
| 2  |                  |             |                  | Residential                                   | 0                              | 0                                 | 0                                 | 0%                         | 0                           | 0                              | 0                         | 0%                  | 0                 | 0                  | 0                           | 0            | 0%                      | 0             | 0%           | 0                          | 0                             | 0.00%                 |                 |
|  |                  |             |                  | Agricultural                                  | 0                              | 0                                 | 0                                 | 0%                         | 0                           | 0                              | 0                         | 0%                  |                   | 0                  | 0                           | 0            | 0%                      |               |              | 0                          | 0                             | 0.00%                 |                 |
|  |                  |             |                  | Commercial/Industrial-LT                      | 0                              | 0                                 | 0                                 | 0%                         | 0                           | 0                              | 0                         | 0%                  |                   | 0                  | 0                           | 0            | 0%                      |               |              | 0                          | 0                             | 0.00%                 |                 |
|  |                  |             |                  | Commercial/Industrial-HT                      | 0                              | 0                                 | 0                                 | 0%                         | 0                           | 0                              | 0                         | 0%                  |                   | 0                  | 0                           | 0            | 0%                      |               |              | 0                          | 0                             | 0.00%                 |                 |
|  |                  |             |                  | Others  | 0                              | 0                                 | 0                                 | 0%                         | 0                           | 0                              | 0                         | 0%                  |                   | 0                  | 0                           | 0            | 0%                      |               |              | 0                          | 0                             | 0.00%                 |                 |
|  |                  |             |                  | Sub-total                                     | 0                              | 0                                 | 0                                 | 100%                       | 0                           | 0                              | 0                         | 100%                |                   | 0                  | 0                           | 0            | 0                       |               |              | 100%                       | 0                             | 0%                    |                 |
| 76   | Total            |             |                  | Residential                                   | 14010                          | 0                                 | 14010                             | 84.48%                     | 16.45                       | 0                              | 16.45                     | 48.33%              | 59.048            | 7.80               | 0                           | 7.80         | 14%                     | 5.038         | 8.53%        | 3.7656                     | 3.7841                        | 100.49%               |                 |
|  |                  |             |                  | Agricultural                                  | 7                              | 0                                 | 7                                 | 0.04%                      | 0.04                        | 0                              | 0.04                      | 0.13%               |                   | 0.016              | 0                           | 0.016        | 0.03%                   |               |              | 0.0049                     | 0.0049                        | 100.00%               |                 |
|  |                  |             |                  | Commercial/Industrial-LT                      | 1317                           | 0                                 | 1317                              | 7.94%                      | 4.94                        | 0                              | 4.94                      | 14.51%              |                   | 3.99               | 0                           | 3.99         | 7%                      |               |              | 3.9026                     | 3.9073                        | 100.12%               |                 |
|  |                  |             |                  | Commercial/Industrial-HT                      | 31                             | 0                                 | 31                                | 0.19%                      | 9.69                        | 0                              | 9.69                      | 28.46%              |                   | 34.30              | 0                           | 34.30        | 64%                     |               |              | 25.3352                    | 25.3174                       | 99.93%                |                 |
|  |                  |             |                  | Others  | 1218                           | 0                                 | 1218                              | 7.34%                      | 2.92                        | 0                              | 2.92                      | 8.57%               |                   | 7.90               | 0                           | 7.90         | 15%                     |               |              | 2.4389                     | 2.3176                        | 95.03%                |                 |
|  |                  |             |                  | Sub-total                                     | 16583                          | 0                                 | 16583                             | 100%                       | 34.03                       | 0                              | 34.03                     | 100%                |                   | 59.048             | 54.011                      | 0            | 54.011                  |               |              | 100%                       | 5.038                         | 8.53%                 |                 |
| 77   | At company level |             |                  | 16583   | 0                              | 16583                             | 100%                              | 34.03                      | 0                           | 34.03                          | 100%                      | 59.048              | 54.011            | 0                  | 54.011                      | 100%         | 5.038                   | 8.53%         | 35.4473      | 35.3314                    | 99.673%                       | 8.83%                 |                 |

\*\* Note - It shall be mandatory to record the energy supplied separately for each category of consumers which is being provided a separate rate of subsidy in the tariff, by the state government, so that the subsidy due for the electricity distribution company is quarterly calculated by multiplying the energy supplied to each of such category of consumers by the applicable rate of subsidy notified by the state government.

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal

Name of Authorised Signatory:

Name of the DISCOM:

Full Address:-

Seal

Signature:-

Name of Energy Manager:

Registration Number:

J Nagesh Kumar

Director/AEA 0133

Centre for Energy Environment & Productivity

Centre for Energy, Environment and Productivity

Plot No. 1039, 26th Street, H-Block,

Ponni Colony, Anna Nagar, Chennai - 600 040.

PH : 044 2616 3483, 9444882553

12.6.4 Details of infrastructure

| Form-Details of Input Infrastructure |  |  |                         |  |                                     |
|--------------------------------------|--|--|-------------------------|--|-------------------------------------|
| 1                                    | Parameters   | Total  | Covered during in audit | Verified by Auditor in Sample Check  | Remarks (Source of data)            |
| i                                    | Number of circles  | 1  | 1                       | 1  |                                     |
| ii                                   | Number of divisions  | 1  | 1                       | 1  |                                     |
| iii                                  | Number of sub-divisions                                    | 1  | 1                       | 1  |                                     |
| iv                                   | Number of feeders  | 7  | 7                       | 7  |                                     |
| v                                    | Number of DTs  | 133  | 133                     | 133  | Including HT consumers              |
| vi                                   | Number of consumers  | 16583  | 16583                   | 16583  |                                     |
| 2                                    | Parameters   | 66kV and above   | 33kV                    | 11/22kV  | LT                                  |
| a.i.                                 | Number of conventional metered consumers                   | -  | -                       | -  | 6613                                |
| ii                                   | Number of consumers with 'smart' meters                    | -  | -                       | -  | -                                   |
| iii                                  | Number of consumers with 'smart prepaid' meters            | -  | -                       | -  | -                                   |
| iv                                   | Number of consumers with 'AMR' meters                      | -  | -                       | -  | -                                   |
| v                                    | Number of consumers with 'non-smart prepaid' meters        | -  | -                       | 36   | 9934                                |
| vi                                   | Number of unmetered consumers                              | -  | -                       | -  | -                                   |
| vii                                  | <b>Number of total consumers</b>                           | -  | -                       | 36   | 16547                               |
| b.i.                                 | Number of conventionally metered Distribution Transformers | -  | -                       | -  | 63                                  |
| ii                                   | Number of DTs with communicable meters                     | -  | -                       | -  | -                                   |
| iii                                  | Number of unmetered DTs                                    | -  | -                       | -  | 70                                  |
| iv                                   | <b>Number of total Transformers</b>                        | -  | -                       | -  | 133                                 |
| c.i.                                 | Number of metered feeders                                  | -  | -                       | -  | -                                   |
| ii                                   | Number of feeders with communicable meters                 | -  | -                       | 7  | -                                   |
| iii                                  | Number of unmetered feeders                                | -  | -                       | -  | -                                   |
| iv                                   | <b>Number of total feeders</b>                             | -  | -                       | 7  | -                                   |
| d.                                   | Line length (ct km)  | -  | -                       | 180.23   | 193.8                               |
| e.                                   | Length of Aerial Bunched Cables (km)                       | -  | -                       | -  | -                                   |
| f.                                   | Length of Underground Cables (km)                          | -  | -                       | 0.405  | 4.525                               |
| 3                                    | Voltage level  | Particulars  | MU                      | Reference  | Remarks (Source of data)            |
| v                                    | 11 kV  | Renewable Energy Procurement                                   | 0                       |  |                                     |
|                                      |  | Small capacity conventional/ biomass/ hydro plants Procurement | 54.12                   |  | Purchase unit excluding feedback    |
|                                      |  | Sales Migration Input  | 4.93                    |  | Feedback                            |
| vi                                   | LT   | Renewable Energy Procurement                                   | 0                       |  |                                     |
|                                      |  | Sales Migration Input  | 0                       |  |                                     |
| vii                                  |  | <b>Energy Embedded within DISCOM wires network</b>             | 59.048                  |  |                                     |
| viii                                 |  | <b>Total Energy Available/ Input</b>                           | 59.048                  |  |                                     |
| 4                                    | Voltage level  | Energy Sales Particulars                                       | MU                      | Reference  | Remarks (Source of data)            |
| i                                    | LT Level   | DISCOM' consumers  | 13.98                   | Include sales to consumers in franchisee areas, unmetered consumers                    | Total LT sales                      |
|                                      |  | Demand from open access, captive                               | 0.00                    | Non DISCOM's sales   |                                     |
|                                      |  | Embedded generation used at LT level                           | 0.0237                  | Demand from embedded generation at LT level  |                                     |
|                                      |  | Sale at LT level   | 13.98                   |  |                                     |
|                                      |  | Quantum of LT level losses                                     | 3.81                    | Included the LT OH line length, LT cable, Switch gear, Commercial & Transformer losses | 6.4531% of total energy requirement |
|                                      |  | Energy Input at LT level                                       | 17.79                   |  |                                     |
|                                      |  | DISCOM' consumers  | 35.10                   | Include sales to consumers in franchisee areas, unmetered consumers                    | HT sales                            |
| ii                                   | 11 kV Level  | Demand from open access, captive                               | 4.93                    | Non DISCOM's sales   | Feedback                            |
|                                      |  | Embedded generation at 11 kV level used                        | 0.001                   | Demand from embedded generation at 11kV level  | PPC solar export                    |
|                                      |  | <b>Sales at 11 kV level</b>                                    | 40.03                   |  |                                     |
|                                      |  | Quantum of Losses at 11 kV                                     | 1.227                   |  | 2.0781% of total energy requirement |
|                                      |  | Energy input at 11 kV level                                    | 41.26                   |  |                                     |
|                                      |  | <b>Total Energy Requirement</b>                                | <b>59.048</b>           |  |                                     |
|                                      |  | <b>Total Energy Sales</b>                                      | <b>54.011</b>           |  |                                     |
| Energy Accounting Summary            |  |  |                         |  |                                     |
| 5                                    | DISCOM   | Input (in MU)  | Sale (in MU)            | Loss (in MU)   | Loss %                              |
| i                                    | LT   |  |                         |  |                                     |
| ii                                   | 11 Kv  | 59.048   | 54.011                  | 5.038  | 8.53                                |
| iii                                  | 33 kv  |  |                         |  |                                     |
| iv                                   | > 33 kv  |  |                         |  |                                     |

| Loss Estimation for DISCOM |       |
|----------------------------|-------|
| T&D loss (MU)              | 5.038 |
| D loss (MU)                | 5.038 |
| T&D loss (%)               | 8.53  |
| D loss (%)                 | 8.53  |



J Nagesh Kumar  
 Director/AEA 0133  
 Centre for Energy Environment & Productivity

Centre for Energy, Environment and Productivity  
 Plot No. 1039, 26th Street, H-Block,  
 Ponnai Colony, Anna Nagar, Chennai - 600 040.  
 PH : 044 2616 3483, 9444882553

### 12.6.5 Details of input energy sources

| Form-input energy(Details of input energy & Infrastructure)   |   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   |                                      |             |                                  |                   |                          |  |  |        |      |  |        |  |
|---|---|--------|--------------------|----------------|--------------------|-----------|-----------------|---|---|--|--------------------------------------|---|--|-------------------------------------|---|--------------------------------------|-------------|----------------------------------|-------------------|--------------------------|--|--|--------|------|--|--------|--|
| A. Summary of energy input & Infrastructure   |   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   |                                      |             |                                  |                   |                          |  |  |        |      |  |        |  |
| S.No  | Parameters  |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | Period From April 2022 to March 2023 |             | Remarks (Source of data)         |                   |                          |  |  |        |      |  |        |  |
| A.1   | Input Energy purchased (MU)   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 54.118                               |             | Electricity bill                 |                   |                          |  |  |        |      |  |        |  |
| A.2   | Transmission loss (%)   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 0%                                   |             |                                  |                   |                          |  |  |        |      |  |        |  |
| A.3   | Transmission loss (MU)  |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 0                                    |             |                                  |                   |                          |  |  |        |      |  |        |  |
| A.4   | Energy sold outside the periphery(MU)   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 4.93                                 |             | Feedback energy                  |                   |                          |  |  |        |      |  |        |  |
| A.5   | Open access sale (MU)   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 0                                    |             |                                  |                   |                          |  |  |        |      |  |        |  |
| A.6   | EHT sale  |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 0                                    |             |                                  |                   |                          |  |  |        |      |  |        |  |
| A.7   | Net input energy (received at DISCOM periphery or at distribution point) (MU) |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 59.048                               |             | Total feeder input               |                   |                          |  |  |        |      |  |        |  |
| A.8   | Is 100% metering available at 66/33 kV (Select yes or no from list)           |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | Yes                                  |             |                                  |                   |                          |  |  |        |      |  |        |  |
| A.9   | Is 100% metering available at 11 kV (Select yes or no from list)              |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | Yes                                  |             |                                  |                   |                          |  |  |        |      |  |        |  |
| A.10  | % of metering available at DT   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 47%                                  |             | 63 out of 133 DT                 |                   |                          |  |  |        |      |  |        |  |
| A.11  | % of metering available at consumer end                                       |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 100%                                 |             |                                  |                   |                          |  |  |        |      |  |        |  |
| A.12  | No of feeders at 66kV voltage level   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 0                                    |             |                                  |                   |                          |  |  |        |      |  |        |  |
| A.13  | No of feeders at 33kV voltage level   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 0                                    |             |                                  |                   |                          |  |  |        |      |  |        |  |
| A.14  | No of feeders at 11kV voltage level   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 7                                    |             |                                  |                   |                          |  |  |        |      |  |        |  |
| A.15  | No of LT feeders level  |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 0                                    |             | Not available                    |                   |                          |  |  |        |      |  |        |  |
| A.16  | Line length (cst. km) at 66kV voltage level                                   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 0                                    |             |                                  |                   |                          |  |  |        |      |  |        |  |
| A.17  | Line length (cst. km) at 33kV voltage level                                   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 0                                    |             |                                  |                   |                          |  |  |        |      |  |        |  |
| A.18  | Line length (cst. km) at 11kV voltage level                                   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 190.23                               |             | Measured through HT line mapping |                   |                          |  |  |        |      |  |        |  |
| A.19  | Line length (km) at LT level  |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 193.8                                |             | Measured through LT line mapping |                   |                          |  |  |        |      |  |        |  |
| A.20  | Length of Aerial Bunched Cables   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 0                                    |             |                                  |                   |                          |  |  |        |      |  |        |  |
| A.21  | Length of Underground Cables  |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 4.525                                |             | Site measurement                 |                   |                          |  |  |        |      |  |        |  |
| A.22  | HT/LT ratio   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   | 1:1.075                              |             |                                  |                   |                          |  |  |        |      |  |        |  |
| B. Meter reading of input energy at injection points  |   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   |                                      |             |                                  |                   |                          |  |  |        |      |  |        |  |
| S.No  | Zone  | Circle | Voltage Level (KV) | Division (KVA) | Sub-Division (KVA) | Feeder ID | Feeder Name     | Feeder Metering Status (Metered/ un-metered/ AMI/AMR) | Status of Meter (Functional/Non-functional) | Metering Date (Date of last actual meter reading/ communication) | Feeder Type (Agri/ Industrial/Mixed) | Status of Communication                             |  |                                     | Period From 1st April 2022 to 31st March 2023 |                                      |             |                                  | Sales             | Remarks (Source of data) |  |  |        |      |  |        |  |
|   |   |        |                    |                |                    |           |                 |   |   |  |                                      | % data received through automatically if feeder AMR | Number of hours when meter was unable to communicate in period | Total Number of hours in the period | Meter S.No                                    | CT/PT ratio                          | Import (MU) | Export (MU)                      |                   |                          |  |  |        |      |  |        |  |
| B.1   | KDHP  | KDHP   | 11                 | NIL            | NIL                | NIL       | HR 1 & 2        | Metered   | Functioning                                 | 31-03-2023   | Mixed                                | 0   | 0  | NA                                  | K3E98355                                      | 500/5                                | 46.089      | -                                | Switching station |                          |  |  |        |      |  |        |  |
| B.2   | KDHP  | KDHP   | 11                 | NIL            | NIL                | NIL       | Pipeline (HR-3) | Metered   | Functioning                                 | 31-03-2023   | Mixed                                | 0   | 0  | NA                                  | 16116905                                      | 200/5                                | 8.700       | -                                | Switching station |                          |  |  |        |      |  |        |  |
| B.3   | KDHP  | KDHP   | 11                 | NIL            | NIL                | NIL       | Madupatty       | Metered   | Functioning                                 | 31-03-2023   | Mixed                                | 0   | 0  | NA                                  | 16088095                                      | 200/5                                | 4.259       | -                                | Switching station |                          |  |  |        |      |  |        |  |
| B.5   |   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   |                                      |             |                                  |                   |                          |  |  |        |      |  |        |  |
| B.1001  | Total (MU)  |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   |                                      |             |                                  |                   |                          |  |  | 59.048 | 0.00 |  |        |  |
| B.1002  | Net input energy at DISCOM periphery (MU)                                     |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   |                                      |             |                                  |                   |                          |  |  |        |      |  | 59.048 |  |
| I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss. |   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   |                                      |             |                                  |                   |                          |  |  |        |      |  |        |  |
| Authorised Signatory and Seal   |   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   |                                      |             |                                  |                   |                          |  |  |        |      |  |        |  |
| Name of Authorised Signatory  |   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     | Signature:-                                   |                                      |             |                                  |                   |                          |  |  |        |      |  |        |  |
| Name of the DISCOM:   |   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     | Name of Energy Manager:                       |                                      |             |                                  |                   |                          |  |  |        |      |  |        |  |
| Full Address:-  |   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     | Registration Number:                          |                                      |             |                                  |                   |                          |  |  |        |      |  |        |  |
| Seal  |   |        |                    |                |                    |           |                 |   |   |  |                                      |   |  |                                     |   |                                      |             |                                  |                   |                          |  |  |        |      |  |        |  |

J Nagesh Kumar

Director/AEA 0133

Centre for Energy Environment & Productivity

Centre for Energy, Environment and Productivity  
 Plot No. 1039, 28th Street, H-Block,  
 Ponni Colony, Anna Nagar, Chennai - 600 040.  
 PH : 044 2616 3483, 9444882553



12.6.7 Details of Feeder wise losses

| (Details of Feeder-wise losses)               |      |                            |                              |                                  |                     |                |             |  |  |                                  |                            |  |            |             |   |                              |
|---|------|----------------------------|------------------------------|----------------------------------|---------------------|----------------|-------------|--|--|----------------------------------|----------------------------|--|------------|-------------|---|------------------------------|
| Period From 1st April 2022 to 31st March 2023 |      |                            |                              |                                  |                     |                |             |  |  |                                  |                            |  |            |             |   |                              |
| Sl No.  | Zone | Received at Circle (In MU) | Received at Division (In MU) | Received at Sub-division (In MU) | Name of the Station | Feeder Code/ID | Feeder Name | Type of Feeder ( Urban/Mixed/Industrial /Agricultural/Rural) | Type of feeder meter ( AMI/AMR/ Other) | Received at Feeder (Final in MU) | Feeder Consumption (In MU) | Final Net Export at Feeder Level (In MU) | T&D losses | AT&C losses | % Data Received through Automatically (if feeder AMR/AMI) | Remarks                      |
| 1   | KDHP |                            |                              |                                  |                     |                | Nayamakad   | Mixed  | Others                                 | 11.12                            | 9.99                       | 0  | 10.17      | 12.24       | nil   |                              |
| 2   | KDHP |                            |                              |                                  |                     |                | Madupatty   | Mixed  | Others                                 | 14.98                            | 12.90                      | 0  | 13.90      | 15.88       | nil   | Madupatty 2 MW gets exported |
| 3   | KDHP |                            |                              |                                  |                     |                | Nettigudi   | Mixed  | Others                                 | 10.58                            | 9.85                       | 0  | 6.93       | 9.07        | nil   |                              |
| 4   | KDHP |                            |                              |                                  |                     |                | Town        | Mixed  | Others                                 | 9.95                             | 8.66                       | 0  | 12.97      | 14.97       | nil   |                              |
| 5   | KDHP |                            |                              |                                  |                     |                | ITD         | Auxiliary  | Others                                 | 9.88                             | 9.38                       | 0  | 5.03       | 7.21        | nil   |                              |
| 6   | KDHP |                            |                              |                                  |                     |                | Pullivasal  | Mixed  | Others                                 | 3.21                             | 3.04                       | 0  | 5.17       | 7.35        | nil   |                              |
| 7   | KDHP |                            |                              |                                  |                     |                | Station     | Mixed  | Others                                 | 0.01                             | 0.01                       | 0  | 0.00       | 0.00        | nil   |                              |



J Nagesh Kumar

Director/AEA 0133

Centre for Energy Environment & Productivity

Centre for Energy, Environment and Productivity  
 Plot No. 1039, 26th Street, H-Block,  
 Ponni Colony, Anna Nagar, Chennai - 600 040.  
 PH : 044 2616 3483, 9444882553

12.6.8 Details of Subsidy

| Consumer category (Separate for each subsidized consumer category) | Billed energy      |           |                    | Subsidized billed energy |                           |         | Applicable rate of subsidy as notified by state govt |                  | Subsidy due from state govt |                  |              | Subsidy actually billed/claimed from state govt (as against col 12) | Subsidy received from state govt (As against col 13) |
|--|--------------------|-----------|--------------------|--------------------------|---------------------------|---------|--|------------------|-----------------------------|------------------|--------------|---|--|
|  | (in kWh)           |           |                    | (in kWh)                 |                           |         | (In Rs/kWh)  |                  | (in Rs Cr)                  |                  |              | (in Rs Cr)  | (in Rs Cr)   |
|  | Metered            | Unmetered | Total              | Metered (out of col 2)   | Unmetered* (out of col 3) | Total   | Metered energy**                                     | Unmetered energy | Metered energy              | Unmetered energy | Total        |   |  |
| 1  | 2                  | 3         | 4= 2 + 3           | 5                        | 6                         | 7 = 5+6 | 8  | 9                | 10 = 5 x 8                  | 11 = 6 x 9       | 12 = 10 + 11 | 13  | 14   |
| Residential  | 7802628            | 0         | 7802628            | 0                        | 0                         | 0       | 0  | 0                | 0                           | 0                | 0            | 0   | 0  |
| Agricultural   | 15942              | 0         | 15942              | 0                        | 0                         | 0       | 0  | 0                | 0                           | 0                | 0            | 0   | 0  |
| Commercial/Industrial-LT   | 3991682            | 0         | 3991682            | 0                        | 0                         | 0       | 0  | 0                | 0                           | 0                | 0            | 0   | 0  |
| Commercial/Industrial-HT   | 34303573           | 0         | 34303573           | 0                        | 0                         | 0       | 0  | 0                | 0                           | 0                | 0            | 0   | 0  |
| Others + feedback  | 7896825            | 0         | 7896825            | 0                        | 0                         | 0       | 0  | 0                | 0                           | 0                | 0            | 0   | 0  |
| <b>Total</b>   | <b>5,40,10,650</b> |           | <b>5,40,10,650</b> |                          |                           |         |  |                  |                             |                  |              |   |  |

\*Basis of assessment of energy to be provided in the notes along with relevant Government Orders

\*\* Provide copy of relevant work orders



J Nagesh Kumar

Director/AEA 0133

Centre for Energy Environment & Productivity

Centre for Energy, Environment and Productivity  
 Plot No. 1039, 26th Street, H-Block,  
 Ponni Colony, Anna Nagar, Chennai - 600 040.  
 PH : 044 2616 3483, 9444882553



12.6.9 Details of DT level losses

| a. Division wise status of DT level metering   |             |               |             |                          |   |  |   |   |   |  |                    |                     |                   |
|--|-------------|---------------|-------------|--------------------------|---|--|---|---|---|--|--------------------|---------------------|-------------------|
| Zone name  | Circle name | Division name | Feeder name | Total no of DT on feeder | No of unmetered DTs   | No of metered DTs                          |   |   | No. of DTs with functional meters       |  |                    |                     |                   |
|  |             |               |             |                          |   | AMR metered (communicable)                 | AMI metered (communicable)                  | Non-AMR / AMI metered (non-communicable)      | Communicating (Total No out of 7 and 8) | Non-communicating (Total No. out of 7,8 and 9) |                    |                     |                   |
| 1  | 2           | 3             | 4           | 5=(6+7+8+9)              | 6   | 7  | 8   | 9   | 10                                      | 11   |                    |                     |                   |
| KDHP   | KDHP        | KDHP          | Nayamakad   | 31                       | 16  |  |   | 15  |   | 15   |                    |                     |                   |
| KDHP   | KDHP        | KDHP          | Madupatty   | 41                       | 25  |  |   | 16  |   | 16   |                    |                     |                   |
| KDHP   | KDHP        | KDHP          | Nettigudi   | 24                       | 12  |  |   | 12  |   | 12   |                    |                     |                   |
| KDHP   | KDHP        | KDHP          | Town        | 18                       | 9   |  |   | 9   |   | 9  |                    |                     |                   |
| KDHP   | KDHP        | KDHP          | ITD         | 16                       | 8   |  |   | 8   |   | 8  |                    |                     |                   |
| KDHP   | KDHP        | KDHP          | Pullivasal  | 3                        | 0   |  |   | 3   |   | 3  |                    |                     |                   |
| b. Details of DT-wise losses   |             |               |             |                          |   |  |   |   |   |  |                    |                     |                   |
| Sub-station ID   | Feeder ID   | Feeder Name   | DT Id no    | DT Capacity (kVA)        | Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed) | Type of metering (Unmetered/AMI/AMR/Other) | Status of meter (functional/non-functional) | % of data received automatically (if AMI/AMR) | No. of connected consumers              | Input Energy (MU)                              | Billed Energy (MU) | Loss of Energy (MU) | % Loss            |
|  |             | 1             | 2           |                          |   |  |   |   | 3                                       | 4  | 5                  | 6 = 4-5             | (7)=[(6)/(4)]*100 |
| Not available as 100% DT metering not done also the DT measurement not yet commenced |             |               |             |                          |   |  |   |   |   |  |                    |                     |                   |



J Nagesh Kumar

Director/AEA 0133

Centre for Energy Environment & Productivity

Centre for Energy, Environment and Productivity

PLOT No. 1039, 26th Street, H-Block,

Ponni Colony, Anna Nagar, Chennai - 600 040.

PH : 044 2616 3483, 9444882553

## 12. ABBREVIATIONS

|      |   |  |     |   |                              |
|------|---|--|-----|---|------------------------------|
| ABR  | : | Average billing rate                                     | UG  | : | Underground                  |
| ACSR | : | Aluminium core steel reinforced                          | UPS | : | Uninterruptible power supply |
| APFC | : | Automatic Power Factor controller                        | VFD | : | Variable frequency drive     |
| AVG  | : | Average  |     |   |                              |
| BD   | : | Billing demand   |     |   |                              |
| BDV  | : | Breakdown voltage  |     |   |                              |
| BEE  | : | Bureau of energy efficiency                              |     |   |                              |
| CEA  | : | Central electrical authority                             |     |   |                              |
| CFL  | : | Compact fluorescent lamp                                 |     |   |                              |
| CFM  | : | Feet cube per minute                                     |     |   |                              |
| CT   | : | Current transformer                                      |     |   |                              |
| DB   | : | Distribution Board                                       |     |   |                              |
| DC   | : | Designated consumer                                      |     |   |                              |
| DT   | : | Distribution transformer                                 |     |   |                              |
| EC   | : | Energy Conservation                                      |     |   |                              |
| FD   | : | Forced draft   |     |   |                              |
| HPSV | : | High pressure sodium vapour                              |     |   |                              |
| HT   | : | High Tension   |     |   |                              |
| IEC  | : | International electro technical<br>commission            |     |   |                              |
| IEEE | : | The Institute of electrical and<br>electronics engineers |     |   |                              |
| IS   | : | Indian Standard  |     |   |                              |
| KG   | : | Kilo gram  |     |   |                              |
| KSEB | : | Kerala state electricity board                           |     |   |                              |
| KVA  | : | Kilo Volt Ampere   |     |   |                              |
| KVAH | : | Kilo volt Ampere Hour                                    |     |   |                              |
| KVAR | : | Kilo volt ampere   |     |   |                              |
| KW   | : | Kilo Watts   |     |   |                              |
| KWH  | : | Kilo watt hour   |     |   |                              |
| LED  | : | Light emitting diode                                     |     |   |                              |
| LT   | : | Low tension  |     |   |                              |
| MAX  | : | Maximum  |     |   |                              |
| MH   | : | Metal halide   |     |   |                              |
| MU   | : | Million units  |     |   |                              |
| MVA  | : | Mega volt ampere   |     |   |                              |
| MW   | : | Mega watt  |     |   |                              |
| NEMA | : | National Electrical Manufacturers<br>Association         |     |   |                              |
| ONAN | : | Oil natural air natural                                  |     |   |                              |
| PCC  | : | Point of common coupling                                 |     |   |                              |
| PF   | : | Power factor   |     |   |                              |
| PSI  | : | Pound square inch  |     |   |                              |
| PT   | : | Protentional transformer                                 |     |   |                              |
| R/km | : | Resistance per kilometre                                 |     |   |                              |
| RMD  | : | Registered Maximum demand                                |     |   |                              |
| SDA  | : | State designated agency                                  |     |   |                              |
| SEC  | : | Specific electricity consumption                         |     |   |                              |
| SFU  | : | Switch Fuse Unit   |     |   |                              |
| SLD  | : | Single Line Diagram                                      |     |   |                              |
| TDD  | : | Total demand distortion                                  |     |   |                              |
| THD  | : | Total harmonics distortion                               |     |   |                              |
| TOD  | : | Time of day  |     |   |                              |
| TOE  | : | Tonne of oil equivalent                                  |     |   |                              |
| TPEA | : | Third party energy auditor                               |     |   |                              |