

FY 2022-23 (JULY 2023)

**ANNUAL ENERGY AUDIT REPORT
OF**

BSES YAMUNA POWER LTD.

SHAKTI KIRAN BUILDING, KARKARDOOMA, DELHI-110032

Audit Conducted and Report prepared by

K K JHA (AEA -007/ EMAEA-026)



PADMASHTDAL ENERGY SERVICES PVT. LTD.

320, Janaki Appt. Plot No 7, Sec -22, Dwarka, N. Delhi – 110077

Telefax : 91-11-28051185, Mobile : 9810392563,9811942412

Table of Contents

Table of Contents

List of Table

List of Figures

Acknowledgement

LIST OF ABBREVIATIONS

1 Executive summary

1.1	Brief Overview of the BSES- Yamuna Power Ltd. (BYPL)	14
1.2	Goals and Objective	14
1.3	About Energy Audit Firm	15
1.4	Period of audit	15
1.5	Energy Input, Output and Losses	16
1.6	Major challenges and goals for the upcoming year	16
1.7	Major activities to meet challenge and goal	17
1.8	Summary and classification of Energy	17
1.9	Energy Conservation measures and initiative for technical loss reduction	17
1.10	Notes On Calculation of Feeder Wise Loss	17
1.11	Notes On Calculation of DT Wise Loss	18
1.11.1	Constraint to compute DT Wise Loss:	18

2 Background

2.1	Extent Regulation and Role of BEE	19
2.1.1	The objective of BEE	21
2.1.2	Role of BEE	21
2.1.3	Regulatory framework for Energy Accounting & Audit	22
2.2	Purpose of Audit and Accounting Report	24
2.3	Period of Energy Auditing and Accounting	25

3 Introduction of Discom

3.1	Details of BSES- Yamuna Power Ltd. (BYPL)	26
3.2	Details of Authorised signatory and Energy Manager of BYPL	26
3.3	Profile of BYPL	27
3.3.1	Details of Energy Accounting /Audit wing of BSES Yamuna Power Limited (BYPL)	29
3.3.2	Organizational Structure of BSES Yamuna Power Limited (BYPL)	29
3.3.3	Consumer Details of BSES Yamuna Power Limited (BYPL)	31
3.4	Electrical infrastructure and assets Voltage wise	32

3.4.1	Network Infrastructure of BSES Yamuna Power Limited (BYPL)	32
3.4.2	Metering Details of BSES Yamuna Power Limited (BYPL)	33
3.4.3	Distribution Transformer (DT) Details of BYPL	34
3.4.4	Feeder Details of BYPL	34
3.4.5	Distribution Line Details of BYPL	34
3.4.6	Energy Flow Details	35
3.4.7	Pattern of Energy Distribution in BYPL	35
3.4.8	Salient Features of BYPL	38
3.5	Energy Conservation Measures	39
3.5.1	Energy Conservation Measures Already Taken by BYPL	39
3.5.2	Proposal for Energy Conservation Measures.	39
4	Energy Flow Analysis	43
4.1	Energy Flow Across Five Service Level	43
4.2	Validation of Metered Data	44
5	Loss And Subsidy Computation	45
5.1	Energy accounts analysis for FY 2022-23	45
5.1.1	Summary of AT&C Loss	45
5.1.2	Division wise T&D and AT&C Losses	46
5.2	Energy accounts analysis for FY 2022-23	47
5.2.1	Summary of AT&C Loss	47
5.2.2	Division wise T&D and AT&C Losses	47
5.3	Energy accounts analysis for FY 2022-23	48
5.3.1	Month wise Input energy and billed energy details	48
5.3.2	Quarterly and annual AT&C losses	49
5.3.3	Voltage wise AT&C losses	50
5.3.4	Circle wise AT&C losses analysis	51
5.3.5	Division wise AT&C losses analysis	53
5.3.6	Feeder wise AT&C losses analysis	61
5.4	Subsidy Computation and analysis (based on quarterly data)	61
5.4.1	Subsidy Computation & Analysis (based on quarterly data)	61
5.4.2	Category Wise subsidy details	63
5.5	Trend analysis and identification of key exceptions	67
6	Energy Audit Finding	68
6.1	Review of capacity of DISCOM's energy accounting and audit wing	68
6.2	Critical Analysis	68
6.2.1	Transformer loading & Efficiency analysis	71

6.2.2	Status and Progress in Compliance to pre-requisites to energy accounting	72
6.2.3	Data gaps	77
6.3	Revised finding based on data validation and field verification	79
6.4	Inclusions and Exclusions	79
6.4.1	Input Energy Details & Infrastructure	79
6.4.2	Details of Feeder Levels	80
6.4.3	Generating Station wise POC Loss Calculation	80
6.4.4	Division and Subdivision wise distribution of embedded generation	81
6.4.5	Period for T&D Loss and AT&C loss calculation	82
7	Conclusion and Action Plan	
7.1	Summary of critical analysis and way forward proposed by Energy Auditor	83
7.1.1	Areas of Inefficiencies:	83
7.1.2	Recommendations:	83
7.1.3	Cost- Benefit Analysis:	83
7.2	Summary of key findings-energy balance and losses	83
7.3	Recommendations and best practices	84
7.3.1	Energy accounting	84
7.3.2	Loss reduction	84
7.3.3	Energy conservation	85
7.4	Action Plan for line loss reduction	85
7.5	Action plan for monitoring and reporting	86
7.6	Action plan for automated energy accounting	86
8	Annexure	
8.1	Annexure 1:Introduction of Verification Firm	88
8.1.1	Brief of Verification Firm	88
8.1.2	Composition of Team	88
8.1.3	Registration No	89
8.1.4	Undertaking	89
8.2	Annexure 2: Minutes Of Meeting with the Discom Team	89
8.3	Annexure 3: Checklist Prepared by Auditing Firm	89
8.4	Annexure 4: Brief Approach, Scope & Methodology for audit	91
8.4.1	Scope	91
8.4.2	Approach and methodology	91
8.5	Annexure 5: Infrastructure Details	92
8.5.1	Grid Source	94
8.5.2	Power Transformer	94

8.5.3	EHV Feeder _____	95
8.5.4	Distribution Transformer _____	95
8.5.5	11 KV Feeder _____	95
8.5.6	LT Feeders _____	95
8.5.7	Protection/Switching System _____	95
8.5.8	Metering System _____	95
8.5.9	Cables _____	95
8.5.10	Power Capacitors _____	96
8.5.11	Earthing System _____	96
8.6	Annexure 6: Electrical Distribution System _____	96
8.7	Annexure 7: Power Purchase Details _____	97
8.7.1	Input Purchase power for FY 2022-23 _____	98
8.7.2	Circle wise monthly Input Energy for FY2022-23 _____	99
8.8	Annexure 8: Line Diagram (SLD) _____	99
8.8.1	SLD of East Zone _____	99
8.8.2	SLD of Central Zone _____	99
8.9	Annexure 9: Category of service details (With Consumer and voltage-wise) _____	100
8.10	Annexure 10: Field verification Data and Reports _____	100
8.11	Annexure 11: List of documents verified with each parameter _____	101
8.12	Annexure 13: List of Parameters arrived through calculation or formulae with list of documents as source of Data _____	101
8.13	Annexure 14: Details of attachment _____	102
Following (8.13.1 to 8.13.12) attached as attachment 12 _____		
8.13.1	General Information _____	102
8.13.2	Summary Sheet _____	102
8.13.3	Infrastructure Details _____	102
8.13.4	Details of Input Energy and Sales _____	102
8.13.5	Details of Input Energy _____	102
8.13.6	Details Of Received Sources _____	102
8.13.7	Details Of Consumer _____	102
8.13.8	Division Wise Loss _____	102
8.13.9	Details Of Feeder Wise Losses _____	102
8.13.10	Details Of Subsidy _____	102
8.13.11	DT Metering and AMR Status _____	102
8.13.12	DT Wise Loss Report _____	102
8.14	Attachment 1: Details of Energy audit Cell – Shared _____	102

8.15	Attachment 2: Drawing of outgoing feeder (<i>GIS to suggest name of feeder</i>) _____	102
8.16	Attachment 3: Sample Test certificate for 3 cases _____	102
8.17	Attachment 4: Form 3 FY 2022-23 _____	102
8.18	Attachment 5: Power Purchase Certificate _____	102
8.19	Attachment 6: SLD East Zone _____	102
8.20	Attachment 7: SLD Central Zone _____	103
8.21	Attachment 8: DTL Billing details _____	103
8.22	Attachment 9: Balance Sheet (Sales) Notes _____	103
8.23	Attachment 10: Subsidy certificate _____	103
8.24	Attachment 11: Subsidy order _____	103
8.25	Attachment 12 : BEE Formats (Annual Data) _____	103
8.26	Attachment 13 & 14 :Images of DT & Feeder meters _____	103
8.27	Attachment 15: Slot-wise details of DT & feeder meters. _____	103
8.28	Attachment 16 : Consumer meter data _____	103
8.29	Attachment 17 : Minutes of meeting _____	103

List of Table

Table 1 BYPL Consumer Profile (FY 2022-23)	14
Table 2 Energy Performance	16
Table 3 Details of Recommendation	17
Table 4 Period of Energy Auditing and Accounting	25
Table 5 Details of BYPL	26
Table 6 Details of Authorised Signatory and Energy Manager of BYPL.....	27
Table 7 Details of Energy accounting/Audit Wing of BYPL.....	29
Table 8 Administrative hierarchy structure in BYPL.....	29
Table 9 Administrative hierarchy in BYPL up to Section Level	29
Table 10 Customer Profile BYPL (FY 2022-23)	31
Table 11 Network Infrastructure Details.....	32
Table 12 Input Energy and Infrastructure Details	32
Table 13 voltage wise Metering Details	33
Table 14 details of distribution Transformer.....	34
Table 15 Details of Feeder.....	34
Table 16 Length of Distribution Line	34
Table 17 Energy Flow Details.....	35
Table 18 Month wise input energy for FY 2022-23	36
Table 19 Month wise Billed Energy Fy 2022-23	37
Table 20 Voltage Wise Consumption Pattern	38
Table 21 Cost Benefit of Recommendation 1.....	40
Table 22 Cost Benefit of Recommendation 2.....	42
Table 23 AT&C Losses FY 2022-23	45
Table 24 Division wise T&D and AT&C Loss FY 2022-23.....	46

Table 25 AT&C Losses FY 2022-23	47
Table 26 Division wise T&D and AT&C Loss FY 22-23.....	48
Table 27 Month wise Input energy & Billed Energy	49
Table 28 Energy Input and AT&C Losses FY 2022-23	49
Table 29 Voltage wise AT&C Losses FY 2022-23	50
Table 30 Circle Wise No of consumer, Input Energy & Losses FY 2022-23	51
Table 31 Circle wise T&D losses, Collection Efficiency and AT&C Losses.....	52
Table 32 Division wise T&D losses, collection efficiency and AT&C Losses	53
Table 33 Top 5 number division with higher AT&C Losses in % and T&D Losses in MU.....	59
Table 34 Quarter Wise Subsidy Details	62
Table 35 Subsidy details 2022-23	63
Table 36 Transformer Loading and Efficiency analysis.....	72
Table 37 Compliance status w.r.t Timelines and Pre-requisites	72
Table 38 Pre-Requisites for Annual Energy Audit and periodic Energy Accounting	76
Table 39 Summary of Data gaps	77
Table 40 Comments on BEE format.....	78
Table 41 Energy balance and losses	83
Table 42 Details of Study Team	89
Table 43 Infrastructure Details.....	92
Table 44 Metering Details	92
Table 45 Inventory List as on March 2023	94
Table 46 System Element Power Loss	97
Table 47 Source of Power.....	97
Table 48 Month wise power purchase	98
Table 49 Circle wise monthly input energy (MU).....	99
Table 50 Energy Balance BSES Yamuna.....	100

Table 51 Field inspection details	100
Table 52 List of documents verified with each parameter.....	101
Table 53 Formulas used to derive the Parameters	102

List of Figures

Figure 1Regulatory Framework for Energy Accounting & Audit	23
Figure 2 Organisational chart of Energy Accounting/ audit wing of BYPL.....	29
Figure 3 Circle wise T&D Loss %	52
Figure 4 Division Wise T&D Losses in MU Vs In AT&C Loss in %	58
Figure 5 AT&C Loss VS T&D Loss in %.....	59
Figure 6 Division wise Collection efficiency.....	61
Figure 7 Category wise Subsidy 2022-23.....	64
Figure 8 Division wise Subsidy 2022-23.....	66
Figure 9 Methodology	92
Figure 10 SLD of East Zone	99
Figure 11 SLD of Central Zone	99

Acknowledgement

We express our sincere gratitude to the management of BSES – Yamuna New Delhi for giving us the opportunity to conduct the energy audit of DISCOM for FY 2022-23, in accordance with the Bureau of Energy Efficiency (Manner and Intervals for Conduct of Energy Audit (Accounting) In Electricity Distribution Companies) Regulation, 2022 And Its Amendment (Vide Notification No 18/1/BEE/DISCOM/2021 Dated 6th October 2021 and Amendment Dated 28th October 2022). . We thankfully acknowledge the support provided by Mr. Brajesh Kumar, Head – Business & Mr. Naveen Vats, Head – Business (Retail) & Mr. Rajesh Srivastava, VP & Energy Manager and concerned departmental leaders during the conduct of this exercise.

Mr. Samir Banger	Asst. V P -GIS
Mr. Dilip Agrawal	Asst. V P -PMG
Mr. Devanshu Sharma	GM-PAT Cell & Business
Mr. Bidyut Dey	GM- Energy Audit
Mr. Govind Gandhi	GM, Finance
Mr. Manjeet Singh	GM, O&M
Mr. Mohan Tahilyani	DGM, IT
Mr. Vikas Dixit	DGM, Regulatory Affairs
Mr. Sameer Singh	DGM, Regulatory Affairs


We are thankful to all officers and employees of the BSES – Yamuna Power Ltd. New Delhi with whom we interacted during the field studies for their wholehearted support in undertaking measurements and eagerness to assess the system / equipment efficiencies and saving potential. The willingness of these key personnel to participate in this program and acknowledge the call for energy efficiency is more than half the issues resolved.

We are also thankful to the site working staff for their positive support in undertaking this intricate task of system mapping and measurement activity. The field studies would not have been completed on time without their interaction and timely support. We are grateful for their co-operation during field studies and providing of data for the study.

Last but not the least; The management of the company deserves special appreciation for undertaking energy audit of its system, this initiative by the company is a major step towards mitigating the biggest risk the mankind is facing in this 21st century- global warming.

PESPL looks forward to their continued support in all future endeavors as well.

Signature



Name : Kamalesh K Jha
 Designation : Accredited Energy Auditor
 Registered No : AEA 0007
 Firm : Padmashtdal Energy Services P Ltd.

LIST OF ABBREVIATIONS

AEA	Accredited Energy Auditor
AMI	Advanced Metering Infrastructure
AMR	Automated Meter Reading
AMRUT	Atal Mission for Rejuvenation and Urban Transformation
AT&C	Aggregate Technical and Commercial
APFC	Automatic Power Factor Control
BEE	Bureau of Energy Efficiency
BYPL	BSES Yamuna Power Limited
CEA	Certified Energy Auditor
CERC	Central Electricity Regulatory Commission (India)
CO2	Carbon dioxide
CKT	Circuit
CT	Current Transformer
DC	Designated Consumer
DEEP	Discovery of Efficient Electricity Price
DERC	Delhi Electric Regulatory Company
DISCOM	Electricity Distribution Company
DT	Distribution Transformer
EA	Energy Audit
EAR	Energy Audit Report
EC	Energy Conservation
EE	Energy Efficiency
ECM	Energy Performance Improvement Action
EHT	Extra High Tension
EHV	Extra High Voltage
EM	Energy Manager
FY	Financial Year
GHG	Greenhouse Gas
HT	High Tension

HVDS	High Voltage Distribution System
IPMVP	International Performance Measurement and Verification Protocol
LT	Low Tension
MNRES	Indian Ministry of Non-Conventional and renewable Energy Sources
MoP	Ministry of Power
M&V	Measurement and Verification
NCV	Net Calorific Value
NO	Nodal Officer
OA	Open Access
O&M	Operation and Maintenance
PF	Power Factor
PLC	Programmable Logic Control
POC	Point of Connection
PT	Potential Transformer
PX	Power Exchange
PMV	Performance Measurement and Verification
RE	Renewable Energy
RLDC	Regional Load Dispatch Centre
SDA	State Designated Agency
SLD	Single Line Diagram
SLDC	State Load Dispatch Centre
T&D	Transmission and Distribution

UNITS AND MEASURES

GWh (or MU)	Giga Watt Hour or Million Units
KVA	Kilo Volt Ampere
MW	Mega Watt
KWh	Kilo Watt Hour (Unit)
MWe / GWe	Megawatt / Gigawatt of electricity capacity
V	Voltage

Conversion Factors

1kgoe 10000 Kcal

1 kWh 860 Kcal

Emission Factor

Electricity 0.82 Kg CO₂/kWh

1 Executive summary

1.1 Brief Overview of the BSES- Yamuna Power Ltd. (BYPL)

BYPL is responsible for Central and East Delhi Power Distribution, spread over an area of 180 sq. km catering to a customer base of 1.9 million, with the apparent customer density for it being 10,575 Cons. /sq. km. While the energy billed by BYPL for the customer is 6958 MU, the peak demand of 1752 MW, the monthly consumption per customer stands at 304.6 Kwh/Month. BYPL cater to areas spread over 14 division across Central, North East and South East areas including Chandni Chowk, Darya Ganj, GT Road, Karkardooma, Karawal Nagar, Krishna Nagar, Laxmi Nagar, Mayur Vihar Phase I & II, Mayur Vihar – Phase III, Nandnagri, Pahar Ganj, Patel Nagar, Shankar Road and Yamuna Vihar. The Consumer profile of BYPL is shown in following table.

Table 1 BYPL Consumer Profile (FY 2022-23)

BYPL Customer Profile				
Category	Consumption		Consumer Number	
	MU	% Share	Number	% Share
Residential HT	85	1.23%	43	0.00%
Residential LT	4,312	61.97%	1,482,598	77.89%
Commercial-HT	308	4.43%	314	0.02%
Commercial-LT	1,407	20.22%	406,731	21.37%
Industrial-HT	79	1.14%	34	0.00%
Industrial-LT	302	4.33%	7,620	0.40%
Others	466	6.69%	6,217	0.33%
Total	6,958		1,903,557	

1.2 Goals and Objective

BYPL is a designated consumer in Discom sector. Being a designated Consumer BYPL need to have Annual energy audit (Accounting) of their facilities as per BEE notification No 18/1/BEE/Discom/2021 dated 6th October 2021.

The Annual Energy Audit (Accounting) at BYPL is conducted with the following Objectives:

- Verification of existing pattern of energy distribution across periphery of electricity Distribution Company.
- Verification of accounted energy flow submitted by electricity Distribution Company at all applicable voltage levels of the distribution network.
- Verification of the accuracy of the data collected and analyse and process the data with respect to consistency, improvement in accounting and reducing loss of DISCOM.
- Verification of the information submitted by DC to the SDA/BEE about status of energy input, Output and loss for the previous two year.
- Access the past performance of the establishment.
- Quantification of Energy Losses, and Energy Saving Potential.

1.3 About Energy Audit Firm

Padmashtdal Energy Services Private Limited (PESPL) is a service consultancy company providing techno commercial solution to customers in the areas of Power System, Industrial Electronics and Utility system management since 1996. In last few years of its operation, the company has been able to generate positive reputation and goodwill among its clientele.

PESPL entered into the arena of ENERGY CONSERVATION in 2005 with the aims to assist all stakeholders in implementing energy efficiency and creating awareness about the merits of energy efficiency and safety practices. Company is an accredited energy audit firm and also empanelled with BEE (A statutory body under Ministry of Power, Govt. of India) for PAT Baseline Audit, Mandatory Energy Audit and M & V Audits. Our CEO of company Mr. Kamallesh Kumar Jha is also an Accredited Energy Auditor by BEE.

We have conducted several energy audits and provided consultancy to industrial units and office facilities to achieve substantial reduction in their Energy-Cost. Our client base includes Sugar industries, Paper Industries, Power Plants, steel plant, MSME units, commercial buildings etc.

1.4 Period of audit

Energy audit activity was started with a meeting at Head Office of BYPL in the month of June 2023. Based on the requirement, visits were made to Division, Subdivision, Grid etc. for data collection and technical discussion. The period of study was from April 2022 to March 2023.

1.5 Energy Input, Output and Losses

The trends of energy input, output and loss for the year 2022-23 is shown in following table.

Table 2 Energy Performance

Trend of BYPL (2022-23)				
Sr. No.	Energy Input Details	Formula	UOM	Value
1	Purchase Energy (From Generation Source)	A	MU	8704
2	Net Energy Input to Discom (at DISCOM Periphery after adjusting the transmission losses and energy traded)	B	MU	7504
3	Energy billed (is the Net energy billed, adjusted for energy traded)	C	MU	6,958.33
4		D	Rs. Crores	5,592.87
5	Average Billing Rate	$E=D*10/C$	Rs/Kwh	8.04
6	Amount collected	F	Rs. Crores	5,641.15
	Transmission and Distribution (T&D) Loss	$G=B-C$	MU	545.43
7		$H= G/B$	%	7.27%
8		$J=E*G/10$	Rs. Crores	438.40
10	Billing Efficiency	$K=C/B$	%	92.73%
11	Collection efficiency	$L=F/D$	%	100.86%
12	Aggregate Technical & Commercial (AT&C) Loss	$M =1-(K*L)$	%	6.47%

1.6 Major challenges and goals for the upcoming year

- For sustainable growth of company major challenge and goal is to reduce T&D and AT&C loss in divisions which are having losses higher than Discom average value.
- To meet the T&D reduction target given by DERC and PAT target given by BEE.

1.7 Major activities to meet challenge and goal

To achieve Loss reduction target BYPL has started various activities for strengthening and monitoring of entire network so that corrective action can be taken to reduce losses.

1.8 Summary and classification of Energy

- Being a Discom, BYPL procures Electrical Energy from long term and short-term sources and distributed it to the end users.
- To fulfill the requirement of RPO compliance BYPL is procuring power from long term purchases, net metering consumers and REC certificates etc.

1.9 Energy Conservation measures and initiative for technical loss reduction

- Various measures are identified to reduce the T & D as well as AT&C losses in FY 2022-23. Some of them are mentioned below:

Table 3 Details of Recommendation

Sl. No	Energy Efficiency Measures	Estimated Annual Energy Savings/Billing	Estimated Investment	Monetary Savings	Simple Payback Period	Emission Reduction	Eq. Energy Saving
		Electricity (M KWh)	(Rs. In Crores)	(Rs. In Crores)	(Months)	(t CO ₂)	(TOE)
1	ECM 1- Improvement in metering system	25	40	18	27	-	-
2	ECM 2- Improvement & Automation	34	60	25	31	28900	2923
Total		59	100	43	-	28900	2923

1.10 Notes On Calculation of Feeder Wise Loss

- Every 11kV Feeder is having RING main supply arrangement under which DTs or HT Consumers are back-fed through other than normal dedicated feeder based on the system and network requirements. Since the downstream network from feeder to DT is so dynamic in nature that it is very cumbersome to maintain the feeder network connectivity to DT accurately. Such switchovers will trigger the change in normal

network configuration leading to downstream network connectivity and shift the network cut-off points and ultimately the change in grouping of DTs.

- Hence, there could be instances where the Feeder consumption figure would be higher than the figure of energy received at that Feeder. Hence, It is requested to modify this form to exclude Subdivision and Feeder consumption or consider the aggregated figures of consumption and feeder input for all feeders taken together.
- Further, a Feeder can supply load to multiple Division & Subdivision.

1.11 Notes On Calculation of DT Wise Loss

- As per Govt. of India Gazette Notification of Bureau of Energy Efficiency (Manner and Intervals for Conduct of Energy Audit (Accounting) in Electricity Distribution Companies) Regulations, 2021 dated 07th October, 2020-21 format for the DT wise Loss computation was not notified. Format is included in the Gazette Notification of Energy Audit Amendment Regulation named as “The Bureau of Energy Efficiency (Manner and Intervals for Conduct of Energy Audit in electricity distribution companies) Amendment Regulations, 2022” dated 28th October, 2022.

1.11.1 Constraint to compute DT Wise Loss:

- The downstream network from DT to consumer is dynamic in nature as group of consumers can be shifted from one DT to another DT in that locality hence it is very cumbersome to maintain the DT network connectivity to consumer accurately. The network is being changed during load transfer conditions which triggers to shift the network cut-off points and ultimately the change in grouping of consumers. This poses an acute problem in computing the losses at DT level.
- As per the Bureau of Energy Efficiency (Manner and Intervals for Conduct of Energy Audit in electricity distribution companies) Amendment Regulations, 2022, smart meters installation for consumers to be completed till March 2025. After completion of smart meter installation, deviation between input energy cycle and consumer billing cycle can be eliminated, and actual DT wise loss can be calculated.
- It is requested to consider cluster wise DT loss report instead of individual DT loss report so that energy gaps due to shifting of group of consumers from on DTs to the nearby DTs can be accounted.
- BYPL is submitting Cluster wise loss report to DERC.
- Completion of consumer connect project after getting the approval from Hon’ble commission, Individual DT loss can be calculated.

- It is expected that mapping of low-tension consumers with DTs and LT network on GIS will take 2 years after getting approval from DERC.

- **Disclaimer**

- The above analysis is based on the details available on publicly available data and the data shared the DISCOM from their MIS/ Dashboard/ R15/ Power BI. Therefore, there may be deviation between the numbers shown in this report and the values shown in the Annual Audit report.

2 Background

2.1 Extent Regulation and Role of BEE

Recognizing the fact that efficient use of energy and its conservation is an essential part of India's goals to mitigate the gap between demand and supply and to promote economic competitiveness, the Government of India enacted the Energy Conservation Act – 2001. The Act provides for institutionalizing and strengthening delivery mechanisms for energy efficiency services in the country and provides the much-needed coordination between the various organizations and stakeholders, within the Government and in the private sector.

The Government of India has set up Bureau of Energy Efficiency (BEE) (Website: www.beeindia.gov.in) on 1st March, 2002 under the provisions of the Energy Conservation Act, 2001. The mission of Bureau of Energy Efficiency is to assist in developing policies and strategies with a thrust on self-regulation and market principles, within the overall framework of the Energy Conservation Act, 2001 with primary objective of reducing energy intensity of the Indian economy. Overcoming barriers for financing of energy efficiency is a key policy goal. This will be achieved with active participation of all stakeholders, resulting in accelerated and sustained adoption of energy efficiency in all sectors.

The setting up of Bureau of Energy Efficiency (BEE) provides a legal framework for energy efficiency initiatives in the country. The Act empowers the Central Government and in some instances the State Governments to:

- Notify energy intensive industries, other establishments, and commercial buildings as designated consumers.
- Establish and prescribe energy consumption norms and standards for designated consumers.

- Direct designated consumers to designate or appoint certified energy manager in charge of activities for efficient use of energy and its conservation.
- Get an energy audit conducted by an accredited energy auditor in the specified manner and intervals of time.
- Furnish information with regard to energy consumed and action taken on the recommendation of the accredited energy auditor to the designated agency.
- Comply with energy consumption norms and standards, and if not so, to prepare and implement schemes for efficient use of energy and its conservation.
- Prescribe energy conservation building codes for efficient use of energy and its conservation in commercial buildings State Governments to amend the energy conservation building codes to suit regional and local climatic conditions.
- Direct owners or occupiers of commercial buildings to comply with the provisions of energy conservation building codes.
- Direct mandatory display of label on notified equipment's and appliances.
- Specify energy consumption standard for notified equipment's and appliances.
- Prohibit manufacture, sale, purchase and import of notified equipment and appliances not conforming to standards.

Schedule to EC Act provides list of 15 energy intensive industries and other establishments to be notified as designated consumers (DC).

Section 14 (e) of the EC Act provides that the Central Government may, by notification, in consultation with the Bureau of Energy Efficiency specify any user or class of user of energy as designated consumers which satisfies the following conditions:

- i. Energy Quantity or Energy Intensity
- ii. Amount of investment required for switching over to energy efficient equipment;
- iii. Capacity of the industry to make investment for switching over to energy efficient equipment; and
- iv. Availability of the energy efficient machinery and equipment required by the industry.

Since the objective of the Act is to promote energy efficiency and its conservation and consequently to reduce the energy cost, selection of industry for the purpose of declaring it, the Designated Consumer under Section 14(e) of the EC Act should primarily take into account-

- (i) total annual energy consumption in Metric Ton of Oil Equivalent;
- (ii) Energy intensity; and
- (iii) Percentage of Energy cost on total cost, as every designated consumer is always keen to reduce energy consumption as well as energy cost to make its product competitive. in exercise of the powers conferred by clause (g) of sub-section (2) of section 58, read with clause (q) of sub-section (2) of section 13 of the Energy Conservation Act, 2001 (52 of 2001), the Bureau of Energy Efficiency, with the previous approval of the Central Government, hereby makes the following regulations, namely: --Manner and Intervals for Conduct of Energy Audit in electricity distribution companies Regulations, 2021.

These regulations shall apply to all electricity distribution companies specified as designated consumer.

They shall come into force on the date of their publication in the Official Gazette which is 6th October 2021

2.1.1 The objective of BEE

- To develop Policies and Programmers on efficient use of energy and its conservation with the involvement of Stakeholders.
- To Plan manage and implement energy conservation programmers as envisaged in the EC Act.
- To assume leadership and provide policy framework and direction to national energy efficiency and conservation efforts and programmers.
- To demonstrate energy efficiency delivery mechanism, as envisaged in the EC Act, through public – private partnership (PPP).
- To establish systems and procedures to measure, monitor and verify energy efficiency results in individual sectors as well as at the national level.
- To leverage multi-lateral, bi-lateral and private sector support in implementation of programmers and project on efficient use of energy and its conservation.
- To promote awareness of energy saving and energy conservation.

2.1.2 Role of BEE

- BEE coordinates with designated agencies, designated consumers and other organization working in the field of energy conservation/efficiency to recognize and utilize the existing resources and infrastructure in performing the functions assigned to the bureau under the energy conservation Act.
- The Act provides regulatory mandate for: standards and labeling of equipment and appliances; energy conservation building code for commercial buildings; and energy consumption norms of energy intensive industries.

- The EC Act was amended in 2010 to incorporate few additional provisions required to better equip BEE to manage ever evolving sphere of energy efficiency in the country.
- Create awareness and disseminate information of energy efficiency and conservation.
- Arrange and organize training of personnel and specialist in the techniques for efficient use of energy and its conservation.
- Strengthen consultancy services in the field of Energy Efficiency.
- Promote research and development.
- Develop testing and certification procedures and promote testing facilities.
- Formulate and facilitate implementation of pilot project and demonstration projects.
- Promote use of energy efficient processes, equipment, devices and systems.
- Take steps to encourage preferential treatment for use of energy efficient equipment or appliances.
- Promote innovative financing of energy efficiency projects.
- Give financial assistance to institution for promoting efficient use of energy and its conservation.
- Prepare educational curriculum on efficient use of energy and its conservation.
- Implement international co-operation programmers relating to efficient use of energy and its conservation.

2.1.3 Regulatory framework for Energy Accounting & Audit

The Energy Conservation Act 2001 (hereafter referred to as EC Act. 2001) was enacted on 29th September 2001 & EC (Amendment) Act 2022. The EC Act 2001 & further amendments empowers BEE to notify regulations regarding energy conservation and efficiency improvement in accordance with the EC Act, BEE notified the Bureau of Energy Efficiency (Manner and Intervals for Conduct of Energy Audit) Regulations, 2021, on 6th October 2021. BEE subsequently amended these regulations with the Bureau of Energy Efficiency (Manner and Intervals for Conduct of Energy Audit) (Amendment) Regulations, 2022, The Ministry of Power (MoP) issued guidelines on 17th January 2023 for energy accounting and auditing of distribution companies, in line with the BEE regulations. Distribution companies and energy Audit firms must comply with this regulatory framework when preparing energy accounts and audit reports. The regulatory framework for Energy accounting and Energy Auditing is shown in the below figure:




Figure 1 Regulatory Framework for Energy Accounting & Audit

2.1.3.1 Key Highlights of the Regulatory Framework Are Listed Below

- The Central Government may issue the energy savings certificate to the designated consumer whose energy consumption is less than the prescribed norms and standards in accordance with the procedure as may be prescribed.
- The designated consumer whose energy consumption is more than the prescribed norms and standards shall be entitled to purchase the energy savings certificate to comply with the prescribed norms and standards

- The Central Government may, in consultation with the Bureau prescribe value of per metric ton of oil equivalent of energy consumed
- Commercial building which are having a connected load of 100kw or contract demand of 120 kva and above brought under the purview under the EC Act.

2.2 Purpose of Audit and Accounting Report

BYPL is a designated consumer in Discom sector. Being a designated Consumer BYPL need to have Annual energy audit (Accounting) of their facilities as per BEE notification No 18/1/BEE/Discom/2021 dated 6th October 2021.

The energy intensity of India is higher with respect to GDP growth and there is an urgent need to address these issues on priority through integrated and comprehensive approach and by adopting latest techniques and technologies with active participation of all stakeholders.

Sensing the need of the hour Government of India initiated a mechanism for all energy intensive large industries and facilities (designated consumer) known as PAT Scheme which is “A market-based mechanism to enhance cost effectiveness of improvements in energy efficiency in designated consumers, through certification of energy savings that could be traded.”

Annual Energy audit (Accounting) will not only help in reducing losses in system but it also helps DISCOM in sustainable growth. The objective of this energy audit is to reduce T&D loss and AT&C loss of the DISCOM through identification of commercially viable and implementable scheme for reduction of technical and commercial loss in the DISCOM thus leading to sustainable energy cost reductions.

The Annual Energy Audit (Accounting) at BYPL is conducted with the following Objectives:

- Verification of existing pattern of energy distribution across periphery of electricity distribution company.
- Verification of accounted energy flow submitted by electricity distribution company at all applicable voltage levels of the distribution network.
- Verification of the accuracy of the data collected and analyse and process the data with respect to consistency, improvement in accounting and reducing loss of DISCOM.

- Verification of the information submitted by DC to the SDA/BEE about status of energy input, Output and loss for the previous two year.
- Access the past performance of the establishment.
- Quantification of Energy Losses, and Energy Saving Potential.

2.3 Period of Energy Auditing and Accounting

Energy audit activity was started with a meeting at Head Office of BYPL in the month of June 2023. Based on the requirement visit was made to Division, Subdivision, Grid etc. for data collection and technical discussion. The period of study was from April 2022 to March 2023.

Table 4 Period of Energy Auditing and Accounting

Particulars	Energy Accounting				Energy Audit
	Q1	Q2	Q3	Q4	FY22-23
Applicable Period	1 st April 2022 to 30 th June 2022	1 st July 2022 to 30 th September 2022	1 st October 2022 to 31 st December 2022	1 st January 2023 to 31 st March 2023	1 st April 2022 to 31 st March 2023
Date Commencement	-	-	-	-	-
Date of Publishing	-	-	-	-	-
Officer In charge	-	-	-	-	K K Jha (AEA 0007) Reg. No EmAEA 0026

The quarterly reports have been sent to BEE by discom.

3 Introduction of Discom

3.1 Details of BSES- Yamuna Power Ltd. (BYPL)

The details of BYPL are shown in following table.

Table 5 Details of BYPL

Details of DISCOM – BSES- Yamuna Power Ltd. (BYPL)			
General Details			
Name of the Unit	BSES Yamuna Power Ltd.		
Year of Establishment	2002		
Government/Public/Private	Private		
Contact details & Address			
City/Town/Village	Karkardooma		
District	Delhi		
State	Delhi	Pin	110092
Telephone	011-41247111	Fax	011-41249765
Registered Office			
Name of Chief Executive	Sh. Amarjeet Singh		
Designation	CEO		
Address	Shakti Kiran Building, Karkardooma		
City/Town/Village	New Delhi	PO	
District			
State	Delhi	Pin	110092
Telephone	011-41249382	Fax	011-41249765

3.2 Details of Authorised signatory and Energy Manager of BYPL

The PAT-Cell is looked after by Mr. **Devanshu Sharma**, (**General Manager**) and Mr. **Rajesh Srivastava** (Deg) is a BEE certified Energy Manager is leading the energy accounting activities in BYPL. The details of DISCOM'S energy manager and authorized signatory for this report are shown in following table.

Table 6 Details of Authorised Signatory and Energy Manager of BYPL

Details of Authorised Signatory and Energy Manager (BYPL)			
Nodal Officer Details			
Name of Nodal Officer	Sh. Devanshu Sharma		
Designation	General Manager		
Address	Shakti Kiran Buidling, Karkardooma		
City/Town/Village	New Delhi	PO	
District			
State	Delhi	Pin	110032
Telephone	011-41249135	Fax	011-41249765
Energy Manager Details			
Name of Energy Manager	Sh Rajesh Srivastava		
Designation	Vice-President	Whether EA/EM	Energy Manager
EA/EM Registration No.	EA-24509		
Telephone	011-41249842	Fax	011-41249765
Mobile	9350261189	Email Id	rajesh.r.srivastava@relianceada.com

3.3 Profile of BYPL

BSES with its tagline ‘A Journey of Operational Excellence’ commenced its operations in Delhi in the year 2002 after the privatization of the Delhi Power Distribution System. While whole Delhi accounts for 4% of total India, BSES mainly operates in West, South, East and Central Delhi while the TPDDL (Formerly known as NDPL) operates in the North Delhi.

Prior to privatization the Delhi power situation was very poor and in dire need of improvements where AT&C Loss Level was more than 63% while the operation reliability only stood at 70%. Even with a govt. support of Rs. 1200 Cr. p.a. the Technology used was of Obsolete Legacy System with the customer service being generalist.

Post-privatization Delhi saw a turnaround in the Delhi Power Distribution System with reduction in AT&C loss, improvement in operational reliability, adoption of an Integrated System Technology and having a customer centric approach.

It has also been certified with ISO - 9001:2015 for Quality Management System, ISO – 14001:2015 for Environment Management System, ISO – 45001-2018 for Occupational Health and Safety Management, ISO/IEC – 27001:2013 for IT Security Management and ISO/IEC 17025:2005 for Testing and calibration Laboratory.

Also, due to its excellence in the field of Power Distribution System, BSES has also been graced with multiple Rewards as well as recognition both National like D L Shah - Quality Council of India, PHDCCI (*PHD Chamber of Commerce*) ICC (*Indian Chambers of Commerce*) etc. as well as international like Stevie Award and British Safety Council Award.

BSES Yamuna Power Limited (BYPL)

BYPL is the second largest utility in National Capital of Delhi in terms of Area been served and numbers of consumers been served. Since the privatization, BYPL has traversed a long and successful journey to become one of the most respected utilities in the country. Among various other achievements, BYPL has been successful in drastically bringing down the AT&C Losses from 63 % in FY 2002-03 to 7.26% in FY 2021-22 which by any standard is a significant reduction. BYPL has achieved operational excellence by providing 24X7 reliable and quality power to its consumers for more than two decades. BYPL has transformed itself into a world class utility with integrated state of the art systems, automated processes, and customer friendly value-added services. BYPL's ever improving customer centering service initiatives at Delhi. In the challenging environment of electricity distribution BYPL is redesigning its business process towards B2C business model. BYPL is Committed towards utilities led Demand Side Management (DSM) program for its consumers and views Energy efficiency as well as DSM as the cheapest resource to be dispatched in Integral Resource planning (IRP). BYPL Power Purchase Portfolio: Nearly 22% power (more than 440 MW) expected from Renewable Energy by 2022-23. Roof Top solar system has been promoted aggressively by BYPL as a result more than 12 MWp roof top solar has been installed in last 3 years.

BYPL is responsible for Central and East Delhi Power Distribution, spread over an area of 180 sq. km catering to a customer base of 1.9 million, with the apparent customer density for it being 10,575 Cons. /sq. km. While the energy billed by BYPL for the customer is 6958 MU, the peak demand of 1752 MW, the monthly consumption per customer stands at 304.6 Kwh/Month. BYPL caters to areas spread over 14 divisions across Central, North East and South East areas including Chandni Chowk, Darya Ganj, GT Road, Karkardooma, Karawal Nagar, Krishna Nagar, Laxmi Nagar, Mayur Vihar Phase I & II, Mayur Vihar – Phase III, Nandnagri, Pahar Ganj, Patel Nagar, Shankar Road and Yamuna Vihar.

The energy available at the periphery of Delhi which is procured from generating stations and transmitted by Transmission systems are used by BYPL, TPDDL, NDMC and MES.

3.3.1 Details of Energy Accounting /Audit wing of BSES Yamuna Power Limited (BYPL)

The Energy Accounting/Audit wing in the BYPL has been established on 13/12/2021. The Organization details of the DISCOM are as shown below:

Table 7 Details of Energy accounting/Audit Wing of BYPL

Sr. No.	Name	Department	Designation	Responsibility
1	Sh Rajesh Srivastava	Business	Vice - President	Energy Manager
2	Sh Govind Gandhi	Finance	General Manager	Financial Manager
3	Sh Mohan Tahilyani	IT	Dy. General Manager	IT Manager
4	Sh Devanshu Sharma	PAT Cell & Business	General Manager	Nodal Officer

Figure 2 Organisational chart of Energy Accounting/ audit wing of BYPL

3.3.2 Organizational Structure of BSES Yamuna Power Limited (BYPL)

BYPL is having its corporate office at Shakti Kiran Building, Karkardooma, Delhi and has 3 circles. These Circles are further divided into 14 Divisions & 46 Sub Division as shown in the below tables.

Table 8 Administrative hierarchy structure in BYPL

Parameter	Total
Number of Circles	3
Number of Divisions	14
Number of Sub-Divisions	46

The Circles are further divided into Divisions and Sub- Divisions as shown in the table below:

Table 9 Administrative hierarchy in BYPL up to Section Level

Circle	Division	No. of Sub-Division	Name of Sub-Division	Name of Sections
Central	Chandni Chowk	3	Hamilton Road	
			Lahori Gate	

			Town Hall	
	Darya Ganj	3	Daryaganj	
			Jama Masjid	
			Minto Road	
	Paharganj	3	B G Road	
			Chuna Mandi & Ram Nagar	
			Pp Quarters	
	Shankar Road	3	Chhapparwalan	
			Pusa Road	
			R Block New Rajender Nagar	
	Patel Nagar	3	Kikarwalan	
			Patel Nagar	
			Sarai Rohilla	
North East	GT Road	3	E&F Dilshad Garden	
			Gt Road Shahdra	
			Zaffrabad	
	Yamuna Vihar	4	C-12 Yamuna Vihar	
			Ghonda	
			New Seelampur	
			Shastri Park	
	Karawal Nagar	3	Gokul Puri	
			Karawal Nagar	
			Sonia Vihar	
	Nand Nagri	3	C-4 Nandnagri	
			Mig East Of Loni Road	
			Sudama Puri	
South - East	Karkardooma	3	B-Block Vivek Vihar	
			Jwala Nagar	
			Saini Enclave	
	Krishna Nagar	5	Gagan Vihar	
			Gandhi Nagar	

			Geeta Colony	
			Kanti Nagar	
			Krishna Nagar	
	Laxmi Nagar	4	Anand Vihar Isbt	
			Laxmi Nagar	
			Mandawali	
			Preet Vihar	
	Mayur Vihar	3	S/Stn 8 Pocket C	
			Sadar Apartments	
			Trilokpuri	
	Vasundhara Enclave	3	Mvr-lli	
			New Ashok Nagar	
			Vasundhara Enclave	
Total	14	46		

3.3.3 Consumer Details of BSES Yamuna Power Limited (BYPL)

The energy received by BYPL in the year 2022-23 and its consumption with type of customer in different segment is shown in following table and figure.

Table 10 Customer Profile BYPL (FY 2022-23)

BYPL Customer Profile				
Category	Consumption		Consumer Number	
	MU	% Share	Number	% Share
Residential HT	85	1.23%	43	0.00%
Residential LT	4,312	61.97%	1,482,598	77.89%
Commercial-HT	308	4.43%	314	0.02%
Commercial-LT	1,407	20.22%	406,731	21.37%
Industrial-HT	79	1.14%	34	0.00%
Industrial-LT	302	4.33%	7,620	0.40%
Others	466	6.69%	6,217	0.33%
Total	6,958	100%	1,903,557	100%

3.4 Electrical infrastructure and assets Voltage wise

3.4.1 Network Infrastructure of BSES Yamuna Power Limited (BYPL)

The Details of network Infrastructure owned by BYPL is shown in following table.

Table 11 Network Infrastructure Details

Asset	Particulars	Unit	FY 18-19	FY 19-20	FY 20-21	FY 21-22	FY 22-23
66KV and above	66/11 KV Sub Station	Nos	20	20	20	20	20
	66 KV feeders	Nos	60	60	61	61	61
	66 KV Line	CKt KM	225	225	235	244	244
33kv	33/11 KV Sub Station	Nos	33	33	33	33	33
	33 KV feeders	Nos	105	105	110	110	110
	33 KV Line	CKt KM	381	394	422	423	432
11kv	11 KV feeders	Nos	894	924	955	988	998
	11 KV OH Line	CKt KM	14	14	14	14	14
	11 KV UG Line	CKt KM	2869	2953	3012	3123	3207
LT	LT Line	CKt KM	2855	2939	2998	3109	3193
PT	Power Transformer	Nos	5460	5560	5684	5765	5915
	Power Transformer capacity	MVA	162	164	168	168	168
DT	Distribution Transformer	Nos	3778	3821	3921	3930	3989
	Distribution Transformer Capacity	MVA	3946	4009	4063	4101	4132

The Input energy, consumption, transmission losses and key infrastructure details of the BYPL are summarized in table below:

Table 12 Input Energy and Infrastructure Details

Sr. No	Parameters	UOM	FY 2022-23
	Input energy purchased	MU	8704
	Transmission loss	%	4.70

Transmission loss	MU	409
Energy sold outside the periphery	MU	791
Net input energy (received at DISCOM periphery or at distribution point)	MU	7503
Is 100% metering available at 66/33 Kv	Yes/No	Yes
Is 100% metering available at 11 kv	Yes/No	Yes
Metering available at DT	%	100
Metering available at consumer end	%	100
No of feeders at 66kv voltage level	Nos	61
No of feeders at 33kv voltage level	Nos	110
No of feeders at 11kv voltage level	Nos	998
No of LT feeders' level	Nos	19,543
Line length at 66kv voltage level	Ckt KM	244
Line length at 33kv voltage level	Ckt KM	432
Line length at 11kv voltage level	Ckt KM	3,207
Line length at LT level	KM	5,915
Length of Aerial Bunched Cables	KM	3,235
Length of Underground Cables	KM	6375
HT/LT ratio	%	0.54

3.4.2 Metering Details of BSES Yamuna Power Limited (BYPL)

The status of meters installed in BYPL as on 31st March 2023 are given in the below tables

Table 13 voltage wise Metering Details

Parameters	66kv and above	33kv	11/22kv	LT
Number of conventional metered consumer	BYPL is working on report generation through IT			
Number of consumers with 'smart' meters				
Number of consumers with 'smart prepaid' meters				
Number of consumers with 'AMR' meters				
Number of consumers with 'non-smart prepaid' meters				

Number of unmetered consumers			
Numbers of total consumers	3	465	1903089

3.4.3 Distribution Transformer (DT) Details of BYPL

The details of distribution transformers in BYPL as on 31st March 2023 are given in the below table:

Table 14 details of distribution Transformer

Parameters	66kv and above	33kv	11/22 kv	LT
Number of Conventionally metered Transformers			2174	NA
Number of Trfs with Communicable meters	70	98	1959	NA
Number of Unmetered Trfs	-	-	-	NA
Number of total transformers	70	98	4133	NA

3.4.4 Feeder Details of BYPL

The details of feeders in BYPL as on 31st March 2023 are given in the below table:

Table 15 Details of Feeder

Parameters	66kv and above	33kv	11/22kv	LT
Number of meter feeders	-	-	-	NA
Number of feeders with Communicable meters	61	110	998	NA
Number of Unmetered feeders	-	-	-	NA
Number of total feeders	61	110	998	NA

3.4.5 Distribution Line Details of BYPL

The details of Distribution line in BYPL as on 31st March 2023 are given in the below table:

Table 16 Length of Distribution Line

Particulars	Value(km)
Line length (ct km)	5915
Length of Aerial Bunched Cables	2799

3.4.6 Energy Flow Details

Energy flow details for FY 2022-23 are given in the table and figure

Table 17 Energy Flow Details

Trend of BYPL (2022-23)				
Sr. No.	Energy Input Details	Formula	UOM	Value
1	Purchase Energy (From Generation Source)	A	MU	8704
2	Net Energy Input to Discom (at DISCOM Periphery after adjusting the transmission losses and energy traded)	B	MU	7,503
3	Energy billed (is the Net energy billed, adjusted for energy traded)	C	MU	6,958.33
4		D	Rs. Crores	5,592.87
5	Average Billing Rate	$E=D*10/C$	Rs/Kwh	8.04
6	Amount collected	F	Rs. Crores	5,641.15
	Transmission and Distribution (T&D) Loss	$G=B-C$	MU	545.43
7		$H= G/B$	%	7.27%
8		$J=E*G/10$	Rs. Crores	438.40
10	Billing Efficiency	$K=C/B$	%	92.73%
11	Collection efficiency	$L=F/D$	%	100.86%
12	Aggregate Technical & Commercial (AT&C) Loss	$M =1-(K*L)$	%	6.47%

3.4.7 Pattern of Energy Distribution in BYPL

Energy flow details for FY 2022-23 are given in the table and figure

Energy Input:

During the analyzed period, BYPL's maximum energy input of 867 million units (MUs) in the month of Jun'22, while the least energy input of- 419 MUs was in the month of Nov'22. This shows that the company's energy input varies considerably from month to month irrespective of the seasonal impact.

Energy Billed:

The energy billed by BYPL was lowest in Dec'22 – 407 MUs & Highest in Sep'22 – 762 MUs.

The Month wise break up of input energy (MUs) parameter for all divisions is given below:

Table 18 Month wise input energy for FY 2022-23

Division Name	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Total
Chandni Chowk	25.79	29.75	30.97	31.03	29.79	28.10	19.44	15.19	14.62	16.02	12.22	14.23	267.14
Darya Ganj	51.15	60.12	62.38	62.53	58.74	53.31	35.81	28.66	30.34	34.41	24.27	29.28	531.00
Pahar Ganj	34.58	40.25	43.03	42.58	40.41	37.56	24.89	18.70	18.72	21.43	17.19	20.02	359.38
Shankar Road	37.24	43.74	45.72	44.69	41.46	39.04	26.44	21.10	20.85	23.58	18.91	22.02	384.79
Patel Nagar	42.52	48.82	51.56	51.79	48.61	45.26	31.62	26.74	27.36	30.44	24.99	28.39	458.10
Jhilmil	43.88	52.40	54.80	53.92	50.50	45.56	31.19	24.30	25.40	29.58	22.54	25.44	459.51
Dilshad Garden	61.22	68.40	71.42	70.44	66.77	64.03	46.13	42.23	43.67	45.62	39.06	42.50	661.50
Krishna Nagar	68.17	79.26	83.31	80.90	76.86	70.64	47.64	36.21	35.30	39.68	33.47	39.10	690.53
Laxmi Nagar	79.31	95.83	100.36	100.20	93.27	84.56	57.76	46.39	48.91	57.10	43.84	49.16	856.67
Mayur Vihar	40.96	49.33	51.64	52.51	48.48	41.76	28.17	24.25	25.98	29.55	22.36	25.44	440.44
Mayur Vihar - III	26.37	31.74	33.19	33.27	31.27	27.73	19.50	15.50	16.60	19.57	14.70	16.94	286.39
Yamuna Vihar	71.97	81.58	87.13	85.90	83.74	76.12	53.61	42.13	43.57	49.05	38.18	44.62	757.58
Karawal Nagar	70.67	80.20	84.31	85.29	80.96	73.34	54.82	44.90	46.49	52.84	41.99	48.33	764.14
Nandnagri	55.11	63.22	66.91	66.01	63.22	56.85	40.35	33.12	34.75	40.42	31.17	35.45	586.58
Total	708.93	824.64	866.73	861.09	814.08	743.86	517.36	419.41	432.56	489.29	384.89	440.92	7,503.76

The Month wise break up of billed energy (MUs) parameter for all the circle is given below:

Table 19 Month wise Billed Energy Fy 2022-23

Division Name	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Total
Chandni Chowk	17.71	23.88	26.24	26.45	25.54	27.04	21.77	16.17	14.09	13.75	13.66	14.76	241.05
Darya Ganj	28.93	46.66	52.45	52.65	51.99	51.49	41.25	30.00	26.61	30.19	29.02	36.96	478.19
Pahar Ganj	23.67	33.44	37.57	37.71	36.69	37.84	29.18	20.65	18.37	18.28	18.35	15.84	327.58
Shankar Road	25.95	38.44	41.84	41.88	40.00	40.98	32.49	24.08	21.01	21.24	21.29	18.79	367.98
Patel Nagar	31.06	42.84	46.42	47.57	45.99	47.06	37.25	29.09	26.69	27.74	26.60	24.02	432.34
Jhilmil	32.42	47.05	50.88	50.76	47.79	48.31	35.66	27.41	24.84	27.31	24.72	23.14	440.30
Dilshad Garden	46.74	60.82	65.26	64.70	62.90	64.71	52.36	42.09	42.41	42.93	40.96	37.66	623.54
Krishna Nagar	46.73	67.61	74.50	74.42	69.16	72.03	54.57	39.12	34.84	35.22	33.90	34.03	636.13
Laxmi Nagar	58.24	83.21	91.33	92.90	87.33	88.71	66.17	49.98	46.32	51.22	47.21	42.72	805.35
Mayur Vihar	26.42	42.56	46.13	47.00	45.26	44.44	32.19	23.65	23.92	26.24	23.65	22.92	404.38
Mayur Vihar - III	17.77	26.65	29.82	30.03	28.67	28.86	22.60	16.07	15.46	17.11	15.58	14.24	262.86
Yamuna Vihar	48.81	68.72	73.22	74.78	72.99	75.20	57.85	43.52	42.15	40.75	40.38	44.34	682.70
Karawal Nagar	51.83	69.97	75.49	75.96	73.78	76.43	59.19	47.60	46.13	46.77	45.13	44.88	713.15
Nandnagri	38.08	54.69	58.46	59.48	56.85	59.09	45.22	34.62	34.27	34.87	34.08	33.04	542.77
Total	494.36	706.53	769.61	776.29	744.94	762.20	587.75	444.04	417.11	433.61	414.53	407.35	6,958.33

The Voltage wise Consumption Pattern is given below:

Table 20 Voltage Wise Consumption Pattern

Voltage Level	Consumers		Energy Consumption	
	No.	% Share	MUs	% Share
440v	1903089	99.98%	6,215.79	89.33%
11kv	465	0.02%	628.43	9.03%
33kv				
66kv	3	0.00%	114.11	1.64%
132kV	-	-	-	-
220kv	-	-	-	-
Total	1903557	-	6,958.33	-

3.4.8 Salient Features of BYPL

BYPL'S main objectives are to achieve efficiency gains and make necessary changes to make the company commercially viable, progressively self- sustainable, and less dependent on the government while balancing the interests of consumers with regards to quality of service and economical tariffs.

a) Vision

BYPL aspires to be the best electricity supply company in India by continuously enhancing its technological leadership and commercial acumen to satisfy its customers,

b) Mission

Our Mission is to provide quality electricity supply services to each customer satisfying his/ her needs in most efficient and effective manner at reasonable prices through continuous innovations and by maintaining commercial & financial viability of the company along with employee's satisfaction.

- To ensure a balanced all- round development of power infrastructure in all circles of operation.
- To achieve high standards of consumer satisfaction by committing to Honesty, Transparency and Integrity in all of our actions.
- To achieve technological excellence and financial turnaround for the overall benefit of the consumers.
- To become a self –learning organization focusing on continuous improvement.

c) Core Values

To achieve its mission, the company and its employees commit themselves to honesty and integrity, result oriented work, transparency in work, dedication to duty, cost consciousness, openness to suggestions and feedback from all stake holders.

3.5 Energy Conservation Measures

Energy conservation is a critical issue in today's World, as the demand for energy continues to increase while the resources available to produce it are finite. The energy conservation measures that have already been taken and propose some measures for the future are explained below.

3.5.1 Energy Conservation Measures Already Taken by BYPL

BSES Yamuna Power Ltd has implemented various proactive programs and awareness campaigns to curb demand-supply imbalances and promote the responsible use of electricity, in accordance with the Demand Side Management Regulations – DERC.

Following Initiatives were undertaken over the years in the direction of Demand-side Management and Energy Conservation apart from general awareness to all consumers:

DSM Activities Undertaken In FY 2022-2023		
S N o.	Energy Efficiency Measures	Activity
1	Tube light Replacement with LED	No replacement done in FY 2022-2023
2	Old Fans with Energy Efficient Fans	No replacement done in FY 2022-2023
3	Replacement of Old AC's with Energy Efficient AC	No replacement done in FY 2022-2023
4	Awareness Programs	767 Numbers of awareness programs done for energy conservation
5	Home Automation	MoU signed between BYPL and SE in October 2022
6	Smart Innovation Norway	MoU signed between BYPL and SIN in Norway Embassy in February 2023
7	Jan Suraksha Muheem For Energy Conservation	52 number of Jan suraksha Muheem done for safety and Energy Conservation

Form 3 of FY 2022-23 is enclosed as Attachment 4

3.5.2 Proposal for Energy Conservation Measures.

During Energy Audit of establishment all energy consuming equipment and processes studied. The analysis of all major energy consuming equipment and appliances carried out and the same is discussed in earlier section of this report. Based on the analysis Energy conservation measures (ECM) have been identified; each of which are described below:

3.5.2.1 ECM 1: System Improvement and Automation***Project***

- System Improvement and Automation

Study & investigation

- Overloaded distribution transformer
- Unbalanced and overloaded LT feeder.
- Network components are old and inefficient
- Old technology for distribution system management
- Hot spot-on termination due to poor termination

Recommendation Action

For the improvement of system, it is recommended to:

- Replace overloaded distribution transformer
- Load Balance DT & LT feeders by shifting of load from overloaded phase to under loaded feeder
- Replace old equipment's, cables with efficient equipment's
- Upgrade Distribution system management
- Do real time health monitoring of DT.
- Replacement of old obsolete network element.
- Addition of new substations to reduce LT length
- Do thermal scanning of electrical joints
- Install pole meters, pole distribution box, lock and revamp feeder pillar.
- Lay new LT feeder to relieve overloaded LT feeders

Saving Assessment

- The cost-benefit analysis of the energy conservation measure is as shown in the table below:

Table 21 Cost Benefit of Recommendation 1

Sl. No	Parameters	Units	Present	Proposed
1	Energy Available	MU	7503	7468
2	T&D Loss	%	7.27%	7.15%
3	T&D Loss	MU	545	534

4	Energy Sale	MU	6958	6934
5	Cost of Energy	Rs/Unit	8.04	9.48
6	Cost of Energy	Rs. Crores/Year	5593	6575
7	Energy Savings	MU/year	34	
8	Annual Rs saved	Rs. Crores/Year	32	
9	Investment required	Rs. Crores	60	
10	Payback Period	Months	33	

Action Plan

Item	Action
Operation & Maintenance	<ul style="list-style-type: none"> Load balancing on DT and LT feeder Replacement of old inefficient equipment's Revamping of pole distribution box, feeder pillar Health monitoring of DT and feeders Thermal scanning of Electrical joints
Replacement	Defective and overloaded DT, Pole distribution
Procurement	Pole Meter, DT, Distribution management system, electrical hardware etc.
Construction	<ul style="list-style-type: none"> Installation of new 66/33 KV grid substation, Laying of new LT feeders
Costing	Rs 60 Crores
Project Specific Baseline Parameters	<ul style="list-style-type: none"> Present T&D Loss Energy Purchase power and power billed
Baseline	As shown in this section
M&V	It is proposed to use IPMVP protocol 'C', the 'Whole Facility Method'. Conduct T & D loss calculation before and after implementation in particular segment.
Implication, if any & precaution	None
Social Benefits	Reduction in CO ₂ emission and Improvement in Reliability of power supply

Notes

- As ECM 1 are having impact on reduction on T& D loss and activities are inter related hence it will be very difficult to quantify the losses due to any isolated activities.
- T&D loss of the year is 7.27 % which is already very near to best achievable value hence the scope of further reduction is very difficult whereas investment is required for

maintain the system as well as T&D loss percentage. This is the reason for high payback period.

- Due to Covid 19 and subsequent lock down consumption is very low for industrial as well as commercial sector. Consumption of certain other sector also got affected due to non-operation of Delhi Metro and Railway.
- It is observed that consumption is low in the area where T&D loss as well as AT&C loss was minimum which means area having high T&D loss and AT&C loss are now major contributor in overall T&D Loss and AT&C loss causing which overall T&D loss as well as AT&C loss may increase

3.5.2.2 ECM 2: Improvement in metering system

Project

- Improvement in metering system

Study & investigation

- Advanced technology meter / Smart Meter is very accurate
- Better understanding of energy usages
- Meter box found tampered
- There are some defective meters/aged meters

Recommendation Action

To improve metering system, it is recommended to install smart meters for better result.

Saving Assessment

The cost-benefit analysis of the energy conservation measure is as shown in the table below:

Table 22 Cost Benefit of Recommendation 2

Sl. No	Parameters	Units	Present	Proposed
1	Energy Available	MU	7503	7468
2	Billing Efficiency	%	92.73%	92.8%
3	Collection Efficiency	%	100.86%	99.80%
4	AT & C Loss	MU	6.47%	7.34%
5	Energy Sale	MU	6958	6934
6	Cost of Energy	Rs/Unit	8.04	9.48
7	Cost of Energy	Rs. Crores/Year	5593	6575
8	Improvement in Energy Billing	MU/year	25	
9	Annual Rs earned	Rs. Crores/Year	24	

10	Investment required	Rs. In Crores	44
11	Payback Period	Months	22

Action Plan

Item	Action
Operation & Maintenance	
Retrofit	Smart Energy Meters
Replacement	Old Meter
Procurement	Smart Meter
Construction	The installation and commissioning can be done by in-house staff/ on contract
Costing	Rs 44 Crores
Project Specific Baseline Parameters	<ul style="list-style-type: none"> • Present Billing Efficiency • Present Collection Efficiency • Energy Purchase power and power billed
Baseline	As shown in this section
M&V	It is proposed to use IPMVP protocol 'C', the 'Whole Facility Method'. Conduct energy monitoring before and after installation of energy meters
Implication, If any & precaution	None
Social Benefits	Reduction in Co2 emission and Confidence building

4 Energy Flow Analysis

4.1 Energy Flow Across Five Service Level

- Energy flow between transmission and 220kV/132kV/33kV/20kV/11kV/6.0 kV/3.3 kV incoming distribution feeders
- Energy flow between 132kV/33kV outgoing and 20 kV/11kV/6.6 kV/6.0 kV incoming feeders
- Energy flow between 11kV/6.0 kV/3.3 kV feeders and distribution transformers, or high voltage distribution system
- Energy flow between distribution transformer, or high voltage distribution system to end consumer, including ring main system
- Energy flow between Feeder to end-consumer & Energy flow between 132kV/33kV/20kV/11 kV/6.0 kV/3.3 kV directly to consumer

4.2 Validation of Metered Data

AS per SoP validation of meter data must be as per the below criteria. Accordingly, the metered data validated needs to be elaborated.

- a) **Validation of feeder data:** Based on data available in 11 kv Feeder meter at substation for a sample size of 10% for which documentary evidence to be captured in the audit report.
- b) **Validation of energy flow data losses:** Based on field survey as per the following sample size:
- Min. 10 or 1%(whichever is higher of DISCOM's input energy metering points between Transmission and 66kv/33kv/11kv distribution feeders by checking functional and communication status of meters etc.
 - For all Division with AT&C losses greater than 25% or at least 1/3 of the total Divisions of DISCOM, verify:
 - Total of min. 10 or 1% of metering points (whichever is higher) between 220-132-110-66/33kv outgoing and 22kv-11kv-6.6kv-3kv incoming feeders/ direct end consumer by checking functional and communication status of meters
 - In an Urban High Loss Division, Check 5 or 1% of metering points (whichever is higher) at DTs where communicable meters were already installed under other Schemes such as R-APDRP IPDS.
 - Total of min. of 10 or 1% of metering points (whichever is higher) between 11kv/6.6kv feeders and DTs by checking functional and communication status of meters, foot survey of feeder to check for thefts/ hooking etc.
 - Verify metering and connection status of min. of 10 or 2% Consumers of the Division (Whichever is higher) of the following category of consumers- Agriculture (Metered and Un-metered), Govt. category connection (ULB, RLB etc.) and LT Industrial
- c) **Field verification report** of the activities undertaken in a) and b) above to be included as an annexure to the energy audit report>

5 Loss And Subsidy Computation

5.1 Energy accounts analysis for FY 2022-23

5.1.1 Summary of AT&C Loss

The AT&C losses over the q1, q2, q3, q4 FY 2022-23 and annual AT&C losses for FY 2022-23 are as shown below:

Table 23 AT&C Losses FY 2022-23

Input Energy and Losses BYPL FY 2022-23								
Sr. No.	Energy Input Details	Formula	UOM	Quarterly				FY 22-23
				Q1	Q2	Q3	Q4	
1	Purchase Energy (From Generation Source)	A	MU	2733.9	2766.0	1608	1597	8704.4
2	Net Energy Input to Discom (at DISCOM Periphery after adjusting the transmission losses and energy traded)	B	MU	2,400.30	2,419.03	1,369.33	1,315.09	7,503
3	Energy billed (is the Net energy billed, adjusted for energy traded)	C	MU	1,970.50	2,283.43	1,448.91	1,255.49	6,958.33
4		D	Rs. Crores	1,507.71	1,806.85	1,215.69	1,062.62	5,592.87
5	Average Billing Rate	$E=D*10/C$	Rs/Kwh	7.65	7.91	8.39	8.46	8.04
6	Amount collected	F	Rs. Crores	1,281.90	1,785.66	1,329.89	1,243.70	5,641.15
7	Transmission and Distribution (T&D) Loss	$G=B-C$	MU	429.80	135.60	79.58	59.60	545.43
8		$H=G*100/B$	%	17.91%	5.61%	-5.81%	4.53%	7.27%
9		$J=E*G/10$	Rs. Crores	328.86	107.30	66.77	50.45	438.40
10	Billing Efficiency	$K=C*100/B$	%	82.09%	94.39%	105.81%	95.47%	92.73%
11	Collection efficiency	$L=F*100/D$	%	85.02%	98.83%	109.39%	117.04%	100.86%
12	Aggregate Technical & Commercial (AT&C) Loss	$M=1-(K*L)$	%	30.20%	6.71%	-15.75%	-11.74%	6.47%

5.1.2 Division wise T&D and AT&C Losses

The Circle wise connected load & input energy, transmission & distribution losses and AT&C loss is given in following table:

Table 24 Division wise T&D and AT&C Loss FY 2022-23

Division Wise T&D and AT&C Losses FY 2022-23							
Sr. No	Name of Division	No of Connections	Connected Load	Input energy	T&D Loss		AT&C Loss
		Number	MW	MU	MU	%	%
1	Chandni Chowk	99804	252.47	267	26	9.77%	9.89%
2	Darya Ganj	74444	334.48	531	53	9.94%	7.00%
3	Pahar Ganj	106883	267.03	359	32	8.85%	8.17%
4	Shankar Road	68734	325.65	385	17	4.37%	4.42%
5	Patel Nagar	110793	342.32	458	26	5.62%	5.40%
6	Jhilmil	99193	367.03	460	19	4.18%	3.60%
7	Dilshad Garden	118474	418.04	662	38	5.74%	5.41%
8	Krishna Nagar	196039	504.51	691	54	7.88%	7.35%
9	Laxmi Nagar	204281	645.98	857	51	5.99%	5.46%
10	Mayur Vihar	114941	295.48	440	36	8.19%	6.07%
11	Mayur Vihar - III	83886	199.34	286	24	8.22%	7.66%
12	Yamuna Vihar	217534	446.33	758	75	9.88%	9.63%
13	Karawal Nagar	234972	459.99	764	51	6.67%	5.37%
14	Nandnagri	173579	371.42	587	44	7.47%	6.26%
	Total	1903557	5,230.08	7504	545	7.27%	6.47%

5.2 Energy accounts analysis for FY 2022-23

5.2.1 Summary of AT&C Loss

The AT&C losses over the q1, q2, q3, q4 FY 2022-23 and annual AT&C losses for FY 2022-23 are as shown below:

Table 25 AT&C Losses FY 2022-23

Input Energy and Losses BYPL FY 2022-23								
Sr. No.	Energy Input Details	Formula	UOM	Quarterly				FY 2022-23
				Q1	Q1	Q1	Q1	
1	Purchase Energy (From Generation Source)	A	MU	2733.9	2766.0	1608	1597	8704.4
2	Net Energy Input to Discom (at DISCOM Periphery after adjusting the transmission losses and energy traded)	B	MU	2,400.30	2,419.03	1,369.33	1,315.09	7503
3	Energy billed (is the Net energy billed, adjusted for energy traded)	C	MU	1,970.50	2,283.43	1,448.91	1,255.49	6,958.33
4		D	Rs. Crores	1,507.71	1,806.85	1,215.69	1,062.62	5,592.87
5	Average Billing Rate	$E=D*10/C$	Rs/Kwh	7.65	7.91	8.39	8.46	8.04
6	Amount collected	F	Rs. Crores	1,281.90	1,785.66	1,329.89	1,243.70	5,641.15
7	Transmission and Distribution (T&D) Loss	$G=B-C$	MU	429.80	135.60	-	59.60	545.43
8		$H=G*100/B$	%	17.91%	5.61%	-5.81%	4.53%	7.27%
9		$J=E*G/10$	Rs. Crores	328.86	107.30	-	50.45	438.40
10	Billing Efficiency	$K=C*100/B$	%	82.09%	94.39%	105.81%	95.47%	92.73%
11	Collection efficiency	$L=F*100/D$	%	85.02%	98.83%	109.39%	117.04%	100.86%
12	Aggregate Technical & Commercial (AT&C) Loss	$M=1-(K*L)$	%	30.20%	6.71%	-15.75%	-11.74%	6.47%

5.2.2 Division wise T&D and AT&C Losses

The Circle wise connected load & input energy, transmission & distribution losses and AT&C loss is given in following table:

Table 26 Division wise T&D and AT&C Loss FY 22-23

Division Wise T&D and AT&C Losses FY 2022-23							
Sr. No	Name of Division	No of Connections	Connected Load	Input energy	T&D Loss		AT&C Loss
		Number	MW	MU	MU	%	%
1	Chandni Chowk	99804	252.47	241	15	99.86%	9.77%
2	Darya Ganj	74444	334.48	478	31	103.27%	9.94%
3	Pahar Ganj	106883	267.03	328	36	100.75%	8.85%
4	Shankar Road	68734	325.65	368	11	99.94%	4.37%
5	Patel Nagar	110793	342.32	432	49	100.24%	5.62%
6	Jhilmil	99193	367.03	440	86	100.60%	4.18%
7	Dilshad Garden	118474	418.04	624	68	100.35%	5.74%
8	Krishna Nagar	196039	504.51	636	137	100.57%	7.88%
9	Laxmi Nagar	204281	645.98	805	160	100.56%	5.99%
10	Mayur Vihar	114941	295.48	404	120	102.30%	8.19%
11	Mayur Vihar - III	83886	199.34	263	91	100.60%	8.22%
12	Yamuna Vihar	217534	446.33	683	219	100.28%	9.88%
13	Karawal Nagar	234972	459.99	713	228	101.39%	6.67%
14	Nandnagri	173579	371.42	543	168	101.31%	7.47%
	Total	1903557	5,230.08	6958	1,365	100.86%	7.27%

5.3 Energy accounts analysis for FY 2022-23

5.3.1 Month wise Input energy and billed energy details

The month wise input energy & billed energy for FY 2022-23 of the Discom periphery is shown in below table.

Table 27 Month wise Input energy & Billed Energy

Sl No	Month	Energy Input	Energy billed		Amount collected
		MU	MU	Rs. Crores	Rs. Crores
1	Apr-22	708.93	494.36	388.39	282.03
2	May-22	824.64	706.53	531.35	455.18
3	Jun-22	866.73	769.61	587.97	544.70
4	Jul-22	861.09	776.29	613.40	592.39
5	Aug-22	814.08	744.94	591.67	597.78
6	Sep-22	743.86	762.20	601.79	595.48
7	Oct-22	517.36	587.75	476.66	522.14
8	Nov-22	419.41	444.04	381.63	434.15
9	Dec-22	432.56	417.11	357.39	373.60
10	Jan-23	489.29	433.61	366.74	371.33
11	Feb-23	384.89	414.53	357.81	372.08
12	Mar-23	440.92	407.35	338.08	500.29
Total	Total	7,503.76	6,958.33	5,592.87	5,641.15

Note: Details Sheet Attached in Annexure

5.3.2 Quarterly and annual AT&C losses

The Quarter wise and annual AT &C losses for FY 2022-23 shown in below table.

Table 28 Energy Input and AT&C Losses FY 2022-23

Input Energy and Losses BYPL FY 2022-23								
Sr. No.	Energy Input Details	Formula	UOM	Quarterly				FY 22-23
				Q1	Q1	Q1	Q1	
1	Purchase Energy (From Generation Source)	A	MU	2733.9	2766.0	1608	1597	8704.4

2	Net Energy Input to Discom (at DISCOM Periphery after adjusting the transmission losses and energy traded)	B	MU	2,400.30	2,419.03	1,369.33	1,315.09	7,503
3	Energy billed (is the Net energy billed, adjusted for energy traded)	C	MU	1,970.50	2,283.43	1,448.91	1,255.49	6,958.33
4		D	Rs. Crores	1,507.71	1,806.85	1,215.69	1,062.62	5,592.87
5	Average Billing Rate	$E=D*10/C$	Rs/Kwh	7.65	7.91	8.39	8.46	8.04
6	Amount collected	F	Rs. Crores	1,281.90	1,785.66	1,329.89	1,243.70	5,641.15
7	Transmission and Distribution (T&D) Loss	$G=B-C$	MU	429.80	135.60	-	59.60	545.43
8		$H=G*100/B$	%	17.91%	5.61%	-5.81%	4.53%	7.27%
9		$J=E*G/10$	Rs. Crores	328.86	107.30	-	50.45	438.40
10	Billing Efficiency	$K=C*100/B$	%	82.09%	94.39%	105.81%	95.47%	92.73%
11	Collection efficiency	$L=F*100/D$	%	85.02%	98.83%	109.39%	117.04%	100.86%
12	Aggregate Technical & Commercial (AT&C) Loss	$M=1-(K*L)$	%	30.20%	6.71%	-15.75%	-11.74%	6.47%

Analysis based on the above table may be provided

5.3.3 Voltage wise AT&C losses

The voltage wise AT&C losses of Discom for FY 2022-23 are as shown in the below table:

Table 29 Voltage wise AT&C Losses FY 2022-23

4	Voltage level	Energy Sales Particulars	MU
i	LT level	DISCOM' consumers	1,903,089
		Demand from open access, captive	-
		Embedded generation used at LT level	-
		Sale at LT Level	6,216
		Quantum of LT level losses	531
		Energy Input at LT level	6,747
ii	11 kV level	DISCOM' consumers	465

		Demand from open access, captive	-
		Embedded generation at 11 kV level used	-
		Sale at 11 kV Level	628
		Quantum of 11 kV level losses	13
		Energy Input at 11 kV level	642
iii	>33 kV level	DISCOM' consumers	3
		Demand from open access, captive	-
		Embedded generation at >33 kV or below level	-
		Sale at >33 kV Level	114
		Quantum of Losses at >33 kV	0.65
		Energy input at >33kV Level	114.76
		Total Energy Requirement	-
		Total Energy Sales	6,958

5.3.4 Circle wise AT&C losses analysis

5.3.4.1 Circle Wise connections, load, input energy & Billed energy

Circle Wise connections, load, input energy & Billed energy with Percentage share in different circle is given below the "x" circle having maximum numbers of consumers and "Y" circle having maximum numbers of consumers. "Z" has maximum input energy as well as billed units and "T" have maximum input energy as well as billed units as shown in table:

Table 30 Circle Wise No of consumer, Input Energy & Losses FY 2022-23

Circle	Total Number of Connection		Total Connected Load		Input Energy		Billed energy	
	Nos.	% Share	MW	% Share	MU	% Share	MU	% Share
Central	460658	24.20%	1,521.95	29%	2,000.40	26.66%	1,847.15	26.55%
South East	698340	36.69%	2,012.34	38%	2,733.55	36.43%	2,549.02	36.63%
North East	744559	39.11%	1,695.79	32%	2,769.80	36.91%	2,562.16	36.82%
Total	1903557		5230.084		7,503.76		6,958.33	

5.3.4.2 Circle- wise AT&C losses

The circle wise AT&C losses are shown in the table below:

Table 31 Circle wise T&D losses, Collection Efficiency and AT&C Losses

Name of circle	Input Energy	Billed energy		T&D loss		Collection Efficiency	AT&C loss
	MU	MU	Rs. In Cr	(MU)	(%)	%	%
Central	2,000.40	1,847.15	1,758.40	153.25	7.66%	100.98%	6.76%
South East	2,733.55	2,549.02	1,954.32	184.53	6.75%	100.83%	5.98%
North East	2,769.80	2,562.16	1,880.15	207.65	7.50%	100.79%	6.76%
Total	7,503.76	6,958.33	5,592.87	545.43	7.27%	100.86%	6.47%

Note: AT&C Loss's calculation as per BEE Performa the calculation is as actual Collection efficiency.

5.3.4.3 High loss Circle

North East Circle had the highest T&D loss quantum of 208 MU and Central Circle had the highest T&D loss percentage of 7.66 %. However, when T&D losses (MU) and AT&C losses (%) are seen together than reducing T&D losses in North East Circle must be prioritized in order to have overall reduction in AT&C losses of the DISCOM. Further, the circle with high loss that needs to be prioritized can be identified from the below chart:




Figure 3 Circle wise T&D Loss %

5.3.5 Division wise AT&C losses analysis

5.3.5.1 Division- wise AT&C losses

The Division wise AT&C losses are shown in the table below:

Table 32 Division wise T&D losses, collection efficiency and AT&C Losses

Name of Division	Period (2022-23)									
	Consumer profile		Energy parameters		Losses		Commercial Parameter			AT & C loss (%)
	Consumer category	No of connection metered (Nos)	Input energy (MU)	Billed energy (MU)	T&D loss (MU)	T&D loss (%)	Billed Amount in Rs. Crore	Collected Amount in Rs. Crore	Collection Efficiency	
Chandni Chowk	Residential	36963	267	99	26	9.77%	53.62	256	99.86%	
	Agricultural	-		-						
	Commercial/ Industrial-LT	62479		134			194.38			
	Commercial/ Industrial-HT			7			7.90			
	Others	362		7			7.90			
		99804	267	240	26.09	9.77%	255.90	255.56	99.86%	9.89%
Darya Ganj	Residential	52707	531	204	53	9.94%	133.10	462	103.27%	
	Agricultural	-		-						
	Commercial/ Industrial-LT	21223		164			224.40			
	Commercial/ Industrial-HT			100			90.06			
	Others	514		100			90.06			
		74444	531.00	468	52.80	9.94%	447.56	462.20	103.27%	7.00%
Pahar Ganj	Residential	61408	359	178	32	8.85%		294		

							92.95			
	Agricultural	-		-			-			
	Commercial/ Industrial-LT	45045		142			190.05			
	Commercial/ Industrial-HT									
	Others	430		7			8.96			
		106883	359.38	328	31.80	8.85%	291.97	294.14	100.75%	8.17%
Patel Nagar	Residential	83672		244			133.16			
	Agricultural	1.00		0.02			0.01			
	Commercial/ Industrial-LT	26847	458	178	26	5.62%	240.21	384		
	Commercial/ Industrial-HT									
	Others	273		10			10.14			
		110793	458.10	432	25.76	5.62%	383.52	384.44	100.24%	5.40%
Shanker Road	Residential	37673		165			108.42			
	Agricultural	-		-			-			
	Commercial/ Industrial-LT	30757	385	195	17	4.37%	263.71	379		
	Commercial/ Industrial-HT									
	Others	285		7			7.32			
		68715	384.79	368	16.80	4.37%	379.45	379.22	99.94%	4.42%
GT Road	Residential	100042		309			167.10			
	Agricultural	1.00		0.04			0.01			
	Commercial/ Industrial-LT	18020	662	302	38	5.74%	377.82	558		
	Commercial/ Industrial-HT									
	Others	411		10			11.05			
		118474	661.50	622	37.97	5.74%	555.98	557.94	100.35%	5.41%

SAVE ENERGY- SAVE FUTURE

Karawal nagar	Residential	201059	764	487	51	6.67%	225.12	492	101.39%	5.37%
	Agricultural	20.00		0.07			0.04			
	Commercial/ Industrial-LT	33428		132			174.61			
	Commercial/ Industrial-HT			94			85.02			
	Others	465								
		234972	764.14	713	50.99	6.67%	484.79	491.55	101.39%	5.37%
Nand nagri	Residential	150939	587	411	44	7.47%	211.64	380	101.31%	6.26%
	Agricultural	15.00		0.05			0.03			
	Commercial/ Industrial-LT	22092		101			134.53			
	Commercial/ Industrial-HT			30			29.01			
	Others	533								
		173579	586.58	543	43.81	7.47%	375.21	380.12	101.31%	6.26%
Yamuna Vihar	Residential	180965	758	502	75	9.88%	249.77	465	100.28%	9.63%
	Agricultural	2.00		0.05			0.01			
	Commercial/ Industrial-LT	35890		153			190.94			
	Commercial/ Industrial-HT			24			23.45			
	Others	677								
		217534	757.58	679	74.88	9.88%	464.17	465.48	100.28%	9.63%
Karkardooma	Residential	83991	460	316	19	4.18%	197.97	356		
	Agricultural	-		-			-			
	Commercial/ Industrial-LT	14834		113			145.14			
	Commercial/ Industrial-HT			11			10.70			
	Others	368								

SAVE ENERGY- SAVE FUTURE

		99193	459.51	440	19.22	4.18%	353.81	355.94	100.60%	3.60%
Krishna Nagar	Residential	141741	691	439	54	7.88%	238.93	502		
	Agricultural	1.00		0.03			0.01			
	Commercial/ Industrial-LT	53874		189			251.86			
	Commercial/ Industrial-HT			8			8.48			
	Others	423								
		196039	690.53	635	54.40	7.88%	499.28	502.14	100.57%	7.35%
Laxmi nagar	Residential	173311	857	548	51	5.99%	314.60	649		
	Agricultural	-		-			-			
	Commercial/ Industrial-LT	30454		238			310.94			
	Commercial/ Industrial-HT			19			19.43			
	Others	516								
		204281	856.67	805	51.33	5.99%	644.97	648.59	100.56%	5.46%
Mayur Vihar Ph 1	Residential	103032	440	298	36	8.19%	158.57	291		
	Agricultural	1.00		0.04			0.01			
	Commercial/ Industrial-LT	11504		73			95.22			
	Commercial/ Industrial-HT			33			30.18			
	Others	404								
		114941	440.44	404	36.06	8.19%	283.98	290.52	102.30%	6.07%
Mayur Vihar Ph 3	Residential	75139	286	210	24	8.22%	111.47	173		
	Agricultural	-		-			-			
	Commercial/ Industrial-LT	8451		36			45.50			
	Commercial/ Industrial-HT			16						
	Others	296								

SAVE ENERGY- SAVE FUTURE

						15.31			
	83886	286.39	263	23.53	8.22%	172.28	173.32	100.60%	7.66%
Total	Residential	1482642	7504	4410	545	7.27%	2396	5641	6.47%
	Agricultural	41		0			0		
	Commercial/ Industrial-LT	414898		2152			2839		
	Commercial/ Industrial-HT	0		0			0		
	Others	5957		376			357		
BYPL	1903538	7504	6938	545	7.27%	5593	5641	100.86%	6.47%

SAVE ENERGY- SAVE FUTURE

5.3.5.2 High loss division

Yamuna Vihar Division had the highest T&D loss quantum of 74.88 MU and Chandni Chowk Division had the highest AT&C loss percentage of 9.89 %. Further, the circles with high loss that needs to be prioritized can be identified from the below chart:




Figure 4 Division Wise T&D Losses in MU Vs In AT&C Loss in %

As seen in following chart AT&C losses increases with increase of T&D losses.




Figure 5 AT&C Loss VS T&D Loss in %


The list of top five number Division with higher AT&C losses (%) & T&D losses (MU) identified from the above chart are tabulated below:

Table 33 Top 5 number division with higher AT&C Losses in % and T&D Losses in MU

Sr. No.	Division	T&D loss (MU)	AT&C loss (%)
1	Yamuna Vihar	74.88	9.63%
2	Krishna Nagar	54.40	7.35%
3	Darya Ganj	52.80	7.00%
4	Pahar Ganj	31.80	8.17%
5	Chandni Chowk	26.09	9.89%

SAVE ENERGY- SAVE FUTURE

Further, it was observed that the collection efficiency is 100% or more across all the Division as shown below:



Division	Collection Efficiency
Chandni Chowk	99.86%
Darya Ganj	103.27%
Pahar Ganj	100.75%
Patel Nagar	100.24%
Shanker Road	99.94%
GT Road	100.35%
Karawal nagar	101.39%
Nand nagri	101.31%
Yamuna Vihar	100.28%
Karkardooma	100.60%

SAVE ENERGY- SAVE FUTURE

Krishna Nagar	100.57%
Laxmi nagar	100.56%
Mayur Vihar Ph 1	102.30%
Mayur Vihar Ph 3	100.60%
BYPL	100.86%

Figure 6 Division wise Collection efficiency

5.3.6 Feeder wise AT&C losses analysis

5.3.6.1 Feeder wise AT&C losses

BYPL is ring network, hence losses are calculated division-wise

The Feeder wise losses are as shown in the Table below:

5.3.6.2 Identify high loss feeders

BYPL is ring network, hence losses are calculated division-wise

5.4 Subsidy Computation and analysis (based on quarterly data)

5.4.1 Subsidy Computation & Analysis (based on quarterly data)

The quarter wise subsidy details during FY 2022-23 are shown in the table below :-

SAVE ENERGY- SAVE FUTURE

Table 34 Quarter Wise Subsidy Details

Category	Energy billed	Subsidized energy billed	Tariff (Rs.		Total Amount Subsidy (Rs. Cr.)	Subsidy received	Balance Subsidy
	(MU)	(MU)	/kwh)	Subsidy Per Unit (Rs./kwh)			
	1	2	3	4	5= 2*4	6	7=5-6
Opening Subsidy (outstanding)					23.92		
Quarter-1							
Residential	1,296.73				188.97		
Agricultural	0.08				0.01		
Commercial/Industrial-LT	463.14				0.18		
Commercial/Industrial-HT	105.05						
Other (specify)	105.50						
Total	1,970.50				189.15	0	
Quarter-2							
Residential	1,516.94				198.55		
Agricultural	0.09				0.01		
Commercial/Industrial-LT	518.17				0.20		
Commercial/Industrial-HT	120.68						
Other (specify)	127.54						
Total	2,283.43	BYPL is working on online preparation of report	NA	NA	198.76	252.91	
Quarter-3							
Residential	853.66				187.96		
Agricultural	0.07				0.01		
Commercial/Industrial-LT	400.66				0.10		
Commercial/Industrial-HT	86.02						
Other (specify)	108.49						
Total	1,448.91				188.06	0	
Quarter-4							
Residential	729.99				185.33		
Agricultural	0.05				0.01		
Commercial/Industrial-LT	326.36				0.15		
Commercial/Industrial-HT	75.22						
Other (specify)	123.87						
Total	1,255.49				185.48	537.47	

SAVE ENERGY- SAVE FUTURE


5.4.2 Category Wise subsidy details

The category wise subsidy details are as shown in the table below:

Table 35 Subsidy details 2022-23

Category	Consumer Number		Billed Energy		Subsidy	
	Number	% Share	MU	% Share	Rs. In Crore	% Share
Agriculture	41	0.00%	0.29	0.00%	0.03	0.00%
Commercial-HT	314	0.02%	307.94	4.43%	-	0.00%
Commercial-LT	406731	21.37%	1,406.80	20.22%	0.63	0.08%
Residential	1482641	77.89%	4,397.33	63.20%	760.80	99.91%
Industrial-HT	34	0.00%	79.03	1.14%		0.00%
Industrial-LT	7620	0.40%	301.53	4.33%		0.00%
Others	6176	0.32%	465.41	6.69%		0.00%
Total	1903557	100.00%	6,958.33	100.00%	761.46	100.00%

Across the subsidized categories, Residential category accounted for 99.91 % of total Subsidy billed amount.



SAVE ENERGY- SAVE FUTURE

Figure 7 Category wise Subsidy 2022-23

Across the Divisions, the Subsidy billed amount ranges between Rs. 14.98 Cr. to Rs. 112.68 Cr. The Subsidy billed amount across Divisions is shown in the below table. Karawal Nagar had the highest Subsidy of 112.68 (Rs.Cr.) and Shankar Road had the lowest Subsidy of 14.98 (Rs. Cr.)

Circle	Division	Category	Billed Energy	Subsidized Energy billed	Tariff	Subsidy Per unit	Subsidy	Subsidy received	Balance subsidy
			MU	MU	Rs./KWH	Rs./KWH	Rs in Cr.	Rs in Cr.	Rs in Cr.
			1	2	3	4	5=2*4	6	7=5-6
Central	Chandni Chowk	Residential	98.96				17.67		
		Agricultural	-				0.01		
		Commercial/ Industrial-LT	134.26						
		Commercial/ Industrial-HT	-						
		Others	7.83						
		Total Chandni Chowk	241.05					17.68	
Central	Darya Ganj	Residential	204.02				25.82		
		Agricultural	-						
		Commercial/ Industrial-LT	164.39						
		Commercial/ Industrial-HT	-						
		Others	109.79						
		Total Darya Ganj	478.19					25.82	
Central	Pahar Ganj	Residential	177.69				28.84		
		Agricultural	-						
		Commercial/ Industrial-LT	142.39						
		Commercial/ Industrial-HT	-						
		Others	7.50						
		Total Pahar Ganj	327.58					28.84	
Central	Patel Nagar	Residential	244.21				42.30		
		Agricultural	0.02						
		Commercial/ Industrial-LT	178.00						
		Commercial/ Industrial-HT	-						
		Others	10.11						
		Total Patel Nagar	432.34					42.30	
Central	Shanker Road	Residential	165.14				14.98		
		Agricultural	-						
		Commercial/ Industrial-LT	195.46						

SAVE ENERGY- SAVE FUTURE

		Commercial/ Industrial-HT	-						
		Others	7.39						
		Total Shanker Road	367.98				14.98		
North East	GT Road	Residential	309.13				50.37		
		Agricultural	0.04				0.00		
		Commercial/ Industrial-LT	302.46						
		Commercial/ Industrial-HT	-						
		Others	11.91						
		Total GT Road	623.54				50.37		
North East	Karawal Nagar	Residential	486.67				112.67		
		Agricultural	0.07				0.01		
		Commercial/ Industrial-LT	132.29						
		Commercial/ Industrial-HT	-						
		Others	94.12						
		Total Karawal Nagar	713.15				112.68		
North East	Nand Nagri	Residential	411.22				84.58		
		Agricultural	0.05				0.01		
		Commercial/ Industrial-LT	101.23						
		Commercial/ Industrial-HT	-						
		Others	30.27						
		Total Nand Nagri	542.77				84.59		
North East	Yamuna Vihar	Residential	502.22				96.66		
		Agricultural	0.05				0.00		
		Commercial/ Industrial-LT	152.78						
		Commercial/ Industrial-HT	-						
		Others	27.65						
		Total Yamuna Vihar	682.70				96.66		
South East	Karkardooma	Residential	316.40				39.64		
		Agricultural	-						
		Commercial/ Industrial-LT	112.80				0.62		
		Commercial/ Industrial-HT	-						
		Others	11.09						
		Total Karkardooma	440.30				40.26		
South East	Krishna Nagar	Residential	438.75				68.82		
		Agricultural	0.03				0.00		
		Commercial/ Industrial-LT	188.89						
		Commercial/ Industrial-HT	-						
		Others	8.46						

SAVE ENERGY- SAVE FUTURE

		Total Krishna Nagar	636.13				68.82		
South East	Laxmi Nagar	Residential	547.56				86.67		
		Agricultural	-						
		Commercial/ Industrial-LT	238.16						
		Commercial/ Industrial-HT	-						
		Others	19.63						
		Total Laxmi Nagar	805.35				86.67		
South East	Mayur Vihar Ph I	Residential	298.01				53.77		
		Agricultural	0.04				0.00		
		Commercial/ Industrial-LT	72.88						
		Commercial/ Industrial-HT	-						
		Others	33.46						
		Total Mayur Vihar Ph I	404.38				53.77		
South East	Mayur Vihar Ph III	Residential	209.98				38.02		
		Agricultural	-						
		Commercial/ Industrial-LT	36.29						
		Commercial/ Industrial-HT	-						
		Others	16.60						
		Total Mayur Vihar Ph III	262.86				38.02		
BYPL All Circles	BYPL All Divisions	Residential	4,409.97				760.80		
		Agricultural	0.29				0.04		
		Commercial/ Industrial-LT	2,152.27				0.62		
		Commercial/ Industrial-HT	-				-		
		Others	395.80				-		
		Total BYPL All Divisions	6,958.33				761.46		

Figure 8 Division wise Subsidy 2022-23

SAVE ENERGY- SAVE FUTURE

5.5 Trend analysis and identification of key exceptions

BYPL has commendable AT&C loss level of 6.47% due to many initiatives & focused approach. More concentric approach is required for High loss divisions as mentioned / analysed in above sections.

Comparative performance of DISCOM in last three year is shown in following table

Comparative Performance of DISCOM								
Sr. no	Description	UOM	2020-21		2021-22		2022-23	
1	Number of Consumer	Million No	1.77		1.83		1.90	
2	Consumer density	Number per SQ KM	9833.2		10161.7		10575.3	
3	Purchase Energy	MU	7329		8278		8704	
4	Cost of purchase Power	Rs/KWH	7.24		7.63		8.04	
5	Peak Demand	MW	1439		1662			
6	Net energy to DISCOM	MU	6374		6683		7504	
7	Consumption	MU	5866		6171		6958	
8	Consumption per consumer per month	KWH/Month	276.2		281.2		304.6	
9	T&D Loss	MU	509		511		545	
10		%	7.98		7.65		7.27	
11	Billing efficiency	%	92.02		92.35		92.73	
12	Collection efficiency	%	100.57		100.43		100.86	
13	AT&C Loss	%	7.46		7.26		6.47	
14	Circle Wise							
14.1	Lowest T&D Loss	%	South East	6.21	South East	6.30	South East	6.75
14.	Highest T&D	%	Central	10.27	Central	9.55	Central	7.66

2	Loss		I					
14.3	Lowest AT&C Loss	%	South East	5.55	South East	5.93	South East	5.98
14.4	Highest AT&C Loss	%	Central	9.70	Central	9.36	Central	6.76
15	Division Wise							
15.1	Lowest T&D Loss	%	Shankar Road	3.71	Karkardooma	4.39	Karkardooma	4.18
15.2	Highest T&D Loss	%	Darya Ganj	16.79	Darya Ganj	14.78	Darya Ganj	9.94
15.3	Lowest AT&C Loss	%	Shankar Road	3.03	Shankar Road	3.98	Karkardooma	3.60
15.4	Highest AT&C Loss	%	Darya Ganj	16.146	Darya Ganj	14.26	Chandni chowk	9.89

6 Energy Audit Finding

As required by clause 5(g) of Bureau of energy efficiency (manner and interval for conduct of energy audit in electricity distribution companies) regulation Energy audit Cell (EAC) comprising of Additional Vice President Mr. Rajesh Srivastavaas Energy Manager, General Manager Mr. Devanshu Sharma as Nodal officer and supported by one Financial Manager (Mr. Govind GandhiGM) and one IT Manager (Mr. Mohan Tahilyani Dy.GM).

This was already informed to BEE vide letter no CEO(BYPL)/21-22/1976 dated 29th December 2021

6.1 Review of capacity of DISCOM's energy accounting and audit wing

Details and analysis may be specified such as compliance of staffing in Energy Accounting/ Energy Audit wing w.r.t the Regulations

6.2 Critical Analysis

- BYPL provides services to approx. 1.9 million consumers of various categories. The consumer base of DISCOM consists of Domestic, Non-Domestic, Industrial consumers etc.
- While the energy billed by BYPL for the customer is 6958 MU, the monthly consumption per customer stands at 304.6 KWh/Month. BYPL caters to area spread in 180Sq. Km.
- Verified Distribution (T&D) losses, collection efficiency & aggregate technical & commercial losses of BYPL for FY22-23, i.e., 1st April'2022 to 31st March'2023 is 7.27%, 100.86% & 6.47% respectively.
- BYPL has 100 % metering available at all level.

- BYPL 's distribution network consists of 3 numbers of circles, 14 numbers of divisions, 42 numbers of sub-division, 20712 number of feeders, 4133 number of DTs and 1903557 numbers of consumers.
- Calculation methodology of AT&C Losses, calculated on not more than 100% collection efficiency.
- The electrical energy which is supplied by various interstate Purchase Power agreement at v, 66kv, 33 kv and same is supplied to Customers at 66 kv, 33 kv, 11 kv, 400 v and 230 v single phase.
- BYPL has 100% metering available at 11/33/66 kv system. However, there is 100 % metering at consumer end and 100 % metering available at DT.
- The electrical energy which is supplied by Delhi Transco & Power Grid Corporation Ltd. at 400 KV, 220 KV, 66 KV, 33 KV and same is supplied to customers at 66 KV, 33 KV, 11 KV, 400 V and 230 V single phase.
- Being a Discom BYPL have RPO obligation which will be a certain percentage of energy sale. For the FY 2022-23 it is about 10.25%. It can be fulfilled by either purchasing of power from renewable energy producer or purchasing of REC certificate.
- The objective of this is to promote generation of electricity from renewable source of energy hence for non-compliance; there is a provision for penal action.
- Quantum of electricity generated under Delhi Electricity Regulatory commission (net metering for renewable energy) Regulation 2014 shall qualify towards compliance of renewable purchase obligation (RPO) for the Discom if renewable energy generator is not an obligated entity
- At present source for solar power is from SECI, Thyagraj, Delhi MSW, Roof Top Net Metering etc. The balance is by purchasing of REC certificate.
- The source for non-solar renewable energy is TOWMCL and PTC (Wind) and balance is by purchasing of REC certificate.
- Discom has initiated various activities for Technical Loss reduction as well as AT & C Loss reduction. Some of major activities are mentioned as under.
 - ❖ Technical Loss Reduction Activity
 - New Grids, HT and LT feeders
 - DT Addition/ Augmentation for overloaded DT, HVDS
 - Balancing of Load at all voltage levels; Shunt Capacitors at LV
 - LT Less system for Agriculture Pump connections
 - Pole Metering; Group Metering,
 - HVDS Bushing mounted DB
 - New armoured street light Ckts in HVDS area
 - Heat Shrink Coatings on theft prone points in network

- Chemical Joints; Application of Conductive paste on LT bushings to reduce contact resistance
- ❖ Commercial Loss Reduction Activity
- Meter Relocation, Old Meter Replacement; MS box with shearing nut arrangement
- Bare conductor with armour cable; Armour cable in place of heavily punctured AB cable span, armoured cast tape to secure joints.
- Enforcement activities - Curbing E-Rickshaw theft, Odd Hour/ Surprise raids, Lady Guards
- Facilitator engagement to support team on the ground
- Surveillance of actions taken and generation of LR leads

1. Specify best & worst performing Circle/ Divisions
2. Areas where in DT loading/ Network loading needs to be improved
3. Areas with low PF/ require Capacity banks installations.
4. High Theft prone areas
5. Improvement /degradation in comparison with previous Years
6. **Specify best & worst performing Circle/ Divisions**

Category	Best	Worst
AT&C	5.98%	6.76%
Circle	South East	North East

Category	Best	Worst
AT&C	3.60%	9.89%
Division	KKD	CCK

High Theft prone areas

Category	Division	Major Areas	Pockets
High Theft Prone Areas	Darya Ganj	Jama Masjid	Kucha Challan, Gali Pahadwali, Dujana House, Girdharpanna, Mohalla Qabristaan, Turkman Gate, Bulbuli Khana, Chandi Mahal, Chitli Qabar, Chata Lal Mian, Rakabganj & Choodiwalan
	Chandni Chowk	Lahori Gate	Lal Darwaza, Jangli Kuan, Chatta Nawab, Farsh Khana, Shahganj Chowk Bridge, Gali Chahshirin, Gali Chabuk Sawar, Ballimaran, Chatta Rajan, Katra Dina Beg, Phathak Loharu

Yamuna Vihar	New Seelampur & Ghonda	New Seelampur, Gamri, Chauhan Banger, , Tikona Park, Babu Ram Chowk, Ghonda village, Welcome, Janta Majdoor Colony & Kabootar Market
Pahar Ganj	BG Road and PP Quarter	Bara Hindo Rao, Chimni Mil, Model Basti, Gali Darjiyan, Basti Julan. Gali Daryajan, Ahata Kidara, Old Quashab Pura, New Quashab Pura, A K Tanki Outside, Choti Masjid, Chamelian Road
Nandnagri	MIG East of Loni Road & Sudamapuri	Loni Border No. 1 & 2, Gokalpur, Chajjupur, Babarpur, Shakti Garden.
Krishna Nagar	Krishna Nagar and Gandhi Nagar	Old Seelampur Village, Ghondli Village, Shastri Park and Pandit park and Kaushik Puri

Improvement /degradation in comparison with previous Years*

Division Name	FY 21-22		FY 22-23	
	AT&C Loss (%)	T&D Loss (%)	AT&C Loss (%)	T&D Loss (%)
Chandni Chowk	13.02%	12.68%	9.89%	9.77%
Darya Ganj	14.26%	14.78%	7.00%	9.94%
Pahar Ganj	9.27%	9.37%	8.17%	8.85%
Patel Nagar	5.63%	5.31%	5.40%	5.62%
Shankar Road	3.98%	4.75%	4.42%	4.37%
GT Road	5.29%	5.92%	5.41%	5.74%
Karawal Nagar	5.63%	6.41%	5.37%	6.67%
Nandnagri	6.88%	7.88%	6.26%	7.47%
Yamuna Vihar	10.15%	10.26%	9.63%	9.88%
Karkardooma	4.18%	4.39%	3.60%	4.18%
Krishna Nagar	7.15%	6.85%	7.35%	7.88%
Laxmi Nagar	5.44%	6.02%	5.46%	5.99%
Mayur Vihar	6.40%	7.05%	6.07%	8.19%
Mayur Vihar - III	6.28%	7.70%	7.66%	8.22%
BYPL	7.26%	7.65%	6.47%	7.27%

6.2.1 Transformer loading & Efficiency analysis

Details of transformer loading & efficiency is discussed as under.

Parameter	Units	SCHOOL KHATTA-	MOHAN	J EXTN.	U BLOCK	MANDAWALI
-----------	-------	----------------	-------	---------	---------	-----------

		II,MANDAWALI:PM	PARK LAXMI NAGAR:K	LAXMI NAGAR:PM	SHAKARPUR:PM	(POST OFFICE):PL
Rating	KVA	1000	1000	1000	1600	2000
No Load Loss	W	1090	1090	1090	1524	1800
Load Loss (100% Loading)	W	7700	7700	7700	11800	15000
Max. Operating Load	KW	801	738	664	1271	1644
Avg. Operating Load	KW	486	493	398	881	895
Power factor @ maximum loading	PF	0.99	0.99	0.99	0.99	0.99
Max. Operating Load	KVA	809	745	671	1284	1661
Avg. Operating Load	KVA	491	498	402	890	904
maximum loading percentage	%	81%	75%	67%	80%	83%
Transformer losses at max.	KW	7.32	6.83	6.26	10.99	14.26
	%	0.93%	0.95%	0.97%	0.99%	1.01%

Table 36 Transformer Loading and Efficiency analysis

6.2.2 Status and Progress in Compliance to pre-requisites to energy accounting

This Energy Audit report is being issued within the timeline stipulated in Regulations and hence no further comments from Energy Auditor with regards to this aspect.

BYPL has submitted all quarterly & annual reports so far. Further, the compliance with regards to Regulations and pre-requisites are tabulated in the table below:

Table 37 Compliance status w.r.t Timelines and Pre-requisites

The pre-requisites have been complied / being complied

Clause	Details	Sub- Clause	Criteria	Compliance Status
3	Intervals of time for conduct of annual energy audit	a	Conducted an annual energy audit for every financial year and submitted the annual energy audit report to the Bureau and respective State. Designated Agency and also made available on the website of the electricity distribution company within a period of four months from the expiry of the relevant financial year	
4	Intervals of time for conduct of periodic energy accounting.	a	All feeder wise, circle wise and division wise periodic energy accounting is conducted by the energy manager of the electricity distribution company for each quarter of the financial year.	
		b	All feeder wise, circle wise and division wise periodic energy accounting is conducted by the energy manager of the electricity distribution company for each quarter of the financial year.	
		c	Electricity distribution company conducted its first periodic energy accounting, for the last quarter of the financial year immediately preceding the date of such commencement (i.e.,	

Clause	Details	Sub Clause	Criteria	Compliance Status
			6th October 2021)	
		d	Electricity distribution company conducted its subsequent periodic energy accounting for each quarter of the financial year for a period of two financial years from the date of such commencement and submit the periodic energy accounting report within sixty days from the date of periodic energy accounting.	
5	Pre-requisites for annual energy audit and periodic energy accounting	a	Pre-requisites for annual energy audit and periodic energy accounting	
		b	Identification and mapping of high tension and low-tension consumers	
		c	Development and implementation of information technology enabled energy accounting and audit system, including associated software	
		d	Electricity distribution company ensures the installation of functional meters for all consumers, transformers and feeders. Meter installation is done in a phased manner within a period of three financial years from the date of the commencement of these regulations in accordance with the trajectory set out in the First Schedule d.1. 100% Communicable Feeder Metering integrated with AMI, by 31st December 2022 along with replacement of existing non-communicable feeder meters.	
			d.2. All Distribution Transformers (other than HVDS DT up to 25kVA and other DTs below 25 kVA) shall be metered with communicable meters. Communicable DT Metering for the following areas/ consumers to be completed by December 2023 and in balance areas by December 2025:	
			d.2.1. All Electricity Divisions of 500 AMRUT cities, with AT&C Losses > 15%	
			d.2.2. All Union Territories (for areas with technical difficulty, non-communicable meters may be installed)	
			d.2.3. All Industrial and Commercial consumers	
			d.2.4. All Government offices at Block level and above	
			d.2.5. Other high loss areas i.e., rural areas with losses more than 25% and urban areas with losses more than 15%	
			d.3. Prepaid Smart Consumer Metering to be completed for all directly connected meters and AMR in case of other meters, by December 2023 in the following areas:	

Clause	Details	Sub-Clause	Criteria	Compliance Status
			d.3.1. All Electricity Divisions of 500 AMRUT cities, with AT&C Losses > 15%;	
			d.3.2. All Union Territories (for areas with technical difficulty, prepaid meters to be installed);	
			d.3.3. All Industrial and Commercial consumers;	
			d.3.4. All Government offices at Block level and above;	
			d.3.5. Other high loss areas i.e., rural areas with losses more than 25% and urban areas with losses more than 15%.	
			d.4. Consumer Metering: 98% by FY 2022-23 99% by FY 2023-24	
			d.5. Targets for functional meters - Meter FY 22-23 FY 23-24 FY24-25 Feeder metering 98.5% 99.5% 99.5% DT metering 90% 95% 98% Consumer metering 93% 96% 98	
		e	e.1. All distribution transformers (other than high voltage distribution system up to 25kVA and other distribution system below 25 kVA) is metered with communicable meters.	
			e.2. And existing non communicable distribution transformer meters is replaced with communicable meters and integrated with advanced metering infrastructure.	
		f	Electricity distribution company has established an information technology enabled system to create energy accounting reports without any manual interference and such systems may be within a period of three years from the date of the commencement of these regulations in case of urban and priority area consumers; and within five years from the date of the commencement of these regulations in case of rural consumers	
		g	Electricity distribution company has a centralized energy accounting and audit cell comprising of (i) a nodal officer, an energy manager and an information technology manager, having professional experience of not less than five years; and (ii) a financial manager having professional experience of not less than five years	
6	Reporting requirements for annual energy audit and periodic energy	a	Electricity distribution company has a nodal officer, who is a full time employee of the electricity distribution company in the rank of the Chief Engineer or above, for the purpose of	

Clause	Details	Sub-Clause	Criteria	Compliance Status
	accounting		reporting of the annual energy audit and periodic energy accounting and communicate the same to the Bureau	
		b	Electricity distribution company ensures that the energy accounting data is generated from a metering system or till such time the metering system is not in place, by an agreed method of assumption as may be prescribed by the State Commission.	
		c	Metering of distribution transformers at High Voltage Distribution System up to 25KVA is done on cluster meter installed by the electricity distribution company	
		d	The energy accounting and audit system and software is developed to create monthly, quarterly and yearly energy accounting reports.	
		c	Electricity distribution company has provided the details of the information technology system in place as specified in clause (f) of regulation 5 that ensures minimal manual intervention in creating the energy accounting reports and any manual intervention of any nature, in respect of the period specified therein, shall be clearly indicated in the periodic energy accounting report	

Table 38 Pre-Requisites for Annual Energy Audit and periodic Energy Accounting

Sr No	Activity	Status
1	Identification and mapping of all of the electrical network assets.	Identified
2	Identification and mapping of high tension and low-tension consumers.	Identified & already shared
3	Development and/or implementation of information technology enabled energy accounting and audit system including associated software;	GEMS, MDAS, SAP Software are used
4	Electricity distribution company shall ensure installation of functional meters for all consumers, and feeders. It is clarified that meter installation shall be done in a phased manner within a period of 3 financial years from the date of coming into effect of these regulations in accordance with the trajectory as set-out in Annexure 2.	All feeders are having communicable meters – 1169 feeders (66/33/11 KV).
5	All Distribution Transformers (other than those connected with dedicated / segregated agricultural feeders, HVDS DTs below 25kVA and DTs below 25 kVA) shall be metered with communicable meters. Existing non-communicable Distribution Transformer meters shall also be replaced with communicable meters and integrated with AMI.	Around 50% % Communication meter installed at DTs. Activities are going on for remaining Distribution

		Transformers.
6	To establish an IT system to create energy accounting reports without any manual interference. Such system shall be established within a period of 3 years from the date of coming into effect of these regulations for urban and priority area consumers; and within 5 years from the date of coming into effect of these regulations for rural consumers excluding agricultural consumers.	Ongoing
7	Create a centralized energy accounting and audit cell comprising of nodal officer, energy manager, IT manager (not below 5 years' service experience) and a financial manager (not below 5 years' service experience).	List have already shared (Attached as Attachment 1)
7.1	Nodal Officer, who shall be a full-time employee of the Electricity Distribution Company in the rank of the Chief Engineer or above and also having professional experience of not less than five years.	List have already shared
7.2	1 Energy Manager, 1 Financial Manager and 1 IT Manager, having professional experience of not less than five years.	List have already shared

6.2.3 Data gaps

The Audit firm has raised the data gaps to the DISCOM dated 17/07/2023 and the DISCOM has submitted the details to the Audit firm dated 18/07/2023. The Summary of data gaps raised and response from DISCOM is summarized in the table below:

Table 39 Summary of Data gaps

Sr.No.	Data gaps raised by Energy Auditor	Response shared by DISCOM	Status data submission by DISCOM
1	Voltage-wise & meter-type wise segregation of consumers	Working for online availability of report / data	Yes
2	Subsidized Energy Billed (MU)	Working for online availability of report / data	Yes

Comments of BEE data sheet is discussed as under.

Table 40 Comments on BEE format

Sr. No	Reference Data Sheet	Comments & Queries	Remarks
1	General information sheet	Nil	Nil
2	Input Infrastructure	T&D Loss and D Loss	Since T&D Loss and D loss is same for DISCOMs so D loss to be removed from modified format.
3	Input energy injection point	Zone, Circle, Division & Sub-division column	<p>Net Input energy at DISCOM periphery is calculated based on Import/Export interface ABT meters installed at Transco level.</p> <p>The Transco ABT meters are installed on incoming feeders (66kV/33kV) feeding to DISCOM Grid.</p> <p>Outgoing 11kV feeders connected to Distribution Transformer located in different Divisions / Subdivisions.</p> <p>11kV feeders can be segregated in division but 66/33kV Feeders can't be segregated into Division / Subdivision level.</p> <p>Based on Above fact modification of Part B Table is required and Zone, Circle, Division & Sub-division column to be excluded from the Form.</p>
4	Input energy source	POC Loss Calculation and voltage level	<p>BYPL is purchasing power from different generating station situated at different states and connected through national, regional and state level grid hence generating station wise POC loss is not feasible. Generating station voltage level is also not feasible as BYPL is receiving power mostly at 66 KV level and 33 KV level. In view of above fact POC loss and voltage level to be excluded from Input Energy Source form.</p>
5	Embedded generation	Circle, Division and subdivision wise embedded generation	<p>Circle and Division wise distribution of embedded generation is given in attached file Note- MU means Million units (kwh)</p>

Sr. No	Reference Data Sheet	Comments & Queries	Remarks
6	Details of consumer	Nil	Nil
7	Feeder wise loss	Individual Feeder wise loss calculation is not feasible	<p>Every 11kV Feeder is having RING main supply arrangement under which DTs or HT Consumers are back-fed through other than normal dedicated feeder based on the system and network requirements. Since the downstream network from feeder to DT is so dynamic in nature that it is very cumbersome to maintain the feeder network connectivity to DT accurately. Such switchovers will trigger the change in normal network configuration leading to downstream network connectivity and shift the network cut-off points and ultimately the change in grouping of DTs.</p> <p>Further, a Feeder can supply load to multiple Division & Subdivision.</p> <p>Based on above fact feeder wise loss sheet to be modified suitably.</p> <p>T&D Loss for feeders to be calculated on YTM basis instead of quarterly basis.</p>
8	Division Wise loss	Loss calculation on quarterly basis	T&D Loss & AT&C Loss should be computed on YTM Basis instead of Quarterly Basis
9	Subsidy Reconciliation	NIL	NIL

6.3 Revised finding based on data validation and field verification

40 DTs & 44 feeders were analysed & field verification done. Data & images attached as attachment 13 & 14.

6.4 Inclusions and Exclusions

6.4.1 Input Energy Details & Infrastructure

- Net Input energy at DISCOM periphery is calculated based on Import/Export interface ABT meters installed at Transco level.

- The Transco ABT meters are installed on incoming feeders (66kV/33kV) feeding to DISCOM Grid.
- Outgoing 11kV feeders connected to Distribution Transformer located in different Divisions / Subdivisions.
- 11kV feeders can be segregated in division but 66/33kV Feeders can't be segregated into Division / Subdivision level.
- Similar format (Form 1, Part B) is also being submitted during PAT Cycle-II submissions, under which Division and Sub-division was not included.

6.4.2 Details of Feeder Levels

- Name of the Station: Name of DISCOM Grid Station
- Received at Feeder (Final): Energy at 11kV Feeder level emanating from DISCOM Grid
- Feeder consumption: Summation of energy recorded at Distribution Transformer and HT Consumer connected to a respective 11kV Feeder

Every 11kV Feeder is having RING main supply arrangement under which DTs or HT Consumers are back-fed through other than normal dedicated feeder based on the system and network requirements. Since the downstream network from feeder to DT is so dynamic in nature that it is very cumbersome to maintain the feeder network connectivity to DT accurately. Such switchovers will trigger the change in normal network configuration leading to downstream network connectivity and shift the network cut-off points and ultimately the change in grouping of DTs.

Hence, there could be instances where the Feeder consumption figure would be higher than the figure of energy received at that Feeder. Hence, It is requested to modify this form to exclude Subdivision and Feeder consumption or consider the aggregated figures of consumption and feeder input for all feeders taken together.

Further, a Feeder can supply load to multiple Division & Subdivision. A sample SLD is enclosed wherein the Cut-off points have been marked as X through which supply changeovers can be performed.

6.4.3 Generating Station wise POC Loss Calculation

BYPL is purchasing power from different generating station situated at different states and connected through national, regional and state level grid hence generating station wise POC loss is not feasible. Generating station voltage level is also not feasible as BYPL is receiving power mostly at 66 KV level and 33 KV level. In view of above fact POC loss and voltage level to be excluded from Input Energy Source form.

NRSLDC is not calculating POC loss based on Generating station wise but calculating POC loss for all inter-state generation on weekly basis whereas SLDC /DTL is declaring POC loss and state transmission unit (STU) basis not on generating unit basis.

6.4.4 Division and Subdivision wise distribution of embedded generation

S. No.	Name of Generation Station	Generation Capacity (In MW)	Based-Solid/Liquid/Gas	Type of Contract	Type of Grid	Voltage Level (KV)	Circle Load (MW)	Received at Circle (KV)	Received at Circle (MU)	Division Level Load (MW)	Received at Division Level (KV)	Received at Division Level (MU)	Sub-Division Level Load (MW)	Received at Sub-Division Level (KV)	Received at Sub-Division Level (MU)	Remarks (Source of data)
1	Roof Top Solar System	2.00	Solar	Net Metering	Intrastate	11 KV	12.41	11 KV	8.26	2.42	11 KV	0.86	2.42	11 KV	0.86	Chandni Chowk
2	Roof Top Solar System	0.03	Solar	Net Metering	Intrastate	230 V		230 V			230 V			230 V		Chandni Chowk
3	Roof Top Solar System	0.39	Solar	Net Metering	Intrastate	415 V		415 V			415 V			415 V		Chandni Chowk
4	Roof Top Solar System	4.83	Solar	Net Metering	Intrastate	11 KV		11 KV		5.69	4.29	5.69	11 KV	4.29	11 KV	Daryaganj
5	Roof Top Solar System	0.05	Solar	Net Metering	Intrastate	230 V		230 V					230 V		230 V	Daryaganj
6	Roof Top Solar System	0.81	Solar	Net Metering	Intrastate	415 V		415 V					415 V		415 V	Daryaganj
7	Roof Top Solar System	1.04	Solar	Net Metering	Intrastate	11 KV		11 KV		1.35	0.43	1.35	11 KV	0.43	11 KV	Pahar Ganj
8	Roof Top Solar System	0.02	Solar	Net Metering	Intrastate	230 V		230 V					230 V		230 V	Pahar Ganj
9	Roof Top Solar System	0.30	Solar	Net Metering	Intrastate	415 V		415 V					415 V		415 V	Pahar Ganj
10	Roof Top Solar System	0.06	Solar	Net Metering	Intrastate	11 KV		11 KV		1.42	1.53	1.42	11 KV	1.53	11 KV	Patel Nagar
11	Roof Top Solar System	0.10	Solar	Net Metering	Intrastate	230 V		230 V					230 V		230 V	Patel Nagar
12	Roof Top Solar System	1.26	Solar	Net Metering	Intrastate	415 V		415 V					415 V		415 V	Patel Nagar
13	Roof Top Solar System	0.54	Solar	Net Metering	Intrastate	11 KV	11 KV	1.53	1.14	1.53	11 KV	1.14	11 KV	Shankar Road		
14	Roof Top Solar System	0.08	Solar	Net Metering	Intrastate	230 V	230 V				230 V		230 V	Shankar Road		
15	Roof Top Solar System	0.91	Solar	Net Metering	Intrastate	415 V	415 V				415 V		415 V	Shankar Road		
16	Roof Top Solar System	0.34	Solar	Net Metering	Intrastate	11 KV	11 KV	1.49	1.52	1.49	11 KV	1.52	11 KV	Gt Road		
17	Roof Top Solar System	0.12	Solar	Net Metering	Intrastate	230 V	230 V				230 V		230 V	Gt Road		
18	Roof Top Solar System	1.03	Solar	Net Metering	Intrastate	415 V	415 V				415 V		415 V	Gt Road		
19	Roof Top Solar System	3.47	Solar	Net Metering	Intrastate	11 KV	11 KV	3.68	4.52	3.68	11 KV	4.52	11 KV	Karawal Nagar		
20	Roof Top Solar System	0.07	Solar	Net Metering	Intrastate	230 V	230 V				230 V		230 V	Karawal Nagar		
21	Roof Top Solar System	0.14	Solar	Net Metering	Intrastate	415 V	415 V				415 V		415 V	Karawal Nagar		
22	Roof Top Solar System	0.97	Solar	Net Metering	Intrastate	11 KV	11 KV	2.12	1.24	2.12	11 KV	1.24	11 KV	Nand Nagri		
23	Roof Top Solar System	0.09	Solar	Net Metering	Intrastate	230 V	230 V				230 V		230 V	Nand Nagri		
24	Roof Top Solar System	1.06	Solar	Net Metering	Intrastate	415 V	415 V				415 V		415 V	Nand Nagri		

	System			ing	te										
25	Roof Top Solar System	0.04	Biowaste	Net Metering	Intraste	415 V	415 V								Yamuna Vihar
26	Roof Top Solar System	0.17	Solar	Net Metering	Intraste	11 KV	11 KV	0.81	0.75	0.81	0.75	0.81	0.75	0.81	Yamuna Vihar
27	Roof Top Solar System	0.09	Solar	Net Metering	Intraste	230 V	230 V								Yamuna Vihar
28	Roof Top Solar System	0.52	Solar	Net Metering	Intraste	415 V	415 V								Yamuna Vihar
29	Roof Top Solar System	1.34	Solar	Net Metering	Intraste	11 KV	11 KV	3.47	3.18	3.47	3.18	3.47	3.18	3.47	Karkar Dooma
30	Roof Top Solar System	0.55	Solar	Net Metering	Intraste	230 V	230 V								Karkar Dooma
31	Roof Top Solar System	1.58	Solar	Net Metering	Intraste	415 V	415 V								Karkar Dooma
32	Roof Top Solar System	0.04	Biowaste	Net Metering	Intraste	415 V	415 V								Krishna Nagar
33	Roof Top Solar System	0.04	Solar	Net Metering	Intraste	11 KV	11 KV	1.04	0.98	1.04	0.98	1.04	0.98	1.04	Krishna Nagar
34	Roof Top Solar System	0.29	Solar	Net Metering	Intraste	230 V	230 V								Krishna Nagar
35	Roof Top Solar System	0.67	Solar	Net Metering	Intraste	415 V	415 V								Krishna Nagar
36	Roof Top Solar System	3.75	Solar	Net Metering	Intraste	11 KV	11 KV	7.08	5.92	7.08	5.92	7.08	5.92	7.08	Laxmi Nagar
37	Roof Top Solar System	0.20	Solar	Net Metering	Intraste	230 V	230 V								Laxmi Nagar
38	Roof Top Solar System	3.14	Solar	Net Metering	Intraste	415 V	415 V								Laxmi Nagar
39	Roof Top Solar System	0.32	Solar	Net Metering	Intraste	11 KV	11 KV	1.55	1.59	1.55	1.59	1.55	1.59	1.55	Mayur Vihar i&ii
40	Roof Top Solar System	0.13	Solar	Net Metering	Intraste	230 V	230 V								Mayur Vihar i&ii
41	Roof Top Solar System	1.09	Solar	Net Metering	Intraste	415 V	415 V								Mayur Vihar i&ii
42	Roof Top Solar System	0.20	Biowaste	Net Metering	Intraste	11 KV	11 KV	0.99	0.79	0.99	0.79	0.99	0.79	0.99	Vasundhara Enclave
43	Roof Top Solar System	0.11	Solar	Net Metering	Intraste	11 KV	11 KV								Vasundhara Enclave
44	Roof Top Solar System	0.03	Solar	Net Metering	Intraste	230 V	230 V								Vasundhara Enclave
45	Roof Top Solar System	0.64	Solar	Net Metering	Intraste	415 V	415 V								Vasundhara Enclave

6.4.5 Period for T&D Loss and AT&C loss calculation

T&D Loss & AT&C Loss should be computed on YTM Basis instead of Quarterly Basis.

7 Conclusion and Action Plan

7.1 Summary of critical analysis and way forward proposed by Energy Auditor

The Primary energy- consuming areas are the distribution network, the office buildings, and the fleet of vehicles used for maintenance and repairs. The distribution network accounts for the majority of energy consumption, followed by office building and vehicles.

7.1.1 Areas of Inefficiencies:

- **LT/HT Ratio:** Increasing HT lines can help in reducing both line losses and voltage drops. Efforts should be made to achieve a low LT/HT ratio, which would be very beneficial for improving efficiency of power distribution in BYPL.
- **Vehicle conversion :** BYPL may take-up conversion of vehicles to EVs as it is having large fleet

7.1.2 Recommendations:

BYPL has already achieved AT &C loss level of 6.47%. Focused approach can be adopted for divisions which are operating at higher AT&C loss level than BYPL's at company level.

7.1.3 Cost- Benefit Analysis:

To determine the cost- effectiveness of the recommended measures, a cost- benefit analysis should be conducted. The cost of implementing the measures should be compared to the potential energy saving to determine the return on investment. This analysis will help the company prioritize the implementation of the recommended measures.

The electricity distribution company revealed several areas of Inefficiencies in energy consumption. The recommended measures, including upgrading the infrastructure, promoting employee awareness, and further improving the fleet of vehicles, will help to improve energy efficiency and reduce energy consumption. Conducting a cost-benefit analysis will help the company to prioritize the implementation of these measures. Overall, the implementation of these measures will improve the company's energy efficiency, reduce energy consumption, and lower energy costs.

7.2 Summary of key findings-energy balance and losses

The Energy balance and losses of BYPL for FY 2022-23 are as shown in the table below:

Table 41 Energy balance and losses

Trend of BYPL (2022-23)				
Sr. No.	Energy Input Details	Formula	UOM	Value
1	Purchase Energy (From Generation Source)	A	MU	8704
2	Net Energy Input to Discom (at DISCOM Periphery after adjusting the transmission losses and energy	B	MU	7,503

	traded)			
3	Energy billed (is the Net energy billed, adjusted for energy traded)	C	MU	6,958.33
4		D	Rs. Crores	5,592.87
5	Average Billing Rate	$E=D*10/C$	Rs/Kwh	8.04
6	Amount collected	F	Rs. Crores	5,641.15
7	Transmission and Distribution (T&D) Loss	$G=B-C$	MU	545.43
8		$H=G*100/B$	%	7.27%
9		$J=E*G/10$	Rs. Crores	438.40
10	Billing Efficiency	$K=C*100/B$	%	92.73%
11	Collection efficiency	$L=F*100/D$	%	100.86%
12	Aggregate Technical & Commercial (AT&C) Loss	$M=1-(K*L)$	%	6.47%

7.3 Recommendations and best practices

7.3.1 Energy accounting

Energy accounting is being done regularly in BYPL. Meters are installed at all levels. All feeder meters are communicable & more than 50% of DT meters are communicable. Almost all the reports are generated through system data.

7.3.2 Loss reduction

- Discom has initiated various activities for Technical Loss reduction as well as AT & C Loss reduction. Some of major activities are mentioned as under.
 - ❖ Technical Loss Reduction Activity
 - New Grids, HT and LT feeders
 - DT Addition/ Augmentation for overloaded DT, HVDS
 - Balancing of Load at all voltage levels; Shunt Capacitors at LV
 - LT Less system for Agriculture Pump connections
 - Pole Metering; Group Metering,
 - HVDS Bushing mounted DB
 - New armoured street light Ckts in HVDS area
 - Heat Shrink Coatings on theft prone points in network

- Chemical Joints; Application of Conductive paste on LT bushings to reduce contact resistance
- ❖ Commercial Loss Reduction Activity
- Meter Relocation, Old Meter Replacement; MS box with shearing nut arrangement
- Bare conductor with armour cable; Armour cable in place of heavily punctured AB cable span, armoured cast tape to secure joints.
- Enforcement activities - Curbing E-Rickshaw theft, Odd Hour/ Surprise raids, Lady Guards
- Facilitator engagement to support team on the ground
- Surveillance of actions taken and generation of LR leads

7.3.3 Energy conservation

BSES Yamuna Power Ltd has implemented various proactive programs and awareness campaigns to curb demand-supply imbalances and promote the responsible use of electricity, in accordance with the Demand Side Management Regulations – DERC.

Following Initiatives were undertaken over the years in the direction of Demand-side Management and Energy Conservation apart from general awareness to all consumers:

DSM Activities Undertaken In FY 2022-2023		
S N o.	Energy Efficiency Measures	Activity
1	Tube light Replacement with LED	No replacement done in FY 2022-2023
2	Old Fans with Energy Efficient Fans	No replacement done in FY 2022-2023
3	Replacement of Old AC's with Energy Efficient AC	No replacement done in FY 2022-2023
4	Awareness Programs	767 Numbers of awareness programs done for energy conservation
5	Home Automation	MoU signed between BYPL and SE in October 2022
6	Smart Innovation Norway	MoU signed between BYPL and SIN in Norway Embassy in February 2023
7	Jan Suraksha Muheem For Energy Conservation	52 number of Jan suraksha Muheem done for safety and Energy Conservation

7.4 Action Plan for line loss reduction

Following energy conservation Measures (ECMs) is adopted for line loss reduction

1. Installation of Smart Meters.
2. Installation of Automatic power factor controller (Capacitor Bank).
3. System improvement & automation.

4. Improvement in metering system.
5. Replacing of conventional/non star rated transformer into energy efficient transformers.
6. Replacement of all conventional mechanical energy meters with static digital energy meters having less power consumption and more accuracy.
7. Laying of AB Cable in theft prone area where loss are in higher side.
8. HVD System to reduce low tension line losses.
9. Replacing worm out/ under sized conductors.
10. Increase in HT/LT Ratio.
11. Preventive & periodic maintenance of line & transformer.
12. Load balancing of Distribution transformers.
13. MIS Based periodic reporting of unit wise business parameters.
14. Installation of solar generation plant & solar pumps.
15. Strengthening of energy accounting infrastructure-100% consumer metering.
16. GIS based asset mapping of all 33/11kv substations, 11kv Lines and distribution transformers has been completed.
17. 11kv Feeder wise base line technical data i.e., length, peak load, VR and technical loss calculated by algorithm & published in power BI.
18. Feeder wise baseline commercial loss is being collected by subtracting technical loss for total T&D loss.
19. Selection/priority of area must be made under:
 - i. Feeder having VR more than 15%.
 - ii. Feeder having VR more than 9 to 15%.
 - iii. Feeder having peak load more than 100 amp. & length more than 30km.
 - iv. High T&D loss feeder.
 - v. High commercial loss feeder.

7.5 Action plan for monitoring and reporting

Monitoring of loss levels & activities are being motored at all levels of BYPLs.

At divisional level it is monitored on daily / weekly basis & at circle level every fortnightly.

Top Management reviews performance every month.

7.6 Action plan for automated energy accounting

Automated energy accounting is a critical component of modern electricity distribution systems. It allows for accurate and efficient tracking of energy usage, which helps identify energy waste, reduce energy consumption, and improve billing accuracy. In this report, we will outline an action plan for implementing automated energy accounting in an electricity distribution company.

Step 1: Evaluate Current Energy Accounting System

The first step is to evaluate the current energy accounting system to identify areas that need improvement. This will involve reviewing the current processes, systems, and data management practices. The evaluation should consider the following factors:

- Accuracy of billing and metering

- Timeliness of bill generation
- Data management practices
- Energy usage tracking capabilities
- Customer feedback and complaints

Step 2: Identify Automated Energy Accounting System Requirements

After evaluating the current energy accounting system, the next step is to identify the requirements for an automated energy accounting system. This will involve considering the following factors:

- Energy usage tracking capabilities
- Billing accuracy and timeliness
- Integration with existing systems
- Data management capabilities
- Scalability and flexibility

Step 3: Research and select an Automated Energy Accounting system

Once the requirements are identified, the next step is to research and select an automated energy accounting system. This will involve reviewing available options and selecting a system that meets the identified requirements. The selected system should have the following features:

- Real-time energy usage tracking
- Automated billing and metering
- Data management and analysis capabilities
- Integration With existing systems
- User friendly interface

Step 4: Develop Implementation plan

After selecting an automated energy accounting system, the next step is to develop an implementation plan. This will involve determining the following:

- Timeline for implementation
- Resource requirements
- Roles and responsibilities
- Training requirements
- Data migration Plan

Step 5: Implementation and Testing

Once the Implementation plan is developed, the next step is to implement and test the automated energy accounting system. This will involve the following:

- Installation and configuration of the system
- Data migration from the old system to the new system
- User training
- System testing

Step 6: Rollout and Monitoring

After successful testing, the next step is to rollout the automated energy accounting system to all customers. This will involve communicating the changes to customers and ensuring a smooth transition. Once rolled out, the system should be continuously monitored to identify any issues and improve the system's performance.

In conclusion implementing an automated energy accounting system can help in improving billing accuracy, reduce energy waste, and enhance data management capabilities. The action plan outlined above provides a framework for implementing an automated energy accounting systems in an electricity distribution company. By following this plan, the company can successfully implement the system and achieve its energy accounting goals.

8 Annexure

8.1 Annexure 1: Introduction of Verification Firm

8.1.1 Brief of Verification Firm

Padmashtdal Energy Services Private Limited (PESPL) is a service consultancy company providing techno commercial solution to customers in the areas of Power System, Industrial Electronics and Utility system management since 1996. In last few years of its operation, the company has been able to generate positive reputation and goodwill among its clientele.

The experience of PESPL in various industries around the country made it realize that there is huge potential of saving energy in almost all industries. In some of the industrial units and office set up the possibility of saving energy is as high as 20%. In some of the industries and companies the energy conservation seemed possible by simply adhering to better operating practices and in some by technical up-gradation in instrumentation & control system and modification in plants.

With this experience, PESPL entered into the arena of ENERGY CONSERVATION in 2005. It focused on ensuring that our client industries adopt efficient energy management systems that help them to optimize their resource utilization thereby reducing the operational cost. We have conducted several energy audits and provided consultancy to industrial units and office facilities to achieve substantial reduction in their Energy-Cost. Our client base includes Sugar industries, Paper Industries, Power Plants, steel plant, MSME units, commercial buildings etc.

PESPL has been accredited as an ESCO (Energy Service Company) by BEE (A statutory body under Ministry of Power, Govt. Of India) in the year 2008. Our CEO of company Mr. Kamalesh Kumar Jha is also an Accredited Energy Auditor by BEE

8.1.2 Composition of Team

The composition of team is shown in following table. We would like to add further that apart from this there are few support staffs who are also participated in this exercise.

Table 42 Details of Study Team

Sr No	Name	Qualification	EM/EA/AEA/EmAEA Registration No	Experience In Years / Sector
Team Leader				
	Mr. Kamalesh Kr Jha	BE MS	EmAEA-026/AEA-0007/ EA 2197	34
Sector Expert				
	Mr.S G Nima	PG Dip, B.E.	Sector Expert	60
Team Members				
1	Mr. Santosh S Malani	B E.	EA- 14799	32
2	Mr. Gautam K Dam	BE	EA- 15151	41
3	Mr. Amit	M Tech	EA - 19689	12
4	Mr. N K Singh	M Tech	Energy Engineer	21
5	Mr. Amit Kr Verma	BE	Energy Engineer	06

8.1.3 Registration No

EmAEA-026/AEA-0007/ EA 2197

8.1.4 Undertaking

It is undertaken that the Audit is carried out as per BEE regulations with sample check of data through field verification.

The details as submitted are as per data submitted by BYPL.

8.2 Annexure 2: Minutes Of Meeting with the Discom Team

Attached as attachment 15.

8.3 Annexure 3: Checklist Prepared by Auditing Firm

Based on the BEE notification No 18/1/BEE/DISCOM/2021 dated 6th October 2021 regarding Manner and Interval for conduct of Energy audit (Accounting) in Electrical Distribution company following general checklist was prepared for completion of Energy Audit assignment.

List of documents required:

- Month Wise input and billed energy.

- T&D losses Computation approach.
- Internal field audit report of input and billed energy.
- Performance of disicom on distribution losses.
- Outcome of internal filed audit.
- Measures taken to reduce losses and improve losses.
- Zone/circle/Division/Sub-division wise loss computation.
- Reduction achieved, measures adopted for energy conservation and quantify of energy saved.
- Report on distribution losses.
- List of measuring equipment's and calibration certificates and frequency of calibration.
- Wire up on energy scenario.
- Generation Via solar, DG and other source and share of energy consumption.
- Net input Energy Computation Details.
- Category wise consumer's details.
- Category wise consumer's connected load and %load.
- Bifurcation of billed Energy (metered billed energy and unmetered billed energy).
- Disconnected consumers details.
- Loss Analysis report.
- Write up on procedure followed Technical loss analysis.
- Details of Energy Purchase, Energy Billing, Revenue Collection, Losses (T&D as well as AT & C) etc. with proper supporting documents for April 2020 to March 2021.
- Signed form as per final regulation notified by BEE.
- Signed Form III submitted to BEE
- Energy Flow and balance.
- Details of RPO obligation with supporting documents.
- Unit Profile with past history
- Details of Infrastructure.
- Present consumer profile
- Annual Report submitted to DERC.
- Third Party audited Power Purchase Certificate
- Input energy at Discom Periphery verified by DTL Bill.
- Third Party audited Billing Certificate
- Third Party audited Subsidy Certificate
- Details of Enforcement protocol.
- Meter calibration/healthiness protocol.

8.4 Annexure 4: Brief Approach, Scope & Methodology for audit

8.4.1 Scope

8.4.1.1 Data collection and verification of energy distribution

- Monthly energy consumption data of consumers and system metering from electricity distribution company at following voltage levels
 - ❖ 33/66 kV levels, including 33/66kV feeder and Sub-station;
 - ❖ 11kV levels, including 11kV feeder and Distribution Sub-station;
 - ❖ 415 V level, including Distribution Transformer and low-tension consumer;
- Input energy details for all metered input points
- Boundary meter details
- Source of energy supply (e.g., Electricity from grid or self-generation), including generation from renewables
- Review of the current consumption practices
- Identification of the energy loss in the system

8.4.1.2 Data verification, validation and correction

- A monitoring and verification protocol to quantify on annual basis the impact of each measure with respect to energy conservation and cost reduction for reporting to Bureau and the concerned State designated agency
- Verification and correction of input energy, taking into account the following
 - ❖ Recorded system meter reading by metering agency
 - ❖ All the input points of transmission system
 - ❖ Details provided by the transmission unit
 - ❖ Relevant records at each electricity test division for each month
 - ❖ Recorded meter reading at all export points (where energy sent outside the State is from the distribution system)
 - ❖ system loading and corresponding infrastructure
- Energy supplied to Open Access Consumers which is directly purchased by Open Access consumers from any supplier other than electricity distribution company
- Verify and validate the system metering data provided by metering agency through random field visit (particularly for data irregularity)

8.4.2 Approach and methodology

The following flow chart illustrates the methodology followed for carrying out different tasks leading to preparation of the EAR.




Figure 9 Methodology

8.5 Annexure 5: Infrastructure Details

The major components of BYPL are listed as under:

Table 43 Infrastructure Details

Parameters	Total	Covered during in Audit	Verified by Auditor in Sample Check	Remarks (Source of data)
Number of Circles	3	2	Data verified	MDAS, SAP, GEM and DTL bill
Number of Divisions	14	5		
Number of Sub-Divisions	46	14		
Number of Feeders	20712	44		
Number of DTs	4133	40		
Number of Consumers	1903557	200		

Table 44 Metering Details

1	Parameters	Total	Covered during in audit	Verified by Auditor in Sample Check	Remarks (Source of data)
i	Number of circles	3	22-23		
ii	Number of divisions	14			

iii	Number of subdivisions	46			
iv	Number of feeders	20,712			
v	Number of DTs	4,133			
vi	Number of consumers	1,903,557			
2	Parameters	66kV & above	33kV	11/22kV	LT
a. i.	Number of conventional metered consumers	BYPL working on the preparation of report for segregation.			
ii	Number of consumers with 'smart' meters				
iii	Number of consumers with 'smart prepaid' meters				
iv	Number of consumers with 'AMR' meters				
v	Number of consumers with 'non-smart prepaid' meters				
vi	Number of unmetered consumers				
vii	Number of total consumers	3	465	1,903,089	
b. i.	Number of conventionally metered Distribution Transformers	NA	NA	2174	NA
	Number of DTs with communicable meters			1959	
	Number of unmetered DTs			0	
	Number of total Transformers			4133	
c. i.	Number of metered feeders	61	110	998	19543
ii	Number of feeders with communicable meters	61	110	998	NA
iii	Number of unmetered feeders	0	0	0	NA
iv	Number of total feeders	61	110	998	19,543
d.	Line length (ct km)	244	432	3,207	5,915
e.	Length of Aerial Bunched Cables	(No Aerial Bunch Cable at 66kV level; 66.5 KM of O/H network)	(No Aerial Bunch Cable at 33kV level; 10.7 of O/H network)	436	2,799
f.	Length of Underground Cables	67	421	2771	3116

- Grid substation 66KV/33KV/11KV
- Distribution Substation 11KV/415 V
- Power/Distribution Transformer
- Protection system
- Metering system

- Cables
- Power Capacitor
- Earthing

Table 45 Inventory List as on March 2023

SI No	Description	UOM	2022-23
1	Grid	Number	55
2	66 KV feeder	Number	61
3	66 KV Lines/Cable	KM	244
4	33 KV Feeder	Number	110
5	33 KV Lines/Cable	KM	432
6	Power Transformer	Number	168
7	EHV capacity	MVA	3989
8	Metering at 66/33 KV	%	100
9	Shunt Capacitors	MVAr	990
10	11 KV Feeder	Number	998
11	11 KV lines/Cable laid (UG)/OH	KM	3207
12	Metering at 11 KV level	%	100
13	Distribution Transformer	Number	4132
14		MVA	3638
15	Metering at DT Level	%	100
16	LT feeders	Number	19543
17	LT Line Length	KM	5915
18	Length of AB cables	KM	2799
19	Length of U/G Cables	KM	6486
20	HT/LT ratio	Number	0.54
21	Metering at consumer end	%	100

8.5.1 Grid Source

The BYPL is getting supply from Transco and Power grid at 66 KV and 33 KV. Total number of grid substation in BYPL is 55 in the year 2022-23.

8.5.2 Power Transformer

Power transformers installed at various grid substation and it is used to step down voltage level from 66/33 which is received Transco, to 11 KV for different feeders. Total number of power transformer of different rating installed at BYPL is 168 having a cumulative capacity of 3969 MVA.

8.5.3 EHV Feeder

BYPL is having 171 number of EHV feeders at 66/33 KV. It is used to receive power from Transco and also for feeding of Bulk consumer like DIAL, DJB, Railway, DMRC etc.

8.5.4 Distribution Transformer

BYPL is having 4133 number of distribution transformer with a cumulative capacity of 3638 MVA. It is used to convert voltage from 11 KV to 415 V. it is located near to consumer base.

8.5.5 11 KV Feeder

11 KV Feeders are used to transport power from grid substation to HT consumers and different distribution transformers. BYPL is having about 998 number of 11 KV feeders.

8.5.6 LT Feeders

LT feeders are used to transfer power from distribution transformer to end consumers. It may be at 415 V for three phase connection and at 220 V for small domestic consumers. BYPL is having about 19543 number of LT feeders.

8.5.7 Protection/Switching System

Complete distribution network is protected with proper protection relays like overload, earth fault, distance protection relay, Feeder Protection relay installed at different feeder panels.

Power Transformers are protected with Overload, Earth fault, Differential relays.

Switching of different feeders are with VCB/SF6 for HT switching and ACB/MCCB/ SFU for LT switching

8.5.8 Metering System

Energy meters are installed for all individual as well as bulk consumers. Apart from this energy meters are also installed at all EHV, HT feeders and distribution transformers for monitoring of energy flow in the Discom. BYPL is having very good metering system for real time monitoring of power flow in the distribution network.

8.5.9 Cables

Cables are used to for interconnecting of different feeders to power transformers, Distribution transformers, end consumers etc. Based on the site condition and requirement overhead as well as underground cables are used. The cable length in BYPL is shown as under:

- 66 KV cables/Lines : 244 KM
- 33 KV cable/Lines : 432 KM
- 11 KV cables/Lines : 3207 KM
- LT Cable /Lines : 5915 KM

- AB cables : 3235 KM
- U/G Cables : 6486 KM

8.5.10 Power Capacitors

Copper Loss in electrical system is very much dependent on current flowing through the system. Hence to reduce copper loss current should be as low as possible. To reduce current, we have to increase voltage and maintain power factor as high as possible near to unity. Voltage level is already optimized as per requirement of network.

To reduce distribution loss and to maintain power factor near to unity BYPL has installed sufficient shunt capacitors at different EHT/HT feeders and distribution transformers. The power factor is also monitored in real time.

8.5.11 Earthing System

To avoid electrical hazard all electrical system, need to be earthed properly. Keeping this in mind BYPL is following all the guidelines of CERC and IS codes of practice for earthing. The main objective of earthing should be:

- The impedance to ground should be as low as possible and it should be as per standards.
- The electrode or earth conductor and earthing strips should be capable enough to carry fault current so that electrical hazard can be avoided.

8.6 Annexure 6: Electrical Distribution System

DISCOM is an organization whose sole responsibility is to procure the electrical power from power generating company through Transmission Company at EHV level and distribute it to end user at appropriate voltage level.

Power received by DISCOM from Transmission Company at 220KV/132KV/66KV/33KV/11 KV level and same is supplied to different customer as per their required voltage level. Type of consumer and their voltage level are shown as under:

- Individual Residential Consumer: 230 V Single Phase / 400 V Three Phase
- Group Housing Society : 11 KV Three Phase
- Commercial Consumer : 230 V Single Phase/ 400 V Three Phase/ 11 KV Three Phase/ 33 KV Three Phase/ 66 KV Three Phase
- Industrial LT Consumer : 230 V Single Phase and 400 V Three Phase
- Industrial HT Consumer : 11 KV/33 KV/66 KV/132 KV Three Phase
- Agriculture Consumer : 230 V Single Phase and 400 V Three Phase
- Street Light/Pump House : 400 V Three Phase/ 11 KV Three Phase

Note: Voltage Specified is as per DERC Supply code and performance Standards Regulations 2017, with +/- 6% variation is admissible in case of Low-Tension voltage level.

As per EC Act 2001 DISCOM is an energy intensive organization, due to its nature of operation. A large amount of energy is being distributed by DISCOM and during the process a significant amount of energy is lost known as T&D loss. The T&D loss percentage is having a wide variation among various DISCOM.

During financial year 2013-14, T&D loss was as low as 12.08% in Himachal Pradesh DISCOM and it was as high as 46.36% in J& K DISCOM with an India level average of 20.68 % which is equivalent to 193750 MU causing revenue loss of 96875 Crores (@Rs 5/unit). The equivalent Co2 emission is about 1589 Lakh MT. The gap between world average and India average is more than 10%.

System Element Power Losses (%)

Table 46 System Element Power Loss

Sr no	Description	Minimum	Maximum
1	Step UP Transformer & EHV Transmission	0.5	1.0
2	Transformation to Intermediate Voltage Level	1.5	3.0
3	Transmission System and step down to sub transmission voltage level	2.0	4.5
4	Distribution Line & Service Connection	3.0	7.0
Total		7.0	15.5

8.7 Annexure 7: Power Purchase Details

- The electrical energy is supplied by Delhi Transco & Power Grid Corporation Ltd. at 400 KV, 220 KV, 66 KV, 33 KV and same is supplied to customers at 66 KV, 33 KV, 11 KV, 400 V and 230 V single phase.

Table 47 Source of Power

Sr. No	Source	Energy in MU
1	Long-Term Conventional	7279
2	Short Term Conventional & others	1118
3	Banking	825
4	Long-Term Renewable energy	3751
5	Medium and Short-Term RE	1581
6	Captive, open access input	497
7	Sale of surplus power	1698
8	Quantum of inter-state transmission loss	547

9	Power procured from inter-state sources	-
10	Power at state transmission boundary	12417
11	Renewable Energy Procurement	-
12	Sales Migration Input	-
13	Energy Embedded within DISCOM wires network	108
14	Total Energy Available/ Input	12964

Note: Sample power purchase details attached as attachment 5.0

8.7.1 Input Purchase power for FY 2022-23

In addition to the details specified below, the audit firm may provide source wise/ generating station wise power purchase, contracted capacity, RPO obligation met by the DISCOM, etc.

BYPL purchase the power from the power generators the month wise purchase units are shown in below table:

Table 48 Month wise power purchase

Sr.No.	Month	Energy(in MUS)
1	Apr-22	781
2	May-22	938
3	Jun-22	1015
4	Jul-22	1006
5	Aug-22	911
6	Sep-22	849
7	Oct-22	568
8	Nov-22	495
9	Dec-22	545
10	Jan-23	609
11	Feb-23	481
12	Mar-23	506
	Total	8704

8.7.2 Circle wise monthly Input Energy for FY2022-23

The Month wise break up of input energy (MUs) parameter for all the circle is given below:

Table 49 Circle wise monthly input energy (MU)

Circle Name	Central	North-East	South-East
Apr-22	191	259	259
May-22	223	293	309
Jun-22	234	310	323
Jul-22	233	308	321
Aug-22	219	295	300
Sep-22	203	270	270
Oct-22	138	184	195
Nov-22	110	147	162
Dec-22	112	152	168
Jan-23	126	175	188
Feb-23	98	137	150
Mar-23	114	156	171
Total	2000	2734	2770

8.8 Annexure 8: Line Diagram (SLD)

8.8.1 SLD of East Zone

Figure 10 SLD of East Zone

Attached as Attachment 6

8.8.2 SLD of Central Zone

Figure 11 SLD of Central Zone

Attached as Attachment 7

8.9 Annexure 9: Category of service details (With Consumer and voltage-wise)

Energy balance of BSES Yamuna is shown in following table

Table 50 Energy Balance BSES Yamuna

Sr.No	Type of Consumers	Category of Consumers (HT/LT)	Voltage Level	No of Consumers	Total Consumption (In MU)
1	Domestic	LT	415V	2488841	7403
2	Commercial	LT	415V	349682	1624
3	IP Sets	LT	415V	6128	20
4	Water Supply	LT	415V	3847	86
5	Public Lighting	LT	415V	7012	130
6	HT Water Supply	HT	11KV	77	142
7	HT Industrial	HT	11KV	163	178
8	Industrial (Small)	LT	415V	5191	283
9	HT Commercial	HT	11KV	1272	736
10	HT Commercial	EHV	33/66 KV	13	117
11	Applicable to Government Hospitals & Hospitals	LT	415V	19	28
12	HT Res. Apartments Applicable to all areas	LT	415V	200	180
15	Others-1 (Delhi Metro)	HT	33/66 KV	9	288
16	Others-2 (Delhi Airport)	HT	33/66 KV	1	26
17	Others-3 (if any , specify in remarks)	LT	415V	5936	245
	TOTAL			2868391	11486

8.10 Annexure 10: Field verification Data and Reports

The field inspection details are shown in the below table:

Table 51 Field inspection details

Date & Time	Activity	Description of work done/ key points identified
10/07/2023	Visit & sample data download for DTs	Sample data (Time-slot wise) downloaded & deliberations with BYPL officials

17/07/2023	Visit & sample data download for feeders	Sample data (Time-slot wise) downloaded & deliberations with BYPL officials
18/07/2023	Checking of consumer meter data	Discussion with BYPL Officials

8.11 Annexure 11: List of documents verified with each parameter

The documents verified are listed in the below table:

Table 52 List of documents verified with each parameter

Sr.No.	Parameter	Data Source/Documents verified	Remarks of Energy Auditor, if any	Response of Discom, if any
1	Time-slot wise DT data	Downloaded data of meter	Data analysed for DT loss level calculation	Discussions done with BYPL officials
2	Time-slot wise feeder data	Downloaded data of Feeder meter	Data analysed for feeder loading	Discussions done with BYPL officials

- Third Party audited Power Purchase Certificate (Attachment 5.0)
- Input energy at Discom Periphery verified by DTL Bill. (Attachment 8.0)
- Third Party audited Sale Certificate (Attachment 9.0)
- Third Party audited Subsidy Certificate (Attachment 10.0)

8.12 Annexure 13: List of Parameters arrived through calculation or formulae with list of documents as source of Data

Ideally, reduction of technical losses should be the parameter for evaluation of performance of Discom sector. However, the technical losses of the Discom are not available and it involves a Cumbersome process to calculate the technical losses, which varies based on various factors like loading pattern etc.

Now, only the T&D losses and AT&C losses are available as the performance parameter for achieving energy efficiency by DISCOMs

It was decided that out the two parameters, T&D loss parameter seems to be appropriate parameter which reflects energy saving to a greater extent as compared to AT&C losses

Table 53 Formulas used to derive the Parameters

Parameter	Formula	Data SOURCE
AT&C Losses	$(1 - (\text{Billing efficiency} * \text{collection efficiency})) * 100$	SAP data
T&D Losses	$(1 - (\text{Total Energy Billed} / \text{Total energy Input to the System})) * 100$	DTL bill & SAP data
Billing efficiency	Total unit billed / Total unit input	SAP data
Collection efficiency	Revenue Collected / Amount Billed	SAP data

8.13 Annexure 14: Details of attachment

Following (8.13.1 to 8.13.12) attached as attachment 12

8.13.1 General Information

8.13.2 Summary Sheet

8.13.3 Infrastructure Details

8.13.4 Details of Input Energy and Sales

8.13.5 Details of Input Energy

8.13.6 Details Of Received Sources

8.13.7 Details Of Consumer

8.13.8 Division Wise Loss

8.13.9 Details Of Feeder Wise Losses

8.13.10 Details Of Subsidy

8.13.11 DT Metering and AMR Status

8.13.12 DT Wise Loss Report

8.14 Attachment 1: Details of Energy audit Cell – Shared

8.15 Attachment 2: Drawing of outgoing feeder *(GIS to suggest name of feeder)*

8.16 Attachment 3: Sample Test certificate for 3 cases

8.17 Attachment 4: Form 3 FY 2022-23

8.18 Attachment 5: Power Purchase Certificate

8.19 Attachment 6: SLD East Zone

- 8.20 Attachment 7: SLD Central Zone**
- 8.21 Attachment 8: DTL Billing details**
- 8.22 Attachment 9: Balance Sheet (Sales) Notes**
- 8.23 Attachment 10: Subsidy certificate**
- 8.24 Attachment 11: Subsidy order**
- 8.25 Attachment 12 : BEE Formats (Annual Data)**
- 8.26 Attachment 13 & 14 :Images of DT & Feeder meters**
- 8.27 Attachment 15: Slot-wise details of DT & feeder meters.**
- 8.28 Attachment 16 : Consumer meter data**
- 8.29 Attachment 17 : Minutes of meeting**