



BSES Rajdhani Power Limited

BSES Bhawan, Nehru Place,
New Delhi - 110 019, India.
CIN : U40109DL2001PLC111527
GST : 07AAGCS3187H2Z3
Tel. : +91 11 4920 9999
Fax : +91 11 4920 7888
www.bsesdelhi.com

Date: 11th August, 2023

To,
Shri A. K. Jha,
Executive Officer
Energy Efficiency and Renewable Energy Management Centre.
2nd Floor, E Block, Vikas Bhavan-II
Near GPO Building, Civil Line,
New Delhi-110055

Sub: Submission of first quarter energy audit report of BSES Rajdhani Power Ltd for FY 2023 – 24.


Dear Sir,

This is with reference to submission of first quarter energy audit report of BSES Rajdhani Power Ltd for FY2023-24 as per Govt. of India Gazette Notification of Bureau of Energy Efficiency (Manner and Intervals for Conduct of Energy Audit (Accounting) in Electricity Distribution Companies) Regulations, 2021. As per the Gazette Notification **No. 18/1/BEE/DISCOM/2021**, every electricity distribution company shall conduct a periodic audit (quarterly) within 45 days of every subsequent quarter.

In this regard, first quarter Energy Report of BRPL has been prepared for FY 2023-24 and same is enclosed herewith.

Thanking You.

Yours Sincerely,


(Gopal Nariya)
Vice President
Head DSM and PAT Cell
BSES Rajdhani Power Ltd.
Mobile: 9312710510

CC:
Shri Milind Deore,
Director, Bureau of Energy Efficiency,
4th Floor, Sewa Bhawan, Sector-1, R.K. Puram, New Delhi-110066

Encl: First quarter Energy Audit Report of BRPL for FY 2023-24

S.No.	General Details	Description		
1	Name of the Unit	BSES Rajhdani Power Ltd.		
2	(i) Year of Establishment	2002		
	(ii) Government/Public/Private	Private		
3	Contact details & Address			
i	City/Town/Village	Nehru Place		
ii	District	Delhi-South		
iii	State	Delhi	Pin	110019
iv	Telephone		Fax	
4	Registered Office			
i	Company's Chief Executive Name	Sh. Vineet Sikka		
ii	Designation	CEO		
iii	Adress	2nd Floor, B Block, BSES Bhawan, Nehru Place, New Delhi		
iv	City/Town/Village	New Delhi	PO	Nehru Place
v	District	Delhi-South		
vi	State	Delhi	Pin	110019
vii	Telephone	1149209425	Fax	
5	Nodal Officer Details			
i	Nodal Officer Name (Designated at DISCOM's)	Gopal Nariya		
ii	Designation	VP		
iii	Adress	2nd Floor, D Block, BSES Bhawan, Nehru Place, New Delhi		
iv	City/Town/Village	New Delhi	PO	Nehru Place
v	District	Delhi-South		
vi	State	Delhi	Pin	110019
vii	Telephone	1149107327	Fax	
6	Energy Manager Details			
i	Name	Avinash Kumar		
ii	Designation	Ass. VP	Whether EA or EM	EA
iii	EA/EM Registration No.	EA-6550		
iv	Telephone		Fax	
v	Mobile	9346259327	Email Id	avinash.c.kumar@relianceada.com
7	Period of Information			
	Year of (FY) information including Date and Month (Start & End)	1st Apr, 23 – 30th June, 23		

Performance Summary of Electricity Distribution Company

1	Period of Information Year of (FY) information including Date and Month (Start & End)	1st Apr, 23 – 30th June, 23	
2	Technical Details		
(a)	Energy Input Details		
(i)	Input Energy Purchase (From Generation Source)	Million kwh	3988
(ii)	Net input energy (at DISCOM Periphery after adjusting the transmission losses and energy traded)	Million kwh	3819
(iii)	Total Energy billed (is the Net energy billed, adjusted for energy traded))	Million kwh	3240
(b)	Transmission and Distribution (T&D) loss Details	Million kwh	579
		%	15.17%
	Collection Efficiency	%	80.94%
(c)	Aggregate Technical & Commercial Loss	%	31.33%

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal		Signature:-	
		Name of Energy Manager:	Avinash Kumar
Name of Authorised Signatory	Gopal Nariya	Registration Number:	EA-6550
Name of the DISCOM	BSES Rajdhani Power limited		
Full Address:- 2nd Floor D - Block, BSES Bhawan, Nehru Place, Delhi-South, Delhi-110019			
Seal			

Performance Summary of Electricity Distribution Company

1	Period of Information Year of (FY) information including Date and Month (Start & End)	1st Apr, 23 – 30th June, 23	
2	Technical Details		
(a)	Energy Input Details		
(i)	Input Energy Purchase (From Generation Source)	Million kwh	3988
(ii)	Net input energy (at DISCOM Periphery after adjusting the transmission losses and energy traded)	Million kwh	3819
(iii)	Total Energy billed (is the Net energy billed, adjusted for energy traded))	Million kwh	3240
(b)	Transmission and Distribution (T&D) loss Details	Million kwh	579
		%	15.17%
	Collection Efficiency	%	80.94%
(c)	Aggregate Technical & Commercial Loss	%	31.33%

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal		Signature:-	
		Name of Energy Manager:	Avinash Kumar
Name of Authorised Signatory	Gopal Nariya	Registration Number:	EA-6550
Name of the DISCOM	BSES Rajdhani Power limited		
Full Address:- 2nd Floor D - Block, BSES Bhawan, Nehru Place, Delhi-South, Delhi-110019			
Seal	VI - Automation Head-SCADA, DMS, Smart Meter & Asset Management Emp. No. 41016354 BSES Rajdhani Power Limited A Joint Venture with Govt of NCT Delhi		

Form-Details of Input Infrastructure					
1	Parameters	Total	Covered during in audit	Verified by Auditor in Sample Check	Remarks (Source of data)
i	Number of circles	8	Apr-23-June-2023	Verified	Annual Report
ii	Number of divisions	22	Apr-23-June-2023	Verified	Annual Report
iii	Number of sub-divisions	91	Apr-23-June-2023	Verified	Annual Report
iv	Number of feeders	39,344	Apr-23-June-2023	Verified	Including HT and LT feeders
v	Number of DTs	9,609	Apr-23-June-2023	Verified	Excluding HVDS and less than 25KVA DTs
vi	Number of consumers	30,14,967	Apr-23-June-2023	Verified	Form 2.1 A
2	Parameters	66 KV and above	33 KV	11/22 KV	LT
a. i.	Number of conventional metered consumers				29,85,093
ii	Number of consumers with 'smart' meters				8,450
iii	Number of consumers with 'smart prepaid' meters				7,928
iv	Number of consumers with 'AMR' meters	12	11	1,526	11,947
v	Number of consumers with 'non-smart prepaid' meters	-	-	-	-
vi	Number of unmetered consumers	-	-	-	-
vii	Number of total consumers	12	11	1,526	30,13,418
b.i.	Number of conventionally metered Distribution Transformers	-	-	-	5,866
ii	Number of DTs with communicable meters	16	17	0	3743
iii	Number of unmetered PTR/DTs	146	95	-	-
iv	Number of total Transformers	162	112	-	9609
c.i.	Number of metered feeders	-	-	-	325
ii	Number of feeders with communicable meters	117	150	1690	-
iii	Number of unmetered feeders	-	-	-	37,062

iv	Number of total feeders	117	150	1690	37,387
d.	Line length (ct km)	24,259			
e.	Length of Aerial Bunched Cables	9167			
f.	Length of Underground Cables	12417			
3	Voltage level	Particulars	MU	Reference	Remarks (Source of data)
i	66KV /33KV/11KV	Long-Term Conventional	2,488	Includes input energy for	
		Medium Conventional			
		Short Term Conventional	277		
		Banking	240		
		Long-Term Renewable energy	717		
		Medium and Short-Term RE	645	Includes power from bilateral/ PX/ DEEP	
		Captive, open access input	129	Any power wheeled for any purchase other than sale to DISCOM. Does not include input for franchisee.	
		Sale of surplus power	407		
		Quantum of inter-state transmission loss	169	As confirmed by SLDC, RLDC etc	
		Power procured from inter-state sources	3960	Based on data from Form 5	
Power at state transmission boundary	3,791				

ii	33KV	Long-Term Conventional		
		Medium Conventional		
		Short Term Conventional		
		Banking		
		Long-Term Renewable energy		
		Medium and Short-Term RE		
		Captive, open access input		
		Sale of surplus power		
		Quantum of intra-state transmission loss	0	
		Power procured from intra-state sources	0	
iii		Input in DISCOM wires network	3,791	
iv	33KV	Renewable Energy Procurement		
		Small capacity conventional/ biomass/ hydro plants Procurement	17	
		Captive, open access input		
v	11 KV	Renewable Energy Procurement	3.0	
		Small capacity conventional/ biomass/ hydro plants Procurement		
		Sales Migration Input		
vi	LT	Renewable Energy Procurement	8.1	
		Sales Migration Input		
vii		Energy Embedded within DISCOM wires network	28.0	
viii		Total Energy Available/ Input	3,819	

Power Purchase Accounting

4	Voltage level	Energy Sales Particulars	MU	Reference	
i	LT Level	DISCOM' consumers	2,684	Include sales to consumers in franchisee areas, unmetered consumers	Billing Data
		Demand from open access, captive		Non DISCOM's sales	
		Embedded generation used at LT level	8.14	Demand from embedded generation at LT level	Monthly RTS Generation Report
		Sale at LT level	2,684		Billing Data
		Quantum of LT level losses	458		Calculated
		Energy Input at LT level	3,142		Energy Audit Report
ii	11 kV Level	DISCOM' consumers	3,578	Include sales to consumers in franchisee areas, unmetered consumers	HT Consumers and input for Distribution Transformer HT consumer sale:436.08 Mus
		Demand from open access, captive	13	Non DISCOM's sales	DTL Billing data
		Embedded generation at 11 kV level used	3.0	Demand from embedded generation at 11kV level	Monthly RTS Generation Report
		Sales at 11 kV level	3,578		Billing Data
		Quantum of Losses at 11 kV	112		Calculated
		Energy input at 11 kV level	3,690		Energy Audit Report
iii	33 kV and 66 KV Level	DISCOM' consumers	3,804	Include sales to consumers in franchisee areas, unmetered consumers	Sale at EHV level (66/33 KV level) and input for PTR EHV Level sale: 119.72 Mus
		Demand from open access, captive	116	Non DISCOM's sales	Including sale to other Discoms
		Embedded generation at 33 kV or below level	17	This is DISCOM and OA demand met via energy generated at same voltage level	Monthly RTS Generation Report
		Sales at >33 kV level	3,804		Sale at EHV level (66/33 KV level) and input for PTR EHV Level sale: 119.72Mus
		Quantum of Losses at 33 kV and 66 KV	14		
		Energy input at 33 kV and 66 KV	3819		

iv	> 66 kV	DISCOM' consumers		Include sales to consumers in franchisee areas, unmetered consumers	
		Demand from open access, captive		Non DISCOM's sales	
		Cross border sale of energy			
		Sale to other DISCOMs	407		DTL Billing data
		Banking			
		Energy input at > 33kV Level			
		Sales at 66kV and above (EHV)			
Total Energy Requirement			3819		
Total Energy Sales			3240		
Energy Accounting Summary					
5	DISCOM	Input (in MU)	Sale (in MU)	Loss (in MU)	Loss %
i	LT	3142	2684	458	14.59%
ii	11 Kv	3690	3578	112	3.04%
iii	33 kv and 66 KV	3819	3804	14	0.38%
iv	> 66 kv				
6	Open Access, Captive	Input (in MU)	Sale (in MU)	Loss (in MU)	
i	LT	-	-	-	BRPL is only maintaining the sale details for Open Acces quantity
ii	11 Kv	-	13	-	
iii	33 kv	-		-	
iv	> 33 kv		116		
Loss Estimation for DISCOM					
	T&D loss	579			
	D loss	579			
	T&D loss (%)	15.2%			
	D loss (%)	15.2%			

Details of Division Wise Losses
Sector-Electricity Distribution Companies

Division Wise Losses																							
Period From Apr-23- Jun-23																							
S.No.	Name of circle	Circle code	Name of Division	Consumer profile								Energy parameters					Losses		Commercial Parameter			AT & C loss (%)	
				Consumer category	No of connection metered (Nos)	No of connection Un-metered (Nos)	Total Number of connections (Nos)	% of number of connections	Connected Load metered (MW)	Connected Load Un-metered (MW)	Total Connected Load (MW)	% of connected load	Input energy (MU)	Billed energy (MU)			% of energy consumption	T&D loss (MU)	T&D loss (%)	Billed Amount in Rs. Crore	Collected Amount in Rs. Crore		Collection Efficiency
														Metered energy	Unmetered /assessment energy	Total energy							
1	SOUTH-3	S-3	ALAKNANDA	Residential	107340	0	107340	84%	347	0	347	64%	175	87	0	87	58%	25	14.34%	54	43	80.27%	30.14%
				Agricultural	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0		
				Commercial/Industrial-LT	19845	0	19845	15%	152	0	152	28%		45	0	45	30%			62	54	86.86%	
				Commercial/Industrial-HT	61	0	61	0%	31	0	31	6%		11	0	11	7%			14	10	76.43%	
				Others	900	0	900	1%	12	0	12	2%		6	0	6	4%			7	4	54.99%	
Sub-total				128146	0	128146	100%	543	0	543	100%	175	150	0	150	100%	25	14.34%	137	111	82%	30.14%	
2	SOUTH-1	S-1	KHANPUR	Residential	202694	0	202694	90%	346	0	346	81%	176	117	0	117	80%	30	17.0%	55	45	82.96%	32.93%
				Agricultural	4	0	4	0%	0	0	0	0%		0	0	0	0%			0	0	99.45%	
				Commercial/Industrial-LT	20742	0	20742	9%	56	0	56	13%		16	0	16	11%			21	18	84.62%	
				Commercial/Industrial-HT	18	0	18	0%	17	0	17	4%		6	0	6	4%			7	7	89.09%	
				Others	971	0	971	0%	10	0	10	2%		7	0	7	5%			7	3	46.31%	
Sub-total				224429	0	224429	100%	429	0	429	100%	176	146	0	146	100%	30	17.0%	90	73	81%	32.93%	
3	SOUTH-4	S-4	SAKET	Residential	192541	0	192541	89%	570	0	570	68%	325	161	0	161	60%	55	16.9%	99	79	79.85%	33.28%
				Agricultural	656	0	656	0%	5	0	5	1%		1	0	1	0%			0	0	85.60%	
				Commercial/Industrial-LT	22209	0	22209	10%	146	0	146	17%		45	0	45	17%			60	52	85.59%	
				Commercial/Industrial-HT	101	0	101	0.0%	79	0	79	9.4%		40	0	40	15%			47	39	82.98%	
				Others	1533	0	1533	1%	43	0	43	5%		23	0	23	8%			23	14	62.99%	
Sub-total				217040	0	217040	100%	842	0	842	100%	325	270	0	270	100%	55	16.9%	229	184	80%	33.28%	
4	SOUTH-4	S-4	VASANTKUNJ	Residential	129441	0	129441	88%	382	0	382	55%	273	114	0	114	48%	37	13.4%	69	56	80.50%	30.19%
				Agricultural	511	0	511	0%	4	0	4	1%		1	0	1	1%			1	0	83.56%	
				Commercial/Industrial-LT	15315	0	15315	10%	111	0	111	16%		41	0	41	17%			53	46	86.74%	
				Commercial/Industrial-HT	133	0	133	0%	121	0	121	17%		57	0	57	24%			66	59	90.13%	
				Others	1089	0	1089	1%	79	0	79	11%		23	0	23	10%			24	10	40.89%	
Sub-total				146489	0	146489	100%	696	0	696	100%	273	236	0	236	100%	37	13.4%	212	171	81%	30.19%	
5	SOUTH-2	S-2	NEHRU PLACE	Residential	53109	0	53109	74%	232	0	232	46%	167	61	0	61	40%	15	9.0%	42	34	78.99%	25.32%
				Agricultural	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0		
				Commercial/Industrial-LT	18198	0	18198	25%	187	0	187	37%		52	0	52	34%			73	62	84.45%	
				Commercial/Industrial-HT	95	0	95	0%	59	0	59	12%		25	0	25	17%			30	23	78.16%	
				Others	644	0	644	1%	23	0	23	5%		14	0	14	9%			13	11	87.62%	
Sub-total				72046	0	72046	100%	500	0	500	100%	167	152	0	152	100%	15	9.0%	159	130	82%	25.32%	

6	SOUTH-2	S-2	NIZAMUDDIN	Residential	88506	0	88506	81%	312	0	312	57%	187	83	0	83	51%	26	13.9%	53	42	80.07%	26.73%
				Agricultural	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0		
				Commercial/ Industrial-LT	20598	0	20598	19%	132	0	132	24%		35	0	35	21%			48	43	88.55%	
				Commercial/ Industrial-HT	81	0	81	0%	90	0	90	16%		35	0	35	22%			43	43	100.00%	
				Others	650	0	650	1%	14	0	14	3%		9	0	9	6%			11	4	36.99%	
Sub-total					109835	0	109835	100%	548	0	548	100%	187	161	0	161	100%	26	13.9%	155	132	85%	26.73%
7	SOUTH-1	S-1	SARITA VIHAR	Residential	141415	0	141415	90%	247	0	247	68%	157	91	0	91	68%	23	14.3%	44	36	81.51%	32.08%
				Agricultural	18	0	18	0%	0	0	0	0%		0	0	0	0%			0	0	88.91%	
				Commercial/ Industrial-LT	14504	0	14504	9%	59	0	59	16%		20	0	20	15%			26	21	83.11%	
				Commercial/ Industrial-HT	75	0	75	0%	31	0	31	9%		11	0	11	8%			14	11	79.87%	
				Others	829	0	829	1%	24	0	24	7%		13	0	13	10%			13	8	62.92%	
Sub-total					156841	0	156841	100%	360	0	360	100%	157	135	0	135	100%	23	14.3%	97	77	79%	32.08%
8	SOUTH-1	S-1	NEW FRIENDS COLONY	Residential	113749	0	113749	89%	301	0	301	71%	178	96	0	96	66%	33	18.6%	58	46	79.27%	36.10%
				Agricultural	4	0	4	0%	0	0	0	0%		0	0	0	0%			0	0	92.99%	
				Commercial/ Industrial-LT	13240	0	13240	10%	52	0	52	12%		17	0	17	11%			21	18	86.03%	
				Commercial/ Industrial-HT	63	0	63	0%	53	0	53	13%		20	0	20	14%			24	19	78.28%	
				Others	552	0	552	0%	15	0	15	4%		12	0	12	8%			12	7	62.03%	
Sub-total					127608	0	127608	100%	422	0	422	100%	178	145	0	145	100%	33	18.6%	115	90	79%	36.10%
9	SOUTH-3	S-3	R K PURAM	Residential	63153	0	63153	87%	229	0	229	62%	129	58	0	58	51%	16	12.5%	41	34	83.28%	28.09%
				Agricultural	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0		
				Commercial/ Industrial-LT	8418	0	8418	12%	56	0	56	15%		16	0	16	14%			22	18	84.84%	
				Commercial/ Industrial-HT	60	0	60	0%	50	0	50	13%		19	0	19	17%			24	21	87.38%	
				Others	695	0	695	1%	37	0	37	10%		20	0	20	18%			18	13	69.68%	
Sub-total					72326	0	72326	100%	372	0	372	100%	129	112	0	112	100%	16	12.5%	104	86	82%	28.09%
10	SOUTH-3	S-3	HAUZ KHAS	Residential	66995	0	66995	84%	340	0	340	64%	167	78	0	78	53%	21	12.6%	57	45	78.95%	30.79%
				Agricultural	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0		
				Commercial/ Industrial-LT	11911	0	11911	15%	102	0	102	19%		29	0	29	20%			40	34	84.08%	
				Commercial/ Industrial-HT	94	0	94	0%	77	0	77	15%		35	0	35	24%			43	33	77.81%	
				Others	535	0	535	1%	10	0	10	2%		4	0	4	3%			5	2	51.73%	
Sub-total					79535	0	79535	100%	530	0	530	100%	167	146	0	146	100%	21	12.6%	145	115	79%	30.79%
11	WEST-1	W-1	JANAKPURI	Residential	130057	0	130057	81%	404	0	404	61%	245	121	0	121	56%	29	11.9%	73	57	77.09%	28.97%
				Agricultural	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0		
				Commercial/ Industrial-LT	29248	0	29248	18%	183	0	183	28%		59	0	59	27%			79	69	87.29%	
				Commercial/ Industrial-HT	70	0	70	0%	35	0	35	5%		17	0	17	8%			20	17	82.51%	
				Others	882	0	882	1%	43	0	43	6%		19	0	19	9%			17	11	63.20%	
Sub-total					160257	0	160257	100%	666	0	666	100%	245	216	0	216	100%	29	11.9%	190	153	81%	28.97%
12	WEST-4	W-4	NAJAFGARH	Residential	163935	0	163935	89%	302	0	302	70%	177	98	0	98	73%	42	24.0%	47	39	83.54%	38.31%
				Agricultural	2488	0	2488	1%	13	0	13	3%		2	0	2	1%			1	1	94.51%	
				Commercial/ Industrial-LT	16581	0	16581	9%	66	0	66	15%		23	0	23	17%			30	25	85.01%	
				Commercial/ Industrial-HT	27	0	27	0%	42	0	42	10%		1	0	1	1%			2	7	418.80%	
				Others	879	0	879	0%	11	0	11	2%		11	0	11	8%			13	3	23.63%	
Sub-total					183910	0	183910	100%	434	0	434	100%	177	134	0	134	100%	42	24.0%	93	75	81%	38.31%

13	WEST-4	W-4	JAFFARPUR	Residential	49217	0	49217	90%	92	0	92	74%	59	28	0	28	72%	21	34.9%	13	12	87.52%	47.05%
				Agricultural	2416	0	2416	4%	11	0	11	9%		1	0	1	2%			1	1	103.83%	
				Commercial/ Industrial-LT	2887	0	2887	5%	9	0	9	8%		3	0	3	8%			4	3	85.90%	
				Commercial/ Industrial-HT	11	0	11	0%	4	0	4	3%		2	0	2	4%			2	1	69.51%	
				Others	424	0	424	1%	9	0	9	7%		5	0	5	13%			3	2	54.56%	
Sub-total					54955	0	54955	100%	124	0	124	100%	59	38	0	38	100%	21	34.9%	24	19	81%	47.05%
14	WEST-2	W-2	NANGLOI	Residential	151192	0	151192	88%	298	0	298	65%	205	107	0	107	59%	24	11.5%	55	43	78.55%	26.83%
				Agricultural	49	0	49	0%	0	0	0	0%		0	0	0	0%			0	0	75.52%	
				Commercial/ Industrial-LT	20677	0	20677	12%	122	0	122	27%		48	0	48	26%			61	52	85.94%	
				Commercial/ Industrial-HT	69	0	69	0%	26	0	26	6%		20	0	20	11%			22	19	85.30%	
				Others	675	0	675	0%	10	0	10	2%		6	0	6	3%			6	5	78.12%	
Sub-total					172662	0	172662	100%	457	0	457	100%	205	181	0	181	100%	24	11.5%	144	119	83%	26.83%
15	WEST-3	W-3	MUNDKA	Residential	81428	0	81428	83%	138	0	138	49%	135	49	0	49	45%	27	20.1%	23	19	83.96%	32.55%
				Agricultural	150	0	150	0%	1	0	1	0%		0	0	0	0%			0	0	98.70%	
				Commercial/ Industrial-LT	16422	0	16422	17%	119	0	119	42%		46	0	46	42%			60	53	89.29%	
				Commercial/ Industrial-HT	34	0	34	0%	9	0	9	3%		6	0	6	5%			6	6	86.80%	
				Others	376	0	376	0%	16	0	16	6%		7	0	7	7%			8	3	45.04%	
Sub-total					98410	0	98410	100%	283	0	283	100%	135	108	0	108	100%	27	20.1%	97	82	84%	32.55%
16	WEST-2	W-2	PUNJABI BAGH	Residential	82322	0	82322	85%	285	0	285	74%	140	86	0	86	70%	18	13.2%	55	43	78.52%	31.53%
				Agricultural	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0		
				Commercial/ Industrial-LT	13957	0	13957	14%	71	0	71	18%		21	0	21	17%			28	25	87.33%	
				Commercial/ Industrial-HT	42	0	42	0%	19	0	19	5%		10	0	10	8%			11	9	83.78%	
				Others	440	0	440	0%	8	0	8	2%		5	0	5	4%			6	2	32.29%	
Sub-total					96761	0	96761	100%	382	0	382	100%	140	122	0	122	100%	18	13.2%	100	79	79%	31.53%
17	WEST-3	W-3	TAGORE GARDEN	Residential	141174	0	141174	86%	298	0	298	72%	182	103	0	103	72%	40	22.2%	53	41	77.54%	37.39%
				Agricultural	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0		
				Commercial/ Industrial-LT	23315	0	23315	14%	91	0	91	22%		27	0	27	19%			35	31	86.57%	
				Commercial/ Industrial-HT	17	0	17	0%	19	0	19	4%		7	0	7	5%			8	7	83.90%	
				Others	449	0	449	0%	9	0	9	2%		6	0	6	4%			5	3	64.50%	
Sub-total					164955	0	164955	100%	417	0	417	100%	182	142	0	142	100%	40	22.2%	102	82	80%	37.39%
18	WEST-2	W-2	VIKASPURI	Residential	114703	0	114703	89%	237	0	237	78%	127	82	0	82	74%	16	12.3%	43	34	78.37%	29.03%
				Agricultural	8	0	8	0%	0	0	0	0%		0	0	0	0%			0	0	91.76%	
				Commercial/ Industrial-LT	13794	0	13794	11%	48	0	48	16%		15	0	15	14%			20	17	86.14%	
				Commercial/ Industrial-HT	15	0	15	0%	11	0	11	4%		7	0	7	7%			8	8	95.50%	
				Others	420	0	420	0%	10	0	10	3%		7	0	7	6%			6	4	62.25%	
Sub-total					128940	0	128940	100%	306	0	306	100%	127	111	0	111	100%	16	12.3%	77	62	81%	29.03%
19	WEST-2	W-2	UTTAM NAGAR	Residential	88518	0	88518	88%	175	0	175	82%	87	61	0	61	82%	12	14.1%	30	24	79.73%	30.81%
				Agricultural	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0		
				Commercial/ Industrial-LT	12152	0	12152	12%	35	0	35	16%		11	0	11	15%			14	12	85.17%	
				Commercial/ Industrial-HT	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0		
				Others	283	0	283	0%	3	0	3	1%		2	0	2	2%			1	1	50.04%	
Sub-total					100953	0	100953	100%	213	0	213	100%	87	74	0	74	100%	12	14.1%	46	37	81%	30.81%

20	WEST-2	W-2	MOHAN GARDEN	Residential	112730	0	112730	91%	198	0	198	87%	96	70	0	70	86%	14	15.0%	33	27	81.90%	30.40%
				Agricultural	2	0	2	0%	0	0	0%	0		0	0	0%	0			0	105.88%		
				Commercial/Industrial-LT	10354	0	10354	8%	27	0	27	12%		9	0	9	11%			12	10	87.89%	
				Commercial/Industrial-HT	1	0	1	0%	0	0	0	0%		0	0	0	0%			0	0		
				Others	200	0	200	0%	2	0	2	1%		2	0	2	2%			1	0	31.87%	
Sub-total					123287	0	123287	100%	227	0	227	100%	96	81	0	81	100%	14	15.0%	47	38	82%	30.40%
21	WEST-1	W-1	PALAM	Residential	207140	0	207140	90%	466	0	466	83%	218	150	0	150	81%	32	14.8%	77	64	82.57%	32.23%
				Agricultural	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0		
				Commercial/Industrial-LT	22313	0	22313	10%	71	0	71	13%		23	0	23	12%			30	25	84.35%	
				Commercial/Industrial-HT	36	0	36	0%	19	0	19	3%		6	0	6	3%			7	5	75.83%	
				Others	700	0	700	0%	7	0	7	1%		7	0	7	4%			7	2	27.36%	
Sub-total					230189	0	230189	100%	564	0	564	100%	218	186	0	186	100%	32	14.8%	121	96	80%	32%
22	WEST-1	W-1	DWARKA	Residential	147762	0	147762	89%	407	0	407	73%	216	133	0	133	69%	23	10.5%	76	59	78.17%	29%
				Agricultural	2	0	2	0%	0	0	0%	0		0	0	0%	0			0	97.66%		
				Commercial/Industrial-LT	16862	0	16862	10%	66	0	66	12%		19	0	19	10%			26	21	83.99%	
				Commercial/Industrial-HT	73	0	73	0%	53	0	53	9%		22	0	22	12%			27	23	84.93%	
				Others	694	0	694	0%	35	0	35	6%		19	0	19	10%			18	12	67.80%	
Sub-total					165393	0	165393	100%	560	0	560	100%	216	194	0	194	100%	23	10.5%	146	116	79%	29%
23	Total		BRPL	Residential	2629121	0	2629121	87%	6607	0	6607	67%	3818.96	2033	0	2033	63%	579	15.2%	1151	922	80%	6.45%
				Agricultural	6308	0	6308	0%	34	0	34	0%		5	0	5	0%			3	3	93%	
				Commercial/Industrial-LT	363542	0	363542	12%	1961	0	1961	20%		619	0	619	19%			825	711	86%	
				Commercial/Industrial-HT	1176	0	1176	0%	847	0	847	9%		356	0	356	11%			424	366	86%	
				Others	14820	0	14820	0%	428	0	428	4%		226	0	226	7%			226	126	56%	
24	At company level			3014967	0	3014967	100%	9876	0	9876	100%	3819	3240	0	3240	100%	579	15.2%	2628	2127	80.94%	31.33%	

**** Note - It shall be mandatory to record the energy supplied separately for each category of consumers which is being provided a separate rate of subsidy in the tariff, by the state government, so that the subsidy due for the electricity distribution company is quarterly calculated by multiplying the energy supplied to each of such category of by the applicable rate of subsidy notified by the state government.**

Subsidy Details is mentioned in subsidy details sheet.

	Please enter name of circle	
	Please enter circle code	
0	Please enter numeric value or 0	
	Formula protected	

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal	
Name of the Authorised Signatory	GOPAL NARIYA
Name of the DISCOM:	BSES RAJDHANI POWER LTD
Full Address	2nd Floor, C Block, BSES Bhawan, Nehru Place, New Delhi - 110019
Seal	



Signature:-	
Name of Energy Manager:	Avinash Kumar
Registration Number:	EA - 6550

20	WEST-2	W-2	MOHAN GARDEN	Residential	112730	0	112730	91%	198	0	198	87%	96	70	0	70	86%	14	15.0%	33	27	81.90%	30.40%
				Agricultural	2	0	2	0%	0	0	0	0%		0	0	0	0%			0	0	105.88%	
				Commercial/Industrial-LT	10354	0	10354	8%	27	0	27	12%		9	0	9	11%			12	10	87.89%	
				Commercial/Industrial-HT	1	0	1	0%	0	0	0	0%		0	0	0	0%			0	0		
				Others	200	0	200	0%	2	0	2	1%		2	0	2	2%			1	0	31.87%	
				Sub-total				123287	0	123287	100%	227		0	227	100%	96			81	0	81	
21	WEST-1	W-1	PALAM	Residential	207140	0	207140	90%	466	0	466	83%	218	150	0	150	81%	32	14.8%	77	64	82.57%	32.23%
				Agricultural	0	0	0	0%	0	0	0	0%		0	0	0	0%			0	0		
				Commercial/Industrial-LT	22313	0	22313	10%	71	0	71	13%		23	0	23	12%			30	25	84.35%	
				Commercial/Industrial-HT	36	0	36	0%	19	0	19	3%		6	0	6	3%			7	5	75.83%	
				Others	700	0	700	0%	7	0	7	1%		7	0	7	4%			7	2	27.36%	
				Sub-total				230189	0	230189	100%	564		0	564	100%	218			186	0	186	
22	WEST-1	W-1	DWARKA	Residential	147762	0	147762	89%	407	0	407	73%	216	133	0	133	69%	23	10.5%	76	59	78.17%	29%
				Agricultural	2	0	2	0%	0	0	0	0%		0	0	0	0%			0	0	97.66%	
				Commercial/Industrial-LT	16862	0	16862	10%	66	0	66	12%		19	0	19	10%			26	21	83.99%	
				Commercial/Industrial-HT	73	0	73	0%	53	0	53	9%		22	0	22	12%			27	23	84.93%	
				Others	694	0	694	0%	35	0	35	6%		19	0	19	10%			18	12	67.80%	
				Sub-total				165393	0	165393	100%	560		0	560	100%	216			194	0	194	
23	Total	BRPL	Residential	2629121	0	2629121	87%	6607	0	6607	67%	3818.96	2033	0	2033	63%	579	15.2%	1151	922	80%	6.45%	
			Agricultural	6308	0	6308	0%	34	0	34	0%		5	0	5	0%			3	3	93%		
			Commercial/Industrial-LT	363542	0	363542	12%	1961	0	1961	20%		619	0	619	19%			825	711	86%		
			Commercial/Industrial-HT	1176	0	1176	0%	847	0	847	9%		356	0	356	11%			424	366	86%		
			Others	14820	0	14820	0%	428	0	428	4%		226	0	226	7%			226	126	56%		
			Sub-total				165393	0	165393	100%	560		0	560	100%	216			194	0	194		100%
24	At company level			3014967	0	3014967	100%	9876	0	9876	100%	3819	3240	0	3240	100%	579	15.2%	2628	2127	80.94%	31.33%	


** Note - It shall be mandatory to record the energy supplied separately for each category of consumers which is being provided a separate rate of subsidy in the tariff, by the state government, so that the subsidy due for the electricity distribution company is quarterly calculated by multiplying the energy supplied to each of such category of by the applicable rate of subsidy notified by the state government. Subsidy Details is mentioned in subsidy details sheet.

Please enter name of circle	
Please enter circle code	
0 Please enter numeric value or 0	
Formula protected	

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal	
Name of the Authorised Signatory	GOPAL NARIYA
Name of the DISCOM:	BSES RAJDHANI POWER LTD
Full Address	2nd Floor, C Block, BSES Bhawan, Nehru Place, New Delhi - 110019
Seal	

Gopal Nariya
VP - Automation
Head SCADA, DMS, Smart
Meter & Asset Management
Emp. No. 41016354
BSES Rajdhani Power Limited
A Joint Venture with Govt of NCT Delhi

Signature:-	
Name of Energy Manager:	Avinash Kumar
Registration Number:	EA - 6550

Form-Input energy(Details of Input energy & Infrastructure)

A. Summary of energy input & Infrastructure

S.No	Parameters	Period From 1st April to 30th June-2023	Remarks (Source of data)
A.1	Input Energy purchased (MU)	3988	Power Purchase
A.2	Transmission loss (%)	4.24%	
A.3	Transmission loss (MU)	169	
A.4	Energy sold outside the periphery(MU)	145	Energy Accounting
A.5	Open access sale (MU)	129	Energy Accounting
A.6	EHT sale	120	Energy Accounting
A.7	Net input energy (received at DISCOM periphery or at distribution point)-(MU)	3819	
A.8	Is 100% metering available at 66/33 kV (Select yes or no from list)	Yes	Energy Accounting
A.9	Is 100% metering available at 11 kV (Select yes or no from list)	Yes	Energy Accounting
A.10	% of metering available at DT	100%	Energy Accounting
A.11	% of metering available at consumer end	100%	Energy Accounting
A.12	No of feeders at 66kV voltage level	117	Technical Service Report
A.13	No of feeders at 33kV voltage level	150	Technical Service Report
A.14	No of feeders at 11kV voltage level	1690	Technical Service Report
A.15	No of LT feeders level	37387	Technical Service Report
A.16	Line length (ckt. km) at 66kV voltage level	582	Technical Service Report
A.17	Line length (ckt. km) at 33kV voltage level	724	Technical Service Report
A.18	Line length (ckt. km) at 11kV voltage level	8723	Technical Service Report
A.19	Line length (km) at LT level	14230	Technical Service Report
A.20	Length of Aerial Bunched Cables	9167	Technical Service Report
A.21	Length of Underground Cables	12417	Technical Service Report
A.22	HT/LT ratio	0.61	Technical Service Report

B. Meter reading of input energy at injection points

S.No	Zone	Circle*	Voltage Level (KV)	Division*	Sub-Division* (KV)	Feeder ID	Feeder Name	Feeder Metering Status (Metered/unmetered/AMI/AMR)	Status of Meter (Functional/ Non-functional)	Metering Date (Date of last actual meter reading/ communication)	Feeder Type (Agri/ Industrial/ Mixed)	Status of Communication**			Period From 1st April to 30th June-2023				Sales	Remarks (Source of data)
												% data received through automatically if feeder AMR/AMI	Number of hours when meter was unable to communicate in period	Total Number of hours in the period	Meter S.No	CT/PT ratio	Import (MU)	Export (MU)		
B.1	South	South-1 / South-2	33KV	NZD/NFC/ NHP	KILOKARI,LAJPAT NAGAR IV,LAJPAT NAGAR-2,LODHI ROAD,OKHLA,OKHLA IND AREA PH-2 & PH-3,JUNG PURA,KALINDI COLONY,GK 1,DEFENCE COLONY,ABUL FAZAL	4865170	IP STATION BAY-24	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865170	160/300	17.79	0.00	0.0	<p>Source: DTL Billing Data</p> <p>Remarks:</p> <p>Type of feeders:</p> <ul style="list-style-type: none"> Some feeders are used for auxiliary supply of Grid station hence it is proposed to add Auxiliary supply feeders as type of feeders. <p>Status of communication:</p> <ul style="list-style-type: none"> Delhi Transco Limited (DTL) is the custodian of the input energy meters and responsibility for installing AMR is with DTL. Please note that AMR are not installed as on date on interface meters and neither real time meter data will be shared with us for generating this report. Incoming feeders from DTL are connected to the BRPL grid as incomers. The supply is distributed From BRPL grid to multiple circles, divisions and sub divisions.
B.2	South	South-1 / South-2	33KV	NZD/NFC/ NHP	KILOKARI,LAJPAT NAGAR IV,LAJPAT NAGAR-2,LODHI ROAD,OKHLA,OKHLA IND AREA PH-2 & PH-3,JUNG PURA,KALINDI COLONY,GK 1,DEFENCE COLONY,ABUL FAZAL	4864887	IP STATION BAY-25	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864887	800/300	22.53	0.00	0.0	
B.3	South	South-1 / South-2	33KV	NZD/NFC/ NHP	KILOKARI,LAJPAT NAGAR IV,LAJPAT NAGAR-2,LODHI ROAD,OKHLA,OKHLA IND AREA PH-2 & PH-3,JUNG PURA,KALINDI COLONY,GK 1,DEFENCE COLONY,ABUL FAZAL	4864799	IP STATION BAY-13	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864799	800/300	11.86	0.00	0.0	
B.4	South	South-1 / South-2	33KV	NZD/NFC/ NHP	KILOKARI,LAJPAT NAGAR IV,LAJPAT NAGAR-2,LODHI ROAD,OKHLA,OKHLA IND AREA PH-2 & PH-3,JUNG PURA,KALINDI COLONY,GK 1,DEFENCE COLONY,ABUL FAZAL	4865127	IP STATION BAY-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865127	800/300	18.97	0.00	0.0	
B.5	South	South-1 / South-2	33KV	NZD/NFC/ NHP	KILOKARI,LAJPAT NAGAR IV,LAJPAT NAGAR-2,LODHI ROAD,OKHLA,OKHLA IND AREA PH-2 & PH-3,JUNG PURA,KALINDI COLONY,GK 1,DEFENCE COLONY,ABUL FAZAL	4865177	IP STATION BAY-3	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865177	240/300	21.09	0.00	0.0	
B.6	South	South-1 / South-2	33KV	NZD/NFC/ NHP	KILOKARI,LAJPAT NAGAR IV,LAJPAT NAGAR-2,LODHI ROAD,OKHLA,OKHLA IND AREA PH-2 & PH-3,JUNG PURA,KALINDI COLONY,GK 1,DEFENCE COLONY,ABUL FAZAL	4865111	IP STATION BAY-7	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865111	60/300	0.04	0.00	0.0	
B.7	South	South-1 / South-2	33KV	NZD/NFC/ NHP	KILOKARI,LAJPAT NAGAR IV,LAJPAT NAGAR-2,LODHI ROAD,OKHLA,OKHLA IND AREA PH-2 & PH-3,JUNG PURA,KALINDI COLONY,GK 1,DEFENCE COLONY,ABUL FAZAL	4865160	IP STATION BAY-37	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865160	60/300	24.49	0.00	0.0	

B.8	South	South-1 / South-2	33KV	NZD/NFC/ NHP	KILOKARI,LAJPAT NAGAR IV,LAJPAT NAGAR-2,LODHI ROAD,OKHLA,OKHLA IND AREA PH-2 & PH-3,JUNG PURA,KALINDI COLONY,GK 1,DEFENCE COLONY,ABUL FAZAL	4865157	IP STATION BAY-9	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865157	60/300	8.24	0.00	0.0
B.9	South	South-1 / South-2	33KV	NZD/NFC/ NHP	KILOKARI,LAJPAT NAGAR IV,LAJPAT NAGAR-2,LODHI ROAD,OKHLA,OKHLA IND AREA PH-2 & PH-3,JUNG PURA,KALINDI COLONY,GK 1,DEFENCE COLONY,ABUL FAZAL	4865179	IP STATION BAY-5 LAJPAT NGR.	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865179	160/300	16.97	0.00	0.0
B.10	South	South-1 / South-2	11KV	NZD/NFC/ NHP	KILOKARI,LAJPAT NAGAR IV,LAJPAT NAGAR-2,LODHI ROAD,OKHLA,OKHLA IND AREA PH-2 & PH-3,JUNG PURA,KALINDI COLONY,GK 1,DEFENCE COLONY,ABUL FAZAL	4902602	I.P.Ext. Local Tx-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902602	6/100		0.02	0.0
B.11	West	West-1 / West-2 / West-3	33KV	JKP/PBG/ TGN	B1 COMPLAINT CENTER JANAKPURI,B-32 MAYAPURI PH-1,C-3 COMPLAINT CENTER JKP,D2 COMPLAINT CENTER JKP,MUKHARJI PARK,ROAD NO-41 PUNJABI BAGH,B 3 PASCHIM VIHAR,B BLK KARAMPURA,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4865155	ROHTAK ROAD SBM-1/DLF MALL	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865155	400/300	9.15	0.00	0.0
B.12	West	West-1 / West-2 / West-3	33KV	JKP/PBG/ TGN	B1 COMPLAINT CENTER JANAKPURI,B-32 MAYAPURI PH-1,C-3 COMPLAINT CENTER JKP,D2 COMPLAINT CENTER JKP,MUKHARJI PARK,ROAD NO-41 PUNJABI BAGH,B 3 PASCHIM VIHAR,B BLK KARAMPURA,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4864794	ROHTAK ROAD SB MILL	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864794	400/300	7.55	0.00	0.0
B.13	West	West-1 / West-2 / West-3	33KV	JKP/PBG/ TGN	B1 COMPLAINT CENTER JANAKPURI,B-32 MAYAPURI PH-1,C-3 COMPLAINT CENTER JKP,D2 COMPLAINT CENTER JKP,MUKHARJI PARK,ROAD NO-41 PUNJABI BAGH,B 3 PASCHIM VIHAR,B BLK KARAMPURA,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4865100	ROHTAK ROAD VISHAL	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865100	500/300	14.06	0.00	0.0
B.14	West	West-1 / West-2 / West-3	33KV	JKP/PBG/ TGN	B1 COMPLAINT CENTER JANAKPURI,B-32 MAYAPURI PH-1,C-3 COMPLAINT CENTER JKP,D2 COMPLAINT CENTER JKP,MUKHARJI PARK,ROAD NO-41 PUNJABI BAGH,B 3 PASCHIM VIHAR,B BLK KARAMPURA,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4864863	ROHTAK ROAD MADIPUR	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864863	750/300	14.80	0.00	0.0

B.15	West	West-1 / West-2 / West-3	33KV	JKP/PBG/ TGN	B1 COMPLAINT CENTER JANAKPURI,B-32 MAYAPURI PH-1,C- 3 COMPLAINT CENTER JKP,D2 COMPLAINT CENTER JKP,MUKHARJI PARK,ROAD NO-41 PUNJABI BAGH,B 3 PASCHIM VIHAR,B BLK KARAMPURA,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	5252046	20 MVA TX.-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5252046	800/300	8.05	0.00	0.0
B.16	West	West-1 / West-2 / West-3	33KV	JKP/PBG/ TGN	B1 COMPLAINT CENTER JANAKPURI,B-32 MAYAPURI PH-1,C- 3 COMPLAINT CENTER JKP,D2 COMPLAINT CENTER JKP,MUKHARJI PARK,ROAD NO-41 PUNJABI BAGH,B 3 PASCHIM VIHAR,B BLK KARAMPURA,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4864851	20 MVA TX.-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864851	400/300	9.66	0.00	0.0
B.17	West	West-1 / West-2 / West-3	33KV	JKP/PBG/ TGN	B1 COMPLAINT CENTER JANAKPURI,B-32 MAYAPURI PH-1,C- 3 COMPLAINT CENTER JKP,D2 COMPLAINT CENTER JKP,MUKHARJI PARK,ROAD NO-41 PUNJABI BAGH,B 3 PASCHIM VIHAR,B BLK KARAMPURA,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4865149	SUDARSHAN PARK (VISHAL)	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865149	150/300		0.04	0.0
B.18	West	West-2 / West-3	66KV	NGL/MDK	DSIDC MUNDKA,GH-9 PASCHIM VIHAR,NANGLOI,swarn park Mundka,TIKRI,UDYOG NAGAR,BAPROLLA	4864971	Mundka-MGP T OFF NGL Ckt-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864971	800/600	0.00	0.00	0.0
B.19	West	West-2 / West-3	66KV	NGL/MDK	DSIDC MUNDKA,GH-9 PASCHIM VIHAR,NANGLOI,swarn park Mundka,TIKRI,UDYOG NAGAR,BAPROLLA	Y035782	MANGOLPURI NANGLOI-II	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	Y035782	800/600	0.00	0.00	0.0
B.20	West	West-1 / West-2 / West-4	66KV	DWK/VKP/ MGN/UGN/NJ F/PLM	SEC 4, DWARKA,SEC-9 DWK,SEWAK PARK,SHYAM VIHAR,VIPIN GARDEN,MILAP NAGAR,SEC 13, DWARKA,MATIYALA,MANGLA PURI,MAHIPAL PUR,MADHU VIHAR,KAPASHERA,KAILASHPURI,JH ATIKARA MORE,DELHI GATE,DAULATPUR,DABRI,D-4 VKJ,CHHAWLA,CHANAKYA PLACE,C- 9 VASANT KUNJ,BINDAPUR,ANAJMANDI,ANAN D VIHAR,B-1 VKJ.,BHARTAL,BIJWASAN	5128438	PAPPANKALAN-II TX.-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5128438	1000/600	88.71	0.00	0.0

B.21	West	West-1 / West-2 / West-4	66KV	DWK/VKP/ MGN/UGN/NJ/ F/PLM	SEC 4, DWARKA,SEC-9 DWK,SEWAK PARK,SHYAM VIHAR,VIPIN GARDEN,MILAP NAGAR,SEC 13, DWARKA,MATIYALA,MANGLA PURI,MAHIPAL PUR,MADHU VIHAR,KAPASHERA,KAILASHPURI,JH ATIKARA MORE,DELHI GATE,DAULATPUR,DABRI,D-4 VKJ,CHHAWLA,CHANAKYA PLACE,C- 9 VASANT KUNJ,BINDAPUR,ANAJMANDI,ANAN D VIHAR,B-1 VKJ.,BHARTAL,BIJWASAN	5295164	PAPPANKALAN-II TX-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5295164	1000/600	48.24	0.00	0.0
B.22	West	West-1 / West-2 / West-4	11KV	DWK/VKP/M GN/UGN/NJ/ PLM	SEC 4, DWARKA,SEC-9 DWK,SEWAK PARK,SHYAM VIHAR,VIPIN GARDEN,MILAP NAGAR,SEC 13, DWARKA,MATIYALA,MANGLA PURI,MAHIPAL PUR,MADHU VIHAR,KAPASHERA,KAILASHPURI,JH ATIKARA MORE,DELHI GATE,DAULATPUR,DABRI,D-4 VKJ,CHHAWLA,CHANAKYA PLACE,C- 9 VASANT KUNJ,BINDAPUR,ANAJMANDI,ANAN D VIHAR,B-1 VKJ.,BHARTAL,BIJWASAN	4902601	PPK-II. Local Tx- 1(630kva)	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902601	15/100		0.08	0.1
B.23	West	West-1 / West-2 / West-4	66KV	DWK/VKP/ MGN/UGN/NJ/ F/PLM	SEC 4, DWARKA,SEC-9 DWK,SEWAK PARK,SHYAM VIHAR,VIPIN GARDEN,MILAP NAGAR,SEC 13, DWARKA,MATIYALA,MANGLA PURI,MAHIPAL PUR,MADHU VIHAR,KAPASHERA,KAILASHPURI,JH ATIKARA MORE,DELHI GATE,DAULATPUR,DABRI,D-4 VKJ,CHHAWLA,CHANAKYA PLACE,C- 9 VASANT KUNJ,BINDAPUR,ANAJMANDI,ANAN D VIHAR,B-1 VKJ.,BHARTAL,BIJWASAN	4864988	PPK-2 66KV- I/C- 3	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864988	2000/600	78.98	0.00	0.0
B.24	West	West-1 / West-2 / West-4	66KV	DWK/VKP/ MGN/UGN/ NJ/PLM	SEC 4, DWARKA,SEC-9 DWK,SEWAK PARK,SHYAM VIHAR,VIPIN GARDEN,MILAP NAGAR,SEC 13, DWARKA, MATIYALA, MANGLA PURI,MAHIPAL PUR,MADHU VIHAR, KAPASHERA,KAILASHPURI,JHATIKAR A MORE,DELHI GATE, DAULATPUR, DABRI,D-4 VKJ, CHHAWLA, CHANAKYA PLACE,C-9 VASANT KUNJ, BINDAPUR, ANAJMANDI,ANAND VIHAR,B-1 VKJ., BHARTAL, BIJWASAN	4864938	PPK-2 66KV- I/C- 4	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864938	2000/600	144.06	0.00	0.0

B.25	West	West-1 / West-2 / West-3 / West-4	66KV	PLM/DWK/U GN/NJF/ JKP/TGN/ VKP	MUKHARJI PARK,SEC 13, DWARKA,SEC 4, DWARKA,SEC-9 DWK,SHIV VIHAR ,SHYAM VIHAR,MATIYALA,MILAP NAGAR,MANGLA PURI,MADHU VIHAR,LIG-2 HASTSAL,KAILASHPURI,JHATIKARA MORE,DELHI GATE,DAULATPUR,DABRI,D2 COMPLAINT CENTER JKP,CHHAWLA,CHANAKYA PLACE,C- 3 COMPLAINT CENTER JKP,C BLOCK VKP,BINDAPUR,BHARTAL,4/1 SUBHASH NAGAR,A-BLK TAGORE GARDEN,ANAJMANDI,B1 COMPLAINT CENTER JANAKPURI,B- 32 MAYAPURI PH-1,24 BLK Tilak nagar	4864786	PAPPANKALAN TX.-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864786	1000/600	69.97	0.00	0.0
B.26	West	West-1 / West-2 / West-3 / West-4	66KV	PLM/DWK/U GN/NJF/ JKP/TGN/ VKP	MUKHARJI PARK,SEC 13, DWARKA,SEC 4, DWARKA,SEC-9 DWK,SHIV VIHAR ,SHYAM VIHAR,MATIYALA,MILAP NAGAR,MANGLA PURI,MADHU VIHAR,LIG-2 HASTSAL,KAILASHPURI,JHATIKARA MORE,DELHI GATE,DAULATPUR,DABRI,D2 COMPLAINT CENTER JKP,CHHAWLA,CHANAKYA PLACE,C- 3 COMPLAINT CENTER JKP,C BLOCK VKP,BINDAPUR,BHARTAL,4/1 SUBHASH NAGAR,A-BLK TAGORE GARDEN,ANAJMANDI,B1 COMPLAINT CENTER JANAKPURI,B- 32 MAYAPURI PH-1,24 BLK Tilak nagar	4865025	PAPPANKALAN TX.-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865025	1000/600	72.67	0.00	0.0
B.27	West	West-1 / West-2 / West-3 / West-4	66KV	PLM/DWK/U GN/NJF/ JKP/TGN/ VKP	MUKHARJI PARK,SEC 13, DWARKA,SEC 4, DWARKA,SEC-9 DWK,SHIV VIHAR ,SHYAM VIHAR,MATIYALA,MILAP NAGAR,MANGLA PURI,MADHU VIHAR,LIG-2 HASTSAL,KAILASHPURI,JHATIKARA MORE,DELHI GATE,DAULATPUR,DABRI,D2 COMPLAINT CENTER JKP,CHHAWLA,CHANAKYA PLACE,C- 3 COMPLAINT CENTER JKP,C BLOCK VKP,BINDAPUR,BHARTAL,4/1 SUBHASH NAGAR,A-BLK TAGORE GARDEN,ANAJMANDI,B1 COMPLAINT CENTER JANAKPURI,B- 32 MAYAPURI PH-1,24 BLK Tilak nagar	5128433	PAPPANKALAN TX.-3	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5128433	2000/600	122.50	0.00	0.0

B.28	West	West-1 / West-2 / West-3 / West-4	66KV	PLM/DWK/U GN/NJF/ JKP/TGN/ VKP	MUKHARJI PARK,SEC 13, DWARKA,SEC 4, DWARKA,SEC-9 DWK,SHIV VIHAR ,SHYAM VIHAR,MATIYALA,MILAP NAGAR,MANGLA PURI,MADHU VIHAR,LIG-2 HASTSAL,KAILASHPURI,JHATIKARA MORE,DELHI GATE,DAULATPUR,DABRI,D2 COMPLAINT CENTER JKP,CHHAWLA,CHANAKYA PLACE,C- 3 COMPLAINT CENTER JKP,C BLOCK VKP,BINDAPUR,BHARTAL,4/1 SUBHASH NAGAR,A-BLK TAGORE GARDEN,ANAJMANDI,B1 COMPLAINT CENTER JANAKPURI,B- 32 MAYAPURI PH-1,24 BLK Tilak nagar	4902499	PAPPANKALAN TX.-4	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902499	1000/600	0.00	0.00	0.0
B.29	West	West-1 / West-2 / West-3 / West-4	66kV	PLM/DWK/U GN/NJF/ JKP/TGN/ VKP	MUKHARJI PARK,SEC 13, DWARKA,SEC 4, DWARKA,SEC-9 DWK,SHIV VIHAR ,SHYAM VIHAR,MATIYALA,MILAP NAGAR,MANGLA PURI,MADHU VIHAR,LIG-2 HASTSAL,KAILASHPURI,JHATIKARA MORE,DELHI GATE,DAULATPUR,DABRI,D2 COMPLAINT CENTER JKP,CHHAWLA,CHANAKYA PLACE,C- 3 COMPLAINT CENTER JKP,C BLOCK VKP,BINDAPUR,BHARTAL,4/1 SUBHASH NAGAR,A-BLK TAGORE GARDEN,ANAJMANDI,B1 COMPLAINT CENTER JANAKPURI,B- 32 MAYAPURI PH-1,24 BLK Tilak nagar	5128464	PAPPANKALAN-1 TX.-5	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5128464	2000/600	114.90	0.00	0.0
B.30	West	West-1 / West-2 / West-3 / West-4	11KV	PLM/DWK/U GN/NJF/ JKP/TGN/ VKP	MUKHARJI PARK,SEC 13, DWARKA,SEC 4, DWARKA,SEC-9 DWK,SHIV VIHAR ,SHYAM VIHAR,MATIYALA,MILAP NAGAR,MANGLA PURI,MADHU VIHAR,LIG-2 HASTSAL,KAILASHPURI,JHATIKARA MORE,DELHI GATE,DAULATPUR,DABRI,D2 COMPLAINT CENTER JKP,CHHAWLA,CHANAKYA PLACE,C- 3 COMPLAINT CENTER JKP,C BLOCK VKP,BINDAPUR,BHARTAL,4/1 SUBHASH NAGAR,A-BLK TAGORE GARDEN,ANAJMANDI,B1 COMPLAINT CENTER JANAKPURI,B- 32 MAYAPURI PH-1,24 BLK Tilak nagar	4902554	PPK-I Local Tx-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902554	6/100	0.10	0.1	

B.31	West	West-1 / West-2 / West-3 / West-4	11KV	PLM/DWK/ GN/NJF/ JKP/TGN/ VKP	MUKHARJI PARK,SEC 13, DWARKA,SEC 4, DWARKA,SEC-9 DWK,SHIV VIHAR ,SHYAM VIHAR,MATIYALA,MILAP NAGAR,MANGLA PURI,MADHU VIHAR,LIG-2 HASTSAL,KAILASHPURI,JHATIKARA MORE,DELHI GATE,DAULATPUR,DABRI,D2 COMPLAINT CENTER JKP,CHHAWLA,CHANAKYA PLACE,C- 3 COMPLAINT CENTER JKP,C BLOCK VKP,BINDAPUR,BHARTAL,4/1 SUBHASH NAGAR,A-BLK TAGORE GARDEN,ANAJMANDI,B1 COMPLAINT CENTER JANAKPURI,B- 32 MAYAPURI PH-1,24 BLK Tilak nagar	5295192	PPK-1 Local Tx-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5295192	6/100	0.00	0.00	0.0
B.32	West	West-1 / West-2 / West-4	66KV	NJF/PLM/DW K/NGL/ PBG/VKP	SHIV VIHAR ,SHYAM VIHAR,UDYOG NAGAR,SEC 4, DWARKA,SEC-9 DWK,SEC 13, DWARKA,ROAD NO-41 PUNJABI BAGH,NANGLOI,MATIYALA,MANGL A PURI,MADHU VIHAR,LIG-2 HASTSAL,KAILASHPURI,JHATIKARA MORE,GH-9 PASCHIM VIHAR,DELHI GATE,DAULATPUR,DABRI,CHHAWLA ,C BLOCK VKP,ANAJMANDI,B 3 PASCHIM VIHAR,B BLK KARAMPURA,BAPROLLA,BHARTAL	4864912	PPK -3 66KV I/C 1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864912	1600/600	124.52	0.00	0.0
B.33	West	West-1 / West-2 / West-4	66KV	NJF/PLM/DW K/NGL/ PBG/VKP	SHIV VIHAR ,SHYAM VIHAR,UDYOG NAGAR,SEC 4, DWARKA,SEC-9 DWK,SEC 13, DWARKA,ROAD NO-41 PUNJABI BAGH,NANGLOI,MATIYALA,MANGL A PURI,MADHU VIHAR,LIG-2 HASTSAL,KAILASHPURI,JHATIKARA MORE,GH-9 PASCHIM VIHAR,DELHI GATE,DAULATPUR,DABRI,CHHAWLA ,C BLOCK VKP,ANAJMANDI,B 3 PASCHIM VIHAR,B BLK KARAMPURA,BAPROLLA,BHARTAL	5128459	PPK -3 66KV I/C 2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5128459	1600/600	124.99	0.00	0.0

B.34	South	South-1 / South-2 / South-3 / South-4	66KV	NHP/NFC/ ALN/KPR/ SKT	MMTC,OKHLA,OKHLA IND AREA PH-2 & PH-3,OKHLA PHASE 1,PUL PRAHLADPUR,MALVIYA NAGAR,MIG DDA FLAT SAKET,LAJPAT NAGAR IV,KHANPUR,KALINDI COLONY,JAUNAPUR,GK 2,GK 1,G BLOCK KALKA JI,FATEHPUR BERI,DURGA VIHAR,DDA FLAT KALKAJI,D-BLOCK SANGAM VIHAR,CHATARPUR,AYA NAGAR,ABUL FAZAL	5128411	OKHLA TX.-1 (66KV)	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5128411	2000/600	120.33	0.00	0.0
B.35	South	South-1 / South-2 / South-3 / South-4	66KV	NHP/NFC/ ALN/KPR/ SKT	MMTC,OKHLA,OKHLA IND AREA PH-2 & PH-3,OKHLA PHASE 1,PUL PRAHLADPUR,MALVIYA NAGAR,MIG DDA FLAT SAKET,LAJPAT NAGAR IV,KHANPUR,KALINDI COLONY,JAUNAPUR,GK 2,GK 1,G BLOCK KALKA JI,FATEHPUR BERI,DURGA VIHAR,DDA FLAT KALKAJI,D-BLOCK SANGAM VIHAR,CHATARPUR,AYA NAGAR,ABUL FAZAL	4864947	OKHLA TX.- 2 (66KV)	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864947	1000/600	72.33	0.00	0.0
B.36	South	South-1 / South-2 / South-3 / South-4	33KV	NHP/NFC/ ALN/KPR/ SKT	MMTC,OKHLA,OKHLA IND AREA PH-2 & PH-3,OKHLA PHASE 1,PUL PRAHLADPUR,MALVIYA NAGAR,MIG DDA FLAT SAKET,LAJPAT NAGAR IV,KHANPUR,KALINDI COLONY,JAUNAPUR,GK 2,GK 1,G BLOCK KALKA JI,FATEHPUR BERI,DURGA VIHAR,DDA FLAT KALKAJI,D-BLOCK SANGAM VIHAR,CHATARPUR,AYA NAGAR,ABUL FAZAL	4864890	OKHLA TX.- 1 (33KV)	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864890	2000/300		0.00	0.0
B.37	South	South-1 / South-2 / South-3 / South-4	33KV	NHP/NFC/ ALN/KPR/ SKT	MMTC,OKHLA,OKHLA IND AREA PH-2 & PH-3,OKHLA PHASE 1,PUL PRAHLADPUR,MALVIYA NAGAR,MIG DDA FLAT SAKET,LAJPAT NAGAR IV,KHANPUR,KALINDI COLONY,JAUNAPUR,GK 2,GK 1,G BLOCK KALKA JI,FATEHPUR BERI,DURGA VIHAR,DDA FLAT KALKAJI,D-BLOCK SANGAM VIHAR,CHATARPUR,AYA NAGAR,ABUL FAZAL	4864933	OKHLA TX.- 5 (33KV)	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864933	2000/300	69.92	0.00	0.0

B.38	South	South-1 / South-2 / South-3 / South-4	33KV	NHP/NFC/ ALN/KPR/ SKT	MMTC,OKHLA,OKHLA IND AREA PH-2 & PH-3,OKHLA PHASE 1,PUL PRAHLADPUR,MALVIYA NAGAR,MIG DDA FLAT SAKET,LAJPAT NAGAR IV,KHANPUR,KALINDI COLONY,JAUNAPUR,GK 2,GK 1,G BLOCK KALKA JI,FATEHPUR BERI,DURGA VIHAR,DDA FLAT KALKAJI,D-BLOCK SANGAM VIHAR,CHATARPUR,AYA NAGAR,ABUL FAZAL	4864904	OKHLA TX.- 3 (33KV)	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864904	2000/300	50.90	0.00	0.0
B.39	South	South-1 / South-2 / South-3 / South-4	33KV	NHP/NFC/ALN /KPR/SKT	MMTC,OKHLA,OKHLA IND AREA PH-2 & PH-3,OKHLA PHASE 1,PUL PRAHLADPUR,MALVIYA NAGAR,MIG DDA FLAT SAKET,LAJPAT NAGAR IV,KHANPUR,KALINDI COLONY,JAUNAPUR,GK 2,GK 1,G BLOCK KALKA JI,FATEHPUR BERI,DURGA VIHAR,DDA FLAT KALKAJI,D-BLOCK SANGAM VIHAR,CHATARPUR,AYA NAGAR,ABUL FAZAL	4864942	OKHLA TX.- 4 (33KV)	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864942	2000/300	51.02	0.00	0.0
B.40	South	South-1 / South-2 / South-3 / South-4	11KV	NHP/NFC/ALN /KPR/SKT	MMTC,OKHLA,OKHLA IND AREA PH-2 & PH-3,OKHLA PHASE 1,PUL PRAHLADPUR,MALVIYA NAGAR,MIG DDA FLAT SAKET,LAJPAT NAGAR IV,KHANPUR,KALINDI COLONY,JAUNAPUR,GK 2,GK 1,G BLOCK KALKA JI,FATEHPUR BERI,DURGA VIHAR,DDA FLAT KALKAJI,D-BLOCK SANGAM VIHAR,CHATARPUR,AYA NAGAR,ABUL FAZAL	4902600	Okhla. Local Tx-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902600	80/100		0.05	0.0
B.41	West	West-2 / West-3 / West-4	11KV	NJF/NGL/MD K/JFP/TGN/VK P/ MGN	SHYAM VIHAR,swarn park Mundka,TIKRI,UDYOG NAGAR,UJWA,VIPIN GARDEN,SEWAK PARK,SHIV VIHAR ,NANGLOI,MUNDHELA,MUKHARJI PARK,MITRAON,LIG-2 HASTSAL,JHATIKARA MORE,GHUMANHERA,GH-9 PASCHIM VIHAR,DSIDC MUNDKA,DHANSA,DELHI GATE,DAULATPUR,CRPF,CHHAWLA, C BLOCK VKP,A-BLK TAGORE GARDEN,ANAJMANDI,ANAND VIHAR,BAPROLLA,BHARTAL,24 BLK Tilak nagar	4902592	Najafgarh Local Tx-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902592	80/100		0.12	0.1

B.42	West	West-2 / West-3 / West-4	11KV	NJF/NGL/ MDK/JFP/ TGN/VKP/ MGN	SHYAM VIHAR,swarn park Mundka,TIKRI,UDYOG NAGAR,UJWA,VIPIN GARDEN,SEWAK PARK,SHIV VIHAR ,NANGLOI,MUNDHELA,MUKHARJI PARK,MITRAON,LIG-2 HASTSAL,JHATIKARA MORE,GHUMANHERA,GH-9 PASCHIM VIHAR,DSIDC MUNDKA,DHANSA,DELHI GATE,DAULATPUR,CRPF,CHHAWLA, C BLOCK VKP,A-BLK TAGORE GARDEN,ANAJMANDI,ANAND VIHAR,BAPROLA,BHARTAL,24 BLK Tilak nagar	4902569	Najafgarh Local Tx-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902569	80/100		0.01	0.0
B.43	West	West-2 / West-3 / West-4	66KV	NJF/NGL/ MDK/JFP/ TGN/VKP/ MGN	SHYAM VIHAR,swarn park Mundka,TIKRI,UDYOG NAGAR,UJWA,VIPIN GARDEN,SEWAK PARK,SHIV VIHAR ,NANGLOI,MUNDHELA,MUKHARJI PARK,MITRAON,LIG-2 HASTSAL,JHATIKARA MORE,GHUMANHERA,GH-9 PASCHIM VIHAR,DSIDC MUNDKA,DHANSA,DELHI GATE,DAULATPUR,CRPF,CHHAWLA, C BLOCK VKP,A-BLK TAGORE GARDEN,ANAJMANDI,ANAND VIHAR,BAPROLA,BHARTAL,24 BLK Tilak nagar	4864867	NAJAFGARH TX.- 1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864867	1000/600	91.91	0.00	0.0
B.44	West	West-2 / West-3 / West-4	66KV	NJF/NGL/ MDK/JFP/ TGN/VKP/ MGN	SHYAM VIHAR,swarn park Mundka,TIKRI,UDYOG NAGAR,UJWA,VIPIN GARDEN,SEWAK PARK,SHIV VIHAR ,NANGLOI,MUNDHELA,MUKHARJI PARK,MITRAON,LIG-2 HASTSAL,JHATIKARA MORE,GHUMANHERA,GH-9 PASCHIM VIHAR,DSIDC MUNDKA,DHANSA,DELHI GATE,DAULATPUR,CRPF,CHHAWLA, C BLOCK VKP,A-BLK TAGORE GARDEN,ANAJMANDI,ANAND VIHAR,BAPROLA,BHARTAL,24 BLK Tilak nagar	4865036	NAJAFGARH TX.- 2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865036	2000/600	159.49	0.00	0.0

B.45	West	West-2 / West-3 / West-4	66KV	NJF/NGL/ MDK/JFP/ TGN/VKP/ MGN	SHYAM VIHAR,swarn park Mundka,TIKRI,UDYOG NAGAR,UJWA,VIPIN GARDEN,SEWAK PARK,SHIV VIHAR ,NANGLOI,MUNDHELA,MUKHARJI PARK,MITRAON,LIG-2 HASTSAL,JHATIKARA MORE,GHUMANHERA,GH-9 PASCHIM VIHAR,DSIDC MUNDKA,DHANSA,DELHI GATE,DAULATPUR,CRPF,CHHAWLA, C BLOCK VKP,A-BLK TAGORE GARDEN,ANAJMANDI,ANAND VIHAR,BAPROLLA,BHARTAL,24 BLK Tilak nagar	5295147	NAJAFGARH TX.- 3	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5295147	2000/600	148.07	0.00	0.0
B.46	West	West-2 / West-3 / West-4	66KV	NJF/NGL/ MDK/JFP/ TGN/VKP/ MGN	SHYAM VIHAR,swarn park Mundka,TIKRI,UDYOG NAGAR,UJWA,VIPIN GARDEN,SEWAK PARK,SHIV VIHAR ,NANGLOI,MUNDHELA,MUKHARJI PARK,MITRAON,LIG-2 HASTSAL,JHATIKARA MORE,GHUMANHERA,GH-9 PASCHIM VIHAR,DSIDC MUNDKA,DHANSA,DELHI GATE,DAULATPUR,CRPF,CHHAWLA, C BLOCK VKP,A-BLK TAGORE GARDEN,ANAJMANDI,ANAND VIHAR, BAPROLLA, BHARTAL,24 BLK Tilak nagar	4864989	NAJAFGARH TX.- 4	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864989	1000/600	32.23	0.00	0.0
B.47	South	South-1 / South-4 / West-1 / West-4	66KV	SKT/VKJ/ KPR/NJF/ PLM	MANGLA PURI,MIG DDA FLAT SAKET,MMTC,PUL PRAHLADPUR,SEC-9 DWK,SHYAM VIHAR, MAHIPAL PUR, MALVIYA NAGAR,KHANPUR,KAPASHERA,KAIL ASHPURI,JHATIKARA MORE, JAUNAPUR, FATEHPUR BERI,DURGA VIHAR,DELHI GATE,D-BLOCK SANGAM VIHAR,DAULATPUR,DABRI,D-4 VKJ, CHHAWLA, CHATARPUR,C-9 VASANT KUNJ,ANAJMANDI,AYA NAGAR,B-1 VKJ.,BHARTAL,BIJWASAN	4865016	MEHRAULI TX.-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865016	1000/600	94.51	0.00	0.0

B.48	South	South-1 / South-4 / West-1 / West-4	66KV	SKT/VKJ/ KPR/NJF/ PLM	MANGLA PURI,MIG DDA FLAT SAKET,MMTC,PUL PRAHLADPUR,SEC-9 DWK,SHYAM VIHAR, MAHIPAL PUR, MALVIYA NAGAR,KHANPUR,KAPASHERA,KAIL ASHPURI,JHATIKARA MORE, JAUNAPUR, FATEHPUR BERI,DURGA VIHAR,DELHI GATE,D-BLOCK SANGAM VIHAR,DAULATPUR,DABRI,D-4 VKJ, CHHAWLA, CHATARPUR,C-9 VASANT KUNJ,ANAJMANDI,AYA NAGAR,B-1 VKJ.,BHARTAL,BIJWASAN	4864967	MEHRAULI TX.-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864806	1000/600	85.58	0.00	0.0
B.49	South	South-1 / South-4 / West-1 / West-4	66KV	SKT/VKJ/ KPR/NJF/ PLM	MANGLA PURI,MIG DDA FLAT SAKET,MMTC,PUL PRAHLADPUR,SEC-9 DWK,SHYAM VIHAR, MAHIPAL PUR, MALVIYA NAGAR,KHANPUR,KAPASHERA,KAIL ASHPURI,JHATIKARA MORE, JAUNAPUR, FATEHPUR BERI,DURGA VIHAR,DELHI GATE,D-BLOCK SANGAM VIHAR,DAULATPUR,DABRI,D-4 VKJ, CHHAWLA, CHATARPUR,C-9 VASANT KUNJ,ANAJMANDI,AYA NAGAR,B-1 VKJ.,BHARTAL,BIJWASAN	4864840	MEHRAULI TX.-3	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864840	1000/600	95.33	0.00	0.0
B.50	South	South-1 / South-4 / West-1 / West-4	66KV	SKT/VKJ/ KPR/NJF/ PLM	MANGLA PURI,MIG DDA FLAT SAKET,MMTC,PUL PRAHLADPUR,SEC-9 DWK,SHYAM VIHAR, MAHIPAL PUR, MALVIYA NAGAR,KHANPUR,KAPASHERA,KAIL ASHPURI,JHATIKARA MORE, JAUNAPUR, FATEHPUR BERI,DURGA VIHAR,DELHI GATE,D-BLOCK SANGAM VIHAR,DAULATPUR,DABRI,D-4 VKJ, CHHAWLA, CHATARPUR,C-9 VASANT KUNJ,ANAJMANDI,AYA NAGAR,B-1 VKJ.,BHARTAL,BIJWASAN	4865042	MEHRAULI 66KV I/C -TX.-4	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865042	2000/600	103.41	0.00	0.0

B.51	South	South-1 / South-4 / West-1 / West-4	11KV	SKT/VKJ/ KPR/NJF/ PLM	MANGLA PURI,MIG DDA FLAT SAKET,MMTC,PUL PRAHLADPUR,SEC-9 DWK,SHYAM VIHAR, MAHIPAL PUR, MALVIYA NAGAR,KHANPUR,KAPASHERA,KAIL ASHPURI,JHATIKARA MORE, JAUNAPUR, FATEHPUR BERI,DURGA VIHAR,DELHI GATE,D-BLOCK SANGAM VIHAR,DAULATPUR,DABRI,D-4 VKJ, CHHAWLA, CHATARPUR,C-9 VASANT KUNJ,ANAJMANDI,AYA NAGAR,B-1 VKJ.,BHARTAL,BIJWASAN	4902596	Mehrauli Local Tx-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902596	6/100	0.00	0.00	0.0
B.52	South	South-1 / South-4 / West-1 / West-4	11KV	SKT/VKJ/ KPR/NJF/ PLM	MANGLA PURI,MIG DDA FLAT SAKET,MMTC,PUL PRAHLADPUR,SEC-9 DWK,SHYAM VIHAR, MAHIPAL PUR, MALVIYA NAGAR,KHANPUR,KAPASHERA,KAIL ASHPURI,JHATIKARA MORE, JAUNAPUR, FATEHPUR BERI,DURGA VIHAR,DELHI GATE,D-BLOCK SANGAM VIHAR,DAULATPUR,DABRI,D-4 VKJ, CHHAWLA, CHATARPUR,C-9 VASANT KUNJ,ANAJMANDI,AYA NAGAR,B-1 VKJ.,BHARTAL,BIJWASAN	4902586	Mehrauli Local Tx-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902586	6/100	0.00	0.00	0.0
B.53	South	South-4	11KV	VKJ	B-1 VKJ.,BIJWASAN,C-9 VASANT KUNJ,D-4 VKJ,KAPASHERA,MAHIPAL PUR	4865079	Vasant Kunj. Local Tx-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865079	80/100		0.08	0.1
B.54	South	South-4	11KV	VKJ	B-1 VKJ.,BIJWASAN,C-9 VASANT KUNJ,D-4 VKJ,KAPASHERA,MAHIPAL PUR	4865084	Vasant Kunj. Local Tx-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865084	80/100		0.01	0.0
B.55	South	South-4	66KV	VKJ	B-1 VKJ.,BIJWASAN,C-9 VASANT KUNJ,D-4 VKJ,KAPASHERA,MAHIPAL PUR	4864920	VASANT KUNJ TX.-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864920	1000/600	26.63	0.00	0.0
B.56	South	South-4	66KV	VKJ	B-1 VKJ.,BIJWASAN,C-9 VASANT KUNJ,D-4 VKJ,KAPASHERA,MAHIPAL PUR	4865038	VASANT KUNJ TX.-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865038	1000/600	27.43	0.00	0.0
B.57	South	South-4	66KV	VKJ	B-1 VKJ.,BIJWASAN,C-9 VASANT KUNJ,D-4 VKJ,KAPASHERA,MAHIPAL PUR	5295165	VASANT KUNJ TX.-3	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5295165	2000/600	76.22	0.00	0.0
B.58	South	South-1	11KV	SVR/NFC	BADARPUR,KALINDI COLONY,KANCHAN KUNJ,OKHLA,SARITA VIHAR,SAURABH VIHAR,ABUL FAZAL	4902522	Sarita Vihar. Local Tx-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902522	6/100		0.06	0.1

B.59	South	South-1	66KV	SVR/NFC	BADARPUR,KALINDI COLONY,KANCHAN KUNJ,OKHLA,SARITA VIHAR,SAURABH VIHAR,ABUL FAZAL	4864966	SARITA VIHAR TX.-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864966	2000/600	124.11	0.00	0.0
B.60	South	South-1	66kV	SVR/NFC	BADARPUR,KALINDI COLONY,KANCHAN KUNJ,OKHLA,SARITA VIHAR,SAURABH VIHAR,ABUL FAZAL	4864932	SARITA VIHAR TX.-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864932	1000/600	38.92	0.00	0.0
B.61	South	South-1	66KV	SVR/NFC	BADARPUR,KALINDI COLONY,KANCHAN KUNJ,OKHLA,SARITA VIHAR,SAURABH VIHAR,ABUL FAZAL	4864999	SARITA VIHAR TX.-3	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864999	1000/600	40.11	0.00	0.0
B.62	South	South-1 / South-2 / South-3	11KV	NZD/NFC/ NHP/HKS	OKHLA IND AREA PH-2 & PH-3,RBI HAUZ KHAS,LODHI ROAD,OKHLA,LAJPAT NAGAR-2,LAJPAT NAGAR IV,KILOKARI,KATWARIA SARAI,KALINDI COLONY,JUNG PURA,GREEN PARK,GK 1,DEFENCE COLONY,ANDREWS GANJ POLICE COLONY,ABUL FAZAL	4902518	Lodhi Rd. (400 KVA) Local Tx-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902518	80/100		0.12	0.1
B.63	South	South-1 / South-2 / South-3	11KV	NZD/NFC/ NHP/HKS	OKHLA IND AREA PH-2 & PH-3,RBI HAUZ KHAS,LODHI ROAD,OKHLA,LAJPAT NAGAR-2,LAJPAT NAGAR IV,KILOKARI,KATWARIA SARAI,KALINDI COLONY,JUNG PURA,GREEN PARK,GK 1,DEFENCE COLONY,ANDREWS GANJ POLICE COLONY,ABUL FAZAL	5295194	Lodhi Rd. (100 KVA) Local Tx-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5295194	6/100		0.00	0.0
B.64	South	South-1 / South-2 / South-3	11KV	NZD/NFC/ NHP/HKS	OKHLA IND AREA PH-2 & PH-3,RBI HAUZ KHAS,LODHI ROAD,OKHLA,LAJPAT NAGAR-2,LAJPAT NAGAR IV,KILOKARI,KATWARIA SARAI,KALINDI COLONY,JUNG PURA,GREEN PARK,GK 1,DEFENCE COLONY,ANDREWS GANJ POLICE COLONY,ABUL FAZAL	4902580	LODHI ROAD SHAN NAGAR-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902580	80/100		3.05	3.1
B.65	South	South-1 / South-2 / South-3	11KV	NZD/NFC/ NHP/HKS	OKHLA IND AREA PH-2 & PH-3,RBI HAUZ KHAS,LODHI ROAD,OKHLA,LAJPAT NAGAR-2,LAJPAT NAGAR IV,KILOKARI,KATWARIA SARAI,KALINDI COLONY,JUNG PURA,GREEN PARK,GK 1,DEFENCE COLONY,ANDREWS GANJ POLICE COLONY,ABUL FAZAL	4902544	LODHI ROAD SHAN NAGAR-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902544	80/100		2.86	2.9

B.66	South	South-1 / South-2 / South-3	66KV	NZD/NFC/ NHP/HKS	OKHLA IND AREA PH-2 & PH-3,RBI HAUZ KHAS,LODHI ROAD,OKHLA,LAJPAT NAGAR-2,LAJPAT NAGAR IV,KILOKARI,KATWARIA SARAI,KALINDI COLONY,JUNG PURA, GREEN PARK,GK 1,DEFENCE COLONY,ANDREWS GANJ POLICE COLONY,ABUL FAZAL	5269210	LODHI ROAD TX.- 1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5269210	2000/300	0.00	0.00	0.0
B.67	South	South-1 / South-2 / South-3	66KV	NZD/NFC/ NHP/HKS	OKHLA IND AREA PH-2 & PH-3,RBI HAUZ KHAS,LODHI ROAD,OKHLA,LAJPAT NAGAR-2,LAJPAT NAGAR IV,KILOKARI,KATWARIA SARAI,KALINDI COLONY,JUNG PURA, GREEN PARK,GK 1,DEFENCE COLONY,ANDREWS GANJ POLICE COLONY,ABUL FAZAL	5269749	LODHI ROAD TX.- 2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5269749	2000/300	60.22	0.00	0.0
B.68	South	South-1 / South-2 / South-3	66KV	NZD/NFC/ NHP/HKS	OKHLA IND AREA PH-2 & PH-3,RBI HAUZ KHAS,LODHI ROAD,OKHLA,LAJPAT NAGAR-2,LAJPAT NAGAR IV,KILOKARI,KATWARIA SARAI,KALINDI COLONY,JUNG PURA, GREEN PARK,GK 1,DEFENCE COLONY,ANDREWS GANJ POLICE COLONY,ABUL FAZAL	4864945	LODHI ROAD TX.- 3	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864945	2000/300	72.71	0.00	0.0
B.69	South	South-1 / South-2 / South-3	33KV	NZD/NFC/ NHP/HKS	OKHLA IND AREA PH-2 & PH-3,RBI HAUZ KHAS,LODHI ROAD,OKHLA,LAJPAT NAGAR-2,LAJPAT NAGAR IV,KILOKARI,KATWARIA SARAI,KALINDI COLONY,JUNG PURA, GREEN PARK,GK 1,DEFENCE COLONY,ANDREWS GANJ POLICE COLONY,ABUL FAZAL	5269199	LODHI ROAD VIDYUT BHAWAN .	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5269199	400/300	0.00	0.00	0.0
B.70	West	West-1 / West-2 / West-3	11KV	JKP/PBG/ TGN	B1 COMPLAINT CENTER JANAKPURI,B-32 MAYAPURI PH-1,C-3 COMPLAINT CENTER JKP,D2 COMPLAINT CENTER JKP,MUKHARJI PARK,ROAD NO-41 PUNJABI BAGH,B 3 PASCHIM VIHAR,B BLK KARAMPURA,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4902541	VISHAL BALI NAGAR	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902541	80/100	0.00	0.00	0.0
B.71	West	West-1 / West-2 / West-3	11KV	JKP/PBG/ TGN	B1 COMPLAINT CENTER JANAKPURI,B-32 MAYAPURI PH-1,C-3 COMPLAINT CENTER JKP,D2 COMPLAINT CENTER JKP,MUKHARJI PARK,ROAD NO-41 PUNJABI BAGH,B 3 PASCHIM VIHAR,B BLK KARAMPURA,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4902539	VISHAL ESI HOSPITAL	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902539	80/100		1.82	1.8

B.72	West	West-1 / West-2 / West-3	11KV	JKP/PBG/TGN	B1 COMPLAINT CENTER JANAKPURI,B-32 MAYAPURI PH-1,C-3 COMPLAINT CENTER JKP,D2 COMPLAINT CENTER JKP,MUKHARJI PARK,ROAD NO-41 PUNJABI BAGH,B 3 PASCHIM VIHAR,B BLK KARAMPURA,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4902572	VISHAL RAMESH NAGAR-I	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902572	80/100	0.01	0.00	0.0
B.73	South	South-1 / South-2 / South-3	33kV	NHP/HKS/NZD/NFC	OKHLA IND AREA PH-2 & PH-3,RBI HAUZ KHAS,LODHI ROAD,OKHLA,LAJPAT NAGAR-2,LAJPAT NAGAR IV,KILOKARI,KATWARIA SARAI,KALINDI COLONY,JUNG PURA,GREEN PARK,GK 1,DEFENCE COLONY,ANDREWS GANJ POLICE COLONY,ABUL FAZAL	4865114	33KV SIRI FORT AT AIIMS	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865114	500/300	0.00	0.00	0.0
B.74	South	South-1 / South-2 / South-3	33KV	NHP/HKS/NZD/NFC	OKHLA IND AREA PH-2 & PH-3,RBI HAUZ KHAS,LODHI ROAD,OKHLA,LAJPAT NAGAR-2,LAJPAT NAGAR IV,KILOKARI,KATWARIA SARAI,KALINDI COLONY,JUNG PURA,GREEN PARK,GK 1,DEFENCE COLONY,ANDREWS GANJ POLICE COLONY,ABUL FAZAL	4902508	33KV RIDGE VALLEY CKT AT AIIMS	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902508	500/300		5.30	5.3
B.75	South	South-2	33KV	NZD	DEFENCE COLONY,JUNG PURA,KILOKARI,LAJPAT NAGAR-2,LODHI ROAD	4865151	TILAK MARG EXHB-II	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865151	400/300		5.19	5.2
B.76	South	South-3	33KV	RKP	MOTI BAGH,R.K. PURAM,VASANT VIHAR	4864850	I/C From R.Vally-Kidwai Ngr.	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864850	500/300		3.16	3.2
B.77	South	South-3	66KV	RKP	MOTI BAGH,R.K. PURAM,VASANT VIHAR	4864955	RIDGE VALLEY SPM-1 Babu Dham	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864955	800/600		8.73	8.7
B.78	South	South-3	66KV	RKP	MOTI BAGH,R.K. PURAM,VASANT VIHAR	4864820	RIDGE VALLEY SPM-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864820	800/300		13.33	13.3
B.79	South	South-3	66KV	RKP	MOTI BAGH,R.K. PURAM,VASANT VIHAR	4864811	RIDGE VALLEY NEHRU PARK	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864811	800/300		10.25	10.2
B.80	South	South-3	66KV	RKP	MOTI BAGH,R.K. PURAM,VASANT VIHAR	4864961	R.Vally State Guest House	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864961	800/600		15.41	15.4
B.81	South	South-3	66KV	RKP	MOTI BAGH,R.K. PURAM,VASANT VIHAR	4864994	Ridge Vally-66KV RLY Ckt	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864994	800/600		23.42	23.4
B.82	South	West-1	11KV	JKP	4/1 SUBHASH NAGAR,B1 COMPLAINT CENTER JANAKPURI,B-32 MAYAPURI PH-1,C-3 COMPLAINT CENTER JKP,D2 COMPLAINT CENTER JKP	4902566	NARAINA GOPINATH BAZAAR	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902566	80/100	2.59	0.00	0.0

B.83	West	West-1 / West-2 / West-3	11KV	JKP/PBG/TGN/PLM	ROAD NO-41 PUNJABI BAGH,SEC-9 DWK,MANGLA PURI,MUKHARJI PARK,KAILASHPURI,DABRI,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,B-32 MAYAPURI PH-1,B1 COMPLAINT CENTER JANAKPURI,B BLK KARAMPURA,B 3 PASCHIM VIHAR,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4902529	REWARI LINE BUS I-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902529	320/100	0.00	0.00	0.0
B.84	West	West-1 / West-2 / West-3	11KV	JKP/PBG/TGN/PLM	ROAD NO-41 PUNJABI BAGH,SEC-9 DWK,MANGLA PURI,MUKHARJI PARK,KAILASHPURI,DABRI,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,B-32 MAYAPURI PH-1,B1 COMPLAINT CENTER JANAKPURI,B BLK KARAMPURA,B 3 PASCHIM VIHAR,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4902525	REWARI LINE BUS 2-3	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902525	320/100		0.06	0.1
B.85	South	South-3	33KV	RKP	MOTI BAGH,R.K. PURAM,VASANT VIHAR	4865137	RIDGE VALLEY (S RD.-1)	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865137	800/300	0.00	0.00	0.0
B.86	South	South-3	33KV	RKP	MOTI BAGH,R.K. PURAM,VASANT VIHAR	4864828	RIDGE VALLEY (S RD.-2)	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864828	800/300		0.29	0.3
B.87	West	West-2	11KV	PBG	B 3 PASCHIM VIHAR,B BLK KARAMPURA,ROAD NO-41 PUNJABI BAGH	4902591	SB MILL MOTI NAGAR	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902591	80/100		0.42	0.4
B.88	West	West-2	11KV	PBG	B 3 PASCHIM VIHAR,B BLK KARAMPURA,ROAD NO-41 PUNJABI BAGH	4902564	SB MILL N.G. ROAD	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902564	80/100		2.04	2.0
B.89	West	West-2	11KV	PBG	B 3 PASCHIM VIHAR,B BLK KARAMPURA,ROAD NO-41 PUNJABI BAGH	4902548	SB MILL MOTI NAGAR-II	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902548	80/100	0.00	0.00	0.0
B.90	West	West-2	11kv	PBG	B 3 PASCHIM VIHAR,B BLK KARAMPURA,ROAD NO-41 PUNJABI BAGH	4902528	SB MILL 53 RAMA ROAD	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902528	80/100		1.40	1.4
B.91	West	West-2	11KV	PBG	B 3 PASCHIM VIHAR,B BLK KARAMPURA,ROAD NO-41 PUNJABI BAGH	4902523	SB MILL BREAKFAST	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902523	80/100	0.00	0.00	0.0
B.92	West	West-2	11KV	PBG	B 3 PASCHIM VIHAR,B BLK KARAMPURA,ROAD NO-41 PUNJABI BAGH	4865093	SB MILL 70 RAMA ROAD	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865093	80/100	0.00	0.00	0.0
B.93	South	South-3	66KV	RKP	MOTI BAGH,R.K. PURAM,VASANT VIHAR	4864949	PARK STREET R. VALLEY-I	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864949	800/600	0.00	0.00	0.0
B.94	South	South-3	66KV	RKP	MOTI BAGH,R.K. PURAM,VASANT VIHAR	4865016	(P.ST. R.V-II)	Metered	Functional	13-07-2023	Mixed	0%	2184	2184		800/600			0.0
B.95	West	West-3	66KV	MDK	DSIDC MUNDKA,swarn park Mundka,TIKRI	5128439	Kanjhawala-66kv DMRC MUNDKA	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5128439	800/600	0.52	0.00	0.0

B.96	West	West-2 / West-3 / West-4	66KV	NGL/MDK/NJ F	JHATIKARA MORE,NANGLOI,SHYAM VIHAR,swarn park Mundka,TIKRI,UDYOG NAGAR,DSIDC MUNDKA,GH-9 PASCHIM VIHAR,DELHI GATE,DAULATPUR,CHHAWLA,BHAR TAL,BAPROLA,ANAJMANDI	5100233	Mundka 66kv DMRC	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5100233	800/600	5.80	0.00	0.0
B.97	South	South-3 / South-4	11KV	RKP/VKJ	D-4 VKJ,KAPASHERA,MAHIPAL PUR,MOTI BAGH,R.K. PURAM,VASANT VIHAR,BIJWASAN,C- 9 VASANT KUNJ,B-1 VKJ.	4865065	SIGNAL ENCLAVE	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865065	30/100		0.00	0.0
B.98	South	South-3 / South-4	11KV	RKP/VKJ	D-4 VKJ,KAPASHERA,MAHIPAL PUR,MOTI BAGH,R.K. PURAM,VASANT VIHAR,BIJWASAN,C- 9 VASANT KUNJ,B-1 VKJ.	4902594	R.R. HOSPITAL	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902594	30/100		2.72	2.7
B.99	South	South-3 / South-4	11KV	RKP/VKJ	D-4 VKJ,KAPASHERA,MAHIPAL PUR,MOTI BAGH,R.K. PURAM,VASANT VIHAR,BIJWASAN,C- 9 VASANT KUNJ,B-1 VKJ.	4865067	DEFENCE CLUB	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865067	30/100		0.19	0.2
B.100	South	South-3 / South-4	11KV	RKP/VKJ	D-4 VKJ,KAPASHERA,MAHIPAL PUR,MOTI BAGH,R.K. PURAM,VASANT VIHAR,BIJWASAN,C- 9 VASANT KUNJ,B-1 VKJ.	4865081	SUBROTO PARK	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865081	60/100		0.42	0.4
B.101	South	South-3 / South-4	11KV	RKP/VKJ	D-4 VKJ,KAPASHERA,MAHIPAL PUR,MOTI BAGH,R.K. PURAM,VASANT VIHAR,BIJWASAN,C- 9 VASANT KUNJ,B-1 VKJ.	4902562	SUBROTO PARK 2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902562	60/100		2.11	2.1
B.102	South	South-3 / South-4	11KV	RKP/VKJ	D-4 VKJ,KAPASHERA,MAHIPAL PUR,MOTI BAGH,R.K. PURAM,VASANT VIHAR,BIJWASAN,C- 9 VASANT KUNJ,B-1 VKJ.	4902552	BI LINES	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902552	60/100		0.15	0.2
B.103	South	South-3 / South-4	11KV	RKP/VKJ	D-4 VKJ,KAPASHERA,MAHIPAL PUR,MOTI BAGH,R.K. PURAM,VASANT VIHAR,BIJWASAN,C- 9 VASANT KUNJ,B-1 VKJ.	4865075	BI LINES 2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865075	60/100		0.42	0.4
B.104	South	West-1 / West-2 / West-3	11KV	JKP/PBG/ TGN	B1 COMPLAINT CENTER JANAKPURI,B-32 MAYAPURI PH-1,C- 3 COMPLAINT CENTER JKP,D2 COMPLAINT CENTER JKP,MUKHARJI PARK,ROAD NO-41 PUNJABI BAGH,B 3 PASCHIM VIHAR,B BLK KARAMPURA,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4902559	BUS COUPLER -3 BRPL	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902559	240/100		0.02	0.0

B.105	South	South-1 / South-2 / South-3 / South-4	33KV	ALN/NHP/ SKT/HKS/ KPR	MIG DDA FLAT SAKET,MMTC,OKHLA IND AREA PH-2 & PH-3,OKHLA PHASE 1,PUL PRAHLADPUR,RBI HAUZ KHAS,LAJPAT NAGAR IV,MALVIYA NAGAR,KHANPUR,KATWARIA SARAI,JAUNAPUR,GREEN PARK,GK 2,GK 1,G BLOCK KALKA JI,FATEHPUR BERI,DURGA VIHAR,DDA FLAT KALKAJI,D-BLOCK SANGAM VIHAR,CHATARPUR,AYA NAGAR,ANDREWS GANJ POLICE COLONY	4864905	Masjid Moth 33kv -1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864905	2000/300	64.26	0.00	0.0
B.106	South	South-1 / South-2 / South-3 / South-4	33KV	ALN/NHP/ SKT/HKS/ KPR	MIG DDA FLAT SAKET,MMTC,OKHLA IND AREA PH-2 & PH-3,OKHLA PHASE 1,PUL PRAHLADPUR,RBI HAUZ KHAS,LAJPAT NAGAR IV,MALVIYA NAGAR,KHANPUR,KATWARIA SARAI,JAUNAPUR,GREEN PARK,GK 2,GK 1,G BLOCK KALKA JI,FATEHPUR BERI,DURGA VIHAR,DDA FLAT KALKAJI,D-BLOCK SANGAM VIHAR,CHATARPUR,AYA NAGAR,ANDREWS GANJ POLICE COLONY	4902504	Masjid Moth 33kv -2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902504	2000/300	65.58	0.00	0.0
B.107	South	South-1 / South-2 / South-3 / South-4	33KV	ALN/NHP/ SKT/HKS/ KPR	MIG DDA FLAT SAKET,MMTC,OKHLA IND AREA PH-2 & PH-3,OKHLA PHASE 1,PUL PRAHLADPUR,RBI HAUZ KHAS,LAJPAT NAGAR IV,MALVIYA NAGAR,KHANPUR,KATWARIA SARAI,JAUNAPUR,GREEN PARK,GK 2,GK 1,G BLOCK KALKA JI,FATEHPUR BERI,DURGA VIHAR,DDA FLAT KALKAJI,D-BLOCK SANGAM VIHAR,CHATARPUR,AYA NAGAR,ANDREWS GANJ POLICE COLONY	5128426	Masjid Mode I/C. 3	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5128426	2000/300	60.42	0.00	0.0
B.108	South	South-3	33KV	RKP	MOTI BAGH,R.K. PURAM,VASANT VIHAR	4865164	RIDGE VALLEY KHYBER LANE-1 EXP.	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865164	800/300	7.01	7.0	
B.109	South	South-3	33KV	RKP	MOTI BAGH,R.K. PURAM,VASANT VIHAR	4864845	RIDGE VALLEY KHYBER LANE-2 EXP.	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864845	800/300		8.08	8.1
B.110	South	South-2	0.44KV	NZD	DEFENCE COLONY,JUNG PURA,KILOKARI,LAJPAT NAGAR- 2,LODHI ROAD	4962369	GT (GAIL)	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4962369	40/1	0.01	0.00	0.0

B.111	South	South-1 / South-2 / South-3	11KV	NHP/HKS/NZ D/NFC	OKHLA IND AREA PH-2 & PH-3,RBI HAUZ KHAS,LODHI ROAD,OKHLA,LAJPAT NAGAR-2,LAJPAT NAGAR IV,KILOKARI,KATWARIA SARAI,KALINDI COLONY,JUNG PURA,GREEN PARK,GK 1,DEFENCE COLONY,ANDREWS GANJ POLICE COLONY,ABUL FAZAL	4865072	11KV VIKAS SADAN (AIIMS)	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865072	60/100	0.52	0.00	0.0
B.112	South	South-1 / South-2 / South-3	11KV	NHP/HKS/NZ D/NFC	OKHLA IND AREA PH-2 & PH-3,RBI HAUZ KHAS,LODHI ROAD,OKHLA,LAJPAT NAGAR-2,LAJPAT NAGAR IV,KILOKARI,KATWARIA SARAI,KALINDI COLONY,JUNG PURA,GREEN PARK,GK 1,DEFENCE COLONY,ANDREWS GANJ POLICE COLONY,ABUL FAZAL	4865066	11KV NDSE (AIIMS)	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865066	60/100	0.82	0.00	0.0
B.113	South	South-1 / South-2 / South-3	33KV	NHP/HKS/NZ D/NFC	OKHLA IND AREA PH-2 & PH-3,RBI HAUZ KHAS,LODHI ROAD,OKHLA,LAJPAT NAGAR-2,LAJPAT NAGAR IV,KILOKARI,KATWARIA SARAI,KALINDI COLONY,JUNG PURA,GREEN PARK,GK 1,DEFENCE COLONY,ANDREWS GANJ POLICE COLONY,ABUL FAZAL	4865103	33 KV Kilokari Fdr. (AIIMS)	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865103	500/300	0.00	0.00	0.0
B.114	South	South-3	66KV	RKP	MOTI BAGH,R.K. PURAM,VASANT VIHAR	5128461	Ridge Valley -Tx-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5128461	2000/600	90.06	0.00	0.0
B.115	South	South-3	66KV	RKP	MOTI BAGH,R.K. PURAM,VASANT VIHAR	4865003	Ridge Valley -Tx-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865003	2000/600	92.34	0.00	0.0
B.116	South	South-4	66KV	VKJ	B-1 VKJ.,BIJWASAN,C-9 VASANT KUNJ,D-4 VKJ,KAPASHERA,MAHIPAL PUR	5128472	DIAL Tx-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5128472	2000/600	44.20	0.00	0.0
B.117	South	South-4	66KV	VKJ	B-1 VKJ.,BIJWASAN,C-9 VASANT KUNJ,D-4 VKJ,KAPASHERA,MAHIPAL PUR	5128452	DIAL Tx-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5128452	2000/600	45.04	0.00	0.0
B.118	West	West-2 / West-3 / West-4	66KV	NGL/MDK/NJ F	JHATIKARA MORE,NANGLOI,SHYAM VIHAR,swarn park Mundka,TIKRI,UDYOG NAGAR,DSIDC MUNDKA,GH-9 PASCHIM VIHAR,DELHI GATE,DAULATPUR,CHHAWLA,BHARTAL,BAPROLA,ANAJMANDI	4865026	Nangloi Water Works	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865026	800/600	31.78	0.00	0.0
B.119	West	West-2 / West-3 / West-4	66KV	NGL/MDK/NJ F	JHATIKARA MORE,NANGLOI,SHYAM VIHAR,swarn park Mundka,TIKRI,UDYOG NAGAR,DSIDC MUNDKA,GH-9 PASCHIM VIHAR,DELHI GATE,DAULATPUR,CHHAWLA,BHARTAL,BAPROLA,ANAJMANDI	4902509	Mundka 66kv Nangloi	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4902509	800/600	3.62	0.00	0.0

B.120	West	West-2 / West-3 / West-4	66KV	NGL/MDK/NJ F	JHATIKARA MORE,NANGLOI,SHYAM VIHAR,swarn park Mundka,TIKRI,UDYOG NAGAR,DSIDC MUNDKA,GH-9 PASCHIM VIHAR,DELHI GATE,DAULATPUR,CHHAWLA,BHAR TAL,BAPROLLA,ANAJMANDI	4864985	B-611 (BRPL Mundka S/stn.) 66KV	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864985	800/600	27.24	0.00	0.0
B.121	West	West-2 / West-3 / West-4	66KV	NGL/MDK/NJ F	JHATIKARA MORE,NANGLOI,SHYAM VIHAR,swarn park Mundka,TIKRI,UDYOG NAGAR,DSIDC MUNDKA,GH-9 PASCHIM VIHAR,DELHI GATE,DAULATPUR,CHHAWLA,BHAR TAL,BAPROLLA,ANAJMANDI	5128436	B-612 (BRPL Mundka S/stn.) 66KV	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5128436	800/600	23.36	0.00	0.0
B.122	West	West-1 / West-2 / West-3	33KV	JKP/PBG/ TGN/NGL	ROAD NO-41 PUNJABI BAGH,UDYOG NAGAR,MUKHARJI PARK,NANGLOI,GH-9 PASCHIM VIHAR,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,BAPROLLA,B-32 MAYAPURI PH- 1,B1 COMPLAINT CENTER JANAKPURI,B BLK KARAMPURA,B 3 PASCHIM VIHAR,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4864861	Vishal 33 KV Line- 3 Peera garhi	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864861	400/300	22.09	0.00	0.0
B.123	West	West-1 / West-2 / West-3	33KV	JKP/PBG/ TGN/NGL	ROAD NO-41 PUNJABI BAGH,UDYOG NAGAR,MUKHARJI PARK,NANGLOI,GH-9 PASCHIM VIHAR,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,BAPROLLA,B-32 MAYAPURI PH- 1,B1 COMPLAINT CENTER JANAKPURI,B BLK KARAMPURA,B 3 PASCHIM VIHAR,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4864877	A-4 Paschim Vihar 33 KV Line- 4 Peera garhi	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864877	800/300	33.97	0.00	0.0

B.124	West	West-1 / West-2 / West-3	33KV	JKP/PBG/ TGN/NGL	ROAD NO-41 PUNJABI BAGH,UDYOG NAGAR,MUKHARJI PARK,NANGLOI,GH-9 PASCHIM VIHAR,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,BAPROLLA,B-32 MAYAPURI PH- 1,B1 COMPLAINT CENTER JANAKPURI,B BLK KARAMPURA,B 3 PASCHIM VIHAR,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4864841	Udyog Nagar 33 KV Line-5 Peera garhi	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864841	800/300	32.11	0.00	0.0
B.125	West	West-1 / West-2 / West-3	33KV	JKP/PBG/TGN /NGL	ROAD NO-41 PUNJABI BAGH,UDYOG NAGAR,MUKHARJI PARK,NANGLOI,GH-9 PASCHIM VIHAR,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,BAPROLLA,B-32 MAYAPURI PH- 1,B1 COMPLAINT CENTER JANAKPURI,B BLK KARAMPURA,B 3 PASCHIM VIHAR,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4864882	Madipur 33 KV Line-6 Peera garhi	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864882	800/300	15.10	0.00	0.0
B.126	West	West-1 / West-2 / West-3	33KV	JKP/PBG/TGN /NGL	ROAD NO-41 PUNJABI BAGH,UDYOG NAGAR,MUKHARJI PARK,NANGLOI,GH-9 PASCHIM VIHAR,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,BAPROLLA,B-32 MAYAPURI PH- 1,B1 COMPLAINT CENTER JANAKPURI,B BLK KARAMPURA,B 3 PASCHIM VIHAR,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4865064	Paschim Puri-1 33 KV Line-7 Peera garhi	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865064	800/300	23.81	0.00	0.0
B.127	West	West-1 / West-2 / West-3	33KV	JKP/PBG/TGN /NGL	ROAD NO-41 PUNJABI BAGH,UDYOG NAGAR,MUKHARJI PARK,NANGLOI,GH-9 PASCHIM VIHAR,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,BAPROLLA,B-32 MAYAPURI PH- 1,B1 COMPLAINT CENTER JANAKPURI,B BLK KARAMPURA,B 3 PASCHIM VIHAR,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	5295123	Paschim Puri -2 33 KV Line-8 Peera garhi	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5295123	800/300	22.22	0.00	0.0

B.128	West	West-1 / West-2 / West-3	33KV	JKP/PBG/TGN /NGL	ROAD NO-41 PUNJABI BAGH,UDYOG NAGAR,MUKHARJI PARK,NANGLOI,GH-9 PASCHIM VIHAR,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,BAPROLLA,B-32 MAYAPURI PH- 1,B1 COMPLAINT CENTER JANAKPURI,B BLK KARAMPURA,B 3 PASCHIM VIHAR,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4864790	Peeragarhi-1- 33KV Mukharjee Park-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864790	800/300	23.99	0.00	0.0
B.129	West	West-1 / West-2 / West-3	33KV	JKP/PBG/ TGN/NGL	ROAD NO-41 PUNJABI BAGH,UDYOG NAGAR,MUKHARJI PARK,NANGLOI,GH-9 PASCHIM VIHAR,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,BAPROLLA,B-32 MAYAPURI PH- 1,B1 COMPLAINT CENTER JANAKPURI,B BLK KARAMPURA,B 3 PASCHIM VIHAR,A-BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4864847	Peeragarhi-2- 33KV Mukharjee Park-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864847	800/300	30.16	0.00	0.0
B.130	South	South-3	33KV	RKP/HKS	GREEN PARK,KATWARIA SARAI,MOTI BAGH,R.K. PURAM,RBI HAUZ KHAS,VASANT VIHAR,ANDREWS GANJ POLICE COLONY	4864839	Trauma Center 33KV Bhikaji Cama Place	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864839	800/300	24.80	0.00	0.0
B.131	South	South-3	33KV	RKP/HKS	GREEN PARK,KATWARIA SARAI,MOTI BAGH,R.K. PURAM,RBI HAUZ KHAS,VASANT VIHAR,ANDREWS GANJ POLICE COLONY	4864872	Trauma Center- IIT	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864872	800/300	16.86	0.00	0.0
B.132	West	West-1	33KV	JKP	4/1 SUBHASH NAGAR,B1 COMPLAINT CENTER JANAKPURI,B- 32 MAYAPURI PH-1,C-3 COMPLAINT CENTER JKP,D2 COMPLAINT CENTER JKP	5128400	Naraina Maya Puri Ckt-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5128400	800/300	34.09	0.00	0.0
B.133	West	West-1	33KV	JKP	4/1 SUBHASH NAGAR,B1 COMPLAINT CENTER JANAKPURI,B- 32 MAYAPURI PH-1,C-3 COMPLAINT CENTER JKP,D2 COMPLAINT CENTER JKP	5295156	Naraina Maya Puri Ckt-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864870	800/300	34.95	0.00	0.0

B.134	West	West-1 / West-2 / West-3 / West-4	66KV	PLM/DWK/ GN/NJF/ JKP/TGN/ VKP	MUKHARJI PARK,SEC 13, DWARKA,SEC 4, DWARKA,SEC-9 DWK,SHIV VIHAR ,SHYAM VIHAR,MATIYALA,MILAP NAGAR,MANGLA PURI,MADHU VIHAR,LIG-2 HASTSAL,KAILASHPURI,JHATIKARA MORE,DELHI GATE,DAULATPUR,DABRI,D2 COMPLAINT CENTER JKP,CHHAWLA,CHANAKYA PLACE,C- 3 COMPLAINT CENTER JKP,C BLOCK VKP,BINDAPUR,BHARTAL,4/1 SUBHASH NAGAR,A-BLK TAGORE GARDEN,ANAJMANDI,B1 COMPLAINT CENTER JANAKPURI,B- 32 MAYAPURI PH-1,24 BLK Tilak nagar	4864960	PPK-1 R.Line	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864960	800/600	18.70	18.7	
B.135	West	West-1 / West-2 / West-3	33KV	JKP/PBG/ TGN/PLM	ROAD NO-41 PUNJABI BAGH,SEC-9 DWK,MANGLA PURI,MUKHARJI PARK,KAILASHPURI,DABRI,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,B-32 MAYAPURI PH-1,B1 COMPLAINT CENTER JANAKPURI,B BLK KARAMPURA,B 3 PASCHIM VIHAR,A- BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4865158	R. Line -33KV Vishal -1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865158	160/300	5.70	0.00	0.0
B.136	West	West-1 / West-2 / West-3	33KV	JKP/PBG/TGN /PLM	ROAD NO-41 PUNJABI BAGH,SEC-9 DWK,MANGLA PURI,MUKHARJI PARK,KAILASHPURI,DABRI,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,B-32 MAYAPURI PH-1,B1 COMPLAINT CENTER JANAKPURI,B BLK KARAMPURA,B 3 PASCHIM VIHAR,A- BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4865140	R. Line -33KV Vishal -2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865140	750/300	0.09	0.00	0.0
B.137	West	West-1 / West-2 / West-3	33KV	JKP/PBG/TGN /PLM	ROAD NO-41 PUNJABI BAGH,SEC-9 DWK,MANGLA PURI,MUKHARJI PARK,KAILASHPURI,DABRI,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,B-32 MAYAPURI PH-1,B1 COMPLAINT CENTER JANAKPURI,B BLK KARAMPURA,B 3 PASCHIM VIHAR,A- BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4864808	R.Line-33KV Mayapuri	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864808	750/300	0.81	0.00	0.0

B.138	West	West-1 / West-2 / West-3	33KV	JKP/PBG/TGN /PLM	ROAD NO-41 PUNJABI BAGH,SEC-9 DWK,MANGLA PURI,MUKHARJI PARK,KAILASHPURI,DABRI,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,B-32 MAYAPURI PH-1,B1 COMPLAINT CENTER JANAKPURI,B BLK KAMPURA,B 3 PASCHIM VIHAR,A- BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4865080	R.Line-20MVA Tx- 3	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865080	250/600	0.92	0.00	0.0
B.139	West	West-1 / West-2 / West-3	66KV	JKP/PBG/TGN /PLM	ROAD NO-41 PUNJABI BAGH,SEC-9 DWK,MANGLA PURI,MUKHARJI PARK,KAILASHPURI,DABRI,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,B-32 MAYAPURI PH-1,B1 COMPLAINT CENTER JANAKPURI,B BLK KAMPURA,B 3 PASCHIM VIHAR,A- BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	4864822	R.Line-16MVA Tx- 1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864822	500/300	2.69	0.00	0.0
B.140	West	West-1 / West-2 / West-3	66KV	JKP/PBG/TGN /PLM	ROAD NO-41 PUNJABI BAGH,SEC-9 DWK,MANGLA PURI,MUKHARJI PARK,KAILASHPURI,DABRI,D2 COMPLAINT CENTER JKP,C-3 COMPLAINT CENTER JKP,B-32 MAYAPURI PH-1,B1 COMPLAINT CENTER JANAKPURI,B BLK KAMPURA,B 3 PASCHIM VIHAR,A- BLK TAGORE GARDEN,4/1 SUBHASH NAGAR,24 BLK Tilak nagar	5129960	I/C Sagarpur AT R.Line	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5129960	750/600	7.36	7.4	
B.141	South	South-2 / South-3 / South-4	66KV	SKT/VKJ/ALN/ NHP/HKS	OKHLA PHASE 1,RBI HAUZ KHAS,MMTC,OKHLA IND AREA PH-2 & PH-3,MIG DDA FLAT SAKET,MALVIYA NAGAR,MAHIPAL PUR,LAJPAT NAGAR IV,KATWARIA SARAI,KAPASHERA,JAUNAPUR,GREE N PARK,GK 2,GK 1,G BLOCK KALKA JI,FATEHPUR BERI,DDA FLAT KALKAJI,D-4 VKJ,CHATARPUR,ANDREWS GANJ POLICE COLONY,AYA NAGAR,B-1 VKJ.,BIJWASAN,C-9 VASANT KUNJ	5295173	R.K Puram 66KV- I/C-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5295173	2000/600	38.43	0.00	0.0

B.142	South	South-2 / South-3 / South-4	66KV	SKT/VKJ/ALN/ NHP/HKS	OKHLA PHASE 1,RBI HAUZ KHAS,MMTC,OKHLA IND AREA PH-2 & PH-3,MIG DDA FLAT SAKET,MALVIYA NAGAR,MAHIPAL PUR,LAJPAT NAGAR IV,KATWARIA SARAI,KAPASHERA,JAUNAPUR,GREE N PARK,GK 2,GK 1,G BLOCK KALKA JI,FATEHPUR BERI,DDA FLAT KALKAJI,D-4 VKJ,CHATARPUR,ANDREWS GANJ POLICE COLONY,AYA NAGAR,B-1 VKJ.,BIJWASAN,C-9 VASANT KUNJ	5100228	R.K Puram 66KV- I/C-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5100228	2000/600	39.09	0.00	0.0
B.143	South	South-2 / South-3 / South-4	33KV	SKT/VKJ/ALN/ NHP/HKS	OKHLA PHASE 1,RBI HAUZ KHAS,MMTC,OKHLA IND AREA PH-2 & PH-3,MIG DDA FLAT SAKET,MALVIYA NAGAR,MAHIPAL PUR,LAJPAT NAGAR IV,KATWARIA SARAI,KAPASHERA,JAUNAPUR,GREE N PARK,GK 2,GK 1,G BLOCK KALKA JI,FATEHPUR BERI,DDA FLAT KALKAJI,D-4 VKJ,CHATARPUR,ANDREWS GANJ POLICE COLONY,AYA NAGAR,B-1 VKJ.,BIJWASAN,C-9 VASANT KUNJ	5295131	R.K Puram 33KV- I/C-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5295131	2000/300	31.28	0.00	0.0
B.144	South	South-2 / South-3 / South-4	33KV	SKT/VKJ/ALN/ NHP/HKS	OKHLA PHASE 1,RBI HAUZ KHAS,MMTC,OKHLA IND AREA PH-2 & PH-3,MIG DDA FLAT SAKET,MALVIYA NAGAR,MAHIPAL PUR,LAJPAT NAGAR IV,KATWARIA SARAI,KAPASHERA,JAUNAPUR,GREE N PARK,GK 2,GK 1,G BLOCK KALKA JI,FATEHPUR BERI,DDA FLAT KALKAJI,D-4 VKJ,CHATARPUR,ANDREWS GANJ POLICE COLONY,AYA NAGAR,B-1 VKJ.,BIJWASAN,C-9 VASANT KUNJ	5295139	R.K Puram 33KV- I/C-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5295139	2000/300	33.46	0.00	0.0
B.145	South	South-1 / South-3 / South-4	66KV	ALN/SVR/SKT/ KPR	MIG DDA FLAT SAKET,MMTC,OKHLA PHASE 1,PUL PRAHLADPUR,SARITA VIHAR,SAURABH VIHAR,KHANPUR,MALVIYA NAGAR,KANCHAN KUNJ,JAUNAPUR,GK 2,G BLOCK KALKA JI,FATEHPUR BERI,DURGA VIHAR,DDA FLAT KALKAJI,D-BLOCK SANGAM VIHAR,CHATARPUR,BADARPUR,AYA NAGAR	5128460	Tuglakabad 66KV I/C-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5128460	1600/600	41.82	0.00	0.0

B.146	South	South-1 / South-3 / South-4	66KV	ALN/SVR/SKT/ KPR	MIG DDA FLAT SAKET,MMTC,OKHLA PHASE 1,PUL PRAHLADPUR,SARITA VIHAR,SAURABH VIHAR,KHANPUR,MALVIYA NAGAR,KANCHAN KUNJ,JAUNAPUR,GK 2,G BLOCK KALKA JI,FATEHPUR BERI,DURGA VIHAR,DDA FLAT KALKAJI,D-BLOCK SANGAM VIHAR,CHATARPUR,BADARPUR,AYA NAGAR	5295149	Tuglakabad 66KV I/C-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5295149	1600/600	42.15	0.00	0.0
B.147	South	South-1	66KV	KPR	DURGA VIHAR,KHANPUR,PUL PRAHLADPUR,D-BLOK SANGAM VIHAR	Q0473785	TKD-TEHKHAND WASTE TO ENERGY PLANT	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	Q0473785	400/600	52.34	0.00	
B.148	South	South-1 / South-2	33KV	NZD/NFC/ NHP	KILOKARI,LAJPAT NAGAR IV,LAJPAT NAGAR-2,LODHI ROAD,OKHLA,OKHLA IND AREA PH-2 & PH-3,JUNG PURA,KALINDI COLONY,GK 1,DEFENCE COLONY,ABUL FAZAL	4865130	IP STATION BAY-38 Supreme Court	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4865130	60/300	2.14	0.00	0.0
B.149	South	South-1	66kV	KPR/SVR	DURGA VIHAR,KANCHAN KUNJ,KHANPUR,PUL PRAHLADPUR,SARITA VIHAR,SAURABH VIHAR,BADARPUR,D-BLOCK SANGAM VIHAR	Y0357818	Stn. Tx-3 at BTPS on 66KV	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	Y0357818	2000/60			0.0
B.150	South	South-1	66kV	KPR/SVR	DURGA VIHAR,KANCHAN KUNJ,KHANPUR,PUL PRAHLADPUR,SARITA VIHAR,SAURABH VIHAR,BADARPUR,D-BLOCK SANGAM VIHAR	Y0357821	Stn. Tx-4 at BTPS on 66KV	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	Y0357821	2000/60			0.0
B.151	West	West-2 / West-3 / West-4	66KV	NGL/MDK/NJ F	JHATIKARA MORE,NANGLOI,SHYAM VIHAR,swarn park Mundka,TIKRI,UDYOG NAGAR,DSIDC MUNDKA,GH-9 PASCHIM VIHAR,DELHI GATE,DAULATPUR,CHHAWLA,BHARTAL,BAPROLA,ANAJMANDI	5128428	5128428 Mundka-66 kv Nilothi ckt-1	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5128428	800/600	47.90		
B.152	West	West-2 / West-3 / West-4	66KV	NGL/MDK/NJ F	JHATIKARA MORE,NANGLOI,SHYAM VIHAR,swarn park Mundka,TIKRI,UDYOG NAGAR,DSIDC MUNDKA,GH-9 PASCHIM VIHAR,DELHI GATE,DAULATPUR,CHHAWLA,BHARTAL,BAPROLA,ANAJMANDI	4864926	4864926 Mundka-66 kv Nilothi ckt-2	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864926	800/600	28.91		
						Q0430821	Q0430821 TKD RLY STATION (Diesel Shed)	Metered	Functional	13-07-2023			2184	2184	Q0430821				0.05
						Q0430831	Q0430831 NZD RLY STN.(SS)	Metered	Functional	13-07-2023			2184	2184	Q0430831				0.16
B.153	South	South-1	66kV	NFC	Kalindi colony, Okhla, Abul Fazal	DLTCL001	BRPL TOWMCL	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	4864899	800/1	16.87	0.00	0.0

B.154	South	South-2	11KV	NHP	GK-1, Lajpat Nagar-IV, Okhla IND area, PH-2&PH-3	DLTGS001	Thaygaraj	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5017305	300/5	0.01	0.00	0.0
B.155							Open Access											129.31	129.3
B.100	Total (MU)																4093	274	
B.100	Net input energy at DISCOM periphery (MU)																3819		

*Incoming feeders from DTL are connected to the grid as incomers and from grid, the supply is distributed in multiple circles, divisions and sub divisions..

**Custodian of these feeder Meters is DTL and AMR is not installed on these meters

Color	Parameter
	Please enter voltage level or leave blank
	Please enter feeder id and name or leave blank
	Enter meter no or leave blank
	Enter CT/PT ratio or leave blank
0	Please enter numeric value or 0
	Please select yes or no from list
	Formula protected

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal

Name of Authorised Signatory: **Gopal Nariya**
Name of the DISCOM: **BSES Rajdhani Power Ltd**
Full Address:- **2nd Floor, D Block, BSES Bhawan, Nehru Place, New Delhi - 110019**

Seal

Signature:-

Name of Energy Manager*:

Registration Number:

Avinash Kumar

EA - 6550


B.154	South	South-2	11KV	NHP	GK-1, Lajpat Nagar-IV, Okhla IND area, PH-2&PH-3	DLTGS001	Thaygaraj	Metered	Functional	13-07-2023	Mixed	0%	2184	2184	5017305	300/5	0.01	0.00	0.0
B.155							Open Access											129.31	129.3
B.100	Total (MU)																4093	274	
B.100	Net input energy at DISCOM periphery (MU)																3819		

*Incoming feeders from DTL are connected to the grid as incomers and from grid, the supply is distributed in multiple circles, divisions and sub divisions.
 **Custodian of these feeder Meters is DTL and AMR is not installed on these meters

Color	Parameter
	Please enter voltage level or leave blank
	Please enter feeder id and name or leave blank
	Enter meter no or leave blank
	Enter CT/PT ratio or leave blank
0	Please enter numeric value or 0
	Please select yes or no from list
	Formula protected

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal



Name of Authorised Signatory: **Gopal Nariya**
 Name of the DISCOM: **BSES Rajdhani Power Ltd**
 Full Address:- **2nd Floor, D Block, BSES Bhawan, Nehru Place, New Delhi - 110019**

Signature:-
 Name of Energy Manager*:
 Registration Number:

Avinash Kumar
Avinash Kumar
EA - 6550

Seal

Gopal Nariya
 VP - Automation
 Head-SCADA, DMS, Smart
 Meter & Asset Management
 Emp. No. 41016354
BSES Rajdhani Power Limited
 A Joint Venture with Govt of NCT Delhi

Details of Input Energy Sources								
Period From Apr-23 to June-23								
A. Generation at Transmission Periphery (Details)								
S.No.	Name of Generation Station	Generation Capacity (In MW)	Generation (Based- Solid (Coal, Lignite)/Liquid/G)	Type of Contract (in years/months/days)	Type of Grid (Intra-state/Inter-state)	Point of Connection(POC) Loss in MU	Voltage Level (At input)	Remarks (Source of data)
1	Anta-Gas	419	Gas	Long Term	Inter-state			Source: Long Term PPA.
2	Auriya-Gas	663	Gas	Long Term	Inter-state			Remarks:
3	Dadri - Gas	830	Gas	Long Term	Inter-state			BRPL is purchasing power from different generating station
4	Singrauli	2000	Coal	Long Term	Inter-state			situated at different states and connected through nation,
5	Unchahar - I	420	Coal	Long Term	Inter-state			regional and state grid hence
6	Unchahar - II	420	Coal	Long Term	Inter-state			generating station wise Point of
7	Unchahar - III	210	Coal	Long Term	Inter-state			contact Loss and voltage level
8	Dadri-II	980	Coal	Long Term	Inter-state			at input points are not feasible.
9	Rihand-I	1000	Coal	Long Term	Inter-state			NRSCLC is not calculating POC
10	Rihand-II	1000	Coal	Long Term	Inter-state			loss based on Generating
11	Rihand-III	1000	Coal	Long Term	Inter-state			station wise but calculating POC
12	Farakka	1600	Coal	Long Term	Inter-state			loss for all inter-state
13	Kahalgaon-1	840	Coal	Long Term	Inter-state			generation on weekly basis.
14	Kahalgaon-II	1500	Coal	Long Term	Inter-state			SLDC /DTL is declaring POC loss
15	Jhajjar (APCPL)	1500	Coal	Long Term	Inter-state			and state transmission unit
16	CTPS-7 & 8	500	Coal	Long Term	Inter-state			(STU) basis not on generating
17	MTPS-6	250	Coal	Long Term	Inter-state			unit basis. DTL has declared
18	Sasan*	3960	Coal	Long Term	Inter-state			POC Loss 0.87838% for FY 2021-
19	GT	90		Long Term	Intra-state			22
20	PPCL-I	330	Gas	Long Term	Inter-state			Suggestion:
21	PPCL-III(Bawana)	1371	Gas	Long Term	Intra-state			Details of Input Energy Sources:
22	Bairasiul	180	Hydro	Long Term	Inter-state			Form A - Generation at
23	Salal	690	Hydro	Long Term	Inter-state			Transmission Periphery
24	Tanakpur	94	Hydro	Long Term	Inter-state			(Details) may be modified and
25	Chamera-I	540	Hydro	Long Term	Inter-state			Point of Connection (POC) Loss
26	Chamera-II	300	Hydro	Long Term	Inter-state			(MU) and Voltage level Colum
27	Chamera-III	231	Hydro	Long Term	Inter-state			to be removed from the form.
28	Uri	480	Hydro	Long Term	Inter-state			
29	Uri-2	240	Hydro	Long Term	Inter-state			
30	Dhauri Ganga Hep	280	Hydro	Long Term	Inter-state			
31	Dulhasti	390	Hydro	Long Term	Inter-state			
32	Sewa-II	120	Hydro	Long Term	Inter-state			
33	Parbati-III	520	Hydro	Long Term	Inter-state			
34	Tala through PTC	1020	Hydro	Long Term	Inter-state			
35	NJPC	1500	Hydro	Long Term	Inter-state			
36	Tehri THDC	1000	Hydro	Long Term	Inter-state			
37	Koteshwar	400	Hydro	Long Term	Inter-state			
38	NAPP	440	Nuclear	Long Term	Inter-state			
39	RAPP C#5 &6	440	Nuclear	Long Term	Inter-state			
40	SECI (Alfanar)		Wind	Long Term	Inter-state			
41	PTC Tuticorin		Wind	Long Term	Inter-state			
42	SECI 1(Acme)		Solar	Long Term	Inter-state			
43	SECI Eden		Solar	Long Term	Inter-state			
44	SECI Azure		Solar	Long Term	Inter-state			
45	Delhi MSW	24	MSW	Long Term	Intra-state			
46	TOWMCL	16	MSW	Long Term	Intra-state			

B. Embedded Generation in DISCOM Area

S.No.	Name of Generation Station	Generation Capacity (In MW)	Based-Solid/Liquid/Gas	Type of Contract	Type of Grid	Voltage Level (KV)	Circle Load (MW)	Received at Circle (KV)	Received at Circle (MU)	Division Level Load (MW)	Received at Division Level (KV)	Received at Division Level (MU)	Sub-Division Level Load (MW)	Received at Sub-Division Level (KV)	Received at Sub-Division Level (MU)	Remarks (Source of data)
1	TOWMCL	16.00	Waste	Longterm PPA	Intrastate	33KV	8.0	33KV	16.87	NA	NA	NA	NA	NA	NA	TOWMCL generating station is connected with BRPL Grid in which Other sources (DTL) are also connected. The Grid feed supply to different divisions and subdivisions hence supply received from TOWMCL at division and subdivision level is not feasible. BRPL share from the TOWMCL is considered as Circle load.
2	Roof Top Solar System	0.10	Solar Energy	Net Metering	Intrastate	11 KV	5.54	11 KV	0.54	0.10	11 KV	0.05	0.10	11 KV	0.00	Rooftop solar system : cumulative capacity is considered as circle/division and subdivision load.
3	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV					0.00	11 KV	0.00	
4	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV					0.00	11 KV	0.05	
5	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV					0.00	11 KV	0.00	
6	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.00	11 KV	0.00				
7	Roof Top Solar System	2.12	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		2.12	11 KV	0.32				
8	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.00	11 KV	0.00				
9	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.00	11 KV	0.00				
9	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.00	11 KV	0.00				
10	Roof Top Solar System	0.61	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.61	11 KV	0.03				
11	Roof Top Solar System	2.71	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		2.71	11 KV	0.14				
12	Roof Top Solar System	0.24	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.24	11 KV	0.00				
13	Roof Top Solar System	0.40	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.40	11 KV	0.06				
14	Roof Top Solar System	0.02	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.02	11 KV	0.03				
15	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.00	11 KV	0.00				
16	Roof Top Solar System	1.48	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		1.48	11 KV	0.04				
17	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.00	11 KV	0.05				
18	Roof Top Solar System	0.37	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.37	11 KV	0.01				
19	Roof Top Solar System	0.51	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.51	11 KV	0.17				
							3.02		0.36							

20	Roof Top Solar System	0.20	Solar Energy	Net Metering	Intrastate	11 KV	6.51	11 KV	0.45	1.63	0.29	0.20	11 KV	0.07
21	Roof Top Solar System	0.10	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				0.10	11 KV	0.00
22	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				0.00	11 KV	0.00
23	Roof Top Solar System	1.33	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				1.33	11 KV	0.22
24	Roof Top Solar System	0.14	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.14	11 KV	0.00		
25	Roof Top Solar System	0.01	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.01	11 KV	0.06		
26	Roof Top Solar System	0.23	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.23	11 KV	0.00		
27	Roof Top Solar System	0.99	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.99	11 KV	0.04		
28	Roof Top Solar System	0.09	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.09	11 KV	0.01		
29	Roof Top Solar System	3.32	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		3.32	11 KV	0.02		
30	Roof Top Solar System	0.11	Solar Energy	Net Metering	Intrastate	11 KV	11 KV	0.11	11 KV	0.01				
31	Roof Top Solar System	1.08	Solar Energy	Net Metering	Intrastate	11 KV	3.55	11 KV	0.41	2.13	0.23	1.08	11 KV	0.18
32	Roof Top Solar System	0.27	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				0.27	11 KV	0.02
33	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				0.00	11 KV	0.00
34	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				0.00	11 KV	0.00
35	Roof Top Solar System	0.65	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.65	11 KV	0.02		
36	Roof Top Solar System	0.13	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.13	11 KV	0.01		
36	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.00	11 KV	0.00		
37	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.00	11 KV	0.00		
38	Roof Top Solar System	0.14	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.14	11 KV	0.15		
39	Roof Top Solar System	0.31	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.31	11 KV	0.00		
40	Roof Top Solar System	0.21	Solar Energy	Net Metering	Intrastate	11 KV	11 KV	0.21	11 KV	0.02				
41	Roof Top Solar System	0.18	Solar Energy	Net Metering	Intrastate	11 KV	11 KV	0.18	11 KV	0.01				
42	Roof Top Solar System	0.58	Solar Energy	Net Metering	Intrastate	11 KV	11 KV	0.58	11 KV	0.00				
43	Roof Top Solar System	0.13	Solar Energy	Net Metering	Intrastate	11 KV	0.80	11 KV	0.12	0.13	11 KV	0.03		
44	Roof Top Solar System	0.06	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.06	11 KV	0.01		
45	Roof Top Solar System	0.29	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.29	11 KV	0.02		

46	Roof Top Solar System	0.20	Solar Energy	Net Metering	Intrastate	11 KV
47	Roof Top Solar System	0.13	Solar Energy	Net Metering	Intrastate	11 KV
48	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV
49	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV
50	Roof Top Solar System	0.55	Solar Energy	Net Metering	Intrastate	11 KV
51	Roof Top Solar System	1.40	Solar Energy	Net Metering	Intrastate	11 KV
52	Roof Top Solar System	0.27	Solar Energy	Net Metering	Intrastate	11 KV
53	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV
54	Roof Top Solar System	4.85	Solar Energy	Net Metering	Intrastate	11 KV
55	Roof Top Solar System	1.78	Solar Energy	Net Metering	Intrastate	11 KV

9.64

11 KV
11 KV
11 KV
11 KV
11 KV
11 KV
11 KV
11 KV
11 KV
11 KV
11 KV
11 KV
11 KV
11 KV
11 KV

1.01

	11 KV		0.20	11 KV	0.06
	11 KV		0.13	11 KV	0.00
1.94	11 KV	0.08	0.00	11 KV	0.00
	11 KV		0.00	11 KV	0.00
	11 KV		0.55	11 KV	0.03
	11 KV		1.40	11 KV	0.05
6.90	11 KV	0.81	0.27	11 KV	0.01
	11 KV		0.00	11 KV	0.01
	11 KV		4.85	11 KV	0.06
	11 KV		1.78	11 KV	0.73

56	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV	0.87	11 KV	0.03	0.19	0.00	0.00	11 KV	0.00
57	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				0.00	11 KV	0.00
58	Roof Top Solar System	0.12	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				0.12	11 KV	0.00
59	Roof Top Solar System	0.07	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				0.07	11 KV	0.00
60	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.64	0.03	0.00	11 KV	0.00
61	Roof Top Solar System	0.06	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				0.06	11 KV	0.00
62	Roof Top Solar System	0.58	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				0.58	11 KV	0.03
63	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.00	0.00	0.00	11 KV	0.00
64	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				0.00	11 KV	0.00
65	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				0.00	11 KV	0.00
66	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.00	0.00	0.00	11 KV	0.00
67	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				0.00	11 KV	0.00
68	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				0.00	11 KV	0.00
69	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.05	0.00	0.00	11 KV	0.00
70	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV				0.00	11 KV	0.00
71	Roof Top Solar System	0.05	Solar Energy	Net Metering	Intrastate	11 KV	11 KV	0.05	11 KV			0.00		
72	Roof Top Solar System	1.55	Solar Energy	Net Metering	Intrastate	11 KV	2.17	11 KV	2.17	0.19	1.55	11 KV	0.12	
73	Roof Top Solar System	0.32	Solar Energy	Net Metering	Intrastate	11 KV					11 KV	0.32	11 KV	0.05
74	Roof Top Solar System	0.30	Solar Energy	Net Metering	Intrastate	11 KV					11 KV	0.30	11 KV	0.02
75	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV	0.00	0.00	0.00	11 KV	0.00	
76	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV			0.00	11 KV	0.00	
77	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV	11 KV	1.28	0.02	0.00	11 KV	0.00		
78	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV	11 KV			0.11	11 KV	0.01		
79	Roof Top Solar System	0.11	Solar Energy	Net Metering	Intrastate	11 KV	11 KV			0.00	11 KV	0.00		
80	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV	11 KV			0.02	11 KV	0.00		
81	Roof Top Solar System	0.02	Solar Energy	Net Metering	Intrastate	11 KV	11 KV			0.00	11 KV	0.00		
82	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV	11 KV	0.00	11 KV	0.00				

83	Roof Top Solar System	0.15	Solar Energy	Net Metering	Intrastate	11 KV	1.46	11 KV	0.05	11 KV	0.18	0.03	0.15	11 KV	0.00
84	Roof Top Solar System	1.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		1.00			11 KV	0.00	
85	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.00			11 KV	0.00	
86	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.00			11 KV	0.00	
87	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.00			11 KV	0.00	
88	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.00			11 KV	0.00	
89	Roof Top Solar System	0.10	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.10			11 KV	0.01	
90	Roof Top Solar System	0.08	Solar Energy	Net Metering	Intrastate	11 KV		11 KV		0.08			11 KV	0.02	
91	Roof Top Solar System	0.12	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV		0.12			0.415KV	0.01	
92	Roof Top Solar System	0.07	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV		0.07			0.415KV	0.02	
93	Roof Top Solar System	1.07	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	1.07	0.415KV	0.06					
94	Roof Top Solar System	0.18	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.18	0.415KV	0.02					
95	Roof Top Solar System	0.30	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.30	0.415KV	0.02					
96	Roof Top Solar System	0.80	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.80	0.415KV	0.10					
97	Roof Top Solar System	0.22	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.22	0.415KV	0.00					
98	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.00	0.415KV	0.00					
98	Roof Top Solar System	0.19	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.19	0.415KV	0.02					
99	Roof Top Solar System	1.22	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	1.22	0.415KV	0.15					
100	Roof Top Solar System	0.17	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.17	0.415KV	0.02					
101	Roof Top Solar System	0.94	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.94	0.415KV	0.15					
102	Roof Top Solar System	0.71	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.71	0.415KV	0.11					
103	Roof Top Solar System	1.30	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	1.30	0.415KV	0.06					
104	Roof Top Solar System	0.54	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.54	0.415KV	0.07					
105	Roof Top Solar System	1.25	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	1.25	0.415KV	0.05					
106	Roof Top Solar System	0.13	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.13	0.415KV	0.02					
107	Roof Top Solar System	0.67	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.67	0.415KV	0.08					
108	Roof Top Solar System	0.82	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.82	0.415KV	0.02					

109	Roof Top Solar System	0.41	Solar Energy	Net Metering	Intrastate	0.415KV	9.80	0.415KV	1.26	2.65	0.36	0.41	0.415KV	0.07
110	Roof Top Solar System	0.82	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV				0.82	0.415KV	0.11
111	Roof Top Solar System	0.75	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV				0.75	0.415KV	0.13
112	Roof Top Solar System	0.67	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV				0.67	0.415KV	0.05
113	Roof Top Solar System	0.60	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV		3.75	0.38	0.60	0.415KV	0.08
114	Roof Top Solar System	1.71	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV				1.71	0.415KV	0.14
115	Roof Top Solar System	1.44	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV				1.44	0.415KV	0.17
116	Roof Top Solar System	0.65	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV		3.40	0.52	0.65	0.415KV	0.09
117	Roof Top Solar System	1.32	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV				1.32	0.415KV	0.26
118	Roof Top Solar System	0.51	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV				0.51	0.415KV	0.03
119	Roof Top Solar System	0.92	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV				0.92	0.415KV	0.14

120	Roof Top Solar System	1.81	Solar Energy	Net Metering	Intrastate	0.415KV	15.22	0.415KV	2.15	9.45	0.415KV	1.44	1.81	0.415KV	0.18
121	Roof Top Solar System	2.01	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV					2.01	0.415KV	0.29
122	Roof Top Solar System	1.27	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV					1.27	0.415KV	0.20
123	Roof Top Solar System	0.74	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV					0.74	0.415KV	0.10
124	Roof Top Solar System	3.08	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV					3.08	0.415KV	0.58
125	Roof Top Solar System	0.54	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV					0.54	0.415KV	0.07
126	Roof Top Solar System	0.00	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV		0.00	0.415KV	0.01			
126	Roof Top Solar System	1.00	Solar Energy	Net Metering	Intrastate	0.415KV		5.77		0.415KV	0.71	1.00	0.415KV	0.05	
127	Roof Top Solar System	1.02	Solar Energy	Net Metering	Intrastate	0.415KV						1.02	0.415KV	0.13	
128	Roof Top Solar System	0.68	Solar Energy	Net Metering	Intrastate	0.415KV						0.68	0.415KV	0.09	
129	Roof Top Solar System	1.11	Solar Energy	Net Metering	Intrastate	0.415KV						1.11	0.415KV	0.20	
130	Roof Top Solar System	1.26	Solar Energy	Net Metering	Intrastate	0.415KV						1.26	0.415KV	0.16	
131	Roof Top Solar System	0.70	Solar Energy	Net Metering	Intrastate	0.415KV						0.70	0.415KV	0.07	
132	Roof Top Solar System	1.05	Solar Energy	Net Metering	Intrastate	0.415KV	12.51	0.415KV	2.02	4.43	0.415KV	0.87	1.05	0.415KV	0.22
133	Roof Top Solar System	1.27	Solar Energy	Net Metering	Intrastate	0.415KV							1.27	0.415KV	0.27
134	Roof Top Solar System	1.05	Solar Energy	Net Metering	Intrastate	0.415KV							1.05	0.415KV	0.17
135	Roof Top Solar System	0.68	Solar Energy	Net Metering	Intrastate	0.415KV							0.68	0.415KV	0.15
136	Roof Top Solar System	0.39	Solar Energy	Net Metering	Intrastate	0.415KV							0.39	0.415KV	0.05
137	Roof Top Solar System	0.14	Solar Energy	Net Metering	Intrastate	0.415KV							0.14	0.415KV	0.09
138	Roof Top Solar System	0.70	Solar Energy	Net Metering	Intrastate	0.415KV				3.49	0.415KV	0.69	0.70	0.415KV	0.21
139	Roof Top Solar System	1.01	Solar Energy	Net Metering	Intrastate	0.415KV							1.01	0.415KV	0.15
140	Roof Top Solar System	1.63	Solar Energy	Net Metering	Intrastate	0.415KV							1.63	0.415KV	0.24
141	Roof Top Solar System	0.36	Solar Energy	Net Metering	Intrastate	0.415KV							0.36	0.415KV	0.02
142	Roof Top Solar System	0.85	Solar Energy	Net Metering	Intrastate	0.415KV							0.85	0.415KV	0.05
143	Roof Top Solar System	0.83	Solar Energy	Net Metering	Intrastate	0.415KV							0.83	0.415KV	0.11
144	Roof Top Solar System	2.55	Solar Energy	Net Metering	Intrastate	0.415KV				4.59	0.415KV	0.47	2.55	0.415KV	0.29
145	Roof Top Solar System	0.32	Solar Energy	Net Metering	Intrastate	0.415KV	0.32	0.415KV	0.05						

146	Roof Top Solar System	0.75	Solar Energy	Net Metering	Intrastate	0.415KV	6.36	0.93	1.76	0.415KV	0.25	0.75	0.415KV	0.12	
147	Roof Top Solar System	0.20	Solar Energy	Net Metering	Intrastate	0.415KV				0.415KV		0.20	0.415KV	0.03	
148	Roof Top Solar System	0.48	Solar Energy	Net Metering	Intrastate	0.415KV				0.415KV		0.48	0.415KV	0.05	
149	Roof Top Solar System	0.35	Solar Energy	Net Metering	Intrastate	0.415KV			0.415KV	2.36	0.415KV	0.39	0.35	0.415KV	0.07
150	Roof Top Solar System	0.86	Solar Energy	Net Metering	Intrastate	0.415KV			0.415KV		0.86		0.415KV	0.15	
151	Roof Top Solar System	1.15	Solar Energy	Net Metering	Intrastate	0.415KV			0.415KV		1.15		0.415KV	0.17	
152	Roof Top Solar System	0.98	Solar Energy	Net Metering	Intrastate	0.415KV			0.415KV	1.47	0.415KV	0.19	0.98	0.415KV	0.13
153	Roof Top Solar System	0.41	Solar Energy	Net Metering	Intrastate	0.415KV			0.415KV		0.41		0.415KV	0.05	
154	Roof Top Solar System	0.08	Solar Energy	Net Metering	Intrastate	0.415KV			0.415KV		0.08		0.415KV	0.01	
155	Roof Top Solar System	0.30	Solar Energy	Net Metering	Intrastate	0.415KV			0.415KV	0.45	0.415KV	0.05	0.30	0.415KV	0.03
156	Roof Top Solar System	0.03	Solar Energy	Net Metering	Intrastate	0.415KV			0.415KV		0.03		0.415KV	0.00	
157	Roof Top Solar System	0.11	Solar Energy	Net Metering	Intrastate	0.415KV			0.415KV		0.11		0.415KV	0.02	
158	Roof Top Solar System	0.15	Solar Energy	Net Metering	Intrastate	0.415KV			0.415KV	0.32	0.415KV	0.05	0.15	0.415KV	0.02
159	Roof Top Solar System	0.10	Solar Energy	Net Metering	Intrastate	0.415KV			0.415KV		0.10		0.415KV	0.02	
160	Roof Top Solar System	0.07	Solar Energy	Net Metering	Intrastate	0.415KV			0.415KV		0.07		0.415KV	0.02	
161	Roof Top Solar System	0.86	Solar Energy	Net Metering	Intrastate	0.415KV			3.49	0.40	1.78	0.415KV	0.23	0.86	0.415KV
162	Roof Top Solar System	0.46	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.46				0.415KV		0.09	
163	Roof Top Solar System	0.45	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.45				0.415KV		0.04	
164	Roof Top Solar System	0.70	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	1.71			0.415KV	0.17	0.70	0.415KV	0.08
165	Roof Top Solar System	0.42	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV		0.42	0.415KV	0.05				
166	Roof Top Solar System	0.59	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV		0.59	0.415KV	0.05				
167	Roof Top Solar System	0.19	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	2.55	0.415KV	0.29	0.19	0.415KV	0.02		
168	Roof Top Solar System	0.31	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV		0.31		0.415KV	0.04			
169	Roof Top Solar System	0.53	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV		0.53		0.415KV	0.05			
170	Roof Top Solar System	0.21	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV		0.21		0.415KV	0.01			
171	Roof Top Solar System	0.48	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV		0.48		0.415KV	0.05			
172	Roof Top Solar System	0.43	Solar Energy	Net Metering	Intrastate	0.415KV	0.415KV	0.43	0.415KV	0.05					

173	Roof Top Solar System	0.40	Solar Energy	Net Metering	Intrastate	0.415KV	5.19	0.415KV	0.39	0.415KV	0.10	0.40	0.415KV	0.06
174	Roof Top Solar System	0.05	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV		0.05		0.415KV	0.00	
175	Roof Top Solar System	1.67	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV		1.67		0.415KV	0.01	
176	Roof Top Solar System	0.04	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV		0.04		0.415KV	0.00	
177	Roof Top Solar System	0.24	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV		0.24		0.415KV	0.02	
178	Roof Top Solar System	0.17	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV		0.17		0.415KV	0.01	
179	Roof Top Solar System	0.48	Solar Energy	Net Metering	Intrastate	0.415KV		0.415KV		0.48		0.415KV	0.05	

(Details of Consumers)- Source of Data Regulatory

Summary of energy sold						
Period From Apr-23 to June-23						
S.No.	Type of Consumers	Category of Consumers (HT/LT/Others)	Voltage Level	No of Consumers	Total Consumption (In MU)	Remarks (Source of data)
1	Domestic	LT	415V	2625420	1977	Form 2.1 A
2	Commercial	LT	415V	358279	537	
3	IP Sets	LT	415V	6334	6	
4	Hor. & Nur. & Coffee/Tea & Rubber (Metered)	-	-			
5	Hor. & Nur. & Coffee/Tea & Rubber (Flat)	-	-			
6	Heating and Motive Power	-	-			
7	Water Supply	LT	415V	4171	24	
8	Public Lighting	LT	415V	7219	30	
9	HT Water Supply	HT	11KV	81	41	
10	HT Industrial	HT	11KV	161	58	
11	Industrial (Small)	LT	415V	5264	82	
12	Industrial (Medium)	-	-			
13	HT Commercial	HT	11KV	1002	298	
14	HT Commercial	EHV	33/66 KV	13		
15	Applicable to Government Hospitals & Hospitals	LT	415V	14	7	
16	Lift Irrigation Schemes/Lift Irrigation Societies	-	-			
17	HT Res. Apartments Applicable to all areas	LT	415V	188	45	
18	Mixed Load	-	-			
19	Government offices and department	-	-			
20	Others-1 (Delhi Metro)	EHV	33/66 KV	9	74	
21	Others-2 (Delhi Airport)	EHV	33/66 KV	2	3	
22	Others-3 (if any , specify in remarks)	LT/HT	415V/11KV	6810	59	
	TOTAL			3014967	3240	

(Details of Feeder-wise losses)

Period From Apr 2023 To June 2023

S.No.	Zone	Received at Circle (In MU)	Received at Division (In MU)	Received at Sub-division (In MU)	Name of the Station	Feeder Code/ID	Feeder Name	Type of Feeder (Urban/Mixed/Industrial/Agricultural/Rural)	Type of feeder meter (AMI/AMR/Other)	Received at Feeder (Final in MU)	Feeder Consumption (in MU)	Final Net Export at Feeder Level (In MU)	T&D losses	AT&C losses	% Data Received through Automaticall y (if feeder AMR/AMI)	Remarks
1	KHAN PUR	509.65	175.57	2.61	66 KV MCIA BADARPUR	SBDPR103	STORM WATER PUMPING STN.	Residential	AMR	2.61	0.72	1.83	2.62%		100%	Feeder Level AT&C Loss Computation: • For computation of AT&C loss, computation of collection efficiency is required. • Collection efficiency is computed based on collected amount from HT & LT consumers against billed amount of HT & LT consumers at division level as per billing cycle where as T&D loss of feeders are calculated based on received energy of feeders level, consumption of HT consumers and net energy exports from the feeders based on calendar months in which consumption of LT consumers, which is significant, are not taken in account. There is no direct correlation between T&D loss of feeders and collection efficiency at division level hence computation of AT&C loss at feeders' level is not feasible. • It is pertinent to note that Hon'ble commission also mandated the T&D and collection efficiency at division level.
2	KHAN PUR			3.26	66 KV MCIA BADARPUR	SBDPR109	PUL PRALADPUR S/STN-1	Mixed	AMR	3.26	0.00	3.20	1.74%		100%	
3	KHAN PUR			3.08	66 KV MCIA BADARPUR	SBDPR121	RAVIDAAS PUL PRAHLADPUR	Residential	AMR	3.08	0.00	3.05	1.01%		100%	
4	KHAN PUR			2.71	66 KV MCIA BADARPUR	SBDPR122	HAMDARD DP (PULPRAHALADPUR)	Mixed	AMR	2.71	0.74	1.93	1.48%		100%	
5	KHAN PUR			2.72	66 KV MCIA BADARPUR	SBDPR126	KISHOR PETROL PUMP PRAHLADPUR	Residential	AMR	2.72	0.00	2.69	1.02%		100%	
6	KHAN PUR			2.84	66 KV TIA BATRA	SBTRA102	11 KV O/G TIGRI KIOSK	Residential	AMR	2.84	0.00	2.80	1.41%		100%	
7	KHAN PUR			3.77	66 KV TIA BATRA	SBTRA103	11 KV O/G D-BLOCK SANGAM VIHAR	Mixed	AMR	3.77	0.00	3.74	1.03%		100%	
8	KHAN PUR			2.66	66 KV TIA BATRA	SBTRA104	11 KV O/G DDA TIGRI	Mixed	AMR	2.66	0.00	2.62	1.49%		100%	
9	KHAN PUR			0.92	66 KV TIA BATRA	SBTRA105	11 KV O/G KHANPUR RMU	Residential	AMR	0.92	0.00	0.91	1.43%		100%	
10	KHAN PUR			2.36	66 KV TIA BATRA	SBTRA106	11 KV O/G DEVL1 EXTN	Residential	AMR	2.36	0.00	2.34	1.14%		100%	
11	KHAN PUR			1.03	66 KV TIA BATRA	SBTRA108	11 KV O/G INSTITUTIONAL AREA	Commercial	AMR	1.03	0.00	0.99	4.00%		100%	
12	KHAN PUR			1.80	66 KV TIA BATRA	SBTRA109	11 KV O/G BATRA HOSPITAL	Public Utilities	AMR	1.80	1.79	0.00	0.33%		100%	
13	KHAN PUR			2.23	66 KV TIA BATRA	SBTRA110	11 KV O/G DAKHSIN PURI S/S NO-3	Residential	AMR	2.23	0.65	1.55	1.29%		100%	
14	KHAN PUR			3.37	66 KV TIA BATRA	SBTRA112	11 KV O/G S/STN - 7 DPURI	Residential	AMR	3.37	0.00	3.34	1.11%		100%	
15	KHAN PUR			3.30	66 KV TIA BATRA	SBTRA113	11 KV O/G S/STN - 2 DPURI	Residential	AMR	3.30	0.00	3.26	1.47%		100%	
16	KHAN PUR			3.49	66 KV TIA BATRA	SBTRA114	11 KV O/G DURGA VIHAR B BLOCK	Residential	AMR	3.49	0.00	3.45	1.10%		100%	
17	KHAN PUR			0.03	66 KV TIA BATRA	SBTRA116	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.01	0.02	0.35%		100%	
18	KHAN PUR			2.15	66 KV TIA BATRA	SBTRA117	A-BLOCK RAJU PARK	Residential	AMR	2.15	0.00	2.12	1.33%		100%	
19	KHAN PUR			3.43	66 KV TIA BATRA	SBTRA118	KHANPUR KHATAWALA	Residential	AMR	3.43	0.00	3.39	1.40%		100%	
20	KHAN PUR			3.85	66 KV TIA BATRA	SBTRA119	B-2/1 MADANGIR	Residential	AMR	3.85	0.00	3.81	0.97%		100%	
21	KHAN PUR			2.85	66 KV TIA BATRA	SBTRA120	E1 MADANGIR PH-1(VIA C BLK MCD SCH)	Residential	AMR	2.85	0.00	2.82	1.10%		100%	
22	KHAN PUR			3.68	66 KV TIA BATRA	SBTRA121	D-SANGAM VIHAR-2	Mixed	AMR	3.68	0.00	3.64	1.14%		100%	
23	KHAN PUR			3.12	66 KV TIA BATRA	SBTRA122	DAKSHINPURI S/STN-5	Residential	AMR	3.12	0.00	3.09	0.86%		100%	
24	KHAN PUR			0.68	66 KV TIA BATRA	SBTRA123	11KV O/G Dr. Karan Singh Shooting Range	Public Utilities	AMR	0.68	0.24	0.43	2.20%		100%	
25	KHAN PUR			2.20	66 KV TIA BATRA	SBTRA124	C-BLOCK TINWALA SANGAM VIHAR	Residential	AMR	2.20	0.00	2.18	1.14%		100%	
26	KHAN PUR			1.62	66 KV TIA BATRA	SBTRA125	L-1A SAGAM VIHAR	Residential	AMR	1.62	0.00	1.59	1.97%		100%	
27	KHAN PUR			0.81	66 KV TIA BATRA	SBTRA126	L-1-15 SAGAM VIHAR	Residential	AMR	0.81	0.00	0.80	1.33%		100%	
28	KHAN PUR			3.09	66 KV IGNOU	SIGNO104	S/STN-3 IGNOU CAMPUS FRD-1	Residential	AMR	3.09	0.00	3.06	1.20%		100%	
29	KHAN PUR			1.91	66 KV MALVIYA NAGAR	SMALV102	11 KV O/G KHANPUR CAMP CENTRE	Residential	AMR	1.91	0.00	1.89	1.24%		100%	
30	KHAN PUR			3.29	66 KV MALVIYA NAGAR	SMALV119	J.J. KHANPUR	Residential	AMR	3.29	0.87	2.39	0.74%		100%	
31	KHAN PUR			3.57	66 KV MALVIYA NAGAR	SMALV127	SCHOOL ROAD MCD KHANPUR	Residential	AMR	3.57	0.00	3.54	0.85%		100%	
32	KHAN PUR			2.77	66 KV MALVIYA NAGAR	SMALV129	A-BLOCK, JAWAHAR PARK	Residential	AMR	2.77	0.00	2.74	1.36%		100%	
33	KHAN PUR			0.32	66 KV MALVIYA NAGAR	SMALV137	11KV AMBEDKAR HOSPITAL NO-1	Commercial	AMR	0.32	0.31	0.00	1.44%		100%	
34	KHAN PUR			2.42	66 KV OKHLA PH 1	SOKH1106	O/H HOT MIX PLANT PHASE 1	Mixed	AMR	2.42	0.68	1.70	1.34%		100%	
35	KHAN PUR			3.33	66 KV OKHLA PH 1	SOKH1134	11 KV O/G I BLOCK LAL KAUN	Mixed	AMR	3.33	0.00	3.28	1.61%		100%	
36	KHAN PUR			2.28	33 KV PUSP VIHAR	SPUSP120	S/STN NO-5 DAKSHINPURI	Residential	AMR	2.28	0.00	2.24	1.63%		100%	
37	KHAN PUR			2.61	33 KV PUSP VIHAR	SPUSP121	S/STN MATRIKA DAKSHINPURI	Residential	AMR	2.61	0.00	2.58	1.50%		100%	
38	KHAN PUR			3.75	33 KV PUSP VIHAR	SPUSP122	S/STN NO-4 DAKSHINPURI	Residential	AMR	3.75	0.00	3.71	1.14%		100%	
39	KHAN PUR			1.85	33 KV D C SAKET	SSAKT105	L.S.C.NO.1 M/GIR	Mixed	AMR	1.85	0.00	1.78	3.48%		100%	
40	KHAN PUR			2.00	33 KV D C SAKET	SSAKT107	M.GIR S/STN NO1	Residential	AMR	2.00	0.00	1.96	1.64%		100%	
41	KHAN PUR			2.58	33 KV D C SAKET	SSAKT110	DDA FLATE M/GIR GALI NO-20	Residential	AMR	2.58	0.00	2.56	0.74%		100%	
42	KHAN PUR			2.56	33 KV D C SAKET	SSAKT113	L.S.C.NO.II M/GIR (VIA S/S NO.-15)	Mixed	AMR	2.56	0.00	2.49	2.69%		100%	

43	KHAN PUR
44	KHAN PUR
45	KHAN PUR
46	KHAN PUR
47	KHAN PUR
48	KHAN PUR
49	KHAN PUR
50	KHAN PUR
51	KHAN PUR
52	KHAN PUR
53	KHAN PUR
54	KHAN PUR
55	KHAN PUR
56	KHAN PUR
57	KHAN PUR
58	KHAN PUR
59	KHAN PUR
60	KHAN PUR
61	KHAN PUR
62	KHAN PUR
63	KHAN PUR
64	KHAN PUR
65	KHAN PUR
66	KHAN PUR
67	KHAN PUR
68	KHAN PUR
69	KHAN PUR
70	KHAN PUR
71	KHAN PUR
72	NEW FRIENDS COLONY
73	NEW FRIENDS COLONY
74	NEW FRIENDS COLONY
75	NEW FRIENDS COLONY
76	NEW FRIENDS COLONY
77	NEW FRIENDS COLONY
78	NEW FRIENDS COLONY
79	NEW FRIENDS COLONY
80	NEW FRIENDS COLONY

176.97

2.84	66 KV SANGAM VIHAR	SSNGM113	B&C BLK JAWAHAR PARK	Residential	AMR	2.84	0.00	2.80	1.37%	100%
4.09	66 KV SANGAM VIHAR	SSNGM114	J-2B MAKHAN CHOR	Residential	AMR	4.09	0.00	3.97	2.77%	100%
0.03	66 KV SANGAM VIHAR	SSNGM125	11 KV LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	0.39%	100%
4.09	66 KV SANGAM VIHAR	SSNGM126	L BLOCK SAINIWALA	Mixed	AMR	4.09	0.00	4.06	0.91%	100%
2.11	66 KV SANGAM VIHAR	SSNGM127	SAGWAN	Mixed	AMR	2.11	0.00	2.08	1.32%	100%
2.35	66 KV SANGAM VIHAR	SSNGM128	DEVLI JHOR	Mixed	AMR	2.35	0.00	2.32	1.08%	100%
4.72	66 KV SANGAM VIHAR	SSNGM129	C-2 RAJU PARK	Residential	AMR	2.72	0.00	2.66	2.13%	100%
4.22	66 KV SANGAM VIHAR	SSNGM145	JHEELWALA	Mixed	AMR	4.22	0.00	4.19	0.61%	100%
2.73	33 KV Tuglakabad	STLBD103	JAMIA HAMDARD	Public Utilities	AMR	2.73	0.76	1.94	1.04%	100%
2.96	33 KV Tuglakabad	STLBD104	DMS (TRUST)	Residential	AMR	2.96	0.00	2.93	1.02%	100%
4.41	33 KV Tuglakabad	STLBD106	11 KV O/G D-BLOCK SANGAM VIHAR S/ST	Residential	AMR	4.41	0.00	4.35	1.43%	100%
2.87	33 KV Tuglakabad	STLBD107	S/STN H BLOCK TIGRI	Residential	AMR	2.87	0.00	2.83	1.33%	100%
0.80	33 KV Tuglakabad	STLBD108	11 KV O/G INSTITUTIONAL AREA NO-1	Commercial	AMR	0.80	0.27	0.52	1.05%	100%
3.66	33 KV Tuglakabad	STLBD109	O/G TO SANGAM VIHAR S/STN-1 F-1	Residential	AMR	3.66	0.00	3.60	1.65%	100%
4.19	33 KV Tuglakabad	STLBD110	G & H BLOCK SANGAM VIHAR	Residential	AMR	4.19	0.00	4.16	0.61%	100%
1.00	33 KV Tuglakabad	STLBD117	VAYU SENABAD	Residential	AMR	1.00	0.30	0.68	1.85%	100%
2.82	33 KV Tuglakabad	STLBD120	O/G TIGRI J.J.KHANPUR	Residential	AMR	2.82	0.00	2.77	1.76%	100%
1.04	33 KV Tuglakabad	STLBD121	DAKSHANPUR S/STN-2(NEW)	Residential	AMR	1.04	0.00	1.02	2.37%	100%
1.88	33 KV Tuglakabad	STLBD122	LAL KAUN	Mixed	AMR	1.88	0.00	1.84	2.12%	100%
3.69	33 KV Tuglakabad	STLBD123	11KV DR,KARANI SINGH SHOOTING RANGE	Residential	AMR	3.69	0.98	2.61	2.80%	100%
0.51	33 KV Tuglakabad	STLBD124	11 KV O/G MES NO 2	Residential	AMR	0.51	0.18	0.33	1.55%	100%
0.49	33 KV Tuglakabad	STLBD125	O/G BATRA HOSPITAL	Public Utilities	AMR	0.49	0.48	0.00	0.61%	100%
2.73	33 KV Tuglakabad	STLBD127	F-1 S/S NO.2 SANGAM VIHAR	Residential	AMR	2.73	0.00	2.68	1.90%	100%
0.34	33 KV Tuglakabad	STLBD130	E/O 325 RES FLATS AT ITBP CAMPUS	Mixed	AMR	0.34	0.09	0.25	0.33%	100%
3.16	33 KV Tuglakabad	STLBD131	RMU IN GRID	Residential	AMR	3.16	0.00	3.08	2.50%	100%
1.84	33 KV Tuglakabad	STLBD132	H-16 RAMNIWAS DP	Mixed	AMR	1.84	0.00	1.80	1.89%	100%
4.34	33 KV Tuglakabad	STLBD312	G- 2,K-19 SANGAM VIHAR	Residential	AMR	4.34	0.00	4.28	1.39%	100%
2.73	33 KV Tuglakabad	STLBD313	O/G SANGAM VIHAR F-2 PLINTH MOUNTED	Residential	AMR	2.73	0.00	2.70	1.05%	100%
0.02	33 KV Tuglakabad	STLBD316	100 KVA LOCAL TRANSFORMER PML NO-4	Local Grid	AMR	0.02	0.00	0.02	0.26%	100%
1.71	33 KV JAMIA MILIYA	SJAMI101	11 KV O/G GAFAR MANZIL	Residential	AMR	1.71	0.51	1.17	1.46%	100%
2.98	33 KV JAMIA MILIYA	SJAMI103	11 KV O/G OKHLA VILLEGE	Residential	AMR	2.98	0.84	2.13	0.36%	100%
1.53	33 KV JAMIA MILIYA	SJAMI104	11 KV O/G FILTRATION PLANT	Commercial	AMR	1.53	0.00	1.53	0.06%	100%
3.76	33 KV JAMIA MILIYA	SJAMI105	11 KV O/G ZAKIR NAGAR	Residential	AMR	3.76	0.00	3.73	0.99%	100%
0.02	33 KV JAMIA MILIYA	SJAMI106	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.19%	100%
2.15	33 KV JAMIA MILIYA	SJAMI108	RMU Jamia(Dempo+Jakir Nagar West)	Residential	AMR	2.15	0.00	2.14	0.82%	100%
4.14	33 KV JAMIA MILIYA	SJAMI109	11kv Noor Nagar	Residential	AMR	4.14	0.00	4.13	0.24%	100%
1.30	33 KV JAMIA MILIYA	SJAMI110	11KV O/G DENTAL MEDICAL COLLEGE - 2	Mixed	AMR	1.30	0.42	0.86	1.92%	100%
3.23	33 KV JAMIA MILIYA	SJAMI111	11kv Sanjay Jheel	Residential	AMR	3.23	0.00	3.20	0.90%	100%

81	NEW FRIENDS COLONY
82	NEW FRIENDS COLONY
83	NEW FRIENDS COLONY
84	NEW FRIENDS COLONY
85	NEW FRIENDS COLONY
86	NEW FRIENDS COLONY
87	NEW FRIENDS COLONY
88	NEW FRIENDS COLONY
89	NEW FRIENDS COLONY
90	NEW FRIENDS COLONY
91	NEW FRIENDS COLONY
92	NEW FRIENDS COLONY
93	NEW FRIENDS COLONY
94	NEW FRIENDS COLONY
95	NEW FRIENDS COLONY
96	NEW FRIENDS COLONY
97	NEW FRIENDS COLONY
98	NEW FRIENDS COLONY
99	NEW FRIENDS COLONY
100	NEW FRIENDS COLONY
101	NEW FRIENDS COLONY
102	NEW FRIENDS COLONY
103	NEW FRIENDS COLONY

3.27	33 KV JAMIA MILIYA	SJAMI113	11KV DELHI JAL BOARD	Mixed	AMR	3.27	0.92	2.31	1.09%	100%
3.80	33 KV JAMIA MILIYA	SJAMI114	RMU NO-3 GALI NO-22 ZAKIR NAGAR	Commercial	AMR	3.80	1.04	2.71	1.47%	100%
3.04	33 KV JAMIA MILIYA	SJAMI115	11KV O/G JAMIA STADIUM	Residential	AMR	3.04	0.00	3.01	0.99%	100%
0.00	33 KV JAMIA MILIYA	SJAMI118	11 KV O/G LOCAL TRANSFORMER NO. 2	Local Grid	AMR	0.00	0.00	0.00	0.00%	100%
4.34	33 KV JAMIA MILIYA	SJAMI119	11 KV O/G OKHLA VIHAR MASJID	Residential	AMR	4.34	1.20	3.12	0.23%	100%
4.20	33 KV JAMIA MILIYA	SJAMI120	11 KV O/G P BLOCK NAFEES ROAD	Residential	AMR	4.20	0.00	4.19	0.24%	100%
2.93	33 KV JAMIA MILIYA	SJAMI121	11 KV O/G MEHBOOB NAGAR VIA RAHAMII MASZID	Residential	AMR	2.93	0.00	2.89	1.44%	100%
5.31	33 KV JAMIA MILIYA	SJAMI123	B BLOCK ABUL FAZAL	Mixed	AMR	5.31	0.00	5.28	0.44%	100%
3.44	33 KV JAMIA MILIYA	SJAMI125	11 KV O/G KHAZOORI ROAD	Residential	AMR	3.44	0.00	3.38	1.68%	100%
0.28	66 KV JASOLA GRID	SJASL110	S/STN -4 SEC-33 JASOLA	Commercial	AMR	0.28	0.07	0.20	1.77%	100%
0.88	66 KV JASOLA GRID	SJASL111	O/G PLOT NO. 8	Residential	AMR	0.88	0.28	0.58	2.61%	100%
1.04	66 KV JASOLA GRID	SJASL112	O/G PLOT NO.6 D C JASOLA	Residential	AMR	1.04	1.04	0.00	0.17%	100%
0.57	66 KV JASOLA GRID	SJASL113	S/STN NO 2 SC 33 JASOLA	Commercial	AMR	0.57	0.21	0.35	1.85%	100%
0.42	66 KV JASOLA GRID	SJASL114	O/G PLOT NO.9 D C JASOLA	Residential	AMR	0.42	0.11	0.30	2.71%	100%
1.96	66 KV JASOLA GRID	SJASL115	RMU-1 JASOLA	Mixed	AMR	1.96	0.58	1.36	1.32%	100%
2.10	66 KV JASOLA GRID	SJASL116	S/STN-1 PKT-1 JASOLA	Residential	AMR	2.10	0.00	2.07	1.36%	100%
2.46	66 KV JASOLA GRID	SJASL117	JASOLA SPORTS COMPLEX	Mixed	AMR	2.46	0.70	1.74	1.24%	100%
0.02	66 KV JASOLA GRID	SJASL118	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.33%	100%
0.60	66 KV JASOLA GRID	SJASL128	A1 REALTOR	Commercial	AMR	0.60	0.22	0.38	0.35%	100%
0.83	66 KV JASOLA GRID	SJASL129	11kv DLF Blk B	Commercial	AMR	0.83	0.28	0.55	0.95%	100%
0.99	66 KV JASOLA GRID	SJASL130	11KV DLF BLK A	Commercial	AMR	0.99	0.99	0.00	0.48%	100%
3.81	66 KV JASOLA GRID	SJASL131	RMU-3	Commercial	AMR	3.81	0.00	3.77	1.03%	100%
0.86	66 KV JASOLA GRID	SJASL132	11KV IGIB NO-1	Commercial	AMR	0.86	0.86	0.00	0.33%	100%

104	NEW FRIENDS COLONY
105	NEW FRIENDS COLONY
106	NEW FRIENDS COLONY
107	NEW FRIENDS COLONY
108	NEW FRIENDS COLONY
109	NEW FRIENDS COLONY
110	NEW FRIENDS COLONY
111	NEW FRIENDS COLONY
112	NEW FRIENDS COLONY
113	NEW FRIENDS COLONY
114	NEW FRIENDS COLONY
115	NEW FRIENDS COLONY
116	NEW FRIENDS COLONY
117	NEW FRIENDS COLONY
118	NEW FRIENDS COLONY
119	NEW FRIENDS COLONY
120	NEW FRIENDS COLONY
121	NEW FRIENDS COLONY
122	NEW FRIENDS COLONY
123	NEW FRIENDS COLONY
124	NEW FRIENDS COLONY
125	NEW FRIENDS COLONY
126	NEW FRIENDS COLONY

0.14	66 KV JASOLA GRID	SJASL133	11KV IGIB NO-2	Commercial	AMR	0.14	0.14	0.00	0.33%	100%
2.42	66 KV JASOLA GRID	SJASL134	11KV RMU-2	Mixed	AMR	2.42	0.68	1.71	1.31%	100%
4.14	66 KV JASOLA GRID	SJASL135	THOKAR NO.6 NR P CHOKI SHAHEEN BAGH	Residential	AMR	4.14	0.00	4.09	1.10%	100%
0.84	66 KV JASOLA GRID	SJASL136	UDHYOG SHEEL MAHILA	Commercial	AMR	0.84	0.27	0.57	0.87%	100%
2.81	33 KV Kilokari	SKKRI103	11 KV O/G NEW FRIEND COLONY	Residential	AMR	2.81	0.00	2.78	1.05%	100%
1.76	33 KV Kilokari	SKKRI104	11 KV O/G MAHARANI BAG - 1	Residential	AMR	1.76	0.52	1.23	0.58%	100%
3.46	33 KV Kilokari	SKKRI105	11 KV O/G MAHARANI BAG - 2	Residential	AMR	3.46	0.00	3.41	1.52%	100%
1.94	33 KV Kilokari	SKKRI109	11 KV O/G SRI NIWASPURI O/H	Residential	AMR	1.94	0.00	1.92	1.13%	100%
2.62	33 KV EAST OF KAILASH	SKLSH102	O/G SIRI NIWAS PURI	Residential	AMR	2.62	0.75	1.87	0.13%	100%
1.09	33 KV LAJPAT NAGAR	SLJPT111	NURSING STAFF QTRS. S.N.PURI FED-2	Residential	AMR	1.09	0.35	0.73	0.85%	100%
2.62	66 KV MATHURA ROAD	SMTRD107	OKHLA SEWAGE	Residential	AMR	2.62	0.74	1.86	0.56%	100%
3.64	66 KV MATHURA ROAD	SMTRD108	APOLLO HOSPITAL	Commercial	AMR	3.64	3.62	0.00	0.55%	100%
1.00	66 KV MATHURA ROAD	SMTRD110	B-BLOCK FRIENDS COLONY	Residential	AMR	1.00	0.31	0.67	0.90%	100%
0.27	66 KV MATHURA ROAD	SMTRD111	GEETA NURSERY	Residential	AMR	0.27	0.07	0.20	1.58%	100%
2.73	66 KV SARITA VIHAR	SSARI102	F- BLOCK MOTHER DIARY SHAHEEN BAGH	Residential	AMR	2.73	0.00	2.71	0.54%	100%
0.48	66 KV SARITA VIHAR	SSARI105	O/G APPOLLO HOSPITAL	Commercial	AMR	0.48	0.48	0.00	0.55%	100%
2.30	66 KV SARITA VIHAR	SSARI107	DDA JASOLA S/STN NO.2	Residential	AMR	2.30	0.65	1.63	0.89%	100%
0.55	66 KV SARITA VIHAR	SSARI108	DDA JASOLA S/STN NO.1	Residential	AMR	0.55	0.14	0.40	0.90%	100%
3.28	66 KV SARITA VIHAR	SSARI109	O/G SAHEEN BAGH	Residential	AMR	3.28	0.00	3.24	1.28%	100%
4.07	66 KV SARITA VIHAR	SSARI119	N BLOCK ABUL FAZAL ENCLAVE	Residential	AMR	4.07	1.14	2.92	0.25%	100%
2.38	66 KV SARITA VIHAR	SSARI120	G4 SAHEEN BAGH	Residential	AMR	2.38	0.00	2.38	0.08%	100%
2.74	66 KV SARITA VIHAR	SSARI121	11 KV O/G THOKAR NO. 5	Residential	AMR	2.74	0.00	2.69	1.55%	100%
4.31	66 KV SARITA VIHAR	SSARI122	11 KV O/G ABUBAKR MAJID	Residential	AMR	4.31	0.00	4.26	1.10%	100%

127	NEW FRIENDS COLONY
128	NEW FRIENDS COLONY
129	NEW FRIENDS COLONY
130	NEW FRIENDS COLONY
131	NEW FRIENDS COLONY
132	NEW FRIENDS COLONY
133	NEW FRIENDS COLONY
134	NEW FRIENDS COLONY
135	NEW FRIENDS COLONY
136	NEW FRIENDS COLONY
137	NEW FRIENDS COLONY
138	NEW FRIENDS COLONY
139	NEW FRIENDS COLONY
140	NEW FRIENDS COLONY
141	NEW FRIENDS COLONY
142	NEW FRIENDS COLONY
143	NEW FRIENDS COLONY
144	NEW FRIENDS COLONY
145	NEW FRIENDS COLONY
146	NEW FRIENDS COLONY
147	NEW FRIENDS COLONY
148	NEW FRIENDS COLONY
149	NEW FRIENDS COLONY

3.97	66 KV SARITA VIHAR	SSARI123	11 KV O/G D BLOCK SAHEEN BAGH	Residential	AMR	3.97	0.00	3.96	0.25%	100%
3.43	66 KV SARITA VIHAR	SSARI125	ABUL FAZAL ENCLAVE M BLOCK	Residential	AMR	3.43	0.00	3.42	0.29%	100%
1.53	33 KV Sarai Jullena	SSJNA101	11 KV O/G D.D.A FLAT SARAI JULLENA	Residential	AMR	1.53	0.00	1.52	0.85%	100%
5.18	33 KV Sarai Jullena	SSJNA102	11 KV O/G ESCORT HEART INST. No-2	Mixed	AMR	5.18	1.42	3.72	0.70%	100%
2.79	33 KV Sarai Jullena	SSJNA103	S/S NO-5 N F C	Mixed	AMR	2.79	0.78	1.98	1.18%	100%
2.87	33 KV Sarai Jullena	SSJNA104	11 KV O/G B-BLOCK FRIENDS COLONY	Residential	AMR	2.87	0.82	2.04	0.35%	100%
5.39	33 KV Sarai Jullena	SSJNA105	11 KV O/G TAMOOR NAGAR	Residential	AMR	5.39	1.52	3.86	0.19%	100%
0.42	33 KV Sarai Jullena	SSJNA106	11 KV O/G JMI FACULTY CENTRE	Commercial	AMR	0.42	0.11	0.31	1.17%	100%
4.51	33 KV Sarai Jullena	SSJNA107	JAMIA PLAINTH S/S	Mixed	AMR	4.51	0.00	4.46	1.11%	100%
0.73	33 KV Sarai Jullena	SSJNA108	11 KV O/G SUKHDEV VIHAR	Residential	AMR	0.73	0.24	0.48	0.35%	100%
2.30	33 KV Sarai Jullena	SSJNA109	11 KV O/G OKHLA FILTRATION PLANT.	Commercial	AMR	2.30	0.64	1.62	1.52%	100%
1.51	33 KV Sarai Jullena	SSJNA110	11 KV O/G ESCORT HEART INST. No-1	Commercial	AMR	1.51	0.44	1.06	0.03%	100%
1.69	33 KV Sarai Jullena	SSJNA111	11 KV O/G C.S.I.R STAFF QRS.	Residential	AMR	1.69	0.50	1.17	0.96%	100%
2.71	33 KV Sarai Jullena	SSJNA112	11 KV O/G S/STN NO 6 NFC	Residential	AMR	2.71	0.76	1.92	1.46%	100%
3.66	33 KV Sarai Jullena	SSJNA113	11 KV O/G BATLA HOUSE SEWAGE PUMPIN	Residential	AMR	3.66	1.01	2.60	1.21%	100%
1.43	33 KV Sarai Jullena	SSJNA114	11 KV O/G M.R. CHILDREN	Commercial	AMR	1.43	0.43	0.98	0.66%	100%
4.00	33 KV Sarai Jullena	SSJNA115	11 KV O/G S/STN NO 3 NEW FRIENDS CO	Residential	AMR	4.00	0.00	3.98	0.37%	100%
2.14	33 KV Sarai Jullena	SSJNA116	11 KV O/G COMMUNITY CENTRE	Commercial	AMR	2.14	0.61	1.50	1.06%	100%
0.56	33 KV Sarai Jullena	SSJNA119	TATA TELE SERVICES	Commercial	AMR	0.56	0.21	0.35	1.19%	100%
3.15	33 KV Sarai Jullena	SSJNA120	11 KV O/G OKHLA SEWAGE DISPOSAL PLA	Commercial	AMR	3.15	0.87	2.23	1.48%	100%
0.01	33 KV Sarai Jullena	SSJNA121	LOCAL TRANSFORMER	Local Grid	AMR	0.01	0.00	0.01	0.40%	100%
0.12	33 KV Sarai Jullena	SSJNA122	11KV JAMIYA SPORT COMPLEX	Commercial	AMR	0.12	0.03	0.08	2.47%	100%
1.54	33 KV Sarai Jullena	SSJNA123	SDMC CAR PARKING NFC	Mixed	AMR	1.54	0.47	1.07	0.39%	100%

150	NEW FRIENDS COLONY	1.79	33 KV Sarai Jullena	SSJNA125	SFS NO.-1 SUKHDEV VIHAR	Mixed	AMR	1.79	0.52	1.26	0.60%	100%
151	SARITA VIHAR	10.47	220 KV SARITA VIHAR GRID	150011442	66 KV DMRC-2 SARITA VIHAR	Commercial	AMR	10.47	10.43	0.00	0.37%	100%
152	SARITA VIHAR	2.53	66 KV MCIA BADARPUR	SBDRP101	4 POLE POLICE STATION	Residential	AMR	2.53	0.62	1.89	0.77%	100%
153	SARITA VIHAR	0.25	66 KV MCIA BADARPUR	SBDRP102	DP- N.T.P.C	Residential	AMR	0.25	0.00	0.24	2.40%	100%
154	SARITA VIHAR	3.91	66 KV MCIA BADARPUR	SBDRP104	S/STN NO. - 5 MB EXTN.	Residential	AMR	3.91	0.00	3.88	0.82%	100%
155	SARITA VIHAR	3.85	66 KV MCIA BADARPUR	SBDRP105	S/STN NO. 3 M.B EXTN.	Residential	AMR	3.85	0.00	3.84	0.26%	100%
156	SARITA VIHAR	0.96	66 KV MCIA BADARPUR	SBDRP106	PM OPP. B-II/66 MCIE	Commercial	AMR	0.96	0.21	0.74	0.81%	100%
157	SARITA VIHAR	0.26	66 KV MCIA BADARPUR	SBDRP107	HONDA CITY SERVICE	Commercial	AMR	0.26	0.07	0.19	2.65%	100%
158	SARITA VIHAR	3.13	66 KV MCIA BADARPUR	SBDRP108	D.P.S.K.S	Residential	AMR	3.13	0.75	2.33	1.49%	100%
159	SARITA VIHAR	1.94	66 KV MCIA BADARPUR	SBDRP110	S/STN NO.5 M.C.I.E	Commercial	AMR	1.94	0.44	1.48	1.20%	100%
160	SARITA VIHAR	4.09	66 KV MCIA BADARPUR	SBDRP113	WATER PUMPING S/STN MITHAPUR	Residential	AMR	4.09	0.00	4.08	0.24%	100%
161	SARITA VIHAR	0.02	66 KV MCIA BADARPUR	SBDRP116	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.24%	100%
162	SARITA VIHAR	3.88	66 KV MCIA BADARPUR	SBDRP119	11KV NEHRU MARKET	Residential	AMR	3.88	0.00	3.87	0.26%	100%
163	SARITA VIHAR	4.98	66 KV MCIA BADARPUR	SBDRP120	S/STN NO.2 M.B. EXT.(O/G FEEDER)	Residential	AMR	4.98	0.00	4.97	0.20%	100%
164	SARITA VIHAR	4.86	66 KV MCIA BADARPUR	SBDRP123	11 KV O/G MEETHAPUR AGARWAL DHRAMSALA	Residential	AMR	4.86	0.00	4.82	0.83%	100%
165	SARITA VIHAR	4.37	66 KV MCIA BADARPUR	SBDRP124	11 KV O/G LUV KUSH D.P	Residential	AMR	4.37	0.00	4.32	1.10%	100%
166	SARITA VIHAR	2.37	66 KV MCIA BADARPUR	SBDRP125	BADARPUR THANA	Residential	AMR	2.37	0.55	1.77	1.85%	100%
167	SARITA VIHAR	3.76	66 KV MEETHA PUR	SMTPR101	11KV O/G GYAN MANDIR	Residential	AMR	3.76	0.00	3.70	1.48%	100%
168	SARITA VIHAR	3.20	66 KV MEETHA PUR	SMTPR102	H BLOCK KHADDA COLONY	Residential	AMR	3.20	0.00	3.15	1.37%	100%
169	SARITA VIHAR	5.04	66 KV MEETHA PUR	SMTPR103	11KV O/ MADRASI COLONY	Residential	AMR	5.04	0.00	5.03	0.21%	100%
170	SARITA VIHAR	3.80	66 KV MEETHA PUR	SMTPR104	PUSTA ROAD KHADDA COLONY	Residential	AMR	3.80	0.00	3.76	1.23%	100%
171	SARITA VIHAR	1.27	66 KV MEETHA PUR	SMTPR105	SR. SEC. SCHOOL MEETHAPUR	Mixed	AMR	1.27	0.00	1.26	0.81%	100%
172	SARITA VIHAR	4.67	66 KV MEETHA PUR	SMTPR106	11KV O/G ABC BLK. OM NAGAR	Residential	AMR	4.67	1.05	3.61	0.21%	100%
173	SARITA VIHAR	0.77	66 KV MEETHA PUR	SMTPR109	MANBHARI KUNJ	Mixed	AMR	0.77	0.00	0.76	0.64%	100%
174	SARITA VIHAR	2.11	66 KV MEETHA PUR	SMTPR112	SHARDA KUNJ A-BLK OM NAGAR	Mixed	AMR	2.11	0.00	2.08	1.31%	100%
175	SARITA VIHAR	3.51	66 KV MEETHA PUR	SMTPR113	HARI NAGAR PART 2	Mixed	AMR	3.51	0.73	2.73	1.55%	100%
176	SARITA VIHAR	2.39	66 KV MEETHA PUR	SMTPR114	11KV OM NAGAR BARAT GHAR	Residential	AMR	2.39	0.00	2.36	1.38%	100%
177	SARITA VIHAR	3.66	66 KV MEETHA PUR	SMTPR115	11KV LAKHPAT COLONY PART-II	Residential	AMR	3.66	0.00	3.61	1.29%	100%
178	SARITA VIHAR	2.77	66 KV MEETHA PUR	SMTPR116	HARIJAN BASTI	Residential	AMR	2.77	0.00	2.73	1.55%	100%
179	SARITA VIHAR	0.02	66 KV MEETHA PUR	SMTPR121	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.20%	100%
180	SARITA VIHAR	3.19	66 KV MATHURA ROAD	SMTRD104	SARITA VIHAR S/STN - 4	Residential	AMR	3.19	0.76	2.42	0.31%	100%
181	SARITA VIHAR	0.31	66 KV MATHURA ROAD	SMTRD105	11KV O/G Mohan Baba Nagar-1	Commercial	AMR	0.31	0.00	0.31	1.13%	100%
182	SARITA VIHAR	1.79	66 KV MATHURA ROAD	SMTRD106	BADARPUR O/H	Commercial	AMR	1.79	0.41	1.36	1.44%	100%
183	SARITA VIHAR	1.55	66 KV MATHURA ROAD	SMTRD109	MCIE	Commercial	AMR	1.55	0.35	1.18	1.45%	100%
184	SARITA VIHAR	0.74	66 KV MATHURA ROAD	SMTRD112	SUKHDEV VIHAR O/H	Commercial	AMR	0.74	0.25	0.47	2.10%	100%
185	SARITA VIHAR	1.85	66 KV MATHURA ROAD	SMTRD113	S/STN NO. 8 SARITA VIHAR	Residential	AMR	1.85	0.00	1.83	1.28%	100%
186	SARITA VIHAR	0.72	66 KV MATHURA ROAD	SMTRD114	O/G S/Stn-1 MCIE	Commercial	AMR	0.72	0.00	0.71	1.58%	100%
187	SARITA VIHAR	0.01	66 KV MATHURA ROAD	SMTRD116	LOCAL TRANSFORMER	Local Grid	AMR	0.01	0.00	0.01	0.39%	100%
188	SARITA VIHAR	1.07	66 KV MATHURA ROAD	SMTRD118	A 26/5,MCIE IDEA CELLULAR	Commercial	AMR	1.07	1.07	0.00	0.24%	100%
189	SARITA VIHAR	0.94	66 KV MATHURA ROAD	SMTRD119	O/G S/Stn-2 MCIE	Commercial	AMR	0.94	0.21	0.70	3.72%	100%
190	SARITA VIHAR	0.14	66 KV MATHURA ROAD	SMTRD120	11KV O/G A 3 MCIE	Commercial	AMR	0.14	0.04	0.10	2.35%	100%
191	SARITA VIHAR	0.08	66 KV MATHURA ROAD	SMTRD121	11KV O/G MOHAN BABA NAGAR-2	Commercial	AMR	0.08	0.00	0.07	0.55%	100%
192	SARITA VIHAR	0.44	66 KV MATHURA ROAD	SMTRD122	DMRC FLAT SARITA	Residential	AMR	0.44	0.12	0.32	0.96%	100%
193	SARITA VIHAR	4.19	66 KV MATHURA ROAD	SMTRD123	LIG DDA FLAT-2 MOLAR BAND	Residential	AMR	4.19	0.93	3.25	0.24%	100%
194	SARITA VIHAR	1.62	66 KV MATHURA ROAD	SMTRD124	LIG DDA FLAT-1 MOLAR BAND	Residential	AMR	1.62	0.37	1.22	1.34%	100%
195	SARITA VIHAR	0.95	66 KV MATHURA ROAD	SMTRD125	F/O AYUSH MEDICAL COLLEGE MOREBAND	Public Utilities	AMR	0.95	0.21	0.73	0.70%	100%
196	SARITA VIHAR	1.95	66 KV MATHURA ROAD	SMTRD126	O/G A-26/1 MCIE	Commercial	AMR	1.95	0.44	1.49	0.86%	100%
197	SARITA VIHAR	1.08	66 KV MATHURA ROAD	SMTRD127	O/G B-1/H-8 MCIE HALDI RAM	Commercial	AMR	1.08	0.22	0.85	1.01%	100%
198	SARITA VIHAR	1.96	66 KV MATHURA ROAD	SMTRD128	S/STN- 3, MCIE B-1 BLOCK	Commercial	AMR	1.96	0.47	1.47	1.35%	100%
199	SARITA VIHAR	3.96	66 KV MATHURA ROAD	SMTRD129	11KV O/G PRIYANKA CAMP	Residential	AMR	3.96	0.00	3.91	1.31%	100%
200	SARITA VIHAR	4.68	66 KV MATHURA ROAD	SMTRD130	11KV OG S/S NO. 22 SARITA VIHAR	Residential	AMR	4.68	0.00	4.62	1.17%	100%
201	SARITA VIHAR	2.14	66 KV SARITA VIHAR	SSARI101	11 KV O/G S/STN NO18 S VIHAR	Residential	AMR	2.14	0.51	1.60	1.37%	100%
202	SARITA VIHAR	1.06	66 KV SARITA VIHAR	SSARI103	11 KV O/G AMERICAN EXPRESS	Commercial	AMR	1.06	0.21	0.80	4.54%	100%

203	SARITA VIHAR		4.58	66 KV SARITA VIHAR	SSARI104	MADANPUR KHADAR TRANS-II	Residential	AMR	4.58	0.00	4.57	0.22%	100%	
204	SARITA VIHAR		3.35	66 KV SARITA VIHAR	SSARI106	S/STN 13 SARITA VIHAR	Residential	AMR	3.35	0.81	2.53	0.30%	100%	
205	SARITA VIHAR		0.57	66 KV SARITA VIHAR	SSARI114	MADANPUR KHADAR TRANS-I	Residential	AMR	0.57	0.00	0.57	0.26%	100%	
206	SARITA VIHAR		0.03	66 KV SARITA VIHAR	SSARI115	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	0.37%	100%	
207	SARITA VIHAR		0.74	66 KV SARITA VIHAR	SSARI116	K - POCKET SARITA VIHAR	Residential	AMR	0.74	0.00	0.74	0.16%	100%	
208	SARITA VIHAR		0.01	66 KV SARITA VIHAR	SSARI118	MN POCKET	Residential	AMR	0.01	0.00	0.01	0.26%	100%	
209	SARITA VIHAR		3.24	66 KV SARITA VIHAR	SSARI124	POCKET M JANTA FLAT SARITA VIHAR	Residential	AMR	3.24	0.00	3.19	1.47%	100%	
210	SARITA VIHAR		3.48	220 KV SARITA VIHAR GRID	TDTSG101	ALI VILLAGE	Residential	AMR	3.48	0.00	3.47	0.29%	100%	
211	SARITA VIHAR		3.05	220 KV SARITA VIHAR GRID	TDTSG102	SOURABH VIHAR - 1	Residential	AMR	3.05	0.00	3.04	0.39%	100%	
212	SARITA VIHAR		4.35	220 KV SARITA VIHAR GRID	TDTSG103	INDIAN OIL CORPO.	Mixed	AMR	4.35	0.97	3.35	0.77%	100%	
213	SARITA VIHAR		0.15	220 KV SARITA VIHAR GRID	TDTSG104	S/STN NO. 22 SARITA VIHAR	Residential	AMR	0.15	0.00	0.15	1.72%	100%	
214	SARITA VIHAR		0.27	220 KV SARITA VIHAR GRID	TDTSG105	S/STN NO. 21 SARITA VIHAR	Residential	AMR	0.27	0.00	0.27	0.99%	100%	
215	SARITA VIHAR		0.42	220 KV SARITA VIHAR GRID	TDTSG106	SEWAGE PUMPING STN.	Commercial	AMR	0.42	0.41	0.00	0.40%	100%	
216	SARITA VIHAR		3.57	220 KV SARITA VIHAR GRID	TDTSG107	JAITPUR	Mixed	AMR	3.57	0.00	3.56	0.28%	100%	
217	SARITA VIHAR		0.60	220 KV SARITA VIHAR GRID	TDTSG108	SAURABH VIHAR -2	Mixed	AMR	0.60	0.00	0.59	0.64%	100%	
218	SARITA VIHAR		3.43	220 KV SARITA VIHAR GRID	TDTSG109	AMERICAN EXPRESS	Commercial	AMR	3.43	0.00	3.40	0.86%	100%	
219	NEHRU PLACE	352.84	166.34	0.82	33 KV NEHRU PLACE	100004113	NSIC, OKHLA INDUSTRIAL ESTATE	Commercial	AMR	0.82	0.81	0.00	0.37%	100%
220	NEHRU PLACE			6.73	220 KV SARITA VIHAR GRID	152338093	DELHI METRO RAIL	Commercial	AMR	6.73	6.70	0.00	0.37%	100%
221	NEHRU PLACE			6.34	33 KV VSNL	152865963	TATA COMMUNICATION (EHV)	Commercial	AMR	6.34	6.32	0.00	0.37%	100%
222	NEHRU PLACE			1.32	33 KV BALAJI GRID	SBALA111	GB PANT STAFF QUATERS	Industrial	AMR	1.32	0.39	0.93	0.38%	100%
223	NEHRU PLACE			2.10	33 KV BALAJI GRID	SBALA113	S/STN NO 80, OKHLA PHASE III	Commercial	AMR	2.10	0.59	1.48	0.94%	100%
224	NEHRU PLACE			1.68	33 KV BALAJI GRID	SBALA114	BUILDING NO. 235 PH-III	Industrial	AMR	1.68	0.50	1.17	1.19%	100%
225	NEHRU PLACE			1.90	33 KV BALAJI GRID	SBALA116	IIIT-D-F1 VIA GB PANT POLYTECHNIC	Commercial	AMR	1.90	0.00	1.89	0.26%	100%
226	NEHRU PLACE			1.18	33 KV BALAJI GRID	SBALA117	IIIT-D-2 (RMU)	Industrial	AMR	1.18	0.35	0.82	1.00%	100%
227	NEHRU PLACE			0.88	33 KV BALAJI GRID	SBALA120	237 OKHLA PH-3	Industrial	AMR	0.88	0.27	0.61	0.57%	100%
228	NEHRU PLACE			1.60	33 KV Defence Colony	SDCOL107	11 KV O/G LAJPAT NAGAR - IV	Residential	AMR	1.60	0.00	1.60	0.44%	100%
229	NEHRU PLACE			2.10	33 KV Defence Colony	SDCOL111	11 KV O/G VIKRAM HOTEL	Mixed	AMR	2.10	0.58	1.49	0.84%	100%
230	NEHRU PLACE			3.93	33 KV HUDCO GRID	SHUDC102	11 KV O/G OLD HUDCO KIOSK	Residential	AMR	3.93	1.05	2.87	0.42%	100%
231	NEHRU PLACE			0.37	33 KV HUDCO GRID	SHUDC117	JAMRUDPUR S/STN NO-3	Mixed	AMR	0.37	0.10	0.26	1.42%	100%
232	NEHRU PLACE			0.36	33 KV HUDCO GRID	SHUDC119	SDM OFFICE VIA NURSING HOSTEL	Commercial	AMR	0.36	0.09	0.27	0.99%	100%
233	NEHRU PLACE			2.16	33 KV HUDCO GRID	SHUDC120	NATIONAL PARK I.J.P	Residential	AMR	2.16	0.00	2.14	0.86%	100%
234	NEHRU PLACE			4.32	33 KV EAST OF KAILASH	SKLSH101	KAILASH APARTMENT	Residential	AMR	4.32	0.00	4.32	0.12%	100%
235	NEHRU PLACE			1.06	33 KV EAST OF KAILASH	SKLSH103	S/STN NO.6 OKHLA PH-III	Commercial	AMR	1.06	0.32	0.73	0.78%	100%
236	NEHRU PLACE			2.34	33 KV EAST OF KAILASH	SKLSH104	E BLOCK EAST OF KAILASH	Commercial	AMR	2.34	0.65	1.69	0.03%	100%
237	NEHRU PLACE			2.07	33 KV EAST OF KAILASH	SKLSH105	B BLOCK EAST OF KAILASH	Residential	AMR	2.07	0.00	2.06	0.24%	100%
238	NEHRU PLACE			2.18	33 KV EAST OF KAILASH	SKLSH106	FLETED FACTORY	Industrial	AMR	2.18	0.60	1.57	0.48%	100%
239	NEHRU PLACE			1.34	33 KV EAST OF KAILASH	SKLSH107	S/STN NO. 1 OKHLA PH-III	Commercial	AMR	1.34	0.39	0.94	0.84%	100%
240	NEHRU PLACE			3.09	33 KV EAST OF KAILASH	SKLSH108	SAI PLAZA	Commercial	AMR	3.09	0.84	2.23	0.40%	100%
241	NEHRU PLACE			0.90	33 KV EAST OF KAILASH	SKLSH109	SBI -1	Commercial	AMR	0.90	0.29	0.61	0.05%	100%
242	NEHRU PLACE			3.36	33 KV EAST OF KAILASH	SKLSH110	DAYANAND KIOSK	Mixed	AMR	3.36	0.00	3.35	0.15%	100%
243	NEHRU PLACE			0.02	33 KV EAST OF KAILASH	SKLSH113	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.01	0.02	0.33%	100%
244	NEHRU PLACE			2.89	33 KV EAST OF KAILASH	SKLSH114	D BLOCK EAST OF KAILASH	Mixed	AMR	2.89	0.00	2.88	0.17%	100%
245	NEHRU PLACE			3.63	33 KV EAST OF KAILASH	SKLSH116	KALA KATRIR	Mixed	AMR	3.63	0.00	3.62	0.27%	100%
246	NEHRU PLACE			2.38	33 KV EAST OF KAILASH	SKLSH117	SBI NO.-2	Commercial	AMR	2.38	0.66	1.71	0.21%	100%
247	NEHRU PLACE			2.45	33 KV EAST OF KAILASH	SKLSH118	G BLOCK EAST OF KAILASH	Residential	AMR	2.45	0.00	2.43	0.74%	100%
248	NEHRU PLACE			2.95	33 KV EAST OF KAILASH	SKLSH119	O/G INDOOR GARI S/STN	Mixed	AMR	2.95	0.00	2.94	0.17%	100%
249	NEHRU PLACE			4.21	33 KV LAJPAT NAGAR	SLJPT108	11KV O/G LAJPAT NAGAR-IV	Mixed	AMR	4.21	0.00	4.20	0.12%	100%
250	NEHRU PLACE			1.59	33 KV LAJPAT NAGAR	SLJPT119	A BLK MINI MKT (E.O.K)	Mixed	AMR	1.59	0.00	1.58	0.28%	100%
251	NEHRU PLACE			1.52	33 KV LAJPAT NAGAR	SLJPT120	39 RING ROAD	Mixed	AMR	1.52	0.00	1.51	0.55%	100%
252	NEHRU PLACE			1.26	33 KV MASJID MOTH GRID	SMMOT102	11 KV O/G W - BLOCK G K - 1	Residential	AMR	1.26	0.00	1.25	0.40%	100%
253	NEHRU PLACE			3.42	33 KV MASJID MOTH GRID	SMMOT108	11 KV O/G GK PUMPING HOUSE	Industrial	AMR	3.42	3.41	0.00	0.15%	100%
254	NEHRU PLACE			1.38	33 KV MASJID MOTH GRID	SMMOT110	OCS GK-1 VIA B & C BLOCK PASCHIM ENCLAVE	Residential	AMR	1.38	0.00	1.37	0.36%	100%
255	NEHRU PLACE			0.65	33 KV MASJID MOTH GRID	SMMOT112	11 KV O/G DDA FLAT S/STN. M.MOTH PH	Residential	AMR	0.65	0.22	0.43	0.94%	100%
256	NEHRU PLACE			2.70	33 KV NEHRU PLACE	SNPHG102	O/G DELHI ADMINISTRATION FLATES	Residential	AMR	2.70	0.74	1.95	0.47%	100%
257	NEHRU PLACE			3.50	33 KV NEHRU PLACE	SNPHG103	O/G R BLOCK GK 1	Residential	AMR	3.50	0.00	3.50	0.07%	100%

258	NEHRU PLACE
259	NEHRU PLACE
260	NEHRU PLACE
261	NEHRU PLACE
262	NEHRU PLACE
263	NEHRU PLACE
264	NEHRU PLACE
265	NEHRU PLACE
266	NEHRU PLACE
267	NEHRU PLACE
268	NEHRU PLACE
269	NEHRU PLACE
270	NEHRU PLACE
271	NEHRU PLACE
272	NEHRU PLACE
273	NEHRU PLACE
274	NEHRU PLACE
275	NEHRU PLACE
276	NEHRU PLACE
277	NEHRU PLACE
278	NEHRU PLACE
279	NEHRU PLACE
280	NEHRU PLACE
281	NEHRU PLACE
282	NEHRU PLACE
283	NEHRU PLACE
284	NEHRU PLACE
285	NEHRU PLACE
286	NEHRU PLACE
287	NEHRU PLACE
288	NEHRU PLACE
289	NEHRU PLACE
290	NEHRU PLACE
291	NEHRU PLACE
292	NEHRU PLACE
293	NEHRU PLACE
294	NEHRU PLACE
295	NEHRU PLACE
296	NEHRU PLACE
297	NEHRU PLACE
298	NEHRU PLACE
299	NEHRU PLACE
300	NEHRU PLACE
301	NEHRU PLACE
302	NEHRU PLACE
303	NEHRU PLACE
304	NEHRU PLACE
305	NEHRU PLACE
306	NEHRU PLACE
307	NIZAMMUDIN
308	NIZAMMUDIN
309	NIZAMMUDIN

186.50

1.22	33 KV NEHRU PLACE	SNPHG104	O/G BLDG NO 89 NHP	Commercial	AMR	1.22	0.00	1.22	0.03%	100%
3.25	33 KV NEHRU PLACE	SNPHG105	O/G BLDG NO 42 NHP	Mixed	AMR	3.25	0.00	3.24	0.15%	100%
1.18	33 KV NEHRU PLACE	SNPHG106	O/G S/S 16 NHP	Commercial	AMR	1.18	0.00	1.16	1.82%	100%
1.72	33 KV NEHRU PLACE	SNPHG108	O/G SIS DDA GARHI	Mixed	AMR	1.72	0.49	1.22	0.47%	100%
3.34	33 KV NEHRU PLACE	SNPHG109	O/G D BLOCK E O K	Residential	AMR	3.34	0.00	3.33	0.56%	100%
0.47	33 KV NEHRU PLACE	SNPHG112	O/G BLDG NO 43 NHP	Commercial	AMR	0.47	0.00	0.46	1.96%	100%
3.55	33 KV NEHRU PLACE	SNPHG114	O/G S BLOCK GK I	Residential	AMR	3.55	0.97	2.58	0.14%	100%
1.54	33 KV NEHRU PLACE	SNPHG115	O/G NHP HOTEL NO 3	Commercial	AMR	1.54	1.53	0.00	0.75%	100%
0.27	33 KV NEHRU PLACE	SNPHG116	O/G BLDG NO 37 NHP	Commercial	AMR	0.27	0.07	0.20	0.26%	100%
1.28	33 KV NEHRU PLACE	SNPHG117	O/G TELEPHONE XCHANGE	Commercial	AMR	1.28	0.38	0.89	0.87%	100%
0.70	33 KV NEHRU PLACE	SNPHG118	O/G BLDG NO 75 76 NHP	Commercial	AMR	0.70	0.23	0.46	0.37%	100%
0.51	33 KV NEHRU PLACE	SNPHG119	11 KV O/G SATYAM COMPLEX	Commercial	AMR	0.51	0.13	0.37	0.80%	100%
0.48	33 KV NEHRU PLACE	SNPHG120	O/G NHP HOTEL COMPLEX2	Commercial	AMR	0.48	0.47	0.00	2.02%	100%
3.22	33 KV NEHRU PLACE	SNPHG121	O/G KAILASH COL. DISP	Mixed	AMR	3.22	0.90	2.32	0.16%	100%
1.20	33 KV NEHRU PLACE	SNPHG122	O/G S/STN NO 5 NHP	Commercial	AMR	1.20	0.35	0.84	0.13%	100%
1.79	33 KV NEHRU PLACE	SNPHG123	O/G S/S NO 4 NHP	Residential	AMR	1.79	0.00	1.78	0.87%	100%
0.46	33 KV NEHRU PLACE	SNPHG124	O/G NHP HOTEL COMPLEX1	Commercial	AMR	0.46	0.45	0.00	2.02%	100%
1.19	33 KV NEHRU PLACE	SNPHG125	O/G DEVIKA TOWER NHP	Commercial	AMR	1.19	0.36	0.82	0.75%	100%
0.09	33 KV NEHRU PLACE	SNPHG130	LOCAL TRAF0-1	Local Grid	AMR	0.09	0.00	0.09	0.55%	100%
0.34	33 KV NEHRU PLACE	SNPHG131	LOCAL TRAF0-2	Local Grid	AMR	0.34	0.00	0.34	0.60%	100%
1.09	33 KV NEHRU PLACE	SNPHG133	NP HOTEL PARKING	Commercial	AMR	1.09	0.32	0.75	1.77%	100%
0.42	33 KV NEHRU PLACE	SNPHG134	BLD NO - 38	Commercial	AMR	0.42	0.00	0.41	1.47%	100%
4.56	33 KV NEHRU PLACE	SNPHG137	11 KV O/G BAHAI MANDIR	Mixed	AMR	4.56	1.23	3.32	0.40%	100%
0.63	33 KV NEHRU PLACE	SNPHG138	11 KV O/G IFCI TOWER	Commercial	AMR	0.63	0.63	0.00	0.56%	100%
1.66	33 KV OKHLA PH 2	SOKH2101	11 KV Y-PKT PH-II	Industrial	AMR	1.66	0.48	1.19	0.18%	100%
2.53	33 KV OKHLA PH 2	SOKH2102	11 KV O/G S/STN-1, PH II FDR 1	Industrial	AMR	2.53	0.70	1.82	0.20%	100%
2.14	33 KV OKHLA PH 2	SOKH2103	11 KV O/G W-BLOCK, PH II	Industrial	AMR	2.14	0.00	2.13	0.04%	100%
1.31	33 KV OKHLA PH 2	SOKH2104	11 KV O/G TO DDA LSC OKHLA PH-2	Industrial	AMR	1.31	0.00	1.30	0.38%	100%
0.24	33 KV OKHLA PH 2	SOKH2105	O/G FIEE COMPLEX S/STN NO-2 OKHLA PH-2	Industrial	AMR	0.24	0.00	0.24	0.23%	100%
0.73	33 KV OKHLA PH 2	SOKH2106	11 KV RMU	Industrial	AMR	0.73	0.24	0.48	1.74%	100%
0.81	33 KV OKHLA PH 2	SOKH2107	SCH-1 DSID C PH-2	Industrial	AMR	0.81	0.26	0.54	1.18%	100%
1.23	33 KV OKHLA PH 2	SOKH2108	S STN -4 OKHLA PH-2 FEEDER -1	Industrial	AMR	1.23	0.37	0.85	0.77%	100%
1.15	33 KV OKHLA PH 2	SOKH2115	11 KV O/G S/STN NO 1 FDR-2 OKHLA 2	Industrial	AMR	1.15	0.34	0.79	0.79%	100%
1.96	33 KV OKHLA PH 2	SOKH2118	SEWAGE PUMPING STATION Z-BLOCK PH-2	Industrial	AMR	1.96	0.56	1.40	0.25%	100%
1.66	33 KV OKHLA PH 2	SOKH2119	S/STN-2 OKHALA PH-2	Industrial	AMR	1.66	0.00	1.65	0.30%	100%
2.18	33 KV OKHLA PH 2	SOKH2120	S/STN-4 FEEDER-2 PHASE-2	Industrial	AMR	2.18	0.60	1.57	0.35%	100%
2.99	33 KV OKHLA PH 2	SOKH2121	S/STN-5 OKHLA IND. AREA PH-II	Industrial	AMR	2.99	0.00	2.99	0.17%	100%
1.47	33 KV OKHLA PH 2	SOKH2124	11 KV O/G C-46	Industrial	AMR	1.47	0.00	1.46	0.34%	100%
2.69	33 KV OKHLA PH 2	SOKH2125	11 KV O/G SHED no-8 DSIDC SCHEME-3	Industrial	AMR	2.69	0.00	2.69	0.19%	100%
2.14	33 KV OKHLA PH 2	SOKH2126	11 KV O/G Z BLOCK PH II (VIA X-BLOCK)	Industrial	AMR	2.14	0.58	1.56	0.05%	100%
0.03	33 KV OKHLA PH 2	SOKH2127	LOCAL TRANSFORMER (400 KVA)	Mixed	AMR	0.03	0.00	0.03	0.44%	100%
0.16	33 KV SIRI FORT	SSHRI109	11 KV O/G PUMPING STN GK I	Industrial	AMR	0.16	0.16	0.00	2.23%	100%
0.06	33 KV VSNL	SVSNL102	LOCAL TRANSFORMAR	Local Grid	AMR	0.06	0.00	0.06	0.54%	100%
1.80	33 KV VSNL	SVSNL103	M.BLOCK G.K I	Mixed	AMR	1.80	0.00	1.80	0.28%	100%
3.27	33 KV VSNL	SVSNL107	E BLK. GK-1	Residential	AMR	3.27	0.00	3.27	0.15%	100%
3.20	33 KV VSNL	SVSNL109	EPR COLONY	Residential	AMR	3.20	0.00	3.19	0.25%	100%
2.40	33 KV VSNL	SVSNL110	R BLOCK G.K I	Residential	AMR	2.40	0.00	2.38	0.70%	100%
2.57	33 KV VSNL	SVSNL127	CHIRAG ENCLAVE GK-1 (VIA) NEW POLICE POST	Mixed	AMR	2.57	0.70	1.86	0.06%	100%
2.79	220 KV OKHLA TRANSCO GRID	TDTOG101	LSC DDA OKHLA PH-2	Industrial	AMR	2.79	0.00	2.77	0.64%	100%
2.62	220 KV LODHI ROAD GRID	100018910	ENERGY FROM 220 KV LODI ROAD TO IHC	Commercial	AMR	2.62	2.61	0.00	0.37%	100%
1.67	220 KV LODHI ROAD GRID	150007544	CBI Head Office	Commercial	AMR	1.67	1.66	0.00	0.37%	100%
1.65	33 KV JAWAHAR LAL NEHRU STADIUM	150013816	33 KV JAWAHAR LAL STADIUM (KCC)	Commercial	AMR	1.65	1.64	0.00	0.37%	100%

310	NIZAMMUDIN
311	NIZAMMUDIN
312	NIZAMMUDIN
313	NIZAMMUDIN
314	NIZAMMUDIN
315	NIZAMMUDIN
316	NIZAMMUDIN
317	NIZAMMUDIN
318	NIZAMMUDIN
319	NIZAMMUDIN
320	NIZAMMUDIN
321	NIZAMMUDIN
322	NIZAMMUDIN
323	NIZAMMUDIN
324	NIZAMMUDIN
325	NIZAMMUDIN
326	NIZAMMUDIN
327	NIZAMMUDIN
328	NIZAMMUDIN
329	NIZAMMUDIN
330	NIZAMMUDIN
331	NIZAMMUDIN
332	NIZAMMUDIN
333	NIZAMMUDIN
334	NIZAMMUDIN
335	NIZAMMUDIN
336	NIZAMMUDIN
337	NIZAMMUDIN
338	NIZAMMUDIN
339	NIZAMMUDIN
340	NIZAMMUDIN
341	NIZAMMUDIN
342	NIZAMMUDIN
343	NIZAMMUDIN
344	NIZAMMUDIN

1.35	33 KV ITPO	153385965	33 KV O/G TO ITPO MRS NO - 1	Mixed	AMR	1.35	1.34	0.00	0.37%		100%
2.65	33 KV Nizamuddin	350917462	SUPREME COURT	Commercial	AMR	2.65	2.64	0.00	0.37%		100%
0.03	33 KV KILOKARI	100016647	GT(GAIL)	Commercial	AMR	0.03	0.00	0.03	0.38%		100%
0.83	33 KV Aiims	SAIMS101	11 KV O/G NDSE PART I	Residential	AMR	0.83	0.28	0.54	1.90%		100%
0.50	33 KV Aiims	SAIMS104	11 KV O/G VIKAS SADAN	Mixed	AMR	0.50	0.13	0.36	0.95%		100%
2.40	33 KV Defence Colony	SDCOL101	11 KV O/G C-BLOCK D COLONY	Residential	AMR	2.40	0.00	2.36	1.62%		100%
3.50	33 KV Defence Colony	SDCOL102	11 KV O/G SEWA NAGAR	Mixed	AMR	3.50	1.05	2.39	1.52%		100%
5.15	33 KV Defence Colony	SDCOL103	11 KV O/G SHUKDEV MARKET	Mixed	AMR	5.15	0.00	5.13	0.24%		100%
0.99	33 KV Defence Colony	SDCOL104	11 KV O/G MOOLCHAND BOOSTER PUMPING	Mixed	AMR	0.99	0.32	0.63	3.44%		100%
2.46	33 KV Defence Colony	SDCOL105	11 KV O/G A BLOCK DCOLONY	Mixed	AMR	2.46	0.00	2.45	0.32%		100%
3.69	33 KV Defence Colony	SDCOL106	11 KV O/G D - 337 DCOLONY	Residential	AMR	3.69	0.00	3.63	1.68%		100%
0.02	33 KV Defence Colony	SDCOL108	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.01	0.21%		100%
3.55	33 KV Defence Colony	SDCOL109	11 KV O/G LAJPATH NAGAR - III	Mixed	AMR	3.55	0.89	2.65	0.29%		100%
3.50	33 KV Defence Colony	SDCOL110	11 KV O/G DHARAM BHAWAN	Mixed	AMR	3.50	0.87	2.56	1.95%		100%
1.89	33 KV Defence Colony	SDCOL112	11 KV O/G DCOLONY C-BLOCK FDR NO II	Mixed	AMR	1.89	0.00	1.83	3.09%		100%
3.09	33 KV Defence Colony	SDCOL113	11 KV O/G BAPU PARK TRAINING CENTRE	Mixed	AMR	3.09	0.00	3.05	1.24%		100%
3.94	33 KV Defence Colony	SDCOL114	11 KV O/G B - BLOCK DCOLONY	Residential	AMR	3.94	0.96	2.92	1.40%		100%
2.71	33 KV Defence Colony	SDCOL117	KRISHNA MARKET LAJPAT NAGAR	Mixed	AMR	2.71	0.00	2.67	1.57%		100%
2.26	33 KV Defence Colony	SDCOL120	PILANGI S/STN KM PUR	Mixed	AMR	2.26	0.68	1.56	1.20%		100%
2.02	33 KV Defence Colony	SDCOL121	DHARAM BHAWAN NDSE-1	Mixed	AMR	2.02	0.00	1.98	1.79%		100%
0.61	33 KV Defence Colony	SDCOL320	TYAGARAJA STADIUM	Mixed	AMR	0.61	0.00	0.59	2.46%		100%
0.18	33 KV Defence Colony	SDCOL321	GPRA COLONY TYAGRAJ NAGAR	Mixed	AMR	0.18	0.00	0.18	0.58%		100%
0.01	33 KV Exhibition No - 2	SEXN2101	LOCAL TRANSFORMER	Local Grid	AMR	0.01	0.00	0.00	0.38%		100%
0.32	33 KV Exhibition No - 2	SEXN2104	CPWD S/S -11	Commercial	AMR	0.32	0.32	0.00	0.28%		100%
0.21	33 KV Exhibition No - 2	SEXN2106	CPWD S/S-6	Commercial	AMR	0.21	0.21	0.00	0.28%		100%
0.16	33 KV Exhibition No - 2	SEXN2107	CPWD S/S - 1	Commercial	AMR	0.16	0.16	0.00	0.28%		100%
1.88	33 KV Exhibition No - 2	SEXN2112	BHARO ROAD	Mixed	AMR	1.88	0.56	1.30	1.15%		100%
0.50	33 KV Exhibition No - 2	SEXN2113	SHAPOORJI PALLONJI	Commercial	AMR	0.50	0.00	0.49	1.71%		100%
2.24	33 KV HUDCO GRID	SHUDC108	11 KV O/G D-430 D.COLONY	Mixed	AMR	2.24	0.00	2.21	1.23%		100%
0.01	33 KV ITPO	SITPO103	LOCAL TRANSFORMER 2	Local Grid	AMR	0.01	0.00	0.01	0.16%		100%
0.26	33 KV ITPO	SITPO104	F/O PWD UNDER PASS	Mixed	AMR	0.26	0.07	0.19	0.17%		100%
0.00	33 KV ITPO	SITPO105	LOCAL TRANSFORMER	Local Grid	AMR	0.00	0.00	0.00	0.33%		100%
0.41	33 KV ITPO	SITPO106	BHAIRON ROAD	Residential	AMR	0.41	0.11	0.30	0.48%		100%
0.22	33 KV ITPO	SITPO108	11KV SUPREME COURT	Residential	AMR	0.22	0.00	0.21	1.52%		100%
1.36	33 KV ITPO	SITPO109	SUNDAR NAGAR	Mixed	AMR	1.36	0.47	0.85	3.16%		100%

345	NIZAMMUDIN
346	NIZAMMUDIN
347	NIZAMMUDIN
348	NIZAMMUDIN
349	NIZAMMUDIN
350	NIZAMMUDIN
351	NIZAMMUDIN
352	NIZAMMUDIN
353	NIZAMMUDIN
354	NIZAMMUDIN
355	NIZAMMUDIN
356	NIZAMMUDIN
357	NIZAMMUDIN
358	NIZAMMUDIN
359	NIZAMMUDIN
360	NIZAMMUDIN
361	NIZAMMUDIN
362	NIZAMMUDIN
363	NIZAMMUDIN
364	NIZAMMUDIN
365	NIZAMMUDIN
366	NIZAMMUDIN
367	NIZAMMUDIN
368	NIZAMMUDIN
369	NIZAMMUDIN
370	NIZAMMUDIN
371	NIZAMMUDIN
372	NIZAMMUDIN
373	NIZAMMUDIN
374	NIZAMMUDIN
375	NIZAMMUDIN
376	NIZAMMUDIN
377	NIZAMMUDIN
378	NIZAMMUDIN
379	NIZAMMUDIN

0.29	33 KV ITPO	SITPO110	TILAK BRIDGE RAILWAY COLONY	Commercial	AMR	0.29	0.00	0.28	2.87%		100%
3.03	33 KV Kilokari	SKKRI101	11 KV O/G ASHRAM CHOWK VIA JEEVAN N	Residential	AMR	3.03	0.00	3.01	0.66%		100%
0.04	33 KV Kilokari	SKKRI102	3 MVA 11/6.6 KV T/F	Mixed	AMR	0.04	0.01	0.03	1.83%		100%
1.39	33 KV Kilokari	SKKRI106	11 KV O/G GENERATION COLONY	Mixed	AMR	1.39	0.41	0.91	4.63%		100%
2.40	33 KV Kilokari	SKKRI107	11 KV O/G RING ROAD SEWAGE PUMPING	Commercial	AMR	2.40	0.75	1.60	1.75%		100%
0.43	33 KV Kilokari	SKKRI108	11 KV O/G SARAI KALEY KHAN DSEU COL	Residential	AMR	0.43	0.00	0.41	4.11%		100%
3.04	33 KV Kilokari	SKKRI110	11 KV O/G SIDHARTH EXTN.	Mixed	AMR	3.04	0.86	2.14	1.28%		100%
0.01	33 KV Kilokari	SKKRI116	LOCAL TRANSFORMER	Local Grid	AMR	0.01	0.00	0.01	0.39%		100%
2.95	33 KV Kilokari	SKKRI121	400KV POWER GRID M.BAGH(SARAI K KH)	Commercial	AMR	2.95	0.96	1.97	0.74%		100%
1.31	33 KV Kilokari	SKKRI123	DJB SARAI KALA KHAN	Commercial	AMR	1.31	0.42	0.88	0.43%		100%
0.26	33 KV Kilokari	SKKRI124	DTL	Mixed	AMR	0.26	0.07	0.19	1.68%		100%
5.33	33 KV Kilokari	SKKRI324	DDA SLUM QTR	Mixed	AMR	5.33	1.44	3.82	1.33%		100%
1.85	33 KV Kilokari	SKKRI325	SUNLIGHT COLONY -2	Mixed	AMR	1.85	0.00	1.82	1.76%		100%
2.37	33 KV Kilokari	SKKRI326	AMBEDKAR PARK	Mixed	AMR	2.37	0.00	2.32	1.90%		100%
2.38	33 KV Kilokari	SKKRI327	TIKONA OARK SIDHARTH EXTN.	Mixed	AMR	2.38	0.77	1.57	1.34%		100%
2.03	33 KV LAJPAT NAGAR	SLJPT103	11KV O/G 6 - FIROZ GANDHI ROAD	Mixed	AMR	2.03	0.64	1.37	0.62%		100%
3.10	33 KV LAJPAT NAGAR	SLJPT104	11 KV O/G M-BLOCK LAJPAT NAGAR-II	Mixed	AMR	3.10	0.00	3.03	2.40%		100%
2.39	33 KV LAJPAT NAGAR	SLJPT105	11 KV O/G FEEDER-1 LAJPAT NAGAR-III	Mixed	AMR	2.39	0.00	2.36	1.35%		100%
0.01	33 KV LAJPAT NAGAR	SLJPT106	LOCAL TRANSFORMER	Local Grid	AMR	0.01	0.00	0.01	0.17%		100%
1.52	33 KV LAJPAT NAGAR	SLJPT107	II KV O/G FEEDER-2 LAJPAT NAGAR-3	Mixed	AMR	1.52	0.48	1.00	2.39%		100%
3.48	33 KV LAJPAT NAGAR	SLJPT110	VIMHENCE HOSPITAL NEHRU NAGAR	Mixed	AMR	3.48	0.99	2.43	1.91%		100%
2.27	33 KV LAJPAT NAGAR	SLJPT112	11kv O/G ALANKAR CINEMA	Mixed	AMR	2.27	0.68	1.54	2.32%		100%
1.03	33 KV LAJPAT NAGAR	SLJPT114	11 KV KASTURBHA NIKETEN	Residential	AMR	1.03	0.35	0.66	0.95%		100%
1.83	33 KV LAJPAT NAGAR	SLJPT115	11KV MOOLCHAND HOSPITAL	Mixed	AMR	1.83	0.57	1.26	0.15%		100%
2.24	33 KV LAJPAT NAGAR	SLJPT116	F BLOCK LAJPAT NAGAR NO-1	Mixed	AMR	2.24	0.00	2.20	1.54%		100%
3.78	33 KV LAJPAT NAGAR	SLJPT117	TIKONA PARK LAJPAT NAGAR NO - 2	Mixed	AMR	3.78	0.00	3.77	0.23%		100%
3.36	33 KV LAJPAT NAGAR	SLJPT118	11 KV O/G MCD DISPENSARY LPN- 2	Mixed	AMR	3.36	0.00	3.32	1.12%		100%
2.24	33 KV NDSE II	SNDSE103	11 KV O/G G-BLOCK MKT NDSE -1	Commercial	AMR	2.24	0.70	1.51	1.40%		100%
1.94	33 KV NDSE II	SNDSE111	C-57 NDSE-1	Mixed	AMR	1.94	0.00	1.88	3.20%		100%
1.43	33 KV NDSE II	SNDSE112	B-BLOCK DEFENCE COLONY	Mixed	AMR	1.43	0.42	0.98	1.86%		100%
1.84	33 KV NDSE II	SNDSE115	INA COLONY	Residential	AMR	1.84	0.63	1.16	2.70%		100%
0.60	33 KV NDSE II	SNDSE118	11KV O/G TYAGRAJ STADIUM	Commercial	AMR	0.60	0.15	0.42	3.74%		100%
2.69	33 KV NDSE II	SNDSE119	GPO INA-2+WAZIR NAGAR GALI NO-5	Commercial	AMR	2.69	0.00	2.65	1.77%		100%
1.05	33 KV NDSE II	SNDSE123	11 KV O/G GPO INA-1	Commercial	AMR	1.05	0.00	1.03	1.99%		100%
1.77	33 KV NIZAMUDDIN	SNZMD101	KILOKRI SEWAGE	Commercial	AMR	1.77	0.54	1.19	1.67%		100%

380	NIZAMMUDIN
381	NIZAMMUDIN
382	NIZAMMUDIN
383	NIZAMMUDIN
384	NIZAMMUDIN
385	NIZAMMUDIN
386	NIZAMMUDIN
387	NIZAMMUDIN
388	NIZAMMUDIN
389	NIZAMMUDIN
390	NIZAMMUDIN
391	NIZAMMUDIN
392	NIZAMMUDIN
393	NIZAMMUDIN
394	NIZAMMUDIN
395	NIZAMMUDIN
396	NIZAMMUDIN
397	NIZAMMUDIN
398	NIZAMMUDIN
399	NIZAMMUDIN
400	NIZAMMUDIN
401	NIZAMMUDIN
402	NIZAMMUDIN
403	NIZAMMUDIN
404	NIZAMMUDIN
405	NIZAMMUDIN
406	NIZAMMUDIN
407	NIZAMMUDIN
408	NIZAMMUDIN
409	NIZAMMUDIN
410	NIZAMMUDIN
411	NIZAMMUDIN
412	NIZAMMUDIN
413	NIZAMMUDIN
414	NIZAMMUDIN

0.85	33 KV NIZAMUDDIN	SNZMD102	SHALIMAR CINEMA VIA SAM INDIA	Mixed	AMR	0.85	0.00	0.84	1.38%		100%
2.04	33 KV NIZAMUDDIN	SNZMD103	O/G LODHI HOTEL	Commercial	AMR	2.04	0.61	1.40	1.77%		100%
0.94	33 KV NIZAMUDDIN	SNZMD104	LAJPAT NAGAR -I FERDER -2, I BLK	Residential	AMR	0.94	0.00	0.91	2.83%		100%
3.94	33 KV NIZAMUDDIN	SNZMD105	11 KV NZD TIE NO-2	Mixed	AMR	3.94	1.00	2.88	1.63%		100%
3.38	33 KV NIZAMUDDIN	SNZMD106	11 KV NZD TIE NO-1	Mixed	AMR	3.38	0.00	3.37	0.35%		100%
2.58	33 KV NIZAMUDDIN	SNZMD107	JANGPURA	Mixed	AMR	2.58	0.00	2.54	1.39%		100%
1.21	33 KV NIZAMUDDIN	SNZMD108	LAJPAT NAGAR -II FEDER-1	Mixed	AMR	1.21	0.00	1.19	2.28%		100%
3.52	33 KV NIZAMUDDIN	SNZMD109	G BLOCK NZD WEST	Mixed	AMR	3.52	0.00	3.51	0.14%		100%
1.43	33 KV NIZAMUDDIN	SNZMD110	SUNDER NAGAR FEEDER	Residential	AMR	1.43	0.45	0.94	2.22%		100%
3.62	33 KV NIZAMUDDIN	SNZMD111	BIRBAL PARK	Mixed	AMR	3.62	0.00	3.56	1.72%		100%
2.05	33 KV NIZAMUDDIN	SNZMD112	C BLOCK NZD. EAST	Residential	AMR	2.05	0.62	1.43	0.04%		100%
1.68	33 KV NIZAMUDDIN	SNZMD113	MICRO WAVE NIZAMUDDIEN EST	Mixed	AMR	1.68	0.48	1.17	1.63%		100%
2.49	33 KV NIZAMUDDIN	SNZMD114	LAJPAT NAGAR - II FEDER -3	Mixed	AMR	2.49	0.00	2.45	1.38%		100%
0.03	33 KV NIZAMUDDIN	SNZMD116	LOCAL TR.(11 KV SWITCH BOARD)	Local Grid	AMR	0.03	0.01	0.02	0.40%		100%
3.03	33 KV NIZAMUDDIN	SNZMD120	11 KV NZD TIE NO-3	Mixed	AMR	3.03	0.00	2.98	1.60%		100%
1.76	33 KV NIZAMUDDIN	SNZMD121	CABINET SECRETARITE 5A LODHI ROAD CGO COMPLEX	Commercial	AMR	1.76	0.56	1.19	0.10%		100%
1.60	33 KV NIZAMUDDIN	SNZMD122	SUCHNA BHAVAN CGO COMPLEX	Commercial	AMR	1.60	1.59	0.00	0.77%		100%
0.84	33 KV NIZAMUDDIN	SNZMD123	O/G TO CAINET SECRETARIAT OLD BULDING (RAW)	Commercial	AMR	0.84	0.00	0.83	1.90%		100%
3.44	33 KV NIZAMUDDIN	SNZMD124	KASHMIRI PARK JUNGपुरA	Mixed	AMR	3.44	0.00	3.38	1.72%		100%
0.44	220 KV LODHI ROAD GRID	TDTLR101	SEWAGE PUMPINH STN	Commercial	AMR	0.44	0.13	0.30	0.61%		100%
0.65	220 KV LODHI ROAD GRID	TDTLR102	DEFENCE UNDER FLYOVER	Mixed	AMR	0.65	0.20	0.45	1.96%		100%
0.65	220 KV LODHI ROAD GRID	TDTLR103	DOE NO-2	Commercial	AMR	0.65	0.65	0.00	0.96%		100%
1.41	220 KV LODHI ROAD GRID	TDTLR104	LODI COLONY COMPLAINT CENTRE	Residential	AMR	1.41	0.43	0.96	1.14%		100%
0.94	220 KV LODHI ROAD GRID	TDTLR105	SCPOE BUILDING NO-16	Commercial	AMR	0.94	0.32	0.60	2.99%		100%
0.57	220 KV LODHI ROAD GRID	TDTLR106	DOE NO-1	Commercial	AMR	0.57	0.56	0.00	0.96%		100%
0.52	220 KV LODHI ROAD GRID	TDTLR107	NBCC S/STN(EAST BLOCK)	Commercial	AMR	0.52	0.14	0.38	1.90%		100%
0.78	220 KV LODHI ROAD GRID	TDTLR108	MSO NO-2	Commercial	AMR	0.78	0.78	0.00	0.23%		100%
1.94	220 KV LODHI ROAD GRID	TDTLR109	TELEPHONE EXCHANGE	Commercial	AMR	1.94	0.59	1.34	0.40%		100%
0.89	220 KV LODHI ROAD GRID	TDTLR110	SCOPE BLDG NO 17	Commercial	AMR	0.89	0.00	0.88	0.68%		100%
0.81	220 KV LODHI ROAD GRID	TDTLR111	NBCC+ STADIUM R-1	Commercial	AMR	0.81	0.29	0.50	2.62%		100%
1.29	220 KV LODHI ROAD GRID	TDTLR112	SCOPE BLDG NO 15	Commercial	AMR	1.29	1.28	0.00	0.63%		100%
0.96	220 KV LODHI ROAD GRID	TDTLR113	DEFENCE COLONY	Mixed	AMR	0.96	0.33	0.62	1.34%		100%
1.80	220 KV LODHI ROAD GRID	TDTLR114	MSO NO-1	Commercial	AMR	1.80	1.80	0.00	0.23%		100%
0.42	220 KV LODHI ROAD GRID	TDTLR115	CABINET SECTY	Commercial	AMR	0.42	0.14	0.28	0.10%		100%
1.25	220 KV LODHI ROAD GRID	TDTLR116	INSTITUTIONAL AREA	Mixed	AMR	1.25	0.41	0.81	2.39%		100%

415	NIZAMMUDIN			2.26	220 KV LODHI ROAD GRID	TDTLR117	UNIDO	Mixed	AMR	2.26	0.81	1.41	1.67%		100%
416	NIZAMMUDIN			0.02	220 KV LODHI ROAD GRID	TDTLR118	Cabinet Secretariat (NEW)	Commercial	AMR	0.02	0.00	0.02	1.90%		100%
417	ALAKNANDA	468.27	173.74	1.81	33 KV Alaknanda	SALKN101	11 KV O/G DDA SLUM KALKAJI	Residential	AMR	1.81	0.27	1.51	1.21%		100%
418	ALAKNANDA			2.44	33 KV Alaknanda	SALKN102	11 KV O/G DDA JANTA FLAT KALKAJI	Mixed	AMR	2.44	0.00	2.43	0.41%		100%
419	ALAKNANDA			2.00	33 KV Alaknanda	SALKN103	11 KV O/G E.P.D.P S/STN - 2	Mixed	AMR	2.00	0.00	1.99	0.50%		100%
420	ALAKNANDA			1.84	33 KV Alaknanda	SALKN104	11 KV O/G NILGIRI S/STN - 1	Residential	AMR	1.84	0.00	1.79	3.06%		100%
421	ALAKNANDA			1.62	33 KV Alaknanda	SALKN105	11 KV O/G MANDAKINI S/S NO.1	Mixed	AMR	1.62	0.23	1.34	2.90%		100%
422	ALAKNANDA			2.50	33 KV Alaknanda	SALKN106	11 KV O/G DESH BANDHU APPARTMENT	Residential	AMR	2.50	0.47	2.02	0.67%		100%
423	ALAKNANDA			2.45	33 KV Alaknanda	SALKN107	11 KV O/G KAVERI APPT.+SHIVALIK	Residential	AMR	2.45	0.00	2.44	0.41%		100%
424	ALAKNANDA			2.28	33 KV Alaknanda	SALKN108	11 KV O/G NRI S/T	Mixed	AMR	2.28	0.43	1.81	1.83%		100%
425	ALAKNANDA			0.01	33 KV Alaknanda	SALKN112	LOCAL TRANSFORMER	Local Grid	AMR	0.01	0.00	0.01	0.18%		100%
426	ALAKNANDA			2.67	33 KV Alaknanda	SALKN113	11 KV O/G S-BLOCK GK-II	Mixed	AMR	2.67	0.53	2.13	0.37%		100%
427	ALAKNANDA			2.38	33 KV Alaknanda	SALKN117	SHIVALIK APPT	Residential	AMR	2.38	0.00	2.35	1.14%		100%
428	ALAKNANDA			1.72	33 KV Alaknanda	SALKN118	W-I GK-2	Mixed	AMR	1.72	0.00	1.70	1.69%		100%
429	ALAKNANDA			1.64	33 KV Alaknanda	SALKN120	11KV EPDP-6	Residential	AMR	1.64	0.00	1.63	0.82%		100%
430	ALAKNANDA			2.10	33 KV Alaknanda	SALKN121	11 KV EPDP-1	Mixed	AMR	2.10	0.00	2.10	0.29%		100%
431	ALAKNANDA			1.57	33 KV Alaknanda	SALKN122	11 KV O/G DLF E-BLK-G.K.-2	Residential	AMR	1.57	0.21	1.31	2.63%		100%
432	ALAKNANDA			0.74	33 KV Alaknanda	SALKN123	11 KV O/G DLF W-BLK G.K.-2	Residential	AMR	0.74	0.19	0.53	1.72%		100%
433	ALAKNANDA			3.16	33 KV Alaknanda	SALKN124	11 KV O/G GALI NO 16 G. PURI	Residential	AMR	3.16	0.00	3.16	0.09%		100%
434	ALAKNANDA			1.79	33 KV Alaknanda	SALKN125	O/G SSTN-1 NARMADA APPT	Residential	AMR	1.79	0.23	1.55	0.16%		100%
435	ALAKNANDA			2.04	33 KV BALAJI GRID	SBALA101	MUNJAL S/STN KALKAJI	Residential	AMR	2.04	0.35	1.67	1.25%		100%
436	ALAKNANDA			2.77	33 KV BALAJI GRID	SBALA102	G BLOCK KALKAJI	Mixed	AMR	2.77	0.00	2.76	0.36%		100%
437	ALAKNANDA			2.35	33 KV BALAJI GRID	SBALA103	A- BLOCK KALKAJI	Residential	AMR	2.35	0.00	2.34	0.43%		100%
438	ALAKNANDA			2.58	33 KV BALAJI GRID	SBALA104	GALI NO. 10 GOVINDPURI	Residential	AMR	2.58	0.00	2.57	0.55%		100%
439	ALAKNANDA			1.72	33 KV BALAJI GRID	SBALA105	H-BLOCK GOLE CHAKKAR	Mixed	AMR	1.72	0.00	1.66	3.46%		100%
440	ALAKNANDA			0.16	33 KV BALAJI GRID	SBALA107	LOCAL TRANSFORMER	Local Grid	AMR	0.16	0.00	0.16	0.57%		100%
441	ALAKNANDA			3.50	33 KV BALAJI GRID	SBALA112	POCKET A3 KALKAJI EXTENSION	Residential	AMR	3.50	0.00	3.47	1.02%		100%
442	ALAKNANDA			2.59	33 KV BALAJI GRID	SBALA115	GIRI NAGAR No. 2	Residential	AMR	2.59	0.50	2.08	0.26%		100%
443	ALAKNANDA			3.17	33 KV BALAJI GRID	SBALA118	O/G Giri Ngr No 1 Near Metro Station	Residential	AMR	3.17	0.00	3.13	1.20%		100%
444	ALAKNANDA			2.27	33 KV BALAJI GRID	SBALA122	11KV O/G RAMANUJ COLLEGE	Commercial	AMR	2.27	0.42	1.83	0.99%		100%
445	ALAKNANDA			3.04	66 KV TIA BATRA	SBTRA111	11 KV O/G TARA APPARTMENT	Residential	AMR	3.04	0.00	2.99	1.53%		100%
446	ALAKNANDA			2.19	66 KV TIA BATRA	SBTRA127	O/G GALI NO. 29 TKD EXT.	Mixed	AMR	2.19	0.00	2.17	0.92%		100%
447	ALAKNANDA			2.58	33 KV MASJID MOTH GRID	SMMOT105	11 KV O/G E-BLK GK-2	Mixed	AMR	2.58	0.50	2.08	0.09%		100%
448	ALAKNANDA			0.59	33 KV MASJID MOTH GRID	SMMOT107	11 KV O/G VIPPS INDIA S/STN	Mixed	AMR	0.59	0.07	0.51	2.06%		100%
449	ALAKNANDA			1.47	33 KV NEHRU PLACE	SNPHG101	DESHBANDHU COL.	Mixed	AMR	1.47	0.22	1.24	0.44%		100%
450	ALAKNANDA			1.87	33 KV NEHRU PLACE	SNPHG107	O/G G BLOCK KALKAJI	Mixed	AMR	1.87	0.00	1.82	2.47%		100%
451	ALAKNANDA			2.14	33 KV NEHRU PLACE	SNPHG110	ARYA SAMAJ MANDIR KALKAJ	Residential	AMR	2.14	0.00	2.12	1.03%		100%
452	ALAKNANDA			2.71	33 KV NEHRU PLACE	SNPHG111	POLICE STATION KALKAJI	Residential	AMR	2.71	0.54	2.15	0.73%		100%
453	ALAKNANDA			2.24	33 KV NEHRU PLACE	SNPHG113	O/G C R PARK S/STN A	Residential	AMR	2.24	0.00	2.23	0.71%		100%
454	ALAKNANDA			1.43	66 KV OKHLA PH 1	SOKH1101	INTERNAL CONTAINER DEPOT	Commercial	AMR	1.43	1.42	0.00	0.62%		100%
455	ALAKNANDA			2.59	66 KV OKHLA PH 1	SOKH1102	S/STN A,DSIDC, OKHLA PHASE 1	Industrial	AMR	2.59	0.00	2.54	1.67%		100%
456	ALAKNANDA			1.94	66 KV OKHLA PH 1	SOKH1103	O/G S/STN 1,F-BLK,OKHLA PH-1	Industrial	AMR	1.94	0.26	1.67	0.59%		100%
457	ALAKNANDA			1.73	66 KV OKHLA PH 1	SOKH1104	SUB STATION 3,OKHLA, PHASE 1	Industrial	AMR	1.73	0.00	1.68	2.59%		100%
458	ALAKNANDA			1.75	66 KV OKHLA PH 1	SOKH1105	S/STN-11 DIA-1	Industrial	AMR	1.75	0.25	1.49	0.57%		100%
459	ALAKNANDA			2.03	66 KV OKHLA PH 1	SOKH1107	S/STN-E, ESI,PH-1	Industrial	AMR	2.03	0.34	1.67	1.49%		100%
460	ALAKNANDA			3.20	66 KV OKHLA PH 1	SOKH1108	11 KV O/G CCI COMPLEX 1	Residential	AMR	3.20	0.00	3.15	1.46%		100%
461	ALAKNANDA			0.14	66 KV OKHLA PH 1	SOKH1109	STN NO.2 SLUM FLATS, A214, KALKAJI EXT.	Mixed	AMR	0.14	0.00	0.14	1.54%		100%
462	ALAKNANDA			1.54	66 KV OKHLA PH 1	SOKH1110	S/STN. 7, OKHLA,PH-1	Industrial	AMR	1.54	0.00	1.49	3.26%		100%
463	ALAKNANDA			0.05	66 KV OKHLA PH 1	SOKH1111	E.T.P.FEEDER NO.2	Mixed	AMR	0.05	0.00	0.05	1.46%		100%
464	ALAKNANDA			1.66	66 KV OKHLA PH 1	SOKH1112	DTC WORKSHOP, OKHLA,PH-1	Commercial	AMR	1.66	0.18	1.46	1.14%		100%
465	ALAKNANDA			1.78	66 KV OKHLA PH 1	SOKH1113	S/STN No. A	Industrial	AMR	1.78	0.26	1.49	1.63%		100%
466	ALAKNANDA			0.87	66 KV OKHLA PH 1	SOKH1114	PUL PAHLAD PUR	Commercial	AMR	0.87	0.13	0.74	0.48%		100%
467	ALAKNANDA			1.27	66 KV OKHLA PH 1	SOKH1115	S/STN -C, OKHLA, PH-1	Industrial	AMR	1.27	0.00	1.26	0.54%		100%
468	ALAKNANDA			1.04	66 KV OKHLA PH 1	SOKH1116	S/STN -2 OKHLA PH-1	Industrial	AMR	1.04	0.11	0.93	1.17%		100%

469	ALAKNANDA
470	ALAKNANDA
471	ALAKNANDA
472	ALAKNANDA
473	ALAKNANDA
474	ALAKNANDA
475	ALAKNANDA
476	ALAKNANDA
477	ALAKNANDA
478	ALAKNANDA
479	ALAKNANDA
480	ALAKNANDA
481	ALAKNANDA
482	ALAKNANDA
483	ALAKNANDA
484	ALAKNANDA
485	ALAKNANDA
486	ALAKNANDA
487	ALAKNANDA
488	ALAKNANDA
489	ALAKNANDA
490	ALAKNANDA
491	ALAKNANDA
492	ALAKNANDA
493	ALAKNANDA
494	ALAKNANDA
495	ALAKNANDA
496	ALAKNANDA
497	ALAKNANDA
498	ALAKNANDA
499	ALAKNANDA
500	ALAKNANDA
501	ALAKNANDA
502	ALAKNANDA
503	ALAKNANDA
504	ALAKNANDA
505	ALAKNANDA
506	ALAKNANDA
507	ALAKNANDA
508	ALAKNANDA
509	HAUZ KHAS
510	HAUZ KHAS
511	HAUZ KHAS
512	HAUZ KHAS
513	HAUZ KHAS
514	HAUZ KHAS
515	HAUZ KHAS
516	HAUZ KHAS
517	HAUZ KHAS
518	HAUZ KHAS
519	HAUZ KHAS
520	HAUZ KHAS
521	HAUZ KHAS

166.49

2.00	66 KV OKHLA PH 1	SOKH1117	S/STN F90/5 OKHLA PH-1	Commercial	AMR	2.00	0.31	1.64	2.34%	100%
1.53	66 KV OKHLA PH 1	SOKH1121	S/STN-10, OKHLA PH-1	Industrial	AMR	1.53	0.00	1.51	1.35%	100%
1.60	66 KV OKHLA PH 1	SOKH1122	S/STN -NO 6	Industrial	AMR	1.60	0.23	1.36	0.79%	100%
1.88	66 KV OKHLA PH 1	SOKH1123	S/STN.NO.9,OKHLA, PH-1	Industrial	AMR	1.88	0.33	1.54	0.53%	100%
0.04	66 KV OKHLA PH 1	SOKH1124	LOCAL TRANSFORMER	Local Grid	AMR	0.04	0.00	0.04	0.51%	100%
3.31	66 KV OKHLA PH 1	SOKH1125	CCJ,COMPLEX NO.2	Residential	AMR	3.31	0.67	2.62	0.43%	100%
0.87	66 KV OKHLA PH 1	SOKH1126	ESI HOSPITAL NO.-1 + D-176	Commercial	AMR	0.87	0.23	0.63	1.01%	100%
1.29	66 KV OKHLA PH 1	SOKH1130	S/5 NO. D-173	Industrial	AMR	1.29	0.00	1.28	0.94%	100%
3.34	66 KV OKHLA PH 1	SOKH1131	MCD SANITARY LAND	Public Utilities	AMR	3.34	0.71	2.61	0.74%	100%
0.81	66 KV OKHLA PH 1	SOKH1132	11 KV DLF PRIME TOWER FEEDER - 1	Commercial	AMR	0.81	0.21	0.59	0.87%	100%
0.00	66 KV OKHLA PH 1	SOKH1133	11 KV DLF PRIME TOWER FEEDER - 2	Commercial	AMR	0.00	0.00	0.00	0.35%	100%
0.50	66 KV OKHLA PH 1	SOKH1135	11 KV O/G NBCC	Commercial	AMR	0.50	0.13	0.36	2.91%	100%
3.18	66 KV OKHLA PH 1	SOKH1136	VILLAGE TEHKHAND	Residential	AMR	3.18	0.59	2.57	0.42%	100%
0.60	66 KV OKHLA PH 1	SOKH1137	DJB ESI NO.1	Public Utilities	AMR	0.60	0.00	0.60	0.69%	100%
2.10	66 KV OKHLA PH 1	SOKH1138	KANGAR MOHALLA TUGLAKABAD VILLAGE	Residential	AMR	2.10	0.00	2.08	0.89%	100%
0.95	66 KV OKHLA PH 1	SOKH1630	STN NO.3 SLUM FLATS, A 14, KALKKA JI EXT.	Mixed	AMR	0.95	0.00	0.95	0.01%	100%
0.65	33 KV OKHLA PH 2	SOKH2109	B-26 OKHLA PH -1	Industrial	AMR	0.65	0.08	0.56	1.18%	100%
0.85	33 KV OKHLA PH 2	SOKH2114	11KV O/G TODAY HOTEL-2	Commercial	AMR	0.85	0.09	0.74	2.42%	100%
1.77	33 KV OKHLA PH 2	SOKH2117	S/STN 12 OKHLA PH-1	Industrial	AMR	1.77	0.25	1.47	2.27%	100%
2.07	33 KV OKHLA PH 2	SOKH2122	11KV O/G TODAY HOTEL-1	Commercial	AMR	2.07	0.55	1.52	0.02%	100%
2.54	33 KV OKHLA PH 2	SOKH2123	11KV O/G SSTN 8 PH - 1	Industrial	AMR	2.54	0.00	2.48	2.50%	100%
1.06	33 KV OKHLA PH 2	SOKH2128	NBCC OKHLA -1	Commercial	AMR	1.06	0.28	0.76	2.49%	100%
0.00	33 KV D C SAKET	SSAKT101	C.C.M/MOTH	Mixed	AMR	0.00	0.00	0.00	0.33%	100%
1.01	33 KV Tuglakabad	STLBD111	O/G TO TUGLAKABAD EXT.	Mixed	AMR	1.01	0.00	0.99	1.28%	100%
3.82	33 KV Tuglakabad	STLBD114	TUGLAKABAD EXTN. S/STN. NO.1	Mixed	AMR	3.82	0.89	2.92	0.13%	100%
2.62	33 KV VSNL	SVSNL104	E BLOCK SEHEGAL MKT GK-II	Mixed	AMR	2.62	0.00	2.55	2.49%	100%
2.56	33 KV VSNL	SVSNL105	M BLOCK MOTHER DAIRY GK-II	Mixed	AMR	2.56	0.00	2.53	1.43%	100%
1.23	33 KV VSNL	SVSNL106	CC MASJID MOTH:ID	Mixed	AMR	1.23	0.00	1.22	1.37%	100%
2.75	33 KV VSNL	SVSNL108	VSNL / TCIL	Mixed	AMR	2.75	0.00	2.71	1.36%	100%
1.17	33 KV VSNL	SVSNL123	EPR GK ENCLAVE-2	Mixed	AMR	1.17	0.00	1.12	4.22%	100%
2.78	33 KV VSNL	SVSNL128	G.BLOCK MASJID MOTH	Mixed	AMR	2.78	0.00	2.74	1.39%	100%
2.12	33 KV VSNL	SVSNL129	NEHRU APARTMENT MARKET KALKKA JEE	Mixed	AMR	2.12	0.00	2.11	0.41%	100%
3.44	220 KV OKHLA TRANSCO GRID	TDTOG102	GOVINDPURI BUDHVIHAR (C LAL)	Residential	AMR	3.44	0.00	3.44	0.02%	100%
2.35	220 KV OKHLA TRANSCO GRID	TDTOG103	KALKAJI EXTN A-10	Residential	AMR	2.35	0.00	2.29	2.51%	100%
1.81	220 KV OKHLA TRANSCO GRID	TDTOG104	TRANSIT CAMP B	Residential	AMR	1.81	0.35	1.45	0.35%	100%
2.93	220 KV OKHLA TRANSCO GRID	TDTOG105	ALAKNANDA VIA TA PKT.	Mixed	AMR	2.93	0.00	2.89	1.21%	100%
2.59	220 KV OKHLA TRANSCO GRID	TDTOG106	KALKAJI EXTN A-12	Residential	AMR	2.59	0.00	2.58	0.24%	100%
2.68	220 KV OKHLA TRANSCO GRID	TDTOG107	KALKAJI EXTN POCKET A 8	Mixed	AMR	2.68	0.00	2.64	1.69%	100%
1.82	220 KV OKHLA TRANSCO GRID	TDTOG108	TARA APP	Mixed	AMR	1.82	0.00	1.81	0.40%	100%
3.39	220 KV OKHLA TRANSCO GRID	TDTOG109	GOVINDPURI GALI NO 13 (KHATTA)	Residential	AMR	3.39	0.00	3.38	0.29%	100%
3.36	33 KV ADHCHINI	SADCN103	C 1 TIKONA PARK	Residential	AMR	3.36	1.20	2.15	0.22%	100%
2.52	33 KV ADHCHINI	SADCN105	KATWARIA SARAI MULTI STORY	Residential	AMR	2.52	0.96	1.55	0.38%	100%
1.61	33 KV ADHCHINI	SADCN108	SIHA NO.2 S/STN	Mixed	AMR	1.61	0.72	0.88	0.58%	100%
2.46	33 KV ADHCHINI	SADCN109	I I T NO-3	Mixed	AMR	2.46	2.45	0.00	0.44%	100%
2.62	33 KV ADHCHINI	SADCN110	BHIM NAGARI	Mixed	AMR	2.62	0.00	2.60	1.01%	100%
0.79	33 KV ADHCHINI	SADCN122	B-8 Q.I.A FEEDER	Mixed	AMR	0.79	0.29	0.48	2.04%	100%
2.10	33 KV AIIMS - 2	SAIIM005	AIIMS SURGICAL BLK FDR-1	Mixed	AMR	2.10	0.84	1.25	0.48%	100%
0.89	33 KV AIIMS - 2	SAIIM006	AIIMS SURGICAL BLK FDR-2	Mixed	AMR	0.89	0.00	0.87	1.79%	100%
0.58	33 KV AIIMS - 2	SAIIM008	AIIMS GERIA TRICS BLK FDR-2	Mixed	AMR	0.58	0.00	0.58	0.96%	100%
0.04	33 KV AIIMS - 2	SAIIM014	LOCAL TRANSFORMER	Local Grid	AMR	0.04	0.00	0.04	0.51%	100%
3.25	33 KV BIKAJI CAMA	SBKCM105	B-4 S.J ENCLAVE	Residential	AMR	3.25	1.15	2.08	0.73%	100%
2.21	33 KV BIKAJI CAMA	SBKCM108	B-5 D.D.A S.J (ENCLAVE)	Residential	AMR	2.21	0.89	1.31	0.22%	100%
3.32	33 KV BIKAJI CAMA	SBKCM110	A-1 S.J ENCLAVE	Residential	AMR	3.32	1.20	2.11	0.06%	100%

522	HAUZ KHAS
523	HAUZ KHAS
524	HAUZ KHAS
525	HAUZ KHAS
526	HAUZ KHAS
527	HAUZ KHAS
528	HAUZ KHAS
529	HAUZ KHAS
530	HAUZ KHAS
531	HAUZ KHAS
532	HAUZ KHAS
533	HAUZ KHAS
534	HAUZ KHAS
535	HAUZ KHAS
536	HAUZ KHAS
537	HAUZ KHAS
538	HAUZ KHAS
539	HAUZ KHAS
540	HAUZ KHAS
541	HAUZ KHAS
542	HAUZ KHAS
543	HAUZ KHAS
544	HAUZ KHAS
545	HAUZ KHAS
546	HAUZ KHAS
547	HAUZ KHAS
548	HAUZ KHAS
549	HAUZ KHAS
550	HAUZ KHAS
551	HAUZ KHAS
552	HAUZ KHAS
553	HAUZ KHAS
554	HAUZ KHAS
555	HAUZ KHAS
556	HAUZ KHAS
557	HAUZ KHAS
558	HAUZ KHAS
559	HAUZ KHAS
560	HAUZ KHAS
561	HAUZ KHAS
562	HAUZ KHAS
563	HAUZ KHAS
564	HAUZ KHAS
565	HAUZ KHAS
566	HAUZ KHAS
567	HAUZ KHAS
568	HAUZ KHAS
569	HAUZ KHAS
570	HAUZ KHAS
571	HAUZ KHAS
572	HAUZ KHAS
573	HAUZ KHAS

3.42	33 KV BIKAJI CAMA	SBKCM113	S/STN B-6 (S.D.A)	Residential	AMR	3.42	1.21	2.20	0.29%	100%
2.95	33 KV BIKAJI CAMA	SBKCM116	B 3 ZANDHU SINGH MARG	Residential	AMR	2.95	0.00	2.94	0.34%	100%
2.32	33 KV BIKAJI CAMA	SBKCM118	GREEN PARK EXTN.	Mixed	AMR	2.32	0.00	2.29	1.46%	100%
2.62	33 KV BIKAJI CAMA	SBKCM122	CREMATION GROUND GREEN PARK EXT.	Residential	AMR	2.62	0.94	1.67	0.38%	100%
2.74	33 KV BIKAJI CAMA	SBKCM124	11KV O/G RAJ NAGAR	Residential	AMR	2.74	1.00	1.73	0.37%	100%
4.33	33 KV BIKAJI CAMA	SBKCM125	B-7 SAFDARJANG ENCLAVE	Residential	AMR	4.33	0.00	4.32	0.23%	100%
3.15	33 KV BIKAJI CAMA	SBKCM129	A-2/15 SAFDARJUNG ENCLAVE	Residential	AMR	3.15	1.10	2.05	0.32%	100%
1.68	33 KV HUDCO GRID	SHUDC101	11 KV O/G 4 PANEL BOARD HUDCO	Residential	AMR	1.68	0.69	0.99	0.41%	100%
2.83	33 KV HUDCO GRID	SHUDC103	HUDCO S.STN NO.6	Residential	AMR	2.83	0.00	2.80	0.90%	100%
4.32	33 KV HUDCO GRID	SHUDC104	POLICE COLONY	Residential	AMR	4.32	0.00	4.30	0.37%	100%
0.97	33 KV HUDCO GRID	SHUDC105	11 KV O/G I.O.C BUILDING	Mixed	AMR	0.97	0.45	0.50	1.97%	100%
1.48	33 KV HUDCO GRID	SHUDC106	11 KV O/G NDSE _ II	Commercial	AMR	1.48	0.00	1.47	0.99%	100%
3.11	33 KV HUDCO GRID	SHUDC107	11 KV O/G AIIMS	Residential	AMR	3.11	1.27	1.83	0.32%	100%
2.15	33 KV HUDCO GRID	SHUDC109	11 KV O/G AV NAGAR S/S - 2	Residential	AMR	2.15	0.87	1.26	1.03%	100%
0.02	33 KV HUDCO GRID	SHUDC110	11KV O/G LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.32%	100%
1.86	33 KV HUDCO GRID	SHUDC112	HUDCO S.STN NO.2 + YUSUF SARAI COMM. CENTER	Mixed	AMR	1.86	0.00	1.85	0.70%	100%
2.16	33 KV HUDCO GRID	SHUDC116	HARDEV PURI	Residential	AMR	2.16	0.00	2.14	0.72%	100%
1.72	33 KV HUDCO GRID	SHUDC118	ISRO SADIQ NAGAR	Mixed	AMR	1.72	0.67	1.04	0.33%	100%
0.00	33 KV HUDCO GRID	SHUDC414	SIRIFORT STADIUM (MAIN)	Commercial	AMR	0.00	0.00	0.00	0.36%	100%
1.18	33 KV IIT	SIITG104	SIIA NO-1	Commercial	AMR	1.18	0.59	0.58	1.02%	100%
1.19	33 KV IIT	SIITG105	SIIA NO-4	Commercial	AMR	1.19	0.58	0.59	1.57%	100%
2.78	33 KV IIT	SIITG106	BHARTI SCHOOL - 1 +CSMRS	Mixed	AMR	2.78	1.04	1.73	0.34%	100%
2.24	33 KV IIT	SIITG107	TIFAK BULD NO-4	Commercial	AMR	2.24	0.83	1.40	0.45%	100%
0.01	33 KV IIT	SIITG108	LOCAL TRANSFORMER	Local Grid	AMR	0.01	0.00	0.01	0.39%	100%
2.24	33 KV IIT	SIITG109	SIIA NO-5 KATWARIA SARAI	Mixed	AMR	2.24	0.93	1.30	0.45%	100%
3.48	33 KV IIT	SIITG110	MINI CAMPUS	Residential	AMR	3.48	0.00	3.47	0.34%	100%
3.77	33 KV IIT	SIITG113	IIT S/STN - 3	Mixed	AMR	3.77	3.75	0.00	0.44%	100%
1.39	33 KV IIT	SIITG115	O/G BHARTI SCHOOL-2 +TELEPHONE EXCH	Mixed	AMR	1.39	0.66	0.72	0.47%	100%
0.72	33 KV IIT	SIITG116	O/G PROFESSOR FLATS IIT SSTN-3	Residential	AMR	0.72	0.00	0.70	3.22%	100%
4.29	66 KV JNU	SJNUG101	11 KV O/G N. INST. IMMUNOLOGY	Commercial	AMR	4.29	1.50	2.79	0.04%	100%
2.66	66 KV JNU	SJNUG106	11 KV O/G JNU CAMPUS	Commercial	AMR	2.66	2.64	0.00	0.78%	100%
0.04	66 KV JNU	SJNUG116	11 KV O/G LOCAL TRANSFORMER	Local Grid	AMR	0.04	0.00	0.04	0.46%	100%
2.36	66 KV JNU	SJNUG117	11 KV O/G JNU NO. II	Commercial	AMR	2.36	2.35	0.00	0.38%	100%
0.81	33 KV MASJID MOTH GRID	SMMOT104	11 KV O/G DAKSHIN DEEP S/STN	Residential	AMR	0.81	0.42	0.38	1.32%	100%
2.58	33 KV MASJID MOTH GRID	SMMOT106	11 KV O/G SOAMI NAGAR	Residential	AMR	2.58	0.00	2.56	0.68%	100%
2.41	33 KV MASJID MOTH GRID	SMMOT111	B&C BLOCK PANCHSHEEL ENC.	Residential	AMR	2.41	0.00	2.37	1.55%	100%
0.02	33 KV MASJID MOTH GRID	SMMOT118	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.01	0.01	0.25%	100%
0.15	33 KV MASJID MOTH GRID	SMMOT120	C7 PANCHSHEEL PARK, RMU	Residential	AMR	0.15	0.00	0.14	3.39%	100%
2.99	33 KV NDSE II	SNDS101	D12 YES BANK NDSE-2	Mixed	AMR	2.99	1.26	1.71	0.82%	100%
2.18	33 KV NDSE II	SNDS104	11 KV O/G GREEN PARK EXTN.	Mixed	AMR	2.18	0.87	1.30	0.83%	100%
0.42	33 KV NDSE II	SNDS105	11KV O/G DJB PUMP/STN+HAZOORI LAL	Mixed	AMR	0.42	0.11	0.30	1.72%	100%
1.58	33 KV NDSE II	SNDS106	11 KV ANDREWS GANJ MAIN	Residential	AMR	1.58	0.67	0.89	1.03%	100%
0.28	33 KV NDSE II	SNDS107	11 KV O/G COMMUNITY CENTER	Residential	AMR	0.28	0.10	0.16	3.97%	100%
3.52	33 KV NDSE II	SNDS108	11 KV O/G ANDRWES GANJ POLICE CLY	Residential	AMR	3.52	0.00	3.50	0.64%	100%
0.43	33 KV NDSE II	SNDS109	11 KV O/G MEDICAL ENCLAVE	Commercial	AMR	0.43	0.00	0.42	2.20%	100%
1.95	33 KV NDSE II	SNDS116	AIIMS STAFF QTRS.	Residential	AMR	1.95	0.76	1.17	0.95%	100%
0.02	33 KV NDSE II	SNDS323	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.20%	100%
1.15	33 KV R.K.Puram - 1	SRKP1111	11kv R.K. Khanna stadium CWG	Mixed	AMR	1.15	0.00	1.13	1.61%	100%
2.27	33 KV R.K.PURAM -II	SRKP2119	11KV R.K. KHANNA STADIUM CWG	Mixed	AMR	2.27	0.00	2.26	0.44%	100%
2.35	33 KV SHIVALIK	SSHIV106	11 KV O/G S-BLK PANCHSHEEL PRK(S)	Residential	AMR	2.35	0.00	2.33	0.45%	100%
1.63	33 KV SHIVALIK	SSHIV110	O/G TO C-1 BHIM NAGAR S.D.A.	Residential	AMR	1.63	0.00	1.63	0.06%	100%
0.79	33 KV SHIVALIK	SSHIV111	O/G TO TIKONA PARK S.D.A.	Residential	AMR	0.79	0.00	0.78	1.33%	100%

574	HAUZ KHAS
575	HAUZ KHAS
576	HAUZ KHAS
577	HAUZ KHAS
578	HAUZ KHAS
579	HAUZ KHAS
580	HAUZ KHAS
581	HAUZ KHAS
582	HAUZ KHAS
583	HAUZ KHAS
584	HAUZ KHAS
585	HAUZ KHAS
586	HAUZ KHAS
587	HAUZ KHAS
588	HAUZ KHAS
589	HAUZ KHAS
590	HAUZ KHAS
591	HAUZ KHAS
592	HAUZ KHAS
593	HAUZ KHAS
594	HAUZ KHAS
595	HAUZ KHAS
596	HAUZ KHAS
597	HAUZ KHAS
598	HAUZ KHAS
599	HAUZ KHAS
600	R.K.PURAM
601	R.K.PURAM
602	R.K.PURAM
603	R.K.PURAM
604	R.K.PURAM
605	R.K.PURAM
606	R.K.PURAM
607	R.K.PURAM
608	R.K.PURAM
609	R.K.PURAM
610	R.K.PURAM
611	R.K.PURAM
612	R.K.PURAM
613	R.K.PURAM
614	R.K.PURAM
615	R.K.PURAM
616	R.K.PURAM
617	R.K.PURAM
618	R.K.PURAM
619	R.K.PURAM
620	R.K.PURAM
621	R.K.PURAM
622	R.K.PURAM

128.04

1.28	33 KV SHIVALIK	SSHIV123	O/G TO L BLK HAUZ KHAS	Residential	AMR	1.28	0.60	0.69	0.09%	100%
2.17	33 KV SHIVALIK	SSHIV301	MAY FAIR GARDEN	Residential	AMR	2.17	0.89	1.26	0.49%	100%
0.58	33 KV SHIVALIK	SSHIV418	SIRIFORT SPORTS COMPLEX (TRA. AVEN)	Commercial	AMR	0.58	0.23	0.34	2.01%	100%
2.05	33 KV SIRI FORT	SSHRI101	11 KV O/G NITI BAG S/STN	Residential	AMR	2.05	0.00	2.05	0.45%	100%
1.59	33 KV SIRI FORT	SSHRI102	11 KV O/G E-BLOCK HAUZ KHAS	Residential	AMR	1.59	0.00	1.57	1.60%	100%
4.13	33 KV SIRI FORT	SSHRI103	11 KV O/G GREEN PARK MAIN	Mixed	AMR	4.13	0.00	4.12	0.21%	100%
2.77	33 KV SIRI FORT	SSHRI104	11 KV O/G PHD HOUSE	Commercial	AMR	2.77	0.98	1.76	1.15%	100%
0.84	33 KV SIRI FORT	SSHRI105	11kv O/G AGV Complex S/S No-II	Residential	AMR	0.84	0.41	0.43	0.81%	100%
2.67	33 KV SIRI FORT	SSHRI106	INSTITUTIONAL AREA HAUZ KHAS	Commercial	AMR	2.67	0.00	2.65	0.57%	100%
2.21	33 KV SIRI FORT	SSHRI107	N 98 PANCHSHEEL	Residential	AMR	2.21	0.00	2.20	0.45%	100%
2.96	33 KV SIRI FORT	SSHRI108	11 KV O/G GULMOHAR PARK	Residential	AMR	2.96	0.00	2.95	0.34%	100%
0.37	33 KV SIRI FORT	SSHRI110	11kv Sirifort Sports stadium	Commercial	AMR	0.37	0.10	0.27	1.32%	100%
0.69	33 KV SIRI FORT	SSHRI111	11 KV O/G C.W.C S/STN	Commercial	AMR	0.69	0.68	0.00	0.59%	100%
2.46	33 KV SIRI FORT	SSHRI112	11 KV O/G PANCHSEEL CLUB S/S	Residential	AMR	2.46	0.98	1.47	0.45%	100%
0.69	33 KV SIRI FORT	SSHRI113	11 KV O/G AGVC CULTURAL CENTER	Commercial	AMR	0.69	0.26	0.43	0.79%	100%
0.02	33 KV SIRI FORT	SSHRI117	LOCAL TRAFORMER NO 1	Local Grid	AMR	0.02	0.00	0.02	0.26%	100%
0.68	33 KV SIRI FORT	SSHRI118	11 KV O/G AGV COMPLEX S/S NO III	Residential	AMR	0.68	0.00	0.66	2.99%	100%
2.93	33 KV SIRI FORT	SSHRI119	O/G TO 40 SAHAPUR JAT	Mixed	AMR	2.93	0.00	2.92	0.34%	100%
3.12	33 KV SIRI FORT	SSHRI120	GULMOHAR ENCLAVE	Residential	AMR	3.12	1.12	2.00	0.01%	100%
0.00	33 KV SIRI FORT	SSHRI121	LOCAL TRANSFORMER NO-2	Local Grid	AMR	0.00	0.00	0.00	0.37%	100%
0.53	33 KV SIRI FORT	SSHRI123	CPC DOOR DARSHAN	Commercial	AMR	0.53	0.51	0.00	2.55%	100%
2.17	33 KV SIRI FORT	SSHRI125	11 KV O/G P-SHEEL SHOPPING CENTER	Mixed	AMR	2.17	0.81	1.35	0.37%	100%
0.21	33 KV SIRI FORT	SSHRI324	11 SIRIFORT SPORTS COM. (TRAIN. AV)	Commercial	AMR	0.21	0.00	0.20	1.04%	100%
1.24	66 KV VASANT KUNJ B	SVKGB102	11 KV O/G S/S BIOTECH NO. 1	Commercial	AMR	1.24	0.61	0.63	0.23%	100%
2.16	66 KV VASANT KUNJ B	SVKGB103	11 KV O/G NUCLEAR SCIENCE CENTRE	Commercial	AMR	2.16	0.80	1.35	0.29%	100%
0.52	66 KV VASANT KUNJ B	SVKGB109	11 KV O/G S/STN BIOTECH NO-II	Commercial	AMR	0.52	0.14	0.38	1.34%	100%
6.45	66 KV RIDGE VALLEY	151247916	DMRC DHAULA KUAN	Commercial	AMR	6.45	6.42	0.00	0.37%	100%
11.19	220 KV VASANT KUNJ GRID	151483488	DMRC SEC 4, R.K PURAM	Commercial	AMR	11.19	11.15	0.00	0.37%	100%
0.23	33 KV BIKAJI CAMA	SBKCM102	S/STN -III BIKAJI CAMA PLACE	Commercial	AMR	0.23	0.06	0.17	1.43%	100%
0.59	33 KV BIKAJI CAMA	SBKCM103	PLOT NO. 25 S/STN A.K BHAWAN+NBCC	Commercial	AMR	0.59	0.19	0.38	3.56%	100%
0.28	33 KV BIKAJI CAMA	SBKCM106	PLOT NO.14 Mohdpur	Commercial	AMR	0.28	0.28	0.00	0.99%	100%
0.62	33 KV BIKAJI CAMA	SBKCM107	M.T.N.L.BLDG DVB S/S	Commercial	AMR	0.62	0.14	0.46	1.51%	100%
0.84	33 KV BIKAJI CAMA	SBKCM109	PLOT NO. 16 GAIL	Commercial	AMR	0.84	0.82	0.00	2.25%	100%
3.39	33 KV BIKAJI CAMA	SBKCM111	HOTEL HYATT BIKAJI CAMA PLACE	Commercial	AMR	3.39	3.37	0.00	0.50%	100%
1.58	33 KV BIKAJI CAMA	SBKCM112	E.I.I BIKAJI CAMA PLACE	Commercial	AMR	1.58	0.00	1.57	1.05%	100%
0.77	33 KV BIKAJI CAMA	SBKCM114	PLOT NO.5 S/STN BIKAJI CAMA PLACE	Commercial	AMR	0.77	0.17	0.59	2.10%	100%
0.45	33 KV BIKAJI CAMA	SBKCM115	PLOT NO. 11 S/STN BIKAJI CAMA PLACE	Commercial	AMR	0.45	0.12	0.33	1.66%	100%
1.36	33 KV BIKAJI CAMA	SBKCM117	PLOT NO. 6 BIKAJI CAMA PLACE	Commercial	AMR	1.36	0.32	1.03	0.82%	100%
0.01	33 KV BIKAJI CAMA	SBKCM120	LOCAL TRANSFORMER	Local Grid	AMR	0.01	0.00	0.01	0.38%	100%
1.49	33 KV BIKAJI CAMA	SBKCM126	MOHMADPUR VILLAGE	Mixed	AMR	1.49	0.00	1.48	0.93%	100%
0.52	33 KV BIKAJI CAMA	SBKCM127	NBCC TOWER	Commercial	AMR	0.52	0.00	0.51	1.78%	100%
1.06	33 KV IIT	SIITG112	FCI MUNIRKA (JNU OLD CAMPUS)	Mixed	AMR	1.06	0.26	0.79	1.77%	100%
2.99	66 KV JNU	SJUG102	11 KV O/G MUNRIKA VIHAR	Mixed	AMR	2.99	0.00	2.98	0.43%	100%
0.96	66 KV JNU	SJUG103	11 KV O/G VASANT LOK	Commercial	AMR	0.96	0.00	0.93	2.80%	100%
2.20	66 KV JNU	SJUG104	11 KV O/G S/S-3, DDA FLAT MUNIRKA	Residential	AMR	2.20	0.00	2.13	3.16%	100%
1.66	66 KV JNU	SJUG105	11 KV O/G HOTEL SIDDARTHA	Mixed	AMR	1.66	0.41	1.23	0.77%	100%
2.97	66 KV JNU	SJUG107	11 KV O/G S/S 2 SFS V VIHAR	Residential	AMR	2.97	0.74	2.22	0.34%	100%
1.21	66 KV JNU	SJUG108	11 KV O/G BUDH VIHAR O/H	Mixed	AMR	1.20	0.00	1.18	2.13%	100%
1.76	33 KV R.K.Puram - 1	SRKP1101	11 KV O/G R.K. PURAM SEC VI	Mixed	AMR	1.76	0.44	1.31	0.05%	100%

623	R.K.PURAM	1.48	33 KV R.K.Puram - 1	SRKP1103	11 KV O/G SEWA BHAWAN	Commercial	AMR	1.48	0.00	1.45	1.43%	100%
624	R.K.PURAM	3.56	33 KV R.K.Puram - 1	SRKP1104	MUNIRKA DDA FLAT	Mixed	AMR	3.56	0.90	2.65	0.28%	100%
625	R.K.PURAM	0.46	33 KV R.K.Puram - 1	SRKP1105	11 KV O/G R.K. PURAM WEST BLOCK	Commercial	AMR	0.46	0.12	0.34	2.06%	100%
626	R.K.PURAM	2.77	33 KV R.K.Puram - 1	SRKP1106	11 KV O/G VASANT VIHAR E - 1	Mixed	AMR	2.77	0.69	2.07	0.46%	100%
627	R.K.PURAM	2.17	33 KV R.K.Puram - 1	SRKP1107	11 KV O/G R.K. PURAM SEC IX	Mixed	AMR	2.17	0.48	1.67	0.84%	100%
628	R.K.PURAM	1.06	33 KV R.K.Puram - 1	SRKP1108	11 KV O/G SCIENTIFIC HOSTEL	Residential	AMR	1.06	0.00	1.05	1.06%	100%
629	R.K.PURAM	1.38	33 KV R.K.Puram - 1	SRKP1109	11 KV O/G JNU ACADAMY	Mixed	AMR	1.38	0.34	1.02	1.29%	100%
630	R.K.PURAM	0.36	33 KV R.K.Puram - 1	SRKP1110	11 KV O/G R.K.P EAST BLOCK	Commercial	AMR	0.36	0.00	0.35	2.45%	100%
631	R.K.PURAM	0.82	33 KV R.K.Puram - 1	SRKP1112	11 KV O/G R.K.P SEC- 2	Residential	AMR	0.82	0.21	0.61	0.38%	100%
632	R.K.PURAM	2.16	33 KV R.K.Puram - 1	SRKP1113	11 KV O/G R.K.P SEC -12	Mixed	AMR	2.16	0.54	1.62	0.10%	100%
633	R.K.PURAM	0.01	33 KV R.K.Puram - 1	SRKP1118	11 KV O/G LOCAL TRANSFORMER	Local Grid	AMR	0.01	0.00	0.00	0.37%	100%
634	R.K.PURAM	1.19	33 KV R.K.PURAM -II	SRKP2108	WEST BLOCK CPWD RKP	Commercial	AMR	1.19	1.18	0.00	0.73%	100%
635	R.K.PURAM	2.58	33 KV R.K.PURAM -II	SRKP2109	R K PURAM SECTOR - 7	Mixed	AMR	2.58	0.64	1.92	0.94%	100%
636	R.K.PURAM	0.82	33 KV R.K.PURAM -II	SRKP2110	NIVEDITA KUNJ S/STN - 5	Residential	AMR	0.82	0.00	0.81	1.57%	100%
637	R.K.PURAM	1.66	33 KV R.K.PURAM -II	SRKP2111	NIVEDITA KUNJ S/STN - 2	Residential	AMR	1.66	0.42	1.23	0.33%	100%
638	R.K.PURAM	2.18	33 KV R.K.PURAM -II	SRKP2112	R K PURAM SECTOR - 4	Mixed	AMR	2.18	0.00	2.17	0.46%	100%
639	R.K.PURAM	3.55	33 KV R.K.PURAM -II	SRKP2113	CANARA BANK	Mixed	AMR	3.55	0.00	3.53	0.64%	100%
640	R.K.PURAM	0.20	33 KV R.K.PURAM -II	SRKP2114	NIVEDITA KUNJ S/STN - 1	Residential	AMR	0.20	0.05	0.15	1.42%	100%
641	R.K.PURAM	0.03	33 KV R.K.PURAM -II	SRKP2115	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	0.39%	100%
642	R.K.PURAM	0.89	33 KV R.K.PURAM -II	SRKP2120	SEWA BHAWAN	Mixed	AMR	0.89	0.21	0.66	1.58%	100%
643	R.K.PURAM	3.25	33 KV R.K.PURAM -II	SRKP2122	O/G S/STN NO. 1, SEC-1, R.K PURAM	Mixed	AMR	3.25	0.00	3.22	1.17%	100%
644	R.K.PURAM	0.52	33 KV R.K.PURAM -II	SRKP2123	11 KV O/G AIR HEAD QUATER FEEDER-1	Commercial	AMR	0.52	0.14	0.38	0.42%	100%
645	R.K.PURAM	1.18	33 KV R.K.PURAM -II	SRKP2124	11 KV O/G CPWD EAST BLOCK	Commercial	AMR	1.18	0.27	0.89	1.11%	100%
646	R.K.PURAM	0.86	33 KV R.K.PURAM -II	SRKP2129	11 KV 3W O/D RMU INSIDE GRID	Commercial	AMR	0.86	0.00	0.85	1.31%	100%
647	R.K.PURAM	2.59	33 KV R.K.PURAM -II	SRKP2132	CAR PARKING MUNIRKA	Mixed	AMR	2.59	0.65	1.91	1.20%	100%
648	R.K.PURAM	0.05	66 KV RIDGE VALLEY	SRVAL104	LOCAL TRANSFORMER	Local Grid	AMR	0.05	0.00	0.05	0.52%	100%
649	R.K.PURAM	2.49	66 KV RIDGE VALLEY	SRVAL105	SOUTH CAMPUS NEW	Mixed	AMR	2.49	0.62	1.84	1.13%	100%
650	R.K.PURAM	3.27	66 KV RIDGE VALLEY	SRVAL106	A.R.S.D COLLEGE SATYA NIKETAN	Mixed	AMR	3.27	0.83	2.42	0.65%	100%
651	R.K.PURAM	0.61	66 KV RIDGE VALLEY	SRVAL108	11 KV ST. LTG NO.1 (PALAM ROAD)	Public Utilities	AMR	0.61	0.00	0.59	2.92%	100%
652	R.K.PURAM	2.64	66 KV RIDGE VALLEY	SRVAL110	MOTI BAGH O/H	Mixed	AMR	2.64	0.66	1.92	2.11%	100%
653	R.K.PURAM	0.20	66 KV RIDGE VALLEY	SRVAL128	PWD DHAULA KUAN FLYOVER	Mixed	AMR	0.20	0.05	0.14	0.65%	100%
654	R.K.PURAM	2.60	66 KV RIDGE VALLEY	SRVAL136	VENKATESHWAR COLLEGE OLD CAMPUS	Mixed	AMR	2.60	0.66	1.93	0.51%	100%
655	R.K.PURAM	0.02	66 KV RIDGE VALLEY	SRVAL137	630 KVA LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.29%	100%
656	R.K.PURAM	0.29	66 KV RIDGE VALLEY	SRVAL637	MOTI BAGH GURUDWARA	Mixed	AMR	0.29	0.00	0.29	1.10%	100%
657	R.K.PURAM	1.28	33 KV Vasant Vihar	SVVHR102	11 KV O/G B BLK V VIHAR FDR NO. 1	Residential	AMR	1.28	0.00	1.27	0.59%	100%
658	R.K.PURAM	2.65	33 KV Vasant Vihar	SVVHR103	11 KV O/G F BLOCK V VIHAR	Residential	AMR	2.65	0.00	2.64	0.54%	100%
659	R.K.PURAM	3.31	33 KV Vasant Vihar	SVVHR104	O/G WESTEND COLONY S/STN	Residential	AMR	3.31	0.00	3.26	1.72%	100%
660	R.K.PURAM	3.82	33 KV Vasant Vihar	SVVHR105	11 KV O/G ANAND NIKETAN	Mixed	AMR	3.82	0.96	2.85	0.26%	100%
661	R.K.PURAM	3.35	33 KV Vasant Vihar	SVVHR107	11 KV O/G D BLOCK V VIHAR	Residential	AMR	3.35	0.83	2.51	0.30%	100%
662	R.K.PURAM	3.10	33 KV Vasant Vihar	SVVHR108	11 KV O/G A BLOCK VASANT VIHAR	Residential	AMR	3.10	0.00	3.08	0.61%	100%
663	R.K.PURAM	1.22	33 KV Vasant Vihar	SVVHR109	11KV O/G VASANT ENCLAVE FEEDER NO.2	Mixed	AMR	1.22	0.30	0.92	0.20%	100%
664	R.K.PURAM	3.00	33 KV Vasant Vihar	SVVHR110	11 KV O/G MES SUBROTO PARK	Mixed	AMR	3.00	0.00	2.98	0.81%	100%
665	R.K.PURAM	1.67	33 KV Vasant Vihar	SVVHR111	VASANT ENCLAVE S/STN NO. 1	Residential	AMR	1.67	0.00	1.66	0.80%	100%
666	R.K.PURAM	2.92	33 KV Vasant Vihar	SVVHR112	11 KV O/G VASANT MARG COMPLAINT CEN	Residential	AMR	2.92	0.75	2.16	0.60%	100%
667	R.K.PURAM	2.27	33 KV Vasant Vihar	SVVHR113	11 KV O/G B BLK V VIHAR FDR NO. 2	Mixed	AMR	2.27	0.58	1.68	0.45%	100%
668	R.K.PURAM	0.04	33 KV Vasant Vihar	SVVHR116	LOCAL TRANSFORMER	Local Grid	AMR	0.04	0.00	0.04	0.48%	100%
669	R.K.PURAM	0.96	33 KV Vasant Vihar	SVVHR118	NIRYAT BHAVAN	Mixed	AMR	0.96	0.23	0.73	0.70%	100%
670	R.K.PURAM	2.12	33 KV Vasant Vihar	SVVHR119	VASANT LOK COMMUNITY CENTER	Commercial	AMR	2.12	0.52	1.59	0.15%	100%
671	R.K.PURAM	1.83	33 KV Vasant Vihar	SVVHR120	C-BLK VASANT VIHAR	Mixed	AMR	1.83	0.00	1.77	3.27%	100%
672	SAKET	5.76	66 KV MALVIYA NAGAR	100014206	33 KV SELECT CITYWALK	Commercial	AMR	5.76	5.73	0.00	0.37%	100%

595.01

322.93

673	SAKET
674	SAKET
675	SAKET
676	SAKET
677	SAKET
678	SAKET
679	SAKET
680	SAKET
681	SAKET
682	SAKET
683	SAKET
684	SAKET
685	SAKET
686	SAKET
687	SAKET
688	SAKET
689	SAKET
690	SAKET
691	SAKET
692	SAKET
693	SAKET
694	SAKET
695	SAKET
696	SAKET
697	SAKET
698	SAKET
699	SAKET
700	SAKET
701	SAKET
702	SAKET
703	SAKET
704	SAKET
705	SAKET
706	SAKET
707	SAKET
708	SAKET
709	SAKET
710	SAKET
711	SAKET
712	SAKET
713	SAKET
714	SAKET
715	SAKET
716	SAKET
717	SAKET
718	SAKET
719	SAKET
720	SAKET
721	SAKET
722	SAKET
723	SAKET
724	SAKET
725	SAKET

13.34	220 KV MEHRAULI GRID	I50011446	66 KV DMRC MEHRAULI	Commercial	AMR	13.34	13.29	0.00	0.37%	100%
2.29	66 KV C-DOT GRID	SCDOT618	66 KV O/G CKT-1 CDOT(KCC)	Commercial	AMR	2.29	2.28	0.00	0.37%	100%
0.00	66 KV C-DOT GRID	SCDOT619	66 KV O/G CKT-2 CDOT(KCC)	Commercial	AMR	0.00	0.00	0.00	0.00%	100%
1.09	South Asian university		South Asian university	Commercial	AMR	1.09	1.09	0.00	0.37%	100%
1.40	33 KV ANDHERIA BAG	SABAG101	DURGA ASHRAM, CHATTARPUR	Mixed	AMR	1.40	0.39	0.96	3.55%	100%
2.16	33 KV ANDHERIA BAG	SABAG102	11 KV O/G JONAPUR	Mixed	AMR	2.16	0.51	1.58	3.12%	100%
1.15	33 KV ANDHERIA BAG	SABAG103	HARGOVIND ENCLAVE, RAJPUR	Mixed	AMR	1.15	0.31	0.80	3.25%	100%
3.17	33 KV ANDHERIA BAG	SABAG105	11 KV O/G NBCC	Commercial	AMR	3.17	0.76	2.31	3.40%	100%
2.90	33 KV ANDHERIA BAG	SABAG111	STP MEHROULI	Residential	AMR	2.90	0.00	2.82	2.52%	100%
3.15	33 KV ANDHERIA BAG	SABAG113	DLF CHHATARPUR	Mixed	AMR	3.15	0.00	3.07	2.49%	100%
5.28	33 KV ANDHERIA BAG	SABAG117	11 KV O/G SATBARI	Residential	AMR	5.28	1.30	3.80	3.21%	100%
3.07	33 KV ADHCHINI	SADCN101	LADO SARAI	Mixed	AMR	3.07	0.78	2.21	2.43%	100%
2.07	33 KV ADHCHINI	SADCN102	SARVODAYS ENCLAVE	Mixed	AMR	2.07	0.00	2.01	3.08%	100%
1.78	33 KV ADHCHINI	SADCN104	A- BLOCK SHIVALIK	Mixed	AMR	1.78	0.00	1.73	3.20%	100%
2.09	33 KV ADHCHINI	SADCN106	MMTC	Residential	AMR	2.09	0.00	2.02	3.40%	100%
3.45	33 KV ADHCHINI	SADCN107	MALVIYA NAGAR	Mixed	AMR	3.45	0.00	3.36	2.71%	100%
0.90	33 KV ADHCHINI	SADCN113	AURBINDO MARG	Mixed	AMR	0.90	0.00	0.87	3.67%	100%
0.07	33 KV ADHCHINI	SADCN114	LOCAL TRANSFORMER	Local Grid	AMR	0.07	0.00	0.07	2.55%	100%
1.71	33 KV ADHCHINI	SADCN119	MALVIYA NAGAR HOSPITAL	Commercial	AMR	1.71	0.45	1.22	2.56%	100%
0.07	33 KV ADHCHINI	SADCN120	D.J.B MALVIYA NAGAR-2 (VIA AURVINDO COLEGE)	Commercial	AMR	0.07	0.07	0.00	0.22%	100%
2.89	33 KV ADHCHINI	SADCN121	ADHCHINI CROSSING	Mixed	AMR	2.89	0.63	2.19	2.58%	100%
0.02	66 KV CAPFIMS GRID	SCAPF009	11 KV LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	2.23%	100%
3.69	66 KV C-DOT GRID	SCDOT102	MEHAR CHAND TR DLF	Residential	AMR	3.69	0.93	2.64	3.02%	100%
3.52	66 KV C-DOT GRID	SCDOT103	MCD Park Chhatar Pur No.1	Residential	AMR	3.52	0.00	3.38	4.06%	100%
0.03	66 KV C-DOT GRID	SCDOT106	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.02	2.37%	100%
3.60	66 KV C-DOT GRID	SCDOT108	ASHWANI KUMAR MEHRA HOTEL (D-1)	Mixed	AMR	3.60	0.00	3.54	1.68%	100%
1.15	66 KV C-DOT GRID	SCDOT109	O/G MANGLA PURI	Mixed	AMR	1.15	0.00	1.11	3.27%	100%
2.23	66 KV C-DOT GRID	SCDOT110	O/G MES	Mixed	AMR	2.23	0.53	1.63	2.92%	100%
0.27	66 KV C-DOT GRID	SCDOT111	CHADDA FARM	Commercial	AMR	0.27	0.07	0.19	2.59%	100%
4.29	66 KV C-DOT GRID	SCDOT112	O/G SULTANPUR COLONY	Mixed	AMR	4.29	1.08	3.08	3.22%	100%
2.14	66 KV C-DOT GRID	SCDOT117	AAYA NAGAR	Residential	AMR	2.14	0.00	2.06	3.43%	100%
4.12	66 KV C-DOT GRID	SCDOT120	O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	Residential	AMR	4.12	0.00	4.04	1.81%	100%
0.62	66 KV C-DOT GRID	SCDOT122	IIPM NO-2	Mixed	AMR	0.62	0.19	0.41	3.29%	100%
3.84	66 KV C-DOT GRID	SCDOT124	11 KV O/G DJB	Mixed	AMR	3.84	0.00	3.75	2.46%	100%
2.95	66 KV C-DOT GRID	SCDOT125	O/G JONAPUR (RMU NO.-3 MANDI ROAD)	Residential	AMR	2.95	0.00	2.84	3.78%	100%
2.78	66 KV C-DOT GRID	SCDOT126	(LUTYAN HOTEL RMU) NTRO NO.-2	Mixed	AMR	2.78	0.71	2.00	2.60%	100%
2.76	66 KV C-DOT GRID	SCDOT127	CHATTARPUR-2	Residential	AMR	2.76	0.00	2.68	2.62%	100%
0.98	66 KV C-DOT GRID	SCDOT128	IIPM-1	Residential	AMR	0.98	0.24	0.71	3.26%	100%
2.68	66 KV C-DOT GRID	SCDOT129	DLF GATE NO.-1	Residential	AMR	2.68	0.00	2.60	2.78%	100%
4.11	66 KV C-DOT GRID	SCDOT130	DLF GATE-2 (MAIDAN GARHI)	Residential	AMR	4.11	1.03	2.91	4.07%	100%
4.14	66 KV C-DOT GRID	SCDOT131	RMU BANDH ROAD (RAJ SWARAJ)	Residential	AMR	4.14	0.00	4.05	2.15%	100%
0.00	66 KV C-DOT GRID	SCDOT132	LOCAL TRANSFORMER NO 2	Local Grid	AMR	0.00	0.00	0.00	2.35%	100%
3.62	66 KV C-DOT GRID	SCDOT133	RAJPUR KHURD	Residential	AMR	3.62	0.00	3.49	3.59%	100%
2.90	66 KV C-DOT GRID	SCDOT134	CENTRUM MALL SULTANPUR	Mixed	AMR	2.90	0.71	2.08	3.44%	100%
2.67	66 KV C-DOT GRID	SCDOT136	AIRFORCE ARJUN GARH NO.2	Commercial	AMR	2.67	0.00	2.60	2.85%	100%
2.96	66 KV C-DOT GRID	SCDOT137	AIRFORCE ARJUN GARH NO.1	Commercial	AMR	2.96	0.74	2.13	3.00%	100%
1.78	66 KV C-DOT GRID	SCDOT622	PANDIT MOHALLA VIA GADAIPUR CHECK POST	Mixed	AMR	1.78	0.00	1.72	3.36%	100%
0.20	66 KV C-DOT GRID	SCDOT625	L&T CHATERPUR METRO SSTN-NO.01	Commercial	AMR	0.20	0.00	0.19	2.58%	100%
2.17	66 KV C-DOT GRID	SCDOT627	MAIDAN GHARI EXTN. TUBEWELL	Mixed	AMR	2.17	0.00	2.10	3.10%	100%
0.40	66 KV FATEHPUR BERI	SFTPR101	RSSB S/STN-4	Public Utilities	AMR	0.40	0.00	0.38	3.28%	100%
3.20	66 KV FATEHPUR BERI	SFTPR102	G BLOCK AYA NAGAR	Residential	AMR	3.20	0.00	3.11	2.84%	100%
3.46	66 KV FATEHPUR BERI	SFTPR103	ANANT RAJ	Mixed	AMR	3.46	0.85	2.49	3.42%	100%
1.60	66 KV FATEHPUR BERI	SFTPR104	ANSAL FARMS	Residential	AMR	1.60	0.40	1.14	3.80%	100%

726	SAKET
727	SAKET
728	SAKET
729	SAKET
730	SAKET
731	SAKET
732	SAKET
733	SAKET
734	SAKET
735	SAKET
736	SAKET
737	SAKET
738	SAKET
739	SAKET
740	SAKET
741	SAKET
742	SAKET
743	SAKET
744	SAKET
745	SAKET
746	SAKET
747	SAKET
748	SAKET
749	SAKET
750	SAKET
751	SAKET
752	SAKET
753	SAKET
754	SAKET
755	SAKET
756	SAKET
757	SAKET
758	SAKET
759	SAKET
760	SAKET
761	SAKET
762	SAKET
763	SAKET
764	SAKET
765	SAKET
766	SAKET
767	SAKET
768	SAKET
769	SAKET
770	SAKET
771	SAKET
772	SAKET
773	SAKET
774	SAKET
775	SAKET
776	SAKET

3.77	66 KV FATEHPUR BERI	SFTPR105	DERA BHATI	Residential	AMR	3.77	0.95	2.70	3.23%	100%
1.13	66 KV FATEHPUR BERI	SFTPR106	GATE NO.2C RADHA SWAMI	Residential	AMR	1.13	0.25	0.84	3.53%	100%
2.52	66 KV FATEHPUR BERI	SFTPR107	SHANTI KHANNA	Mixed	AMR	2.52	0.00	2.44	2.91%	100%
2.30	66 KV FATEHPUR BERI	SFTPR108	FATEHPUR BERI COMPLAINT CENTER	Residential	AMR	2.30	0.00	2.23	3.10%	100%
2.53	66 KV FATEHPUR BERI	SFTPR109	ASOLA VILLAGE	Mixed	AMR	2.53	0.65	1.81	2.61%	100%
2.97	66 KV FATEHPUR BERI	SFTPR110	HARSWAROOP COLONY	Residential	AMR	2.97	0.00	2.89	2.91%	100%
5.18	66 KV FATEHPUR BERI	SFTPR111	BHATI MINES	Residential	AMR	5.18	1.31	3.71	3.09%	100%
2.18	66 KV FATEHPUR BERI	SFTPR112	RUMALO DEVI	Residential	AMR	2.18	0.52	1.60	2.61%	100%
3.26	66 KV FATEHPUR BERI	SFTPR113	RSSB S/STN-1	Mixed	AMR	3.26	0.00	3.14	3.87%	100%
2.40	66 KV FATEHPUR BERI	SFTPR114	ASOLA BANDH	Residential	AMR	2.40	0.58	1.75	3.17%	100%
2.01	66 KV FATEHPUR BERI	SFTPR115	RSSB S/STN-2	Public Utilities	AMR	2.01	0.00	1.96	2.87%	100%
2.54	66 KV FATEHPUR BERI	SFTPR116	CHADDA MURGI	Residential	AMR	2.54	0.00	2.45	3.36%	100%
0.03	66 KV FATEHPUR BERI	SFTPR121	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	2.39%	100%
2.74	66 KV FATEHPUR BERI	SFTPR122	SHANI DHAM	Residential	AMR	2.74	0.63	2.03	2.65%	100%
2.63	66 KV FATEHPUR BERI	SFTPR621	JADAIPUR POLICE STATION	Mixed	AMR	2.63	0.68	1.89	2.29%	100%
2.07	66 KV FATEHPUR BERI	SFTPR622	NICF GHITORNI VIA SHIV MANDIR	Mixed	AMR	2.07	0.00	2.00	3.21%	100%
1.14	66 KV IGNOU	SIGNO101	N BLOCK SAINIK FARM	Residential	AMR	1.14	0.00	1.09	3.69%	100%
1.74	66 KV IGNOU	SIGNO105	S/S NO.9 IGNOU CAMPUS	Residential	AMR	1.74	0.00	1.67	3.83%	100%
2.26	66 KV IGNOU	SIGNO106	NEB SARAI VIDRA PM S/S	Mixed	AMR	2.26	0.00	2.19	2.70%	100%
1.65	66 KV IGNOU	SIGNO107	Main Road 192 Sainik Farm	Residential	AMR	1.65	0.00	1.58	4.20%	100%
2.70	66 KV IGNOU	SIGNO108	NEB SARAI ETXN.	Mixed	AMR	2.70	0.00	2.61	3.22%	100%
3.11	66 KV IGNOU	SIGNO109	O/G FEEDER NO-1 IGNOU KIOSK	Mixed	AMR	3.11	0.00	3.01	3.12%	100%
3.58	66 KV IGNOU	SIGNO110	ANUPAM GARDEN	Mixed	AMR	3.58	0.00	3.51	1.96%	100%
1.01	66 KV IGNOU	SIGNO111	S/STN-3 IGNOU CAMPUS FRD-2	Commercial	AMR	1.01	0.24	0.75	2.37%	100%
0.02	66 KV IGNOU	SIGNO112	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.01	0.01	2.23%	100%
2.86	66 KV IGNOU	SIGNO113	MADAN GARHI VILLAGE	Residential	AMR	2.86	0.00	2.79	2.52%	100%
3.71	66 KV MALVIYA NAGAR	SMALV101	11 KV S/STN 11 SEC-4 PUSP VIHAR	Mixed	AMR	3.71	0.00	3.63	2.20%	100%
1.33	66 KV MALVIYA NAGAR	SMALV103	11 KV O/G S/S - 4 SEC-3 PUSP VIHAR	Mixed	AMR	1.33	0.32	0.95	4.64%	100%
0.56	66 KV MALVIYA NAGAR	SMALV104	DMRC	Public Utilities	AMR	0.56	0.00	0.54	3.18%	100%
3.74	66 KV MALVIYA NAGAR	SMALV105	11 KV O/G J-BLOCK SAKET	Mixed	AMR	3.74	0.93	2.69	3.22%	100%
2.61	66 KV MALVIYA NAGAR	SMALV106	11 KV O/G IGNOU VIA 4 POLE	Mixed	AMR	2.61	0.64	1.91	2.44%	100%
1.82	66 KV MALVIYA NAGAR	SMALV107	11 KV O/G S/S - 1 SEC-1 PUSP VIHAR-	Mixed	AMR	1.82	0.43	1.32	3.79%	100%
1.41	66 KV MALVIYA NAGAR	SMALV108	O/G ANUPAM APPARTMENTS	Mixed	AMR	1.41	0.37	0.99	3.36%	100%
2.37	66 KV MALVIYA NAGAR	SMALV117	11 KV O/G MIG DDA FLAT SAKET	Mixed	AMR	2.37	0.00	2.31	2.62%	100%
0.02	66 KV MALVIYA NAGAR	SMALV123	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.01	0.01	2.26%	100%
2.92	66 KV MALVIYA NAGAR	SMALV126	11 KV O/G SPORTS COMPLEX	Mixed	AMR	2.92	0.00	2.82	3.21%	100%
0.37	66 KV MALVIYA NAGAR	SMALV128	NBCC PLAZA	Commercial	AMR	0.37	0.06	0.29	3.86%	100%
2.43	66 KV MALVIYA NAGAR	SMALV131	J-57 PARYARVARAN VIA ANUPAM APPARTMENT	Mixed	AMR	2.43	0.00	2.37	2.58%	100%
1.01	66 KV MALVIYA NAGAR	SMALV132	11 KV O/G J-12 SAKET	Mixed	AMR	1.01	0.00	0.97	3.46%	100%
2.31	66 KV MALVIYA NAGAR	SMALV133	LADO SARAI PREM SINGH	Mixed	AMR	2.31	0.00	2.24	3.06%	100%
4.53	66 KV MALVIYA NAGAR	SMALV134	BANERJEE HOSPITAL SAIDLULJAB	Mixed	AMR	4.53	1.12	3.24	3.77%	100%
2.20	66 KV MALVIYA NAGAR	SMALV135	E-2 SAKET	Mixed	AMR	2.20	0.00	2.14	2.57%	100%
2.08	33 KV MASJID MOTH GRID	SMMOT101	11 KV O/G SFS SHEIKH SARAI PH-1	Mixed	AMR	2.08	0.00	2.02	3.27%	100%
2.64	33 KV MASJID MOTH GRID	SMMOT103	11 KV O/G RPS SHEIKH SARAI PH - 1	Mixed	AMR	2.64	0.00	2.54	3.80%	100%
2.21	33 KV MASJID MOTH GRID	SMMOT109	11 KV O/G CHIRAG DELHI	Mixed	AMR	2.21	0.00	2.15	2.65%	100%
2.03	33 KV MASJID MOTH GRID	SMMOT119	BALMIKI MANDIR	Mixed	AMR	2.03	0.00	1.97	3.29%	100%
0.90	33 KV MASJID MOTH GRID	SMMOT122	11 KV SFS B1 SHIEKH SARAI PH-1	Mixed	AMR	0.90	0.25	0.62	3.24%	100%
1.15	33 KV PUSP VIHAR	SPUSP101	11 KV SIDE-31 SHEKHA SARAI	Commercial	AMR	1.15	0.00	1.11	3.46%	100%
1.04	33 KV PUSP VIHAR	SPUSP102	11 KV MAX DEVI HOSPITAL	Commercial	AMR	1.04	0.25	0.75	3.90%	100%
0.89	33 KV PUSP VIHAR	SPUSP103	11 KV S/STN-6 SHEKHA SARAI PH-2	Mixed	AMR	0.89	0.00	0.86	3.57%	100%
0.47	33 KV PUSP VIHAR	SPUSP104	11 KV SHANTI NIKETAN BLDG	Commercial	AMR	0.47	0.45	0.00	3.76%	100%

777	SAKET
778	SAKET
779	SAKET
780	SAKET
781	SAKET
782	SAKET
783	SAKET
784	SAKET
785	SAKET
786	SAKET
787	SAKET
788	SAKET
789	SAKET
790	SAKET
791	SAKET
792	SAKET
793	SAKET
794	SAKET
795	SAKET
796	SAKET
797	SAKET
798	SAKET
799	SAKET
800	SAKET
801	SAKET
802	SAKET
803	SAKET
804	SAKET
805	SAKET
806	SAKET
807	SAKET
808	SAKET
809	SAKET
810	SAKET
811	SAKET
812	SAKET
813	SAKET
814	SAKET
815	SAKET
816	SAKET
817	SAKET
818	SAKET
819	SAKET
820	VASANT KUNJ
821	VASANT KUNJ
822	VASANT KUNJ
823	VASANT KUNJ

272.08

3.40	33 KV PUSP VIHAR	SPUSP107	11KV KHIRAKHI BANDHA	Mixed	AMR	3.40	0.85	2.44	3.24%	100%
2.82	33 KV PUSP VIHAR	SPUSP108	11 KV O/G CHIRAG DELHI KHATTA	Mixed	AMR	2.82	0.00	2.75	2.63%	100%
0.43	33 KV PUSP VIHAR	SPUSP110	11 KV DLF RETAILER DEVELOPER FDR-1	Commercial	AMR	0.43	0.00	0.42	2.60%	100%
0.62	33 KV PUSP VIHAR	SPUSP111	11 KV DLF RETAILER DEVELOPER FDR-2	Commercial	AMR	0.62	0.00	0.59	4.70%	100%
0.01	33 KV PUSP VIHAR	SPUSP112	11 KV LOCAL TRANSFORMER	Local Grid	AMR	0.01	0.00	0.01	2.14%	100%
0.10	33 KV PUSP VIHAR	SPUSP113	11 KV O/G DELHI POLICE POST SAKET	Commercial	AMR	0.10	0.03	0.07	1.97%	100%
2.00	33 KV D C SAKET	SSAKT102	WELCOME HOTEL NO.1+FARGO SAKET	Commercial	AMR	2.00	1.94	0.00	3.28%	100%
1.80	33 KV D C SAKET	SSAKT103	P./VIHAR SECT-1 S/S NO-5+MAX HOSPITAL NO.-1	Mixed	AMR	1.80	0.45	1.27	3.91%	100%
3.17	33 KV D C SAKET	SSAKT104	MODI HOSPITAL	Mixed	AMR	3.17	0.78	2.31	2.68%	100%
2.35	33 KV D C SAKET	SSAKT106	C.C.ANUPAM	Mixed	AMR	2.35	0.60	1.69	2.43%	100%
2.33	33 KV D C SAKET	SSAKT108	PSRI HOSPITAL+IFFCO DISTT CENTER	Mixed	AMR	2.33	0.56	1.70	3.15%	100%
4.82	33 KV D C SAKET	SSAKT109	HAUZ RANI(JAHANPANAH NO-1)+MGF MALL D.C SAKET	Mixed	AMR	4.82	1.20	3.44	3.98%	100%
2.45	33 KV D C SAKET	SSAKT111	WELCOME HOTEL NO-II (DDA KHIRKI)	Mixed	AMR	2.45	0.00	2.38	3.22%	100%
2.18	33 KV D C SAKET	SSAKT112	Max Devika Devi Hospital	Commercial	AMR	2.18	0.00	2.10	3.42%	100%
1.61	33 KV D C SAKET	SSAKT114	DISTRICT COURT COMPLEX	Commercial	AMR	1.61	0.38	1.18	3.54%	100%
0.01	33 KV D C SAKET	SSAKT118	LOCAL TR.	Local Grid	AMR	0.01	0.00	0.01	2.18%	100%
2.30	33 KV D C SAKET	SSAKT119	OG TO DMRC ENCL(ANDHRA+BLIND SCH+PUSP NO-12)	Public Utilities	AMR	2.30	0.56	1.67	2.55%	100%
0.00	33 KV D C SAKET	SSAKT120	RES. S/S-1 COURT COMPLEX	Mixed	AMR	0.00	0.00	0.00	2.33%	100%
0.54	33 KV D C SAKET	SSAKT121	ADCO STN 2 COURT COMPLEX	Commercial	AMR	0.54	0.00	0.53	1.60%	100%
1.95	33 KV D C SAKET	SSAKT122	SPORT COMPLEX SAKET(DISTRICT COURT FDR-2)	Mixed	AMR	1.95	0.48	1.40	3.47%	100%
4.52	33 KV D C SAKET	SSAKT125	DLF A-4 SAKET	Commercial	AMR	4.52	4.39	0.00	2.86%	100%
1.65	33 KV D C SAKET	SSAKT126	MAX SUPER SPACELITY FDR-2	Commercial	AMR	1.65	0.48	1.11	3.79%	100%
3.44	33 KV SHIVALIK	SSHIV102	SARVEPRIYA APPARTMENT	Residential	AMR	3.44	0.00	3.35	2.50%	100%
2.41	33 KV SHIVALIK	SSHIV103	11 KV O/G TO C BLK SHIVALIK	Mixed	AMR	2.41	0.00	2.36	2.40%	100%
2.23	33 KV SHIVALIK	SSHIV104	11 KV O/G TO BHAVISHIYA NIDHI ENCL.	Mixed	AMR	2.23	0.00	2.16	3.25%	100%
1.82	33 KV SHIVALIK	SSHIV105	11 KV O/G TO 80 BLK MALVIYA NGR	Mixed	AMR	1.82	0.00	1.76	3.42%	100%
0.07	33 KV SHIVALIK	SSHIV107	LOCAL TRANSFORMER	Local Grid	AMR	0.07	0.00	0.07	2.55%	100%
1.94	33 KV SHIVALIK	SSHIV109	L-BLOCK MALVIYA NAGAR	Mixed	AMR	1.94	0.00	1.88	3.02%	100%
2.70	33 KV SHIVALIK	SSHIV112	11 KV O/G R.P.S. SHIEKH SARAI PH-1	Mixed	AMR	2.70	0.68	1.93	3.14%	100%
3.41	33 KV SHIVALIK	SSHIV113	11 KV TO COMP. CENTER MALVIYA NAGAR	Mixed	AMR	3.41	0.00	3.27	3.95%	100%
4.24	33 KV SHIVALIK	SSHIV120	F-BLOCK MALVIYA NAGAR	Mixed	AMR	4.24	0.00	4.13	2.54%	100%
1.85	33 KV SHIVALIK	SSHIV122	F-BLOCK KIOSK S/STN MALVIYA NAGAR	Mixed	AMR	1.85	0.00	1.78	3.75%	100%
2.47	33 KV SHIVALIK	SSHIV124	O/G TO NIL BLK MALVIYA NAGAR	Mixed	AMR	2.47	0.00	2.40	2.85%	100%
2.04	33 KV SHIVALIK	SSHIV125	O/G TO ORTHONOVA HOSPITAL	Commercial	AMR	2.04	0.51	1.47	3.30%	100%
0.68	33 KV SHIVALIK	SSHIV126	11 KV DIB MALVIYA NAGAR	Mixed	AMR	0.68	0.68	0.00	0.22%	100%
2.11	33 KV SHIVALIK	SSHIV127	P. BLOCK MALVIYA NAGAR	Mixed	AMR	2.11	0.00	2.04	3.50%	100%
2.69	33 KV SHIVALIK	SSHIV128	11 KV O/G SERVPRIYA VIHAR	Residential	AMR	2.69	0.66	1.95	3.00%	100%
0.63	66 KV SANGAM VIHAR	SSNGM142	W-5B SAINIK FARM	Residential	AMR	0.63	0.00	0.61	3.13%	100%
1.59	66 KV SANGAM VIHAR	SSNGM144	W-2 SAINIK FARM	Residential	AMR	1.59	0.00	1.53	3.49%	100%
0.83	220 KV MEHRAULI GRID	TDTMG101	VSNL GATE	Mixed	AMR	0.83	0.00	0.81	2.65%	100%
1.22	220 KV MEHRAULI GRID	TDTMG102	MEERA CHATTARPUR VILLAGE	Mixed	AMR	1.22	0.00	1.19	2.67%	100%
1.19	220 KV MEHRAULI GRID	TDTMG105	RAJPUR EXTENSION	Mixed	AMR	1.19	0.00	1.15	2.66%	100%
0.57	220 KV MEHRAULI GRID	TDTMG106	CHATTARPUR ENCLAVE BARRIER	Mixed	AMR	0.57	0.00	0.56	2.63%	100%
0.00	220 KV DAIL	100007026	66KV T-3 Dail	Commercial	AMR	0.00	0.00	0.00	0.00%	100%
1.87	66 KV VASANT KUNJ B	150024654	33 KV O/G LIVER HOSPITAL	Commercial	AMR	1.87	1.86	0.00	0.37%	100%
6.20	220 KV DAIL	150836007	66KV DMRC Metro	Commercial	AMR	6.20	6.18	0.00	0.37%	100%
6.72	66 KV VASANT KUNJ B/66 KV JNU/33	151187493	AMBIANCE MALL	Commercial	AMR	6.72	6.69	0.00	0.37%	100%

824	VASANT KUNJ
825	VASANT KUNJ
826	VASANT KUNJ
827	VASANT KUNJ
828	VASANT KUNJ
829	VASANT KUNJ
830	VASANT KUNJ
831	VASANT KUNJ
832	VASANT KUNJ
833	VASANT KUNJ
834	VASANT KUNJ
835	VASANT KUNJ
836	VASANT KUNJ
837	VASANT KUNJ
838	VASANT KUNJ
839	VASANT KUNJ
840	VASANT KUNJ
841	VASANT KUNJ
842	VASANT KUNJ
843	VASANT KUNJ
844	VASANT KUNJ
845	VASANT KUNJ
846	VASANT KUNJ
847	VASANT KUNJ
848	VASANT KUNJ
849	VASANT KUNJ
850	VASANT KUNJ
851	VASANT KUNJ
852	VASANT KUNJ
853	VASANT KUNJ
854	VASANT KUNJ
855	VASANT KUNJ
856	VASANT KUNJ
857	VASANT KUNJ
858	VASANT KUNJ
859	VASANT KUNJ
860	VASANT KUNJ
861	VASANT KUNJ
862	VASANT KUNJ
863	VASANT KUNJ
864	VASANT KUNJ
865	VASANT KUNJ
866	VASANT KUNJ
867	VASANT KUNJ
868	VASANT KUNJ
869	VASANT KUNJ
870	VASANT KUNJ
871	VASANT KUNJ
872	VASANT KUNJ
873	VASANT KUNJ
874	VASANT KUNJ
875	VASANT KUNJ
876	VASANT KUNJ
877	VASANT KUNJ

0.71	66 KV VASANT KUNJ B	152360687	33 KV O/G TO NAT GRID	Mixed	AMR	0.71	0.70	0.00	0.37%		100%
1.38	66 KV Bijwasan	SBWSN624	IOC 1&2	Commercial	AMR	1.38	1.37	0.00	0.37%		100%
0.00	66 KV IAAI PALAM	SPLAP610	EXE ENG.(E) AIRPORT MAIN (KCC)	Commercial	AMR	0.00	0.00	0.00	0.00%		100%
2.52	33 KV ANDHERIA BAG	SABAG104	MANGLAPURI	Mixed	AMR	2.52	0.75	1.70	2.99%		100%
3.00	33 KV ANDHERIA BAG	SABAG106	TAMPO STAND	Mixed	AMR	3.00	0.00	2.91	2.99%		100%
2.16	33 KV ANDHERIA BAG	SABAG107	VASANT KUNJ SEC. - A	Mixed	AMR	2.16	0.66	1.44	2.71%		100%
2.84	33 KV ANDHERIA BAG	SABAG110	VASANT KUNJ SEC. - D	Mixed	AMR	2.84	0.00	2.77	2.38%		100%
0.16	33 KV ANDHERIA BAG	SABAG112	LOCAL TRANSFORMOR	Local Grid	AMR	0.16	0.04	0.11	0.56%		100%
4.49	33 KV ANDHERIA BAG	SABAG114	LEVER INSTITUTE HOSPITAL	Mixed	AMR	4.49	0.00	4.38	2.48%		100%
2.30	33 KV ANDHERIA BAG	SABAG115	APEX HOME PVT LTD	Commercial	AMR	2.30	0.70	1.55	2.12%		100%
3.23	33 KV ANDHERIA BAG	SABAG118	PICNIC HUT VIA TEMPOSTAND	Mixed	AMR	3.23	0.00	3.18	1.51%		100%
1.86	33 KV ANDHERIA BAG	SABAG119	SALOON APPARTMENT	Mixed	AMR	1.86	0.00	1.80	3.09%		100%
4.61	33 KV ANDHERIA BAG	SABAG120	GHITONI	Mixed	AMR	4.61	1.29	3.16	3.35%		100%
4.65	33 KV ADHCHINI	SADCN111	T.B. HOSPITAL	Mixed	AMR	4.65	1.31	3.22	2.62%		100%
2.29	33 KV ADHCHINI	SADCN112	PTS COLONY	Mixed	AMR	2.29	0.00	2.24	2.49%		100%
3.25	66 KV AEROCITY	SAERO104	HYACINTH HOTEL+ LEMON TREES + RED FOX	Commercial	AMR	3.25	1.10	2.07	2.11%		100%
4.13	66 KV AEROCITY	SAERO105	11 KV ASSEST - 09 IBIS + 05	Commercial	AMR	4.13	4.13	0.00	0.04%		100%
3.43	66 KV AEROCITY	SAERO106	NOVOTEL + PULL MAN HOTEL + CADDIE	Commercial	AMR	3.43	3.40	0.00	0.82%		100%
2.64	66 KV AEROCITY	SAERO107	JUNIPER HOTEL+ GRAND HYATT	Commercial	AMR	2.64	2.64	0.00	0.03%		100%
0.35	66 KV AEROCITY	SAERO108	GMR- 1	Local Grid	AMR	0.35	0.09	0.26	0.55%		100%
2.98	66 KV AEROCITY	SAERO111	ARIA+ JWMARRIOT	Commercial	AMR	2.98	2.97	0.00	0.17%		100%
0.24	66 KV AEROCITY	SAERO112	GMR- 2	Local Grid	AMR	0.24	0.00	0.24	0.97%		100%
1.34	66 KV AEROCITY	SAERO113	WAB HOSPITALITY+ HOLIDAY INN	Commercial	AMR	1.34	1.34	0.00	0.04%		100%
1.92	66 KV AEROCITY	SAERO114	BIRD GROUP+ DUSIT	Commercial	AMR	1.92	0.60	1.25	3.68%		100%
0.35	66 KV AEROCITY	SAERO115	11 KV ASSEST - 13 CKT - 2	Mixed	AMR	0.35	0.00	0.35	1.98%		100%
2.13	66 KV Bijwasan	SBWSN102	KAPASHERA U/G	Mixed	AMR	2.13	0.00	2.08	2.42%		100%
2.29	66 KV Bijwasan	SBWSN103	11KV O/G VILLAGE SHAHABAD MOHAMMAD PUR	Mixed	AMR	2.29	0.00	2.22	3.13%		100%
2.28	66 KV Bijwasan	SBWSN105	11 KV O/G NANGAL DAIRY NO.1 INTERCO	Mixed	AMR	2.28	0.70	1.52	2.58%		100%
3.06	66 KV Bijwasan	SBWSN107	11 KV O/G BIJWASAN	Mixed	AMR	3.06	0.91	2.08	2.18%		100%
1.88	66 KV Bijwasan	SBWSN108	11 KV O/G SPG	Mixed	AMR	1.88	0.00	1.81	3.38%		100%
4.05	66 KV Bijwasan	SBWSN110	HINDUSTAN PETROLIUM	Mixed	AMR	4.05	1.17	2.82	1.65%		100%
0.03	66 KV Bijwasan	SBWSN113	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	0.43%		100%
4.19	66 KV Bijwasan	SBWSN115	NANGAL DAIRY INTERCONNECTOR NO-2	Mixed	AMR	4.19	1.19	2.89	2.50%		100%
4.02	66 KV Bijwasan	SBWSN116	KAPASERA O/H	Mixed	AMR	4.02	1.16	2.79	1.73%		100%
4.50	66 KV Bijwasan	SBWSN119	NAVAL KAPASHERA	Mixed	AMR	4.50	1.27	3.13	2.41%		100%
3.09	66 KV Bijwasan	SBWSN120	HOLI CHOWNK, BIJWASAN	Mixed	AMR	3.09	0.00	3.00	2.66%		100%
4.01	66 KV Bijwasan	SBWSN123	AIR FORCE RAJOKARI	Mixed	AMR	4.01	1.15	2.77	2.35%		100%
2.87	66 KV Bijwasan	SBWSN125	11 KV O/G JAI SINGH	Mixed	AMR	2.87	0.00	2.80	2.68%		100%
3.28	66 KV Bijwasan	SBWSN127	SAMALKHA VILLAGE	Residential	AMR	3.28	0.95	2.24	2.86%		100%
3.79	66 KV Bijwasan	SBWSN128	BLUE DART KAPASHERA	Mixed	AMR	3.79	0.00	3.69	2.63%		100%
3.86	66 KV Bijwasan	SBWSN129	SHALAPUR KHEDA VILL.	Mixed	AMR	3.86	0.00	3.74	2.93%		100%
2.76	66 KV Bijwasan	SBWSN130	GREEN RAJOKARI VIA TANEJA	Mixed	AMR	2.76	0.81	1.87	2.88%		100%
2.22	66 KV C-DOT GRID	SCDOT104	O/G NICF GHITORINE	Mixed	AMR	2.22	0.71	1.45	2.78%		100%
4.32	66 KV C-DOT GRID	SCDOT107	GHITORNI (NTR0 NO.-1)	Mixed	AMR	4.32	1.22	2.95	3.63%		100%
3.58	66 KV C-DOT GRID	SCDOT123	11kv Tempo Stand, Mehrauli	Mixed	AMR	3.58	0.00	3.50	2.34%		100%
0.02	220 KV MEHRAULI GRID	SDTMG107	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.29%		100%
1.29	66 KV IAAI PALAM	SPLAP113	A.B HOTEL (RADDISSON)	Commercial	AMR	1.29	0.00	1.25	2.93%		100%
0.36	66 KV IAAI PALAM	SPLAP114	A.M.P.C POST OFFICE	Commercial	AMR	0.36	0.10	0.26	0.17%		100%
4.47	66 KV IAAI PALAM	SPLAP115	E.I.C OBEROI CATERING	Commercial	AMR	4.47	1.30	3.09	1.92%		100%
0.03	66 KV IAAI PALAM	SPLAP116	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.01	0.02	0.36%		100%
1.99	66 KV IAAI PALAM	SPLAP117	11KV O/G MEHRAM NAGAR	Mixed	AMR	1.99	0.63	1.29	3.69%		100%
3.33	66 KV IAAI PALAM	SPLAP118	11KV RAJOKARI	Mixed	AMR	3.33	0.96	2.25	3.67%		100%
3.19	66 KV IAAI PALAM	SPLAP119	11KV WESTEN GREEN	Mixed	AMR	3.19	0.93	2.17	2.74%		100%
4.39	66 KV IAAI PALAM	SPLAP120	GMR SSTN.	Mixed	AMR	4.39	0.00	4.28	2.52%		100%

878	VASANT KUNJ
879	VASANT KUNJ
880	VASANT KUNJ
881	VASANT KUNJ
882	VASANT KUNJ
883	VASANT KUNJ
884	VASANT KUNJ
885	VASANT KUNJ
886	VASANT KUNJ
887	VASANT KUNJ
888	VASANT KUNJ
889	VASANT KUNJ
890	VASANT KUNJ
891	VASANT KUNJ
892	VASANT KUNJ
893	VASANT KUNJ
894	VASANT KUNJ
895	VASANT KUNJ
896	VASANT KUNJ
897	VASANT KUNJ
898	VASANT KUNJ
899	VASANT KUNJ
900	VASANT KUNJ
901	VASANT KUNJ
902	VASANT KUNJ
903	VASANT KUNJ
904	VASANT KUNJ
905	VASANT KUNJ
906	VASANT KUNJ
907	VASANT KUNJ
908	VASANT KUNJ
909	VASANT KUNJ
910	VASANT KUNJ
911	VASANT KUNJ
912	VASANT KUNJ
913	VASANT KUNJ
914	VASANT KUNJ
915	VASANT KUNJ
916	VASANT KUNJ
917	VASANT KUNJ
918	VASANT KUNJ
919	VASANT KUNJ
920	VASANT KUNJ
921	VASANT KUNJ

3.94	66 KV IAAI PALAM	SPLAP121	GOLDEN GATE, WESTEND GREENS	Mixed	AMR	3.94	0.00	3.86	2.19%		100%
1.67	66 KV IAAI PALAM	SPLAP122	AVIJIT MAHIPALPUR	Mixed	AMR	1.67	0.52	1.11	2.26%		100%
3.24	66 KV VASANT KUNJ B	SVKGB101	11 KV O/G S/S A-2 VASANT KUNJ	Mixed	AMR	3.24	0.00	3.15	2.74%		100%
2.09	66 KV VASANT KUNJ B	SVKGB104	11 KV O/G SECTOR B-4 VASANT K.	Mixed	AMR	2.09	0.00	2.02	3.19%		100%
4.00	66 KV VASANT KUNJ B	SVKGB105	11 KV O/G SEW AGE TREATMENT PLANT	Mixed	AMR	4.00	1.15	2.79	1.28%		100%
2.21	66 KV VASANT KUNJ B	SVKGB106	11 KV O/G WARD NO, 2 MEHRAULI	Mixed	AMR	2.21	0.00	2.14	3.22%		100%
3.59	66 KV VASANT KUNJ B	SVKGB107	LEVER HOSPITAL,D1 VASANT KUNJ	Mixed	AMR	3.59	0.00	3.49	3.03%		100%
1.99	66 KV VASANT KUNJ B	SVKGB108	11 KV O/G S/STN-1 SEC- B	Mixed	AMR	1.99	0.00	1.93	2.71%		100%
0.04	66 KV VASANT KUNJ B	SVKGB110	11 KV O/G LOCAL TRANSFORMER	Local Grid	AMR	0.04	0.00	0.03	0.44%		100%
2.65	66 KV VASANT KUNJ B	SVKGB115	STN NO-1, B BLK 5 & 6 VASANT KUNJ	Mixed	AMR	2.65	0.79	1.81	2.05%		100%
3.38	66 KV VASANT KUNJ B	SVKGB116	FORTIS HOSPITAL - 2 via RMU INSIDE GRID	Mixed	AMR	3.38	0.99	2.32	2.07%		100%
3.20	66 KV VASANT KUNJ B	SVKGB121	11 KV O/G MOTHER DAIRY	Mixed	AMR	3.20	0.00	3.13	2.21%		100%
0.88	66 KV VASANT KUNJ B	SVKGB122	FORTIS HOSPITAL - 1	Commercial	AMR	0.88	0.00	0.85	3.24%		100%
0.71	66 KV VASANT KUNJ B	SVKGB628	160 HIG DDA FLATS B-2 VKJ	Mixed	AMR	0.71	0.00	0.70	1.75%		100%
0.98	66 KV VASANT KUNJ INSTITUTIONAL	SVKIA101	11 KV ONGC RMU	Commercial	AMR	0.98	0.97	0.00	0.64%		100%
0.02	66 KV VASANT KUNJ INSTITUTIONAL	SVKIA102	11 KV LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.23%		100%
0.76	66 KV VASANT KUNJ INSTITUTIONAL	SVKIA107	O/G TO BPR&D AND NCRB MAHIPAL PUR	Commercial	AMR	0.76	0.76	0.00	0.02%		100%
0.93	66 KV VASANT KUNJ INSTITUTIONAL	SVKIA108	S/STN-6, DDA FLATS SULTANGARHI	Residential	AMR	0.93	0.00	0.90	2.35%		100%
0.88	66 KV VASANT KUNJ INSTITUTIONAL	SVKIA109	DJB MAHIPAL PUR	Residential	AMR	0.88	0.33	0.52	4.26%		100%
1.67	66 KV VASANT KUNJ INSTITUTIONAL	SVKIA110	DLF EMPERIO RMU NO.2	Commercial	AMR	1.67	1.66	0.00	0.43%		100%
0.51	66 KV VASANT KUNJ INSTITUTIONAL	SVKIA111	DIRECTOR INDIAN AVIATION NO.1	Commercial	AMR	0.51	0.00	0.50	1.34%		100%
0.04	66 KV VASANT KUNJ INSTITUTIONAL	SVKIA114	DIRECTOR INDIAN AVIATION NO.2	Commercial	AMR	0.04	0.01	0.03	0.37%		100%
4.17	66 KV VASANT KUNJ INSTITUTIONAL	SVKIA115	O/G TO CISF CAMP MAHIPAL PUR	Commercial	AMR	4.17	1.18	2.86	3.04%		100%
4.16	66 KV VASANT KUNJ INSTITUTIONAL	SVKIA116	S/STN-3, DDA FLATS SULTANGARHI	Residential	AMR	4.16	1.19	2.85	2.86%		100%
1.17	66 KV VASANT KUNJ INSTITUTIONAL	SVKIA117	DEFENCE ENCLAVE	Residential	AMR	1.17	0.00	1.15	1.87%		100%
0.02	66 KV VASANT KUNJ INSTITUTIONAL	SVKIA118	VASANT ENCLAVE VIA RMU INT. AREA (MAIN)	Residential	AMR	0.02	0.00	0.02	0.27%		100%
2.72	66 KV Vasant Kunj C	SVKJC101	11 KV O/G S/S 12 SEC B10 VK	Mixed	AMR	2.72	0.82	1.84	2.18%		100%
1.83	66 KV Vasant Kunj C	SVKJC102	11 KV O/G S/S 7 SEC B-7 VK	Mixed	AMR	1.83	0.58	1.22	1.43%		100%
0.98	66 KV Vasant Kunj C	SVKJC103	11 KV O/G S/S 1 SEC C -6 & 7 VK	Mixed	AMR	0.98	0.00	0.96	1.94%		100%
1.52	66 KV Vasant Kunj C	SVKJC104	11 kv INTR CNNTR C&D BLK & Institutional Area	Mixed	AMR	1.52	0.51	0.95	3.81%		100%
1.50	66 KV Vasant Kunj C	SVKJC105	11 KV O/G S/S 6 SEC C-3 VK	Mixed	AMR	1.50	0.00	1.47	2.20%		100%
1.66	66 KV Vasant Kunj C	SVKJC106	11 KV O/G S/S 5 SEC C-2 VK	Mixed	AMR	1.66	0.55	1.08	1.10%		100%
3.97	66 KV Vasant Kunj C	SVKJC107	11 KV O/G S/S 5 SEC B -11	Mixed	AMR	3.97	1.15	2.77	1.31%		100%
1.00	66 KV Vasant Kunj C	SVKJC108	PUSHPANALI CNG PUMP & ISIDV	Mixed	AMR	1.00	0.38	0.59	3.25%		100%
0.84	66 KV Vasant Kunj C	SVKJC109	11 KV O/G HOTEL GRAND HAYATT	Commercial	AMR	0.84	0.83	0.00	0.36%		100%
0.88	66 KV Vasant Kunj C	SVKJC110	11 KV O/G S/S B - 8 VK	Mixed	AMR	0.88	0.34	0.52	1.74%		100%
0.97	66 KV Vasant Kunj C	SVKJC111	11 KV O/G S/S- 2 SEC-C -4 VK	Mixed	AMR	0.97	0.37	0.58	2.23%		100%
0.02	66 KV Vasant Kunj C	SVKJC115	11 KV O/G LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.28%		100%
3.34	66 KV Vasant Kunj C	SVKJC121	11 KV O/G DLF PROMENADE MALL	Commercial	AMR	3.34	3.32	0.00	0.43%		100%
2.18	66 KV Vasant Kunj D	SVKJD101	11 KV O/G NANGAL DAIRY NO. 1	Mixed	AMR	2.18	0.00	2.11	3.43%		100%
0.28	66 KV Vasant Kunj D	SVKJD102	11kv O/G S/stn-31904 Mega Housing VKJ	Mixed	AMR	0.28	0.00	0.27	2.99%		100%
0.90	66 KV Vasant Kunj D	SVKJD103	S/STN NO-1 D-6 V.KUNJ	Mixed	AMR	0.90	0.31	0.57	1.62%		100%
0.63	66 KV Vasant Kunj D	SVKJD104	11 KV O/G S/S 1 D-7 & 8 VKJ	Mixed	AMR	0.63	0.00	0.61	2.59%		100%
0.46	66 KV Vasant Kunj D	SVKJD105	11 KV O/G S/STN NO-III D-6 V.KUNJ	Mixed	AMR	0.46	0.00	0.45	2.24%		100%

922	VASANT KUNJ		
923	VASANT KUNJ		
924	VASANT KUNJ		
925	VASANT KUNJ		
926	VASANT KUNJ		
927	VASANT KUNJ		
928	VASANT KUNJ		
929	VASANT KUNJ		
930	VASANT KUNJ		
931	VASANT KUNJ		
932	VASANT KUNJ		
933	VASANT KUNJ		
934	VASANT KUNJ		
935	VASANT KUNJ		
936	VASANT KUNJ		
937	VASANT KUNJ		
938	VASANT KUNJ		
939	VASANT KUNJ		
940	VASANT KUNJ		
941	VASANT KUNJ		
942	VASANT KUNJ		
943	VASANT KUNJ		
944	VASANT KUNJ		
945	VASANT KUNJ		
946	VASANT KUNJ		
947	VASANT KUNJ		
948	VASANT KUNJ		
949	VASANT KUNJ		
950	VASANT KUNJ		
951	VASANT KUNJ		
952	VASANT KUNJ		
953	DWARKA	677.02	215.57
954	DWARKA		
955	DWARKA		
956	DWARKA		
957	DWARKA		
958	DWARKA		
959	DWARKA		
960	DWARKA		
961	DWARKA		
962	DWARKA		
963	DWARKA		
964	DWARKA		
965	DWARKA		
966	DWARKA		
967	DWARKA		
968	DWARKA		
969	DWARKA		
970	DWARKA		
971	DWARKA		

0.03	66 KV Vasant Kunj D	SVKJD108	LOCAL TRANSFORMER (400 KVA)	Mixed	AMR	0.03	0.01	0.02	0.37%	100%
1.58	66 KV Vasant Kunj D	SVKJD111	11 KV O/G NANGAL DAIRY NO. 2	Mixed	AMR	1.58	0.00	1.52	4.06%	100%
3.97	66 KV Vasant Kunj D	SVKJD112	11 KV O/G CANTAUR HOTEL	Mixed	AMR	3.97	0.00	3.86	2.88%	100%
2.30	66 KV Vasant Kunj D	SVKJD113	11 KV O/G S/S-II VK - D 4	Mixed	AMR	2.30	0.00	2.25	2.15%	100%
0.53	66 KV Vasant Kunj D	SVKJD114	11 KV O/G S/STN NO-3 D-7 & 8	Mixed	AMR	0.53	0.00	0.52	2.08%	100%
1.71	66 KV Vasant Kunj D	SVKJD115	11KV O/G Sun City Mall B-5 VK+Rangpuri-1	Commercial	AMR	1.71	1.69	0.00	1.41%	100%
2.70	66 KV Vasant Kunj D	SVKJD116	11KV O/G Sun City Mall B-5 VK+Rangpuri-2	Mixed	AMR	2.70	0.00	2.61	3.35%	100%
0.68	66 KV Vasant Kunj D	SVKJD117	11kv S/S-3,805 MEGA HOUSING	Mixed	AMR	0.68	0.00	0.67	1.97%	100%
0.09	66 KV Vasant Kunj D	SVKJD118	11kv S/S-13,1904 MEGA HOUSING	Mixed	AMR	0.09	0.00	0.09	4.20%	100%
0.20	66 KV Vasant Kunj D	SVKJD119	MEGA HOUSING S/S NO.-1	Mixed	AMR	0.20	0.00	0.19	4.67%	100%
0.44	66 KV Vasant Kunj D	SVKJD120	11KV S/S-10,1904 MEGA HOUSING	Mixed	AMR	0.44	0.00	0.42	4.14%	100%
0.48	66 KV Vasant Kunj D	SVKJD121	11KV S/S-7,1904 MEGA HOUSING	Mixed	AMR	0.48	0.12	0.33	4.64%	100%
1.07	66 KV Vasant Kunj D	SVKJD122	11KV S/S-4,1904 MEGA HOUSING	Mixed	AMR	1.07	0.00	1.03	3.66%	100%
0.14	66 KV Vasant Kunj D	SVKJD123	11KV S/S-3 SULTANGARHI DDA FLAT 850 MEGA HO.	Residential	AMR	0.14	0.00	0.14	1.30%	100%
0.44	66 KV Vasant Kunj D	SVKJD124	11KV S/S-2 SULTANGARHI DDA FLAT 850 MEGA HO.	Residential	AMR	0.44	0.00	0.44	1.37%	100%
2.75	66 KV Vasant Kunj D	SVKJD125	11 KV O/G RANGPURI-1	Mixed	AMR	2.75	0.00	2.70	1.66%	100%
0.73	66 KV Vasant Kunj D	SVKJD126	MES RANGPURI FDR-1	Commercial	AMR	0.73	0.00	0.71	3.09%	100%
0.00	66 KV Vasant Kunj D	SVKJD127	MES RANGPURI FDR-2	Commercial	AMR	0.00	0.00	0.00	0.00%	100%
3.32	33 KV Vasant Vihar	SVVHR117	MEHRAN NAGAR	Mixed	AMR	3.32	0.97	2.28	2.18%	100%
1.22	220 KV MEHRAULI GRID	TDTMG103	VASANT KUNJ PKT-D-3 CHURCH ROAD	Mixed	AMR	1.22	0.00	1.22	0.67%	100%
0.75	220 KV MEHRAULI GRID	TDTMG104	VASANT KUNJ PKT-A	Mixed	AMR	0.75	0.00	0.74	0.64%	100%
1.06	220 KV VASANT KUNJ GRID	TDTVG101	INDIAN SPINAL INIUIERY HOSPITAL	Commercial	AMR	1.06	1.03	0.00	2.21%	100%
1.71	220 KV VASANT KUNJ GRID	TDTVG102	C-8 VASANT KUNJ S/STN-1 F-1	Mixed	AMR	1.71	0.00	1.67	1.92%	100%
0.93	220 KV VASANT KUNJ GRID	TDTVG103	S/STN NO-5, C-9	Mixed	AMR	0.93	0.36	0.55	1.49%	100%
3.76	220 KV VASANT KUNJ GRID	TDTVG104	RANGPURI	Mixed	AMR	3.76	0.00	3.67	2.23%	100%
3.14	220 KV VASANT KUNJ GRID	TDTVG105	IAAI	Mixed	AMR	3.14	0.92	2.18	1.44%	100%
0.96	220 KV VASANT KUNJ GRID	TDTVG106	S/STN NO-2, C-9	Mixed	AMR	0.96	0.00	0.95	1.04%	100%
0.02	220 KV VASANT KUNJ GRID	TDTVG107	C-8 VASANT KUNJ S/STN-1 F-2	Mixed	AMR	0.02	0.00	0.02	2.04%	100%
4.38	220 KV VASANT KUNJ GRID	TDTVG108	NANGAL DAIRY	Mixed	AMR	4.38	0.00	4.27	2.45%	100%
2.00	220 KV VASANT KUNJ GRID	TDTVG109	A V HOTEL	Commercial	AMR	2.00	0.66	1.30	1.90%	100%
1.49	220 KV VASANT KUNJ GRID	TDTVG110	MAHIPALPUR	Mixed	AMR	1.49	0.00	1.43	3.72%	100%
12.15	220 KV PAPANKALAN - 2 GRID	100019338	ENERGY FROM 220 KV PPK-2 TO DMRC	Commercial	AMR	12.15	12.11	0.00	0.37%	100%
2.40	220 KV PAPANKALAN - 1 GRID	TDTPG101	SEC-2	Residential	AMR	2.40	0.82	1.52	2.85%	100%
1.89	220 KV PAPANKALAN - 1 GRID	TDTPG102	SEC-10	Residential	AMR	1.89	0.68	1.21	0.03%	100%
2.49	220 KV PAPANKALAN - 1 GRID	TDTPG104	MAHALAKSHMI	Residential	AMR	2.49	0.86	1.61	1.22%	100%
3.77	220 KV PAPANKALAN - 1 GRID	TDTPG106	SEC-19	Residential	AMR	3.77	1.25	2.48	1.20%	100%
2.20	220 KV PAPANKALAN - 1 GRID	TDTPG107	NSIT	Residential	AMR	2.20	0.82	1.30	3.34%	100%
4.04	66 KV BINDAPUR	WBNDP109	MAHAVIR ENCLAVE S/STN-4	Residential	AMR	4.04	0.00	4.03	0.23%	100%
2.56	66 KV BINDAPUR	WBNDP110	MADHU VIHAR	Residential	AMR	2.56	0.00	2.53	0.80%	100%
3.01	66 KV BINDAPUR	WBNDP111	MAHAVIR ENCLAVE S/STN NO-2	Residential	AMR	3.01	0.00	2.96	1.86%	100%
2.20	66 KV BINDAPUR	WBNDP126	VISHWAS PARK NO-2	Residential	AMR	2.20	0.00	2.16	1.65%	100%
2.46	66 KV BINDAPUR	WBNDP129	AKASH HOSPITAL, SEC-3 DWARKA	Mixed	AMR	2.46	0.88	1.57	0.58%	100%
1.55	66 KV BINDAPUR	WBNDP130	RAJAPURI S/S-1 KHADDA WALA	Residential	AMR	1.55	0.00	1.53	1.39%	100%
2.37	66 KV BINDAPUR	WBNDP131	ROHTAS NAGAR	Residential	AMR	2.37	0.00	2.35	0.86%	100%
1.75	66 KV BINDAPUR	WBNDP607	S/STN 2 RAJA PURI OLD (DWK)	Mixed	AMR	1.75	0.00	1.71	1.98%	100%
3.56	66 KV BINDAPUR	WBNDP610	S/STN BHARAT VIHAR(DWK)	Mixed	AMR	3.56	0.00	3.50	1.63%	100%
0.97	66 KV G-15 PAPPANKALAN	WG15P101	11KV KARGIL APPT SEC-18	Commercial	AMR	0.97	0.36	0.56	4.73%	100%
2.80	66 KV G-15 PAPPANKALAN	WG15P102	11KV KARGIL CHOWK SEC-11	Commercial	AMR	2.80	0.98	1.79	1.30%	100%
3.17	66 KV G-15 PAPPANKALAN	WG15P103	11KV S/STN-4 PKT-7 SEC-12	Residential	AMR	3.17	1.04	2.09	1.08%	100%
2.84	66 KV G-15 PAPPANKALAN	WG15P104	11KV BAIRWA BHARTI APPT.SEC- 12	Commercial	AMR	2.84	1.04	1.78	0.81%	100%

972	DWARKA
973	DWARKA
974	DWARKA
975	DWARKA
976	DWARKA
977	DWARKA
978	DWARKA
979	DWARKA
980	DWARKA
981	DWARKA
982	DWARKA
983	DWARKA
984	DWARKA
985	DWARKA
986	DWARKA
987	DWARKA
988	DWARKA
989	DWARKA
990	DWARKA
991	DWARKA
992	DWARKA
993	DWARKA
994	DWARKA
995	DWARKA
996	DWARKA
997	DWARKA
998	DWARKA
999	DWARKA
1000	DWARKA
1001	DWARKA
1002	DWARKA
1003	DWARKA
1004	DWARKA
1005	DWARKA
1006	DWARKA
1007	DWARKA
1008	DWARKA
1009	DWARKA
1010	DWARKA
1011	DWARKA
1012	DWARKA
1013	DWARKA
1014	DWARKA
1015	DWARKA
1016	DWARKA
1017	DWARKA
1018	DWARKA

1.86	66 KV G-15 PAPPANKALAN	WG15P105	11KV PARK PLAZA HOTEL-2 SEC-13	Commercial	AMR	1.86	1.85	0.00	0.39%		100%
3.06	66 KV G-15 PAPPANKALAN	WG15P106	SEC 3/13 RED LIGHT	Residential	AMR	3.06	0.98	2.03	1.88%		100%
0.57	66 KV G-15 PAPPANKALAN	WG15P107	NHAI Housing Society, Sector-17, Dwarka	Residential	AMR	0.57	0.25	0.30	3.20%		100%
0.03	66 KV G-15 PAPPANKALAN	WG15P108	11KV LOCAL TR5 400KVA	Local Grid	AMR	0.03	0.00	0.03	0.40%		100%
3.60	66 KV G-15 PAPPANKALAN	WG15P109	11KV O/G K.M. Chowk	Residential	AMR	3.60	1.17	2.39	0.92%		100%
3.53	66 KV G-15 PAPPANKALAN	WG15P110	11KV PARK PLAZA HOTEL-1 SEC-13	Commercial	AMR	3.53	1.19	2.28	1.96%		100%
2.72	66 KV G-15 PAPPANKALAN	WG15P111	11KV PLOTTED AREA 5/STN-1,SEC-12	Residential	AMR	2.72	0.93	1.78	0.68%		100%
1.27	66 KV G-15 PAPPANKALAN	WG15P112	11KV DJA APPT SEC-13	Commercial	AMR	1.27	0.56	0.68	1.95%		100%
1.83	66 KV G-15 PAPPANKALAN	WG15P113	11KV S/STN-1 PLOTTED AREA SEC-13	Residential	AMR	1.83	0.73	1.09	0.64%		100%
2.18	66 KV G-15 PAPPANKALAN	WG15P116	11 KV O/G WYNTHAM HOTEL SECT-10	Commercial	AMR	2.18	2.16	0.00	0.93%		100%
1.73	66 KV G-15 PAPPANKALAN	WG15P117	11 KV O/G PERIPHERAL SECTOR-19	Residential	AMR	1.73	0.00	1.71	1.19%		100%
2.77	66 KV G-15 PAPPANKALAN	WG15P120	S/STN. 4 L&T FLATS, SECTOR 18, DWAR	Residential	AMR	2.77	0.94	1.77	2.12%		100%
2.28	66 KV G-15 PAPPANKALAN	WG15P121	S/STN. 3 DDA MEGA HOUSES, SECTOR 18	Residential	AMR	2.28	0.80	1.43	2.15%		100%
3.00	66 KV G-15 PAPPANKALAN	WG15P122	O/G SEC-13, PLOTTED AREA -2	Residential	AMR	3.00	1.49	1.46	1.32%		100%
1.94	66 KV G-15 PAPPANKALAN	WG15P123	O/G DJB SEC 16/D, DWARKA	Mixed	AMR	1.94	1.94	0.00	0.48%		100%
0.98	66 KV G-15 PAPPANKALAN	WG15P124	HUMAN CARE HOSPITAL DWK SECTOR-6	Commercial	AMR	0.98	0.00	0.96	1.64%		100%
0.04	66 KV G-15 PAPPANKALAN	WG15P125	PGCIL SEC -5	Commercial	AMR	0.04	0.00	0.04	2.00%		100%
0.52	66 KV G-15 PAPPANKALAN	WG15P620	BHAWALPUR CGHS, SEC-4	Mixed	AMR	0.52	0.00	0.52	0.09%		100%
2.80	66 KV G-1 PAPPANKALAN	WG1PN108	SHIV PARK	Residential	AMR	2.80	0.00	2.78	0.90%		100%
2.71	66 KV G-1 PAPPANKALAN	WG1PN109	SEC-15 JJ COLONY	Residential	AMR	2.71	0.00	2.63	2.67%		100%
3.76	66 KV G-1 PAPPANKALAN	WG1PN110	KAKROLA HOUSING COMPLEX	Residential	AMR	3.76	0.00	3.74	0.44%		100%
3.70	66 KV G-1 PAPPANKALAN	WG1PN115	VEGAS MALL SEC-14 NO-1	Mixed	AMR	3.70	1.14	2.52	1.10%		100%
0.05	66 KV G-1 PAPPANKALAN	WG1PN118	LOCAL TRANSFORMER	Local Grid	AMR	0.05	0.00	0.05	0.51%		100%
1.55	66 KV G-1 PAPPANKALAN	WG1PN123	SHAHEED BHAGAT SINGH	Residential	AMR	1.55	0.56	0.96	1.74%		100%
1.18	66 KV G-1 PAPPANKALAN	WG1PN126	SEC 13 PARK WALA	Residential	AMR	1.18	0.00	1.15	2.48%		100%
1.37	66 KV G-1 PAPPANKALAN	WG1PN127	VEGAS MALL SEC-14 NO-2	Commercial	AMR	1.37	0.00	1.37	0.26%		100%
0.82	66 KV G-1 PAPPANKALAN	WG1PN129	ELECTION COMMISSION DWK SECTOR-13	Mixed	AMR	0.82	0.40	0.40	3.42%		100%
2.77	66 KV G-1 PAPPANKALAN	WG1PN130	VIKAS SONIYAWALA	Residential	AMR	2.77	0.00	2.73	1.39%		100%
1.14	66 KV G-1 PAPPANKALAN	WG1PN131	VARDHMAN MARKET SEC-3	Mixed	AMR	1.14	0.52	0.61	1.04%		100%
0.13	66 KV G-1 PAPPANKALAN	WG1PN132	346/348 MS APT. SEC - 16 B	Mixed	AMR	0.13	0.00	0.12	4.04%		100%
0.00	66 KV G-1 PAPPANKALAN	WG1PN133	SHYAM VIHAR SEC-15	Mixed	AMR	0.00	0.00	0.00	0.00%		100%
2.93	66 KV G-1 PAPPANKALAN	WG1PN140	NETAJI SUBHAS CHAND APPT. SEC-13 PH-1 PKT-1	Mixed	AMR	2.93	0.00	2.93	0.03%		100%
1.14	66 KV G-4 PAPPANKALAN	WG4PN104	11 KV O/G VENKATASHWAR HOSPITAL NO. 3	Commercial	AMR	1.14	0.43	0.69	1.71%		100%
1.65	66 KV G-4 PAPPANKALAN	WG4PN106	11 KV O/G GULSHAN EQBAL	Residential	AMR	1.65	0.63	0.97	3.01%		100%
1.35	66 KV G-4 PAPPANKALAN	WG4PN107	11 KV KRISHNA RESIDENCY	Residential	AMR	1.35	0.56	0.77	1.58%		100%
2.12	66 KV G-4 PAPPANKALAN	WG4PN108	11 KV MEGA HOUSING SECTOR 18	Residential	AMR	2.12	0.00	2.09	1.23%		100%
1.68	66 KV G-4 PAPPANKALAN	WG4PN109	11 KV O/G OPG SEC-19B	Residential	AMR	1.68	0.77	0.88	2.14%		100%
0.93	66 KV G-4 PAPPANKALAN	WG4PN111	11 KV O/G VENKATASHWAR HOSPITAL NO. 2	Commercial	AMR	0.93	0.00	0.93	0.18%		100%
0.03	66 KV G-4 PAPPANKALAN	WG4PN114	11 KV LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	0.44%		100%
1.12	66 KV G-4 PAPPANKALAN	WG4PN115	11 KV RELIANCE AMBIT	Mixed	AMR	1.12	1.11	0.00	0.63%		100%
2.36	66 KV G-4 PAPPANKALAN	WG4PN116	DDA GROUND 2,SEC 10,RMU-2	Residential	AMR	2.36	0.86	1.49	0.69%		100%
1.14	66 KV G-4 PAPPANKALAN	WG4PN117	DDA GROUND 1,SEC 10,RMU-1	Residential	AMR	1.14	0.54	0.60	0.44%		100%
1.10	66 KV G-4 PAPPANKALAN	WG4PN118	11 KV RELIANCE AMBIT NO-2, SEC 13	Mixed	AMR	1.10	0.50	0.59	1.27%		100%
1.52	66 KV G-4 PAPPANKALAN	WG4PN119	POLICE STATION & QUATOR SEC-16, DWARKA	Mixed	AMR	1.52	0.64	0.83	3.27%		100%
0.01	66 KV G-4 PAPPANKALAN	WG4PN130	352 DDA FLATS 19B DWK	Mixed	AMR	0.01	0.00	0.01	0.39%		100%
3.62	66 KV G-6 PAPPANKALA	WG6PN101	SECTOR-19 PCKET-1	Residential	AMR	3.62	1.20	2.35	1.66%		100%
1.36	66 KV G-6 PAPPANKALA	WG6PN104	DIST. COURT-2 SEC-10	Mixed	AMR	1.36	0.58	0.75	1.69%		100%

1019	DWARKA
1020	DWARKA
1021	DWARKA
1022	DWARKA
1023	DWARKA
1024	DWARKA
1025	DWARKA
1026	DWARKA
1027	DWARKA
1028	DWARKA
1029	DWARKA
1030	DWARKA
1031	DWARKA
1032	DWARKA
1033	DWARKA
1034	DWARKA
1035	DWARKA
1036	DWARKA
1037	DWARKA
1038	DWARKA
1039	DWARKA
1040	DWARKA
1041	DWARKA
1042	DWARKA
1043	DWARKA
1044	DWARKA
1045	DWARKA
1046	DWARKA
1047	DWARKA
1048	DWARKA
1049	DWARKA
1050	DWARKA
1051	DWARKA
1052	DWARKA
1053	DWARKA
1054	DWARKA
1055	DWARKA
1056	DWARKA
1057	JANAK PURI
1058	JANAK PURI
1059	JANAK PURI
1060	JANAK PURI
1061	JANAK PURI
1062	JANAK PURI
1063	JANAK PURI
1064	JANAK PURI
1065	JANAK PURI
1066	JANAK PURI
1067	JANAK PURI
1068	JANAK PURI
1069	JANAK PURI
1070	JANAK PURI
1071	JANAK PURI
1072	JANAK PURI

242.77

1.34	66 KV G-6 PAPPANKALA	WG6PN105	Wyndham Hotal	Mixed	AMR	1.34	1.33	0.00	0.22%	100%
0.88	66 KV G-6 PAPPANKALA	WG6PN113	Sector-10 (Hilansh)	Residential	AMR	0.88	0.35	0.49	4.70%	100%
1.00	66 KV G-6 PAPPANKALA	WG6PN114	DIST. COURT-1 SEC-10	Mixed	AMR	1.00	0.26	0.72	1.91%	100%
2.96	66 KV G-6 PAPPANKALA	WG6PN121	Peripheral S/S-2 Sector- 10	Residential	AMR	2.96	1.03	1.92	0.23%	100%
1.82	66 KV G-6 PAPPANKALA	WG6PN122	PP-1 Sector-10	Residential	AMR	1.82	0.71	1.07	2.46%	100%
2.01	66 KV G-6 PAPPANKALA	WG6PN130	NHAI SEC-10	Residential	AMR	2.01	0.75	1.25	0.85%	100%
2.21	66 KV G-7 DWARKA	WG7PN105	UNIQUE APTT. (DWK)	Residential	AMR	2.21	0.79	1.36	2.80%	100%
1.61	66 KV G-7 DWARKA	WG7PN111	HUMAN CARE MEDICAL CHARITABLE TRUST	Commercial	AMR	1.61	1.60	0.00	0.67%	100%
1.30	66 KV G-7 DWARKA	WG7PN113	GODREJ APTT. (DWK)	Residential	AMR	1.30	0.49	0.81	0.13%	100%
1.37	66 KV G-7 DWARKA	WG7PN120	PUNJAB NATIONAL BANK, PLOT NO -4, SEC 10	Commercial	AMR	1.37	1.36	0.00	0.77%	100%
0.03	66 KV G-5 PPKN(MATIYALA)	WMTLA102	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	0.43%	100%
1.43	66 KV G-5 PPKN(MATIYALA)	WMTLA103	NSITNO 1	Residential	AMR	1.43	1.42	0.00	0.58%	100%
1.84	66 KV G-5 PPKN(MATIYALA)	WMTLA104	JAIN COLONY	Residential	AMR	1.84	0.00	1.82	1.10%	100%
1.96	66 KV G-5 PPKN(MATIYALA)	WMTLA110	SECTOR 3 DWARKA	Residential	AMR	1.96	0.75	1.19	0.99%	100%
1.04	66 KV G-5 PPKN(MATIYALA)	WMTLA111	Sector-4 PPK	Residential	AMR	1.04	0.37	0.66	0.70%	100%
4.75	66 KV G-5 PPKN(MATIYALA)	WMTLA113	MATIYALA	Residential	AMR	4.75	0.00	4.73	0.36%	100%
1.92	66 KV G-5 PPKN(MATIYALA)	WMTLA114	IES Dwarka	Residential	AMR	1.92	0.81	1.09	1.36%	100%
1.69	66 KV G-5 PPKN(MATIYALA)	WMTLA115	G & S BLOCK, RAJAPURI	Residential	AMR	1.69	0.00	1.64	2.65%	100%
1.44	66 KV G-5 PPKN(MATIYALA)	WMTLA116	COMMAND TANK,SECT - 3, DWARKA	Residential	AMR	1.44	0.51	0.89	2.36%	100%
3.05	66 KV G-5 PPKN(MATIYALA)	WMTLA118	O/G ADARSH PRODUKI	Residential	AMR	3.05	0.00	3.02	0.75%	100%
3.65	66 KV G-5 PPKN(MATIYALA)	WMTLA122	KAKROLA NO. II	Residential	AMR	3.65	1.23	2.35	1.97%	100%
1.82	66 KV G-5 PPKN(MATIYALA)	WMTLA123	JJ COLONY SECT - 3, DWARKA	Residential	AMR	1.82	0.70	1.11	1.07%	100%
3.48	66 KV G-5 PPKN(MATIYALA)	WMTLA124	SAINIK NAGAR	Residential	AMR	3.48	0.00	3.43	1.24%	100%
3.02	66 KV G-5 PPKN(MATIYALA)	WMTLA125	210 DDA FLATS	Residential	AMR	3.02	0.00	2.97	1.73%	100%
2.06	66 KV G-5 PPKN(MATIYALA)	WMTLA127	Sec-3 PP S/S-1	Residential	AMR	2.06	0.72	1.29	2.17%	100%
2.66	66 KV G-5 PPKN(MATIYALA)	WMTLA128	11 KV CB : PHASE-1, JJ.COLONY	Residential	AMR	2.66	0.00	2.61	1.71%	100%
3.36	66 KV G-5 PPKN(MATIYALA)	WMTLA137	PRAGYA CGHS, SEC-2, DWARKA	Residential	AMR	3.36	0.00	3.34	0.54%	100%
2.21	66 KV G-5 PPKN(MATIYALA)	WMTLA138	11 KV T-EXTENSION, DWARKA	Residential	AMR	2.21	0.00	2.17	1.87%	100%
1.62	66 KV G-5 PPKN(MATIYALA)	WMTLA142	MANSA RAM PARK	Residential	AMR	1.62	0.00	1.58	2.33%	100%
2.06	66 KV G-5 PPKN(MATIYALA)	WMTLA145	O/G COMMAND TANK NO.2, C.3	Mixed	AMR	2.06	0.78	1.25	1.18%	100%
3.75	66 KV PAPPANKALAN - 2	WPKL2101	NAND VIHAR	Residential	AMR	3.75	0.00	3.71	1.13%	100%
3.31	66 KV PAPPANKALAN - 2	WPKL2103	KAKROLA VILLAGE	Residential	AMR	3.31	0.00	3.27	1.19%	100%
0.01	66 KV PAPPANKALAN - 2	WPKL2104	LOCAL TRANSFORMER	Local Grid	AMR	0.01	0.00	0.01	0.17%	100%
0.04	66 KV PAPPANKALAN - 2	WPKL2106	630 KVA LOCAL TRF(DTL)	Local Grid	AMR	0.04	0.00	0.04	0.50%	100%
1.56	66 KV PAPPANKALAN - 2	WPKL2107	DELHI JUDICIAL-1	Commercial	AMR	1.56	0.65	0.90	0.45%	100%
2.00	66 KV PAPPANKALAN - 2	WPKL2110	PP SEC- 17 DWARKA	Residential	AMR	2.00	0.73	1.21	2.99%	100%
1.43	66 KV PAPPANKALAN - 2	WPKL2113	EROS METRO MALL SEC -14 + 736 EWS SEC-16	Commercial	AMR	1.43	0.54	0.85	2.87%	100%
3.77	66 KV PAPPANKALAN - 2	WPKL2114	GG SIP UNIVERSITY + SECTOR-16 B POCKET-1	Commercial	AMR	3.77	1.17	2.54	1.44%	100%
12.50	220 KV PAPANALAN - 1 GRID	100005524	ENERGY FROM 220 KV PPK-1 TO DMRC NO 182	Commercial	AMR	12.50	12.45	0.00	0.37%	100%
0.15	66 KV REWAR LINE	NRVLN101	A-43 Mayapuri	Mixed	AMR	0.15	0.04	0.11	0.75%	100%
0.02	66 KV REWAR LINE	NRVLN104	B-32 Mayapuri	Mixed	AMR	0.02	0.00	0.01	0.19%	100%
0.04	66 KV REWAR LINE	NRVLN105	DTC FEEDER	Mixed	AMR	0.04	0.00	0.04	0.46%	100%
0.31	66 KV REWAR LINE	NRVLN106	11&12 BLKSUBASH NAGAR	Mixed	AMR	0.31	0.00	0.31	0.59%	100%
2.21	66 KV REWAR LINE	NRVLN107	MCD RG SSTN	Mixed	AMR	2.21	0.00	2.21	0.11%	100%
0.81	66 KV REWAR LINE	NRVLN109	Q-Block	Mixed	AMR	0.81	0.00	0.81	0.64%	100%
1.80	33 KV A-43 MAYAPURI	WA43M115	A8 PH-1 MAYAPURI	Industrial	AMR	1.80	0.00	1.74	3.10%	100%
2.86	33 KV A-43 MAYAPURI	WA43M116	SHOPPING CENTER PH-1	Mixed	AMR	2.86	0.00	2.80	2.06%	100%
3.98	33 KV A-43 MAYAPURI	WA43M117	S/STN NO-2 SUBHASH NAGAR	Residential	AMR	3.98	0.99	2.86	3.30%	100%
0.88	33 KV A-43 MAYAPURI	WA43M118	GILL HOUSE RAJOURI GARDEN	Residential	AMR	0.88	0.00	0.86	2.29%	100%
1.67	33 KV A-43 MAYAPURI	WA43M119	B-32 MAYAPURI PH-1	Industrial	AMR	1.67	0.00	1.61	3.41%	100%
2.60	33 KV A-43 MAYAPURI	WA43M120	RAMA PURA S/STN	Residential	AMR	2.60	0.00	2.54	2.44%	100%
1.43	33 KV A-43 MAYAPURI	WA43M121	DTC MAYAPURI EBUS CHARGING NO. 1	Mixed	AMR	1.43	0.00	1.42	0.45%	100%
2.58	33 KV A-43 MAYAPURI	WA43M133	B-125 PH-1 MAYAPURI	Industrial	AMR	2.58	0.00	2.51	2.63%	100%
2.62	33 KV A-43 MAYAPURI	WA43M134	Q-BLK RAJOURI GARDEN	Residential	AMR	2.62	0.00	2.58	1.82%	100%

1073	JANAK PURI
1074	JANAK PURI
1075	JANAK PURI
1076	JANAK PURI
1077	JANAK PURI
1078	JANAK PURI
1079	JANAK PURI
1080	JANAK PURI
1081	JANAK PURI
1082	JANAK PURI
1083	JANAK PURI
1084	JANAK PURI
1085	JANAK PURI
1086	JANAK PURI
1087	JANAK PURI
1088	JANAK PURI
1089	JANAK PURI
1090	JANAK PURI
1091	JANAK PURI
1092	JANAK PURI
1093	JANAK PURI
1094	JANAK PURI
1095	JANAK PURI
1096	JANAK PURI
1097	JANAK PURI
1098	JANAK PURI
1099	JANAK PURI
1100	JANAK PURI
1101	JANAK PURI
1102	JANAK PURI
1103	JANAK PURI
1104	JANAK PURI
1105	JANAK PURI
1106	JANAK PURI
1107	JANAK PURI
1108	JANAK PURI
1109	JANAK PURI
1110	JANAK PURI
1111	JANAK PURI
1112	JANAK PURI
1113	JANAK PURI
1114	JANAK PURI
1115	JANAK PURI
1116	JANAK PURI
1117	JANAK PURI
1118	JANAK PURI
1119	JANAK PURI
1120	JANAK PURI
1121	JANAK PURI

0.54	33 KV A-43 MAYAPURI	WA43M135	POLICE S/STN MAYAPURI	Mixed	AMR	0.54	0.00	0.53	2.79%	100%
1.58	33 KV A-43 MAYAPURI	WA43M136	E-BLOCK MAYAPURI PH-2	Industrial	AMR	1.58	0.00	1.51	4.16%	100%
0.19	33 KV A-43 MAYAPURI	WA43M138	DJB BPS, MAYAPURI	Mixed	AMR	0.19	0.05	0.14	1.40%	100%
1.92	33 KV A-43 MAYAPURI	WA43M139	METAL FORGING	Mixed	AMR	1.92	0.00	1.88	2.09%	100%
0.03	33 KV A-43 MAYAPURI	WA43M141	LOCAL TRANSFORMER -1	Local Grid	AMR	0.03	0.00	0.03	0.42%	100%
0.01	33 KV A-43 MAYAPURI	WA43M142	DTC MAYAPURI EBUS CHARGING NO. 2	Mixed	AMR	0.01	0.00	0.01	0.32%	100%
2.89	66 KV BODELLA-1	WBDL1123	AGARWAL PLAZA	Mixed	AMR	2.89	0.72	2.10	2.55%	100%
4.15	66 KV HARI NAGAR	WHRGN103	FATEH NAGAR	Mixed	AMR	4.15	1.03	2.97	3.50%	100%
1.79	66 KV HARI NAGAR	WHRGN104	GANDHI PARK I/D S/STN.-1	Mixed	AMR	1.79	0.00	1.77	1.50%	100%
2.83	66 KV HARI NAGAR	WHRGN105	G BLOCK HARI NAGAR	Mixed	AMR	2.83	0.00	2.79	1.07%	100%
2.57	66 KV HARI NAGAR	WHRGN106	GURUDWARA R/GARDEN	Mixed	AMR	2.57	0.00	2.55	0.90%	100%
3.50	66 KV HARI NAGAR	WHRGN107	TIKONA PARK ASHOK NAGAR	Mixed	AMR	3.50	0.00	3.43	1.98%	100%
2.72	66 KV HARI NAGAR	WHRGN108	RMU-2	Mixed	AMR	2.72	0.00	2.69	1.22%	100%
3.36	66 KV HARI NAGAR	WHRGN109	14 BLOCK SUBHASH NAGAR+ARJUN BAKERY	Residential	AMR	3.36	0.84	2.47	1.54%	100%
3.96	66 KV HARI NAGAR	WHRGN110	AJANTA INDOOR+ S/STN NO-3 SUBHASH NGR	Mixed	AMR	3.96	0.00	3.90	1.43%	100%
3.41	66 KV HARI NAGAR	WHRGN111	SUB DISTRICT CENTER NO-2 HARI	Mixed	AMR	3.41	0.86	2.48	2.01%	100%
2.44	66 KV HARI NAGAR	WHRGN113	CET PLANT MAYAPURI	Mixed	AMR	2.44	0.43	1.96	2.43%	100%
2.83	66 KV HARI NAGAR	WHRGN114	J BLOCK RAJOURI GARDEN	Mixed	AMR	2.83	0.72	2.10	0.39%	100%
0.06	66 KV HARI NAGAR	WHRGN115	LOCAL TR. 400 KVA	Local Grid	AMR	0.06	0.00	0.06	0.54%	100%
0.16	66 KV HARI NAGAR	WHRGN116	MTNL FDR NO. I-AJANTA	Commercial	AMR	0.16	0.04	0.12	0.25%	100%
2.02	66 KV HARI NAGAR	WHRGN117	LIG RAJOURI GARDEN	Mixed	AMR	2.02	0.00	1.95	3.54%	100%
3.78	66 KV HARI NAGAR	WHRGN118	MIG RAJOURI GARDEN	Residential	AMR	3.78	0.00	3.73	1.39%	100%
3.06	66 KV HARI NAGAR	WHRGN120	LIG 149	Residential	AMR	3.06	0.00	3.03	1.21%	100%
1.62	66 KV HARI NAGAR	WHRGN121	11 KV DELHI HAAT	Commercial	AMR	1.62	0.39	1.21	1.03%	100%
2.33	66 KV HARI NAGAR	WHRGN127	SHIV NAGAR EXTN	Mixed	AMR	2.33	0.00	2.31	0.95%	100%
2.64	66 KV HARI NAGAR	WHRGN128	SS NO 3 SUBASH NAGAR	Mixed	AMR	2.64	0.00	2.57	2.67%	100%
1.89	66 KV HARI NAGAR	WHRGN129	ARJUN BAKERY MANAK VIHAR	Mixed	AMR	1.89	0.00	1.86	1.46%	100%
2.12	66 KV HARI NAGAR	WHRGN130	GOPAL NAGAR	Mixed	AMR	2.12	0.00	2.07	2.26%	100%
3.62	33 KV JANAK PURI	WJKPG101	11 KV O/G NANGLOI ZALIB	Mixed	AMR	3.62	0.87	2.67	2.04%	100%
1.99	33 KV JANAK PURI	WJKPG104	11 KV O/G JYOTI SHIKHAR+ PICODALITY HOSPITAL	Commercial	AMR	1.99	0.40	1.59	0.19%	100%
3.12	33 KV JANAK PURI	WJKPG106	11 KV O/G BOOSTER (JANAKPURI)	Residential	AMR	3.12	0.79	2.29	1.24%	100%
3.14	33 KV JANAK PURI	WJKPG107	B-3 S/STN JANAKPURI	Mixed	AMR	3.14	0.00	3.08	1.87%	100%
1.96	33 KV JANAK PURI	WJKPG108	PLOT NO.-5 DISTT. CENTRE JANAKPURI	Commercial	AMR	1.96	0.00	1.91	2.38%	100%
3.60	33 KV JANAK PURI	WJKPG109	O/G PLOT NO-11 D.C + BOOSTER PUMP	Commercial	AMR	3.60	0.00	3.52	2.06%	100%
2.35	33 KV JANAK PURI	WJKPG110	11 KV O/G PLOT NO. 13 LIC BLDG.	Mixed	AMR	2.35	0.61	1.72	1.21%	100%
0.55	33 KV JANAK PURI	WJKPG111	11 KV O/G DISTT. SERVICE CENTER JKP	Commercial	AMR	0.55	0.13	0.42	0.40%	100%
0.10	33 KV JANAK PURI	WJKPG112	11 KV O/G LOCAL TRANSFORMER	Local Grid	AMR	0.10	0.00	0.09	0.55%	100%
1.08	33 KV JANAK PURI	WJKPG115	PLOT NO. 7A D C JANAK PURI	Commercial	AMR	1.08	0.28	0.78	1.49%	100%
1.34	33 KV JANAK PURI	WJKPG116	CNG PUMP D C JANAK PURI	Commercial	AMR	1.34	0.31	1.01	1.30%	100%
3.15	33 KV JANAK PURI	WJKPG117	B6 INDOOR, S/STN MAULA WALA	Mixed	AMR	3.15	0.00	3.06	2.80%	100%
0.80	33 KV METAL FORGING	WMEFO101	I/C FROM REWARI LN T-OFF MAYAPURI - 11 KV I/C	Mixed	AMR	0.80	0.18	0.60	1.91%	100%
1.68	33 KV MUKHERJI PARK	WMUKP105	SUBHASH NAGAR S/STN.-1	Mixed	AMR	1.68	0.00	1.67	0.75%	100%
2.70	33 KV MUKHERJI PARK	WMUKP109	AJANTA S/STN.	Mixed	AMR	2.70	0.00	2.64	2.26%	100%
3.48	33 KV MUKHERJI PARK	WMUKP130	6 BLOCK SUBHASH NAGAR	Residential	AMR	3.48	0.00	3.40	2.40%	100%
0.56	33 KV MUKHERJI PARK	WMUKP131	RED MIG RAJOURI GARDEN	Mixed	AMR	0.56	0.00	0.56	0.63%	100%
3.32	33 KV MAYA PURI	WMYPR103	F BLOCK MAYAPURI	Industrial	AMR	3.32	0.00	3.24	2.27%	100%
3.33	33 KV MAYA PURI	WMYPR104	11 KV O/G MIG RAJOKIRI GARDEN	Mixed	AMR	3.33	0.00	3.29	1.06%	100%
1.93	33 KV MAYA PURI	WMYPR105	DDU Hospital	Mixed	AMR	1.93	0.50	1.42	0.35%	100%
2.86	33 KV MAYA PURI	WMYPR108	SFS NO-1	Residential	AMR	2.86	0.73	2.10	1.27%	100%

1122	JANAK PURI
1123	JANAK PURI
1124	JANAK PURI
1125	JANAK PURI
1126	JANAK PURI
1127	JANAK PURI
1128	JANAK PURI
1129	JANAK PURI
1130	JANAK PURI
1131	JANAK PURI
1132	JANAK PURI
1133	JANAK PURI
1134	JANAK PURI
1135	JANAK PURI
1136	JANAK PURI
1137	JANAK PURI
1138	JANAK PURI
1139	JANAK PURI
1140	JANAK PURI
1141	JANAK PURI
1142	JANAK PURI
1143	JANAK PURI
1144	JANAK PURI
1145	JANAK PURI
1146	JANAK PURI
1147	JANAK PURI
1148	JANAK PURI
1149	JANAK PURI
1150	JANAK PURI
1151	JANAK PURI
1152	JANAK PURI
1153	JANAK PURI
1154	JANAK PURI
1155	JANAK PURI
1156	JANAK PURI
1157	JANAK PURI
1158	JANAK PURI
1159	JANAK PURI
1160	JANAK PURI
1161	JANAK PURI
1162	JANAK PURI
1163	JANAK PURI
1164	JANAK PURI
1165	JANAK PURI
1166	JANAK PURI
1167	PALAM
1168	PALAM
1169	PALAM
1170	PALAM
1171	PALAM
1172	PALAM
1173	PALAM
1174	PALAM

218.69

0.88	33 KV MAYA PURI	WMYPR109	AJANTA F. D.	Mixed	AMR	0.88	0.25	0.62	1.96%	100%
3.58	33 KV MAYA PURI	WMYPR110	MAHARANI S/STN.	Industrial	AMR	3.58	0.00	3.47	3.02%	100%
2.78	33 KV MAYA PURI	WMYPR111	D BLOCK KHAZAN BASTI	Mixed	AMR	2.78	0.00	2.73	1.95%	100%
3.07	33 KV MAYA PURI	WMYPR112	TIHAR JAIL	Public Utilities	AMR	3.07	0.78	2.21	2.76%	100%
3.22	33 KV MAYA PURI	WMYPR113	KACCHA TIHAR	Residential	AMR	3.22	0.00	3.16	1.66%	100%
3.06	33 KV MAYA PURI	WMYPR114	C-88 MAYAPURI	Industrial	AMR	3.06	0.77	2.24	1.66%	100%
2.10	33 KV MAYA PURI	WMYPR115	O/H SHIV N.G.R	Mixed	AMR	2.10	0.00	2.04	3.00%	100%
0.02	33 KV MAYA PURI	WMYPR116	LOCAL Transformer	Local Grid	AMR	0.02	0.00	0.02	0.29%	100%
3.41	33 KV MAYA PURI	WMYPR117	Facility Centre	Mixed	AMR	3.41	0.87	2.51	0.63%	100%
2.77	33 KV MAYA PURI	WMYPR118	PUMPING STN., SWARG ASH.,SUBHASHNGR	Mixed	AMR	2.77	0.69	2.01	2.37%	100%
2.71	33 KV MAYA PURI	WMYPR121	O/G POLICE CHOWNKI HARI NAGAR	Residential	AMR	2.71	0.70	2.00	0.38%	100%
2.04	33 KV MAYA PURI	WMYPR122	11 KV O\G D-1 JANAKPURI	Mixed	AMR	2.04	0.53	1.47	1.87%	100%
1.11	33 KV MAYA PURI	WMYPR123	11 KV O\G DDU STAFF QUARTERS	Mixed	AMR	1.11	0.00	1.08	2.66%	100%
1.54	33 KV MAYA PURI	WMYPR124	BOOTER PUMP ,DELHI CANTT	Public Utilities	AMR	1.54	0.00	1.49	2.98%	100%
2.19	66 KV PANKHA ROAD	WPNRD110	O/G TO C-II BLOCK JKP	Mixed	AMR	2.19	0.00	2.12	3.11%	100%
2.77	66 KV PANKHA ROAD	WPNRD111	B -II S/STN JKP	Mixed	AMR	2.77	0.68	2.05	1.39%	100%
3.92	66 KV PANKHA ROAD	WPNRD112	A-4 JKP (ASALAT PUR)	Residential	AMR	3.92	0.00	3.83	2.49%	100%
2.26	66 KV PANKHA ROAD	WPNRD114	R M U	Commercial	AMR	2.26	0.00	2.19	2.76%	100%
1.99	66 KV PANKHA ROAD	WPNRD115	A-1 MOTHER DAIRY	Mixed	AMR	1.99	0.00	1.96	1.28%	100%
0.03	66 KV PANKHA ROAD	WPNRD116	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	0.42%	100%
2.29	66 KV PANKHA ROAD	WPNRD118	P&T QUARTERS	Residential	AMR	2.29	0.00	2.27	1.05%	100%
0.24	66 KV PANKHA ROAD	WPNRD623	DJB BPS JANAKPURI	Mixed	AMR	0.24	0.06	0.17	2.07%	100%
1.79	66 KV PANKHA ROAD	WPNRD626	C-BLK DABRI MORE JKP	Mixed	AMR	1.79	0.00	1.78	0.51%	100%
1.26	66 KV PANKHA ROAD	WPNRD627	C 2A	Mixed	AMR	1.26	0.00	1.26	0.12%	100%
1.00	66 KV SAGARPUR	WSGRP101	COMM. CENTER S/S NO. 1 PETROL PUMP	Mixed	AMR	1.00	0.24	0.77	0.06%	100%
3.05	66 KV SAGARPUR	WSGRP102	TIHAR JAIL NO.-5	Mixed	AMR	3.05	0.78	2.23	1.35%	100%
0.34	66 KV SAGARPUR	WSGRP104	DDU Hospital no-2	Commercial	AMR	0.34	0.00	0.33	1.77%	100%
3.35	66 KV SAGARPUR	WSGRP106	C- 4 JANAKPURI	Mixed	AMR	3.35	0.00	3.30	1.49%	100%
2.21	66 KV SAGARPUR	WSGRP108	MS Building (Comm.Center JKP)	Mixed	AMR	2.21	0.55	1.64	0.97%	100%
2.24	66 KV SAGARPUR	WSGRP109	BOOSTER PUMP DELHI CANTT	Public Utilities	AMR	2.24	0.56	1.65	1.60%	100%
1.75	66 KV SAGARPUR	WSGRP110	INSTITUTIONAL AREA S/S-1 JKP	Commercial	AMR	1.75	0.00	1.71	2.24%	100%
3.28	66 KV SAGARPUR	WSGRP111	D -2 JANAKPURI	Mixed	AMR	3.28	0.00	3.23	1.70%	100%
3.79	66 KV SAGARPUR	WSGRP118	D-1 S/STN JKP	Mixed	AMR	3.79	0.97	2.77	1.39%	100%
3.20	66 KV SAGARPUR	WSGRP119	C-3 COMPLAINT CENTER JKP	Mixed	AMR	3.20	0.00	3.13	2.28%	100%
2.00	66 KV SAGARPUR	WSGRP121	B-2 BOOSTER PUMP-JKP	Mixed	AMR	2.00	0.51	1.46	1.64%	100%
3.01	66 KV SAGARPUR	WSGRP122	C.C.R.A. S/STN JKP	Mixed	AMR	3.01	0.78	2.22	0.36%	100%
0.03	66 KV SAGARPUR	WSGRP124	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	0.39%	100%
2.12	66 KV SAGARPUR	WSGRP125	Musical fountain	Mixed	AMR	2.12	0.00	2.06	2.84%	100%
0.85	66 KV SAGARPUR	WSGRP126	D.D.U. HOSPITAL NO-I	Commercial	AMR	0.85	0.20	0.64	1.07%	100%
2.10	66 KV SAGARPUR	WSGRP130	MOHAN NAGAR, MANDIR WALA S/STN	Mixed	AMR	2.10	0.00	2.06	1.78%	100%
3.44	33 KV WDDC VISHAL	WVSHL112	J-3 RAJOURI GARDEN	Mixed	AMR	3.44	0.00	3.34	2.86%	100%
2.41	33 KV WDDC VISHAL	WVSHL118	GURUDWARA S/STN	Mixed	AMR	2.41	0.59	1.79	1.54%	100%
1.96	33 KV WDDC VISHAL	WVSHL130	LIG RAJORI GARDEN	Residential	AMR	1.96	0.49	1.46	0.38%	100%
2.44	33 KV WDDC VISHAL	WVSHL132	F BLOCK RAJORI GARDEN	Mixed	AMR	2.44	0.61	1.78	1.83%	100%
3.64	33 KV WDDC VISHAL	WVSHL133	A2 BANK QUATER RAJORI GARDEN	Mixed	AMR	3.64	0.00	3.61	0.93%	100%
2.60	220 KV NARAYANA	TDTRN101	11 KV ENERGY FROM GN BAZAR	Mixed	AMR	2.60	0.60	1.95	1.94%	100%
2.99	220 KV PAPANKALAN - 1 GRID	TDTPG103	PP-I	Mixed	AMR	2.99	0.71	2.20	2.78%	100%
1.91	220 KV PAPANKALAN - 1 GRID	TDTPG105	MANGLAPURI-2	Residential	AMR	1.91	0.00	1.87	2.06%	100%
2.68	220 KV PAPANKALAN - 1 GRID	TDTPG108	PP-II	Residential	AMR	2.68	0.00	2.64	1.42%	100%
2.62	220 KV PAPANKALAN - 1 GRID	TDTPG109	BENGALI COLONY	Residential	AMR	2.62	0.00	2.56	2.28%	100%
1.93	220 KV PAPANKALAN - 1 GRID	TDTPG110	NASIR PUR	Mixed	AMR	1.93	0.00	1.88	2.48%	100%
2.50	220 KV PAPANKALAN - 1 GRID	TDTPG111	PALAM VILLAGE	Mixed	AMR	2.50	0.00	2.45	1.93%	100%
0.77	220 KV PAPANKALAN - 1 GRID	TDTPG112	SEC-7	Residential	AMR	0.77	0.25	0.51	1.19%	100%

1175	PALAM
1176	PALAM
1177	PALAM
1178	PALAM
1179	PALAM
1180	PALAM
1181	PALAM
1182	PALAM
1183	PALAM
1184	PALAM
1185	PALAM
1186	PALAM
1187	PALAM
1188	PALAM
1189	PALAM
1190	PALAM
1191	PALAM
1192	PALAM
1193	PALAM
1194	PALAM
1195	PALAM
1196	PALAM
1197	PALAM
1198	PALAM
1199	PALAM
1200	PALAM
1201	PALAM
1202	PALAM
1203	PALAM
1204	PALAM
1205	PALAM
1206	PALAM
1207	PALAM
1208	PALAM
1209	PALAM
1210	PALAM
1211	PALAM
1212	PALAM
1213	PALAM
1214	PALAM
1215	PALAM
1216	PALAM
1217	PALAM
1218	PALAM
1219	PALAM
1220	PALAM
1221	PALAM
1222	PALAM
1223	PALAM
1224	PALAM
1225	PALAM
1226	PALAM

2.56	220 KV PAPAN KALAN - 1 GRID	TDTPG113	EVERGREEN	Residential	AMR	2.56	0.75	1.76	2.01%	100%
2.07	220 KV PAPAN KALAN - 1 GRID	TDTPG114	VINOD PURI	Residential	AMR	2.07	0.00	2.02	2.34%	100%
2.66	220 KV PAPAN KALAN - 1 GRID	TDTPG115	C-2,MAHAVEER ENCLAVE	Residential	AMR	2.66	0.00	2.61	1.87%	100%
1.78	66 KV BINDAPUR	WBNDP114	DABRI S/STN -2	Mixed	AMR	1.78	0.00	1.74	2.21%	100%
3.62	66 KV BINDAPUR	WBNDP115	DABRI S/STN -1	Mixed	AMR	3.62	0.00	3.58	1.20%	100%
2.20	66 KV G-2 PAPPANKALAN	WG2PN101	11 KV MAHAVIR ENCLAVE D3	Residential	AMR	2.20	0.00	2.17	1.44%	100%
3.30	66 KV G-2 PAPPANKALAN	WG2PN102	G-2 KAILASH PURI NO - 1	Residential	AMR	3.30	0.00	3.23	1.92%	100%
2.82	66 KV G-2 PAPPANKALAN	WG2PN103	11 KV DWARKA PURI	Mixed	AMR	2.82	0.00	2.75	2.33%	100%
2.66	66 KV G-2 PAPPANKALAN	WG2PN104	S.P.S. Sector-7 (RMU-1)	Mixed	AMR	2.66	0.61	2.01	1.64%	100%
2.69	66 KV G-2 PAPPANKALAN	WG2PN106	G-2 KAILASH PURI NO.-2	Residential	AMR	2.69	0.00	2.63	2.05%	100%
1.74	66 KV G-2 PAPPANKALAN	WG2PN107	D1 & D2 MAHAVIR ENCLAVE	Mixed	AMR	1.74	0.00	1.72	1.30%	100%
1.53	66 KV G-2 PAPPANKALAN	WG2PN108	11 KV DADA CHATRI MARG	Mixed	AMR	1.53	0.00	1.50	2.34%	100%
0.04	66 KV G-2 PAPPANKALAN	WG2PN109	LOCAL TRANSFORMER	Local Grid	AMR	0.04	0.00	0.04	0.48%	100%
3.19	66 KV G-2 PAPPANKALAN	WG2PN110	11 KV DDA OFFICE	Mixed	AMR	3.19	0.73	2.35	3.30%	100%
2.88	66 KV G-2 PAPPANKALAN	WG2PN111	CGHS Harshuk (RMU-2)	Residential	AMR	2.88	0.67	2.17	1.49%	100%
1.46	66 KV G-2 PAPPANKALAN	WG2PN112	11 KV VARDHMAN PLAZA	Mixed	AMR	1.46	0.42	0.98	3.99%	100%
2.42	66 KV G-2 PAPPANKALAN	WG2PN113	KUMUDI APPTS	Mixed	AMR	2.42	0.00	2.39	1.51%	100%
3.62	66 KV G-2 PAPPANKALAN	WG2PN117	11 KV O/G MCD SCHOOL NASEERPUR	Mixed	AMR	3.62	0.00	3.55	2.01%	100%
3.80	66 KV G-2 PAPPANKALAN	WG2PN118	11 KV O/G SADH NAGAR GALI NO-22	Residential	AMR	3.80	0.00	3.72	2.14%	100%
3.61	66 KV G-2 PAPPANKALAN	WG2PN119	11 KV O/G POCKET-10 NASEERPUR	Mixed	AMR	3.61	0.00	3.54	1.95%	100%
2.77	66 KV G-2 PAPPANKALAN	WG2PN120	11 KV O/G SADH NAGAR GALI NO-9	Mixed	AMR	2.77	0.00	2.73	1.28%	100%
2.89	66 KV G-2 PAPPANKALAN	WG2PN121	11 KV O/G MANDIR MARG	Residential	AMR	2.89	0.00	2.82	2.28%	100%
1.44	66 KV G-2 PAPPANKALAN	WG2PN122	11 KV O/G PURAN NAGAR	Residential	AMR	1.44	0.00	1.39	3.09%	100%
2.76	66 KV G-2 PAPPANKALAN	WG2PN123	PALAM CHOCK	Mixed	AMR	2.76	0.00	2.70	1.86%	100%
3.83	66 KV G-2 PAPPANKALAN	WG2PN124	KAILASH PURI EXTENSION	Residential	AMR	3.83	0.00	3.79	1.12%	100%
2.52	66 KV G-2 PAPPANKALAN	WG2PN125	MAHAVIR ENCLAVE GALI NO.2	Residential	AMR	2.52	0.00	2.46	2.46%	100%
1.65	66 KV G-2 PAPPANKALAN	WG2PN126	DURGA PARK GALI NO.4	Mixed	AMR	1.65	0.00	1.60	3.27%	100%
3.41	66 KV G-2 PAPPANKALAN	WG2PN127	PURAN JAIL DAR FEEDER	Mixed	AMR	3.41	0.00	3.33	2.20%	100%
1.64	66 KV G-2 PAPPANKALAN	WG2PN128	PURAN JAILDAR NO. 2	Residential	AMR	1.64	0.00	1.61	1.76%	100%
2.66	66 KV G-2 PAPPANKALAN	WG2PN129	DABRI ZONAL OFFICE	Mixed	AMR	2.66	0.76	1.84	2.05%	100%
1.83	66 KV G-2 PAPPANKALAN	WG2PN130	COMMAND TANK, SEC-7, DWARKA	Commercial	AMR	1.83	0.54	1.24	2.60%	100%
2.08	66 KV G-2 PAPPANKALAN	WG2PN131	A BLOCK DASHRATH PURI	Mixed	AMR	2.08	0.00	2.05	1.30%	100%
1.95	66 KV G-2 PAPPANKALAN	WG2PN617	NISHKAM APPTT.	Mixed	AMR	1.95	0.00	1.91	1.86%	100%
2.35	66 KV G-2 PAPPANKALAN	WG2PN621	D1 & D2 MAHAVIR ENCLAVE NO - 2	Mixed	AMR	2.35	0.00	2.31	1.95%	100%
2.01	66 KV G-4 PAPPANKALAN	WG4PN103	11 KV O/G MANISH PLAZA SEC 23	Residential	AMR	2.01	0.61	1.34	2.85%	100%
2.85	66 KV G-6 PAPPANKALA	WG6PN102	Sec-23, POLICE STATION	Residential	AMR	2.85	0.67	2.13	1.84%	100%
1.40	66 KV G-6 PAPPANKALA	WG6PN103	SECTOR 20 COMMAND TANK	Mixed	AMR	1.40	0.42	0.94	3.32%	100%
0.03	66 KV G-6 PAPPANKALA	WG6PN106	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	0.39%	100%
3.10	66 KV G-6 PAPPANKALA	WG6PN107	SECTOR-8 DP	Residential	AMR	3.10	0.71	2.32	2.13%	100%
3.95	66 KV G-6 PAPPANKALA	WG6PN111	Sec-9 Pocket-1	Mixed	AMR	3.95	0.94	2.90	2.66%	100%
2.45	66 KV G-6 PAPPANKALA	WG6PN112	SEC-23, EPFO	Mixed	AMR	2.45	0.69	1.69	2.85%	100%
3.35	66 KV G-6 PAPPANKALA	WG6PN115	N.B.E.SECTOR -9	Commercial	AMR	3.35	0.79	2.49	2.11%	100%
1.91	66 KV G-6 PAPPANKALA	WG6PN118	Raj Nagar	Residential	AMR	1.91	0.00	1.87	2.39%	100%
0.86	66 KV G-6 PAPPANKALA	WG6PN119	ARMY QTRS SEC-21 (PANEL NO - 4C)	Commercial	AMR	0.86	0.28	0.54	4.67%	100%
1.46	66 KV G-6 PAPPANKALA	WG6PN120	DDA FALT SEC-23 (PANEL NO - 3C)	Residential	AMR	1.46	0.46	0.96	3.52%	100%
1.29	66 KV G-6 PAPPANKALA	WG6PN123	AWHO-SEC-22	Residential	AMR	1.29	0.39	0.88	1.25%	100%
3.29	66 KV G-6 PAPPANKALA	WG6PN124	CROWN APPTS	Residential	AMR	3.29	0.77	2.45	1.95%	100%
2.25	66 KV G-6 PAPPANKALA	WG6PN126	O/G RANJEET VIHAR SECTOR 23 DWK	Residential	AMR	2.25	0.65	1.54	2.59%	100%
1.45	66 KV G-6 PAPPANKALA	WG6PN127	PARADISE APPARMENT SEC-9	Residential	AMR	1.45	0.45	0.98	1.46%	100%
3.08	66 KV G-6 PAPPANKALA	WG6PN129	G- BLOCK RAJ NAGAR	Residential	AMR	3.08	0.00	3.02	2.02%	100%
0.01	66 KV G-6 PAPPANKALA	WG6PN131	11 KV TAJ HOTEL, SECTOR-21	Mixed	AMR	0.01	0.00	0.01	0.16%	100%
3.49	66 KV G-6 PAPPANKALA	WG6PN132	11 O/G INTELLIGENC BUREAU	Residential	AMR	3.49	0.00	3.43	1.55%	100%

1227	PALAM		1.87	66 KV G-6 PAPPANKALA	WG6PN133	11 O/G BHATTWAL	Residential	AMR	1.87	0.00	1.82	2.18%		100%	
1228	PALAM		4.07	66 KV G-7 DWARKA	WG7PN106	HARIJAN BASTI EXTN (PLM)	Mixed	AMR	4.07	0.00	3.96	2.76%		100%	
1229	PALAM		1.85	66 KV G-7 DWARKA	WG7PN107	S/STN-2 SEC-7 (PLM)	Residential	AMR	1.85	0.00	1.82	1.99%		100%	
1230	PALAM		1.15	66 KV G-7 DWARKA	WG7PN108	DTC DEPOT (PLM)	Commercial	AMR	1.15	0.38	0.76	1.17%		100%	
1231	PALAM		3.33	66 KV G-7 DWARKA	WG7PN109	MAHADEVA	Mixed	AMR	3.33	0.00	3.25	2.44%		100%	
1232	PALAM		1.25	66 KV G-7 DWARKA	WG7PN110	SEC-8, STN-5	Residential	AMR	1.25	0.00	1.23	1.90%		100%	
1233	PALAM		1.61	66 KV G-7 DWARKA	WG7PN112	INDIAN HOTEL	Commercial	AMR	1.61	0.49	1.08	2.50%		100%	
1234	PALAM		2.04	66 KV G-7 DWARKA	WG7PN114	HARIJAN BASTI GADDEWALE (PLM)	Mixed	AMR	2.04	0.61	1.38	2.75%		100%	
1235	PALAM		2.74	66 KV G-7 DWARKA	WG7PN115	STORE SEC-8 (PLM)	Residential	AMR	2.74	0.00	2.67	2.59%		100%	
1236	PALAM		2.10	66 KV G-7 DWARKA	WG7PN116	SPG SEC-8 (PLM)	Residential	AMR	2.10	0.00	2.05	2.37%		100%	
1237	PALAM		0.01	66 KV G-7 DWARKA	WG7PN117	LOCAL TRANSFORMER	Local Grid	AMR	0.01	0.00	0.01	0.18%		100%	
1238	PALAM		0.23	66 KV G-7 DWARKA	WG7PN118	POLICE QUARTERS, SEC-9 DWK	Residential	AMR	0.23	0.08	0.15	2.40%		100%	
1239	PALAM		0.63	66 KV G-7 DWARKA	WG7PN119	INTELLIGENCE BUREAU, SEC-9, DWARKA	Commercial	AMR	0.63	0.61	0.00	3.93%		100%	
1240	PALAM		0.30	66 KV G-7 DWARKA	WG7PN121	S/S No-1 MARBLE MKT SERVICE CENTER SEC-20	Commercial	AMR	0.30	0.08	0.21	1.68%		100%	
1241	PALAM		3.16	66 KV G-7 DWARKA	WG7PN122	11 KV SPG COMPLEX SEC-21, No-1	Mixed	AMR	3.16	0.66	2.43	2.07%		100%	
1242	PALAM		0.57	66 KV G-7 DWARKA	WG7PN123	11 KV SPG COMPLEX SEC-21, No-2	Mixed	AMR	0.57	0.00	0.57	0.64%		100%	
1243	PALAM		3.79	66 KV G-7 DWARKA	WG7PN124	SHASTRI MARG RAJ NAGAR	Residential	AMR	3.79	0.00	3.70	2.34%		100%	
1244	PALAM		4.73	66 KV G-7 DWARKA	WG7PN127	MANGLA PURI NO.1 VIA PALAM VILLAGE	Residential	AMR	4.73	0.00	4.61	2.49%		100%	
1245	PALAM		4.43	66 KV G-7 DWARKA	WG7PN128	MANGLA PURI NO.2 VIA RAMPHAL CHOWK	Residential	AMR	4.43	0.00	4.33	2.28%		100%	
1246	PALAM		2.14	66 KV G-7 DWARKA	WG7PN129	SARGODHA VIHAR SECTOR 7 DWK	Mixed	AMR	2.14	0.63	1.46	2.50%		100%	
1247	PALAM		1.29	66 KV G-7 DWARKA	WG7PN130	SPG COMPLEX SEC-21 NO-3	Mixed	AMR	1.29	0.42	0.84	1.91%		100%	
1248	PALAM		0.14	66 KV G-7 DWARKA	WG7PN132	CRPF MAHILA BATTALION	Mixed	AMR	0.14	0.04	0.10	2.02%		100%	
1249	PALAM		0.70	66 KV G-7 DWARKA	WG7PN605	SPG COMPLEX SEC 21, NO.4	Mixed	AMR	0.70	0.18	0.51	1.84%		100%	
1250	PALAM		3.49	66 KV PANKHA ROAD	WPNRD104	SITA PURI D BLOCK	Mixed	AMR	3.49	0.00	3.43	1.88%		100%	
1251	PALAM		1.95	66 KV PANKHA ROAD	WPNRD108	SITA PURI HARIJAN BASTI	Mixed	AMR	1.95	0.63	1.28	1.82%		100%	
1252	PALAM		2.83	66 KV PANKHA ROAD	WPNRD113	RAGHU NAGAR OLD	Mixed	AMR	2.83	0.00	2.78	1.89%		100%	
1253	PALAM		3.60	66 KV PANKHA ROAD	WPNRD117	RAGHU NAGAR NEW	Mixed	AMR	3.60	0.00	3.50	2.63%		100%	
1254	PALAM		2.83	66 KV PANKHA ROAD	WPNRD628	A-BLOCK SITA PURI	Mixed	AMR	2.83	0.00	2.76	2.33%		100%	
1255	PALAM		3.32	66 KV SAGARPUR	WSGRP103	SAGARPUR MAIN	Residential	AMR	3.32	0.00	3.22	3.08%		100%	
1256	PALAM		3.90	66 KV SAGARPUR	WSGRP105	I BLOCK SAGARPUR	Mixed	AMR	3.90	0.00	3.77	3.17%		100%	
1257	PALAM		3.10	66 KV SAGARPUR	WSGRP107	F-BLOCK SAGARPUR + RAGHU NAGAR NEW NO. 2	Mixed	AMR	3.10	0.00	3.06	1.27%		100%	
1258	PALAM		4.51	66 KV SAGARPUR	WSGRP112	MADANPURI HANS PARK	Residential	AMR	4.51	1.08	3.34	1.90%		100%	
1259	PALAM		4.39	66 KV SAGARPUR	WSGRP129	GEETANJALI PARK + MEHTAWALA	Residential	AMR	4.39	0.00	4.27	2.80%		100%	
1260	Mohan Garden	651.37	95.40	3.51	66 KV DELHI JAL BOARD	WDJBD104	RANA Enc + RAMA PARK	Residential	AMR	3.51	0.16	3.24	3.21%		100%
1261	Mohan Garden			4.75	66 KV DELHI JAL BOARD	WDJBD122	11 KV O/G GANDHI CHOWK	Mixed	AMR	4.75	0.42	4.29	0.93%		100%
1262	Mohan Garden			2.13	66 KV G-1 PAPPANKALAN	WG1PN111	BHAGWATI GARDEN	Residential	AMR	2.13	0.00	2.12	0.48%		100%
1263	Mohan Garden			1.76	66 KV G-1 PAPPANKALAN	WG1PN112	L EXT MOHAN GARDEEN	Residential	AMR	1.76	0.00	1.71	2.82%		100%
1264	Mohan Garden			2.58	66 KV G-1 PAPPANKALAN	WG1PN113	RAMA PARK	Residential	AMR	2.58	0.00	2.50	3.12%		100%
1265	Mohan Garden			3.26	66 KV G-1 PAPPANKALAN	WG1PN114	SEWAK PARK	Mixed	AMR	3.26	0.00	3.23	0.95%		100%
1266	Mohan Garden			1.48	66 KV G-1 PAPPANKALAN	WG1PN116	11KV WINTER HILL SOCIETY DWARKA MOR NO-1	Residential	AMR	1.48	0.00	1.44	2.80%		100%
1267	Mohan Garden			2.18	66 KV G-1 PAPPANKALAN	WG1PN119	11 KV O/G PPK-2	Residential	AMR	2.18	0.00	2.14	1.71%		100%
1268	Mohan Garden			2.21	66 KV G-1 PAPPANKALAN	WG1PN120	MOHAN GARDEN	Residential	AMR	2.21	0.00	2.19	0.75%		100%
1269	Mohan Garden			4.14	66 KV G-1 PAPPANKALAN	WG1PN121	DMRC SHOPPING COMPLEX	Mixed	AMR	4.14	0.00	4.06	2.07%		100%
1270	Mohan Garden			3.18	66 KV G-1 PAPPANKALAN	WG1PN122	LAXMAN PURI(MGM)	Residential	AMR	3.18	0.00	3.14	1.31%		100%
1271	Mohan Garden			2.00	66 KV G-1 PAPPANKALAN	WG1PN128	11KV WINTER HILL SOCIETY DWARKA MOR NO-2	Residential	AMR	2.00	0.52	1.45	1.56%		100%

1272	Mohan Garden
1273	Mohan Garden
1274	Mohan Garden
1275	Mohan Garden
1276	Mohan Garden
1277	Mohan Garden
1278	Mohan Garden
1279	Mohan Garden
1280	Mohan Garden
1281	Mohan Garden
1282	Mohan Garden
1283	Mohan Garden
1284	Mohan Garden
1285	Mohan Garden
1286	Mohan Garden
1287	Mohan Garden
1288	Mohan Garden
1289	Mohan Garden
1290	Mohan Garden
1291	Mohan Garden
1292	Mohan Garden
1293	Mohan Garden
1294	Mohan Garden
1295	Mohan Garden
1296	Mohan Garden
1297	NANGLOI
1298	NANGLOI
1299	NANGLOI
1300	NANGLOI
1301	NANGLOI
1302	NANGLOI
1303	NANGLOI
1304	NANGLOI
1305	NANGLOI
1306	NANGLOI
1307	NANGLOI
1308	NANGLOI
1309	NANGLOI
1310	NANGLOI
1311	NANGLOI
1312	NANGLOI
1313	NANGLOI

203.78

0.29	66 KV G-1 PAPPANKALAN	WG1PN608	VIPIN GARDEN GALI NO. 38	Mixed	AMR	0.29	0.00	0.28	2.87%		100%
2.83	66 KV G-1 PAPPANKALAN	WG1PN609	P BLK MOHAN GARDEN	Mixed	AMR	2.83	0.00	2.82	0.30%		100%
1.70	66 KV G-1 PAPPANKALAN	WG1PN610	ZAILDAR ENCLAVE	Mixed	AMR	1.70	0.00	1.69	0.37%		100%
1.14	66 KV G-1 PAPPANKALAN	WG1PN611	C BLK SEWAK PARK	Mixed	AMR	1.14	0.00	1.11	2.11%		100%
2.92	66 KV HASTSAL GRID	WHAST107	JHANDA CHOWK OM VIHAR PH-5	Mixed	AMR	2.92	0.00	2.89	1.22%		100%
3.30	66 KV HASTSAL GRID	WHAST112	OM VIHAR PH-5 HOLY INTERNATIONAL SCHOOL	Residential	AMR	3.30	0.00	3.27	0.97%		100%
1.96	66 KV HASTSAL GRID	WHAST119	A-BLK MANDIRWALA VKP	Residential	AMR	1.96	0.00	1.94	0.87%		100%
2.97	66 KV HASTSAL GRID	WHAST120	SCHOOL WALA VIKASKUNJ	Mixed	AMR	2.97	0.00	2.94	1.00%		100%
2.90	66 KV HASTSAL GRID	WHAST121	RAKSHA ENCLAVE (JAI SINGH WALA)	Residential	AMR	2.90	0.00	2.85	1.80%		100%
2.40	66 KV HASTSAL GRID	WHAST124	MINI STAND UTTAM NAGAR	Residential	AMR	2.40	0.00	2.38	1.00%		100%
4.75	66 KV HASTSAL GRID	WHAST125	NAWADA USERWALA	Mixed	AMR	4.75	0.00	4.67	1.51%		100%
2.77	66 KV HASTSAL GRID	WHAST126	11KV O/G RAHUL CHOCK MOHAN GARDEN	Residential	AMR	2.77	0.00	2.71	2.11%		100%
2.16	66 KV HASTSAL GRID	WHAST130	OM VIHAR PH-2	Residential	AMR	2.16	0.00	2.13	1.02%		100%
1.43	66 KV G-5 PPKLN(MATIYALA)	WMTLA112	NSIT-2+D K Road	Residential	AMR	1.43	0.00	1.40	1.60%		100%
3.27	66 KV G-5 PPKLN(MATIYALA)	WMTLA135	11 KV O/G LAXMI VIHAR	Residential	AMR	3.27	0.00	3.23	1.07%		100%
2.06	66 KV G-5 PPKLN(MATIYALA)	WMTLA139	11 KV CB : NAWADA	Residential	AMR	2.06	0.00	2.02	2.31%		100%
2.72	66 KV G-5 PPKLN(MATIYALA)	WMTLA141	NAWADA HOUSING COMPLEX	Residential	AMR	2.72	0.00	2.71	0.59%		100%
3.14	66 KV G-5 PPKLN(MATIYALA)	WMTLA143	PRATAP ENCLAVE	Residential	AMR	3.14	0.00	3.08	1.95%		100%
3.78	66 KV G-5 PPKLN(MATIYALA)	WMTLA144	O/G RMU NO.1 (BIJLI GHAR BHAR)	Residential	AMR	3.78	0.00	3.72	1.77%		100%
2.30	66 KV G-5 PPKLN(MATIYALA)	WMTLA146	RMU NO.2 (BIJLI GHAR KE BHAR)	Residential	AMR	2.30	0.00	2.28	1.12%		100%
2.71	66 KV NILOTHI	WNILO116	11 KV UGR	Residential	AMR	2.71	0.00	2.67	1.14%		100%
2.14	66 KV NILOTHI	WNILO126	DEFENCE ENCLAVE	Residential	AMR	2.14	0.00	2.08	2.81%		100%
2.58	66 KV NILOTHI	WNILO127	11 KV TIRANGA CHOWK	Residential	AMR	2.58	0.00	2.52	2.54%		100%
2.81	66 KV PAPPANKALAN - 2	WPKL2108	Delhi Judicial-2+ Sainik Enclave	Residential	AMR	2.81	0.00	2.76	1.71%		100%
1.19	66 KV PAPPANKALAN - 2	WPKL2109	KUMAR DAIRY RAMA PARK	Residential	AMR	1.19	0.00	1.16	1.96%		100%
4.21	66 KV BODHELLA-II	WBDL2103	GRAMSABHA NILOTHI	Residential	AMR	4.21	0.00	4.14	1.81%		100%
2.69	66 KV NILOTHI	WNILO105	11 KV RAJEEV RATAN NO.2	Residential	AMR	2.69	0.00	2.61	3.04%		100%
4.02	66 KV NILOTHI	WNILO106	RAJEEV RATAN NO.1	Residential	AMR	4.02	0.00	3.92	2.69%		100%
4.04	66 KV NILOTHI	WNILO107	T.P.KOTLA	Residential	AMR	4.04	1.41	2.55	1.86%		100%
3.36	66 KV NILOTHI	WNILO108	AMBEDKAR CHOWK	Residential	AMR	3.36	0.00	3.30	1.89%		100%
0.04	66 KV NILOTHI	WNILO110	LOCAL TRANSFORMER	Local Grid	AMR	0.04	0.00	0.04	0.48%		100%
2.31	66 KV NILOTHI	WNILO111	BAPROLA OLD (O/H)	Residential	AMR	2.31	0.00	2.24	2.98%		100%
3.81	66 KV NILOTHI	WNILO112	RAJEEV RATAN NO.3	Residential	AMR	3.81	0.00	3.70	2.98%		100%
3.76	66 KV NILOTHI	WNILO113	BAPROLA NO.2 NEW (U/G)	Residential	AMR	3.76	0.00	3.64	3.13%		100%
3.72	66 KV NILOTHI	WNILO117	LAXMI PARK NO-2	Residential	AMR	3.72	0.00	3.65	1.92%		100%
0.13	66 KV NILOTHI	WNILO118	DJB SPS NILOTHI NO-1	Mixed	AMR	0.13	0.00	0.13	1.93%		100%
3.40	66 KV NILOTHI	WNILO124	ADHYAPAK NAGAR	Residential	AMR	3.40	0.00	3.29	3.22%		100%
3.82	66 KV NILOTHI	WNILO128	DJB STP NILOTHI NO-2	Mixed	AMR	3.82	1.27	2.42	3.28%		100%
2.58	66 KV NILOTHI	WNILO136	SANT HARIDASS SCHOOL D.P	Mixed	AMR	2.58	0.00	2.53	1.97%		100%
1.93	66 KV NILOTHI	WNILO138	11 KV AMANPURI HVDS	Mixed	AMR	1.93	0.00	1.89	1.97%		100%
2.82	66 KV NILOTHI	WNILO139	DEEPAK VIHAR	Mixed	AMR	2.82	0.00	2.79	1.26%		100%
4.16	66 KV NANGLOI	WNNGLO107	11 KV O/G JWALA PURI CAMP-4	Residential	AMR	4.16	0.00	4.03	3.13%		100%

1314	NANGLOI
1315	NANGLOI
1316	NANGLOI
1317	NANGLOI
1318	NANGLOI
1319	NANGLOI
1320	NANGLOI
1321	NANGLOI
1322	NANGLOI
1323	NANGLOI
1324	NANGLOI
1325	NANGLOI
1326	NANGLOI
1327	NANGLOI
1328	NANGLOI
1329	NANGLOI
1330	NANGLOI
1331	NANGLOI
1332	NANGLOI
1333	NANGLOI
1334	NANGLOI
1335	NANGLOI
1336	NANGLOI
1337	NANGLOI
1338	NANGLOI
1339	NANGLOI
1340	NANGLOI
1341	NANGLOI
1342	NANGLOI
1343	NANGLOI
1344	NANGLOI
1345	NANGLOI
1346	NANGLOI
1347	NANGLOI
1348	NANGLOI
1349	NANGLOI
1350	NANGLOI
1351	NANGLOI
1352	NANGLOI
1353	NANGLOI
1354	NANGLOI
1355	NANGLOI
1356	NANGLOI
1357	NANGLOI
1358	NANGLOI
1359	NANGLOI
1360	NANGLOI
1361	NANGLOI
1362	NANGLOI
1363	NANGLOI
1364	NANGLOI
1365	NANGLOI
1366	NANGLOI
1367	NANGLOI
1368	NANGLOI

2.86	66 KV NANGLOI	WNNGL108	LAXMI PARK	Residential	AMR	2.86	0.00	2.77	3.27%	100%
2.03	66 KV NANGLOI	WNNGL109	DSIDC	Industrial	AMR	2.03	0.00	1.99	2.12%	100%
2.18	66 KV NANGLOI	WNNGL110	HINDUSTAN SOCIETY	Residential	AMR	2.18	0.90	1.25	1.32%	100%
3.21	66 KV NANGLOI	WNNGL112	O/G (U/G) NANGLOI-2	Residential	AMR	3.21	1.24	1.90	2.24%	100%
2.74	66 KV NANGLOI	WNNGL113	UDYOG NAGAR-2+RAIL NEER PLANT	Industrial	AMR	2.74	1.00	1.69	1.93%	100%
2.47	66 KV NANGLOI	WNNGL114	SHANKAR GARDEN	Residential	AMR	2.47	1.09	1.35	1.25%	100%
2.83	66 KV NANGLOI	WNNGL115	JAT MOHALLA NANGLOI	Residential	AMR	2.83	0.00	2.79	1.33%	100%
2.79	66 KV NANGLOI	WNNGL116	PVC MARKET JWALA PURI	Residential	AMR	2.79	0.00	2.69	3.61%	100%
2.24	66 KV NANGLOI	WNNGL120	NANGLOI-H	Residential	AMR	2.24	0.00	2.18	2.67%	100%
4.16	66 KV NANGLOI	WNNGL122	UDYOG NAGAR -1 (11 KV)	Industrial	AMR	4.16	0.00	4.05	2.61%	100%
0.03	66 KV NANGLOI	WNNGL125	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	0.41%	100%
1.85	66 KV NANGLOI WATER WORKS	WNNWW103	RAJEEV RATAN-2	Residential	AMR	1.85	0.00	1.81	2.22%	100%
1.87	66 KV NANGLOI WATER WORKS	WNNWW108	NILOTHI, SW TRMT. PLANT	Commercial	AMR	1.87	0.87	0.94	3.15%	100%
1.75	66 KV NANGLOI WATER WORKS	WNNWW109	SHIV RAM PARK	Residential	AMR	1.75	0.00	1.73	1.39%	100%
3.62	66 KV NANGLOI WATER WORKS	WNNWW112	NILOTHI WATER TANK(SAINI MOHALLA)	Residential	AMR	3.62	0.00	3.52	2.69%	100%
4.41	66 KV NANGLOI WATER WORKS	WNNWW124	HARIJAN BASTI	Residential	AMR	4.41	0.00	4.27	3.23%	100%
3.84	66 KV NANGLOI WATER WORKS	WNNWW125	RAJEEV RATAN -1	Residential	AMR	3.84	0.00	3.75	2.29%	100%
3.24	33 KV PASCHIM PURI	WPSCP104	SUNDER VIHAR(GH-10)	Residential	AMR	3.24	0.00	3.17	2.17%	100%
3.23	33 KV PASCHIM PURI	WPSCP108	UDYOG NAGAR NO-1	Residential	AMR	3.23	0.00	3.18	1.74%	100%
1.92	33 KV PASCHIM PURI	WPSCP109	PEERA GARHI SUB STATION 3	Mixed	AMR	1.92	0.00	1.89	1.21%	100%
2.00	33 KV PASCHIM PURI	WPSCP123	SUB STN.7 PEERA GARHI	Mixed	AMR	2.00	0.00	1.95	2.23%	100%
1.89	33 KV PASCHIM PURI	WPSCP124	11 KV RADDISSION HOTEL	Commercial	AMR	1.89	0.89	0.96	1.97%	100%
0.66	33 KV PASCHIM PURI	WPSCP125	11 KV O/G MTNL NO -2	Mixed	AMR	0.66	0.00	0.66	1.37%	100%
0.02	66 KV PASCHIM VIHAR	WPSCV108	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.23%	100%
1.01	66 KV PASCHIM VIHAR	WPSCV109	LIC COLONY	Residential	AMR	1.01	0.00	0.97	3.67%	100%
2.02	66 KV PASCHIM VIHAR	WPSCV112	1312 LIG FLATS S/STN-3+SEWAGE TREATMENT PLANT	Mixed	AMR	2.02	0.91	1.06	2.58%	100%
0.96	66 KV PASCHIM VIHAR	WPSCV114	688 LIG FLATS S/STN-1	Residential	AMR	0.96	0.00	0.93	3.41%	100%
4.16	66 KV PASCHIM VIHAR	WPSCV115	NILOTHI	Residential	AMR	4.16	1.48	2.54	3.39%	100%
3.15	66 KV PASCHIM VIHAR	WPSCV116	1200 MIG FLATS S/STN-3	Residential	AMR	3.15	0.00	3.10	1.65%	100%
5.42	66 KV PASCHIM VIHAR	WPSCV117	HANUMAN MANDIR	Residential	AMR	5.42	0.00	5.25	3.27%	100%
2.71	66 KV PASCHIM VIHAR	WPSCV118	NILOTHI STP (SHIV VIHAR)	Residential	AMR	2.71	0.00	2.62	3.29%	100%
2.34	66 KV PASCHIM VIHAR	WPSCV119	1140 SFS S/STN-1	Residential	AMR	2.34	0.00	2.31	1.34%	100%
1.08	66 KV PASCHIM VIHAR	WPSCV120	656 MIG FLATS S/STN-1	Residential	AMR	1.08	0.50	0.56	1.58%	100%
3.04	66 KV PASCHIM VIHAR	WPSCV126	MEERA BAGH	Residential	AMR	3.04	1.19	1.79	2.17%	100%
4.14	66 KV PASCHIM VIHAR	WPSCV127	E BLK NIHAL VIHAR	Residential	AMR	4.14	0.00	4.04	2.47%	100%
2.35	66 KV PASCHIM VIHAR	WPSCV128	NIHAL VIHAR	Residential	AMR	2.35	0.00	2.28	3.13%	100%
3.25	66 KV PASCHIM VIHAR	WPSCV129	11 KV O/G CHANDER VIHAR	Residential	AMR	3.25	0.00	3.18	2.05%	100%
3.36	66 KV PASCHIM VIHAR	WPSCV130	RADISSON HOTEL + A BLK NIHAL VIHAR	Commercial	AMR	3.36	0.00	3.31	1.37%	100%
4.19	66 KV PASCHIM VIHAR	WPSCV131	UDAY VIHAR	Residential	AMR	4.19	0.00	4.08	2.56%	100%
4.74	66 KV PASCHIM VIHAR	WPSCV132	F & S BLOCK NIHAL VIHAR	Residential	AMR	4.74	0.00	4.61	2.71%	100%
1.00	66 KV PASCHIM VIHAR	WPSCV133	GH -14	Residential	AMR	1.00	0.00	0.99	1.10%	100%
0.40	66 KV PASCHIM VIHAR	WPSCV134	SUNDER VIHAR	Residential	AMR	0.40	0.00	0.40	0.88%	100%
2.80	66 KV PASCHIM VIHAR	WPSCV135	AMBICA VIHAR	Residential	AMR	2.80	0.00	2.72	3.00%	100%
4.86	66 KV PASCHIM VIHAR	WPSCV136	SHIV RAM PARK	Residential	AMR	4.86	0.00	4.71	3.07%	100%
0.49	66 KV PASCHIM VIHAR	WPSCV137	SEWAGE TREATMENT PLANT SAIYAD VILLAGE DJB	Commercial	AMR	0.49	0.13	0.36	0.06%	100%
0.02	33 KV UDHYOG NAGAR	WUDNR102	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.20%	100%
1.97	33 KV UDHYOG NAGAR	WUDNR103	DSIDC, F-BLOCK	Industrial	AMR	1.97	0.00	1.92	2.81%	100%
2.82	33 KV UDHYOG NAGAR	WUDNR104	UDHYOG NGR S/STN NO. III OLD	Industrial	AMR	2.82	1.07	1.69	2.20%	100%
4.14	33 KV UDHYOG NAGAR	WUDNR105	UDHYOG NGR S/STN NO. I	Industrial	AMR	4.14	1.48	2.53	3.00%	100%
3.10	33 KV UDHYOG NAGAR	WUDNR106	UDHYOG NGR S/STN NO. IV OLD	Industrial	AMR	3.10	1.08	1.89	4.02%	100%
2.34	33 KV UDHYOG NAGAR	WUDNR107	MIAWALI NAGAR S/STN	Residential	AMR	2.34	0.00	2.29	1.77%	100%
2.28	33 KV UDHYOG NAGAR	WUDNR108	11 KV O/G UDYOG NAGAR S/STN NO-2	Industrial	AMR	2.28	0.00	2.20	3.24%	100%
1.94	33 KV UDHYOG NAGAR	WUDNR109	UDYOG NAGAR S/SSTN-3 NEW	Industrial	AMR	1.94	0.86	1.03	2.09%	100%
3.19	33 KV UDHYOG NAGAR	WUDNR110	11 KV H- BLOCK DSIDC	Industrial	AMR	3.19	1.18	1.89	3.71%	100%
2.77	33 KV UDHYOG NAGAR	WUDNR113	UDYOG NAGAR S/STN NO-4 NEW	Industrial	AMR	2.77	1.02	1.69	2.39%	100%

1369	NANGLOI
1370	NANGLOI
1371	NANGLOI
1372	NANGLOI
1373	PUNJABI BAGH
1374	PUNJABI BAGH
1375	PUNJABI BAGH
1376	PUNJABI BAGH
1377	PUNJABI BAGH
1378	PUNJABI BAGH
1379	PUNJABI BAGH
1380	PUNJABI BAGH
1381	PUNJABI BAGH
1382	PUNJABI BAGH
1383	PUNJABI BAGH
1384	PUNJABI BAGH
1385	PUNJABI BAGH
1386	PUNJABI BAGH
1387	PUNJABI BAGH
1388	PUNJABI BAGH
1389	PUNJABI BAGH
1390	PUNJABI BAGH
1391	PUNJABI BAGH
1392	PUNJABI BAGH
1393	PUNJABI BAGH
1394	PUNJABI BAGH
1395	PUNJABI BAGH
1396	PUNJABI BAGH
1397	PUNJABI BAGH
1398	PUNJABI BAGH
1399	PUNJABI BAGH
1400	PUNJABI BAGH
1401	PUNJABI BAGH
1402	PUNJABI BAGH
1403	PUNJABI BAGH
1404	PUNJABI BAGH

139.88

4.24	33 KV UDHYOG NAGAR	WUDNR116	CETP DSIDC	Mixed	AMR	4.24	0.00	4.11	3.20%		100%
4.64	33 KV UDHYOG NAGAR	WUDNR117	11 KV O/G D-8 UDHYOG NAGAR+S/STN NO-5	Industrial	AMR	4.64	1.76	2.75	2.82%		100%
3.26	33 KV UDHYOG NAGAR	WUDNR120	SSTN - 5 VIA K-25	Industrial	AMR	3.26	1.25	1.91	3.26%		100%
0.92	33 KV UDHYOG NAGAR	WUDNR121	CEPT PLANT	Public Utilities	AMR	0.92	0.27	0.64	1.48%		100%
1.15	66 KV Rohtak Road	150189261	DLF Tower	Commercial	AMR	1.15	1.14	0.00	0.37%		100%
6.38	66 KV Rohtak Road	151710132	DLF	Commercial	AMR	6.38	6.36	0.00	0.37%		100%
2.78	66 KV Rohtak Road	NRHTK101	AFO Office	Mixed	AMR	2.78	0.31	2.45	0.92%		100%
1.26	66 KV Rohtak Road	NRHTK102	Transport Center	Mixed	AMR	1.26	0.11	1.15	0.90%		100%
2.76	66 KV Rohtak Road	NRHTK103	Bhagwan Das Nagar	Mixed	AMR	2.76	0.00	2.70	2.11%		100%
2.66	66 KV Rohtak Road	NRHTK104	A-BLK karampura	Mixed	AMR	2.66	0.00	2.60	2.19%		100%
2.81	66 KV Rohtak Road	NRHTK105	Punjabi BaghNo-2	Mixed	AMR	2.81	0.55	2.23	1.00%		100%
2.99	66 KV Rohtak Road	NRHTK106	Road No-43	Mixed	AMR	2.99	0.50	2.45	1.47%		100%
2.28	66 KV Rohtak Road	NRHTK107	Jaidav Park	Mixed	AMR	2.28	0.00	2.22	2.81%		100%
2.01	33 KV A-4 PASCHIM VIHAR	WA4PV102	C-Blk Extn. Madipur	Mixed	AMR	2.01	0.00	1.95	2.91%		100%
1.56	33 KV A-4 PASCHIM VIHAR	WA4PV103	O/G-3 SITE 7	Mixed	AMR	1.56	0.21	1.30	3.37%		100%
1.90	33 KV A-4 PASCHIM VIHAR	WA4PV104	O/G -4 A-4 CASH OFFICE	Mixed	AMR	1.90	0.00	1.87	1.71%		100%
3.36	33 KV A-4 PASCHIM VIHAR	WA4PV105	MULTAN NAGAR	Mixed	AMR	3.36	0.67	2.66	0.86%		100%
2.48	33 KV A-4 PASCHIM VIHAR	WA4PV106	O/G-6 COTTAGE ENCLAVE	Residential	AMR	2.48	0.00	2.41	2.88%		100%
0.02	33 KV A-4 PASCHIM VIHAR	WA4PV108	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.28%		100%
0.00	33 KV A-4 PASCHIM VIHAR	WA4PV109	LOCAL Transformer-2	Local Grid	AMR	0.00	0.00	0.00	0.00%		100%
3.88	33 KV A-4 PASCHIM VIHAR	WA4PV110	O/G-7 1212 JANTA QUARTERS	Mixed	AMR	3.88	0.00	3.84	1.06%		100%
2.03	33 KV A-4 PASCHIM VIHAR	WA4PV111	O/G -8 BG-3	Mixed	AMR	2.03	0.00	1.98	2.57%		100%
1.86	33 KV A-4 PASCHIM VIHAR	WA4PV112	O/G -9 PRAGTI APATT	Residential	AMR	1.86	0.00	1.82	2.17%		100%
1.86	33 KV A-4 PASCHIM VIHAR	WA4PV113	O/G-10 208 SFS	Mixed	AMR	1.86	0.37	1.46	1.90%		100%
3.07	33 KV A-4 PASCHIM VIHAR	WA4PV114	O/G -11 SWAYAM SIDHA	Residential	AMR	3.07	0.00	3.02	1.62%		100%
1.97	33 KV A-4 PASCHIM VIHAR	WA4PV115	O/G -12 ADARSH BHAWAN	Mixed	AMR	1.97	0.00	1.93	1.66%		100%
2.19	33 KV A-4 PASCHIM VIHAR	WA4PV119	ACTION CANCER HOSPITAL	Mixed	AMR	2.19	0.37	1.80	1.15%		100%
2.13	33 KV A-4 PASCHIM VIHAR	WA4PV120	11 KV PUNJABI BAGH POLICE STATION	Mixed	AMR	2.13	0.42	1.69	0.87%		100%
2.97	33 KV A-4 PASCHIM VIHAR	WA4PV121	C-BLK MADIPUR	Mixed	AMR	2.97	0.00	2.92	1.68%		100%
0.97	33 KV A-4 PASCHIM VIHAR	WA4PV122	CAPITAL MALL, PASCHIM VIHAR	Mixed	AMR	0.97	0.14	0.82	1.21%		100%
2.50	33 KV A-4 PASCHIM VIHAR	WA4PV123	HANSRAJ MODEL SCHOOL	Mixed	AMR	2.50	0.47	1.97	2.53%		100%
2.16	66 KV Guru Govind Singh Hospital	WGGSH116	CAPITAL MALL PASCHIM VIHAR	Commercial	AMR	2.16	0.00	2.11	1.95%		100%
3.21	33 KV MADI PUR	WM DPR101	BOOSTER PUMPING STATION (PJB)	Mixed	AMR	3.21	0.61	2.56	1.18%		100%
2.13	33 KV MADI PUR	WM DPR102	PALMOHAN APPT.	Mixed	AMR	2.13	0.32	1.78	1.50%		100%
2.49	33 KV MADI PUR	WM DPR103	PKT-2 PASCHIM PURI NEAR MOTHER DAIRY	Mixed	AMR	2.49	0.00	2.44	2.05%		100%
0.00	33 KV MADI PUR	WM DPR106	LOCAL TRANSFORMER	Local Grid	AMR	0.00	0.00	0.00	0.37%		100%

1405	PUNJABI BAGH
1406	PUNJABI BAGH
1407	PUNJABI BAGH
1408	PUNJABI BAGH
1409	PUNJABI BAGH
1410	PUNJABI BAGH
1411	PUNJABI BAGH
1412	PUNJABI BAGH
1413	PUNJABI BAGH
1414	PUNJABI BAGH
1415	PUNJABI BAGH
1416	PUNJABI BAGH
1417	PUNJABI BAGH
1418	PUNJABI BAGH
1419	PUNJABI BAGH
1420	PUNJABI BAGH
1421	PUNJABI BAGH
1422	PUNJABI BAGH
1423	PUNJABI BAGH
1424	PUNJABI BAGH
1425	PUNJABI BAGH
1426	PUNJABI BAGH
1427	PUNJABI BAGH
1428	PUNJABI BAGH
1429	PUNJABI BAGH
1430	PUNJABI BAGH
1431	PUNJABI BAGH
1432	PUNJABI BAGH
1433	PUNJABI BAGH
1434	PUNJABI BAGH
1435	Uttam Nagar
1436	Uttam Nagar
1437	Uttam Nagar
1438	Uttam Nagar
1439	Uttam Nagar
1440	Uttam Nagar
1441	Uttam Nagar
1442	Uttam Nagar

	3.44	33 KV MADI PUR	WM DPR107	240 MIG P/M	Residential	AMR	3.44	0.00	3.32	3.41%		100%
	3.83	33 KV MADI PUR	WM DPR108	1212 JANTA QTRS	Mixed	AMR	3.83	0.00	3.82	0.26%		100%
	2.74	33 KV MADI PUR	WM DPR109	PUNJABI BAGH COMPLAINT CENTER-1	Mixed	AMR	2.74	0.00	2.70	1.52%		100%
	1.48	33 KV MADI PUR	WM DPR111	ADARSH BHAWAN (PJB. EXTN.)	Mixed	AMR	1.48	0.00	1.44	2.42%		100%
	2.14	33 KV MADI PUR	WM DPR112	PASCHIM PURI EXTN.	Mixed	AMR	2.14	0.39	1.70	2.68%		100%
	3.42	33 KV MADI PUR	WM DPR113	SLUM TENAMENT (DSIDC SHED)	Mixed	AMR	3.42	0.00	3.29	3.72%		100%
	2.74	33 KV MADI PUR	WM DPR114	SHIV MANDIR	Mixed	AMR	2.74	0.54	2.16	1.39%		100%
	2.18	33 KV PASCHIM PURI	WPSCP102	PEERA GARI BOOSTER PUMP	Mixed	AMR	2.18	0.36	1.75	2.98%		100%
	1.60	33 KV PASCHIM PURI	WPSCP103	SHAKTI SOCITEY S/STN-4	Mixed	AMR	1.60	0.00	1.59	1.06%		100%
	1.74	33 KV PASCHIM PURI	WPSCP106	304, MIG MILANSAR APPT	Mixed	AMR	1.74	0.32	1.40	1.06%		100%
	0.04	33 KV PASCHIM PURI	WPSCP107	LOCAL TRANSFORMER	Local Grid	AMR	0.04	0.01	0.03	0.45%		100%
	2.31	33 KV PASCHIM PURI	WPSCP110	A-2 S/STN.	Mixed	AMR	2.31	0.00	2.29	0.63%		100%
	1.67	33 KV PASCHIM PURI	WPSCP111	G-BLK PUSHKAR ENCLAVE	Mixed	AMR	1.67	0.00	1.64	2.20%		100%
	2.38	33 KV PASCHIM PURI	WPSCP112	B-2 S/STN.	Mixed	AMR	2.38	0.00	2.34	1.48%		100%
	3.52	33 KV PASCHIM PURI	WPSCP113	O/G B-III S/STN. PASCHIM VIHAR	Mixed	AMR	3.52	0.00	3.46	1.71%		100%
	2.24	33 KV PASCHIM PURI	WPSCP114	A-3 DESPENSARY	Mixed	AMR	2.24	0.43	1.76	2.19%		100%
	2.78	33 KV PASCHIM PURI	WPSCP115	A-6 PASCHIM VIHAR	Mixed	AMR	2.78	0.47	2.27	1.25%		100%
	2.61	33 KV PASCHIM PURI	WPSCP121	DTC DEEPO	Mixed	AMR	2.61	0.50	2.04	2.61%		100%
	3.08	33 KV PASCHIM PURI	WPSCP122	A-2 COMMUNITY CENTRE	Mixed	AMR	3.08	0.59	2.43	1.94%		100%
	2.18	33 KV PASCHIM PURI	WPSCP337	RBI WATER TANK	Mixed	AMR	2.18	0.00	2.14	1.86%		100%
	2.80	33 KV PASCHIM PURI	WPSCP338	A-1 JANTA SS PACHIM VIHAR	Mixed	AMR	2.80	0.00	2.76	1.29%		100%
	3.32	66 KV PASCHIM VIHAR	WPSCV110	STATE BANK NAGAR	Mixed	AMR	3.32	0.63	2.62	1.81%		100%
	1.43	66 KV PASCHIM VIHAR	WPSCV113	Booster Pump Peeragarhi	Mixed	AMR	1.43	0.00	1.41	1.28%		100%
	0.92	33 KV SB MILL	WSBML103	CHARKHI GATE	Residential	AMR	0.92	0.16	0.75	1.18%		100%
	2.18	33 KV SB MILL	WSBML104	TULSIRAM DHARAM SHALA	Mixed	AMR	2.18	0.25	1.87	2.63%		100%
	3.46	33 KV SB MILL	WSBML105	CC KARAMPURA	Mixed	AMR	3.46	0.61	2.78	2.01%		100%
	2.28	33 KV SB MILL	WSBML106	J J COULSTER SHIVA ANAND SCHOOL	Residential	AMR	2.28	0.45	1.77	2.45%		100%
	0.01	33 KV SB MILL	WSBML115	LOCAL TRANSFORMER	Local Grid	AMR	0.01	0.00	0.01	0.16%		100%
	1.19	33 KV SB MILL	WSBML303	PLOT NO. - 8A, DIVISA PROJECT	Mixed	AMR	1.19	0.22	0.95	1.98%		100%
	2.33	33 KV WDDC VISHAL	WVSHL107	PJB BOOSTER	Mixed	AMR	2.33	0.46	1.81	2.24%		100%
86.20	1.89	66 KV BODELLA-1	WB DL1109	B BLK UTTAM NGR (U/G)	Mixed	AMR	1.89	0.00	1.84	2.66%		100%
	3.24	66 KV BINDAPUR	WBNDP104	S/STN NO 5	Mixed	AMR	3.24	0.00	3.16	2.55%		100%
	1.53	66 KV BINDAPUR	WBNDP105	R & S BLOCK CHANAKYA PLACE	Mixed	AMR	1.53	0.00	1.49	2.77%		100%
	1.43	66 KV BINDAPUR	WBNDP106	VISHWAS PARK	Mixed	AMR	1.43	0.00	1.38	3.55%		100%
	2.84	66 KV BINDAPUR	WBNDP108	O BLOCK UTTAM NAGR	Mixed	AMR	2.84	0.00	2.77	2.62%		100%
	2.41	66 KV BINDAPUR	WBNDP112	IJKL Uttam Nagar	Mixed	AMR	2.41	0.00	2.36	1.97%		100%
	1.60	66 KV BINDAPUR	WBNDP113	S/STN NO. 4	Mixed	AMR	1.60	0.00	1.58	1.20%		100%
	2.10	66 KV BINDAPUR	WBNDP116	BINDAPUR SCHOOLWALA	Mixed	AMR	2.10	0.00	2.06	1.86%		100%

1443	Uttam Nagar
1444	Uttam Nagar
1445	Uttam Nagar
1446	Uttam Nagar
1447	Uttam Nagar
1448	Uttam Nagar
1449	Uttam Nagar
1450	Uttam Nagar
1451	Uttam Nagar
1452	Uttam Nagar
1453	Uttam Nagar
1454	Uttam Nagar
1455	Uttam Nagar
1456	Uttam Nagar
1457	Uttam Nagar
1458	Uttam Nagar
1459	Uttam Nagar
1460	Uttam Nagar
1461	Uttam Nagar
1462	Uttam Nagar
1463	Uttam Nagar
1464	Uttam Nagar
1465	Uttam Nagar
1466	Uttam Nagar
1467	Uttam Nagar
1468	Uttam Nagar
1469	Uttam Nagar
1470	Uttam Nagar
1471	VIKAS PURI
1472	VIKAS PURI
1473	VIKAS PURI
1474	VIKAS PURI
1475	VIKAS PURI
1476	VIKAS PURI
1477	VIKAS PURI
1478	VIKAS PURI
1479	VIKAS PURI
1480	VIKAS PURI
1481	VIKAS PURI
1482	VIKAS PURI
1483	VIKAS PURI
1484	VIKAS PURI
1485	VIKAS PURI
1486	VIKAS PURI
1487	VIKAS PURI
1488	VIKAS PURI
1489	VIKAS PURI
1490	VIKAS PURI
1491	VIKAS PURI
1492	VIKAS PURI
1493	VIKAS PURI
1494	VIKAS PURI
1495	VIKAS PURI
1496	VIKAS PURI
1497	VIKAS PURI

126.12

2.60	66 KV BINDAPUR	WBNDP117	PRAJAPATI INDOOR S/STN	Mixed	AMR	2.60	0.00	2.54	2.20%	100%
0.03	66 KV BINDAPUR	WBNDP120	LOCAL TRANS	Local Grid	AMR	0.03	0.00	0.03	0.44%	100%
2.00	66 KV BINDAPUR	WBNDP121	NAIWALA PKT-4 BINDAPUR	Mixed	AMR	2.00	0.22	1.75	1.50%	100%
2.10	66 KV BINDAPUR	WBNDP123	B- BLOCK BINDAPUR	Mixed	AMR	2.10	0.00	2.05	2.09%	100%
3.63	66 KV BINDAPUR	WBNDP124	CHANAKAYA PLACE INDOOR S/STN	Mixed	AMR	3.63	0.00	3.58	1.31%	100%
2.58	66 KV BINDAPUR	WBNDP125	ADARSH NAGAR	Mixed	AMR	2.58	0.00	2.51	2.85%	100%
3.42	66 KV BINDAPUR	WBNDP127	VISHNU VIHAR	Mixed	AMR	3.42	0.00	3.35	1.89%	100%
2.45	66 KV BINDAPUR	WBNDP128	SANJAY ENCLAVE	Mixed	AMR	2.45	0.00	2.41	1.84%	100%
3.23	66 KV BINDAPUR	WBNDP132	O-BLOCK GEETA ENCLAVE	Mixed	AMR	3.23	0.00	3.18	1.43%	100%
2.78	66 KV BINDAPUR	WBNDP604	BINDAPUR DDA S/STN NO-1	Mixed	AMR	2.78	0.00	2.75	1.21%	100%
2.25	66 KV BINDAPUR	WBNDP605	VANI VIHAR PARK	Mixed	AMR	2.25	0.00	2.22	1.46%	100%
1.07	66 KV BINDAPUR	WBNDP606	T BLK KHADDEWALA	Mixed	AMR	1.07	0.00	1.03	3.35%	100%
0.44	66 KV BINDAPUR	WBNDP608	JEEWAN PARK SOM BAZAAR RD	Mixed	AMR	0.44	0.00	0.44	1.95%	100%
1.66	66 KV HASTSAL GRID	WHAST110	B-BLK NEW (UTTAM NAGAR)	Mixed	AMR	1.66	0.00	1.58	4.38%	100%
1.98	66 KV HASTSAL GRID	WHAST113	RAM DUTT ENCLAVE	Mixed	AMR	1.98	0.00	1.95	1.65%	100%
3.57	66 KV HASTSAL GRID	WHAST114	B-BLK OLD (UTTAM NAGAR)	Mixed	AMR	3.57	0.00	3.53	1.17%	100%
1.97	66 KV HASTSAL GRID	WHAST127	JJ COLONY PANKHA ROAD FISH MARK	Mixed	AMR	1.97	0.00	1.95	1.24%	100%
3.44	33 KV JANAK PURI	WJKPG103	11 KV O/G MILAPNAGAR	Mixed	AMR	3.44	0.00	3.36	2.37%	100%
2.27	66 KV G-5 PPKLN(MATIYALA)	WMTLA106	DVBMP TA BLK	Mixed	AMR	2.27	0.00	2.25	1.12%	100%
2.94	66 KV G-5 PPKLN(MATIYALA)	WMTLA108	KIRAN GARDEN PM NEAR MAHINDRU HOSP.	Mixed	AMR	2.94	0.00	2.91	1.12%	100%
2.31	66 KV G-5 PPKLN(MATIYALA)	WMTLA130	11 KV KIRAN GARDEN	Mixed	AMR	2.31	0.00	2.28	1.30%	100%
2.21	66 KV G-5 PPKLN(MATIYALA)	WMTLA140	TIKONA PARK OM VIHAR	Mixed	AMR	2.21	0.00	2.18	1.24%	100%
4.68	66 KV PANKHA ROAD	WPNRD105	CHANAKYA PALACE	Mixed	AMR	4.68	0.00	4.62	1.16%	100%
3.16	66 KV PANKHA ROAD	WPNRD106	MAHINDRA PARK	Mixed	AMR	3.16	0.00	3.13	1.08%	100%
2.54	66 KV PANKHA ROAD	WPNRD107	JEEWAN PARK	Mixed	AMR	2.54	0.00	2.51	1.26%	100%
3.63	66 KV PANKHA ROAD	WPNRD109	UTTAM NAGAR	Mixed	AMR	3.63	0.00	3.59	1.08%	100%
2.04	66 KV PANKHA ROAD	WPNRD123	EAST UTTAM NAGAR	Mixed	AMR	2.04	0.00	1.99	2.50%	100%
2.17	66 KV PANKHA ROAD	WPNRD124	PREM NAGAR S/STN	Mixed	AMR	2.17	0.00	2.14	1.34%	100%
1.44	66 KV BODELLA-1	WBDEL1101	VIKAS KUNJ	Residential	AMR	1.44	0.57	0.83	2.99%	100%
0.25	66 KV BODELLA-1	WBDEL1102	BOOSTER PUMPING STN (C- BLK)	Public Utilities	AMR	0.25	0.00	0.25	1.22%	100%
2.69	66 KV BODELLA-1	WBDEL1103	KANGDA NIKETAN	Residential	AMR	2.69	0.00	2.62	2.30%	100%
0.04	66 KV BODELLA-1	WBDEL1104	100 KVA LOCAL TRANSFORMER	Local Grid	AMR	0.04	0.00	0.04	0.45%	100%
3.37	66 KV BODELLA-1	WBDEL1105	D- BLK VIKAS PURI	Residential	AMR	3.37	0.00	3.31	1.71%	100%
1.45	66 KV BODELLA-1	WBDEL1108	GUJRANWALA APPTT.	Residential	AMR	1.45	0.00	1.41	2.30%	100%
3.20	66 KV BODELLA-1	WBDEL1111	HIMGIRI (LIONS)	Residential	AMR	3.20	0.00	3.14	2.01%	100%
3.03	66 KV BODELLA-1	WBDEL1112	KESHO PUR	Public Utilities	AMR	3.03	0.00	2.97	2.10%	100%
2.12	66 KV BODELLA-1	WBDEL1114	C-BLK VIKAS PURI	Residential	AMR	2.12	0.00	2.07	2.53%	100%
2.05	66 KV BODELLA-1	WBDEL1115	NEW KRISHNA PARK O/H	Residential	AMR	2.05	0.00	1.99	2.53%	100%
1.80	66 KV BODELLA-1	WBDEL1124	RELIANCE MALL A-BLK VIKASHPURI	Mixed	AMR	1.80	0.00	1.76	2.12%	100%
2.61	66 KV BODELLA-1	WBDEL1125	H BLOCK STORE	Mixed	AMR	2.61	0.00	2.57	1.59%	100%
0.23	66 KV BODELLA-1	WBDEL1128	HCC VCCL VIKASPURI	Mixed	AMR	0.23	0.23	0.00	0.43%	100%
0.80	66 KV BODHELLA-II	WBDEL2101	PANCHWATI SOCIETY - 1	Mixed	AMR	0.80	0.34	0.43	4.22%	100%
4.02	66 KV BODHELLA-II	WBDEL2102	HOLY CONVENT SCHOOL	Commercial	AMR	4.02	0.00	3.93	2.28%	100%
2.50	66 KV BODHELLA-II	WBDEL2104	1616, JANTA HASTSAL	Mixed	AMR	2.50	0.00	2.42	3.04%	100%
0.03	66 KV BODHELLA-II	WBDEL2105	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	0.44%	100%
2.23	66 KV BODHELLA-II	WBDEL2106	G-1 S/STN-1 SONIA	Mixed	AMR	2.23	0.86	1.30	3.14%	100%
1.66	66 KV BODHELLA-II	WBDEL2107	GANGOTRI SOCIETY	Residential	AMR	1.66	0.00	1.62	2.32%	100%
1.67	66 KV BODHELLA-II	WBDEL2108	ANURADHYA APPT.	Residential	AMR	1.67	0.00	1.64	1.94%	100%
2.15	66 KV BODHELLA-II	WBDEL2109	UJJWAL APPARTMENTS	Residential	AMR	2.15	0.85	1.23	3.32%	100%
2.71	66 KV BODHELLA-II	WBDEL2110	HASTSAL SOCIETY	Mixed	AMR	2.71	0.00	2.66	1.61%	100%
2.35	66 KV BODHELLA-II	WBDEL2111	11 KV LIG-2 HASTSAL	Mixed	AMR	2.35	0.00	2.28	2.96%	100%
2.27	66 KV BODHELLA-II	WBDEL2112	NAVYUG APPTT. - 1	Residential	AMR	2.27	0.76	1.42	3.85%	100%
1.07	66 KV BODHELLA-II	WBDEL2114	RMU -1	Residential	AMR	1.07	0.48	0.56	2.95%	100%
2.71	66 KV BODHELLA-II	WBDEL2115	F- BLOCK I D S/STN	Residential	AMR	2.71	0.95	1.68	2.76%	100%
3.14	66 KV BODHELLA-II	WBDEL2116	DG-3 VIKASPURI	Residential	AMR	3.14	0.00	3.07	2.14%	100%

1498	VIKAS PURI		1.72	66 KV BODHELLA-II	WBDL2117	SHIV ENCLAVE	Commercial	AMR	1.72	0.00	1.67	2.98%		100%	
1499	VIKAS PURI		1.26	66 KV BODHELLA-II	WBDL2118	LOK VIHAR	Residential	AMR	1.26	0.00	1.22	3.15%		100%	
1500	VIKAS PURI		3.71	66 KV BODHELLA-II	WBDL2119	G-1 S/STN -3	Mixed	AMR	3.71	1.21	2.44	1.43%		100%	
1501	VIKAS PURI		2.97	66 KV BODHELLA-II	WBDL2122	DDA TRANSIT CAMP HASTSAL NO-2	Mixed	AMR	2.97	0.00	2.90	2.31%		100%	
1502	VIKAS PURI		3.26	66 KV BODHELLA-II	WBDL2125	DDA TRANST CAMP-1 HASTSAL	Mixed	AMR	3.26	0.00	3.20	1.92%		100%	
1503	VIKAS PURI		3.98	66 KV BODHELLA-II	WBDL2127	REILANCE MALL A BLOCK	Mixed	AMR	3.98	1.88	2.00	2.56%		100%	
1504	VIKAS PURI		1.97	66 KV BODHELLA-II	WBDL2128	SBI SOCIETY	Mixed	AMR	1.97	0.77	1.12	3.69%		100%	
1505	VIKAS PURI		3.31	66 KV BODHELLA-II	WBDL2129	SHIV VIHAR	Mixed	AMR	3.31	0.00	3.24	2.01%		100%	
1506	VIKAS PURI		0.76	66 KV BODHELLA-II	WBDL2130	LIG COMPLAINT CENTER	Mixed	AMR	0.76	0.00	0.75	1.04%		100%	
1507	VIKAS PURI		0.68	66 KV BODHELLA-II	WBDL2131	LIG MOTHER DAIRY	Mixed	AMR	0.68	0.00	0.67	1.30%		100%	
1508	VIKAS PURI		3.49	66 KV BODHELLA-II	WBDL2135	RP WORLD SCHOOL S/STN	Residential	AMR	3.49	0.00	3.41	2.30%		100%	
1509	VIKAS PURI		1.26	66 KV BODHELLA-II	WBDL2136	A BLOCK MANDIRWALA	Residential	AMR	1.26	0.50	0.72	3.41%		100%	
1510	VIKAS PURI		3.07	66 KV BODHELLA-II	WBDL2138	BHARAT GHAR GULATI WALA	Mixed	AMR	3.07	0.00	3.02	1.70%		100%	
1511	VIKAS PURI		2.02	66 KV BODHELLA-II	WBDL2143	RAJDHANI GALI WALA	Residential	AMR	2.02	0.00	1.95	3.56%		100%	
1512	VIKAS PURI		0.34	66 KV BODHELLA-II	WBDL2144	DJB PRATIBHA PLANT	Commercial	AMR	0.34	0.09	0.25	0.11%		100%	
1513	VIKAS PURI		3.29	66 KV HASTSAL GRID	WHAST101	11 KV DALL MILL FEEDER	Mixed	AMR	3.29	0.00	3.22	2.23%		100%	
1514	VIKAS PURI		2.98	66 KV HASTSAL GRID	WHAST102	11 KV KALI BASTI	Mixed	AMR	2.98	0.00	2.92	1.95%		100%	
1515	VIKAS PURI		1.13	66 KV HASTSAL GRID	WHAST103	MOTHER DAIRY	Mixed	AMR	1.13	0.00	1.09	3.14%		100%	
1516	VIKAS PURI		1.82	66 KV HASTSAL GRID	WHAST104	11 KV C-BLK JJ COLONY	Mixed	AMR	1.82	0.00	1.77	2.77%		100%	
1517	VIKAS PURI		3.67	66 KV HASTSAL GRID	WHAST108	HASTSAL VIHAR	Mixed	AMR	3.67	0.00	3.62	1.54%		100%	
1518	VIKAS PURI		0.02	66 KV HASTSAL GRID	WHAST109	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.33%		100%	
1519	VIKAS PURI		3.80	66 KV HASTSAL GRID	WHAST111	UTTAM NAGAR TRAMINAL	Public Utilities	AMR		1.27	2.46	1.73%		100%	
1520	VIKAS PURI		3.06	66 KV HASTSAL GRID	WHAST115	RAJ HANS VIHAR	Mixed	AMR	3.06	0.00	3.00	1.77%		100%	
1521	VIKAS PURI		1.32	66 KV HASTSAL GRID	WHAST116	HASTSAL SOCITEY	Mixed	AMR	1.32	0.00	1.29	2.31%		100%	
1522	VIKAS PURI		2.68	66 KV HASTSAL GRID	WHAST123	GURUDURA HASTSAL ROAD	Mixed	AMR	2.68	0.00	2.62	2.32%		100%	
1523	VIKAS PURI		2.09	66 KV HASTSAL GRID	WHAST129	11 KV PRESS ENCLAVE	Mixed	AMR	2.09	0.00	2.04	2.71%		100%	
1524	VIKAS PURI		2.66	66 KV HASTSAL GRID	WHAST131	11KV O/G VIDYA VIHAR	Mixed	AMR	2.66	0.00	2.60	2.15%		100%	
1525	VIKAS PURI		3.22	33 KV JANAK PURI	WJKPG102	O/G VIA RMU NO-3 SIMENCE S/STN BODELLA	Mixed	AMR	3.22	1.15	1.98	2.68%		100%	
1526	VIKAS PURI		0.89	33 KV JANAK PURI	WJKPG105	11KV O/G NEW KRISHNA PARK	Residential	AMR	0.89	0.00	0.87	1.78%		100%	
1527	VIKAS PURI		3.17	66 KV NILOTHI	WNILO121	VIKRANT CHOWK	Residential	AMR	3.17	0.00	3.11	1.70%		100%	
1528	VIKAS PURI		2.93	66 KV NILOTHI	WNILO130	PARDHAN CHOWK	Residential	AMR	2.93	0.00	2.86	2.25%		100%	
1529	VIKAS PURI		0.01	66 KV PASCHIM VIHAR	WPSCV111	KESHO PUR PLANT	Public Utilities	AMR		0.01	0.00	3.96%		100%	
1530	MUNDKA	315.71	134.24	3.07	400KV MUNDKA	100017311	220 KV KANJAHAWALA TO DMRC	Commercial	AMR		3.06	0.00	0.37%		100%
1531	MUNDKA			0.16	66 KV MUNDKA	WMUND101	11 KV O/G NEELWAL	Residential	AMR	0.16	0.02	0.14	1.55%		100%
1532	MUNDKA			3.00	66 KV MUNDKA	WMUND102	11 KV O/G GHEVRA MORE	Residential	AMR	3.00	0.59	2.40	0.28%		100%
1533	MUNDKA			4.55	66 KV MUNDKA	WMUND106	11 KV SUBHASH VIHAR-2	Residential	AMR	4.55	0.00	4.54	0.28%		100%
1534	MUNDKA			3.56	66 KV MUNDKA	WMUND107	11 KV BABA HARIDASH	Public Utilities	AMR	3.56	0.70	2.78	2.39%		100%
1535	MUNDKA			4.37	66 KV MUNDKA	WMUND108	11 KV HIRON KUDNA	Industrial	AMR	4.37	0.91	3.44	0.55%		100%
1536	MUNDKA			3.94	66 KV MUNDKA	WMUND109	11 KV BULBUL VATIKA	Industrial	AMR	3.94	0.00	3.82	3.16%		100%
1537	MUNDKA			1.51	66 KV MUNDKA	WMUND110	11 KV PVC MARKET -1	Mixed	AMR	1.51	0.00	1.51	0.33%		100%
1538	MUNDKA			3.59	66 KV MUNDKA	WMUND111	11 KV SUBHASH VIHAR -1	Mixed	AMR	3.59	0.75	2.83	0.25%		100%
1539	MUNDKA			4.78	66 KV MUNDKA	WMUND112	11 KV RANI KHERA MOR	Industrial	AMR	4.78	0.25	4.41	2.67%		100%
1540	MUNDKA			0.98	66 KV MUNDKA	WMUND113	11 KV IOCI BOTTLING PLANT	Industrial	AMR	0.98	0.98	0.00	0.07%		100%
1541	MUNDKA			0.02	66 KV MUNDKA	WMUND114	11 KV LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.21%		100%
1542	MUNDKA			2.48	66 KV MUNDKA	WMUND117	11 KV SHIVA GARDEN	Industrial	AMR	2.48	0.00	2.44	1.56%		100%
1543	MUNDKA			3.39	66 KV MUNDKA	WMUND118	11 KV S/STN NO.5	Mixed	AMR	3.39	0.00	3.30	2.81%		100%
1544	MUNDKA			3.71	66 KV MUNDKA	WMUND119	ABHINANDAN VATIKA	Mixed	AMR	3.71	0.22	3.45	1.16%		100%
1545	MUNDKA			4.15	66 KV MUNDKA	WMUND120	BOOSTER PUMP MUNDKA VILLAGE	Mixed	AMR	4.15	0.00	4.05	2.50%		100%
1546	MUNDKA			2.06	66 KV NILOTHI	WNILO129	DJB SWARN PARK NO.-2	Mixed	AMR	2.06	0.27	1.76	1.57%		100%
1547	MUNDKA			2.51	66 KV NILOTHI	WNILO131	CHANCHAL PARK	Mixed	AMR	2.51	0.00	2.43	3.01%		100%
1548	MUNDKA			2.16	66 KV NILOTHI	WNILO132	SHANI MANDIR	Mixed	AMR	2.16	0.00	2.12	1.72%		100%
1549	MUNDKA			4.48	66 KV NILOTHI	WNILO133	MEERA ENCLAVE	Mixed	AMR	4.48	0.00	4.40	1.88%		100%
1550	MUNDKA			2.23	66 KV NILOTHI	WNILO140	COMMUNITY CENTER	Mixed	AMR	2.23	0.00	2.22	0.18%		100%
1551	MUNDKA			2.09	66 KV NANGLOI	WNNGL111	RAJINDER PARK	Residential	AMR	2.09	0.00	2.04	2.23%		100%

1552	MUNDKA
1553	MUNDKA
1554	MUNDKA
1555	MUNDKA
1556	MUNDKA
1557	MUNDKA
1558	MUNDKA
1559	MUNDKA
1560	MUNDKA
1561	MUNDKA
1562	MUNDKA
1563	MUNDKA
1564	MUNDKA
1565	MUNDKA
1566	MUNDKA
1567	MUNDKA
1568	MUNDKA
1569	MUNDKA
1570	MUNDKA
1571	MUNDKA
1572	MUNDKA
1573	MUNDKA
1574	MUNDKA
1575	MUNDKA
1576	MUNDKA
1577	TAGORE GARDEN
1578	TAGORE GARDEN
1579	TAGORE GARDEN
1580	TAGORE GARDEN
1581	TAGORE GARDEN
1582	TAGORE GARDEN
1583	TAGORE GARDEN
1584	TAGORE GARDEN
1585	TAGORE GARDEN
1586	TAGORE GARDEN
1587	TAGORE GARDEN
1588	TAGORE GARDEN
1589	TAGORE GARDEN
1590	TAGORE GARDEN
1591	TAGORE GARDEN
1592	TAGORE GARDEN
1593	TAGORE GARDEN
1594	TAGORE GARDEN
1595	TAGORE GARDEN
1596	TAGORE GARDEN

	5.27	66 KV NANGLOI	WNNGLI17	BAKARWALA VILLAGE	Mixed	AMR	5.27	0.00	5.07	3.70%		100%
	4.25	66 KV NANGLOI	WNNGLI18	POLICE QTRS. NANGLOI	Residential	AMR	4.25	0.00	4.21	0.95%		100%
	3.82	66 KV NANGLOI	WNNGLI19	JJ COLONY NO. II	Residential	AMR	3.82	0.00	3.74	1.90%		100%
	2.70	66 KV NANGLOI	WNNGLI21	PUNJABI BASTI	Mixed	AMR	2.70	0.00	2.63	2.70%		100%
	2.50	66 KV NANGLOI	WNNGLI23	MUNDKA VILLAGE, C-BLK	Residential	AMR	2.50	0.00	2.43	2.78%		100%
	1.72	66 KV NANGLOI	WNNGLI24	IOC	Industrial	AMR	1.72	0.00	1.68	2.28%		100%
	1.55	66 KV NANGLOI WATER WORKS	WNNWW104	WATER WORKS	Industrial	AMR	1.55	1.55	0.00	0.16%		100%
	0.92	66 KV NANGLOI WATER WORKS	WNNWW105	RANHOLLA	Mixed	AMR	0.92	0.00	0.90	1.88%		100%
	4.22	66 KV NANGLOI WATER WORKS	WNNWW106	SWARN PARK	Mixed	AMR	4.22	0.00	4.13	2.09%		100%
	2.30	66 KV NANGLOI WATER WORKS	WNNWW107	HANUMAN MANDIR	Residential	AMR	2.30	0.00	2.27	1.49%		100%
	3.84	66 KV NANGLOI WATER WORKS	WNNWW110	ARVIND ENCLAVE	Mixed	AMR	3.84	0.00	3.80	1.04%		100%
	4.75	66 KV NANGLOI WATER WORKS	WNNWW111	KAMRUDEEN NGR S/STN-3	Mixed	AMR	4.75	0.00	4.67	1.81%		100%
	3.56	66 KV NANGLOI WATER WORKS	WNNWW113	HVDS Yadav Park	Mixed	AMR	3.56	0.00	3.47	2.38%		100%
	3.88	66 KV NANGLOI WATER WORKS	WNNWW114	DDA FLATS LOK NAYAK PURAM	Residential	AMR	3.88	0.23	3.62	0.85%		100%
	2.78	66 KV NANGLOI WATER WORKS	WNNWW115	Kunwar Singh Nagar	Mixed	AMR	2.78	0.00	2.74	1.18%		100%
	3.11	66 KV NANGLOI WATER WORKS	WNNWW117	Indian Oil	Industrial	AMR	3.11	0.00	3.03	2.39%		100%
	2.84	66 KV NANGLOI WATER WORKS	WNNWW118	Varindavan Vatika	Industrial	AMR	2.84	0.60	2.23	0.61%		100%
	4.18	66 KV NANGLOI WATER WORKS	WNNWW119	11 KV O/G TIKRI	Mixed	AMR	4.18	0.00	4.07	2.49%		100%
	2.06	66 KV NANGLOI WATER WORKS	WNNWW121	11 KV RAJDHANI PARK	Industrial	AMR	2.06	0.10	1.91	2.31%		100%
	3.59	66 KV NANGLOI WATER WORKS	WNNWW122	11 KV MUNDKA LT LESS	Industrial	AMR	3.59	0.00	3.54	1.46%		100%
	4.53	66 KV NANGLOI WATER WORKS	WNNWW123	JAI VIHAR	Mixed	AMR	4.53	0.00	4.43	2.37%		100%
	1.53	66 KV NANGLOI WATER WORKS	WNNWW126	BANI CAMP	Industrial	AMR	1.53	0.24	1.28	1.10%		100%
	0.03	66 KV NANGLOI WATER WORKS	WNNWW127	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	0.41%		100%
	1.33	66 KV NANGLOI WATER WORKS	WNNWW128	BAKKARWALA JJ COLONY	Mixed	AMR	1.33	0.35	0.94	3.04%		100%
	0.17	66 KV NANGLOI WATER WORKS	WNNWW129	GOVT. SCHOOL NEAR RADAR RANHOLA	Industrial	AMR	0.17	0.04	0.12	0.38%		100%
181.47	3.78	33 KV MUKHERJI PARK	150001311	DMRC Metro Mall	Commercial	AMR	3.78	3.76	0.00	0.37%		100%
	2.52	66 KV BODELLA-1	WBDL1106	224 SFS TAGORE GARDEN EXTN	Residential	AMR	2.52	0.00	2.45	2.62%		100%
	2.02	66 KV BODELLA-1	WBDL1107	K BLK KRISHNA PARK EXTN.	Residential	AMR	2.02	0.00	1.97	2.65%		100%
	2.20	66 KV BODELLA-1	WBDL1110	72 SFS NO-1	Residential	AMR	2.20	0.00	2.15	2.31%		100%
	4.27	66 KV BODELLA-1	WBDL1113	320 MIG FLTS, A- PKT, BODELLA EXTN.	Residential	AMR	4.27	0.00	4.21	1.51%		100%
	2.18	66 KV BODELLA-1	WBDL1116	1-BLK , TILAK NGR	Mixed	AMR	2.18	0.00	2.12	2.59%		100%
	3.47	66 KV BODELLA-1	WBDL1117	72 SFS NO-2	Residential	AMR	3.47	0.00	3.34	3.78%		100%
	3.23	66 KV BODELLA-1	WBDL1118	20 BLK, TILAK NGR	Residential	AMR	3.23	0.00	3.15	2.23%		100%
	3.80	66 KV BODELLA-1	WBDL1126	KALI MATA MANDIR	Residential	AMR	3.80	0.00	3.66	3.67%		100%
	2.99	66 KV BODELLA-1	WBDL1127	GALI NO. 8 MAHAVIR ENCLAVE	Residential	AMR	2.99	0.00	2.93	1.90%		100%
	1.67	66 KV BODELLA-1	WBDL1129	K BLK NEW MAHAVIR NAGAR	Mixed	AMR	1.67	0.00	1.63	2.97%		100%
	1.92	66 KV BODHELLA-II	WBDL2113	M B S NAGAR	Residential	AMR	1.92	0.00	1.87	2.88%		100%
	0.02	33 KV CHAUKHANDI GRID	WCHAK101	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.28%		100%
	1.16	33 KV CHAUKHANDI GRID	WCHAK102	FRUIT & VEG. MKT-2	Mixed	AMR	1.16	0.00	1.13	2.98%		100%
	1.11	33 KV CHAUKHANDI GRID	WCHAK103	RAM NAGAR EXTN	Mixed	AMR	1.11	0.00	1.06	4.65%		100%
	2.30	33 KV CHAUKHANDI GRID	WCHAK104	DDA CHAUKHANDI	Mixed	AMR	2.30	0.00	2.23	3.05%		100%
	3.63	33 KV CHAUKHANDI GRID	WCHAK105	RZ VISHNU GARDEN	Mixed	AMR	3.63	0.00	3.54	2.32%		100%
	1.26	33 KV CHAUKHANDI GRID	WCHAK106	224 S.F.S	Residential	AMR	1.26	0.27	0.96	2.47%		100%
	2.54	33 KV CHAUKHANDI GRID	WCHAK107	O/G TILAK VIHAR	Residential	AMR	2.54	0.00	2.46	3.12%		100%
	3.98	33 KV CHAUKHANDI GRID	WCHAK108	FRUIT & VEG. MKT-1 & KESHO PUR	Mixed	AMR	3.98	0.00	3.90	2.02%		100%

1597	TAGORE GARDEN
1598	TAGORE GARDEN
1599	TAGORE GARDEN
1600	TAGORE GARDEN
1601	TAGORE GARDEN
1602	TAGORE GARDEN
1603	TAGORE GARDEN
1604	TAGORE GARDEN
1605	TAGORE GARDEN
1606	TAGORE GARDEN
1607	TAGORE GARDEN
1608	TAGORE GARDEN
1609	TAGORE GARDEN
1610	TAGORE GARDEN
1611	TAGORE GARDEN
1612	TAGORE GARDEN
1613	TAGORE GARDEN
1614	TAGORE GARDEN
1615	TAGORE GARDEN
1616	TAGORE GARDEN
1617	TAGORE GARDEN
1618	TAGORE GARDEN
1619	TAGORE GARDEN
1620	TAGORE GARDEN
1621	TAGORE GARDEN
1622	TAGORE GARDEN
1623	TAGORE GARDEN
1624	TAGORE GARDEN
1625	TAGORE GARDEN
1626	TAGORE GARDEN
1627	TAGORE GARDEN
1628	TAGORE GARDEN
1629	TAGORE GARDEN
1630	TAGORE GARDEN
1631	TAGORE GARDEN

1.27	33 KV CHAUKHANDI GRID	WCHAK109	VISHNU GARDEN B.I 283	Mixed	AMR	1.27	0.00	1.22	3.61%		100%
2.92	33 KV CHAUKHANDI GRID	WCHAK110	O/G EXTN. 5C VISHNU GARDEN	Mixed	AMR	2.92	0.00	2.83	3.13%		100%
0.66	33 KV CHAUKHANDI GRID	WCHAK111	320 MIG VIKAS PURI	Mixed	AMR	0.66	0.00	0.64	2.89%		100%
3.15	33 KV CHAUKHANDI GRID	WCHAK112	CHAND NAGAR KHADDE WALLA	Mixed	AMR	3.15	0.00	3.06	2.88%		100%
1.94	33 KV CHAUKHANDI GRID	WCHAK117	C BLOCK TILAK VIHAR	Residential	AMR	1.94	0.00	1.88	3.14%		100%
0.65	33 KV CHAUKHANDI GRID	WCHAK118	CHAND NAGAR SCHOOLWALA	Mixed	AMR	0.65	0.00	0.63	2.90%		100%
2.59	33 KV CHAUKHANDI GRID	WCHAK119	C&D BLOCK VISHNU GARDEN	Mixed	AMR	2.59	0.00	2.54	2.05%		100%
2.45	33 KV CHAUKHANDI GRID	WCHAK120	RAVI NAGAR GURUDWARA	Mixed	AMR	2.45	0.00	2.38	3.05%		100%
0.29	33 KV CHAUKHANDI GRID	WCHAK121	RAM NAGAR TALWAR WALA	Mixed	AMR	0.29	0.00	0.28	0.58%		100%
1.74	33 KV CHAUKHANDI GRID	WCHAK122	288 PUNARWAS COLONY	Mixed	AMR	1.74	0.00	1.69	3.07%		100%
1.30	33 KV CHAUKHANDI GRID	WCHAK123	AB BLOCK KHAYLA	Mixed	AMR	1.30	0.00	1.24	4.48%		100%
4.69	33 KV CHAUKHANDI GRID	WCHAK124	E BLOCK KHYALA	Mixed	AMR	4.69	0.00	4.62	1.52%		100%
0.03	66 KV Guru Govind Singh Hospital	WGGSH103	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	0.38%		100%
3.20	66 KV Guru Govind Singh Hospital	WGGSH104	11 KV NEW - F BLOCK	Residential	AMR	3.20	0.00	3.10	3.11%		100%
3.73	66 KV Guru Govind Singh Hospital	WGGSH105	11 KV N-W BLOCK	Mixed	AMR	3.73	0.00	3.65	2.26%		100%
2.03	66 KV Guru Govind Singh Hospital	WGGSH106	C-BLK BREAKDOWN OFFICE	Residential	AMR	2.03	0.00	1.97	2.61%		100%
3.88	66 KV Guru Govind Singh Hospital	WGGSH107	608- JANTA FLAT	Residential	AMR	3.88	0.00	3.75	3.38%		100%
3.89	66 KV Guru Govind Singh Hospital	WGGSH108	11 KV O/G G-BLOCK SHIVAJI ENCLAVE	Mixed	AMR	3.89	0.00	3.81	2.01%		100%
3.87	66 KV Guru Govind Singh Hospital	WGGSH109	11 KV O/G M BLOCK RAGHUVIR NAGAR	Residential	AMR	3.87	0.00	3.78	2.38%		100%
3.55	66 KV Guru Govind Singh Hospital	WGGSH110	N-W BLOCK VISHNU GARDEN	Mixed	AMR	3.55	0.00	3.47	2.45%		100%
5.36	66 KV Guru Govind Singh Hospital	WGGSH113	S BLOCK VISHNU GARDEN	Mixed	AMR	5.36	0.00	5.22	2.64%		100%
2.28	66 KV Guru Govind Singh Hospital	WGGSH114	11KV O/G KHYALA BOOSTER TGN	Public Utilities	AMR	2.28	0.42	1.79	2.74%		100%
0.27	66 KV Guru Govind Singh Hospital	WGGSH115	SHOPPERS TOP MALL, PLOT-10, RAJOURI GARDEN	Commercial	AMR	0.27	0.27	0.00	2.41%		100%
1.29	66 KV Guru Govind Singh Hospital	WGGSH117	PLOT NO. 23 SHIVAJI PLACE NO. 2	Residential	AMR	1.29	0.00	1.26	2.64%		100%
0.90	66 KV Guru Govind Singh Hospital	WGGSH118	PLOT NO. 23 SHIVAJI PLACE NO. 1	Residential	AMR	0.90	0.00	0.88	2.92%		100%
2.10	66 KV Guru Govind Singh Hospital	WGGSH119	F- BLOCK KHATTA	Mixed	AMR	2.10	0.00	2.04	2.63%		100%
1.96	33 KV MADI PUR	WM DPR110	RG BLK, RAGHUVI NGR	Residential	AMR	1.96	0.00	1.90	2.89%		100%
3.10	33 KV MUKHERJI PARK	WMUKP101	IND. AREA TILAK NAGAR	Mixed	AMR	3.10	0.71	2.33	1.92%		100%
1.02	33 KV MUKHERJI PARK	WMUKP102	MUKERJEE PARK-2	Mixed	AMR	1.02	0.00	0.98	3.50%		100%
1.05	33 KV MUKHERJI PARK	WMUKP106	B- BLOCK J. J. COLONY CHAUKHANDI	Mixed	AMR	1.05	0.00	1.01	3.26%		100%
2.90	33 KV MUKHERJI PARK	WMUKP107	TAGORE GARDEN	Residential	AMR	2.90	0.00	2.84	2.06%		100%
2.67	33 KV MUKHERJI PARK	WMUKP110	CHAUKHANDI	Mixed	AMR	2.67	0.00	2.57	3.67%		100%
0.02	33 KV MUKHERJI PARK	WMUKP111	LOCAL TRANSFORMER	Local Grid	AMR	0.02	0.00	0.02	0.35%		100%
3.64	33 KV MUKHERJI PARK	WMUKP112	FEEDER-3 SHAM NAGAR	Mixed	AMR	3.64	0.00	3.57	2.02%		100%
3.25	33 KV MUKHERJI PARK	WMUKP113	FEEDER-9 CHAND NAGAR	Mixed	AMR	3.25	0.00	3.19	1.99%		100%

1632	TAGORE GARDEN			1.83	33 KV MUKHERJI PARK	WMUKP114	TELEPHONE EXCHANGE	Commercial	AMR	1.83	0.33	1.46	2.29%		100%
1633	TAGORE GARDEN			1.18	33 KV MUKHERJI PARK	WMUKP117	D BLOCK RAGHUBIR NAGAR	Residential	AMR	1.18	0.00	1.13	3.76%		100%
1634	TAGORE GARDEN			3.81	33 KV MUKHERJI PARK	WMUKP118	MUKHERJI PARK -1	Mixed	AMR	3.81	0.00	3.68	3.46%		100%
1635	TAGORE GARDEN			2.99	33 KV MUKHERJI PARK	WMUKP119	B-1/283 VISHNU GARDEN	Mixed	AMR	2.99	0.00	2.86	4.13%		100%
1636	TAGORE GARDEN			2.44	33 KV MUKHERJI PARK	WMUKP122	WATER TANK TILAK NAGAR	Mixed	AMR	2.44	0.00	2.34	3.99%		100%
1637	TAGORE GARDEN			4.24	33 KV MUKHERJI PARK	WMUKP123	11 KV O/G S-BLOCK, VISHNU GARDEN	Mixed	AMR	4.24	0.00	4.11	3.25%		100%
1638	TAGORE GARDEN			2.79	33 KV MUKHERJI PARK	WMUKP125	MUKHERJI PARK SCHOOL WALA	Mixed	AMR	2.79	0.00	2.73	2.42%		100%
1639	TAGORE GARDEN			3.05	33 KV MUKHERJI PARK	WMUKP128	GANGA RAM VATIKA	Mixed	AMR	3.05	0.00	2.99	2.15%		100%
1640	TAGORE GARDEN			1.92	33 KV MUKHERJI PARK	WMUKP129	MOTHER DAIRY SHAM NAGAR	Mixed	AMR	1.92	0.00	1.85	3.50%		100%
1641	TAGORE GARDEN			3.90	33 KV PASCHIM PURI	WPSCP105	NARSINGH GARDEN	Mixed	AMR	3.90	0.00	3.81	2.28%		100%
1642	TAGORE GARDEN			3.47	33 KV WDDC VISHAL	WVSHL101	11 KV O/G KHAYALA PUMPING STATION	Public Utilities	AMR	3.47	0.00	3.39	2.11%		100%
1643	TAGORE GARDEN			0.00	33 KV WDDC VISHAL	WVSHL102	LOCAL TRANSFORMER	Local Grid	AMR	0.00	0.00	0.00	0.37%		100%
1644	TAGORE GARDEN			2.07	33 KV WDDC VISHAL	WVSHL105	S BLOCK VISHNU GARDEN VIA WORK CNTR	Residential	AMR	2.07	0.46	1.56	2.50%		100%
1645	TAGORE GARDEN			0.42	33 KV WDDC VISHAL	WVSHL106	TDI MALL	Commercial	AMR	0.42	0.41	0.00	2.54%		100%
1646	TAGORE GARDEN			0.88	33 KV WDDC VISHAL	WVSHL109	748 JANTA FLATS	Residential	AMR	0.88	0.00	0.85	2.68%		100%
1647	TAGORE GARDEN			2.27	33 KV WDDC VISHAL	WVSHL110	1040 JANTA COLONY	Residential	AMR	2.27	0.43	1.76	3.20%		100%
1648	TAGORE GARDEN			3.06	33 KV WDDC VISHAL	WVSHL114	A BLOCK SSTN OFFICE	Mixed	AMR	3.06	0.00	2.97	3.06%		100%
1649	TAGORE GARDEN			2.07	33 KV WDDC VISHAL	WVSHL116	F BLOCK SHIVAJI PARK	Residential	AMR	2.07	0.00	2.00	3.32%		100%
1650	TAGORE GARDEN			2.95	33 KV WDDC VISHAL	WVSHL117	TAGORE GARDEN	Residential	AMR	2.95	0.00	2.86	2.82%		100%
1651	TAGORE GARDEN			2.27	33 KV WDDC VISHAL	WVSHL119	INTER CINNECTOR KIOSK-1	Public Utilities	AMR	2.27	0.48	1.72	2.89%		100%
1652	TAGORE GARDEN			2.02	33 KV WDDC VISHAL	WVSHL120	D BLOCK RAGUBIR NAGAR	Residential	AMR	2.02	0.45	1.51	2.72%		100%
1653	TAGORE GARDEN			0.00	33 KV WDDC VISHAL	WVSHL127	CITY SQUARE MALL + TODAY MALL	Commercial	AMR	0.00	0.00	0.00	0.20%		100%
1654	TAGORE GARDEN			0.80	33 KV WDDC VISHAL	WVSHL128	RAJORI GARDEN PLOT NO 10 DIST CENTR	Commercial	AMR	0.80	0.78	0.00	2.54%		100%
1655	TAGORE GARDEN			0.41	33 KV WDDC VISHAL	WVSHL129	CITY SQUARE MALL	Commercial	AMR	0.41	0.41	0.00	0.20%		100%
1656	TAGORE GARDEN			0.94	33 KV WDDC VISHAL	WVSHL131	SPIRIT GLOBAL	Commercial	AMR	0.94	0.93	0.00	0.94%		100%
1657	JAFFARPUR	234.61	58.67	0.08	66 KV MITRAON	WMITR102	11KV LOCAL TRANSFORMER	Local Grid	AMR	0.08	0.00	0.08	0.55%		100%
1658	JAFFARPUR			2.42	66 KV MITRAON	WMITR103	GANGOTRI	Mixed	AMR	2.42	0.00	2.32	4.32%		100%
1659	JAFFARPUR			2.47	66 KV MITRAON	WMITR105	SAINIC ENCLAVE	Mixed	AMR	2.47	1.33	1.04	3.90%		100%
1660	JAFFARPUR			0.67	66 KV MITRAON	WMITR106	NETA JI LINE	Mixed	AMR	0.67	0.00	0.66	1.64%		100%
1661	JAFFARPUR			1.70	66 KV MITRAON	WMITR107	NEW MITRAON	Mixed	AMR	1.70	1.16	0.47	4.31%		100%
1662	JAFFARPUR			2.68	66 KV MITRAON	WMITR110	NEW THANA	Mixed	AMR	2.68	0.00	2.58	3.72%		100%
1663	JAFFARPUR			1.99	66 KV MITRAON	WMITR113	ARADHNA ENCLAVE	Mixed	AMR	1.99	0.00	1.91	3.98%		100%
1664	JAFFARPUR			2.38	66 KV MITRAON	WMITR115	PTS ACADEMY FEEDER	Mixed	AMR	2.38	0.00	2.28	4.20%		100%
1665	JAFFARPUR			2.23	66 KV MITRAON	WMITR116	SURAKHPUR ROAD, GOPAL NAGAR	Mixed	AMR	2.23	0.00	2.14	4.12%		100%
1666	JAFFARPUR			0.52	66 KV MITRAON	WMITR134	KAIR VILLAGE	Mixed	AMR	0.52	0.00	0.52	0.62%		100%
1667	JAFFARPUR			0.03	66 KV MITRAON	WMITR135	SHYAM ENCLAVE	Mixed	AMR	0.03	0.00	0.03	0.43%		100%
1668	JAFFARPUR			0.29	66 KV MITRAON	WMITR136	BALAJI MANDIR	Mixed	AMR	0.29	0.00	0.29	0.59%		100%
1669	JAFFARPUR			1.67	66 KV JAFFARPUR	WZAFF101	RTRN HOSPITAL	Public Utilities	AMR	1.67	0.95	0.66	4.05%		100%
1670	JAFFARPUR			1.04	66 KV JAFFARPUR	WZAFF102	MITRAON	Mixed	AMR	1.04	0.00	1.00	3.81%		100%
1671	JAFFARPUR			2.65	66 KV JAFFARPUR	WZAFF103	ISSAPUR FEEDER	Mixed	AMR	2.65	1.16	1.39	3.90%		100%
1672	JAFFARPUR			1.68	66 KV JAFFARPUR	WZAFF104	DABAR ENCLAVE	Residential	AMR	1.68	0.00	1.61	3.88%		100%

1673	JAFFARPUR
1674	JAFFARPUR
1675	JAFFARPUR
1676	JAFFARPUR
1677	JAFFARPUR
1678	JAFFARPUR
1679	JAFFARPUR
1680	JAFFARPUR
1681	JAFFARPUR
1682	JAFFARPUR
1683	JAFFARPUR
1684	JAFFARPUR
1685	JAFFARPUR
1686	JAFFARPUR
1687	JAFFARPUR
1688	JAFFARPUR
1689	JAFFARPUR
1690	JAFFARPUR
1691	JAFFARPUR
1692	NAJAF GARH
1693	NAJAF GARH
1694	NAJAF GARH
1695	NAJAF GARH
1696	NAJAF GARH
1697	NAJAF GARH
1698	NAJAF GARH
1699	NAJAF GARH
1700	NAJAF GARH
1701	NAJAF GARH
1702	NAJAF GARH
1703	NAJAF GARH
1704	NAJAF GARH
1705	NAJAF GARH
1706	NAJAF GARH
1707	NAJAF GARH
1708	NAJAF GARH
1709	NAJAF GARH
1710	NAJAF GARH
1711	NAJAF GARH
1712	NAJAF GARH
1713	NAJAF GARH
1714	NAJAF GARH
1715	NAJAF GARH
1716	NAJAF GARH
1717	NAJAF GARH
1718	NAJAF GARH
1719	NAJAF GARH
1720	NAJAF GARH
1721	NAJAF GARH
1722	NAJAF GARH
1723	NAJAF GARH
1724	NAJAF GARH
1725	NAJAF GARH
1726	NAJAF GARH
1727	NAJAF GARH
1728	NAJAF GARH

175.94

3.06	66 KV JAFFARPUR	WZAFF105	JAFFARPUR	Mixed	AMR	3.06	0.00	2.93	4.35%	100%
2.73	66 KV JAFFARPUR	WZAFF106	MALIK PUR	Mixed	AMR	2.73	0.00	2.62	4.06%	100%
2.97	66 KV JAFFARPUR	WZAFF107	KHERA DABAR	Mixed	AMR	2.97	0.00	2.84	4.16%	100%
3.41	66 KV JAFFARPUR	WZAFF109	DHANSA	Mixed	AMR	3.41	0.00	3.22	5.43%	100%
0.01	66 KV JAFFARPUR	WZAFF111	LOCAL TRAF0	Local Grid	AMR	0.01	0.00	0.01	0.39%	100%
0.33	66 KV JAFFARPUR	WZAFF115	NEW CRPF	Mixed	AMR	0.33	0.00	0.32	4.41%	100%
0.24	66 KV JAFFARPUR	WZAFF116	THANA NAJAFGARH	Residential	AMR	0.24	0.17	0.06	4.53%	100%
0.00	66 KV JAFFARPUR	WZAFF117	PGCIL-1	Public Utilities	AMR	0.00	0.00	0.00	0.00%	100%
0.12	66 KV JAFFARPUR	WZAFF119	PGCIL-2	Public Utilities	AMR	0.12	0.00	0.12	1.83%	100%
1.23	66 KV JAFFARPUR	WZAFF120	JHUL JHULLI	Mixed	AMR	1.23	0.00	1.18	4.52%	100%
2.90	66 KV JAFFARPUR	WZAFF121	NEW MUNDHELA	Mixed	AMR	2.90	0.00	2.76	4.56%	100%
2.55	66 KV JAFFARPUR	WZAFF125	RAIL MASTER	Residential	AMR	2.55	0.00	2.46	3.85%	100%
3.36	66 KV JAFFARPUR	WZAFF126	GOPAL NAGER	Residential	AMR	3.36	0.00	3.23	3.86%	100%
1.66	66 KV JAFFARPUR	WZAFF127	DTC MUNDHELA KALAN NO -1	Mixed	AMR	1.66	0.00	1.59	4.26%	100%
2.51	66 KV JAFFARPUR	WZAFF128	RAWTA	Mixed	AMR	2.51	0.00	2.40	4.46%	100%
2.54	66 KV JAFFARPUR	WZAFF129	GHUMANHERA MORE	Mixed	AMR	2.54	1.12	1.30	4.54%	100%
0.99	66 KV JAFFARPUR	WZAFF130	SUREHRA VILLAGE	Residential	AMR	0.99	0.00	0.95	3.22%	100%
1.59	66 KV JAFFARPUR	WZAFF131	DTC MUNDHELA KALAN NO -2	Residential	AMR	1.59	0.93	0.60	3.65%	100%
1.95	66 KV JAFFARPUR	WZAFF132	SUREHERA MORE	Mixed	AMR	1.95	0.00	1.88	3.55%	100%
2.88	66 KV Bijwasan	SBWSN101	11 KV O/G BHARTHAL	Residential	AMR	2.88	0.78	2.04	2.27%	100%
2.61	66 KV Bijwasan	SBWSN104	11 KV O/G BAMNOLI	Residential	AMR	2.61	0.56	2.00	1.90%	100%
3.12	66 KV Bijwasan	SBWSN111	11 KV O/G BSF	Mixed	AMR	3.12	0.24	2.79	2.84%	100%
4.37	220 KV NAJAFGARH GRID	TDNG101	NAJAFGARH	Residential	AMR	4.37	0.00	4.24	3.16%	100%
4.21	220 KV NAJAFGARH GRID	TDNG102	11KV DICHHAON NAJAFGARH	Mixed	AMR	4.21	0.00	4.05	3.85%	100%
3.53	220 KV NAJAFGARH GRID	TDNG103	PUMPING STATION	Residential	AMR	3.53	0.00	3.39	3.95%	100%
2.07	220 KV NAJAFGARH GRID	TDNG104	DEENPUR	Residential	AMR	2.07	0.00	2.01	3.06%	100%
3.80	220 KV NAJAFGARH GRID	TDNG105	DVB COLONY	Residential	AMR	3.80	0.00	3.66	3.51%	100%
5.54	220 KV NAJAFGARH GRID	TDNG106	T P KOTLA	Mixed	AMR	5.54	0.32	5.05	3.08%	100%
2.84	220 KV NAJAFGARH GRID	TDNG107	RAMA PARK	Residential	AMR	2.84	0.43	2.34	2.36%	100%
3.45	220 KV NAJAFGARH GRID	TDNG108	NANGI SAKRAWATI	Industrial	AMR	3.45	0.00	3.34	3.11%	100%
3.21	220 KV NAJAFGARH GRID	TDNG109	7 PANNEL BOARD	Residential	AMR	3.21	0.08	3.06	2.08%	100%
4.53	220 KV NAJAFGARH GRID	TDNG110	KAKROLA	Residential	AMR	4.53	0.00	4.35	3.88%	100%
3.99	220 KV NAJAFGARH GRID	TDNG111	ANAJ MANDI	Mixed	AMR	3.99	0.00	3.82	4.32%	100%
2.92	220 KV NAJAFGARH GRID	TDNG112	CHAWALA TANK	Residential	AMR	2.92	0.00	2.82	3.44%	100%
2.23	66 KV DELHI JAL BOARD	WDJBD101	11 KV KANJAL HERI	Mixed	AMR	2.23	0.00	2.12	5.20%	100%
3.00	66 KV DELHI JAL BOARD	WDJBD102	11 KV ROSHAN PURA	Mixed	AMR	3.00	0.00	2.92	2.62%	100%
0.35	66 KV DELHI JAL BOARD	WDJBD103	DELHI JAL BOARD NO. 2	Public Utilities	AMR	0.35	0.00	0.33	3.74%	100%
3.30	66 KV DELHI JAL BOARD	WDJBD107	PRASHANT S/STN DHARAMPURA	Residential	AMR	3.30	0.00	3.18	3.71%	100%
3.03	66 KV DELHI JAL BOARD	WDJBD108	11 KV GOYALA SCHOOL	Residential	AMR	3.03	0.00	2.93	3.13%	100%
0.03	66 KV DELHI JAL BOARD	WDJBD109	11 KV LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	0.43%	100%
2.90	66 KV DELHI JAL BOARD	WDJBD114	VARDHANN VIHAR	Residential	AMR	2.90	0.00	2.79	3.64%	100%
3.05	66 KV DELHI JAL BOARD	WDJBD115	ROSHAN PURA X1-B BLK	Residential	AMR	3.05	0.00	2.97	2.67%	100%
2.96	66 KV DELHI JAL BOARD	WDJBD116	SHYAM VIHAR	Residential	AMR	2.96	0.00	2.86	3.45%	100%
4.00	66 KV DELHI JAL BOARD	WDJBD117	11KV O/G KAPOOR FARM	Residential	AMR	4.00	0.00	3.82	4.66%	100%
3.34	66 KV DELHI JAL BOARD	WDJBD118	DELHI JAI BOARD NO. 1	Residential	AMR	3.34	0.83	2.44	2.19%	100%
0.37	66 KV DELHI JAL BOARD	WDJBD119	DELHI JAI BOARD NO. 3	Public Utilities	AMR	0.37	0.09	0.26	2.50%	100%
0.03	66 KV DELHI JAL BOARD	WDJBD120	50 MGD DELHI JAL BOARD STAFF QUATOR	Public Utilities	AMR	0.03	0.00	0.03	2.45%	100%
4.38	66 KV DELHI JAL BOARD	WDJBD123	ARJUN PARK	Residential	AMR	4.38	0.00	4.21	3.85%	100%
2.20	66 KV DELHI JAL BOARD	WDJBD124	ROSAN GARDEN	Mixed	AMR	2.20	0.00	2.13	3.13%	100%
2.82	66 KV DELHI JAL BOARD	WDJBD125	JHATIKRA MORE	Mixed	AMR	2.82	0.80	1.94	2.71%	100%
3.11	66 KV DELHI JAL BOARD	WDJBD126	11KV O/G FEEDER KHAIRA	Residential	AMR	3.11	0.00	3.00	3.61%	100%
3.13	66 KV DELHI JAL BOARD	WDJBD127	PREM NAGAR	Residential	AMR	3.13	0.83	2.26	1.30%	100%
3.82	66 KV DELHI JAL BOARD	WDJBD128	DELHI GATE	Mixed	AMR	3.82	0.28	3.45	2.52%	100%
2.48	66 KV DELHI JAL BOARD	WDJBD129	G-BLOCK SHYAM VIHAR	Residential	AMR	2.48	0.00	2.41	2.64%	100%
1.88	66 KV DELHI JAL BOARD	WDJBD130	BDO OFFICE	Residential	AMR	1.88	0.00	1.83	2.68%	100%
2.58	66 KV G-4 PAPPANKALAN	WG4PN101	11 KV GOYALA DAIRY	Residential	AMR	2.58	0.00	2.47	4.31%	100%

1729	NAJAF GARH
1730	NAJAF GARH
1731	NAJAF GARH
1732	NAJAF GARH
1733	NAJAF GARH
1734	NAJAF GARH
1735	NAJAF GARH
1736	NAJAF GARH
1737	NAJAF GARH
1738	NAJAF GARH
1739	NAJAF GARH
1740	NAJAF GARH
1741	NAJAF GARH
1742	NAJAF GARH
1743	NAJAF GARH
1744	NAJAF GARH
1745	NAJAF GARH
1746	NAJAF GARH
1747	NAJAF GARH
1748	NAJAF GARH
1749	NAJAF GARH
1750	NAJAF GARH
1751	NAJAF GARH
1752	NAJAF GARH
1753	NAJAF GARH
1754	NAJAF GARH
1755	NAJAF GARH
1756	NAJAF GARH
1757	NAJAF GARH
1758	NAJAF GARH
1759	NAJAF GARH
1760	NAJAF GARH
1761	NAJAF GARH
1762	NAJAF GARH

3.08	66 KV G-4 PAPPANKALAN	WG4PN102	11 KV O/G TEJPUR	Residential	AMR	3.08	0.00	3.00	2.76%		100%
3.52	66 KV G-4 PAPPANKALAN	WG4PN105	11 KV O/G HANUMAN CHOWK	Residential	AMR	3.52	0.00	3.41	3.27%		100%
2.99	66 KV G-4 PAPPANKALAN	WG4PN120	O/G DHOOL SARAS	Residential	AMR	2.99	0.00	2.89	3.44%		100%
3.70	66 KV G-4 PAPPANKALAN	WG4PN121	O/G CHHAWALA(TRISHUL)	Mixed	AMR	3.70	0.08	3.51	2.96%		100%
2.57	66 KV G-4 PAPPANKALAN	WG4PN125	AMBERHAI VILLAGE	Residential	AMR	2.57	0.00	2.49	2.86%		100%
3.12	66 KV G-4 PAPPANKALAN	WG4PN127	MCD SCHOOL QUTUB VIHAR	Residential	AMR	3.12	0.00	3.03	2.94%		100%
2.03	66 KV G-4 PAPPANKALAN	WG4PN128	QUTUB VIHAR PH-2	Residential	AMR	2.03	0.39	1.59	2.06%		100%
2.27	66 KV G-4 PAPPANKALAN	WG4PN129	SHYAM VIHAR PH-2	Residential	AMR	2.27	0.00	2.20	3.17%		100%
0.64	66 KV G-4 PAPPANKALAN	WG4PN625	DDA PKT 4, DWK SEC 23B	Mixed	AMR	0.64	0.00	0.62	3.88%		100%
0.36	66 KV G-4 PAPPANKALAN	WG4PN627	DDA PKT 7, DWK SEC 23B	Mixed	AMR	0.36	0.00	0.35	2.53%		100%
4.12	66 KV G-6 PAPPANKALA	WG6PN125	810,DDA FLAT SEC-26 DWK,OPP BHARTAL	Mixed	AMR	4.12	0.96	3.04	2.94%		100%
4.81	66 KV G-6 PAPPANKALA	WG6PN128	POCHANPUR	Residential	AMR	4.81	0.00	4.62	3.90%		100%
2.36	66 KV G-7 DWARKA	WG7PN131	COMMAND TANK-06,DWK SEC-26	Mixed	AMR	2.36	0.34	1.98	1.89%		100%
0.97	66 KV GOYLA KHURD	WGOYL003	SOMESH VIHAR	Mixed	AMR	0.97	0.00	0.94	3.18%		100%
1.92	66 KV GOYLA KHURD	WGOYL004	GANDHI PARK	Mixed	AMR	1.92	0.00	1.85	3.66%		100%
1.23	66 KV GOYLA KHURD	WGOYL005	NEHRU GARDEN	Mixed	AMR	1.23	0.00	1.19	3.34%		100%
1.78	66 KV GOYLA KHURD	WGOYL006	PAPRAWAT	Mixed	AMR	1.78	0.00	1.74	2.09%		100%
0.03	66 KV GOYLA KHURD	WGOYL007	LOCAL TRANSFORMER	Local Grid	AMR	0.03	0.00	0.03	0.37%		100%
1.09	66 KV GOYLA KHURD	WGOYL008	SHYAM ENCLAVE	Mixed	AMR	1.09	0.00	1.08	0.66%		100%
1.67	66 KV GOYLA KHURD	WGOYL009	GAUTAM COLONY	Mixed	AMR	1.67	0.00	1.63	2.10%		100%
0.92	66 KV GOYLA KHURD	WGOYL010	DEFENCE ENCLAVE	Residential	AMR	0.92	0.00	0.92	0.65%		100%
1.77	66 KV MITRAON	WMITR104	CHAUHAN ENCLAVE	Mixed	AMR	1.77	0.00	1.76	0.76%		100%
3.74	66 KV MITRAON	WMITR108	11KV BABA HARIDAS	Residential	AMR	3.74	0.00	3.69	1.26%		100%
0.83	66 KV MITRAON	WMITR114	HEALTH CENTER NAJAFGARH	Mixed	AMR	0.83	0.00	0.81	2.34%		100%
0.05	66 KV MITRAON	WMITR137	B-BLOCK PRAM NAGAR	Mixed	AMR	0.05	0.00	0.05	0.51%		100%
0.17	66 KV MITRAON	WMITR138	KHARKHARI NAHAR	Mixed	AMR	0.17	0.00	0.17	0.58%		100%
1.85	66 KV MUNDKA	WMUND115	DJB UGR DHICHAON NO. 2	Public Utilities	AMR	1.85	0.13	1.68	1.94%		100%
1.07	66 KV MUNDKA	WMUND116	DJB UGR DHICHAON NO. 1	Public Utilities	AMR	1.07	0.00	1.04	3.53%		100%
2.79	66 KV MUNDKA	WMUND605	JHARODA	Mixed	AMR	2.79	0.00	2.74	1.96%		100%
2.01	66 KV PAPPANKALAN - 2	WPKL2105	DMRC STAFF QUARTER	Residential	AMR	2.01	0.00	1.96	2.40%		100%
0.52	66 KV PAPPANKALAN - 2	WPKL2111	5 MGD PUMPING STN NO-1	Public Utilities	AMR	0.52	0.00	0.51	3.21%		100%
2.71	66 KV PAPPANKALAN - 2	WPKL2112	5 MGD PUMPING STN NO-2	Public Utilities	AMR	2.71	0.50	2.14	2.30%		100%
2.29	66 KV JAFFARPUR	WZAFF110	DAULATPUR	Mixed	AMR	2.29	0.00	2.20	3.82%		100%
2.94	66 KV JAFFARPUR	WZAFF114	PANDWALA (N J F)	Mixed	AMR	2.94	0.00	2.81	4.39%		100%

Annexure -1: Proforma for Quarterly Consumer Category-wise Subsidy Billed/Received/Due for period Apr-23 to Jun-23

Consumer Category (Separate for each)	Billed Energy			Subsidized Billed Energy			Applicable rate of Subsidyas notified by State govt.		Subsidy Due from State Govt.			Subsidy Actually Billed / claimed from State Govt. (As against col.12)	Subsidy Received from State Govt. (As against col.13)*	Balance Subsidy yet to be Received from State Govt.	Remarks
	Metered	Un-metered*	Total	Metered (out of col.2)	Un-metered* (out of col.3)	Total	Metered Energy**	Un-metered Energy***	Metered Energy	Un-metered Energy	Total				
1	2	3	4=2+3	5	6	7=5+6	8	9	10=5X8	11=6x9	12=10+11	13	14	15=13-14	
Residential	2033261135	0	2033261135	1083322972	0	1083322972	3.63	0	393	0	393	423	351	72	Average Subsidy rate is calculated for residential consumers up to 400 units monthly consumption and SIKH rights consumers. Applicable subsidies are as follows: Domestic consumers: Up to 200 Units - No charges 201 to 400 units - upto INR 800/- flat discount SIKH RIOTS: 100% Subsidy up to 400 unit consumption. Total subsidy received from Govt. against total claimed amount. Category wise subsidy received is calculated based on weightage of amount claimed in respective consumer categories. Please note that opening balance of subsidy as on 1st Apr 23 was INR 39.41 Cr which is to be received.
Agriculture	74323	0	74323	74323	0	74323	105.00	0	1	0	1	1	1	0	Subsidy given to agricultural consumers is based on fixed charges INR 105/- Per KW per Month hence billed and subsidized energy is not in KWh it is in KW (Load).
Commercial/Industrial – LT	618538780	0	618538780	188554	0	188554	22.00	0	0	0	0	0	0	0	Lawyer Chamber:Subsidy based on Domestic Tariff as per attached order
Commercial/Industrial - HT	356459040	0	356459040	0	0	0	0.00	0	0	0	0	0	0	0	Subsidy is not applicable
Other (specify)**	226079414	0	226079414	33548259	0	33548259	0.11	0	0	0	0	10	0	10	Generation based incentive is applicable for the consumers who have installed rooftop solar system as on or before 19th May, 2019. Generation from Roof top solar system should be in between 550 units to 750 units per KW in six months.
Total	3234412693	0	3234412693	1117134108	0	1117134108		0	395	0	395	434	352	83	Total Subsidy claimed : INR 434.32 Cr which includes opening balance 39.41 Cr on 01 Apr -2023

*Basis of assessment of energy to be provided in the notes along with relevant Government Orders

**Provide copy of relevant Government Orders

**Others :Generation based Incentive is given to Consumer generating solar power as per Mukhya Mantri Solar Power YOJana

***Openig balance as on Apr 01 2023 -39.41 cr

Division-wise status of DT level metering										
Zone Name	Circle Name	Division name	Feeder name	Total No of DT on feeder	No. of unmetered DTs	No of metered DTs			No of DTs with functional meters	
						AMR metered (Communicable)	AMI Metered (Communicable)	Non-AMR/AMI metered (non-communicable)	Communicating (Total No out of 7 & 8)	Non-communicating (Total No out of 7,8 & 9)
1	2	3	4	5=6+7+8+9	6	7	8	9	10	11
BRPL	South 3	Alaknanda	11kv FDR A-BLOCK, KALKAJI	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11kv FDR ALAKNANDA VIA TA	6	0	1	0	5	1	5
BRPL	South 3	Alaknanda	11kv FDR CC MASJID MODH:ID	3	0	0	0	3	0	3
BRPL	South 3	Alaknanda	11kv FDR D-173	3	0	0	0	3	0	3
BRPL	South 3	Alaknanda	11kv FDR EPR GK ENCLAVE-2	3	0	0	0	3	0	3
BRPL	South 3	Alaknanda	11kv FDR G - BLOCK, KALKAJI	9	0	0	0	9	0	9
BRPL	South 3	Alaknanda	11kv FDR GALI NO.-10, GOVINDPURI	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11kv FDR GIRI NAGAR NO.-1	7	0	0	0	7	0	7
BRPL	South 3	Alaknanda	11kv FDR GIRI NAGAR NO.-1 (NEAR METRO STATION)	7	0	0	0	7	0	7
BRPL	South 3	Alaknanda	11kv FDR GIRI NAGAR NO.-2(T-camp B)	4	0	0	0	4	0	4
BRPL	South 3	Alaknanda	11kv FDR GIRI NAGAR SSTN NO.-2 (NEAR METRO STATION)	4	0	0	0	4	0	4
BRPL	South 3	Alaknanda	11kv FDR GOVIND PURI GALI NO.-5	6	0	0	0	6	0	6
BRPL	South 3	Alaknanda	11kv FDR H-BLOCK GOL CHAKKAR	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11kv FDR MUNJAL, KALKAJI EXTN.	4	0	0	0	4	0	4
BRPL	South 3	Alaknanda	11kv FDR O/G ARYA SAMAJ MANDIR KALKAJI	5	0	1	0	4	1	4
BRPL	South 3	Alaknanda	11kv FDR O/G B-26 RMU PHASE-1	2	0	0	0	2	0	2
BRPL	South 3	Alaknanda	11kv FDR O/G C.R PARK-A, S/STN-A	6	0	0	0	6	0	6
BRPL	South 3	Alaknanda	11kv FDR O/G D.L.F, E-BLOCK G.K-2	3	0	0	0	3	0	3
BRPL	South 3	Alaknanda	11kv FDR O/G D.L.F, W-BLOCK G.K-2	1	0	0	0	1	0	1
BRPL	South 3	Alaknanda	11kv FDR O/G DESHBANDHU COLLEGE	3	0	0	0	3	0	3
BRPL	South 3	Alaknanda	11kv FDR O/G E-BLOCK G.K-2	7	0	0	0	7	0	7
BRPL	South 3	Alaknanda	11kv FDR O/G EPDP NO.-1	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11kv FDR O/G EPDP NO.-6	7	0	0	0	7	0	7
BRPL	South 3	Alaknanda	11kv FDR O/G GALI NO 29 TUGHLAKABAD EXTN	2	0	2	0	0	2	0
BRPL	South 3	Alaknanda	11kv FDR O/G GALI NO.-16, GOVIND PURI (TINWALA)	9	0	0	0	9	0	9
BRPL	South 3	Alaknanda	11kv FDR O/G G-BLOCK KALKA JI	6	0	0	0	6	0	6
BRPL	South 3	Alaknanda	11kv FDR O/G KANGAR MOHALLA TUGHLAKABAD VILLAGE	2	0	0	0	2	0	2
BRPL	South 3	Alaknanda	11kv FDR O/G MCD SANITARY LAND	4	0	2	0	2	2	2
BRPL	South 3	Alaknanda	11kv FDR O/G N.B.C.C. OKHLA PHASE-1	2	0	0	0	2	0	2
BRPL	South 3	Alaknanda	11kv FDR O/G POLICE STATION KALKAJI	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11kv FDR O/G PUL PRAHALADPUR	1	0	0	0	1	0	1
BRPL	South 3	Alaknanda	11kv FDR O/G RAMANUJAN COLLEGE	2	0	0	0	2	0	2
BRPL	South 3	Alaknanda	11kv FDR O/G S/S NO.-1 F-BLOCK OKHLA PH.-1	4	0	0	0	4	0	4
BRPL	South 3	Alaknanda	11kv FDR O/G S/S NO.-11 VIA F-90/5 OKHLA PH.-1	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11kv FDR O/G S/S NO.-12, PHASE-1	5	0	2	0	3	2	3
BRPL	South 3	Alaknanda	11kv FDR O/G S/S NO.-2 OKHLA PH.-1	4	0	0	0	4	0	4
BRPL	South 3	Alaknanda	11kv FDR O/G S/S NO.-A DSIDC OKHLA PH.-1	8	0	2	0	6	2	6
BRPL	South 3	Alaknanda	11kv FDR O/G SHIVALIK APPARTMENT	3	0	0	0	3	0	3
BRPL	South 3	Alaknanda	11kv FDR O/G SSTN. NO.-1, NARMADA APPARTMENT	11	0	0	0	11	0	11
BRPL	South 3	Alaknanda	11kv FDR O/G TARA APPARTMENT	4	0	0	0	4	0	4
BRPL	South 3	Alaknanda	11kv FDR O/G TO CCI COMPLEX NO.-1	6	0	1	0	5	1	5
BRPL	South 3	Alaknanda	11kv FDR O/G TO CCI COMPLEX NO.-2	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11kv FDR O/G TO D.D.A SLUM KALKA JI	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11kv FDR O/G TO DDA JANTA FLATS KALKAJI	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11kv FDR O/G TO DESHBANDHU APPARTMENT	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11kv FDR O/G TO DTC WORK SHOP	2	0	0	0	2	0	2
BRPL	South 3	Alaknanda	11kv FDR O/G TO E.P.D.P SUB/STN NO.-2	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11kv FDR O/G TO KAVERI APPARTMENT	11	0	0	0	11	0	11
BRPL	South 3	Alaknanda	11kv FDR O/G TO MANDAKINI APPT.	6	0	0	0	6	0	6
BRPL	South 3	Alaknanda	11kv FDR O/G TO N.R.I COMPLEX S/S	7	0	0	0	7	0	7
BRPL	South 3	Alaknanda	11kv FDR O/G TO NILGIRI SUB.STN. NO.-1	10	0	0	0	10	0	10
BRPL	South 3	Alaknanda	11kv FDR O/G TO S/S NO.-10	4	0	0	0	4	0	4
BRPL	South 3	Alaknanda	11kv FDR O/G TO S/S NO.-3 OKHLA PHASE-1	4	0	1	0	3	1	3
BRPL	South 3	Alaknanda	11kv FDR O/G TO S/S NO.-7	4	0	0	0	4	0	4
BRPL	South 3	Alaknanda	11kv FDR O/G TO S/S NO.-C OKHLA PH.-1	5	0	0	0	5	0	5

BRPL	South 3	Alaknanda	11kv FDR O/G TO S/STN-A OKHLA PHASE-1	4	0	1	0	3	1	3
BRPL	South 3	Alaknanda	11kv FDR O/G TO S-BLOCK G.K-II	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11kv FDR O/G VILLAGE TEHKHAND	4	0	0	0	4	0	4
BRPL	South 3	Alaknanda	11kv FDR O/G VIPS INDIA	1	0	0	0	1	0	1
BRPL	South 3	Alaknanda	11kv FDR O/G W-1 BLOCK G.K-2	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11kv FDR OUT GOING FEEDER-1, M-BLOCK MOTHER DAIRY G.K-II	8	0	0	0	8	0	8
BRPL	South 3	Alaknanda	11kv FDR OUT GOING FEEDER-2, G-BLOCK MASJID MOTH G.K-II	6	0	0	0	6	0	6
BRPL	South 3	Alaknanda	11kv FDR OUT GOING FEEDER-6,E-BLOCK G.K-2 (SEHGAL MKT.-2)	6	0	0	0	6	0	6
BRPL	South 3	Alaknanda	11kv FDR OUT GOING FEEDER-8,NEHRU APPARTMENT	7	0	0	0	7	0	7
BRPL	South 3	Alaknanda	11kv FDR OUT GOING VSNL (TCIL)	6	0	0	0	6	0	6
BRPL	South 3	Alaknanda	11kv FDR POCKET A-3,KALKAJI EXTN.	6	0	0	0	6	0	6
BRPL	South 3	Alaknanda	11kv FDR POKET A-10 KALKAJI EXTN.	7	0	0	0	7	0	7
BRPL	South 3	Alaknanda	11kv FDR POKET A-12 KALKAJI EXTN.	12	0	5	0	7	5	7
BRPL	South 3	Alaknanda	11kv FDR POKET A-8 KALKAJI EXTN.	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11kv FDR S/S NO.-1, TUGLAKABAD EXTN.	7	0	3	0	4	3	4
BRPL	South 3	Alaknanda	11kv FDR S/S NO.-11 O/H OIA-1	5	0	1	0	4	1	4
BRPL	South 3	Alaknanda	11kv FDR S/S NO.-4	10	0	5	0	5	5	5
BRPL	South 3	Alaknanda	11kv FDR S/S NO.-6	4	0	1	0	3	1	3
BRPL	South 3	Alaknanda	11kv FDR S/S NO.-8, OIA-1	10	0	0	0	10	0	10
BRPL	South 3	Alaknanda	11kv FDR S/S NO.-E(E.S.I)	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11KV FDR SSTN NO 4 SLUM FLATS A-14 KALKA JI EXT	10	0	0	0	10	0	10
BRPL	South 3	Alaknanda	11KV FDR SSTN NO.1 SLUM FLATS, A214, KALKA JI, EXT.	4	0	0	0	4	0	4
BRPL	South 3	Alaknanda	11kv FDR TARA APPARTMENT	2	0	0	0	2	0	2
BRPL	South 3	Alaknanda	11kv FDR TODAY HOTEL FEEDER NO.-1 + R.M.U	3	0	0	0	3	0	3
BRPL	South 3	Alaknanda	11kv FDR TODAY HOTEL FEEDER NO.-2	1	0	0	0	1	0	1
BRPL	South 3	Alaknanda	11kv FDR TUGLAKABAD EXTN.	5	0	0	0	5	0	5
BRPL	South 3	Alaknanda	11kv STR 100KVA STATION TRF. NO.-1	6	0	1	0	5	1	5
BRPL	South 3	Alaknanda	11kv STR 400KVA STATION TRANSFORMER	31	0	13	0	18	13	18
BRPL	South 3	Alaknanda	11kv STR 400kVA STATION TRF. NO.-2	1	0	0	0	1	0	1
BRPL	South 1	Khanpur	11 KV FDR O/G S/S-5, H-BLK. TIGRI	6	0	0	0	6	0	6
BRPL	South 1	Khanpur	11 KV FDR O/G, RMU IN GRID	7	0	0	0	7	0	7
BRPL	South 1	Khanpur	11kv FDR DAKSHIN PURI S/S NO.-II (NEW)	5	0	0	0	5	0	5
BRPL	South 1	Khanpur	11KV FDR DDA GALI NO.-20 MADANGIR	8	0	0	0	8	0	8
BRPL	South 1	Khanpur	11KV FDR EO 325 RES FLATS AT 22BN ITBP CAMPUS	2	0	0	0	2	0	2
BRPL	South 1	Khanpur	11kv FDR G & H BLOCK S/VIHAR	5	0	0	0	5	0	5
BRPL	South 1	Khanpur	11kv FDR G-2 K-19 SANGAM VIHAR	3	0	0	0	3	0	3
BRPL	South 1	Khanpur	11kv FDR HAMDARD D.P	6	0	0	0	6	0	6
BRPL	South 1	Khanpur	11kv FDR IGNOU CAMPUS S/S NO.-3 FDR.-1 (GALI NO.-5, SANGAM VIHAR)	7	0	0	0	7	0	7
BRPL	South 1	Khanpur	11kv FDR KHANPUR COMP. CENTER	1	0	0	0	1	0	1
BRPL	South 1	Khanpur	11kv FDR KISHORE DP SSTN	9	0	1	0	8	1	8
BRPL	South 1	Khanpur	11KV FDR L.S.C NO.-1 MADANGIR	3	0	0	0	3	0	3
BRPL	South 1	Khanpur	11KV FDR L.S.C NO-2 VIA SS NO-15	7	0	0	0	7	0	7
BRPL	South 1	Khanpur	11KV FDR MADANGIR S/S NO.-1	6	0	0	0	6	0	6
BRPL	South 1	Khanpur	11kv FDR O/G A-BLOCK RAJU PARK	2	0	0	0	2	0	2
BRPL	South 1	Khanpur	11kv FDR O/G B-BLOCK DURGA VIHAR	3	0	0	0	3	0	3
BRPL	South 1	Khanpur	11kv FDR O/G B-II/1, MADANGIR	5	0	0	0	5	0	5
BRPL	South 1	Khanpur	11kv FDR O/G D.D.A TIGRI	12	0	3	0	9	3	9
BRPL	South 1	Khanpur	11kv FDR O/G D.M.S TRUST	9	0	0	0	9	0	9
BRPL	South 1	Khanpur	11kv FDR O/G DAKSHIN PURI S/S NO.-2	7	0	0	0	7	0	7
BRPL	South 1	Khanpur	11kv FDR O/G D-BLOCK SANGAM VIHAR	1	0	0	0	1	0	1
BRPL	South 1	Khanpur	11kv FDR O/G D-BLOCK, SANGA VIHAR S/STN.-8	6	0	0	0	6	0	6
BRPL	South 1	Khanpur	11kv FDR O/G DEVLII EXTENSION	3	0	0	0	3	0	3
BRPL	South 1	Khanpur	11kv FDR O/G DR. KARAN SINGH SHOOTING RANGE	6	0	0	0	6	0	6
BRPL	South 1	Khanpur	11kv FDR O/G F-1 S.STN. NO.2 S. VIHAR (NEW)	7	0	0	0	7	0	7
BRPL	South 1	Khanpur	11kv FDR O/G F-2 PLINTH MOUNTED SANGAM VIHAR	3	0	0	0	3	0	3
BRPL	South 1	Khanpur	11kv FDR O/G HOT MIX PLANT	7	0	0	0	7	0	7
BRPL	South 1	Khanpur	11kv FDR O/G I-BLOCK, LAL KUAN	5	0	0	0	5	0	5
BRPL	South 1	Khanpur	11kv FDR O/G INSTITUTIONAL AREA NO-1	3	0	0	0	3	0	3
BRPL	South 1	Khanpur	11kv FDR O/G J.J KHANPUR	5	0	0	0	5	0	5
BRPL	South 1	Khanpur	11kv FDR O/G KHANPUR (KHATTA WALA)	2	0	0	0	2	0	2
BRPL	South 1	Khanpur	11kv FDR O/G LAL KUAN	7	0	0	0	7	0	7
BRPL	South 1	Khanpur	11kv FDR O/G MAITRIKA ASHRAM:PL	5	0	0	0	5	0	5

BRPL	South 1	Khanpur	11kV FDR O/G MCD SCHOOL ROAD KHANPUR	6	0	2	0	4	2	4
BRPL	South 1	Khanpur	11kV FDR O/G PUL PRAHLADPUR SSTN NO-1	8	0	3	0	5	3	5
BRPL	South 1	Khanpur	11kV FDR O/G RAVIDAS PRAHLADPUR	7	0	3	0	4	3	4
BRPL	South 1	Khanpur	11kV FDR O/G RMU AT BATRA GRID	5	0	0	0	5	0	5
BRPL	South 1	Khanpur	11kV FDR O/G RMU L-15 SANGAM VIHAR	1	0	0	0	1	0	1
BRPL	South 1	Khanpur	11kV FDR O/G RMU L-1A SANGAM VIHAR	4	0	0	0	4	0	4
BRPL	South 1	Khanpur	11kV FDR O/G S/S NO.-3, DAKSHINPURI VIA BOOSTER PUMP	2	0	0	0	2	0	2
BRPL	South 1	Khanpur	11kV FDR O/G S/S NO.4 DAKSHINPURI	3	0	0	0	3	0	3
BRPL	South 1	Khanpur	11kV FDR O/G S/S NO.5 DAKSHINPURI	10	0	0	0	10	0	10
BRPL	South 1	Khanpur	11kV FDR O/G S/S NO.-7, DAKSHIN PURI	1	0	0	0	1	0	1
BRPL	South 1	Khanpur	11kV FDR O/G TIGRI KIOSK	6	0	0	0	6	0	6
BRPL	South 1	Khanpur	11kV FDR O/G TO E-1st MADANGIR PHASE-1(VIA C-BLOCK MCD SCHOOL) D.PURI	4	0	0	0	4	0	4
BRPL	South 1	Khanpur	11kV FDR O/G TO S/S NO.-5 DAKSHIN PURI	1	0	0	0	1	0	1
BRPL	South 1	Khanpur	11kV FDR O/G TO TIN WAKA S/STN. C-BLOCK SANGAM VHR.	3	0	0	0	3	0	3
BRPL	South 1	Khanpur	11kV FDR O/G TUGLAKABAD INST. AREA	4	0	0	0	4	0	4
BRPL	South 1	Khanpur	11kV FDR O/G VAYUSENABAD	1	0	0	0	1	0	1
BRPL	South 1	Khanpur	11kV FDR OG H-16 RAMNIWAS DP	2	0	0	0	2	0	2
BRPL	South 1	Khanpur	11kV FDR OG TO B&C BLOCK JAWAHAR PARK I/D	2	0	2	0	0	2	0
BRPL	South 1	Khanpur	11kV FDR OG TO D-BLOCK SANGAM VIHAR (NEW)	3	0	0	0	3	0	3
BRPL	South 1	Khanpur	11kV FDR OG TO D-BLOCK SANGAM VIHAR (OLD)	5	0	0	0	5	0	5
BRPL	South 1	Khanpur	11kV FDR OG TO JHEEL DP NEAR MANDIR	4	0	0	0	4	0	4
BRPL	South 1	Khanpur	11kV FDR OG TO L-BLOCK SAINI WALA	5	0	0	0	5	0	5
BRPL	South 1	Khanpur	11kV FDR SSTN NO-1, FEEDER-1 SANGAM VIHAR	6	0	0	0	6	0	6
BRPL	South 1	Khanpur	11kV FDR STATION C-2 RAJU PARK	5	0	0	0	5	0	5
BRPL	South 1	Khanpur	11kV FDR STATION DEVLJI JOHAR	5	0	0	0	5	0	5
BRPL	South 1	Khanpur	11kV FDR STATION SANGWAN DP	4	0	0	0	4	0	4
BRPL	South 1	Khanpur	11kV FDR STORME WATER PUMPING STN.	5	0	1	0	4	1	4
BRPL	South 1	Khanpur	11kV FDR TIGRI J.J KHANPUR	8	0	0	0	8	0	8
BRPL	South 1	Khanpur	11kV O/G FDR J-2B Makhn Chor	2	0	0	0	2	0	2
BRPL	South 1	Khanpur	11kV STR 100kVA SATTION TRANSFORMER	2	0	0	0	2	0	2
BRPL	South 1	Khanpur	11kV STR 400kVA SATTION TRANSFORMER	2	0	0	0	2	0	2
BRPL	South 1	Khanpur	OG JAWAHAR PARK BLOCK A	2	0	1	0	1	1	1
BRPL	South 4	Saket	11kV FDR ADCHINI CROSSING	6	0	1	0	5	1	5
BRPL	South 4	Saket	11kV FDR ADVOCATE CEMBER NO.-2	2	0	2	0	0	2	0
BRPL	South 4	Saket	11kV FDR ANSAL FARMS	30	0	25	0	5	25	5
BRPL	South 4	Saket	11kV FDR ANUPAM GARDEN/SAINT MARRY	13	0	10	0	3	10	3
BRPL	South 4	Saket	11kV FDR AUROBINDO MARG	6	0	5	0	1	5	1
BRPL	South 4	Saket	11kV FDR C.C ANUPAM	9	0	7	0	2	7	2
BRPL	South 4	Saket	11kV FDR CENTRUM MALL SULTANPUR	5	0	2	0	3	2	3
BRPL	South 4	Saket	11kV FDR CHATTARPUR ENCLAVE BARRIER	4	0	0	0	4	0	4
BRPL	South 4	Saket	11kV FDR D.L.F GATE NO.-1	7	0	2	0	5	2	5
BRPL	South 4	Saket	11kV FDR DDA KHIRIKI	5	0	5	0	0	5	0
BRPL	South 4	Saket	11kV FDR DLF GATE NO.-2 (MAIDAN GARHI)	5	0	2	0	3	2	3
BRPL	South 4	Saket	11kV FDR DMRC VIA ANDHRA SCHOOL S/S AND BLIND SCHOOL	7	0	6	0	1	6	1
BRPL	South 4	Saket	11kV FDR I.I.P.M NO.-1	16	0	14	0	2	14	2
BRPL	South 4	Saket	11kV FDR IGNOU KIOSK	8	0	5	0	3	5	3
BRPL	South 4	Saket	11kV FDR JAHAPANAH NO.-1 + MGF MALL VIA RMU NEAR GATE	5	0	5	0	0	5	0
BRPL	South 4	Saket	11kV FDR J-BLOCK SAKET	9	0	5	0	4	5	4
BRPL	South 4	Saket	11kV FDR LADO SARAI	4	0	3	0	1	3	1
BRPL	South 4	Saket	11kV FDR MAIDAN GARHI VILLAGE	6	0	6	0	0	6	0
BRPL	South 4	Saket	11kV FDR MAIDANGARHI EXTN TUBEWELL VIA MCD PARK CHATTERPUR	2	0	1	0	1	1	1
BRPL	South 4	Saket	11kV FDR MEERA CHATTARPUR VILLAGE	3	0	3	0	0	3	0
BRPL	South 4	Saket	11kV FDR MMTc (VIA 81/3 ADCHINI)	6	0	4	0	2	4	2
BRPL	South 4	Saket	11kV FDR MODI HOSPITAL	10	0	4	0	6	4	6
BRPL	South 4	Saket	11kV FDR N-BLOCK SAINIK FARM	9	0	7	0	2	7	2
BRPL	South 4	Saket	11kV FDR NEB SARAI VADERA P/M SSTN.	3	0	2	0	1	2	1
BRPL	South 4	Saket	11kV FDR NICF VIA AYA NAGAR	3	0	2	0	1	2	1
BRPL	South 4	Saket	11kV FDR O/G 11kV MALVIYA NAGAR (VIA MMTc COLONEY)	5	0	4	0	1	4	1

BRPL	South 4	Saket	11KV FDR O/G AIR FORCE ARJANGARH NO-1	1	0	0	0	1	0	1
BRPL	South 4	Saket	11KV FDR O/G AIR FORCE ARJANGARH NO-2	1	0	0	0	1	0	1
BRPL	South 4	Saket	11kv FDR O/G ANUPAM APPARTMENT	5	0	4	0	1	4	1
BRPL	South 4	Saket	11KV FDR O/G ASHWANI KUMAR MEHRA HOTEL	15	0	12	0	3	12	3
BRPL	South 4	Saket	11kv FDR O/G BALMIKI MANDIR CHIRAG DELHI	2	0	1	0	1	1	1
BRPL	South 4	Saket	11kv FDR O/G C-1 SFS SEKH SARAI PHASE-1	4	0	1	0	3	1	3
BRPL	South 4	Saket	11kv FDR O/G CARRIAPPA MARG SAINIK FARM	6	0	6	0	0	6	0
BRPL	South 4	Saket	11KV FDR O/G CHATTARPUR-2	14	0	8	0	6	8	6
BRPL	South 4	Saket	11kv FDR O/G CHIRAG DELHI KHATTA	4	0	4	0	0	4	0
BRPL	South 4	Saket	11kv FDR O/G CHIRAG DELHI KIOSK	6	0	4	0	2	4	2
BRPL	South 4	Saket	11KV FDR O/G D.J.B BOOSTER PUMP CHATTARPUR PAHARI	13	0	0	0	13	0	13
BRPL	South 4	Saket	11KV FDR O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	14	0	11	0	3	11	3
BRPL	South 4	Saket	11kv FDR O/G DMRC	2	0	2	0	0	2	0
BRPL	South 4	Saket	11kv FDR O/G F-BLOCK MALVIYA NAGAR	6	0	3	0	3	3	3
BRPL	South 4	Saket	11KV FDR O/G I.I.P.M NO.-2	15	0	13	0	2	13	2
BRPL	South 4	Saket	11kv FDR O/G IGNOU S/S NO.-5	6	0	5	0	1	5	1
BRPL	South 4	Saket	11KV FDR O/G JONAPUR	27	0	21	0	6	21	6
BRPL	South 4	Saket	11kv FDR O/G KHIRKI BANDH	5	0	2	0	3	2	3
BRPL	South 4	Saket	11kv FDR O/G MAIN ROAD 192-SAINIK FARM	7	0	6	0	1	6	1
BRPL	South 4	Saket	11kv FDR O/G MALVIYA NGR. HOSPITAL	4	0	4	0	0	4	0
BRPL	South 4	Saket	11kv FDR O/G MAX DEVIKA DEVI HOSPITAL	4	0	0	0	4	0	4
BRPL	South 4	Saket	11kv FDR O/G MIG DDA FLATS SAKET	7	0	5	0	2	5	2
BRPL	South 4	Saket	11kv FDR O/G NIL BLOCK MALVIYA NAGAR	5	0	4	0	1	4	1
BRPL	South 4	Saket	11KV FDR O/G NTRO CKT.-2	5	0	3	0	2	3	2
BRPL	South 4	Saket	11kv FDR O/G P-BLOCK MALVIYA NAGAR S/STN.	5	0	3	0	2	3	2
BRPL	South 4	Saket	11KV FDR O/G PURANA AYA NAGAR	8	0	8	0	0	8	0
BRPL	South 4	Saket	11kv FDR O/G R.P.S SEKH SARAI PHASE-1	4	0	3	0	1	3	1
BRPL	South 4	Saket	11KV FDR O/G RUMALO DEVI	38	0	24	0	14	24	14
BRPL	South 4	Saket	11kv FDR O/G S/S NO.-31. INDUS. AREA SAIKH SARAI PHASE-2	4	0	4	0	0	4	0
BRPL	South 4	Saket	11kv FDR O/G S/S NO.-6 SAIKH SARAI PHASE-2	2	0	2	0	0	2	0
BRPL	South 4	Saket	11KV FDR O/G SEC-1 S/S NO.-1 PUSHUP VIHAR	12	0	10	0	2	10	2
BRPL	South 4	Saket	11kv FDR O/G TO 80-BLOCK MALVIYA NAGAR	5	0	4	0	1	4	1
BRPL	South 4	Saket	11kv FDR O/G TO ANANT RAJ	8	0	3	0	5	3	5
BRPL	South 4	Saket	11KV FDR O/G TO ASOLA BANDH	22	0	17	0	5	17	5
BRPL	South 4	Saket	11KV FDR O/G TO ASOLA VILLAGE	8	0	6	0	2	6	2
BRPL	South 4	Saket	11KV FDR O/G TO BHATI MINES	31	0	28	0	3	28	3
BRPL	South 4	Saket	11kv FDR O/G TO BHAVISHAYA NIDHI ENC.	7	0	5	0	2	5	2
BRPL	South 4	Saket	11kv FDR O/G TO C-BLOCK SHIVALIK	4	0	2	0	2	2	2
BRPL	South 4	Saket	11KV FDR O/G TO CHADDA MURGI	30	0	24	0	6	24	6
BRPL	South 4	Saket	11kv FDR O/G TO COMP. CENTER MALVIYA NAGAR	5	0	3	0	2	3	2
BRPL	South 4	Saket	11kv FDR O/G TO D.L.F CHATTARPUR	11	0	5	0	6	5	6
BRPL	South 4	Saket	11KV FDR O/G TO DERA BHATI	18	0	12	0	6	12	6
BRPL	South 4	Saket	11KV FDR O/G TO FATEHPUR BERI C.C	4	0	4	0	0	4	0
BRPL	South 4	Saket	11kv FDR O/G TO F-BLOCK (K) S/STN.MALVIYA NAGAR -2	3	0	2	0	1	2	1
BRPL	South 4	Saket	11KV FDR O/G TO GATE NO.-2-C RADHA SWAMI	11	0	6	0	5	6	5
BRPL	South 4	Saket	11kv FDR O/G TO HARSWAROOP COLONY	5	0	3	0	2	3	2
BRPL	South 4	Saket	11kv FDR O/G TO JONAPUR	6	0	5	0	1	5	1
BRPL	South 4	Saket	11kv FDR O/G TO L-BLOCK M. NAGAR	4	0	2	0	2	2	2
BRPL	South 4	Saket	11KV FDR O/G TO M.C.Tr. DLF (MEHAR CHAND)	41	0	32	0	9	32	9
BRPL	South 4	Saket	11KV FDR O/G TO MANGALAPURI	33	0	23	0	10	23	10
BRPL	South 4	Saket	11KV FDR O/G TO MCD PARK CHATTARPUR NO.-1	5	0	1	0	4	1	4
BRPL	South 4	Saket	11kv FDR O/G TO N.B.C.C	4	0	3	0	1	3	1
BRPL	South 4	Saket	11kv FDR O/G TO ORTHO NOVA HOSPITAL	4	0	4	0	0	4	0
BRPL	South 4	Saket	11KV FDR O/G TO RAJPUR KHURD	6	0	2	0	4	2	4
BRPL	South 4	Saket	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	25	0	21	0	4	21	4
BRPL	South 4	Saket	11kv FDR O/G TO RPS\SAIKH SARAI PHASE-1	4	0	4	0	0	4	0

BRPL	South 4	Saket	11kv FDR O/G TO S.T.P MEHRAULI	12	0	6	0	6	6	6
BRPL	South 4	Saket	11kv FDR O/G TO SARVAPRIYA VIHAR I/D STN.	6	0	6	0	0	6	0
BRPL	South 4	Saket	11kv FDR O/G TO SARVO PRIYA APARTMENT	9	0	7	0	2	7	2
BRPL	South 4	Saket	11kv FDR O/G TO SATABARI	2	0	0	0	2	0	2
BRPL	South 4	Saket	11KV FDR O/G TO SHANIDHAM ROAD	27	0	23	0	4	23	4
BRPL	South 4	Saket	11KV FDR O/G TO SHANTI KHANNA	16	0	15	0	1	15	1
BRPL	South 4	Saket	11KV FDR O/G TO SULTANPUR COLONY	9	0	7	0	2	7	2
BRPL	South 4	Saket	11kv FDR OG TO BANERJEE HOSPITAL SAIDULAJAB	4	0	3	0	1	3	1
BRPL	South 4	Saket	11kv FDR OG TO E-2 SAKET	4	0	2	0	2	2	2
BRPL	South 4	Saket	11kv FDR OG TO G BLK AYA NAGAR	9	0	7	0	2	7	2
BRPL	South 4	Saket	11kv FDR OG TO J-12 SAKET	7	0	5	0	2	5	2
BRPL	South 4	Saket	11kv FDR OG TO J-57 PARYAVARAN VIA ANUPAM APARTMENT	4	0	4	0	0	4	0
BRPL	South 4	Saket	11kv FDR OG TO LADO SARAI PREM SINGH	9	0	7	0	2	7	2
BRPL	South 4	Saket	11kv FDR OG TO W-2 SAINIK FARM	19	0	11	0	8	11	8
BRPL	South 4	Saket	11KV FDR OG W-5B SAINIK FARM	8	0	7	0	1	7	1
BRPL	South 4	Saket	11kv FDR P.T.S COLONY	2	0	2	0	0	2	0
BRPL	South 4	Saket	11kv FDR PANDIT MOHALLA VIA GADAIPUR CHECK POST	5	0	4	0	1	4	1
BRPL	South 4	Saket	11KV FDR PUSHP VIHAR S/S NO.-12	20	0	19	0	1	19	1
BRPL	South 4	Saket	11KV FDR PUSHP VIHAR SEC.-1, S/S NO.-5	7	0	7	0	0	7	0
BRPL	South 4	Saket	11kv FDR RAJPUR EXTENSION	12	0	5	0	7	5	7
BRPL	South 4	Saket	11KV FDR RES. S/S NO.-1, COURT COMPL.	3	0	3	0	0	3	0
BRPL	South 4	Saket	11KV FDR RES. S/S NO.-2, COURT COMPL.	2	0	2	0	0	2	0
BRPL	South 4	Saket	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	66	0	54	0	12	54	12
BRPL	South 4	Saket	11KV FDR RSSB SSTN NO-1	25	0	19	0	6	19	6
BRPL	South 4	Saket	11KV FDR RSSB SSTN NO-2	3	0	1	0	2	1	2
BRPL	South 4	Saket	11kv FDR RSSB SSTN NO-4	2	0	1	0	1	1	1
BRPL	South 4	Saket	11kv FDR S/S NO.-09, IGNOU CAMPUS	6	0	1	0	5	1	5
BRPL	South 4	Saket	11KV FDR S/S NO.-1, ADVOCATE CHEMBER NO.-1 (COURT COMPLEX)	3	0	1	0	2	1	2
BRPL	South 4	Saket	11kv FDR S/S NO.-1, NEB SARAI EXTN. (GOEL S/S)	5	0	5	0	0	5	0
BRPL	South 4	Saket	11kv FDR S/S NO.-11, SEC-4 PUSHP VIHAR	11	0	7	0	4	7	4
BRPL	South 4	Saket	11kv FDR S/STN. NO.-04, SECTOR-3 PUSHP VIHAR (VIA NEW RMU OUT SIDE GRID)	4	0	4	0	0	4	0
BRPL	South 4	Saket	11KV FDR SAKET SPORTS COMPLEX	2	0	0	0	2	0	2
BRPL	South 4	Saket	11kv FDR SARVODAYA ENCLAVE	7	0	4	0	3	4	3
BRPL	South 4	Saket	11kv FDR SHIVALIK A-BLOCK	6	0	1	0	5	1	5
BRPL	South 4	Saket	11kv FDR SPORTS COMPLEX SAKET	6	0	5	0	1	5	1
BRPL	South 4	Saket	11kv FDR VSNL GATE	1	0	0	0	1	0	1
BRPL	South 4	Saket	11KV O/G SFS B1 SHIEKH SARAI PH-1	6	0	4	0	2	4	2
BRPL	South 4	Saket	11KV O/G TO M.E.S	15	0	13	0	2	13	2
BRPL	South 4	Saket	11kv STR 100KVA STATION TRANS.	3	0	3	0	0	3	0
BRPL	South 4	Saket	11kv STR 100KVA STATION TRANSFORMER	18	0	5	0	13	5	13
BRPL	South 4	Saket	11kv STR 100kVA STATION TRANSFORMER.-1	1	0	1	0	0	1	0
BRPL	South 4	Saket	11kv STR 100kVA STATION TRANSFORMER.-2	1	0	1	0	0	1	0
BRPL	South 4	Saket	11kv STR 400kVA STATION TRF	1	0	0	0	1	0	1
BRPL	South 4	Saket	11kv STR LOCAL TR	1	0	1	0	0	1	0
BRPL	South 4	Saket	11kv STR STATION TRANSFORMER	1	0	1	0	0	1	0
BRPL	South 4	Vasant Kunj	11 kv FDR O/G TO LIVER INSTITUTE VASANT KUNJ	20	0	14	0	6	14	6
BRPL	South 4	Vasant Kunj	11kv 160 HIG DDA FLATS S/S B-2 VKJ	6	0	6	0	0	6	0
BRPL	South 4	Vasant Kunj	11kv FDR 11kv O/G S/STN. NO.-1,1904 MEGHA HOUSING V. KUNJ	5	0	3	0	2	3	2
BRPL	South 4	Vasant Kunj	11kv FDR A.B HOTEL	2	0	2	0	0	2	0
BRPL	South 4	Vasant Kunj	11kv FDR AVIJIT MAHIPALPUR	11	0	6	0	5	6	5
BRPL	South 4	Vasant Kunj	11kv FDR B-1, S/S NO.-1, VASANT KUNJ	11	0	10	0	1	10	1
BRPL	South 4	Vasant Kunj	11kv FDR B-8 V. KUNJ (VIA GOINKA SCHOOL)	4	0	4	0	0	4	0
BRPL	South 4	Vasant Kunj	11kv FDR BIJWASAN	13	0	7	0	6	7	6
BRPL	South 4	Vasant Kunj	11kv FDR C-8 S/S NO.-1 F-2	1	0	1	0	0	1	0
BRPL	South 4	Vasant Kunj	11kv FDR C-8 S/S NO.-1 VASANT KUNJ	8	0	5	0	3	5	3
BRPL	South 4	Vasant Kunj	11kv FDR C-9 S/S NO.-2 VASANT KUNJ	5	0	4	0	1	4	1
BRPL	South 4	Vasant Kunj	11kv FDR C-9 S/S NO.-5 VASANT KUNJ	6	0	3	0	3	3	3
BRPL	South 4	Vasant Kunj	11kv FDR FORTIS HOSPITAL FEEDER-2 DAHYA KISANGARH (RMU IN GRID)	6	0	4	0	2	4	2
BRPL	South 4	Vasant Kunj	11kv FDR GOLDEN GATE WESTERN GREEN	4	0	4	0	0	4	0
BRPL	South 4	Vasant Kunj	11kv FDR HINDUSTAN PETROLIUM	4	0	3	0	1	3	1

BRPL	South 4	Vasant Kunj	11kv FDR I.A.A.I COLONY	7	0	6	0	1	6	1
BRPL	South 4	Vasant Kunj	11kv FDR INSITUATIONAL AREA VASANT KUNJ.	2	0	2	0	0	2	0
BRPL	South 4	Vasant Kunj	11kv FDR INTERCONNECTOTR NO.-1(KAPASHERA)	21	0	11	0	10	11	10
BRPL	South 4	Vasant Kunj	11kv FDR INTERCONNECTOTR NO.-2(KAPASHERA)	17	0	13	0	4	13	4
BRPL	South 4	Vasant Kunj	11kv FDR KAPASHERA O/H	13	0	5	0	8	5	8
BRPL	South 4	Vasant Kunj	11kv FDR KAPASHERA U/G	3	0	1	0	2	1	2
BRPL	South 4	Vasant Kunj	11kv FDR L.I.G MASOODPUR + I.S.I.D V. KUNJ	1	0	1	0	0	1	0
BRPL	South 4	Vasant Kunj	11kv FDR LIVER HOSPITAL(DIVISION VASANT KUNJ)	4	0	3	0	1	3	1
BRPL	South 4	Vasant Kunj	11kv FDR MAHIPAL PUR	2	0	0	0	2	0	2
BRPL	South 4	Vasant Kunj	11kv FDR MOTHER DAIRY S/S VIA WARD NO.2 (RMU)	7	0	3	0	4	3	4
BRPL	South 4	Vasant Kunj	11kv FDR NAGAL DAIRY	4	0	3	0	1	3	1
BRPL	South 4	Vasant Kunj	11kv FDR NANGAL DAIRY NO.-1	7	0	6	0	1	6	1
BRPL	South 4	Vasant Kunj	11kv FDR NANGAL DAIRY O/H	3	0	3	0	0	3	0
BRPL	South 4	Vasant Kunj	11kv FDR NICF GHITORNI	28	0	16	0	12	16	12
BRPL	South 4	Vasant Kunj	11kv FDR NTRO NO.-1 (OPP. GHITORANI BUS STAND)	10	0	6	0	4	6	4
BRPL	South 4	Vasant Kunj	11kv FDR O/G AIRFORCE RAJOKARI	20	0	11	0	9	11	9
BRPL	South 4	Vasant Kunj	11kv FDR O/G APEX HOMES PRIVATE LIMITED	10	0	7	0	3	7	3
BRPL	South 4	Vasant Kunj	11kv FDR O/G BLUE DARK KAPASHERA	3	0	2	0	1	2	1
BRPL	South 4	Vasant Kunj	11kv FDR O/G EIH OBERAI CATERING	1	0	1	0	0	1	0
BRPL	South 4	Vasant Kunj	11kv FDR O/G GMR OPPOSITE PALAM GRID	9	0	3	0	6	3	6
BRPL	South 4	Vasant Kunj	11kv FDR O/G HOLY CHOWK BIJWASAN	9	0	7	0	2	7	2
BRPL	South 4	Vasant Kunj	11kv FDR O/G JAI SINGH	7	0	4	0	3	4	3
BRPL	South 4	Vasant Kunj	11kv FDR O/G MEHRAM NAGAR	8	0	3	0	5	3	5
BRPL	South 4	Vasant Kunj	11kv FDR O/G NANGAL DAIRY NO.-II	4	0	3	0	1	3	1
BRPL	South 4	Vasant Kunj	11kv FDR O/G NAVAL KAPASHERA	10	0	6	0	4	6	4
BRPL	South 4	Vasant Kunj	11kv FDR O/G NSG WESTERN GREEN	27	0	20	0	7	20	7
BRPL	South 4	Vasant Kunj	11kv FDR O/G PALAM MEHRAM NAGAR	8	0	5	0	3	5	3
BRPL	South 4	Vasant Kunj	11kv FDR O/G PICNIC HUT VIA TEMPO STAND	7	0	5	0	2	5	2
BRPL	South 4	Vasant Kunj	11kv FDR O/G RAJOKARI	10	0	8	0	2	8	2
BRPL	South 4	Vasant Kunj	11kv FDR O/G RANG PURI NO-II	6	0	4	0	2	4	2
BRPL	South 4	Vasant Kunj	11kv FDR O/G S/STN. NO.-1, D-6 V.KUNJ	4	0	3	0	1	3	1
BRPL	South 4	Vasant Kunj	11kv FDR O/G S/STN. NO.-10,1904 MEGHA HOUSING V. KUNJ	8	0	7	0	1	7	1
BRPL	South 4	Vasant Kunj	11kv FDR O/G S/STN. NO.-13,1904 MEGHA HOUSING V. KUNJ	6	0	6	0	0	6	0
BRPL	South 4	Vasant Kunj	11kv FDR O/G S/STN. NO.-3,1904-MEGHA HOUSING V. KUNJ	4	0	4	0	0	4	0
BRPL	South 4	Vasant Kunj	11kv FDR O/G S/STN. NO.-3,805 MEGHA HOUSING V. KUNJ	8	0	7	0	1	7	1
BRPL	South 4	Vasant Kunj	11kv FDR O/G S/STN. NO.-4,1904 MEGHA HOUSING V. KUNJ	10	0	9	0	1	9	1
BRPL	South 4	Vasant Kunj	11kv FDR O/G S/STN. NO.-7 1904 MEGHA HOUSING V. KUNJ	6	0	4	0	2	4	2
BRPL	South 4	Vasant Kunj	11kv FDR O/G SALOON APPARTMENT	3	0	2	0	1	2	1
BRPL	South 4	Vasant Kunj	11kv FDR O/G TEMPO STAND	7	0	6	0	1	6	1
BRPL	South 4	Vasant Kunj	11kv FDR O/G TO CENTAUR HOTEL	5	0	2	0	3	2	3
BRPL	South 4	Vasant Kunj	11kv FDR O/G TO CISF CAMP MAHIPAL PUR	1	0	1	0	0	1	0
BRPL	South 4	Vasant Kunj	11kv FDR O/G TO DJB MAHIPALPUR	1	0	1	0	0	1	0
BRPL	South 4	Vasant Kunj	11kv FDR O/G TO GHITORANI	9	0	6	0	3	6	3
BRPL	South 4	Vasant Kunj	11kv FDR O/G TO RANGPURI NO.-1	12	0	9	0	3	9	3
BRPL	South 4	Vasant Kunj	11kv FDR O/G TO S/STN No 3, DDA FLATS SULTANGARHI	11	0	7	0	4	7	4
BRPL	South 4	Vasant Kunj	11kv FDR O/G TO S/STN No 6, DDA FLATS SULTANGARHI	11	0	11	0	0	11	0
BRPL	South 4	Vasant Kunj	11kv FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	18	0	13	0	5	13	5
BRPL	South 4	Vasant Kunj	11kv FDR O/G TO TEMPO STAND	11	0	5	0	6	5	6
BRPL	South 4	Vasant Kunj	11kv FDR O/G TO V. KUNJ SECT.-A	9	0	6	0	3	6	3
BRPL	South 4	Vasant Kunj	11kv FDR O/G TO VASANT KUNJ SECTOR-6, D-1	11	0	9	0	2	9	2
BRPL	South 4	Vasant Kunj	11kv FDR OUTGOING TO ASSET NO.-13	1	0	0	0	1	0	1
BRPL	South 4	Vasant Kunj	11kv FDR RANG PURI PAHARI	11	0	7	0	4	7	4
BRPL	South 4	Vasant Kunj	11kv FDR S.P.G	2	0	1	0	1	1	1
BRPL	South 4	Vasant Kunj	11kv FDR S.T.P FEEDER	9	0	9	0	0	9	0
BRPL	South 4	Vasant Kunj	11kv FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	38	0	25	0	13	25	13
BRPL	South 4	Vasant Kunj	11kv FDR S/STN NO.-2, C-4 V KUNJ VIA POLICE STATION	6	0	4	0	2	4	2
BRPL	South 4	Vasant Kunj	11kv FDR S/STN. NO.-1, C-6 & 7 V. KUNJ	6	0	4	0	2	4	2
BRPL	South 4	Vasant Kunj	11kv FDR S/STN. NO.-12, B-10 V. KUNJ	10	0	9	0	1	9	1

BRPL	South 4	Vasant Kunj	11kv FDR S/STN. NO.-15, B-11 V. KUNJ	10	0	9	0	1	9	1
BRPL	South 4	Vasant Kunj	11kv FDR S/STN. NO.-3, D-7 & 8 V.KUNJ	4	0	4	0	0	4	0
BRPL	South 4	Vasant Kunj	11kv FDR S/STN. NO.-5, C-2 V.KUNJ	7	0	6	0	1	6	1
BRPL	South 4	Vasant Kunj	11kv FDR S/STN. NO.-6, C-3,V. KUNJ	8	0	6	0	2	6	2
BRPL	South 4	Vasant Kunj	11kv FDR S/STN. NO.-7, B-7,V. KUNJ	7	0	7	0	0	7	0
BRPL	South 4	Vasant Kunj	11kv FDR SAMALKHA VILLAGE VIA G8 B	8	0	5	0	3	5	3
BRPL	South 4	Vasant Kunj	11kv FDR SECTOR A-2 VASANT KUNJ	6	0	4	0	2	4	2
BRPL	South 4	Vasant Kunj	11KV FDR SECTOR B-4 VASANT KUNJ	8	0	6	0	2	6	2
BRPL	South 4	Vasant Kunj	11kv FDR SULTAN GARHI S/S -II DDA FLATS 850 MASS HOUSING	6	0	5	0	1	5	1
BRPL	South 4	Vasant Kunj	11kv FDR SULTAN GARHI S/S -III DDA FLATS 850 MASS HOUSING	3	0	3	0	0	3	0
BRPL	South 4	Vasant Kunj	11kv FDR T.B HOSPITAL	15	0	9	0	6	9	6
BRPL	South 4	Vasant Kunj	11kv FDR V. KUNJ S/STN. NO.-1, D-7 & 8	3	0	3	0	0	3	0
BRPL	South 4	Vasant Kunj	11kv FDR V. KUNJ S/STN. NO.-3 D-6	6	0	4	0	2	4	2
BRPL	South 4	Vasant Kunj	11kv FDR VILLAGE SAHIBABAD MOHD. PUR	6	0	4	0	2	4	2
BRPL	South 4	Vasant Kunj	11kv FDR WARD-2 MEHRAULI	5	0	2	0	3	2	3
BRPL	South 4	Vasant Kunj	11kv FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	16	0	5	0	11	5	11
BRPL	South 4	Vasant Kunj	11KV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	19	0	13	0	6	13	6
BRPL	South 4	Vasant Kunj	11kv STR 100kVA STATION TRANS.-1	1	0	0	0	1	0	1
BRPL	South 4	Vasant Kunj	11kv STR 100kVA STATION TRF. NO.-2	1	0	0	0	1	0	1
BRPL	South 4	Vasant Kunj	11kv STR 400kVA STATION TRANS.	4	0	3	0	1	3	1
BRPL	South 4	Vasant Kunj	11kv STR 400kVA STATION TRF.	1	0	0	0	1	0	1
BRPL	South 2	Nehru Place	11 KV FDR CHIRAG ENCLAVE G.K.-1	5	0	0	0	5	0	5
BRPL	South 2	Nehru Place	11kv FDR B-BLOCK EAST OF KAILASH (VIA C-BLOCK)	7	0	0	0	7	0	7
BRPL	South 2	Nehru Place	11kv FDR D.D.A LSC OKHLA PH.-2	8	0	0	0	8	0	8
BRPL	South 2	Nehru Place	11kv FDR DAYANAND KIOSK	7	0	0	0	7	0	7
BRPL	South 2	Nehru Place	11kv FDR D-BLOCK EAST OF KAILASH	10	0	0	0	10	0	10
BRPL	South 2	Nehru Place	11kv FDR DDA FLATS MASJID MOTH PHASE 1 G.K-1 NHP	8	0	0	0	8	0	8
BRPL	South 2	Nehru Place	11kv FDR DDA LSC OKH PHASE-2	3	0	0	0	3	0	3
BRPL	South 2	Nehru Place	11kv FDR DSIDC SCHEME NO.-1 PHASE-2	2	0	0	0	2	0	2
BRPL	South 2	Nehru Place	11kv FDR E-BLOCK EAST OF KAILASH	10	0	0	0	10	0	10
BRPL	South 2	Nehru Place	11kv FDR FIEE COMPLEX S/S NO.-1, OKHLA PH.-2	6	0	0	0	6	0	6
BRPL	South 2	Nehru Place	11kv FDR FLATTED FACTORY	3	0	0	0	3	0	3
BRPL	South 2	Nehru Place	11kv FDR G.B. PANT STAFF QUARTERS	2	0	0	0	2	0	2
BRPL	South 2	Nehru Place	11kv FDR G-BLOCK EAST OF KAILASH	6	0	0	0	6	0	6
BRPL	South 2	Nehru Place	11kv FDR KAILASH APPARTMENT	7	0	0	0	7	0	7
BRPL	South 2	Nehru Place	11kv FDR KALA KUTIR	6	0	0	0	6	0	6
BRPL	South 2	Nehru Place	11KV FDR O/G 39 RING ROAD	3	0	0	0	3	0	3
BRPL	South 2	Nehru Place	11KV FDR O/G A BLK MINI MARKET	1	0	0	0	1	0	1
BRPL	South 2	Nehru Place	11kv FDR O/G BAHAI MANDIR	9	0	0	0	9	0	9
BRPL	South 2	Nehru Place	11KV FDR O/G BUILDING NO.-37 NHP	1	0	0	0	1	0	1
BRPL	South 2	Nehru Place	11kv FDR O/G BUILDING NO.-38	3	0	0	0	3	0	3
BRPL	South 2	Nehru Place	11kv FDR O/G BUILDING NO.-43 NHP	7	0	0	0	7	0	7
BRPL	South 2	Nehru Place	11KV FDR O/G BUILDING NO.-75 & 76 NHP.	7	0	0	0	7	0	7
BRPL	South 2	Nehru Place	11KV FDR O/G BUILDING NO.-89 NHP.	9	0	0	0	9	0	9
BRPL	South 2	Nehru Place	11kv FDR O/G C-46, O.I.A PHASE-2	2	0	0	0	2	0	2
BRPL	South 2	Nehru Place	11KV FDR O/G D.D.A SFS GARHI	2	0	0	0	2	0	2
BRPL	South 2	Nehru Place	11kv FDR O/G D-BLOCK EAST OF KAILASH	3	0	0	0	3	0	3
BRPL	South 2	Nehru Place	11kv FDR O/G DEVIKA TOWER NHP	7	0	0	0	7	0	7
BRPL	South 2	Nehru Place	11kv FDR O/G INDOOR GARI S/STN	8	0	0	0	8	0	8
BRPL	South 2	Nehru Place	11kv FDR O/G JAMRUPUR S/S NO.-2 NHP	8	0	0	0	8	0	8
BRPL	South 2	Nehru Place	11kv FDR O/G KAILASH COLONY DISPENSARY	7	0	0	0	7	0	7
BRPL	South 2	Nehru Place	11kv FDR O/G LAJPAT NAGAR-4	3	0	0	0	3	0	3
BRPL	South 2	Nehru Place	11kv FDR O/G LAJPAT NAGAR-IV	5	0	0	0	5	0	5
BRPL	South 2	Nehru Place	11kv FDR O/G NATIONAL PARK	5	0	0	0	5	0	5
BRPL	South 2	Nehru Place	11kv FDR O/G NEHRU PLACE HOTEL COMPLEX FEEDER NO.-1	1	0	0	0	1	0	1
BRPL	South 2	Nehru Place	11kv FDR O/G NEHRU PLACE HOTEL COMPLEX FEEDER NO.-2	3	0	0	0	3	0	3
BRPL	South 2	Nehru Place	11kv FDR O/G OLD HUDCO KIOSK	8	0	0	0	8	0	8
BRPL	South 2	Nehru Place	11KV FDR O/G R-BLOCK G.K-1	4	0	0	0	4	0	4
BRPL	South 2	Nehru Place	11kv FDR O/G RMU NEAR BALAJI GRID	1	0	0	0	1	0	1
BRPL	South 2	Nehru Place	11KV FDR O/G S/S NO.-16 NHP	7	0	0	0	7	0	7
BRPL	South 2	Nehru Place	11kv FDR O/G S/S NO.-5 NEHRU PLACE	6	0	0	0	6	0	6
BRPL	South 2	Nehru Place	11kv FDR O/G S-BLOCK G.K-1	8	0	0	0	8	0	8
BRPL	South 2	Nehru Place	11kv FDR O/G SDM OFFICE VIA NURSING HOSTEL	3	0	0	0	3	0	3
BRPL	South 2	Nehru Place	11KV FDR O/G TELEPHONE EXCHANGE NHP.	6	0	0	0	6	0	6

BRPL	South 2	Nehru Place	11kv FDR O/G TO DELHI ADMN. FLATS	6	0	0	0	6	0	6
BRPL	South 2	Nehru Place	11kv FDR O/G VIKRAM HOTEL	5	0	0	0	5	0	5
BRPL	South 2	Nehru Place	11kv FDR O/G W-BLOCK G.K-1 (VIA A-BLK. NAL G.K.-1)	5	0	0	0	5	0	5
BRPL	South 2	Nehru Place	11kv FDR O/G Z-BLOCK VIA -X-BLOCK OKHLA PHASE-II	9	0	0	0	9	0	9
BRPL	South 2	Nehru Place	11kv FDR O/H S/S NO.-2 PHASE-2	8	0	0	0	8	0	8
BRPL	South 2	Nehru Place	11kv FDR OKHLA SSTN NO-80 PH-3	6	0	0	0	6	0	6
BRPL	South 2	Nehru Place	11kv FDR OUT GOING FEEDER-4, E-BLOCK (K) S/STN. G.K-I	8	0	0	0	8	0	8
BRPL	South 2	Nehru Place	11kv FDR OUT GOING FEEDER-5, M-BLOCK (K) S/STN. G.K-I	6	0	0	0	6	0	6
BRPL	South 2	Nehru Place	11kv FDR OUT GOING FEEDER-7,EPR CLY.-1	7	0	0	0	7	0	7
BRPL	South 2	Nehru Place	11kv FDR OUT GOING FEEDER-8,R-BLOCK G.K-I	5	0	0	0	5	0	5
BRPL	South 2	Nehru Place	11kv FDR RMU AT GRID	7	0	0	0	7	0	7
BRPL	South 2	Nehru Place	11kv FDR S.B.I NO.-1	6	0	0	0	6	0	6
BRPL	South 2	Nehru Place	11kv FDR S.B.I NO.-2	4	0	0	0	4	0	4
BRPL	South 2	Nehru Place	11kv FDR S/S NO.-1, FEEDER-1 PHASE-2 VIA B-18/2	5	0	0	0	5	0	5
BRPL	South 2	Nehru Place	11kv FDR S/S NO.-1, OKHLA PHASE-2, FEEDER-2	6	0	0	0	6	0	6
BRPL	South 2	Nehru Place	11kv FDR S/S NO.-4 NHP	4	0	0	0	4	0	4
BRPL	South 2	Nehru Place	11kv FDR S/S NO.-4, FEEDER-2 PHASE-2	5	0	0	0	5	0	5
BRPL	South 2	Nehru Place	11kv FDR S/S NO.-4, OKHLA PHASE-2	6	0	0	0	6	0	6
BRPL	South 2	Nehru Place	11kv FDR S/S NO.-5, OIA PHASE-2	3	0	0	0	3	0	3
BRPL	South 2	Nehru Place	11kv FDR S/S NO.-6 OKHLA PHASE-3	6	0	0	0	6	0	6
BRPL	South 2	Nehru Place	11kv FDR SAI PLAZA	7	0	0	0	7	0	7
BRPL	South 2	Nehru Place	11kv FDR SEWAGE PUMPING STATION Z-BLOCK PHASE-2	1	0	0	0	1	0	1
BRPL	South 2	Nehru Place	11kv FDR SHED NO.-8,DSIDC SC-III	4	0	0	0	4	0	4
BRPL	South 2	Nehru Place	11kv FDR SSTN SABJI MANDI OKHLA PHASE-3	9	0	0	0	9	0	9
BRPL	South 2	Nehru Place	11kv FDR W-BLOCK OKHLA PHASE-2	8	0	0	0	8	0	8
BRPL	South 2	Nehru Place	11kv FDR Y-POKET OKHLA PHASE-2	10	0	0	0	10	0	10
BRPL	South 2	Nehru Place	11kv O/G BUILDING NO-37 NHP NO.2	12	0	0	0	12	0	12
BRPL	South 2	Nehru Place	11kv STR 990kVA LOCAL TRF. NO.-1	1	0	0	0	1	0	1
BRPL	South 2	Nehru Place	11kv STR 990kVA LOCAL TRF. NO.-2	1	0	0	0	1	0	1
BRPL	South 2	Nizamuddin	11kv O/G D.J.B VIA CNG SARAI KALE KHAN	2	0	0	0	2	0	2
BRPL	South 2	Nizamuddin	11kv FDR 11KV O/G I.N.A COLONY	12	0	0	0	12	0	12
BRPL	South 2	Nizamuddin	11kv FDR 11KV O/G TYAGARAJ STADIUM	6	0	0	0	6	0	6
BRPL	South 2	Nizamuddin	11kv FDR AMBEDKAR PARK SIDDHARTH	3	0	0	0	3	0	3
BRPL	South 2	Nizamuddin	11kv FDR ASHRAM CHOWK VIA MTNL	6	0	0	0	6	0	6
BRPL	South 2	Nizamuddin	11kv FDR BHAIRON ROAD	7	0	0	0	7	0	7
BRPL	South 2	Nizamuddin	11kv FDR BIRBAL PARK	4	0	0	0	4	0	4
BRPL	South 2	Nizamuddin	11kv FDR C-BLOCK, NZD EAST	6	0	0	0	6	0	6
BRPL	South 2	Nizamuddin	11kv FDR D.V.B COLONY SARAI KALE KHAN	7	0	0	0	7	0	7
BRPL	South 2	Nizamuddin	11kv FDR D-430 DEFENCE COLONY	6	0	0	0	6	0	6
BRPL	South 2	Nizamuddin	11kv FDR DDA SLUM QUTRS SKK	3	0	0	0	3	0	3
BRPL	South 2	Nizamuddin	11kv FDR DEFENCE COLONY (NIZAMUDDINE WEST G-BLOCK)	6	0	1	0	5	1	5
BRPL	South 2	Nizamuddin	11kv FDR DEFENCE COLONY VIA NARULA SHIRAJ	1	0	1	0	0	1	0
BRPL	South 2	Nizamuddin	11kv FDR DEFENCE UNDER FLYOVER (JANGPURA)	12	0	0	0	12	0	12
BRPL	South 2	Nizamuddin	11kv FDR GENERATION COLONY	5	0	0	0	5	0	5
BRPL	South 2	Nizamuddin	11kv FDR INSTITUTIONAL AREA	5	0	0	0	5	0	5
BRPL	South 2	Nizamuddin	11kv FDR J-BLOCK N.D.S.E-2(BRPL FEEDER)	8	0	0	0	8	0	8
BRPL	South 2	Nizamuddin	11kv FDR KASHMIRI MARKET INA (BRPL FEEDER)	1	0	0	0	1	0	1
BRPL	South 2	Nizamuddin	11kv FDR KASHMIRI PRAK JANGPURA	2	0	0	0	2	0	2
BRPL	South 2	Nizamuddin	11kv FDR LAJPAT NAGAR 1, FEEDER NO.-1	5	0	0	0	5	0	5
BRPL	South 2	Nizamuddin	11kv FDR LAJPAT NAGAR-1, FEEDER-2, I-BLOCK	4	0	0	0	4	0	4
BRPL	South 2	Nizamuddin	11kv FDR LAJPAT NAGAR-2, FDR-3	3	0	0	0	3	0	3
BRPL	South 2	Nizamuddin	11kv FDR LODHI COLONEY COMP. CENTER	9	0	0	0	9	0	9
BRPL	South 2	Nizamuddin	11kv FDR MICROWAVE,NZD EAST	7	0	0	0	7	0	7
BRPL	South 2	Nizamuddin	11kv FDR N.B.C.C	1	0	0	0	1	0	1
BRPL	South 2	Nizamuddin	11kv FDR N.B.C.C EAST BLOCK	4	0	0	0	4	0	4
BRPL	South 2	Nizamuddin	11kv FDR NIZAMUDDINE TIE-1	10	0	0	0	10	0	10
BRPL	South 2	Nizamuddin	11kv FDR NIZAMUDDINE TIE-3	5	0	0	0	5	0	5
BRPL	South 2	Nizamuddin	11kv FDR O/G 6-FIROZ GANDHI ROAD	3	0	0	0	3	0	3
BRPL	South 2	Nizamuddin	11kv FDR O/G A-BLOCK DEFENCE COLONY	5	0	0	0	5	0	5
BRPL	South 2	Nizamuddin	11kv FDR O/G ALANKAR CINEMA	4	0	0	0	4	0	4

BRPL	South 2	Nizamuddin	11kV FDR O/G BAPU PARK TRAINING CENTER	7	0	0	0	7	0	7
BRPL	South 2	Nizamuddin	11kV FDR O/G B-BLOCK DEFENCE COLONY	4	0	0	0	4	0	4
BRPL	South 2	Nizamuddin	11kV FDR O/G B-BLOCK, DEFENCE COLONY	8	0	0	0	8	0	8
BRPL	South 2	Nizamuddin	11kV FDR O/G C-57, NDSE-1	1	0	0	0	1	0	1
BRPL	South 2	Nizamuddin	11kV FDR O/G C-57, NDSE-1	4	0	0	0	4	0	4
BRPL	South 2	Nizamuddin	11kV FDR O/G C-BLOCK, DEFENCE COLY. FDR.-1	5	0	0	0	5	0	5
BRPL	South 2	Nizamuddin	11kV FDR O/G C-BLOCK, DEFENCE COLY. FDR.-2	8	0	0	0	8	0	8
BRPL	South 2	Nizamuddin	11kV FDR O/G D-337, DEFENCE COLONY	6	0	0	0	6	0	6
BRPL	South 2	Nizamuddin	11kV FDR O/G DHARAM BHAWAN	4	0	0	0	4	0	4
BRPL	South 2	Nizamuddin	11kV FDR O/G DTL	2	0	0	0	2	0	2
BRPL	South 2	Nizamuddin	11kV FDR O/G F- BLOCK LAJPAT NAGAR NO-2	5	0	0	0	5	0	5
BRPL	South 2	Nizamuddin	11kV FDR O/G FEEDER SUNDER NAGAR	7	0	0	0	7	0	7
BRPL	South 2	Nizamuddin	11kV FDR O/G KASTURBA NIKETAN (HVDS)	2	0	0	0	2	0	2
BRPL	South 2	Nizamuddin	11kV FDR O/G KILOKARI SEWAGE	4	0	0	0	4	0	4
BRPL	South 2	Nizamuddin	11kV FDR O/G KRISHNA MARKET	8	0	0	0	8	0	8
BRPL	South 2	Nizamuddin	11kV FDR O/G LAJPAT NAGAR-3	6	0	0	0	6	0	6
BRPL	South 2	Nizamuddin	11kV FDR O/G LAJPAT NAGAR-3 MAIN FDR.-1	4	0	0	0	4	0	4
BRPL	South 2	Nizamuddin	11kV FDR O/G LAJPAT NAGAR-3 MAIN FDR.-2	5	0	0	0	5	0	5
BRPL	South 2	Nizamuddin	11kV FDR O/G M-BLOCK LAJPAT NAGAR-2	8	0	0	0	8	0	8
BRPL	South 2	Nizamuddin	11kV FDR O/G MCD DISPENSARY LPN-2	9	0	0	0	9	0	9
BRPL	South 2	Nizamuddin	11kV FDR O/G MOOLCHAND BOOSTER PUMP	5	0	0	0	5	0	5
BRPL	South 2	Nizamuddin	11kV FDR O/G NIZAMUDDINE TIE-II	10	0	0	0	10	0	10
BRPL	South 2	Nizamuddin	11kV FDR O/G PILANJI S/STN. K.M. PUR	6	0	0	0	6	0	6
BRPL	South 2	Nizamuddin	11kV FDR O/G SEWA NAGAR	7	0	0	0	7	0	7
BRPL	South 2	Nizamuddin	11kV FDR O/G SUKHDEV MARKET	4	0	0	0	4	0	4
BRPL	South 2	Nizamuddin	11kV FDR O/G SUNDER NAGAR	1	0	0	0	1	0	1
BRPL	South 2	Nizamuddin	11kV FDR O/G TIKONA PARK LAJPAT NAGAR NO - 2	3	0	0	0	3	0	3
BRPL	South 2	Nizamuddin	11kV FDR O/G TO JANGPURA	6	0	0	0	6	0	6
BRPL	South 2	Nizamuddin	11kV FDR O/G VIMHANS HOSPITAL NEHRU NGR.	9	0	0	0	9	0	9
BRPL	South 2	Nizamuddin	11kV FDR O/G WAZIR NAGAR GALI NO.-5	4	0	0	0	4	0	4
BRPL	South 2	Nizamuddin	11KV FDR OG BHAIRON ROAD	4	0	0	0	4	0	4
BRPL	South 2	Nizamuddin	11kV FDR OG DHARAM BHAWAN (NEW)	6	0	1	0	5	1	5
BRPL	South 2	Nizamuddin	11KV FDR OG SUNDER NAGAR	4	0	0	0	4	0	4
BRPL	South 2	Nizamuddin	11KV FDR OG TILAK BRIDGE RAILWAY COLONY	1	0	0	0	1	0	1
BRPL	South 2	Nizamuddin	11kV FDR SHALIMAR CINEMA VIA SAM INDIA LTD	2	0	0	0	2	0	2
BRPL	South 2	Nizamuddin	11kV FDR SIDDHARTHA EXTN.	13	0	0	0	13	0	13
BRPL	South 2	Nizamuddin	11kV FDR SUNLIGHT COLONY NO-2	6	0	0	0	6	0	6
BRPL	South 2	Nizamuddin	11kV FDR SUPREME COURT	3	0	0	0	3	0	3
BRPL	South 2	Nizamuddin	11kV FDR TELEPHONE EXCHANGE	9	0	0	0	9	0	9
BRPL	South 2	Nizamuddin	11kV FDR TIKONA PARK SIDDHARTH BASTI VIA JEEVAN HOSP	7	0	0	0	7	0	7
BRPL	South 2	Nizamuddin	11kV O/G FDR UNIDO	10	0	0	0	10	0	10
BRPL	South 2	Nizamuddin	11kV O/G G-BLOCK NDSE-1	5	0	0	0	5	0	5
BRPL	South 2	Nizamuddin	11kV STR 100KVA STATION TRANSFORMER NO-2	1	0	0	0	1	0	1
BRPL	South 2	Nizamuddin	11kV STR 100KVA STATION TRF.	1	0	0	0	1	0	1
BRPL	South 2	Nizamuddin	11kV STR 400KVA LOCAL TRF. NO.-1	1	0	0	0	1	0	1
BRPL	South 1	Sarita Vihar	11kV FDR ALI VILLAGE	7	0	2	0	5	2	5
BRPL	South 1	Sarita Vihar	11kV FDR AMERICAN EXPRESS	4	0	0	0	4	0	4
BRPL	South 1	Sarita Vihar	11kV FDR B-1/H-8 MCIE HALDI RAM	2	0	2	0	0	2	0
BRPL	South 1	Sarita Vihar	11kV FDR BADARPUR O/H	4	0	4	0	0	4	0
BRPL	South 1	Sarita Vihar	11kV FDR DMRC FLAT SARITA VIHAR	5	0	3	0	2	3	2
BRPL	South 1	Sarita Vihar	11kV FDR DP SKS	7	0	4	0	3	4	3
BRPL	South 1	Sarita Vihar	11kV FDR GYAN MANDIR	8	0	4	0	4	4	4
BRPL	South 1	Sarita Vihar	11kV FDR HARI NAGAR PART-2	8	0	4	0	4	4	4
BRPL	South 1	Sarita Vihar	11kV FDR HARIJAN BASTI	11	0	4	0	7	4	7
BRPL	South 1	Sarita Vihar	11kV FDR H-BLK KHADDA COLONY	9	0	4	0	5	4	5
BRPL	South 1	Sarita Vihar	11kV FDR INDIAN OIL CORPO	12	0	3	0	9	3	9
BRPL	South 1	Sarita Vihar	11kV FDR JAIPUR	9	0	1	0	8	1	8
BRPL	South 1	Sarita Vihar	11kV FDR LAKHPAT COLONY PART-2	4	0	1	0	3	1	3
BRPL	South 1	Sarita Vihar	11kV FDR MADRASI COLONY	6	0	4	0	2	4	2
BRPL	South 1	Sarita Vihar	11kV FDR MANBHARI KUNJ	5	0	3	0	2	3	2
BRPL	South 1	Sarita Vihar	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-1	13	0	3	0	10	3	10

BRPL	South 1	Sarita Vihar	11kv FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	15	0	0	0	15	0	15
BRPL	South 1	Sarita Vihar	11kv FDR MOHAN BABA NAGAR FDR. NO.-1	4	0	1	0	3	1	3
BRPL	South 1	Sarita Vihar	11kv FDR O/G 4-POLE POLICE STATION	4	0	1	0	3	1	3
BRPL	South 1	Sarita Vihar	11kv FDR O/G AMERIKAN EXPRESS	4	0	2	0	2	2	2
BRPL	South 1	Sarita Vihar	11kv FDR O/G BADARPUR THANA	6	0	0	0	6	0	6
BRPL	South 1	Sarita Vihar	11kv FDR O/G D.P NTPC	3	0	0	0	3	0	3
BRPL	South 1	Sarita Vihar	11kv FDR O/G K-POCKET SARITA VIHAR	8	0	6	0	2	6	2
BRPL	South 1	Sarita Vihar	11kv FDR O/G LUV KUSH D.P	8	0	2	0	6	2	6
BRPL	South 1	Sarita Vihar	11kv FDR O/G M PKT. SARITA VIHAR JANTA FLAT	6	0	4	0	2	4	2
BRPL	South 1	Sarita Vihar	11kv FDR O/G MADANPUR KHADAR TRANSIT CAMP NO.-1	3	0	0	0	3	0	3
BRPL	South 1	Sarita Vihar	11kv FDR O/G MADANPUR KHADAR TRANSIT CAMP NO.-2	7	0	1	0	6	1	6
BRPL	South 1	Sarita Vihar	11kv FDR O/G MEETHAPUR AGGARWAL DHARM SHALA	8	0	3	0	5	3	5
BRPL	South 1	Sarita Vihar	11kv FDR O/G MEETHAPUR WATER PMP. STN.	11	0	3	0	8	3	8
BRPL	South 1	Sarita Vihar	11kv FDR O/G N POCKET S/S NO.-1 SARITA VIHAR	2	0	2	0	0	2	0
BRPL	South 1	Sarita Vihar	11kv FDR O/G NEHRU MARKET	8	0	6	0	2	6	2
BRPL	South 1	Sarita Vihar	11kv FDR O/G PUSTA ROAD KHADDA COLONY	9	0	3	0	6	3	6
BRPL	South 1	Sarita Vihar	11kv FDR O/G S/S NO.-13, SARITA VIHAR	16	0	9	0	7	9	7
BRPL	South 1	Sarita Vihar	11kv FDR O/G S/S NO.-18, SARITA VIHAR	13	0	11	0	2	11	2
BRPL	South 1	Sarita Vihar	11kv FDR O/G S/S NO.-5 M.C.I.E	5	0	0	0	5	0	5
BRPL	South 1	Sarita Vihar	11kv FDR O/G S/S NO.-8 SARITA VIHAR	1	0	1	0	0	1	0
BRPL	South 1	Sarita Vihar	11kv FDR O/G SAHEEN BAGH	12	0	6	0	6	6	6
BRPL	South 1	Sarita Vihar	11kv FDR OM NAGAR BARAT GHAR	4	0	2	0	2	2	2
BRPL	South 1	Sarita Vihar	11kv FDR OM NAGAR GALI NO-10 A,B&C BLOCK	8	0	4	0	4	4	4
BRPL	South 1	Sarita Vihar	11kv FDR P/M OPPOSIT B-2/66MCIE-2	7	0	6	0	1	6	1
BRPL	South 1	Sarita Vihar	11kv FDR S/S NO.-1 M.C.I.E.	2	0	1	0	1	1	1
BRPL	South 1	Sarita Vihar	11kv FDR S/S NO.-2	2	0	2	0	0	2	0
BRPL	South 1	Sarita Vihar	11kv FDR S/S NO.-2 M.B EXTN.	6	0	3	0	3	3	3
BRPL	South 1	Sarita Vihar	11kv FDR S/S NO.-21, SARITA VIHAR	4	0	3	0	1	3	1
BRPL	South 1	Sarita Vihar	11kv FDR S/S NO.-22, SARITA VIHAR	10	0	5	0	5	5	5
BRPL	South 1	Sarita Vihar	11kv FDR S/S NO.-3 M.B EXTN.	4	0	1	0	3	1	3
BRPL	South 1	Sarita Vihar	11kv FDR S/S NO.-4 SARITA VIHAR	8	0	6	0	2	6	2
BRPL	South 1	Sarita Vihar	11kv FDR S/S NO.-5 M.B EXTN.	6	0	3	0	3	3	3
BRPL	South 1	Sarita Vihar	11kv FDR S/S NO.-7 M.C.I.E	5	0	3	0	2	3	2
BRPL	South 1	Sarita Vihar	11kv FDR S/S NO.-8 SARITA VIHAR	9	0	5	0	4	5	4
BRPL	South 1	Sarita Vihar	11kv FDR SAURABH VIHAR-2	3	0	0	0	3	0	3
BRPL	South 1	Sarita Vihar	11kv FDR SHARDA KUNJ A-BLK OM NAGAR	4	0	1	0	3	1	3
BRPL	South 1	Sarita Vihar	11kv FDR SOURABH VIHAR-1	6	0	3	0	3	3	3
BRPL	South 1	Sarita Vihar	11kv FDR SR. SEC. SCHOOL MEETHAPUR	3	0	3	0	0	3	0
BRPL	South 1	Sarita Vihar	11kv FDR SSTN PRIYANKA CAMP	8	0	4	0	4	4	4
BRPL	South 1	Sarita Vihar	11kv FDR SUBSTN NO.-3 MCIE B-1 BLK VIA A-33	5	0	2	0	3	2	3
BRPL	South 1	Sarita Vihar	11kv FDR SUKHDEV VIHAR O/H	6	0	4	0	2	4	2
BRPL	South 1	New Friends Colony	11kv FDR A.F.E. M-BLOCK	5	0	5	0	0	5	0
BRPL	South 1	New Friends Colony	11kv FDR B BLOCK ABUL FAZAL	1	0	1	0	0	1	0
BRPL	South 1	New Friends Colony	11kv FDR B-BLOCK F.COLONY	7	0	7	0	0	7	0
BRPL	South 1	New Friends Colony	11kv FDR B-BLOCK FRIENDS COLONEY	7	0	7	0	0	7	0
BRPL	South 1	New Friends Colony	11kv FDR C.S.I.R STAFF QUARTER	8	0	7	0	1	7	1
BRPL	South 1	New Friends Colony	11kv FDR COMMUNITY CENTER	6	0	5	0	1	5	1
BRPL	South 1	New Friends Colony	11kv FDR DDA FLATS S. JULENA	6	0	5	0	1	5	1
BRPL	South 1	New Friends Colony	11kv FDR DELHI JAL BOARD	5	0	5	0	0	5	0
BRPL	South 1	New Friends Colony	11kv FDR ESCORTS HEART INST.-2	6	0	5	0	1	5	1
BRPL	South 1	New Friends Colony	11kv FDR GEETA NURSERY STG. LTG.	5	0	4	0	1	4	1
BRPL	South 1	New Friends Colony	11kv FDR JAMIA PLINTH S/S	5	0	5	0	0	5	0
BRPL	South 1	New Friends Colony	11kv FDR JAMIA STADIUM	12	0	12	0	0	12	0
BRPL	South 1	New Friends Colony	11kv FDR MAHARANI BAGH NO.-2	3	0	2	0	1	2	1
BRPL	South 1	New Friends Colony	11kv FDR MAHARANI BAGH-1	12	0	10	0	2	10	2
BRPL	South 1	New Friends Colony	11kv FDR NEW FRIENDS COLONY S/S NO.-1	11	0	6	0	5	6	5

BRPL	South 1	New Friends Colony	11kV FDR NFC. S/S NO.-3	12	0	8	0	4	8	4
BRPL	South 1	New Friends Colony	11kV FDR NFC. S/S NO.-5	11	0	9	0	2	9	2
BRPL	South 1	New Friends Colony	11kV FDR NFC. S/S NO.-6	4	0	2	0	2	2	2
BRPL	South 1	New Friends Colony	11kV FDR O S D PLANT	1	0	1	0	0	1	0
BRPL	South 1	New Friends Colony	11kV FDR O/G 140 LIG FLAT PKT-12	3	0	3	0	0	3	0
BRPL	South 1	New Friends Colony	11kV FDR O/G ABU BAKAR MASJID	8	0	6	0	2	6	2
BRPL	South 1	New Friends Colony	11kV FDR O/G D-BLOCK SAHEEN BAGH	3	0	2	0	1	2	1
BRPL	South 1	New Friends Colony	11kV FDR O/G F-BLK MOTHER DIARY SHAHEEN BAGH	2	0	0	0	2	0	2
BRPL	South 1	New Friends Colony	11kV FDR O/G FILTERATION PLANT	1	0	1	0	0	1	0
BRPL	South 1	New Friends Colony	11kV FDR O/G G-4, SHAHEEN BAGH	6	0	2	0	4	2	4
BRPL	South 1	New Friends Colony	11kV FDR O/G GAFFAR MANZIL	7	0	7	0	0	7	0
BRPL	South 1	New Friends Colony	11kV FDR O/G MEDICAL COLLEGE NO.-2	1	0	1	0	0	1	0
BRPL	South 1	New Friends Colony	11kV FDR O/G N-BLOCK ABUL FAZAL	6	0	5	0	1	5	1
BRPL	South 1	New Friends Colony	11kV FDR O/G NOOR NAGAR	8	0	7	0	1	7	1
BRPL	South 1	New Friends Colony	11kV FDR O/G NURSING STAFF QUARTERS S.N PURI	3	0	2	0	1	2	1
BRPL	South 1	New Friends Colony	11kV FDR O/G OKHLA VIHAR MASJID	7	0	7	0	0	7	0
BRPL	South 1	New Friends Colony	11kV FDR O/G OKHLA VILLAGE	2	0	2	0	0	2	0
BRPL	South 1	New Friends Colony	11kV FDR O/G RMU NO.-1	5	0	5	0	0	5	0
BRPL	South 1	New Friends Colony	11kV FDR O/G RMU NO.-2 JASOLA	8	0	6	0	2	6	2
BRPL	South 1	New Friends Colony	11kV FDR O/G S/S NO.-1 DDA JASOLA	4	0	4	0	0	4	0
BRPL	South 1	New Friends Colony	11kV FDR O/G S/S NO.-1, PLOT NO.-1, JASOLA	6	0	2	0	4	2	4
BRPL	South 1	New Friends Colony	11kV FDR O/G S/S NO.-2 DDA JASOLA	11	0	11	0	0	11	0
BRPL	South 1	New Friends Colony	11kV FDR O/G S/S NO.-2, F.C-33, JASOLA	6	0	5	0	1	5	1
BRPL	South 1	New Friends Colony	11kV FDR O/G SANJAY JHEEL	7	0	6	0	1	6	1
BRPL	South 1	New Friends Colony	11kV FDR O/G SDMC CAR PARKING NFC	4	0	3	0	1	3	1
BRPL	South 1	New Friends Colony	11kV FDR O/G SPORTS COMPLEX JASOLA	9	0	9	0	0	9	0
BRPL	South 1	New Friends Colony	11kV FDR O/G SRINIWAS PURI S/STN.	1	0	1	0	0	1	0
BRPL	South 1	New Friends Colony	11kV FDR O/G THOKAR NO.-6	11	0	10	0	1	10	1
BRPL	South 1	New Friends Colony	11kV FDR O/G THOKER NO.-5 DHARAM KANTA	8	0	8	0	0	8	0
BRPL	South 1	New Friends Colony	11kV FDR O/G TO KHAJOORI ROAD	4	0	4	0	0	4	0
BRPL	South 1	New Friends Colony	11kV FDR O/G TO MEHBOOB NAGAR VIA REHMANI MASJID	3	0	3	0	0	3	0
BRPL	South 1	New Friends Colony	11kV FDR O/G TO P BLOCK NAFEEZ ROAD	7	0	4	0	3	4	3
BRPL	South 1	New Friends Colony	11kV FDR O/G UDYOG SHEEL MAHILA	1	0	1	0	0	1	0
BRPL	South 1	New Friends Colony	11kV FDR O/G ZAKIR NAGAR	2	0	2	0	0	2	0
BRPL	South 1	New Friends Colony	11kV FDR OKHLA FILTERATION PLANT	1	0	1	0	0	1	0
BRPL	South 1	New Friends Colony	11kV FDR OKHLA SEWAGE	2	0	2	0	0	2	0
BRPL	South 1	New Friends Colony	11kV FDR RMU NO.-1,11kV FDR O/G RMU JAMIA	6	0	6	0	0	6	0
BRPL	South 1	New Friends Colony	11kV FDR RMU-3 ZAKIR NAGAR NO-22	6	0	6	0	0	6	0
BRPL	South 1	New Friends Colony	11kV FDR S/S NO.-4, F.C-33, JASOLA	2	0	1	0	1	1	1
BRPL	South 1	New Friends Colony	11kV FDR SFS NO 1 SUKHDEV VIHAR	8	0	8	0	0	8	0
BRPL	South 1	New Friends Colony	11kV FDR SRINIWASHPURI	11	0	7	0	4	7	4
BRPL	South 1	New Friends Colony	11kV FDR SUKHADEV VIHAR	6	0	5	0	1	5	1
BRPL	South 1	New Friends Colony	11kV FDR TAIMOOR NAGAR	5	0	4	0	1	4	1
BRPL	South 1	New Friends Colony	11kV STR 100KVA STATION TRANSF.	1	0	0	0	1	0	1
BRPL	South 1	New Friends Colony	11kV STR 400KVA STATION TRANSFORMER 1	1	0	1	0	0	1	0
BRPL	South 3	R K Puram	11 KV FDR CAR PARKING MUNIRKA	5	0	0	0	5	0	5

BRPL	South 3	R K Puram	11 KV PLOT NO-16 (GAIL)	2	0	0	0	2	0	2
BRPL	South 3	R K Puram	11KV FDR 3W O/D RMU INSIDE GRID	9	0	3	0	6	3	6
BRPL	South 3	R K Puram	11kv FDR ARSD COLLEGE	6	0	0	0	6	0	6
BRPL	South 3	R K Puram	11kv FDR B.C PLACE S/S NO.-3	3	0	0	0	3	0	3
BRPL	South 3	R K Puram	11kv FDR BUDH VIHAR O/H VIA 3WAY O/D RMU INSTALLED AT GRID	5	0	0	0	5	0	5
BRPL	South 3	R K Puram	11KV FDR GURUDWARA MOTIBAGH	4	0	0	0	4	0	4
BRPL	South 3	R K Puram	11kv FDR MOHAMEDPUR VILLAGE	3	0	0	0	3	0	3
BRPL	South 3	R K Puram	11kv FDR MOTI BAGH	5	0	0	0	5	0	5
BRPL	South 3	R K Puram	11kv FDR MUNREKA VIHAR	6	0	0	0	6	0	6
BRPL	South 3	R K Puram	11kv FDR N.B.C.C.TOWER	2	0	0	0	2	0	2
BRPL	South 3	R K Puram	11kv FDR NIVEDITA KUNJ S/S NO.-1	4	0	0	0	4	0	4
BRPL	South 3	R K Puram	11kv FDR NIVEDITA KUNJ S/S NO.-5	4	0	0	0	4	0	4
BRPL	South 3	R K Puram	11kv FDR O/G A-BLOCK VASANT VIHAR	4	0	0	0	4	0	4
BRPL	South 3	R K Puram	11kv FDR O/G BASANT LOK COMM. CENTER	4	0	0	0	4	0	4
BRPL	South 3	R K Puram	11kv FDR O/G CANERA BANK	5	0	0	0	5	0	5
BRPL	South 3	R K Puram	11kv FDR O/G C-BLOCK VASANT VIHAR	6	0	0	0	6	0	6
BRPL	South 3	R K Puram	11kv FDR O/G D-BLOCK VASANT VIHAR	6	0	0	0	6	0	6
BRPL	South 3	R K Puram	11kv FDR O/G DDA FLATS MUNREKA S/S NO.¿III	3	0	0	0	3	0	3
BRPL	South 3	R K Puram	11kv FDR O/G E-1 VASANT VIHAR	5	0	0	0	5	0	5
BRPL	South 3	R K Puram	11kv FDR O/G F-BLOCK VASANT VIHAR	12	0	0	0	12	0	12
BRPL	South 3	R K Puram	11kv FDR O/G FSI MUNERKA JNU OLD CAMPUS	1	0	0	0	1	0	1
BRPL	South 3	R K Puram	11kv FDR O/G HOTEL SIDDHARTHA VASANT LOK VASANT VIHAR	4	0	0	0	4	0	4
BRPL	South 3	R K Puram	11kv FDR O/G J.N.U ACADEMEY	5	0	0	0	5	0	5
BRPL	South 3	R K Puram	11kv FDR O/G MUNRIKA (DDA FLAT)	7	0	0	0	7	0	7
BRPL	South 3	R K Puram	11kv FDR O/G NIRYAT BHAWAN	1	0	0	0	1	0	1
BRPL	South 3	R K Puram	11kv FDR O/G NIVEDITA KUNJ S/S NO-2	4	0	0	0	4	0	4
BRPL	South 3	R K Puram	11kv FDR O/G R.K PURAM EAST BLOCK	3	0	0	0	3	0	3
BRPL	South 3	R K Puram	11kv FDR O/G R.K PURAM SECTOR-7	9	0	0	0	9	0	9
BRPL	South 3	R K Puram	11kv FDR O/G R.K PURAM WEST BLOCK	4	0	0	0	4	0	4
BRPL	South 3	R K Puram	11kv FDR O/G S/S NO.-1, SECTOR-1, R.K PURAM	8	0	0	0	8	0	8
BRPL	South 3	R K Puram	11kv FDR O/G SCIENTIFIC HOSTEL	11	0	0	0	11	0	11
BRPL	South 3	R K Puram	11kv FDR O/G SECTOR-2 R.K PURAM	4	0	0	0	4	0	4
BRPL	South 3	R K Puram	11kv FDR O/G SECTOR-4 R.K PURAM	5	0	0	0	5	0	5
BRPL	South 3	R K Puram	11kv FDR O/G SEWA BHAWAN	2	0	0	0	2	0	2
BRPL	South 3	R K Puram	11kv FDR O/G SUBROTO PARK (MES)	9	0	0	0	9	0	9
BRPL	South 3	R K Puram	11kv FDR O/G TO ANAND NIKETAN	8	0	0	0	8	0	8
BRPL	South 3	R K Puram	11kv FDR O/G TO R.K PURAM SECTOR¿12	9	0	0	0	9	0	9
BRPL	South 3	R K Puram	11kv FDR O/G TO R.K PURAM SECTOR¿9	3	0	0	0	3	0	3
BRPL	South 3	R K Puram	11kv FDR O/G TO R.K PURAM SECTOR-6	5	0	0	0	5	0	5
BRPL	South 3	R K Puram	11kv FDR O/G TO VASANT ENCLAVE NO.-1	4	0	0	0	4	0	4
BRPL	South 3	R K Puram	11kv FDR O/G VASANT ENCLAVE S/S NO.-2	5	0	0	0	5	0	5
BRPL	South 3	R K Puram	11kv FDR O/G VASANT MARG COMPLAINT CENTER	7	0	0	0	7	0	7
BRPL	South 3	R K Puram	11kv FDR O/G VASANT VIHAR B-BLOCK FDR.-1	3	0	0	0	3	0	3
BRPL	South 3	R K Puram	11kv FDR O/G VASANT VIHAR B-BLOCK FDR.-2	5	0	0	0	5	0	5
BRPL	South 3	R K Puram	11kv FDR O/G WEST END COLONY	8	0	0	0	8	0	8
BRPL	South 3	R K Puram	11kv FDR PLOT NO.-11, B.C PLACE	2	0	0	0	2	0	2
BRPL	South 3	R K Puram	11kv FDR PLOT NO.-25	6	0	0	0	6	0	6
BRPL	South 3	R K Puram	11kv FDR PLOT NO.-6, B.C PLACE	6	0	0	0	6	0	6
BRPL	South 3	R K Puram	11kv FDR PWD FLYOVER DHOLAKAUN	1	0	0	0	1	0	1
BRPL	South 3	R K Puram	11KV FDR ROSHAN PURA X-1 BLOCK	1	0	0	0	1	0	1
BRPL	South 3	R K Puram	11kv FDR S/S NO.-5, B.C PLACE	3	0	0	0	3	0	3
BRPL	South 3	R K Puram	11kv FDR SFS VASANT VIHAR	8	0	0	0	8	0	8
BRPL	South 3	R K Puram	11kv FDR SOUTH CAMPUS NEW	5	0	0	0	5	0	5
BRPL	South 3	R K Puram	11kv FDR ST. LTG. NO.-1	3	0	0	0	3	0	3
BRPL	South 3	R K Puram	11kv FDR VASANT LOK	6	0	0	0	6	0	6
BRPL	South 3	R K Puram	11kv FDR VENKTESHWAR COLLEGE	3	0	0	0	3	0	3
BRPL	South 3	R K Puram	11KV STR 100KVA STATION TRANSFORMER. NO.-1	1	0	0	0	1	0	1
BRPL	South 3	R K Puram	11kv STR 100kVA STATION TRF NO.-1	1	0	0	0	1	0	1
BRPL	South 3	R K Puram	11kv STR 630KVA STATION TRANS.	1	0	0	0	1	0	1
BRPL	South 3	Hauz Khas	11kv FDR 11KV O/G ANDREWS GANJ POLICE STATION	2	0	1	0	1	1	1
BRPL	South 3	Hauz Khas	11kv FDR 11KV O/G COMMUNITY CENTER, NDSE-II	4	0	1	0	3	1	3
BRPL	South 3	Hauz Khas	11kv FDR 11KV O/G DJB PUMPING STATION HAZOORI LAL	1	0	1	0	0	1	0
BRPL	South 3	Hauz Khas	11kv FDR 11KV O/G TO S-BLOCK PANCHSHEEL PARK	7	0	0	0	7	0	7

BRPL	South 3	Hauz Khas	11kv FDR 11kv O/G YES BANK NDSE-2	3	0	1	0	2	1	2
BRPL	South 3	Hauz Khas	11kv FDR 11kv TO O/G MEDICAL ENCLAVE RMU	3	0	0	0	3	0	3
BRPL	South 3	Hauz Khas	11kv FDR 200FLAT AYURVIGYAN NAGAR	7	0	5	0	2	5	2
BRPL	South 3	Hauz Khas	11kv FDR A.I.I.M.S STAFF QUARTERS	5	0	0	0	5	0	5
BRPL	South 3	Hauz Khas	11kv FDR A-1 S.J ENCLAVE	8	0	0	0	8	0	8
BRPL	South 3	Hauz Khas	11kv FDR A2/15 PSS S.J.ENCLAVE	5	0	0	0	5	0	5
BRPL	South 3	Hauz Khas	11kv FDR AGVC NO.-2	4	0	0	0	4	0	4
BRPL	South 3	Hauz Khas	11kv FDR AGVC S/STN. NO.-3	4	0	0	0	4	0	4
BRPL	South 3	Hauz Khas	11kv FDR AIIMS SURGICAL BLOCK-1	4	0	0	0	4	0	4
BRPL	South 3	Hauz Khas	11kv FDR AYURVIGYAN NAGAR S/S NO.-2	7	0	0	0	7	0	7
BRPL	South 3	Hauz Khas	11kv FDR B & C BLOCK PANCHSHEEL ENCL.	6	0	0	0	6	0	6
BRPL	South 3	Hauz Khas	11kv FDR B-3 JHANDU SINGH MARG	7	0	0	0	7	0	7
BRPL	South 3	Hauz Khas	11kv FDR B-4, S.J ENCLAVE	4	0	0	0	4	0	4
BRPL	South 3	Hauz Khas	11kv FDR B-5, S.J ENCLAVE	5	0	0	0	5	0	5
BRPL	South 3	Hauz Khas	11kv FDR B-6, S.J ENCLAVE	3	0	0	0	3	0	3
BRPL	South 3	Hauz Khas	11kv FDR B-7, S.J ENCLAVE	6	0	0	0	6	0	6
BRPL	South 3	Hauz Khas	11kv FDR BHIM NAGRI (I.I.T S/S NO.-2	7	0	2	0	5	2	5
BRPL	South 3	Hauz Khas	11kv FDR CREAMATION GROUND, I/D G.P EXTN.	5	0	0	0	5	0	5
BRPL	South 3	Hauz Khas	11kv FDR CSMRS (DOUBLE CABLE)	6	0	2	0	4	2	4
BRPL	South 3	Hauz Khas	11kv FDR GREEN PARK EXTN.	4	0	0	0	4	0	4
BRPL	South 3	Hauz Khas	11kv FDR GREEN PARK MAIN	4	0	0	0	4	0	4
BRPL	South 3	Hauz Khas	11kv FDR HUDCO S/S NO.-2 (OLD)	1	0	0	0	1	0	1
BRPL	South 3	Hauz Khas	11kv FDR N.D.S.E-2 (HUDCO SIDE)	2	0	0	0	2	0	2
BRPL	South 3	Hauz Khas	11kv FDR NITI BAGH	8	0	3	0	5	3	5
BRPL	South 3	Hauz Khas	11kv FDR O/G 40-SAHPUR JAT	8	0	0	0	8	0	8
BRPL	South 3	Hauz Khas	11kv FDR O/G C-17 PANCH SHEEL PARK (RMU) NEAR FLY OVER	1	0	1	0	0	1	0
BRPL	South 3	Hauz Khas	11kv FDR O/G DAKSHIN DEEP SADIQ NAGAR	9	0	0	0	9	0	9
BRPL	South 3	Hauz Khas	11kv FDR O/G E-BLOCK HAUZ KHAS	4	0	0	0	4	0	4
BRPL	South 3	Hauz Khas	11kv FDR O/G GREEN PARK EXTENSION	3	0	0	0	3	0	3
BRPL	South 3	Hauz Khas	11kv FDR O/G GULMOHAR ENCLAVE	6	0	1	0	5	1	5
BRPL	South 3	Hauz Khas	11kv FDR O/G GULMOHAR PARK	5	0	0	0	5	0	5
BRPL	South 3	Hauz Khas	11kv FDR O/G HARDEV PURI HKS	2	0	1	0	1	1	1
BRPL	South 3	Hauz Khas	11kv FDR O/G HUDCO 4-PANEL BOARD	1	0	0	0	1	0	1
BRPL	South 3	Hauz Khas	11kv FDR O/G HUDCO S/S NO.-6	15	0	2	0	13	2	13
BRPL	South 3	Hauz Khas	11kv FDR O/G I.O.C BUILDING	8	0	0	0	8	0	8
BRPL	South 3	Hauz Khas	11kv FDR O/G INSTITUTIONAL AREA HAUZ KHAS	6	0	0	0	6	0	6
BRPL	South 3	Hauz Khas	11kv FDR O/G KATWARIA SARAI (MULTI STORY) NO.-1	4	0	0	0	4	0	4
BRPL	South 3	Hauz Khas	11kv FDR O/G L-BLOCK HAUZ KHAS	4	0	0	0	4	0	4
BRPL	South 3	Hauz Khas	11kv FDR O/G N-98 PANCHSHEEL PARK	4	0	0	0	4	0	4
BRPL	South 3	Hauz Khas	11kv FDR O/G POLICE COLONY ANDREWS GANJ	5	0	3	0	2	3	2
BRPL	South 3	Hauz Khas	11kv FDR O/G PROFESSOR FLATS I.I.T S/STN	4	0	0	0	4	0	4
BRPL	South 3	Hauz Khas	11kv FDR O/G R.K.KHANNA STADIUM	1	0	0	0	1	0	1
BRPL	South 3	Hauz Khas	11kv FDR O/G S.I.I.A NO.-5,KATWARIA SARAI	4	0	0	0	4	0	4
BRPL	South 3	Hauz Khas	11kv FDR O/G SHOPPING CENTER PANCHSHEEL	7	0	0	0	7	0	7
BRPL	South 3	Hauz Khas	11kv FDR O/G SOAMI NAGAR	6	0	0	0	6	0	6
BRPL	South 3	Hauz Khas	11kv FDR O/G TELEPHONE EXCHANGE S.D.A	7	0	0	0	7	0	7
BRPL	South 3	Hauz Khas	11kv FDR O/G TIFAC BUILDING	4	0	0	0	4	0	4
BRPL	South 3	Hauz Khas	11kv FDR O/G TO BHIM NAGRI S.D.A	3	0	0	0	3	0	3
BRPL	South 3	Hauz Khas	11kv FDR O/G TO C-1 TIKONA PARK S.D.A	4	0	0	0	4	0	4
BRPL	South 3	Hauz Khas	11kv FDR O/G TO MAYFAIR GARDEN	5	0	0	0	5	0	5
BRPL	South 3	Hauz Khas	11kv FDR PANCHSHEEL CLUB	5	0	0	0	5	0	5
BRPL	South 3	Hauz Khas	11kv FDR PHD HOUSE	6	0	0	0	6	0	6
BRPL	South 3	Hauz Khas	11kv FDR R.K KHANNA STADIUM	8	0	0	0	8	0	8
BRPL	South 3	Hauz Khas	11kv FDR RAJ NAGAR	11	0	0	0	11	0	11
BRPL	South 3	Hauz Khas	11kv FDR S.I.I.A NO.-1	2	0	0	0	2	0	2
BRPL	South 3	Hauz Khas	11kv FDR S.I.I.A NO.-4	1	0	0	0	1	0	1
BRPL	South 3	Hauz Khas	11kv FDR S.I.I.A NO.-II	5	0	0	0	5	0	5
BRPL	South 3	Hauz Khas	11kv FDR TIKONA PARK	21	0	2	0	19	2	19
BRPL	South 3	Hauz Khas	11kv FDR YUSUF SARAI COMM. CENTER	4	0	0	0	4	0	4
BRPL	South 3	Hauz Khas	11kv FDR O/G I.I.T MINI CAMPUS	3	0	0	0	3	0	3
BRPL	South 3	Hauz Khas	11kv O/G D-3 HTC NDSE-II ANDREWS GANJ MAIN	9	0	0	0	9	0	9
BRPL	South 3	Hauz Khas	11kv OG AIIMS STAFF QTRS	4	0	1	0	3	1	3
BRPL	South 3	Hauz Khas	11kv STR 100kVA STATION TRF	1	0	0	0	1	0	1
BRPL	South 3	Hauz Khas	11kv STR 100kVA STATION TRF. NO.1	1	0	0	0	1	0	1
BRPL	South 3	Hauz Khas	11kv STR 315kVA STATION TRANS.	1	0	0	0	1	0	1

BRPL	South 3	Hauz Khas	AIIMS TRAUMA CENTER TO AIIMS-2 M.MOTH	1	0	0	0	1	0	1
BRPL	West 1	Janak Puri	11 kv FDR C1A (AMROOD WALA) JKP	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11 KV FDR PLOT NO.-7A, D.C JANAKPURI	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11KV FDR 11&12 BLK SUBHASH NAGAR	1	0	0	0	1	0	1
BRPL	West 1	Janak Puri	11KV FDR 14-BLOCK SUBHASH NAGAR	6	0	0	0	6	0	6
BRPL	West 1	Janak Puri	11KV FDR 6 BLK SUBASH NAGAR	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11KV FDR A-1 MOTHER DAIRY	5	0	3	0	2	3	2
BRPL	West 1	Janak Puri	11KV FDR A-15 MAYAPURI	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11KV FDR A-2 BANK QTR RAJOURI GARDEN	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11KV FDR A-4 JKP(ASALAT PUR)	12	0	2	0	10	2	10
BRPL	West 1	Janak Puri	11KV FDR A-43 MAYA PURI	2	0	0	0	2	0	2
BRPL	West 1	Janak Puri	11KV FDR A-8 PH-1 MYP:PL	2	0	0	0	2	0	2
BRPL	West 1	Janak Puri	11KV FDR AJANTA	8	0	0	0	8	0	8
BRPL	West 1	Janak Puri	11KV FDR AJANTA ID SSTN	4	0	0	0	4	0	4
BRPL	West 1	Janak Puri	11KV FDR ARIJUN BAKERY MANAK VIHAR	5	0	0	0	5	0	5
BRPL	West 1	Janak Puri	11KV FDR B-125 PHASE-1	1	0	0	0	1	0	1
BRPL	West 1	Janak Puri	11KV FDR B-2 BOOSTER PUMP B-2 JKP	5	0	2	0	3	2	3
BRPL	West 1	Janak Puri	11KV FDR B2 JKP (CHANAN DEVI)	8	0	0	0	8	0	8
BRPL	West 1	Janak Puri	11KV FDR B2 JKP CHANAN DEVI	1	0	0	0	1	0	1
BRPL	West 1	Janak Puri	11KV FDR B-3 SS 3 JANAKPURI	8	0	2	0	6	2	6
BRPL	West 1	Janak Puri	11KV FDR B-32 MAYAPURI	3	0	0	0	3	0	3
BRPL	West 1	Janak Puri	11KV FDR B-32 MAYAPURI PH-1	2	0	0	0	2	0	2
BRPL	West 1	Janak Puri	11KV FDR B-49 MAYAPURI	4	0	0	0	4	0	4
BRPL	West 1	Janak Puri	11KV FDR B6 INDOOR, CHOTI SABZI MANDI	4	0	2	0	2	2	2
BRPL	West 1	Janak Puri	11KV FDR BOOSTER PUMP (DELHI CANTT)	2	0	0	0	2	0	2
BRPL	West 1	Janak Puri	11KV FDR BOOSTER PUMP JKP	6	0	6	0	0	6	0
BRPL	West 1	Janak Puri	11KV FDR C-2 A	3	0	0	0	3	0	3
BRPL	West 1	Janak Puri	11KV FDR C-2 JKP	8	0	0	0	8	0	8
BRPL	West 1	Janak Puri	11KV FDR C-3 COMPLAINT CENTER JKP	6	0	0	0	6	0	6
BRPL	West 1	Janak Puri	11KV FDR C-4 JANAK PURI	6	0	0	0	6	0	6
BRPL	West 1	Janak Puri	11KV FDR C-88 MAYA PURI	5	0	0	0	5	0	5
BRPL	West 1	Janak Puri	11KV FDR CCRA SSTN JKP	6	0	0	0	6	0	6
BRPL	West 1	Janak Puri	11KV FDR CET PLANT MAYAPURI	1	0	0	0	1	0	1
BRPL	West 1	Janak Puri	11KV FDR CNG PUMP D. CENTER	2	0	0	0	2	0	2
BRPL	West 1	Janak Puri	11KV FDR COMMUNITY CENTER (PETROL PUMP)	1	0	0	0	1	0	1
BRPL	West 1	Janak Puri	11KV FDR COMMUNITY CENTER MAYAPURI PHASE-1	5	0	0	0	5	0	5
BRPL	West 1	Janak Puri	11KV FDR COMMUNITY CENTRE SSTN-1 (PETROL PUMP JKP)	4	0	0	0	4	0	4
BRPL	West 1	Janak Puri	11KV FDR D-1 JKP(CNG PUMP)	6	0	0	0	6	0	6
BRPL	West 1	Janak Puri	11KV FDR D-1 SUB STN JKP	11	0	0	0	11	0	11
BRPL	West 1	Janak Puri	11KV FDR D-2 JKP	5	0	0	0	5	0	5
BRPL	West 1	Janak Puri	11KV FDR D-BLK KHAJAN BASTI	6	0	0	0	6	0	6
BRPL	West 1	Janak Puri	11KV FDR DDU HOSPITAL	2	0	0	0	2	0	2
BRPL	West 1	Janak Puri	11KV FDR DDU STAFF QUTRS	7	0	2	0	5	2	5
BRPL	West 1	Janak Puri	11KV FDR DELHI HAAT	2	0	1	0	1	1	1
BRPL	West 1	Janak Puri	11KV FDR DISTRICT SERVICE CENTRE	3	0	0	0	3	0	3
BRPL	West 1	Janak Puri	11KV FDR DTC MAYAPURI E-BUS CHARGING NO. 2	11	0	2	0	9	2	9
BRPL	West 1	Janak Puri	11KV FDR E-BLK MAYAPURI PH-2:ID	1	0	0	0	1	0	1
BRPL	West 1	Janak Puri	11KV FDR FACILITY CENTRE	8	0	1	0	7	1	7
BRPL	West 1	Janak Puri	11KV FDR FATEH NAGAR	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11KV FDR F-BLK MAYAPURI	9	0	0	0	9	0	9
BRPL	West 1	Janak Puri	11KV FDR F-BLK RAJOURI GARDEN	8	0	0	0	8	0	8
BRPL	West 1	Janak Puri	11KV FDR GANDHI PARK ID SSTN	5	0	0	0	5	0	5
BRPL	West 1	Janak Puri	11KV FDR G-BLK HARI NAGAR	5	0	4	0	1	4	1
BRPL	West 1	Janak Puri	11KV FDR GILL HOUSE	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11KV FDR GOPAL NAGAR	6	0	0	0	6	0	6
BRPL	West 1	Janak Puri	11KV FDR GURUDWARA R GARDEN	6	0	0	0	6	0	6
BRPL	West 1	Janak Puri	11KV FDR GURUDWARA RAJAURI GDN	6	0	0	0	6	0	6
BRPL	West 1	Janak Puri	11KV FDR GURUDWARA RAJOURI GARDEN	1	0	0	0	1	0	1
BRPL	West 1	Janak Puri	11KV FDR I-BLOCK SAGARPUR	5	0	1	0	4	1	4
BRPL	West 1	Janak Puri	11KV FDR INSTITUTIONAL AREA JKP	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11KV FDR J-3 RAJOURI GDN	4	0	0	0	4	0	4
BRPL	West 1	Janak Puri	11KV FDR J-BLK C C RAJOURI	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11KV FDR JYOTI SHIKHAR PLOT NO 8 (RMU)	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11KV FDR KACHCHA TIHAR	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11KV FDR L.I.G RAJOURI GARDEN	5	0	0	0	5	0	5
BRPL	West 1	Janak Puri	11KV FDR LIG RAJOURI GADAN	5	0	0	0	5	0	5
BRPL	West 1	Janak Puri	11KV FDR LIG-149	6	0	0	0	6	0	6
BRPL	West 1	Janak Puri	11KV FDR MAHARANI SS	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11KV FDR METAL FORGING	4	0	0	0	4	0	4

BRPL	West 1	Janak Puri	11kv FDR MIG RAJOURI GADAN	6	0	0	0	6	0	6
BRPL	West 1	Janak Puri	11KV FDR MIG RAJOURI GARDEN	10	0	0	0	10	0	10
BRPL	West 1	Janak Puri	11kv FDR MOHAN MANDIR HARI NAGAR-K	2	0	0	0	2	0	2
BRPL	West 1	Janak Puri	11kv FDR MOHAN NAGAR MANDIR WALA	6	0	0	0	6	0	6
BRPL	West 1	Janak Puri	11KV FDR MS BUILDING COMM CENTER-JKP	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11KV FDR MS BULDING	1	0	0	0	1	0	1
BRPL	West 1	Janak Puri	11kv FDR MUSICAL FOUNTAIN	5	0	2	0	3	2	3
BRPL	West 1	Janak Puri	11kv FDR NANGLI ZALIB	9	0	3	0	6	3	6
BRPL	West 1	Janak Puri	11kv FDR P&T QTRS (JKP)	8	0	3	0	5	3	5
BRPL	West 1	Janak Puri	11kv FDR PLOT NO 5 DC JKP	9	0	0	0	9	0	9
BRPL	West 1	Janak Puri	11kv FDR PLOT NO-11 DISTT CENTER + BOOSTER PUMP JKP PT VIA RMU NO-2	12	0	5	0	7	5	7
BRPL	West 1	Janak Puri	11kv FDR PLOT NO-13 LIC BUILDING(DC)	11	0	6	0	5	6	5
BRPL	West 1	Janak Puri	11kv FDR POLICE CHOWKY	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11kv FDR POLICE STN MAYAPURI	1	0	0	0	1	0	1
BRPL	West 1	Janak Puri	11KV FDR PUMPING STN S ASRAM	6	0	2	0	4	2	4
BRPL	West 1	Janak Puri	11kv FDR Q BLK RAJOURI GARDEN	4	0	0	0	4	0	4
BRPL	West 1	Janak Puri	11kv FDR RAGHU NAGAR (NEW)	5	0	2	0	3	2	3
BRPL	West 1	Janak Puri	11kv FDR RAMPURA SSTN	4	0	0	0	4	0	4
BRPL	West 1	Janak Puri	11kv FDR RED MIG RAJOURI GARDEN	4	0	0	0	4	0	4
BRPL	West 1	Janak Puri	11kv FDR RMU	4	0	0	0	4	0	4
BRPL	West 1	Janak Puri	11kv FDR RMU NO-2	4	0	0	0	4	0	4
BRPL	West 1	Janak Puri	11kv FDR SFS NO-1	10	0	2	0	8	2	8
BRPL	West 1	Janak Puri	11kv FDR SHIV NAGAR	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11kv FDR SHIV NAGAR EXTN	3	0	1	0	2	1	2
BRPL	West 1	Janak Puri	11kv FDR SSTN NO-2 SUBHASH NAGAR	7	0	0	0	7	0	7
BRPL	West 1	Janak Puri	11kv FDR SSTN NO-3 SUBASH NAGAR CHHATRIWALA	4	0	0	0	4	0	4
BRPL	West 1	Janak Puri	11kv FDR SUB DISTT CENTER NO-2 HARI NAGAR	3	0	0	0	3	0	3
BRPL	West 1	Janak Puri	11kv FDR SUBHASH NAGAR	4	0	0	0	4	0	4
BRPL	West 1	Janak Puri	11kv FDR TIHAR JAIL	4	0	0	0	4	0	4
BRPL	West 1	Janak Puri	11kv FDR TIHAR JAIL NO-5	9	0	0	0	9	0	9
BRPL	West 1	Janak Puri	11KV RAWTA	1	0	0	0	1	0	1
BRPL	West 1	Janak Puri	11KV RMU OUTSIDE GRID	1	0	0	0	1	0	1
BRPL	West 1	Janak Puri	11kv STR STATION TRANSFORMER NO-1	1	0	0	0	1	0	1
BRPL	West 4	Najafgarh	11kv FDR 5-MGD PUMPING SS NO-2	3	0	2	0	1	2	1
BRPL	West 4	Najafgarh	11kv FDR 7 PANEL BOARD	21	0	17	0	4	17	4
BRPL	West 4	Najafgarh	11kv FDR 810 DDA. FLATS SEC-26(DWK)	9	0	9	0	0	9	0
BRPL	West 4	Najafgarh	11kv FDR ANAJ MANDI	18	0	12	0	6	12	6
BRPL	West 4	Najafgarh	11kv FDR ARJUN PARK	14	0	9	0	5	9	5
BRPL	West 4	Najafgarh	11kv FDR B.S.F CHAWLA CAMP	11	0	11	0	0	11	0
BRPL	West 4	Najafgarh	11kv FDR BABA HARDAS	30	0	28	0	2	28	2
BRPL	West 4	Najafgarh	11kv FDR BAMNAULI	35	0	31	0	4	31	4
BRPL	West 4	Najafgarh	11kv FDR BDO OFFICE	4	0	3	0	1	3	1
BRPL	West 4	Najafgarh	11kv FDR BHARTHAL	14	0	12	0	2	12	2
BRPL	West 4	Najafgarh	11kv FDR CHAUHAN ENCLAVE	6	0	2	0	4	2	4
BRPL	West 4	Najafgarh	11kv FDR CHAWLA TANK	9	0	5	0	4	5	4
BRPL	West 4	Najafgarh	11kv FDR CHHAWLA	15	0	13	0	2	13	2
BRPL	West 4	Najafgarh	11kv FDR DAULAT PUR	18	0	17	0	1	17	1
BRPL	West 4	Najafgarh	11kv FDR DDA POCKET 4 DWARKA SEC-23B	4	0	3	0	1	3	1
BRPL	West 4	Najafgarh	11kv FDR DDA POCKET 7 DWARKA SEC-23B	4	0	4	0	0	4	0
BRPL	West 4	Najafgarh	11kv FDR DDA POCKET 9 DWARKA SEC-23B	8	0	7	0	1	7	1
BRPL	West 4	Najafgarh	11kv FDR DEENPUR	24	0	15	0	9	15	9
BRPL	West 4	Najafgarh	11KV FDR DELHI GATE	8	0	7	0	1	7	1
BRPL	West 4	Najafgarh	11kv FDR DHOOL SHIRAS	22	0	19	0	3	19	3
BRPL	West 4	Najafgarh	11kv FDR DICHONAN	20	0	18	0	2	18	2
BRPL	West 4	Najafgarh	11kv FDR DJB UGR DICHONAN NO-1	1	0	0	0	1	0	1
BRPL	West 4	Najafgarh	11kv FDR DJB-1	13	0	8	0	5	8	5
BRPL	West 4	Najafgarh	11kv FDR DMRC STAFF QUARTERS	11	0	7	0	4	7	4
BRPL	West 4	Najafgarh	11kv FDR DTL COLONY	26	0	19	0	7	19	7
BRPL	West 4	Najafgarh	11kv FDR G-BLOCK SHYAM VIHAR	7	0	3	0	4	3	4
BRPL	West 4	Najafgarh	11KV FDR GHUMANHERA MORE	22	0	1	0	21	1	21
BRPL	West 4	Najafgarh	11kv FDR GOYALA DAIRY	12	0	8	0	4	8	4
BRPL	West 4	Najafgarh	11kv FDR GOYALA SCHOOL BD CWL	9	0	7	0	2	7	2
BRPL	West 4	Najafgarh	11kv FDR HANUMAN CHOWK	19	0	15	0	4	15	4
BRPL	West 4	Najafgarh	11kv FDR JHARODA	7	0	7	0	0	7	0
BRPL	West 4	Najafgarh	11kv FDR JHATIKARA MORE	58	0	45	0	13	45	13
BRPL	West 4	Najafgarh	11kv FDR KAKROLA FEEDER	15	0	7	0	8	7	8
BRPL	West 4	Najafgarh	11kv FDR KANGAN HERI	26	0	20	0	6	20	6
BRPL	West 4	Najafgarh	11KV FDR KHAIRA	14	0	13	0	1	13	1

BRPL	West 4	Najafgarh	11kv FDR NANGLI SHAKRAWATI	10	0	9	0	1	9	1
BRPL	West 4	Najafgarh	11kv FDR PANDWALA	13	0	10	0	3	10	3
BRPL	West 4	Najafgarh	11kv FDR POCHAN PUR	14	0	12	0	2	12	2
BRPL	West 4	Najafgarh	11KV FDR POCHANPUR	1	0	0	0	1	0	1
BRPL	West 4	Najafgarh	11kv FDR PRASHANT SS-BD CWL	8	0	8	0	0	8	0
BRPL	West 4	Najafgarh	11kv FDR PREM NAGAR	16	0	5	0	11	5	11
BRPL	West 4	Najafgarh	11kv FDR PUMPING STATION	8	0	4	0	4	4	4
BRPL	West 4	Najafgarh	11kv FDR QUTUB VIHAR PH-2	12	0	11	0	1	11	1
BRPL	West 4	Najafgarh	11kv FDR RAMA PARK	17	0	10	0	7	10	7
BRPL	West 4	Najafgarh	11kv FDR ROSHAN GARDEN S/S NO.-2	1	0	0	0	1	0	1
BRPL	West 4	Najafgarh	11kv FDR ROSHAN PURA	8	0	3	0	5	3	5
BRPL	West 4	Najafgarh	11kv FDR ROSHAN PURA X-1	14	0	10	0	4	10	4
BRPL	West 4	Najafgarh	11kv FDR SAINIK ENCLAVE FEEDER	11	0	9	0	2	9	2
BRPL	West 4	Najafgarh	11kv FDR SHYAM ENCLAVE	5	0	2	0	3	2	3
BRPL	West 4	Najafgarh	11kv FDR SHYAM VIHAR	9	0	5	0	4	5	4
BRPL	West 4	Najafgarh	11kv FDR SHYAM VIHAR PH-2	2	0	1	0	1	1	1
BRPL	West 4	Najafgarh	11kv FDR STAFF QUR 50 MGD NJF	1	0	1	0	0	1	0
BRPL	West 4	Najafgarh	11kv FDR TAJPUR	3	0	3	0	0	3	0
BRPL	West 4	Najafgarh	11kv FDR TP KOTLA	32	0	11	0	21	11	21
BRPL	West 4	Najafgarh	11kv FDR VARDHMAN VIHAR	6	0	2	0	4	2	4
BRPL	West 4	Najafgarh	11kv FDR VILL.AMBERHAI	8	0	7	0	1	7	1
BRPL	West 4	Najafgarh	11kv MCD SCHOOL QUTUB VIHAR	19	0	17	0	2	17	2
BRPL	West 4	Jaffarpur	11kv FDR ARADHNA ENCLAVE	6	0	4	0	2	4	2
BRPL	West 4	Jaffarpur	11kv FDR DABAR ENCLAVE	3	0	0	0	3	0	3
BRPL	West 4	Jaffarpur	11kv FDR DHANSA	40	0	19	0	21	19	21
BRPL	West 4	Jaffarpur	11kv FDR GANGOTRI	10	0	8	0	2	8	2
BRPL	West 4	Jaffarpur	11kv FDR ISSAPUR	24	0	14	0	10	14	10
BRPL	West 4	Jaffarpur	11kv FDR JAFFAR PUR	20	0	2	0	18	2	18
BRPL	West 4	Jaffarpur	11kv FDR JHUL JHULI	13	0	0	0	13	0	13
BRPL	West 4	Jaffarpur	11kv FDR KAIR VILLAGE	11	0	3	0	8	3	8
BRPL	West 4	Jaffarpur	11kv FDR KHERA DABAR	30	0	14	0	16	14	16
BRPL	West 4	Jaffarpur	11kv FDR MALIK PUR	11	0	6	0	5	6	5
BRPL	West 4	Jaffarpur	11kv FDR MITRAON	3	0	2	0	1	2	1
BRPL	West 4	Jaffarpur	11kv FDR NETAJI LANE	2	0	2	0	0	2	0
BRPL	West 4	Jaffarpur	11kv FDR NEW C.R.P.F.	2	0	0	0	2	0	2
BRPL	West 4	Jaffarpur	11kv FDR NEW MITRAON	12	0	10	0	2	10	2
BRPL	West 4	Jaffarpur	11kv FDR NEW MUNDHELA	34	0	6	0	28	6	28
BRPL	West 4	Jaffarpur	11kv FDR NEW THANA	11	0	4	0	7	4	7
BRPL	West 4	Jaffarpur	11kv FDR P-BLOCK GOPAL NAGAR FEEDER	9	0	5	0	4	5	4
BRPL	West 4	Jaffarpur	11kv FDR R.T.R.M. HOSPITAL	13	0	0	0	13	0	13
BRPL	West 4	Jaffarpur	11kv FDR RAIL MASTER	5	0	4	0	1	4	1
BRPL	West 4	Jaffarpur	11kv FDR RAWTA	17	0	0	0	17	0	17
BRPL	West 4	Jaffarpur	11kv FDR SURAKHPUR ROAD GOPAL NAGAR	8	0	5	0	3	5	3
BRPL	West 4	Jaffarpur	11kv FDR SUREHRA VILLAGE	6	0	6	0	0	6	0
BRPL	West 2	Nangloi	11kv FDR 1140 SFS FLATS	16	0	1	0	15	1	15
BRPL	West 2	Nangloi	11kv FDR 1200 M.I.G. FLATS.	8	0	0	0	8	0	8
BRPL	West 2	Nangloi	11kv FDR 1312 LIG FLATS	9	0	0	0	9	0	9
BRPL	West 2	Nangloi	11kv FDR 656 MIG FLATS	5	0	0	0	5	0	5
BRPL	West 2	Nangloi	11kv FDR 688 LIG FLATS(GH-8)	6	0	0	0	6	0	6
BRPL	West 2	Nangloi	11kv FDR A BLK NIHAL VIHAR	1	0	0	0	1	0	1
BRPL	West 2	Nangloi	11kv FDR ADHYAPAK NAGAR	3	0	0	0	3	0	3
BRPL	West 2	Nangloi	11kv FDR AMANPURI HVDS	4	0	0	0	4	0	4
BRPL	West 2	Nangloi	11kv FDR AMBEDKAR CHOWK	8	0	0	0	8	0	8
BRPL	West 2	Nangloi	11kv FDR AMBICA VIHAR	6	0	0	0	6	0	6
BRPL	West 2	Nangloi	11kv FDR BAPROLA NO-2 (UG)	1	0	0	0	1	0	1
BRPL	West 2	Nangloi	11kv FDR BAPROLA OLD O/H	9	0	0	0	9	0	9
BRPL	West 2	Nangloi	11kv FDR BAPROLA NO2 (UG)	2	0	0	0	2	0	2
BRPL	West 2	Nangloi	11kv FDR CHANDER VIHAR	4	0	0	0	4	0	4
BRPL	West 2	Nangloi	11kv FDR D.S.I.D.C	9	0	0	0	9	0	9
BRPL	West 2	Nangloi	11kv FDR DEEPAK VIHAR	5	0	0	0	5	0	5
BRPL	West 2	Nangloi	11kv FDR DJB SPS NILOTHI NO.-2	5	0	0	0	5	0	5
BRPL	West 2	Nangloi	11kv FDR E-BLOCK NIHAL VIHAR	6	0	0	0	6	0	6
BRPL	West 2	Nangloi	11kv FDR F & S BLOCK NIHAL VIHAR	8	0	0	0	8	0	8
BRPL	West 2	Nangloi	11kv FDR F-BLOCK D.S.I.D.C	3	0	0	0	3	0	3
BRPL	West 2	Nangloi	11kv FDR GH-14	14	0	0	0	14	0	14
BRPL	West 2	Nangloi	11kv FDR GRAMSABHA NILOTHI	6	0	0	0	6	0	6
BRPL	West 2	Nangloi	11kv FDR HANUMAN MANDIR	21	0	7	0	14	7	14
BRPL	West 2	Nangloi	11kv FDR H-BLOCK DSIDC ID SSTN	4	0	0	0	4	0	4
BRPL	West 2	Nangloi	11kv FDR HINDUSTAN SOCIETY	8	0	0	0	8	0	8
BRPL	West 2	Nangloi	11kv FDR JAT MOHALLA	4	0	0	0	4	0	4
BRPL	West 2	Nangloi	11kv FDR JAWALAPURI CAMP NO.4	9	0	0	0	9	0	9
BRPL	West 2	Nangloi	11kv FDR LAXMI PARK	6	0	0	0	6	0	6
BRPL	West 2	Nangloi	11kv FDR LAXMI PARK NO2	9	0	0	0	9	0	9
BRPL	West 2	Nangloi	11kv FDR LIC COLONY	3	0	0	0	3	0	3
BRPL	West 2	Nangloi	11kv FDR MEERA BAGH	5	0	0	0	5	0	5

BRPL	West 2	Nangloi	11kv FDR MTNL NO-2	9	0	0	0	9	0	9
BRPL	West 2	Nangloi	11kv FDR NANGLOI NO 2	5	0	0	0	5	0	5
BRPL	West 2	Nangloi	11kv FDR NANGLOI 1	5	0	0	0	5	0	5
BRPL	West 2	Nangloi	11kv FDR NIHAL VIHAR	5	0	0	0	5	0	5
BRPL	West 2	Nangloi	11kv FDR NILOTHI	6	0	0	0	6	0	6
BRPL	West 2	Nangloi	11KV FDR O/G S/STN.NO-1 UDYOG NGR	1	0	0	0	1	0	1
BRPL	West 2	Nangloi	11KV FDR O/G S/STN.NO-3 UDYOG NGR(OLD)	1	0	0	0	1	0	1
BRPL	West 2	Nangloi	11kv FDR P.V.C. MKT.JAWALA PURI (R2BLOCK)	9	0	0	0	9	0	9
BRPL	West 2	Nangloi	11kv FDR PEERA GARHI SS NO-3	4	0	0	0	4	0	4
BRPL	West 2	Nangloi	11kv FDR PEERAGRAHI S/STN NO27	6	0	0	0	6	0	6
BRPL	West 2	Nangloi	11KV FDR PEERAGRAHI SS-7	1	0	0	0	1	0	1
BRPL	West 2	Nangloi	11kv FDR RAIL NEER PLANT	3	0	0	0	3	0	3
BRPL	West 2	Nangloi	11kv FDR RAJEEV RATAN NO21	6	0	0	0	6	0	6
BRPL	West 2	Nangloi	11kv FDR RAJEEV RATAN NO22	2	0	0	0	2	0	2
BRPL	West 2	Nangloi	11kv FDR RAJIV RATAN-1	10	0	0	0	10	0	10
BRPL	West 2	Nangloi	11kv FDR RAJIV RATAN-2	15	0	0	0	15	0	15
BRPL	West 2	Nangloi	11kv FDR RAJIV RATAN-3	11	0	0	0	11	0	11
BRPL	West 2	Nangloi	11kv FDR S/STN NO21 MIANWALI NAGAR	2	0	0	0	2	0	2
BRPL	West 2	Nangloi	11kv FDR S/STN NO22 MIANWALI NGR (NEW)	8	0	0	0	8	0	8
BRPL	West 2	Nangloi	11kv FDR S/STN, NO23 UDYOG NGR (OLD)	5	0	0	0	5	0	5
BRPL	West 2	Nangloi	11kv FDR S/STN,NO21 UDYOG NAGAR	8	0	0	0	8	0	8
BRPL	West 2	Nangloi	11kv FDR S/STN,NO22 UDYOG NAGAR	2	0	0	0	2	0	2
BRPL	West 2	Nangloi	11kv FDR SAINI MOHALLA	5	0	0	0	5	0	5
BRPL	West 2	Nangloi	11kv FDR SHANKAR GARDEN	6	0	0	0	6	0	6
BRPL	West 2	Nangloi	11kv FDR SHIV RAM PARK	3	0	0	0	3	0	3
BRPL	West 2	Nangloi	11kv FDR SHIVRAM PARK	1	0	0	0	1	0	1
BRPL	West 2	Nangloi	11kv FDR SSTN-5 VIA K-25	11	0	0	0	11	0	11
BRPL	West 2	Nangloi	11kv FDR STP NILOTHI(SHIV VIHAR)	5	0	1	0	4	1	4
BRPL	West 2	Nangloi	11kv FDR SUNDER VIHAR	12	0	0	0	12	0	12
BRPL	West 2	Nangloi	11kv FDR UDAY VIHAR	4	0	0	0	4	0	4
BRPL	West 2	Nangloi	11kv FDR UDYOG NAGAR NO21	2	0	0	0	2	0	2
BRPL	West 2	Nangloi	11kv FDR UDYOG NAGAR NO-1 (BHERA ENCLAVE)	6	0	0	0	6	0	6
BRPL	West 2	Nangloi	11kv FDR UDYOG NAGAR NO-2	5	0	0	0	5	0	5
BRPL	West 2	Nangloi	11kv FDR UDYOG NAGAR SS-4 NEW	7	0	0	0	7	0	7
BRPL	West 2	Nangloi	11kv FDR UDYOG NAGAR SSTN NO-3 (NEW)	4	0	0	0	4	0	4
BRPL	West 2	Nangloi	11kv FDR UDYOG NGR S/STN NO-4 (OLD)	1	0	0	0	1	0	1
BRPL	West 3	Mundka	11kv FDR ABHINANDAN VATIKA	22	0	19	0	3	19	3
BRPL	West 3	Mundka	11KV FDR ARVIND ENCL SS-3	1	0	1	0	0	1	0
BRPL	West 3	Mundka	11kv FDR ARVIND ENCLAVE S/S23	9	0	8	0	1	8	1
BRPL	West 3	Mundka	11kv FDR AZAD HIND GRAM	21	0	14	0	7	14	7
BRPL	West 3	Mundka	11kv FDR BAKKAR WALA	11	0	5	0	6	5	6
BRPL	West 3	Mundka	11kv FDR BAKKARWALA JJ COLONY	16	0	10	0	6	10	6
BRPL	West 3	Mundka	11kv FDR BOOSTER PUMP MUNDKA GOAN	5	0	5	0	0	5	0
BRPL	West 3	Mundka	11kv FDR BULBUL VATIKA	35	0	28	0	7	28	7
BRPL	West 3	Mundka	11kv FDR CHANCHAL PARK	11	0	7	0	4	7	4
BRPL	West 3	Mundka	11kv FDR COMMUNITY CENTRE	3	0	1	0	2	1	2
BRPL	West 3	Mundka	11kv FDR DDA. FLATS	41	0	24	0	17	24	17
BRPL	West 3	Mundka	11kv FDR GHEVERA MORE	14	0	10	0	4	10	4
BRPL	West 3	Mundka	11kv FDR HIRAN KUDNA	36	0	30	0	6	30	6
BRPL	West 3	Mundka	11kv FDR I.O.C	13	0	8	0	5	8	5
BRPL	West 3	Mundka	11kv FDR INDIAN OIL	4	0	4	0	0	4	0
BRPL	West 3	Mundka	11kv FDR J.J COLONEY NO.2	7	0	4	0	3	4	3
BRPL	West 3	Mundka	11kv FDR JAI VIHAR	11	0	9	0	2	9	2
BRPL	West 3	Mundka	11kv FDR KAMRUDEEN NGR.	6	0	6	0	0	6	0
BRPL	West 3	Mundka	11kv FDR KUWAR SINGH NAGAR	8	0	6	0	2	6	2
BRPL	West 3	Mundka	11kv FDR MEERA ENCLAVE	6	0	6	0	0	6	0
BRPL	West 3	Mundka	11kv FDR MUNDKA	1	0	0	0	1	0	1
BRPL	West 3	Mundka	11kv FDR MUNDKA LT LESS	27	0	24	0	3	24	3
BRPL	West 3	Mundka	11kv FDR NEEL WALL	11	0	9	0	2	9	2
BRPL	West 3	Mundka	11KV FDR NO-1 821,DDA FLATS,BAKKARWALA,MDK	10	0	0	0	10	0	10
BRPL	West 3	Mundka	11kv FDR POLICE QUATERS	5	0	3	0	2	3	2
BRPL	West 3	Mundka	11kv FDR PUNJABI BASTI	6	0	4	0	2	4	2
BRPL	West 3	Mundka	11kv FDR PVC MARKET-I	8	0	7	0	1	7	1
BRPL	West 3	Mundka	11kv FDR PVC MARKET-II	8	0	8	0	0	8	0
BRPL	West 3	Mundka	11kv FDR RAJDHANI PARK	10	0	6	0	4	6	4
BRPL	West 3	Mundka	11kv FDR RAJENDERA PARK	10	0	7	0	3	7	3
BRPL	West 3	Mundka	11kv FDR RANHOLLA	1	0	0	0	1	0	1
BRPL	West 3	Mundka	11kv FDR RANI KHERA MORE	20	0	17	0	3	17	3
BRPL	West 3	Mundka	11kv FDR SHIVA GARDEN	16	0	14	0	2	14	2
BRPL	West 3	Mundka	11kv FDR SUB STATION NO-5	7	0	6	0	1	6	1

BRPL	West 3	Mundka	11kv FDR SUBASH VIHAR-1	30	0	21	0	9	21	9
BRPL	West 3	Mundka	11kv FDR SUBASH VIHAR-2	5	0	5	0	0	5	0
BRPL	West 3	Mundka	11kv FDR SWARN PARK	6	0	5	0	1	5	1
BRPL	West 3	Mundka	11kv FDR TIKRI VILLAGE	1	0	1	0	0	1	0
BRPL	West 3	Mundka	11kv FDR VRINDAVAN VATIKA	24	0	18	0	6	18	6
BRPL	West 3	Mundka	11kv FDR YADAV PARK EXT	11	0	8	0	3	8	3
BRPL	West 2	Punjabi Bagh	11kv FDR 1212 JANTA QTRS. (C- BLK MADIPUR)	6	0	0	0	6	0	6
BRPL	West 2	Punjabi Bagh	11kv FDR 1212-JANTA FLATS	5	0	0	0	5	0	5
BRPL	West 2	Punjabi Bagh	11kv FDR 208 SFS QTRS.	6	0	0	0	6	0	6
BRPL	West 2	Punjabi Bagh	11kv FDR 240 MIG FLATS (208 SFS) MADIPUR	8	0	0	0	8	0	8
BRPL	West 2	Punjabi Bagh	11kv FDR 6 MILE STONE MADIPUR GATE	7	0	0	0	7	0	7
BRPL	West 2	Punjabi Bagh	11kv FDR A F O (DIST EAST PUNJABI BAGH)	3	0	0	0	3	0	3
BRPL	West 2	Punjabi Bagh	11kv FDR A-1 JANTA SS PASCHIM VIHAR	4	0	0	0	4	0	4
BRPL	West 2	Punjabi Bagh	11kv FDR A-2 COMMUNITY CENTER	11	0	0	0	11	0	11
BRPL	West 2	Punjabi Bagh	11kv FDR A-2 SSTN.	6	0	0	0	6	0	6
BRPL	West 2	Punjabi Bagh	11kv FDR A-3 DISPENSARY	6	0	0	0	6	0	6
BRPL	West 2	Punjabi Bagh	11kv FDR A-4 CASH OFFICE	7	0	0	0	7	0	7
BRPL	West 2	Punjabi Bagh	11kv FDR A-6 PASCHIM VIHAR	9	0	0	0	9	0	9
BRPL	West 2	Punjabi Bagh	11kv FDR A-BLOCK KARAMPURA	11	0	0	0	11	0	11
BRPL	West 2	Punjabi Bagh	11kv FDR ADASRSH BHAWAN	5	0	0	0	5	0	5
BRPL	West 2	Punjabi Bagh	11kv FDR ADRSH BHAWAN	3	0	0	0	3	0	3
BRPL	West 2	Punjabi Bagh	11kv FDR B.G-3	7	0	0	0	7	0	7
BRPL	West 2	Punjabi Bagh	11kv FDR B-2 SSTN.	6	0	0	0	6	0	6
BRPL	West 2	Punjabi Bagh	11kv FDR B-3 PASCHIM VIHAR	6	0	0	0	6	0	6
BRPL	West 2	Punjabi Bagh	11kv FDR B-G-3 PRAGATI APPT. PASCHIM VIHAR	8	0	0	0	8	0	8
BRPL	West 2	Punjabi Bagh	11kv FDR BHAGWAN DAS NAGAR	2	0	0	0	2	0	2
BRPL	West 2	Punjabi Bagh	11kv FDR BOOSTER PUMP PUNJABI BAGH	6	0	0	0	6	0	6
BRPL	West 2	Punjabi Bagh	11kv FDR CAPITAL MALL PASCHIM VIHAR	4	0	0	0	4	0	4
BRPL	West 2	Punjabi Bagh	11kv FDR C-BLK MADIPUR	3	0	0	0	3	0	3
BRPL	West 2	Punjabi Bagh	11kv FDR CHARKHI GATE	2	0	0	0	2	0	2
BRPL	West 2	Punjabi Bagh	11kv FDR COMMUNITY CENTER KARAMPURA	7	0	0	0	7	0	7
BRPL	West 2	Punjabi Bagh	11kv FDR COTTAGE ENCLAVE	1	0	0	0	1	0	1
BRPL	West 2	Punjabi Bagh	11kv FDR COTTEGE ENCLAVE	7	0	0	0	7	0	7
BRPL	West 2	Punjabi Bagh	11kv FDR D.T.C DEPOT	12	0	0	0	12	0	12
BRPL	West 2	Punjabi Bagh	11kv FDR G BLOCK PUSHKAR VIHAR	7	0	0	0	7	0	7
BRPL	West 2	Punjabi Bagh	11kv FDR HANSRAJ MODEL SCHOOL	5	0	0	0	5	0	5
BRPL	West 2	Punjabi Bagh	11kv FDR J.J CLUSTER SHIVA NAND SCHOOL	10	0	0	0	10	0	10
BRPL	West 2	Punjabi Bagh	11kv FDR JAIDEV PARK	4	0	0	0	4	0	4
BRPL	West 2	Punjabi Bagh	11kv FDR M.I.G MILANSAR APPARTMENT	10	0	0	0	10	0	10
BRPL	West 2	Punjabi Bagh	11kv FDR MULTAN NAGAR (C-BLOCK)	7	0	0	0	7	0	7
BRPL	West 2	Punjabi Bagh	11kv FDR PAL MOHAN APART.	6	0	0	0	6	0	6
BRPL	West 2	Punjabi Bagh	11kv FDR PASCHIM VIHAR EXT.	4	0	0	0	4	0	4
BRPL	West 2	Punjabi Bagh	11kv FDR PEERA GARHI BOOSTER PUMP	5	0	0	0	5	0	5
BRPL	West 2	Punjabi Bagh	11kv FDR PEERAGARHI BOOSTER PUMP	7	0	0	0	7	0	7
BRPL	West 2	Punjabi Bagh	11kv FDR PJB C. CENTER NO.-1	6	0	0	0	6	0	6
BRPL	West 2	Punjabi Bagh	11kv FDR POLICE STATION & QUATERS(PJB)	3	0	0	0	3	0	3
BRPL	West 2	Punjabi Bagh	11kv FDR PRAGATI APPARTMENT S/STN NO-2	4	0	0	0	4	0	4
BRPL	West 2	Punjabi Bagh	11kv FDR PUNJABI BAGH BOOSTER PUMP	4	0	0	0	4	0	4
BRPL	West 2	Punjabi Bagh	11kv FDR PUNJABI BAGH NO-2	10	0	0	0	10	0	10
BRPL	West 2	Punjabi Bagh	11kv FDR PUNJABI BAGH-1	7	0	0	0	7	0	7
BRPL	West 2	Punjabi Bagh	11kv FDR RBI COLONY WATER TANK	6	0	0	0	6	0	6
BRPL	West 2	Punjabi Bagh	11kv FDR SHAKTI SOCIETY S/SNO-4	7	0	0	0	7	0	7
BRPL	West 2	Punjabi Bagh	11kv FDR SHIV MANDIR	6	0	0	0	6	0	6
BRPL	West 2	Punjabi Bagh	11kv FDR SHWAYAM.SIDHA	1	0	0	0	1	0	1
BRPL	West 2	Punjabi Bagh	11kv FDR SITE-7	7	0	0	0	7	0	7
BRPL	West 2	Punjabi Bagh	11kv FDR SLUM TREATMENT	10	0	0	0	10	0	10
BRPL	West 2	Punjabi Bagh	11kv FDR STATE BANK NAGAR	9	0	0	0	9	0	9
BRPL	West 2	Punjabi Bagh	11kv FDR SWAYAM SIDHA	6	0	0	0	6	0	6
BRPL	West 2	Punjabi Bagh	11kv FDR TRANSPORT CENTER (PJB BAGH)	4	0	0	0	4	0	4
BRPL	West 2	Punjabi Bagh	11kv FDR TULSI RAM DHARAMSALA	5	0	0	0	5	0	5
BRPL	West 2	Punjabi Bagh	11kv STR 100KVA STATION TRANSFORMER-2	1	0	0	0	1	0	1
BRPL	West 3	Tagore Garden	11kv FDR 1040 JANTA COLONY	2	0	0	0	2	0	2
BRPL	West 3	Tagore Garden	11kv FDR 20-BLOCK TILAK NAGAR	4	0	1	0	3	1	3
BRPL	West 3	Tagore Garden	11kv FDR 224 SFS FLATS TAGORE GARDEN	10	0	1	0	9	1	9

BRPL	West 3	Tagore Garden	11kv FDR 224-SFS QTS	6	0	0	0	6	0	6
BRPL	West 3	Tagore Garden	11kv FDR 288 PUNARWAS COLONY	2	0	0	0	2	0	2
BRPL	West 3	Tagore Garden	11kv FDR 320-MIG FLATS	6	0	0	0	6	0	6
BRPL	West 3	Tagore Garden	11kv FDR 320-MIG FLATS VKP	4	0	0	0	4	0	4
BRPL	West 3	Tagore Garden	11kv FDR 608 JANTA FLAT	10	0	0	0	10	0	10
BRPL	West 3	Tagore Garden	11kv FDR 72 SFS NO-1 T GDN	8	0	0	0	8	0	8
BRPL	West 3	Tagore Garden	11kv FDR 72-SFS NO-2 T.GDN	4	0	0	0	4	0	4
BRPL	West 3	Tagore Garden	11kv FDR 748-JANTA FLATS	8	0	0	0	8	0	8
BRPL	West 3	Tagore Garden	11kv FDR AB-BLOCK KHYALA	7	0	0	0	7	0	7
BRPL	West 3	Tagore Garden	11kv FDR A-BLK TAGORE GDN FDR	4	0	0	0	4	0	4
BRPL	West 3	Tagore Garden	11kv FDR B-1/283 VISHNU GARDEN	4	0	0	0	4	0	4
BRPL	West 3	Tagore Garden	11kv FDR B-1/283 VISHNU GDN (PHADIYA WALA)	3	0	0	0	3	0	3
BRPL	West 3	Tagore Garden	11kv FDR B-BLOCK J.J COLONEY CHAUKHANDI	5	0	0	0	5	0	5
BRPL	West 3	Tagore Garden	11kv FDR C&D BLK VISHNU GARDEN	4	0	0	0	4	0	4
BRPL	West 3	Tagore Garden	11kv FDR C-BLK BREAK DOWN OFFICE	3	0	0	0	3	0	3
BRPL	West 3	Tagore Garden	11kv FDR C-BLK TILAK VIHAR	2	0	0	0	2	0	2
BRPL	West 3	Tagore Garden	11kv FDR CHAND NAGAR	7	0	1	0	6	1	6
BRPL	West 3	Tagore Garden	11kv FDR CHAND NAGAR (KHADDE WALA)	3	0	0	0	3	0	3
BRPL	West 3	Tagore Garden	11kv FDR CHAND NGR SCHOOL WALA	3	0	0	0	3	0	3
BRPL	West 3	Tagore Garden	11kv FDR CHAUKHANDI	3	0	0	0	3	0	3
BRPL	West 3	Tagore Garden	11kv FDR D.D.A CHAUKHANDI	7	0	0	0	7	0	7
BRPL	West 3	Tagore Garden	11kv FDR D-BLOCK RAGHUBIR NAGAR	10	0	0	0	10	0	10
BRPL	West 3	Tagore Garden	11kv FDR E BLOCK KHYALA	3	0	0	0	3	0	3
BRPL	West 3	Tagore Garden	11kv FDR EXT.5C VISHNU GARDEN	5	0	0	0	5	0	5
BRPL	West 3	Tagore Garden	11kv FDR F & V MRKT-2 / VIA - RMU OUT SIDE CHAN. GRID GATE	2	0	0	0	2	0	2
BRPL	West 3	Tagore Garden	11kv FDR F-BLK KHATTE VISHNU GARDEN	3	0	0	0	3	0	3
BRPL	West 3	Tagore Garden	11kv FDR F-BLOCK SHIVAJI ENCLAVE	6	0	0	0	6	0	6
BRPL	West 3	Tagore Garden	11kv FDR GALI NO 8 MAHAVIR NAGAR	5	0	0	0	5	0	5
BRPL	West 3	Tagore Garden	11kv FDR GANGA RAM VATIKA	4	0	0	0	4	0	4
BRPL	West 3	Tagore Garden	11kv FDR G-BLOCK SHIVAJEE ENCLAVE	7	0	0	0	7	0	7
BRPL	West 3	Tagore Garden	11kv FDR I-BLOCK TILAK NAGAR	5	0	0	0	5	0	5
BRPL	West 3	Tagore Garden	11kv FDR IND. AREA TILAK NAGAR	11	0	1	0	10	1	10
BRPL	West 3	Tagore Garden	11kv FDR INTERCONNECTOR NO-1	10	0	0	0	10	0	10
BRPL	West 3	Tagore Garden	11kv FDR KALI MATA MANDIR GANESH NAGAR	3	0	0	0	3	0	3
BRPL	West 3	Tagore Garden	11kv FDR K-BLK KRISHNA PARK	5	0	0	0	5	0	5
BRPL	West 3	Tagore Garden	11kv FDR KESHOPUR F&V MKT.1	5	0	0	0	5	0	5
BRPL	West 3	Tagore Garden	11kv FDR KHAYALA PUMPING STATION	7	0	0	0	7	0	7
BRPL	West 3	Tagore Garden	11kv FDR M-BLK RAGHUBIR NAGAR	6	0	0	0	6	0	6
BRPL	West 3	Tagore Garden	11kv FDR MBS NAGAR	7	0	0	0	7	0	7
BRPL	West 3	Tagore Garden	11kv FDR MOTHER DIARY SHYAM NGR	3	0	0	0	3	0	3
BRPL	West 3	Tagore Garden	11kv FDR MUKHERJEE PARK FEEDER NO.-1	5	0	0	0	5	0	5
BRPL	West 3	Tagore Garden	11kv FDR MUKHERJEE PARK FEEDER NO.-2	3	0	0	0	3	0	3
BRPL	West 3	Tagore Garden	11kv FDR MUKHERJEE PARK SCHOOL WALA	3	0	0	0	3	0	3
BRPL	West 3	Tagore Garden	11kv FDR NEW F-BLOCK TAGORE GARDEN	4	0	0	0	4	0	4
BRPL	West 3	Tagore Garden	11kv FDR NURSING GARDEN	7	0	0	0	7	0	7
BRPL	West 3	Tagore Garden	11kv FDR NW-BLOCK VISHNU GARDEN	4	0	0	0	4	0	4
BRPL	West 3	Tagore Garden	11kv FDR NW-BLOCK, CHOWK RMU (TGN)	5	0	0	0	5	0	5
BRPL	West 3	Tagore Garden	11kv FDR PLOT NO-.23 SHIVAJI PLACE NO-.1	2	0	0	0	2	0	2
BRPL	West 3	Tagore Garden	11kv FDR RAGHUBIR NAGAR D-BLOCK	6	0	0	0	6	0	6
BRPL	West 3	Tagore Garden	11kv FDR RAM NAGAR EXTENTION	4	0	0	0	4	0	4
BRPL	West 3	Tagore Garden	11kv FDR RAM NAGAR TALWAR WALA	3	0	0	0	3	0	3
BRPL	West 3	Tagore Garden	11kv FDR RAVI NAGAR GURUDWARA	4	0	0	0	4	0	4
BRPL	West 3	Tagore Garden	11kv FDR R-G BLOCK RAGHUBIR NAGAR	8	0	0	0	8	0	8
BRPL	West 3	Tagore Garden	11kv FDR RZ-BLOCK, VISHNU GDN	4	0	1	0	3	1	3
BRPL	West 3	Tagore Garden	11kv FDR S-BLK VISHNU GDN	5	0	0	0	5	0	5
BRPL	West 3	Tagore Garden	11kv FDR S-BLOCK VISHNU GARDEN VI WORK CENTER	6	0	0	0	6	0	6
BRPL	West 3	Tagore Garden	11kv FDR S-BLOCK WORK CENTER VISHNU GARDEN	4	0	0	0	4	0	4
BRPL	West 3	Tagore Garden	11kv FDR SHYAM NAGAR	4	0	0	0	4	0	4
BRPL	West 3	Tagore Garden	11kv FDR TAGORE GARDEN	13	0	0	0	13	0	13
BRPL	West 3	Tagore Garden	11kv FDR TILAK VIHAR	7	0	0	0	7	0	7
BRPL	West 3	Tagore Garden	11kv FDR WATER TANK TILAK NAGAR	7	0	0	0	7	0	7
BRPL	West 2	Vikasपुरी	11kv FDR 1616 JANTA HASTSAL	5	0	1	0	4	1	4
BRPL	West 2	Vikasपुरी	11kv FDR 1616-JANTA FLATS HASTSAL	1	0	0	0	1	0	1
BRPL	West 2	Vikasपुरी	11kv FDR A-BLK MANDIR WALA VIKASPURI	9	0	0	0	9	0	9
BRPL	West 2	Vikasपुरी	11kv FDR ARUNODYA S/S NO.-1	14	0	0	0	14	0	14
BRPL	West 2	Vikasपुरी	11kv FDR BHARAT GHAR	3	0	0	0	3	0	3

BRPL	West 2	Vikaspuri	11kv FDR C BLOCK VIKASPURI	7	0	0	0	7	0	7
BRPL	West 2	Vikaspuri	11kv FDR C ₂ BLK J.J COLONY	2	0	0	0	2	0	2
BRPL	West 2	Vikaspuri	11kv FDR C-BLOCK JJ COLONY	1	0	0	0	1	0	1
BRPL	West 2	Vikaspuri	11kv FDR D ₂ BLOCK ₂ VKVP	10	0	2	0	8	2	8
BRPL	West 2	Vikaspuri	11kv FDR DAAL MILL	5	0	2	0	3	2	3
BRPL	West 2	Vikaspuri	11kv FDR DDA TC-1	3	0	0	0	3	0	3
BRPL	West 2	Vikaspuri	11kv FDR DDA TRAN. CAMP ₂ 2 HASTSAL	8	0	0	0	8	0	8
BRPL	West 2	Vikaspuri	11kv FDR DG ₂ 3 VKP	10	0	1	0	9	1	9
BRPL	West 2	Vikaspuri	11kv FDR F ₂ BLK I/D SSTN VKP	11	0	3	0	8	3	8
BRPL	West 2	Vikaspuri	11kv FDR G ₂ 1 SSTN ₂ 1 SONIA	4	0	0	0	4	0	4
BRPL	West 2	Vikaspuri	11kv FDR G-1/3 SUB SATION	9	0	0	0	9	0	9
BRPL	West 2	Vikaspuri	11kv FDR GANGOTRI SOCIETY	15	0	3	0	12	3	12
BRPL	West 2	Vikaspuri	11kv FDR GUJRANWALA SOCIETY	8	0	0	0	8	0	8
BRPL	West 2	Vikaspuri	11kv FDR GURUDWARA HASTAL ROAD	4	0	0	0	4	0	4
BRPL	West 2	Vikaspuri	11kv FDR H ₂ BLOCK STORE I/D VKP	4	0	2	0	2	2	2
BRPL	West 2	Vikaspuri	11kv FDR HASTAL SOCIETY	10	0	0	0	10	0	10
BRPL	West 2	Vikaspuri	11kv FDR HASTAL VIHAR	6	0	0	0	6	0	6
BRPL	West 2	Vikaspuri	11kv FDR HIMGIRI LIONS	8	0	0	0	8	0	8
BRPL	West 2	Vikaspuri	11kv FDR HOLY CONVENT(SCHOOL VIKASPURI)	6	0	0	0	6	0	6
BRPL	West 2	Vikaspuri	11kv FDR KALI BASTI	5	0	2	0	3	2	3
BRPL	West 2	Vikaspuri	11kv FDR KANGRA NIKETAN	10	0	0	0	10	0	10
BRPL	West 2	Vikaspuri	11kv FDR KESHOPUR	1	0	0	0	1	0	1
BRPL	West 2	Vikaspuri	11kv FDR LIG COMPLAINT CENTER	2	0	0	0	2	0	2
BRPL	West 2	Vikaspuri	11kv FDR LIG MOTHER DAIRY	6	0	0	0	6	0	6
BRPL	West 2	Vikaspuri	11kv FDR LIG ₂ 2 HASTAL	2	0	0	0	2	0	2
BRPL	West 2	Vikaspuri	11kv FDR LOK VIHAR VKP	15	0	5	0	10	5	10
BRPL	West 2	Vikaspuri	11kv FDR NAVYUG APPTT ₂ 1	11	0	0	0	11	0	11
BRPL	West 2	Vikaspuri	11kv FDR NEW KRISHNA PARK (VKP)	2	0	0	0	2	0	2
BRPL	West 2	Vikaspuri	11kv FDR NEW KRISHNA PARK OH	3	0	0	0	3	0	3
BRPL	West 2	Vikaspuri	11kv FDR PANCHWATI SOCIETY 1	1	0	0	0	1	0	1
BRPL	West 2	Vikaspuri	11kv FDR PARDHAN CHOWK	5	0	0	0	5	0	5
BRPL	West 2	Vikaspuri	11kv FDR PRESS ENCLAVE	4	0	0	0	4	0	4
BRPL	West 2	Vikaspuri	11kv FDR RAJDHANI GALIWALA	4	0	0	0	4	0	4
BRPL	West 2	Vikaspuri	11kv FDR RAJHANS VIHAR	7	0	0	0	7	0	7
BRPL	West 2	Vikaspuri	11kv FDR RELIANCE MALL A-BLK VIKASPURI	1	0	0	0	1	0	1
BRPL	West 2	Vikaspuri	11kv FDR RMU NO- 1	7	0	0	0	7	0	7
BRPL	West 2	Vikaspuri	11kv FDR RMU NO-3 SIMENCE SSTN BODELLA(VKP)	4	0	0	0	4	0	4
BRPL	West 2	Vikaspuri	11kv FDR RP WORLD SCHOOL	7	0	0	0	7	0	7
BRPL	West 2	Vikaspuri	11kv FDR SBI SOCIETY	18	0	0	0	18	0	18
BRPL	West 2	Vikaspuri	11kv FDR SHIV VIHAR	7	0	0	0	7	0	7
BRPL	West 2	Vikaspuri	11kv FDR SHIVA ENCLAVE	2	0	0	0	2	0	2
BRPL	West 2	Vikaspuri	11kv FDR UJJAWAL APPT	8	0	0	0	8	0	8
BRPL	West 2	Vikaspuri	11kv FDR UTTAM NAG TERM	6	0	2	0	4	2	4
BRPL	West 2	Vikaspuri	11kv FDR VIDHYA VIHAR	8	0	0	0	8	0	8
BRPL	West 2	Vikaspuri	11kv FDR VIKAS KUNJ	8	0	0	0	8	0	8
BRPL	West 2	Vikaspuri	11kv FDR VIKRANT CHOWK	3	0	0	0	3	0	3
BRPL	West 2	Uttam Nagar	11kv FDR ADARSH NAGR	5	0	2	0	3	2	3
BRPL	West 2	Uttam Nagar	11kv FDR B-BLOCK BINDAPUR	2	0	1	0	1	1	1
BRPL	West 2	Uttam Nagar	11kv FDR B-BLOCK UTTAM NAGAR	2	0	0	0	2	0	2
BRPL	West 2	Uttam Nagar	11kv FDR B-BLOCK UTTAM NAGAR U/G	3	0	2	0	1	2	1
BRPL	West 2	Uttam Nagar	11kv FDR B-BOCK UTTAM NAGAR (OLD)	1	0	0	0	1	0	1
BRPL	West 2	Uttam Nagar	11kv FDR BINDAPUR SCHOOL WALA	5	0	1	0	4	1	4
BRPL	West 2	Uttam Nagar	11kv FDR CHANAKYA PLACE	7	0	5	0	2	5	2
BRPL	West 2	Uttam Nagar	11kv FDR CHANAKYA PLACE I/D SSTN NO-1	8	0	5	0	3	5	3
BRPL	West 2	Uttam Nagar	11kv FDR DDA S/STN NO-1 BINDAPUR	3	0	3	0	0	3	0
BRPL	West 2	Uttam Nagar	11kv FDR DVBMJP,TA-BLOCK	3	0	2	0	1	2	1
BRPL	West 2	Uttam Nagar	11kv FDR EAST UTTAM NAGAR	3	0	3	0	0	3	0
BRPL	West 2	Uttam Nagar	11kv FDR IJL BLOCK UTTAM NAGAR	3	0	0	0	3	0	3
BRPL	West 2	Uttam Nagar	11kv FDR J.J COLONY MACHHI MKT	3	0	0	0	3	0	3
BRPL	West 2	Uttam Nagar	11kv FDR JEEVAN PARK	3	0	2	0	1	2	1
BRPL	West 2	Uttam Nagar	11kv FDR JEEWAN PARK SOM BAZAR ROAD	3	0	0	0	3	0	3
BRPL	West 2	Uttam Nagar	11kv FDR KIRAN GARDEN	2	0	0	0	2	0	2
BRPL	West 2	Uttam Nagar	11kv FDR KIRAN GARDEN PM (NEAR MAHINDRU HOSPITAL	2	0	1	0	1	1	1
BRPL	West 2	Uttam Nagar	11kv FDR MAHINDRA PARK	2	0	2	0	0	2	0
BRPL	West 2	Uttam Nagar	11kv FDR MILAP NGR	3	0	2	0	1	2	1
BRPL	West 2	Uttam Nagar	11kv FDR NAIWALA PKT-4,BINDAPUR	4	0	1	0	3	1	3
BRPL	West 2	Uttam Nagar	11kv FDR O-BLOCK GEETA ENCLAVE	3	0	2	0	1	2	1
BRPL	West 2	Uttam Nagar	11kv FDR O-BLOCK UTTAM NAGAR	5	0	4	0	1	4	1
BRPL	West 2	Uttam Nagar	11kv FDR PRAJAPATI I/D S/S NO.-1	4	0	4	0	0	4	0
BRPL	West 2	Uttam Nagar	11kv FDR R & S BLOCK CHANAKYA PLACE	5	0	2	0	3	2	3
BRPL	West 2	Uttam Nagar	11kv FDR RAM DUTT ENCLAVE	2	0	1	0	1	1	1
BRPL	West 2	Uttam Nagar	11kv FDR S/S. NO-5	7	0	5	0	2	5	2

BRPL	West 2	Uttam Nagar	11kv FDR SANJAY ENCLAVE	2	0	2	0	0	2	0
BRPL	West 2	Uttam Nagar	11kv FDR T2BLOCK KHADDAY WALA	2	0	2	0	0	2	0
BRPL	West 2	Uttam Nagar	11kv FDR UTTAM NAGAR	9	0	5	0	4	5	4
BRPL	West 2	Uttam Nagar	11kv FDR VANI VIHAR (PARK)	2	0	0	0	2	0	2
BRPL	West 2	Uttam Nagar	11kv FDR VISHU VIHAR	5	0	4	0	1	4	1
BRPL	West 2	Uttam Nagar	11kv FDR VISHWAS PARK	4	0	1	0	3	1	3
BRPL	West 2	Mohan Garden	11 KV FDR KUMAR DAIRY	4	0	1	0	3	1	3
BRPL	West 2	Mohan Garden	11kv FDR A-BLOCK MANDIRWALA	11	0	2	0	9	2	9
BRPL	West 2	Mohan Garden	11kv FDR BHAGWATI GARDEN COMPLEX	1	0	0	0	1	0	1
BRPL	West 2	Mohan Garden	11kv FDR C AND D BLK MOHAN GARDEN RMU NO-2	2	0	0	0	2	0	2
BRPL	West 2	Mohan Garden	11kv FDR DEFENCE ENCLAVE	3	0	1	0	2	1	2
BRPL	West 2	Mohan Garden	11kv FDR DMRC SHOPPING COMPLEX	7	0	3	0	4	3	4
BRPL	West 2	Mohan Garden	11kv FDR GANDHI CHOWK	12	0	4	0	8	4	8
BRPL	West 2	Mohan Garden	11kv FDR JAILDAR ENC	8	0	4	0	4	4	4
BRPL	West 2	Mohan Garden	11kv FDR JHANDA CHOWK OM VIHAR	7	0	2	0	5	2	5
BRPL	West 2	Mohan Garden	11kv FDR LAXMAN PURI	5	0	1	0	4	1	4
BRPL	West 2	Mohan Garden	11kv FDR LAXMI VIHAR	3	0	0	0	3	0	3
BRPL	West 2	Mohan Garden	11kv FDR LEXT MOHAN GARDEN	2	0	1	0	1	1	1
BRPL	West 2	Mohan Garden	11kv FDR MINI BUS STAND	6	0	1	0	5	1	5
BRPL	West 2	Mohan Garden	11kv FDR MOHAN GARDEN	4	0	1	0	3	1	3
BRPL	West 2	Mohan Garden	11kv FDR NAWADA	5	0	2	0	3	2	3
BRPL	West 2	Mohan Garden	11kv FDR NAWADA HOUSING COMPLEX	4	0	2	0	2	2	2
BRPL	West 2	Mohan Garden	11kv FDR NAWADA USTREWALA	7	0	4	0	3	4	3
BRPL	West 2	Mohan Garden	11kv FDR NSIT NO-2	2	0	0	0	2	0	2
BRPL	West 2	Mohan Garden	11kv FDR OM VIHAR PHASE-2	6	0	2	0	4	2	4
BRPL	West 2	Mohan Garden	11kv FDR P BLK M GDN	3	0	0	0	3	0	3
BRPL	West 2	Mohan Garden	11kv FDR PP-2 (MGN)	4	0	2	0	2	2	2
BRPL	West 2	Mohan Garden	11kv FDR RAHUL COWK	5	0	0	0	5	0	5
BRPL	West 2	Mohan Garden	11kv FDR RAKSHA ENCLAVE	11	0	4	0	7	4	7
BRPL	West 2	Mohan Garden	11kv FDR RANA ENCLAVE+RAMA PARK	14	0	3	0	11	3	11
BRPL	West 2	Mohan Garden	11kv FDR RMU NO.-1 (M-BLOCK SHYAM PARK)	5	0	2	0	3	2	3
BRPL	West 2	Mohan Garden	11kv FDR SAINIK ENCLAVE	7	0	4	0	3	4	3
BRPL	West 2	Mohan Garden	11kv FDR SEWAK PARK	8	0	2	0	6	2	6
BRPL	West 2	Mohan Garden	11kv FDR TIRANGA CHOWK	5	0	1	0	4	1	4
BRPL	West 2	Mohan Garden	11kv FDR UGR MOHAN GARDEN	10	0	7	0	3	7	3
BRPL	West 2	Mohan Garden	11kv FDR VIKAS KUNJ SCHOOL WALA	4	0	3	0	1	3	1
BRPL	West 2	Mohan Garden	11kv FDR VIPIN GDN GALI NO 38	2	0	1	0	1	1	1
BRPL	West 2	Mohan Garden	11kv FDR WIINTER HILL SOCIETY DWARKA MOR NO-2	2	0	2	0	0	2	0
BRPL	West 2	Mohan Garden	11kv FDR WINTER HILL SOCIETY DWARKA MOR NO-1	3	0	1	0	2	1	2
BRPL	West 2	Mohan Garden	11kv FEEDER OM VIHAR PHASE-5	3	0	3	0	0	3	0
BRPL	West 1	Palam	11KV D-1 & D-2, MAHAVIR ENCLAVE	1	0	0	0	1	0	1
BRPL	West 1	Palam	11kv FDR A-BLK DASRATH PURI	4	0	0	0	4	0	4
BRPL	West 1	Palam	11kv FDR A-BLOCK SITAPURI	2	0	1	0	1	1	1
BRPL	West 1	Palam	11kv FDR ARMY QTRS. SEC-21	6	0	3	0	3	3	3
BRPL	West 1	Palam	11kv FDR AWHO, SEC-22	6	0	1	0	5	1	5
BRPL	West 1	Palam	11kv FDR BENGALI COLONY	8	0	0	0	8	0	8
BRPL	West 1	Palam	11kv FDR BHATT WALA	2	0	0	0	2	0	2
BRPL	West 1	Palam	11kv FDR C-2 MAHAVIR ENCLAVE FDR	5	0	0	0	5	0	5
BRPL	West 1	Palam	11kv FDR CAMMAND TANK-4, SECTOR-20	14	0	0	0	14	0	14
BRPL	West 1	Palam	11kv FDR COMMAND TANK 1 DWK 7	2	0	0	0	2	0	2
BRPL	West 1	Palam	11kv FDR CROWN APPTS. SEC-7 PLM	10	0	1	0	9	1	9
BRPL	West 1	Palam	11kv FDR D.D.A FLATS,SEC-23	11	0	1	0	10	1	10
BRPL	West 1	Palam	11kv FDR D1 & D2 MAHAVIR ENCLAVE NO-2	2	0	0	0	2	0	2
BRPL	West 1	Palam	11kv FDR D-1 D-2 MAHAVIR ENCALE	4	0	0	0	4	0	4
BRPL	West 1	Palam	11kv FDR DABRI NO 1	8	0	3	0	5	3	5
BRPL	West 1	Palam	11kv FDR DABRI NO 2	4	0	1	0	3	1	3
BRPL	West 1	Palam	11kv FDR DABRI ZONAL OFFICE	2	0	0	0	2	0	2
BRPL	West 1	Palam	11kv FDR DADA CHHATRI MARG	2	0	0	0	2	0	2
BRPL	West 1	Palam	11kv FDR DDA OFFICE MANGLAPURI	6	0	1	0	5	1	5
BRPL	West 1	Palam	11kv FDR DTC DEPOT	8	0	0	0	8	0	8
BRPL	West 1	Palam	11kv FDR DURGAPAK GALI NO.4	1	0	1	0	0	1	0
BRPL	West 1	Palam	11kv FDR DWARKA PURI	8	0	0	0	8	0	8
BRPL	West 1	Palam	11kv FDR EPFO SEC-23	18	0	0	0	18	0	18
BRPL	West 1	Palam	11kv FDR EVERGREEN	5	0	1	0	4	1	4
BRPL	West 1	Palam	11kv FDR F-BLOCK SAGARPUR + (11kv FDR RAGHU NAGAR NEW NO. 2)	5	0	0	0	5	0	5
BRPL	West 1	Palam	11kv FDR GALI NO-22 SADH NAGAR	7	0	2	0	5	2	5
BRPL	West 1	Palam	11kv FDR GEETANJALI PARK PLM SSTN + (11kv FDR MEHTAWALA)	5	0	1	0	4	1	4
BRPL	West 1	Palam	11kv FDR HARIJAN BASTI EXT.	7	0	0	0	7	0	7
BRPL	West 1	Palam	11kv FDR HARIJAN BASTI NEW GADDEWALA	10	0	0	0	10	0	10

BRPL	West 1	Palam	11kv FDR HARSUKH APPTT.	5	0	0	0	5	0	5
BRPL	West 1	Palam	11kv FDR INDIAN HOTEL SEC-21 PLM	7	0	0	0	7	0	7
BRPL	West 1	Palam	11kv FDR INTELLIGENCE BUREAU SECTOR-9	1	0	0	0	1	0	1
BRPL	West 1	Palam	11kv FDR INTELLIGENCE BUREAU, SEC-9 + GALI NO-11 RAJ NAGAR	5	0	1	0	4	1	4
BRPL	West 1	Palam	11kv FDR KAILASH PURI EXTENSION	5	0	0	0	5	0	5
BRPL	West 1	Palam	11kv FDR KAILASH PURI-1	4	0	0	0	4	0	4
BRPL	West 1	Palam	11kv FDR KAILASH PURI-2	4	0	0	0	4	0	4
BRPL	West 1	Palam	11kv FDR MADANPURI HANS PARK	10	0	1	0	9	1	9
BRPL	West 1	Palam	11kv FDR MAHADEVA	5	0	1	0	4	1	4
BRPL	West 1	Palam	11kv FDR MAHAVIR ENCLAVE D-3	5	0	0	0	5	0	5
BRPL	West 1	Palam	11kv FDR MAHAVIR ENCLAVE GALI-2	4	0	0	0	4	0	4
BRPL	West 1	Palam	11kv FDR MANDIR MARG	5	0	0	0	5	0	5
BRPL	West 1	Palam	11kv FDR MANGLA PURI PHASE-2	5	0	0	0	5	0	5
BRPL	West 1	Palam	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	15	0	5	0	10	5	10
BRPL	West 1	Palam	11kv FDR MANGLAPURI NO-2 VIA RAMPHAL CHOWK	5	0	1	0	4	1	4
BRPL	West 1	Palam	11kv FDR MANISH PLAZA SECTOR-23	8	0	0	0	8	0	8
BRPL	West 1	Palam	11kv FDR MCD SCHOOL NASIR PUR	6	0	0	0	6	0	6
BRPL	West 1	Palam	11kv FDR NASIRPUR VILLAGE	9	0	1	0	8	1	8
BRPL	West 1	Palam	11kv FDR NBE SEC-9 FDR	5	0	0	0	5	0	5
BRPL	West 1	Palam	11kv FDR NISHKAM APPTT	9	0	1	0	8	1	8
BRPL	West 1	Palam	11kv FDR OLD G-BLOCK RAJ NAGAR	5	0	0	0	5	0	5
BRPL	West 1	Palam	11kv FDR OLD NANGAL	6	0	2	0	4	2	4
BRPL	West 1	Palam	11kv FDR PALAM CHOWK	5	0	0	0	5	0	5
BRPL	West 1	Palam	11kv FDR PALAM VILLAGE	8	0	0	0	8	0	8
BRPL	West 1	Palam	11kv FDR PAPPANKALAN SECTOR-7	7	0	0	0	7	0	7
BRPL	West 1	Palam	11kv FDR PARADISE APPT. SEC.-9	9	0	0	0	9	0	9
BRPL	West 1	Palam	11kv FDR PERIPEHERIAL-1	8	0	2	0	6	2	6
BRPL	West 1	Palam	11kv FDR PERIPHERAL-2	6	0	0	0	6	0	6
BRPL	West 1	Palam	11kv FDR PINK APPT.	7	0	0	0	7	0	7
BRPL	West 1	Palam	11kv FDR POCKET-10 NASIR PUR	10	0	1	0	9	1	9
BRPL	West 1	Palam	11kv FDR POLICE TRAINING CENTRE SEC -9	4	0	0	0	4	0	4
BRPL	West 1	Palam	11kv FDR PURAN JAILDAR	6	0	0	0	6	0	6
BRPL	West 1	Palam	11kv FDR PURAN JAILDAR NO.-2	2	0	0	0	2	0	2
BRPL	West 1	Palam	11kv FDR PURAN NAGAR	5	0	0	0	5	0	5
BRPL	West 1	Palam	11kv FDR RAGHU NAGAR (OLD)	11	0	2	0	9	2	9
BRPL	West 1	Palam	11kv FDR RANJEET VIHAR(SEC-23)	14	0	0	0	14	0	14
BRPL	West 1	Palam	11kv FDR RMU NO.-2	3	0	0	0	3	0	3
BRPL	West 1	Palam	11kv FDR S/STN NO-1 MARBEL MARKET SECTOR 20 DWK	13	0	0	0	13	0	13
BRPL	West 1	Palam	11kv FDR S/STN.2 SEC-7	7	0	0	0	7	0	7
BRPL	West 1	Palam	11kv FDR SADH NAGAR GALI NO.-9	3	0	0	0	3	0	3
BRPL	West 1	Palam	11kv FDR SAGARPUR MAIN	3	0	1	0	2	1	2
BRPL	West 1	Palam	11kv FDR SARGODHA VIHAR SEC-7 (PLM)	6	0	1	0	5	1	5
BRPL	West 1	Palam	11kv FDR SEC-23, POLICE STATION	19	0	1	0	18	1	18
BRPL	West 1	Palam	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	24	0	0	0	24	0	24
BRPL	West 1	Palam	11kv FDR SEC-8 S/STN.-5	6	0	0	0	6	0	6
BRPL	West 1	Palam	11kv FDR SEC-9, PKT-1	17	0	0	0	17	0	17
BRPL	West 1	Palam	11kv FDR SECTOR-23 EPFO	1	0	0	0	1	0	1
BRPL	West 1	Palam	11kv FDR SHASTRI MARG RAJ NAGAR	7	0	0	0	7	0	7
BRPL	West 1	Palam	11kv FDR SITAPURI D BLOCK	4	0	0	0	4	0	4
BRPL	West 1	Palam	11kv FDR SITAPURI HARIJAN BASTI	4	0	2	0	2	2	2
BRPL	West 1	Palam	11kv FDR SPG COMPLEX DWK-21 NO-2	8	0	7	0	1	7	1
BRPL	West 1	Palam	11kv FDR SPG COMPLEX SEC-21 NO-3	11	0	8	0	3	8	3
BRPL	West 1	Palam	11kv FDR SPG SEC-8	8	0	0	0	8	0	8
BRPL	West 1	Palam	11kv FDR SSTN.NO.-2 SECTOR-7 (PLM.)	1	0	0	0	1	0	1
BRPL	West 1	Palam	11kv FDR STORE SEC-8	5	0	2	0	3	2	3
BRPL	West 1	Palam	11kv FDR VARDHMAN PLAZA	14	0	0	0	14	0	14
BRPL	West 1	Palam	11kv FDR VINODPURI	3	0	1	0	2	1	2
BRPL	West 1	Palam	11kv STR 400KVA STATION TRANSFORMER-2	1	0	1	0	0	1	0
BRPL	West 1	Dwarka	11kv FDR 210 DDA FLATS SEC-3	8	0	5	0	3	5	3
BRPL	West 1	Dwarka	11kv FDR 346/348 M.S. APPT SEC-16 B	14	0	3	0	11	3	11
BRPL	West 1	Dwarka	11kv FDR 352 DDA FLATS 19 B DWK	4	0	0	0	4	0	4
BRPL	West 1	Dwarka	11kv FDR ADARSH PRODYOGIKI + JAINPARK ID SSTN	5	0	1	0	4	1	4
BRPL	West 1	Dwarka	11kv FDR BAIRWA BHARTI APPT.	29	0	21	0	8	21	8
BRPL	West 1	Dwarka	11kv FDR BHAWALPUR CGHS SEC-4	11	0	8	0	3	8	3
BRPL	West 1	Dwarka	11kv FDR COMMAND TANK NO-2	2	0	2	0	0	2	0
BRPL	West 1	Dwarka	11kv FDR COMMAND TANK SEC-3 MADHU VIHAR	2	0	0	0	2	0	2
BRPL	West 1	Dwarka	11kv FDR COURT-2 SEC-10 DIST + 11kv FDR PARADISE APPT. SEC-9	6	0	5	0	1	5	1

BRPL	West 1	Dwarka	11kv FDR DDA GROUND SEC-10 RMU NO-2	14	0	12	0	2	12	2
BRPL	West 1	Dwarka	11kv FDR DDA GROUND-1 SEC-10 RMU NO-1	4	0	2	0	2	2	2
BRPL	West 1	Dwarka	11kv FDR DDA MEGA HOUSING SEC-18-B	26	0	22	0	4	22	4
BRPL	West 1	Dwarka	11kv FDR DEEN DAYAL UPADHYAYA COLLEGE SEC-3 DWK	1	0	0	0	1	0	1
BRPL	West 1	Dwarka	11kv FDR DISTRICT COURT-1 SEC-10	2	0	1	0	1	1	1
BRPL	West 1	Dwarka	11kv FDR DIA. APPT. SEC-13	21	0	16	0	5	16	5
BRPL	West 1	Dwarka	11kv FDR EROS MALL + 11kv FDR 736 EWS SEC-16B	9	0	3	0	6	3	6
BRPL	West 1	Dwarka	11kv FDR G AND S RAJAPURI	3	0	1	0	2	1	2
BRPL	West 1	Dwarka	11kv FDR GGSIP UNIVERSITY	10	0	6	0	4	6	4
BRPL	West 1	Dwarka	11kv FDR GODREJ APPT.	4	0	4	0	0	4	0
BRPL	West 1	Dwarka	11kv FDR GULSAN A-IQBAAL	18	0	13	0	5	13	5
BRPL	West 1	Dwarka	11kv FDR HUMAN CARE SEC-6 VIA SEC-5 S/STN NO-3	5	0	5	0	0	5	0
BRPL	West 1	Dwarka	11kv FDR IES	6	0	5	0	1	5	1
BRPL	West 1	Dwarka	11kv FDR JAIN COLONY	2	0	0	0	2	0	2
BRPL	West 1	Dwarka	11kv FDR JJ COLONY SEC-3	4	0	3	0	1	3	1
BRPL	West 1	Dwarka	11kv FDR JUDICIAL ACADEMY-1	6	0	6	0	0	6	0
BRPL	West 1	Dwarka	11kv FDR KAKROLA HOUSING	8	0	4	0	4	4	4
BRPL	West 1	Dwarka	11kv FDR KAKROLA VILLAGE	8	0	5	0	3	5	3
BRPL	West 1	Dwarka	11kv FDR KAKROLA-2	12	0	9	0	3	9	3
BRPL	West 1	Dwarka	11kv FDR KGL APPT. SEC-18	6	0	4	0	2	4	2
BRPL	West 1	Dwarka	11kv FDR KM CHOWK, SEC-11	30	0	24	0	6	24	6
BRPL	West 1	Dwarka	11kv FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	19	0	13	0	6	13	6
BRPL	West 1	Dwarka	11kv FDR MADHU VIHAR	5	0	4	0	1	4	1
BRPL	West 1	Dwarka	11kv FDR MAHALAXMI SEC-6	21	0	10	0	11	10	11
BRPL	West 1	Dwarka	11kv FDR MAHAVIR ENCLAVE S/STN-2	3	0	2	0	1	2	1
BRPL	West 1	Dwarka	11kv FDR MAHAVIR ENCLAVE S/S NO-4	6	0	4	0	2	4	2
BRPL	West 1	Dwarka	11kv FDR MANSARAM PARK	5	0	1	0	4	1	4
BRPL	West 1	Dwarka	11kv FDR MATIALA	6	0	3	0	3	3	3
BRPL	West 1	Dwarka	11kv FDR MATIYALA	1	0	1	0	0	1	0
BRPL	West 1	Dwarka	11kv FDR NAND VIHAR	17	0	7	0	10	7	10
BRPL	West 1	Dwarka	11kv FDR NETAJI SUBHAS CHAND APARTMENT SEC-13 PH-1 PKT-1	5	0	3	0	2	3	2
BRPL	West 1	Dwarka	11kv FDR NHAI SEC-10	4	0	2	0	2	2	2
BRPL	West 1	Dwarka	11kv FDR NSIT	16	0	11	0	5	11	5
BRPL	West 1	Dwarka	11kv FDR O/G-6RAJAPURI S/STN.NO-1	4	0	0	0	4	0	4
BRPL	West 1	Dwarka	11kv FDR O/G-5 AAKASH HOSPITAL SEC-3 DWARKA	6	0	4	0	2	4	2
BRPL	West 1	Dwarka	11kv FDR O/G-7 ROHTAS NAGAR DWK	4	0	3	0	1	3	1
BRPL	West 1	Dwarka	11kv FDR OPG SCHOOL SEC-19-B	15	0	14	0	1	14	1
BRPL	West 1	Dwarka	11kv FDR P.P.NO-2 SEC-10	23	0	20	0	3	20	3
BRPL	West 1	Dwarka	11kv FDR PARK PLAZA HOTEL-1 SEC-13	17	0	12	0	5	12	5
BRPL	West 1	Dwarka	11kv FDR PERIPHERAL SEC-19	21	0	12	0	9	12	9
BRPL	West 1	Dwarka	11kv FDR PERIPHERAL-1 SEC-10(P.P.-1)	16	0	7	0	9	7	9
BRPL	West 1	Dwarka	11kv FDR PHASE-1 JJ CLY	9	0	6	0	3	6	3
BRPL	West 1	Dwarka	11kv FDR PP SEC-17	15	0	9	0	6	9	6
BRPL	West 1	Dwarka	11kv FDR PRAGYA CGHS SEC-2 DWARKA	5	0	0	0	5	0	5
BRPL	West 1	Dwarka	11kv FDR RELIANCE AMBIT NO-2 SEC-13	14	0	10	0	4	10	4
BRPL	West 1	Dwarka	11kv FDR S/S NO-3, D.D.A MEGA HOUSES SEC-18	10	0	7	0	3	7	3
BRPL	West 1	Dwarka	11kv FDR S/STN BHARAT VIHAR	4	0	2	0	2	2	2
BRPL	West 1	Dwarka	11kv FDR S/STN NO-1 PLOTTED AREA, SEC-12	19	0	15	0	4	15	4
BRPL	West 1	Dwarka	11kv FDR S/STN NO-1 PLOTTED AREA, SEC-13	18	0	14	0	4	14	4
BRPL	West 1	Dwarka	11kv FDR S/STN NO-2 RAJAPURI (OLD)	1	0	0	0	1	0	1
BRPL	West 1	Dwarka	11kv FDR S/STN NO-4 L & T FLATS SEC-18	37	0	31	0	6	31	6
BRPL	West 1	Dwarka	11kv FDR S/STN NO-4 PKT-7 SEC-12 DWK	37	0	26	0	11	26	11
BRPL	West 1	Dwarka	11kv FDR SAHEED BHAGAT SINGH	6	0	4	0	2	4	2
BRPL	West 1	Dwarka	11kv FDR SAINIK NAGAR	5	0	5	0	0	5	0
BRPL	West 1	Dwarka	11kv FDR SEC-10	6	0	5	0	1	5	1
BRPL	West 1	Dwarka	11kv FDR SEC-11 O/H KGL CHK	15	0	8	0	7	8	7
BRPL	West 1	Dwarka	11kv FDR SEC-13 PARKWALA	7	0	7	0	0	7	0
BRPL	West 1	Dwarka	11kv FDR SEC-13 PLOTTED AREA NO-2	17	0	11	0	6	11	6
BRPL	West 1	Dwarka	11kv FDR SEC-15 J.J. COLONY	10	0	1	0	9	1	9
BRPL	West 1	Dwarka	11kv FDR SEC-15 SHYAM VIHAR	1	0	1	0	0	1	0
BRPL	West 1	Dwarka	11kv FDR SEC-16C DELHI POLICE QUARTERS	10	0	8	0	2	8	2
BRPL	West 1	Dwarka	11kv FDR SEC-19	19	0	15	0	4	15	4
BRPL	West 1	Dwarka	11kv FDR SEC-19 PKT-1	23	0	17	0	6	17	6
BRPL	West 1	Dwarka	11kv FDR SEC-2	22	0	19	0	3	19	3

BRPL	West 1	Dwarka	11kv FDR SEC-3 SSTN NO-1	11	0	3	0	8	3	8
BRPL	West 1	Dwarka	11kv FDR SEC-3/13 RED LIGHT	3	0	1	0	2	1	2
BRPL	West 1	Dwarka	11kv FDR SECTOR-10 HILANSH	8	0	6	0	2	6	2
BRPL	West 1	Dwarka	11kv FDR SECTOR-3 DWARKA	5	0	2	0	3	2	3
BRPL	West 1	Dwarka	11kv FDR SECTOR-4 DWARKA	14	0	8	0	6	8	6
BRPL	West 1	Dwarka	11kv FDR SHIV PARK KAKROLA	5	0	5	0	0	5	0
BRPL	West 1	Dwarka	11kv FDR T-EXTENSION	3	0	2	0	1	2	1
BRPL	West 1	Dwarka	11kv FDR UNIQUE APPT.	12	0	8	0	4	8	4
BRPL	West 1	Dwarka	11kv FDR VANKETSWAR HOSPITAL NO-3	9	0	5	0	4	5	4
BRPL	West 1	Dwarka	11kv FDR VARDHMAN MKT SEC-3	16	0	10	0	6	10	6
BRPL	West 1	Dwarka	11kv FDR VIKAS (SONIA WALA)	5	0	4	0	1	4	1
BRPL	West 1	Dwarka	11kv FDR VIKAS SONIYAWALA	1	0	1	0	0	1	0
BRPL	West 1	Dwarka	11kv FDR VISWAS PARK NO2	2	0	0	0	2	0	2
BRPL	West 1	Dwarka	11kv FDR WYN DHAM HOTEL SEC-10	2	0	0	0	2	0	2

Details of DT-wise losses (Apr-23 to June-23)													
Sub-station ID	Feeder-ID	Feeder name	DT ID no.	DT Capacity (KVA)	Predominant consumer type of DT (Domestic/Industrial/Agriculture/Mixed)	Type of metering (Unmetered/AMI/AMR/Other)	Status of meter (Functional/Non-Functional)	% of data received automatically (if AMI/AMR)	No. of connected consumers	Input energy (MU)	Billed Energy (MU)	Loss of Energy (MU)	% Loss
		1	2						3	4	5	6=4-5	7=(6/4)*100
220kV OKHLA TRANSCO GRID SST	TDTOG106	11kV FDR POKET A-12 KALKAJI EXTN.	TI-OKH031A-1	990	MIXED		Functional	100%	254	0.37	2.93	0.16	5.20%
220kV OKHLA TRANSCO GRID SST	TDTOG106	11kV FDR POKET A-12 KALKAJI EXTN.	TI-OKH031A-2	990	MIXED		Functional	100%	221	0.36			
220kV OKHLA TRANSCO GRID SST	TDTOG106	11kV FDR POKET A-12 KALKAJI EXTN.	TI-OKH040A-1	990	MIXED	AMR	Functional	100%	211	0.35			
220kV OKHLA TRANSCO GRID SST	TDTOG106	11kV FDR POKET A-12 KALKAJI EXTN.	TI-OKH032A-1	990	MIXED		Functional	100%	232	0.31			
220kV OKHLA TRANSCO GRID SST	TDTOG106	11kV FDR POKET A-12 KALKAJI EXTN.	TI-OKH035A-2	630	MIXED		Functional	100%	148	0.24			
220kV OKHLA TRANSCO GRID SST	TDTOG106	11kV FDR POKET A-12 KALKAJI EXTN.	TI-OKH039A-1	630	MIXED	AMR	Functional	100%	181	0.23			
220kV OKHLA TRANSCO GRID SST	TDTOG106	11kV FDR POKET A-12 KALKAJI EXTN.	TI-OKH037A-2	630	MIXED	AMR	Functional	100%	201	0.19			
220kV OKHLA TRANSCO GRID SST	TDTOG103	11kV FDR POKET A-10 KALKAJI EXTN.	TI-OKH033A-2	630	RESIDENTIAL		Functional	100%	86	0.19			
220kV OKHLA TRANSCO GRID SST	TDTOG106	11kV FDR POKET A-12 KALKAJI EXTN.	TI-OKH037A-1	630	MIXED		Functional	100%	29	0.18			
220kV OKHLA TRANSCO GRID SST	TDTOG106	11kV FDR POKET A-12 KALKAJI EXTN.	TI-OKH035A-1	400	MIXED		Functional	100%	162	0.16			
220kV OKHLA TRANSCO GRID SST	TDTOG106	11kV FDR POKET A-12 KALKAJI EXTN.	TI-OKH040A-2	630	MIXED	AMR	Functional	100%	136	0.15			
220kV OKHLA TRANSCO GRID SST	TDTOG103	11kV FDR POKET A-10 KALKAJI EXTN.	TI-OKH033A-1	630	RESIDENTIAL		Functional	100%	199	0.12			
220kV OKHLA TRANSCO GRID SST	TDTOG108	11kV FDR TARA APPARTMENT	TP-OKH195A-1	400	Commercial		Functional	100%	3	0.10			
66 kV OKHLA PHASE 1 GRID	SOKH1109	11kV FDR SSTN NO.1 SLUM FLATS, A&14, KALKA JI, EXT.	510DDK-OKH258A	630	MIXED		Functional	100%	0	0.08			
66 kV OKHLA PHASE 1 GRID	SOKH1109	11kV FDR SSTN NO.1 SLUM FLATS, A&14, KALKA JI, EXT.	510DDK-OKH258A	630	MIXED		Functional	100%	0	0.06			
33 kV OKHLA PHASE-2 GRID	SOKH2109	11kV FDR O/G B-26 RMU PHASE-1	TG-OKH118A-1	990	INDUSTRIAL		Functional	100%	101	0.62	7.15	0.47	6.17%
33 kV OKHLA PHASE-2 GRID	SOKH2123	11kV FDR S/S NO.-8, OIA-1	TG-OKH109A-1	990	INDUSTRIAL		Functional	100%	41	0.61			
66 kV OKHLA PHASE 1 GRID	SOKH1123	11kV FDR S/S NO.-4	25100P1-OKH102A-2	990	INDUSTRIAL		Functional	100%	74	0.61			
66 kV OKHLA PHASE 1 GRID	SOKH1112	11kV FDR O/G TO DTC WORK SHOP	25100P1-OKH102A-1	990	INDUSTRIAL		Functional	100%	25	0.56			
33 kV OKHLA PHASE-2 GRID	SOKH2123	11kV FDR S/S NO.-8, OIA-1	TG-OKH188A-1	990	INDUSTRIAL		Functional	100%	30	0.55			
66 kV OKHLA PHASE 1 GRID	SOKH1121	11kV FDR O/G TO S/S NO.-10	TI-OKH103A-2	990	INDUSTRIAL		Functional	100%	17	0.54			
66 kV OKHLA PHASE 1 GRID	SOKH1121	11kV FDR O/G TO S/S NO.-10	TI-OKH103A-3	1000	INDUSTRIAL		Functional	100%	41	0.38			
33 kV OKHLA PHASE-2 GRID	SOKH2117	11kV FDR O/G S/S NO.-12, PHASE-1	TI-OKH105A-3	990	INDUSTRIAL	AMR	Functional	100%	26	0.38			
66 kV OKHLA PHASE 1 GRID	SOKH1121	11kV FDR O/G TO S/S NO.-10	TG-OKH103A-4	990	RESIDENTIAL		Functional	100%	0	0.37			
33 kV OKHLA PHASE-2 GRID	SOKH2117	11kV FDR O/G S/S NO.-12, PHASE-1	TI-OKH105A-4	990	INDUSTRIAL		Functional	100%	63	0.37			
33 kV OKHLA PHASE-2 GRID	SOKH2117	11kV FDR O/G S/S NO.-12, PHASE-1	TI-OKH105A-2	990	INDUSTRIAL		Functional	100%	169	0.37			
33 kV OKHLA PHASE-2 GRID	SOKH2117	11kV FDR O/G S/S NO.-12, PHASE-1	TG-OKH117A-1	990	INDUSTRIAL	AMR	Functional	100%	362	0.34			
33 kV OKHLA PHASE-2 GRID	SOKH2117	11kV FDR O/G S/S NO.-12, PHASE-1	TI-OKH105A-1	990	INDUSTRIAL		Functional	100%	69	0.33			
33 kV OKHLA PHASE-2 GRID	SOKH2123	11kV FDR S/S NO.-8, OIA-1	TG-OKH111A-2	990	INDUSTRIAL		Functional	100%	59	0.30			
33 kV OKHLA PHASE-2 GRID	SOKH2123	11kV FDR S/S NO.-8, OIA-1	TG-OKH109A-2	990	INDUSTRIAL		Functional	100%	20	0.30			
33 kV OKHLA PHASE-2 GRID	SOKH2123	11kV FDR S/S NO.-8, OIA-1	TG-OKH111A-1	630	INDUSTRIAL		Functional	100%	19	0.29			
33 kV OKHLA PHASE-2 GRID	SOKH2123	11kV FDR S/S NO.-8, OIA-1	5100P1-OKH247A	400	RESIDENTIAL		Functional	100%	5	0.27			
33 kV OKHLA PHASE-2 GRID	SOKH2109	11kV FDR O/G B-26 RMU PHASE-1	TI-OKH145A-1	630	INDUSTRIAL		Functional	100%	17	0.24			
66 kV OKHLA PHASE 1 GRID	SOKH1121	11kV FDR O/G TO S/S NO.-10	TI-OKH103A-1	990	INDUSTRIAL		Functional	100%	36	0.19			
66 kV OKHLA PHASE 1 GRID	SOKH1108	11kV FDR O/G TO CCI COMPLEX NO.-1	TG-OKH088A-1	1600	RESIDENTIAL	AMR	Functional	100%	453	1.02			
66 kV OKHLA PHASE 1 GRID	SOKH1125	11kV FDR O/G TO CCI COMPLEX NO.-2	TG-OKH229A-1	990	RESIDENTIAL		Functional	100%	208	0.98			
66 kV OKHLA PHASE 1 GRID	SOKH1108	11kV FDR O/G TO CCI COMPLEX NO.-1	TG-OKH087A-1	990	RESIDENTIAL		Functional	100%	515	0.76			
66 kV OKHLA PHASE 1 GRID	SOKH1108	11kV FDR O/G TO CCI COMPLEX NO.-1	TG-OKH085A-1	990	RESIDENTIAL		Functional	100%	610	0.61			

66 kv OKHLA PHASE 1 GRID	SOKH1108	11kv FDR O/G TO CCI COMPLEX NO.-1	TG-OKH238A-1	630	RESIDENTIAL		Functional	100%	293	0.59			
66 kv OKHLA PHASE 1 GRID	SOKH1108	11kv FDR O/G TO CCI COMPLEX NO.-1	TG-OKH087A-2	630	RESIDENTIAL		Functional	100%	0	0.39			
66 kv OKHLA PHASE 1 GRID	SOKH1108	11kv FDR O/G TO CCI COMPLEX NO.-1	TP-OKH127A-1	100	RESIDENTIAL		Functional	100%	2	0.01			
33 kv NEHRU PLACE GRID	SNPHG111	11kv FDR O/G POLICE STATION KALKAJI	TG-GK2015A-2	990	RESIDENTIAL		Functional	100%	470	0.69	6.43	0.17	2.52%
33 kv BALAJI STATE GRID	SBALA103	11kv FDR A-BLOCK, KALKAJI	TK-GK2024A-2	990	Residential		Functional	100%	640	0.66			
33 kv NEHRU PLACE GRID	SNPHG111	11kv FDR O/G POLICE STATION KALKAJI	TG-GK2015A-1	1000	Residential		Functional	100%	850	0.62			
33 kv BALAJI STATE GRID	SBALA103	11kv FDR A-BLOCK, KALKAJI	TG-GK2031A-1	630	Residential		Functional	100%	173	0.54			
33 kv NEHRU PLACE GRID	SNPHG113	11kv FDR O/G C.R PARK-A, S/STN-A	TI-GK2033A-1	990	Residential		Functional	100%	314	0.52			
33 kv NEHRU PLACE GRID	SNPHG110	11kv FDR O/G ARYA SAMAJ MANDIR KALKAJI	TX-GK2093A-1	990	Residential	AMR	Functional	100%	285	0.52			
33 kv BALAJI STATE GRID	SBALA103	11kv FDR A-BLOCK, KALKAJI	TG-GK2026A-2	990	Residential		Functional	100%	37	0.39			
33 kv NEHRU PLACE GRID	SNPHG113	11kv FDR O/G C.R PARK-A, S/STN-A	TI-GK2032A-2	990	AGRICULTURE		Functional	100%	214	0.39			
33 kv BALAJI STATE GRID	SBALA103	11kv FDR A-BLOCK, KALKAJI	TG-GK2026A-1	630	Residential		Functional	100%	290	0.34			
33 kv NEHRU PLACE GRID	SNPHG113	11kv FDR O/G C.R PARK-A, S/STN-A	TI-GK2032A-1	990	Residential		Functional	100%	374	0.33			
33 kv BALAJI STATE GRID	SBALA103	11kv FDR A-BLOCK, KALKAJI	TK-GK2024A-1	990	Residential		Functional	100%	516	0.32			
33 kv V.S.N.L. GRID	SVSNL129	11kv FDR OUT GOING FEEDER-8,NEHRU APPARTMENT	TG-GK2025A-1	630	RESIDENTIAL		Functional	100%	201	0.32			
33 kv V.S.N.L. GRID	SVSNL129	11kv FDR OUT GOING FEEDER-8,NEHRU APPARTMENT	TI-GK2019A-1	630	Residential		Functional	100%	147	0.27			
33 kv NEHRU PLACE GRID	SNPHG113	11kv FDR O/G C.R PARK-A, S/STN-A	TI-GK2033A-2	630	Residential		Functional	100%	136	0.21			
66 kv OKHLA PHASE 1 GRID	SOKH1630	11kv FDR SSTN NO 4 SLUM FLATS A-14 KALKA JI EXT	510GBK-OKH254A	630	MIXED		Functional	100%	0	0.18			
33 kv V.S.N.L. GRID	SVSNL129	11kv FDR OUT GOING FEEDER-8,NEHRU APPARTMENT	TG-GK2025A-2	400	RESIDENTIAL		Functional	100%	104	0.14			
33 kv V.S.N.L. GRID	SVSNL129	11kv FDR OUT GOING FEEDER-8,NEHRU APPARTMENT	TI-GK2019A-2	630	RESIDENTIAL		Functional	100%	139	0.13			
66 kv OKHLA PHASE 1 GRID	SOKH1630	11kv FDR SSTN NO 4 SLUM FLATS A-14 KALKA JI EXT	510GBK-OKH254A	630	MIXED		Functional	100%	0	0.03			
66 kv OKHLA PHASE 1 GRID	SOKH1131	11kv FDR O/G MCD SANITARY LAND	TG-OKH218A-1	1600	RESIDENTIAL		Functional	100%	1469	1.54	4.98	2.26	31.26%
66 kv OKHLA PHASE 1 GRID	SOKH1131	11kv FDR O/G MCD SANITARY LAND	TG-OKH086A-2	1600	RESIDENTIAL	AMR	Functional	100%	726	1.11			
66 kv OKHLA PHASE 1 GRID	SOKH1125	11kv FDR O/G TO CCI COMPLEX NO.-2	TG-OKH231A-1	990	RESIDENTIAL		Functional	100%	478	0.90			
66 kv OKHLA PHASE 1 GRID	SOKH1138	11kv FDR O/G KANGAR MOHALLA TUGHLAKABAD VILLAGE	TG-OKH086A-1	990	RESIDENTIAL		Functional	100%	384	0.88			
66 kv OKHLA PHASE 1 GRID	SOKH1125	11kv FDR O/G TO CCI COMPLEX NO.-2	TG-OKH122A-1	990	RESIDENTIAL		Functional	100%	803	0.83			
66 kv OKHLA PHASE 1 GRID	SOKH1138	11kv FDR O/G KANGAR MOHALLA TUGHLAKABAD VILLAGE	TG-OKH086A-3	990	RESIDENTIAL		Functional	100%	630	0.80			
66 kv OKHLA PHASE 1 GRID	SOKH1125	11kv FDR O/G TO CCI COMPLEX NO.-2	510OP1-OKH231A	990	MIXED		Functional	100%	0	0.53			
66 kv OKHLA PHASE 1 GRID	SOKH1131	11kv FDR O/G MCD SANITARY LAND	TP-OKH074A-1	400	MIXED		Functional	100%	404	0.36			
66 kv OKHLA PHASE 1 GRID	SOKH1131	11kv FDR O/G MCD SANITARY LAND	TP-OKH075A-1	400	RESIDENTIAL	AMR	Functional	100%	151	0.28			
33 kv ALAKNANDA GRID	SALKN103	11kv FDR O/G TO E.P.D.P SUB/STN NO.-2	TI-GK2046A-2	990	RESIDENTIAL		Functional	100%	87	0.50	4.31	0.06	1.43%
33 kv ALAKNANDA GRID	SALKN103	11kv FDR O/G TO E.P.D.P SUB/STN NO.-2	TI-GK2046A-1	990	RESIDENTIAL		Functional	100%	405	0.44			
33 kv ALAKNANDA GRID	SALKN103	11kv FDR O/G TO E.P.D.P SUB/STN NO.-2	TI-GK2046A-3	990	RESIDENTIAL		Functional	100%	610	0.42			
33 kv ALAKNANDA GRID	SALKN108	11kv FDR O/G TO N.R.I COMPLEX S/S	TI-GK2073A-2	630	Commercial		Functional	100%	79	0.36			
33 kv ALAKNANDA GRID	SALKN108	11kv FDR O/G TO N.R.I COMPLEX S/S	TG-GK2146A-1	990	RESIDENTIAL		Functional	100%	245	0.34			
33 kv ALAKNANDA GRID	SALKN108	11kv FDR O/G TO N.R.I COMPLEX S/S	TI-GK2073A-1	630	RESIDENTIAL		Functional	100%	284	0.33			
33 kv ALAKNANDA GRID	SALKN121	11kv FDR O/G EPDP NO.-1	510GK2-GK2152A	990	RESIDENTIAL		Functional	100%	254	0.33			
33 kv ALAKNANDA GRID	SALKN120	11kv FDR O/G EPDP NO.-6	TI-GK2052A-1	990	Residential		Functional	100%	462	0.32			
33 kv ALAKNANDA GRID	SALKN120	11kv FDR O/G EPDP NO.-6	TI-GK2052A-2	630	Residential		Functional	100%	632	0.26			
33 kv ALAKNANDA GRID	SALKN120	11kv FDR O/G EPDP NO.-6	TI-GK2051A-2	630	Residential		Functional	100%	234	0.24			
33 kv ALAKNANDA GRID	SALKN120	11kv FDR O/G EPDP NO.-6	TI-GK2048A-2	630	RESIDENTIAL		Functional	100%	90	0.23			
33 kv ALAKNANDA GRID	SALKN120	11kv FDR O/G EPDP NO.-6	TI-GK2052A-3	630	RESIDENTIAL		Functional	100%	0	0.23			
33 kv ALAKNANDA GRID	SALKN120	11kv FDR O/G EPDP NO.-6	TI-GK2051A-1	630	Residential		Functional	100%	178	0.21			
33 kv ALAKNANDA GRID	SALKN120	11kv FDR O/G EPDP NO.-6	TI-GK2048A-1	630	Residential		Functional	100%	227	0.18			
33 kv ALAKNANDA GRID	SALKN112	11kv STR 100kVA STATION TRF. NO.-1	TI-STC066A-1	100	RESIDENTIAL		Functional	100%	1	0.01			
33 kv V.S.N.L. GRID	SVSNL129	11kv FDR OUT GOING FEEDER-8,NEHRU APPARTMENT	TG-GK2099A-1	1600	MIXED		Functional	100%	63	0.62	4.06	0.12	2.86%
33 kv BALAJI STATE GRID	SBALA102	11kv FDR G - BLOCK, KALKAJI	TP-GK2028A-1	990	MIXED		Functional	100%	184	0.51			
33 kv NEHRU PLACE GRID	SNPHG111	11kv FDR O/G POLICE STATION KALKAJI	TX-GK2140A-1	990	MIXED		Functional	100%	370	0.50			
33 kv BALAJI STATE GRID	SBALA101	11kv FDR MUNJAL, KALKAJI EXTN.	TP-GK2036A-1	990	MIXED		Functional	100%	408	0.47			
33 kv BALAJI STATE GRID	SBALA101	11kv FDR MUNJAL, KALKAJI EXTN.	TX-GK2030A-1	990	MIXED		Functional	100%	165	0.43			

33 kV NEHRU PLACE GRID	SNPHG111	11kV FDR O/G POLICE STATION KALKAJI	TI-GK2074A-1	990	MIXED	Functional	100%	197	0.35			
33 kV V.S.N.L. GRID	SVSNL129	11kV FDR OUT GOING FEEDER-8,NEHRU APPARTMENT	TG-GK2027A-2	630	MIXED	Functional	100%	158	0.35			
33 kV NEHRU PLACE GRID	SNPHG111	11kV FDR O/G POLICE STATION KALKAJI	TG-GK2078A-1	990	MIXED	Functional	100%	189	0.35			
33 kV V.S.N.L. GRID	SVSNL129	11kV FDR OUT GOING FEEDER-8,NEHRU APPARTMENT	TG-GK2027A-1	630	MIXED	Functional	100%	132	0.24			
33 kV BALAJI STATE GRID	SBALA102	11kV FDR G - BLOCK, KALKAJI	TX-GK2095A-1	990	MIXED	Functional	100%	136	0.23			
33 kV BALAJI STATE GRID	SBALA101	11kV FDR MUNJAL, KALKAJI EXTN.	TX-GK2030A-2	630	MIXED	Functional	100%	67	0.13			
66 kV OKHLA PHASE 1 GRID	SOKH1130	11kV FDR D-173	TG-OKH189A-1	1600	INDUSTRIAL	Functional	100%	61	0.50	2.76	0.04	1.40%
66 kV OKHLA PHASE 1 GRID	SOKH1130	11kV FDR D-173	TG-OKH190A-1	990	INDUSTRIAL	Functional	100%	15	0.43			
66 kV OKHLA PHASE 1 GRID	SOKH1130	11kV FDR D-173	TG-OKH190A-2	990	INDUSTRIAL	Functional	100%	117	0.41			
66 kV OKHLA PHASE 1 GRID	SOKH1122	11kV FDR S/S NO.-6	TI-OKH066A-2	630	INDUSTRIAL	AMR Functional	100%	1201	0.39			
66 kV OKHLA PHASE 1 GRID	SOKH1122	11kV FDR S/S NO.-6	TI-OKH066A-1	990	INDUSTRIAL	Functional	100%	34	0.37			
66 kV OKHLA PHASE 1 GRID	SOKH1113	11kV FDR O/G TO S/STN-A OKHLA PHASE-1	TI-OKH067A-2	630	INDUSTRIAL	AMR Functional	100%	23	0.26			
66 kV OKHLA PHASE 1 GRID	SOKH1113	11kV FDR O/G TO S/STN-A OKHLA PHASE-1	TI-OKH067A-1	990	INDUSTRIAL	Functional	100%	51	0.22			
66 kV OKHLA PHASE 1 GRID	SOKH1113	11kV FDR O/G TO S/STN-A OKHLA PHASE-1	TI-OKH064A-1	990	INDUSTRIAL	Functional	100%	16	0.18			
66 kV OKHLA PHASE 1 GRID	SOKH1113	11kV FDR O/G TO S/STN-A OKHLA PHASE-1	TI-OKH064A-2	630	INDUSTRIAL	Functional	100%	15	0.04			
33 kV ALAKNANDA GRID	SALKN101	11kV FDR O/G TO D.D.A SLUM KALKA JI	TG-OKH013A-3	990	RESIDENTIAL	Functional	100%	591	0.68	4.97	0.23	4.38%
33 kV ALAKNANDA GRID	SALKN107	11kV FDR O/G TO KAVERI APPARTMENT	TI-OKH052A-2	990	Commercial	Functional	100%	357	0.57			
33 kV ALAKNANDA GRID	SALKN117	11kV FDR O/G SHIVALIK APPARTMENT	TG-OKH024A-1	990	RESIDENTIAL	Functional	100%	238	0.56			
33 kV ALAKNANDA GRID	SALKN117	11kV FDR O/G SHIVALIK APPARTMENT	TG-OKH055A-1	990	Commercial	Functional	100%	438	0.46			
33 kV ALAKNANDA GRID	SALKN107	11kV FDR O/G TO KAVERI APPARTMENT	TI-OKH052A-1	990	RESIDENTIAL	Functional	100%	992	0.44			
33 kV ALAKNANDA GRID	SALKN101	11kV FDR O/G TO D.D.A SLUM KALKA JI	TG-OKH216A-1	630	RESIDENTIAL	Functional	100%	1967	0.42			
33 kV ALAKNANDA GRID	SALKN107	11kV FDR O/G TO KAVERI APPARTMENT	TI-OKH053A-2	630	RESIDENTIAL	Functional	100%	539	0.38			
33 kV ALAKNANDA GRID	SALKN107	11kV FDR O/G TO KAVERI APPARTMENT	TI-OKH053A-1	630	RESIDENTIAL	Functional	100%	173	0.34			
33 kV ALAKNANDA GRID	SALKN125	11kV FDR O/G SSTN. NO.-1, NARMADA APPARTMENT	TI-OKH003A-1	630	Commercial	Functional	100%	190	0.28			
33 kV ALAKNANDA GRID	SALKN125	11kV FDR O/G SSTN. NO.-1, NARMADA APPARTMENT	TX-OKH206A-1	990	Commercial	Functional	100%	348	0.27			
33 kV ALAKNANDA GRID	SALKN117	11kV FDR O/G SHIVALIK APPARTMENT	TI-OKH005A-1	630	RESIDENTIAL	Functional	100%	208	0.23			
33 kV ALAKNANDA GRID	SALKN125	11kV FDR O/G SSTN. NO.-1, NARMADA APPARTMENT	TI-OKH004A-2	630	RESIDENTIAL	Functional	100%	209	0.20			
33 kV ALAKNANDA GRID	SALKN125	11kV FDR O/G SSTN. NO.-1, NARMADA APPARTMENT	TI-OKH004A-1	630	RESIDENTIAL	Functional	100%	20	0.09			
33 kV ALAKNANDA GRID	SALKN105	11kV FDR O/G TO MANDAKINI APPT.	TP-OKH211A-1	400	Commercial	Functional	100%	23	0.09			
66 kV OKHLA PHASE 1 GRID	SOKH1630	11kV FDR SSTN NO 4 SLUM FLATS A-14 KALKA JI EXT	510DDK-OKH252A	630	RESIDENTIAL	Functional	100%	0	0.05			
66 kV OKHLA PHASE 1 GRID	SOKH1630	11kV FDR SSTN NO 4 SLUM FLATS A-14 KALKA JI EXT	510DDK-OKH252A	630	MIXED	Functional	100%	200	0.05			
66 kV OKHLA PHASE 1 GRID	SOKH1630	11kV FDR SSTN NO 4 SLUM FLATS A-14 KALKA JI EXT	510DDK-OKH255A	630	MIXED	Functional	100%	0	0.03			
66 kV OKHLA PHASE 1 GRID	SOKH1109	11kV FDR SSTN NO.1 SLUM FLATS, A214, KALKA JI, EXT.	510DDK-OKH249A	630	RESIDENTIAL	Functional	100%	0	0.03			
66 kV OKHLA PHASE 1 GRID	SOKH1630	11kV FDR SSTN NO 4 SLUM FLATS A-14 KALKA JI EXT	510DDK-OKH255A	630	MIXED	Functional	100%	0	0.02			
66 kV OKHLA PHASE 1 GRID	SOKH1109	11kV FDR SSTN NO.1 SLUM FLATS, A214, KALKA JI, EXT.	510DDK-OKH249A	630	RESIDENTIAL	Functional	100%	0	0.02			
66 kV OKHLA PHASE 1 GRID	SOKH1630	11kV FDR SSTN NO 4 SLUM FLATS A-14 KALKA JI EXT	510DDK-OKH251A	630	MIXED	Functional	100%	0	0.00			
66 kV OKHLA PHASE 1 GRID	SOKH1630	11kV FDR SSTN NO 4 SLUM FLATS A-14 KALKA JI EXT	510DDK-OKH250A	630	MIXED	Functional	100%	0	0.00			
66 kV OKHLA PHASE 1 GRID	SOKH1630	11kV FDR SSTN NO 4 SLUM FLATS A-14 KALKA JI EXT	510DDK-OKH251A	630	MIXED	Functional	100%	0	0.00			
66 kV OKHLA PHASE 1 GRID	SOKH1630	11kV FDR SSTN NO 4 SLUM FLATS A-14 KALKA JI EXT	510DDK-OKH250A	630	MIXED	Functional	100%	0	0.00			
33 kV ALAKNANDA GRID	SALKN107	11kV FDR O/G TO KAVERI APPARTMENT	510DDK-OKH261A	400	MIXED	Functional	100%	0	0.00			
33 kV ALAKNANDA GRID	SALKN107	11kV FDR O/G TO KAVERI APPARTMENT	510DDK-OKH261A	400	MIXED	Functional	100%	0	0.00			
66 kV OKHLA PHASE 1 GRID	SOKH1110	11kV FDR O/G TO S/S NO.-7	TI-OKH100A-4	990	MIXED	Functional	100%	74	0.56	5.24	0.48	8.37%
66 kV OKHLA PHASE 1 GRID	SOKH1117	11kV FDR O/G S/S NO.-11 VIA F-90/5 OKHLA PH.-1	TP-OKH112A-1	990	MIXED	Functional	100%	183	0.55			
66 kV OKHLA PHASE 1 GRID	SOKH1110	11kV FDR O/G TO S/S NO.-7	TI-OKH100A-2	990	MIXED	Functional	100%	62	0.40			
66 kV OKHLA PHASE 1 GRID	SOKH1117	11kV FDR O/G S/S NO.-11 VIA F-90/5 OKHLA PH.-1	TG-OKH115A-1	990	MIXED	Functional	100%	26	0.36			
33 kV OKHLA PHASE-2 GRID	SOKH2122	11kV FDR TODAY HOTEL FEEDER NO.-1 + R.M.U	TX-OKH176A-1	990	MIXED	Functional	100%	101	0.35			
33 kV OKHLA PHASE-2 GRID	SOKH2122	11kV FDR TODAY HOTEL FEEDER NO.-1 + R.M.U	TP-OKH121A-1	630	MIXED	Functional	100%	8	0.32			
66 kV OKHLA PHASE 1 GRID	SOKH1105	11kV FDR S/S NO.-11 O/H OIA-1	TG-OKH110A-1	990	MIXED	Functional	100%	52	0.31			
33 kV OKHLA PHASE-2 GRID	SOKH2114	11kV FDR TODAY HOTEL FEEDER NO.-2	TP-OKH200A-1	630	MIXED	Functional	100%	6	0.30			
66 kV OKHLA PHASE 1 GRID	SOKH1110	11kV FDR O/G TO S/S NO.-7	TI-OKH100A-3	990	MIXED	Functional	100%	43	0.29			

66 kv OKHLA PHASE 1 GRID	SOKH1105	11kv FDR S/S NO.-11 O/H OIA-1	TP-OKH114A-1	630	MIXED	AMR	Functional	100%	104	0.26			
66 kv OKHLA PHASE 1 GRID	SOKH1110	11kv FDR O/G TO S/S NO.-7	TI-OKH100A-1	990	MIXED		Functional	100%	28	0.26			
66 kv OKHLA PHASE 1 GRID	SOKH1107	11kv FDR S/S NO.-E(E.S.I)	TP-OKH201A-1	630	MIXED		Functional	100%	26	0.22			
66 kv OKHLA PHASE 1 GRID	SOKH1105	11kv FDR S/S NO.-11 O/H OIA-1	TI-OKH104A-1	630	MIXED		Functional	100%	219	0.21			
66 kv OKHLA PHASE 1 GRID	SOKH1105	11kv FDR S/S NO.-11 O/H OIA-1	TI-OKH104A-3	990	MIXED		Functional	100%	198	0.20			
66 kv OKHLA PHASE 1 GRID	SOKH1117	11kv FDR O/G S/S NO.-11 VIA F-90/5 OKHLA PH.-1	TG-OKH113A-2	630	MIXED		Functional	100%	73	0.19			
66 kv OKHLA PHASE 1 GRID	SOKH1105	11kv FDR S/S NO.-11 O/H OIA-1	TI-OKH104A-2	630	MIXED		Functional	100%	9	0.16			
66 kv OKHLA PHASE 1 GRID	SOKH1112	11kv FDR O/G TO DTC WORK SHOP	5100P1-OKH248A	400	INDUSTRIAL		Functional	100%	6	0.16			
66 kv OKHLA PHASE 1 GRID	SOKH1117	11kv FDR O/G S/S NO.-11 VIA F-90/5 OKHLA PH.-1	TG-OKH115A-2	400	MIXED		Functional	100%	144	0.15			
33 kv OKHLA PHASE-2 GRID	SOKH2122	11kv FDR TODAY HOTEL FEEDER NO.-1 + R.M.U	TG-OKH077A-1	990	MIXED		Functional	100%	457	0.15			
33 kv OKHLA PHASE-2 GRID	SOKH2128	11kv FDR O/G N.B.C.C. OKHLA PHASE-1	TG-OKH242A-2	990	MIXED		Functional	100%	24	0.12			
33 kv OKHLA PHASE-2 GRID	SOKH2128	11kv FDR O/G N.B.C.C. OKHLA PHASE-1	TG-OKH242A-1	990	MIXED		Functional	100%	55	0.09			
66 kv OKHLA PHASE 1 GRID	SOKH1117	11kv FDR O/G S/S NO.-11 VIA F-90/5 OKHLA PH.-1	TG-OKH113A-1	400	MIXED		Functional	100%	28	0.09			
33 kv NEHRU PLACE GRID	SNPHG113	11KV FDR O/G C.R.PARK-A, S/STN-A	TX-GK2091A-1	990	Commercial		Functional	100%	427	0.56	4.29	0.12	2.73%
33 kv ALAKNANDA GRID	SALKN108	11kv FDR O/G TO N.R.I COMPLEX S/S	TG-GK2143A-2	990	RESIDENTIAL		Functional	100%	0	0.46			
33 kv ALAKNANDA GRID	SALKN121	11kv FDR O/G EPDP NO.-1	TX-GK2115A-1	990	Commercial		Functional	100%	351	0.45			
33 kv ALAKNANDA GRID	SALKN121	11kv FDR O/G EPDP NO.-1	TI-GK2045A-2	990	Commercial		Functional	100%	215	0.45			
33 kv ALAKNANDA GRID	SALKN121	11kv FDR O/G EPDP NO.-1	TI-GK2045A-1	990	Commercial		Functional	100%	375	0.44			
33 kv ALAKNANDA GRID	SALKN121	11kv FDR O/G EPDP NO.-1	TG-GK2147A-1	990	RESIDENTIAL		Functional	100%	83	0.42			
33 kv ALAKNANDA GRID	SALKN108	11kv FDR O/G TO N.R.I COMPLEX S/S	TG-GK2049A-2	990	RESIDENTIAL		Functional	100%	129	0.37			
33 kv ALAKNANDA GRID	SALKN103	11kv FDR O/G TO E.P.D.P SUB/STN NO.-2	TG-GK2071A-1	990	RESIDENTIAL		Functional	100%	327	0.34			
33 kv ALAKNANDA GRID	SALKN108	11kv FDR O/G TO N.R.I COMPLEX S/S	TG-GK2049A-1	990	Commercial		Functional	100%	417	0.33			
33 kv ALAKNANDA GRID	SALKN103	11kv FDR O/G TO E.P.D.P SUB/STN NO.-2	TG-GK2071A-2	630	Commercial		Functional	100%	89	0.29			
33 kv ALAKNANDA GRID	SALKN108	11kv FDR O/G TO N.R.I COMPLEX S/S	TG-GK2143A-1	630	RESIDENTIAL		Functional	100%	785	0.28			
66 kv OKHLA PHASE 1 GRID	SOKH1102	11kv FDR O/G S/S NO.-A DSIDC OKHLA PH.-1	TI-OKH106A-2	990	INDUSTRIAL	AMR	Functional	100%	1065	0.77	4.56	0.05	1.04%
33 kv OKHLA PHASE-2 GRID	SOKH2123	11kv FDR S/S NO.-8, OIA-1	TI-OKH101A-3	990	INDUSTRIAL		Functional	100%	189	0.54			
66 kv OKHLA PHASE 1 GRID	SOKH1102	11kv FDR O/G S/S NO.-A DSIDC OKHLA PH.-1	TI-OKH106A-1	990	INDUSTRIAL	AMR	Functional	100%	685	0.52			
66 kv OKHLA PHASE 1 GRID	SOKH1102	11kv FDR O/G S/S NO.-A DSIDC OKHLA PH.-1	5100P1-OKH108A	990	MIXED		Functional	100%	38	0.50			
66 kv OKHLA PHASE 1 GRID	SOKH1102	11kv FDR O/G S/S NO.-A DSIDC OKHLA PH.-1	5100P1-OKH108A	990	MIXED		Functional	100%	175	0.42			
33 kv OKHLA PHASE-2 GRID	SOKH2123	11kv FDR S/S NO.-8, OIA-1	TI-OKH101A-1	990	INDUSTRIAL		Functional	100%	0	0.36			
66 kv OKHLA PHASE 1 GRID	SOKH1102	11kv FDR O/G S/S NO.-A DSIDC OKHLA PH.-1	5100P1-OKH106A	630	RESIDENTIAL		Functional	100%	0	0.35			
66 kv OKHLA PHASE 1 GRID	SOKH1102	11kv FDR O/G S/S NO.-A DSIDC OKHLA PH.-1	TI-OKH107A-2	990	INDUSTRIAL		Functional	100%	45	0.33			
66 kv OKHLA PHASE 1 GRID	SOKH1102	11kv FDR O/G S/S NO.-A DSIDC OKHLA PH.-1	TI-OKH107A-1	990	INDUSTRIAL		Functional	100%	98	0.26			
33 kv OKHLA PHASE-2 GRID	SOKH2123	11kv FDR S/S NO.-8, OIA-1	TI-OKH101A-2	990	INDUSTRIAL		Functional	100%	22	0.20			
33 kv OKHLA PHASE-2 GRID	SOKH2123	11kv FDR S/S NO.-8, OIA-1	TI-OKH101A-4	990	INDUSTRIAL		Functional	100%	282	0.19			
66 kv OKHLA PHASE 1 GRID	SOKH1102	11kv FDR O/G S/S NO.-A DSIDC OKHLA PH.-1	5100P1-OKH108A	990	MIXED		Functional	100%	0	0.14			
66 kv OKHLA PHASE 1 GRID	SOKH1123	11kv FDR S/S NO.-4	TP-OKH099A-1	400	INDUSTRIAL		Functional	100%	4	0.02			
66 kv OKHLA PHASE 1 GRID	SOKH1114	11kv FDR O/G PUL PRAHALADPUR	TG-OKH084A-1	990	INDUSTRIAL		Functional	100%	1492	0.83	2.49	0.14	5.35%
66 kv OKHLA PHASE 1 GRID	SOKH1107	11kv FDR S/S NO.-E(E.S.I)	TG-OKH192A-1	990	INDUSTRIAL		Functional	100%	103	0.60			
66 kv OKHLA PHASE 1 GRID	SOKH1103	11kv FDR O/G S/S NO.-1 F-BLOCK OKHLA PH.-1	TI-OKH060B-2	990	INDUSTRIAL		Functional	100%	36	0.28			
66 kv OKHLA PHASE 1 GRID	SOKH1107	11kv FDR S/S NO.-E(E.S.I)	TI-OKH131A-2	990	RESIDENTIAL		Functional	100%	38	0.26			
66 kv OKHLA PHASE 1 GRID	SOKH1103	11kv FDR O/G S/S NO.-1 F-BLOCK OKHLA PH.-1	TI-OKH060A-2	990	INDUSTRIAL		Functional	100%	1345	0.20			
66 kv OKHLA PHASE 1 GRID	SOKH1103	11kv FDR O/G S/S NO.-1 F-BLOCK OKHLA PH.-1	TI-OKH060A-1	630	INDUSTRIAL		Functional	100%	0	0.19			
66 kv OKHLA PHASE 1 GRID	SOKH1107	11kv FDR S/S NO.-E(E.S.I)	TI-OKH131A-3	990	INDUSTRIAL		Functional	100%	23	0.18			
66 kv OKHLA PHASE 1 GRID	SOKH1107	11kv FDR S/S NO.-E(E.S.I)	TI-OKH131A-1	630	INDUSTRIAL		Functional	100%	0	0.05			
66 kv OKHLA PHASE 1 GRID	SOKH1124	11kv STR 400kVA STATION TRF. NO.-2	TI-STC090A-1	400	RESIDENTIAL		Functional	100%	1	0.03			
66 kv OKHLA PHASE 1 GRID	SOKH1125	11kv FDR O/G TO CCI COMPLEX NO.-2	TP-OKH129A-1	100	INDUSTRIAL		Functional	100%	3	0.02			
33 kv NEHRU PLACE GRID	SNPHG101	11KV FDR O/G DESHBANDHU COLLEGE	TX-GK2111A-1	990	Residential		Functional	100%	342	0.60	3.69	0.19	4.95%
33 kv NEHRU PLACE GRID	SNPHG101	11KV FDR O/G DESHBANDHU COLLEGE	TK-GK2014A-2	990	Residential		Functional	100%	597	0.57			
33 kv NEHRU PLACE GRID	SNPHG107	11KV FDR O/G G-BLOCK KALKA JI	TI-GK2016A-2	990	RESIDENTIAL		Functional	100%	987	0.50			

33 kV BALAJI STATE GRID	SBALA102	11kV FDR G - BLOCK, KALKAJI	TI-GK2016A-1	990	Residential		Functional	100%	141	0.32			
33 kV BALAJI STATE GRID	SBALA102	11kV FDR G - BLOCK, KALKAJI	TI-GK2017A-2	630	Residential		Functional	100%	129	0.30			
33 kV BALAJI STATE GRID	SBALA102	11kV FDR G - BLOCK, KALKAJI	TG-GK2042A-1	990	Residential		Functional	100%	284	0.28			
33 kV BALAJI STATE GRID	SBALA102	11kV FDR G - BLOCK, KALKAJI	TI-GK2043A-1	990	RESIDENTIAL		Functional	100%	250	0.28			
33 kV BALAJI STATE GRID	SBALA102	11kV FDR G - BLOCK, KALKAJI	TI-GK2017A-1	630	RESIDENTIAL		Functional	100%	155	0.26			
33 kV BALAJI STATE GRID	SBALA102	11kV FDR G - BLOCK, KALKAJI	TG-GK2042A-2	630	RESIDENTIAL		Functional	100%	0	0.23			
33 kV BALAJI STATE GRID	SBALA102	11kV FDR G - BLOCK, KALKAJI	TI-GK2043A-2	990	Residential		Functional	100%	106	0.22			
33 kV NEHRU PLACE GRID	SNPHG101	11kV FDR O/G DESHBANDHU COLLEGE	TK-GK2014A-1	400	RESIDENTIAL		Functional	100%	0	0.17			
33 kV BALAJI STATE GRID	SBALA107	11kV STR 400KVA STATION TRANSFORMER	TI-STC116A-1	400	COMMERCIAL		Functional	100%	1	0.15			
33 kV BALAJI STATE GRID	SBALA118	11kV FDR GIRI NAGAR NO.-1 (NEAR METRO STATION)	510GBK-GK2153A	250	MIXED		Functional	100%	0	0.00			
33 kV BALAJI STATE GRID	SBALA118	11kV FDR GIRI NAGAR NO.-1 (NEAR METRO STATION)	TG-GK2004A-1	990	Commercial		Functional	100%	663	0.58	2.33	0.09	3.90%
33 kV BALAJI STATE GRID	SBALA118	11kV FDR GIRI NAGAR NO.-1 (NEAR METRO STATION)	TI-GK2001A-1	990	RESIDENTIAL		Functional	100%	980	0.58			
220kV OKHLA TRANSCO GRID SST	TDTOG104	11kV FDR GIRI NAGAR NO.-2(T-camp B)	TG-GK2003A-1	630	Commercial		Functional	100%	455	0.48			
33 kV BALAJI STATE GRID	SBALA115	11kV FDR GIRI NAGAR SSTN NO.-2 (NEAR METRO STATION)	TI-GK2002A-1	990	RESIDENTIAL		Functional	100%	272	0.29			
33 kV BALAJI STATE GRID	SBALA118	11kV FDR GIRI NAGAR NO.-1 (NEAR METRO STATION)	TI-GK2001A-2	400	RESIDENTIAL		Functional	100%	174	0.20			
33 kV BALAJI STATE GRID	SBALA115	11kV FDR GIRI NAGAR SSTN NO.-2 (NEAR METRO STATION)	TI-GK2002A-2	400	Commercial		Functional	100%	192	0.15			
33 kV BALAJI STATE GRID	SBALA101	11kV FDR MUNJAL, KALKAJI EXTN.	510GBK-GK2154A	400	RESIDENTIAL		Functional	100%	5	0.14			
33 kV MASJID MOTH GRID	SMMOT105	11kV FDR O/G E-BLOCK G.K-2	510GK2-GK2050A	630	MIXED		Functional	100%	194	0.56	6.34	0.17	2.61%
33 kV MASJID MOTH GRID	SMMOT105	11kV FDR O/G E-BLOCK G.K-2	TI-GK2047A-3	990	RESIDENTIAL		Functional	100%	233	0.53			
33 kV MASJID MOTH GRID	SMMOT105	11kV FDR O/G E-BLOCK G.K-2	TI-GK2047A-2	990	MIXED		Functional	100%	115	0.53			
33 kV NEHRU PLACE GRID	SNPHG110	11kV FDR O/G ARYA SAMAJ MANDIR KALKAJI	TI-GK2044A-2	990	MIXED		Functional	100%	587	0.51			
33 kV V.S.N.L. GRID	SVSNL108	11kV FDR OUT GOING VSNL (TCIL)	TX-GK2068A-1	990	MIXED		Functional	100%	571	0.47			
33 kV NEHRU PLACE GRID	SNPHG110	11kV FDR O/G ARYA SAMAJ MANDIR KALKAJI	TI-GK2044A-1	990	MIXED		Functional	100%	118	0.46			
33 kV MASJID MOTH GRID	SMMOT105	11kV FDR O/G E-BLOCK G.K-2	TG-GK2050A-2	990	MIXED		Functional	100%	134	0.45			
33 kV NEHRU PLACE GRID	SNPHG113	11kV FDR O/G C.R PARK-A, S/STN-A	TX-GK2092A-1	990	MIXED		Functional	100%	302	0.43			
33 kV V.S.N.L. GRID	SVSNL108	11kV FDR OUT GOING VSNL (TCIL)	TX-GK2068A-2	990	MIXED		Functional	100%	189	0.41			
33 kV NEHRU PLACE GRID	SNPHG110	11kV FDR O/G ARYA SAMAJ MANDIR KALKAJI	TG-GK2044A-3	630	RESIDENTIAL		Functional	100%	195	0.35			
33 kV MASJID MOTH GRID	SMMOT105	11kV FDR O/G E-BLOCK G.K-2	TI-GK2047A-1	990	MIXED		Functional	100%	469	0.34			
33 kV NEHRU PLACE GRID	SNPHG110	11kV FDR O/G ARYA SAMAJ MANDIR KALKAJI	TX-GK2116A-1	990	MIXED		Functional	100%	180	0.32			
33 kV ALAKNANDA GRID	SALKN122	11kV FDR O/G D.L.F, E-BLOCK G.K-2	TG-GK2135A-1	630	RESIDENTIAL		Functional	100%	359	0.29			
33 kV V.S.N.L. GRID	SVSNL108	11kV FDR OUT GOING VSNL (TCIL)	TG-GK2068A-3	990	RESIDENTIAL		Functional	100%	0	0.28			
33 kV ALAKNANDA GRID	SALKN122	11kV FDR O/G D.L.F, E-BLOCK G.K-2	510GK2-GK2135A	630	COMMERCIAL		Functional	100%	0	0.26			
33 kV MASJID MOTH GRID	SMMOT105	11kV FDR O/G E-BLOCK G.K-2	TI-GK2060A-2	990	MIXED		Functional	100%	29	0.17			
33 kV MASJID MOTH GRID	SMMOT105	11kV FDR O/G E-BLOCK G.K-2	TI-GK2060A-1	630	MIXED		Functional	100%	69	0.13			
33 kV BALAJI STATE GRID	SBALA118	11kV FDR GIRI NAGAR NO.-1 (NEAR METRO STATION)	TP-GK2011A-2	990	MIXED		Functional	100%	73	1.00	6.86	0.85	10.97%
220kV OKHLA TRANSCO GRID SST	TDTOG102	11kV FDR GIRI NAGAR NO.-1	TK-GK2012A-1	990	MIXED		Functional	100%	1218	0.85			
33 kV BALAJI STATE GRID	SBALA118	11kV FDR GIRI NAGAR NO.-1 (NEAR METRO STATION)	TG-GK2088A-1	990	MIXED		Functional	100%	496	0.80			
33 kV ALAKNANDA GRID	SALKN124	11kV FDR O/G GALI NO.-16, GOVIND PURI (TINWALA)	TG-GK2129A-1	990	MIXED		Functional	100%	977	0.68			
220kV OKHLA TRANSCO GRID SST	TDTOG102	11kV FDR GIRI NAGAR NO.-1	TG-GK2013A-1	990	MIXED		Functional	100%	195	0.66			
220kV OKHLA TRANSCO GRID SST	TDTOG102	11kV FDR GIRI NAGAR NO.-1	TI-GK2038A-1	1000	MIXED		Functional	100%	171	0.63			
33 kV ALAKNANDA GRID	SALKN124	11kV FDR O/G GALI NO.-16, GOVIND PURI (TINWALA)	TG-GK2077A-2	630	MIXED		Functional	100%	419	0.53			
33 kV BALAJI STATE GRID	SBALA118	11kV FDR GIRI NAGAR NO.-1 (NEAR METRO STATION)	TG-GK2011A-1	990	MIXED		Functional	100%	1092	0.53			
220kV OKHLA TRANSCO GRID SST	TDTOG102	11kV FDR GIRI NAGAR NO.-1	TP-GK2013A-3	630	RESIDENTIAL		Functional	100%	0	0.50			
220kV OKHLA TRANSCO GRID SST	TDTOG102	11kV FDR GIRI NAGAR NO.-1	TG-GK2013A-2	630	MIXED		Functional	100%	549	0.44			
33 kV ALAKNANDA GRID	SALKN124	11kV FDR O/G GALI NO.-16, GOVIND PURI (TINWALA)	TG-GK2077A-3	630	MIXED		Functional	100%	1325	0.35			
33 kV ALAKNANDA GRID	SALKN124	11kV FDR O/G GALI NO.-16, GOVIND PURI (TINWALA)	TG-GK2077A-1	990	MIXED		Functional	100%	18	0.29			
33 kV ALAKNANDA GRID	SALKN124	11kV FDR O/G GALI NO.-16, GOVIND PURI (TINWALA)	TP-GK2010A-1	400	MIXED		Functional	100%	124	0.26			

33 kV ALAKNANDA GRID	SALKN124	11kV FDR O/G GALI NO.-16, GOVIND PURI (TINWALA)	TP-GK2010A-2	400	MIXED		Functional	100%	468	0.19	11.26	0.14	1.26%			
33 kV ALAKNANDA GRID	SALKN124	11kV FDR O/G GALI NO.-16, GOVIND PURI (TINWALA)	510GBK-GK2155A	400	MIXED		Functional	100%	0	0.00						
33 kV BALAJI STATE GRID	SBALA104	11kV FDR GALI NO.-10, GOVINDPURI	TK-GK2008A-2	990	RESIDENTIAL		Functional	100%	488	0.94						
33 kV BALAJI STATE GRID	SBALA104	11kV FDR GALI NO.-10, GOVINDPURI	TK-GK2008A-1	990	RESIDENTIAL		Functional	100%	1506	0.86						
220kV OKHLA TRANSCO GRID SST	TDTOG109	11kV FDR GOVIND PURI GALI NO.-5	TG-GK2089A-2	990	RESIDENTIAL		Functional	100%	0	0.77						
33 kV ALAKNANDA GRID	SALKN106	11kV FDR O/G TO DESHBANDHU APPARTMENT	TX-GK2023A-2	990	RESIDENTIAL		Functional	100%	268	0.77						
33 kV BALAJI STATE GRID	SBALA104	11kV FDR GALI NO.-10, GOVINDPURI	TG-GK2007A-1	990	RESIDENTIAL		Functional	100%	770	0.76						
33 kV BALAJI STATE GRID	SBALA104	11kV FDR GALI NO.-10, GOVINDPURI	TG-GK2007A-2	990	RESIDENTIAL		Functional	100%	2668	0.76						
33 kV ALAKNANDA GRID	SALKN101	11kV FDR O/G TO D.D.A SLUM KALKA JI	TG-GK2150A-2	990	RESIDENTIAL		Functional	100%	1482	0.70						
33 kV ALAKNANDA GRID	SALKN101	11kV FDR O/G TO D.D.A SLUM KALKA JI	TG-GK2150A-1	990	RESIDENTIAL		Functional	100%	715	0.67						
220kV OKHLA TRANSCO GRID SST	TDTOG109	11kV FDR GOVIND PURI GALI NO.-5	TK-GK2006A-4	990	Commercial		Functional	100%	232	0.66						
33 kV BALAJI STATE GRID	SBALA115	11kV FDR GIRI NAGAR SSTN NO.-2 (NEAR METRO STATION)	TG-GK2005A-1	990	RESIDENTIAL		Functional	100%	1801	0.60						
220kV OKHLA TRANSCO GRID SST	TDTOG109	11kV FDR GOVIND PURI GALI NO.-5	TK-GK2006A-1	630	RESIDENTIAL		Functional	100%	877	0.51						
33 kV BALAJI STATE GRID	SBALA122	11kV FDR O/G RAMANUJAN COLLEGE	TX-GK2119A-1	630	RESIDENTIAL		Functional	100%	0	0.49						
220kV OKHLA TRANSCO GRID SST	TDTOG109	11kV FDR GOVIND PURI GALI NO.-5	TG-GK2089A-1	990	RESIDENTIAL		Functional	100%	3180	0.49						
220kV OKHLA TRANSCO GRID SST	TDTOG109	11kV FDR GOVIND PURI GALI NO.-5	TK-GK2006A-2	630	RESIDENTIAL		Functional	100%	321	0.47						
33 kV BALAJI STATE GRID	SBALA122	11kV FDR O/G RAMANUJAN COLLEGE	TX-GK2119A-2	990	Commercial		Functional	100%	512	0.45						
33 kV BALAJI STATE GRID	SBALA104	11kV FDR GALI NO.-10, GOVINDPURI	TG-GK2007A-3	630	RESIDENTIAL		Functional	100%	0	0.41						
33 kV BALAJI STATE GRID	SBALA115	11kV FDR GIRI NAGAR SSTN NO.-2 (NEAR METRO STATION)	TG-GK2005A-2	630	RESIDENTIAL		Functional	100%	0	0.40						
220kV OKHLA TRANSCO GRID SST	TDTOG109	11kV FDR GOVIND PURI GALI NO.-5	TK-GK2006A-3	630	RESIDENTIAL		Functional	100%	1527	0.37						
33 kV ALAKNANDA GRID	SALKN101	11kV FDR O/G TO D.D.A SLUM KALKA JI	TG-GK2150A-3	630	RESIDENTIAL		Functional	100%	0	0.29						
33 kV ALAKNANDA GRID	SALKN106	11kV FDR O/G TO DESHBANDHU APPARTMENT	TX-GK2023A-1	990	RESIDENTIAL		Functional	100%	974	0.05						
220kV OKHLA TRANSCO GRID SST	TDTOG106	11kV FDR POKET A-12 KALKAJI EXTN.	TI-OKH042A-1	990	Commercial	AMR	Functional	100%	231	0.75	4.56	0.59	11.43%			
33 kV BALAJI STATE GRID	SBALA112	11kV FDR POCKET A-3,KALKAJI EXTN.	TG-OKH023A-1	990	MIXED		Functional	100%	66	0.69						
220kV OKHLA TRANSCO GRID SST	TDTOG103	11kV FDR POKET A-10 KALKAJI EXTN.	TP-OKH059A-1	630	RESIDENTIAL		Functional	100%	1449	0.53						
220kV OKHLA TRANSCO GRID SST	TDTOG103	11kV FDR POKET A-10 KALKAJI EXTN.	TG-OKH047A-1	630	RESIDENTIAL		Functional	100%	1315	0.49						
220kV OKHLA TRANSCO GRID SST	TDTOG103	11kV FDR POKET A-10 KALKAJI EXTN.	TG-OKH046A-1	630	RESIDENTIAL		Functional	100%	763	0.44						
220kV OKHLA TRANSCO GRID SST	TDTOG106	11kV FDR POKET A-12 KALKAJI EXTN.	TG-OKH237A-1	630	RESIDENTIAL		Functional	100%	344	0.41						
220kV OKHLA TRANSCO GRID SST	TDTOG103	11kV FDR POKET A-10 KALKAJI EXTN.	TG-OKH048A-2	630	RESIDENTIAL		Functional	100%	784	0.40						
33 kV BALAJI STATE GRID	SBALA112	11kV FDR POCKET A-3,KALKAJI EXTN.	TI-OKH029A-1	990	RESIDENTIAL		Functional	100%	306	0.29						
220kV OKHLA TRANSCO GRID SST	TDTOG103	11kV FDR POKET A-10 KALKAJI EXTN.	TG-OKH048A-1	630	Commercial		Functional	100%	457	0.28						
33 kV BALAJI STATE GRID	SBALA112	11kV FDR POCKET A-3,KALKAJI EXTN.	TI-OKH030A-1	630	RESIDENTIAL		Functional	100%	167	0.26						
33 kV BALAJI STATE GRID	SBALA112	11kV FDR POCKET A-3,KALKAJI EXTN.	TG-GK2127A-1	630	RESIDENTIAL		Functional	100%	1004	0.25						
33 kV BALAJI STATE GRID	SBALA112	11kV FDR POCKET A-3,KALKAJI EXTN.	TG-OKH050A-1	630	RESIDENTIAL		Functional	100%	1032	0.19						
33 kV BALAJI STATE GRID	SBALA112	11kV FDR POCKET A-3,KALKAJI EXTN.	TI-OKH030A-2	630	RESIDENTIAL		Functional	100%	101	0.15						
33 kV BALAJI STATE GRID	SBALA105	11kV FDR H-BLOCK GOL CHAKKAR	TI-GK2126A-1	990	Commercial		Functional	100%	170	0.67				5.04	0.24	4.60%
33 kV BALAJI STATE GRID	SBALA105	11kV FDR H-BLOCK GOL CHAKKAR	TG-GK2022A-2	990	RESIDENTIAL		Functional	100%	303	0.57						
33 kV ALAKNANDA GRID	SALKN106	11kV FDR O/G TO DESHBANDHU APPARTMENT	TG-GK2021A-1	990	Commercial		Functional	100%	572	0.53						
33 kV ALAKNANDA GRID	SALKN106	11kV FDR O/G TO DESHBANDHU APPARTMENT	TG-GK2021A-3	630	RESIDENTIAL		Functional	100%	0	0.49						
33 kV NEHRU PLACE GRID	SNPHG107	11kV FDR O/G G-BLOCK KALKA JI	TG-GK2020A-2	990	Commercial		Functional	100%	129	0.49						
33 kV BALAJI STATE GRID	SBALA105	11kV FDR H-BLOCK GOL CHAKKAR	TG-GK2022A-1	990	RESIDENTIAL		Functional	100%	209	0.45						
33 kV NEHRU PLACE GRID	SNPHG107	11kV FDR O/G G-BLOCK KALKA JI	TI-GK2035A-1	630	Commercial		Functional	100%	92	0.43						
33 kV NEHRU PLACE GRID	SNPHG107	11kV FDR O/G G-BLOCK KALKA JI	TG-GK2020A-1	990	Commercial		Functional	100%	742	0.43						

33 kv ALAKNANDA GRID	SALKN106	11kv FDR O/G TO DESHBANDHU APPARTMENT	TG-GK2021A-2	990	Commercial	Functional	100%	369	0.39			
33 kv BALAJI STATE GRID	SBALA105	11kv FDR H-BLOCK GOL CHAKKAR	TX-GK2018A-1	990	Commercial	Functional	100%	148	0.28			
33 kv NEHRU PLACE GRID	SNPHG107	11kv FDR O/G G-BLOCK KALKA JI	TI-GK2034A-1	630	RESIDENTIAL	Functional	100%	46	0.23			
33 kv NEHRU PLACE GRID	SNPHG107	11kv FDR O/G G-BLOCK KALKA JI	TI-GK2034A-2	630	RESIDENTIAL	Functional	100%	57	0.16			
33 kv BALAJI STATE GRID	SBALA105	11kv FDR H-BLOCK GOL CHAKKAR	TX-GK2018A-2	990	Commercial	Functional	100%	150	0.16			
33 kv ALAKNANDA GRID	SALKN104	11kv FDR O/G TO NILGIRI SUB.STN. NO.-1	TI-OKH006A-1	630	RESIDENTIAL	Functional	100%	119	0.26	2.44	0.01	0.30%
33 kv ALAKNANDA GRID	SALKN104	11kv FDR O/G TO NILGIRI SUB.STN. NO.-1	TI-OKH008A-1	630	RESIDENTIAL	Functional	100%	49	0.25			
33 kv ALAKNANDA GRID	SALKN104	11kv FDR O/G TO NILGIRI SUB.STN. NO.-1	TI-OKH008A-2	630	RESIDENTIAL	Functional	100%	222	0.24			
33 kv ALAKNANDA GRID	SALKN104	11kv FDR O/G TO NILGIRI SUB.STN. NO.-1	TI-OKH006A-2	630	Commercial	Functional	100%	161	0.24			
33 kv ALAKNANDA GRID	SALKN104	11kv FDR O/G TO NILGIRI SUB.STN. NO.-1	TI-OKH009A-2	630	RESIDENTIAL	Functional	100%	5	0.23			
33 kv ALAKNANDA GRID	SALKN104	11kv FDR O/G TO NILGIRI SUB.STN. NO.-1	TI-OKH009A-1	630	Commercial	Functional	100%	365	0.21			
33 kv ALAKNANDA GRID	SALKN125	11kv FDR O/G SSTN. NO.-1, NARMADA APPARTMENT	TI-OKH010A-2	630	RESIDENTIAL	Functional	100%	175	0.21			
33 kv ALAKNANDA GRID	SALKN125	11kv FDR O/G SSTN. NO.-1, NARMADA APPARTMENT	TI-OKH011A-1	630	Commercial	Functional	100%	102	0.19			
33 kv ALAKNANDA GRID	SALKN125	11kv FDR O/G SSTN. NO.-1, NARMADA APPARTMENT	TI-OKH011A-2	630	RESIDENTIAL	Functional	100%	164	0.14			
33 kv ALAKNANDA GRID	SALKN104	11kv FDR O/G TO NILGIRI SUB.STN. NO.-1	TI-OKH007A-1	630	Commercial	Functional	100%	182	0.14			
33 kv ALAKNANDA GRID	SALKN104	11kv FDR O/G TO NILGIRI SUB.STN. NO.-1	TI-OKH007A-2	630	RESIDENTIAL	Functional	100%	33	0.13			
33 kv ALAKNANDA GRID	SALKN125	11kv FDR O/G SSTN. NO.-1, NARMADA APPARTMENT	TI-OKH010A-1	630	Commercial	Functional	100%	46	0.11			
33 kv ALAKNANDA GRID	SALKN104	11kv FDR O/G TO NILGIRI SUB.STN. NO.-1	TI-OKH001A-1	630	RESIDENTIAL	Functional	100%	43	0.06			
33 kv ALAKNANDA GRID	SALKN104	11kv FDR O/G TO NILGIRI SUB.STN. NO.-1	TI-OKH001A-2	630	Commercial	Functional	100%	30	0.03			
33 kv V.S.N.L. GRID	SVSNL105	11kv FDR OUT GOING FEEDER-1, M-BLOCK MOTHER DAIRY G.K-II	510GK2-GK2120A	990	MIXED	Functional	100%	394	0.57	6.19	0.09	1.49%
33 kv V.S.N.L. GRID	SVSNL105	11kv FDR OUT GOING FEEDER-1, M-BLOCK MOTHER DAIRY G.K-II	TG-GK2118A-1	990	MIXED	Functional	100%	90	0.55			
33 kv V.S.N.L. GRID	SVSNL104	11kv FDR OUT GOING FEEDER-6,E-BLOCK G.K-2 (SEHGAL MKT.-2)	TI-GK2080A-1	990	MIXED	Functional	100%	378	0.51			
33 kv V.S.N.L. GRID	SVSNL108	11kv FDR OUT GOING VSNL (TCIL)	TK-GK2079A-1	990	MIXED	Functional	100%	278	0.51			
33 kv V.S.N.L. GRID	SVSNL105	11kv FDR OUT GOING FEEDER-1, M-BLOCK MOTHER DAIRY G.K-II	510GK2-GK2120A	990	MIXED	Functional	100%	110	0.46			
33 kv V.S.N.L. GRID	SVSNL104	11kv FDR OUT GOING FEEDER-6,E-BLOCK G.K-2 (SEHGAL MKT.-2)	TI-GK2125A-1	990	MIXED	Functional	100%	184	0.46			
33 kv V.S.N.L. GRID	SVSNL105	11kv FDR OUT GOING FEEDER-1, M-BLOCK MOTHER DAIRY G.K-II	510GK2-GK2120A	990	MIXED	Functional	100%	142	0.46			
33 kv V.S.N.L. GRID	SVSNL108	11kv FDR OUT GOING VSNL (TCIL)	TK-GK2079A-2	990	MIXED	Functional	100%	364	0.43			
33 kv V.S.N.L. GRID	SVSNL104	11kv FDR OUT GOING FEEDER-6,E-BLOCK G.K-2 (SEHGAL MKT.-2)	TI-GK2080A-2	990	MIXED	Functional	100%	99	0.41			
33 kv ALAKNANDA GRID	SALKN122	11kv FDR O/G D.L.F, E-BLOCK G.K-2	TG-GK2065A-1	990	MIXED	Functional	100%	130	0.40			
33 kv ALAKNANDA GRID	SALKN123	11kv FDR O/G D.L.F, W-BLOCK G.K-2	TG-GK2105A-1	630	RESIDENTIAL	Functional	100%	115	0.38			
33 kv V.S.N.L. GRID	SVSNL104	11kv FDR OUT GOING FEEDER-6,E-BLOCK G.K-2 (SEHGAL MKT.-2)	TX-GK2114A-1	990	MIXED	Functional	100%	154	0.34			
33 kv V.S.N.L. GRID	SVSNL108	11kv FDR OUT GOING VSNL (TCIL)	TP-GK2151A-1	630	RESIDENTIAL	Functional	100%	137	0.33			
33 kv V.S.N.L. GRID	SVSNL105	11kv FDR OUT GOING FEEDER-1, M-BLOCK MOTHER DAIRY G.K-II	TG-GK2066A-1	630	MIXED	Functional	100%	193	0.32			
33 kv V.S.N.L. GRID	SVSNL105	11kv FDR OUT GOING FEEDER-1, M-BLOCK MOTHER DAIRY G.K-II	TG-GK2066A-2	400	MIXED	Functional	100%	47	0.17			
33 kv V.S.N.L. GRID	SVSNL105	11kv FDR OUT GOING FEEDER-1, M-BLOCK MOTHER DAIRY G.K-II	510GK2-GK2118A	400	RESIDENTIAL	Functional	100%	0	0.00			
33 kv V.S.N.L. GRID	SVSNL128	11kv FDR OUT GOING FEEDER-2, G-BLOCK MASJID MOTH G.K-II	TI-GK2059A-2	990	Commercial	Functional	100%	68	0.58	5.36	0.18	3.32%
33 kv V.S.N.L. GRID	SVSNL106	11kv FDR CC MASJID MODH:ID	TX-GK2113A-1	990	Commercial	Functional	100%	174	0.58			
33 kv V.S.N.L. GRID	SVSNL128	11kv FDR OUT GOING FEEDER-2, G-BLOCK MASJID MOTH G.K-II	TI-GK2057A-1	1000	RESIDENTIAL	Functional	100%	345	0.56			
33 kv V.S.N.L. GRID	SVSNL128	11kv FDR OUT GOING FEEDER-2, G-BLOCK MASJID MOTH G.K-II	TI-GK2059A-1	990	Commercial	Functional	100%	267	0.56			
33 kv V.S.N.L. GRID	SVSNL123	11kv FDR EPR GK ENCLAVE-2	TG-GK2056A-1	990	Commercial	Functional	100%	316	0.51			
33 kv MASJID MOTH GRID	SMMOT107	11kv FDR O/G VIPS INDIA	TI-GK2058A-2	990	Commercial	Functional	100%	166	0.49			
33 kv V.S.N.L. GRID	SVSNL123	11kv FDR EPR GK ENCLAVE-2	TI-GK2053A-1	990	Commercial	Functional	100%	238	0.44			
33 kv V.S.N.L. GRID	SVSNL106	11kv FDR CC MASJID MODH:ID	TI-GK2058A-3	990	Commercial	Functional	100%	104	0.40			
33 kv V.S.N.L. GRID	SVSNL128	11kv FDR OUT GOING FEEDER-2, G-BLOCK MASJID MOTH G.K-II	TI-GK2057A-2	1000	RESIDENTIAL	Functional	100%	99	0.39			
33 kv V.S.N.L. GRID	SVSNL128	11kv FDR OUT GOING FEEDER-2, G-BLOCK MASJID MOTH G.K-II	TI-GK2055A-2	990	Commercial	Functional	100%	270	0.37			
33 kv V.S.N.L. GRID	SVSNL123	11kv FDR EPR GK ENCLAVE-2	TI-GK2053A-2	630	RESIDENTIAL	Functional	100%	33	0.26			
33 kv V.S.N.L. GRID	SVSNL128	11kv FDR OUT GOING FEEDER-2, G-BLOCK MASJID MOTH G.K-II	TI-GK2055A-1	630	RESIDENTIAL	Functional	100%	118	0.21			
33 kv V.S.N.L. GRID	SVSNL106	11kv FDR CC MASJID MODH:ID	TI-GK2058A-1	400	Commercial	Functional	100%	78	0.20			
33 kv ALAKNANDA GRID	SALKN118	11kv FDR O/G W-1 BLOCK G.K-2	TK-GK2124A-2	990	MIXED	Functional	100%	233	0.55	3.05	0.01	0.23%
33 kv ALAKNANDA GRID	SALKN105	11kv FDR O/G TO MANDAKINI APPT.	TI-GK2072A-1	990	MIXED	Functional	100%	125	0.53			

33 kv ALAKNANDA GRID	SALKN118	11kv FDR O/G W-1 BLOCK G.K-2	TG-GK2104A-2	990	MIXED		Functional	100%	212	0.52			
33 kv V.S.N.L. GRID	SVSNL104	11kv FDR OUT GOING FEEDER-6,E-BLOCK G.K-2 (SEHGAL MKT.-2)	TI-GK2072A-3	990	MIXED		Functional	100%	189	0.43			
33 kv V.S.N.L. GRID	SVSNL104	11kv FDR OUT GOING FEEDER-6,E-BLOCK G.K-2 (SEHGAL MKT.-2)	TI-GK2072A-2	990	MIXED		Functional	100%	77	0.41			
33 kv ALAKNANDA GRID	SALKN118	11kv FDR O/G W-1 BLOCK G.K-2	TK-GK2124A-1	990	MIXED		Functional	100%	134	0.36			
33 kv ALAKNANDA GRID	SALKN118	11kv FDR O/G W-1 BLOCK G.K-2	TG-GK2104A-1	400	MIXED		Functional	100%	0	0.20			
33 kv ALAKNANDA GRID	SALKN118	11kv FDR O/G W-1 BLOCK G.K-2	TG-GK2069A-1	400	MIXED		Functional	100%	147	0.06			
33 kv V.S.N.L. GRID	SVSNL105	11kv FDR OUT GOING FEEDER-1, M-BLOCK MOTHER DAIRY G.K-II	TG-GK2063A-2	990	RESIDENTIAL		Functional	100%	645	0.54	3.75	0.07	1.88%
33 kv ALAKNANDA GRID	SALKN113	11kv FDR O/G TO S-BLOCK G.K-II	TI-GK2062A-2	990	Commercial		Functional	100%	228	0.49			
33 kv ALAKNANDA GRID	SALKN113	11kv FDR O/G TO S-BLOCK G.K-II	TG-GK2063A-1	990	Commercial		Functional	100%	114	0.47			
33 kv ALAKNANDA GRID	SALKN113	11kv FDR O/G TO S-BLOCK G.K-II	TG-GK2090A-1	990	RESIDENTIAL		Functional	100%	170	0.46			
33 kv ALAKNANDA GRID	SALKN113	11kv FDR O/G TO S-BLOCK G.K-II	TI-GK2081A-1	990	Commercial		Functional	100%	312	0.41			
33 kv ALAKNANDA GRID	SALKN113	11kv FDR O/G TO S-BLOCK G.K-II	TI-GK2062A-1	990	RESIDENTIAL		Functional	100%	182	0.38			
33 kv ALAKNANDA GRID	SALKN105	11kv FDR O/G TO MANDAKINI APPT.	TI-GK2075A-2	990	RESIDENTIAL		Functional	100%	212	0.31			
33 kv ALAKNANDA GRID	SALKN105	11kv FDR O/G TO MANDAKINI APPT.	TI-GK2076A-2	990	Commercial		Functional	100%	266	0.29			
33 kv ALAKNANDA GRID	SALKN105	11kv FDR O/G TO MANDAKINI APPT.	TI-GK2075A-1	990	RESIDENTIAL		Functional	100%	207	0.28			
33 kv ALAKNANDA GRID	SALKN105	11kv FDR O/G TO MANDAKINI APPT.	TI-GK2076A-1	630	Commercial		Functional	100%	128	0.19			
66 kv OKHLA PHASE 1 GRID	SOKH1104	11kv FDR O/G TO S/S NO.-3 OKHLA PHASE-1	TI-OKH062A-1	990	INDUSTRIAL	AMR	Functional	100%	13	0.55	3.97	0.24	5.64%
66 kv OKHLA PHASE 1 GRID	SOKH1116	11kv FDR O/G S/S NO.-2 OKHLA PH.-1	TI-OKH061A-1	990	INDUSTRIAL		Functional	100%	55	0.41			
66 kv OKHLA PHASE 1 GRID	SOKH1116	11kv FDR O/G S/S NO.-2 OKHLA PH.-1	TI-OKH061A-2	990	INDUSTRIAL		Functional	100%	27	0.37			
66 kv OKHLA PHASE 1 GRID	SOKH1104	11kv FDR O/G TO S/S NO.-3 OKHLA PHASE-1	TI-OKH062A-3	990	INDUSTRIAL		Functional	100%	43	0.32			
66 kv OKHLA PHASE 1 GRID	SOKH1104	11kv FDR O/G TO S/S NO.-3 OKHLA PHASE-1	TI-OKH062A-2	990	INDUSTRIAL		Functional	100%	20	0.32			
66 kv OKHLA PHASE 1 GRID	SOKH1116	11kv FDR O/G S/S NO.-2 OKHLA PH.-1	TI-OKH070A-2	990	INDUSTRIAL		Functional	100%	8	0.30			
66 kv OKHLA PHASE 1 GRID	SOKH1122	11kv FDR S/S NO.-6	TI-OKH065A-1	990	INDUSTRIAL		Functional	100%	33	0.28			
66 kv OKHLA PHASE 1 GRID	SOKH1115	11kv FDR O/G TO S/S NO.-C OKHLA PH.-1	TI-OKH069A-2	990	INDUSTRIAL		Functional	100%	8	0.28			
66 kv OKHLA PHASE 1 GRID	SOKH1115	11kv FDR O/G TO S/S NO.-C OKHLA PH.-1	TI-OKH068A-2	990	INDUSTRIAL		Functional	100%	17	0.27			
66 kv OKHLA PHASE 1 GRID	SOKH1115	11kv FDR O/G TO S/S NO.-C OKHLA PH.-1	TI-OKH068A-1	630	INDUSTRIAL		Functional	100%	40	0.25			
66 kv OKHLA PHASE 1 GRID	SOKH1116	11kv FDR O/G S/S NO.-2 OKHLA PH.-1	TI-OKH070A-1	990	INDUSTRIAL		Functional	100%	28	0.24			
66 kv OKHLA PHASE 1 GRID	SOKH1122	11kv FDR S/S NO.-6	TI-OKH065A-2	990	INDUSTRIAL		Functional	100%	25	0.22			
66 kv OKHLA PHASE 1 GRID	SOKH1115	11kv FDR O/G TO S/S NO.-C OKHLA PH.-1	TG-OKH061A-3	630	RESIDENTIAL		Functional	100%	0	0.22			
66 kv OKHLA PHASE 1 GRID	SOKH1115	11kv FDR O/G TO S/S NO.-C OKHLA PH.-1	TI-OKH069A-1	990	INDUSTRIAL		Functional	100%	50	0.16			
33 kv ALAKNANDA GRID	SALKN102	11kv FDR O/G TO DDA JANTA FLATS KALKAJI	TI-OKH027A-2	1500	RESIDENTIAL		Functional	100%	147	0.74	4.07	0.19	4.37%
33 kv ALAKNANDA GRID	SALKN102	11kv FDR O/G TO DDA JANTA FLATS KALKAJI	TI-OKH027A-1	1500	RESIDENTIAL		Functional	100%	2229	0.67			
33 kv ALAKNANDA GRID	SALKN102	11kv FDR O/G TO DDA JANTA FLATS KALKAJI	TG-OKH018A-1	990	RESIDENTIAL		Functional	100%	714	0.62			
33 kv ALAKNANDA GRID	SALKN125	11kv FDR O/G SSTN. NO.-1, NARMADA APPARTMENT	TG-OKH208A-1	990	COMMERCIAL		Functional	100%	167	0.50			
33 kv ALAKNANDA GRID	SALKN107	11kv FDR O/G TO KAVERI APPARTMENT	TG-OKH014A-1	630	Commercial		Functional	100%	657	0.39			
33 kv ALAKNANDA GRID	SALKN102	11kv FDR O/G TO DDA JANTA FLATS KALKAJI	TI-OKH002A-2	990	Commercial		Functional	100%	195	0.28			
33 kv ALAKNANDA GRID	SALKN125	11kv FDR O/G SSTN. NO.-1, NARMADA APPARTMENT	TG-OKH072A-1	630	RESIDENTIAL		Functional	100%	184	0.26			
220kv OKHLA TRANSCO GRID SST	TDOG108	11kv FDR TARA APPARTMENT	TI-OKH012A-1	990	Commercial		Functional	100%	275	0.21			
33 kv ALAKNANDA GRID	SALKN125	11kv FDR O/G SSTN. NO.-1, NARMADA APPARTMENT	TI-OKH028A-1	630	RESIDENTIAL		Functional	100%	262	0.13			
33 kv ALAKNANDA GRID	SALKN102	11kv FDR O/G TO DDA JANTA FLATS KALKAJI	TI-OKH002A-1	630	Commercial		Functional	100%	187	0.11			
33 kv ALAKNANDA GRID	SALKN107	11kv FDR O/G TO KAVERI APPARTMENT	TG-OKH051A-1	630	RESIDENTIAL		Functional	100%	95	0.10			
33 kv ALAKNANDA GRID	SALKN107	11kv FDR O/G TO KAVERI APPARTMENT	TI-OKH054A-2	400	Commercial		Functional	100%	3	0.10			
33 kv ALAKNANDA GRID	SALKN107	11kv FDR O/G TO KAVERI APPARTMENT	TG-OKH051A-2	630	RESIDENTIAL		Functional	100%	25	0.08			
33 kv ALAKNANDA GRID	SALKN107	11kv FDR O/G TO KAVERI APPARTMENT	TI-OKH054A-1	400	RESIDENTIAL		Functional	100%	28	0.07			
66 kv OKHLA PHASE 1 GRID	SOKH1136	11kv FDR O/G VILLAGE TEHKHAND	TG-OKH071A-1	990	RESIDENTIAL		Functional	100%	307	0.90	4.01	0.52	11.43%
66 kv OKHLA PHASE 1 GRID	SOKH1103	11kv FDR O/G S/S NO.-1 F-BLOCK OKHLA PH.-1	TI-OKH178A-1	990	INDUSTRIAL		Functional	100%	411	0.82			
66 kv OKHLA PHASE 1 GRID	SOKH1136	11kv FDR O/G VILLAGE TEHKHAND	TG-OKH098A-1	990	RESIDENTIAL		Functional	100%	1130	0.79			
66 kv OKHLA PHASE 1 GRID	SOKH1123	11kv FDR S/S NO.-4	TI-OKH063A-2	990	RESIDENTIAL	AMR	Functional	100%	36	0.53			
66 kv OKHLA PHASE 1 GRID	SOKH1136	11kv FDR O/G VILLAGE TEHKHAND	TG-OKH098A-2	630	RESIDENTIAL		Functional	100%	0	0.52			
66 kv OKHLA PHASE 1 GRID	SOKH1136	11kv FDR O/G VILLAGE TEHKHAND	TG-OKH071A-2	630	RESIDENTIAL		Functional	100%	749	0.46			

66 kV OKHLA PHASE 1 GRID	SOKH1123	11kV FDR S/S NO.-4	TI-OKH063A-1	990	RESIDENTIAL		Functional	100%	55	0.42			
66 kV OKHLA PHASE 1 GRID	SOKH1104	11kV FDR O/G TO S/S NO.-3 OKHLA PHASE-1	TP-OKH179A-1	400	RESIDENTIAL		Functional	100%	3	0.08			
66 kV OKHLA PHASE 1 GRID	SOKH1123	11kV FDR S/S NO.-4	TP-OKH187A-1	100	RESIDENTIAL		Functional	100%	1	0.02			
33 kV ALAKNANDA GRID	SALKN124	11kV FDR O/G GALI NO.-16, GOVIND PURI (TINWALA)	TG-GK2009A-2	990	MIXED		Functional	100%	532	0.60	2.58	0.17	6.29%
220kV OKHLA TRANSCO GRID SST	TDTOG104	11kV FDR GIRI NAGAR NO.-2(T-camp B)	TG-GK2039A-1	630	MIXED		Functional	100%	767	0.56			
220kV OKHLA TRANSCO GRID SST	TDTOG102	11kV FDR GIRI NAGAR NO.-1	TG-GK2144A-1	630	RESIDENTIAL		Functional	100%	784	0.55			
33 kV ALAKNANDA GRID	SALKN124	11kV FDR O/G GALI NO.-16, GOVIND PURI (TINWALA)	TG-GK2009A-1	990	MIXED		Functional	100%	794	0.51			
220kV OKHLA TRANSCO GRID SST	TDTOG104	11kV FDR GIRI NAGAR NO.-2(T-camp B)	TI-GK2041A-1	630	MIXED		Functional	100%	246	0.31			
220kV OKHLA TRANSCO GRID SST	TDTOG104	11kV FDR GIRI NAGAR NO.-2(T-camp B)	TI-GK2041A-2	400	MIXED		Functional	100%	589	0.21			
220kV OKHLA TRANSCO GRID SST	TDTOG102	11kV FDR GIRI NAGAR NO.-1	TP-GK2040A-1	100	MIXED		Functional	100%	1	0.01			
66 kV BATRA GRID	SBTRA111	11kV FDR O/G TARA APPARTMENT	TG-OKH057A-2	1600	RESIDENTIAL		Functional	100%	0	1.01	15.54	0.23	1.46%
220kV OKHLA TRANSCO GRID SST	TDTOG105	11kV FDR ALAKNANDA VIA TA	TK-OKH020A-3	990	RESIDENTIAL		Functional	100%	889	0.93			
33 kV TUGHLAKBAD GRID	STLBD114	11kV FDR S/S NO.-1, TUGLAKABAD EXTN.	TK-OKH015A-2	990	RESIDENTIAL	AMR	Functional	100%	753	0.90			
33 kV TUGHLAKBAD GRID	STLBD114	11kV FDR S/S NO.-1, TUGLAKABAD EXTN.	TK-OKH015A-3	990	RESIDENTIAL	AMR	Functional	100%	668	0.84			
33 kV TUGHLAKBAD GRID	STLBD111	11kV FDR TUGLAKABAD EXTN.	TI-OKH041A-1	990	RESIDENTIAL		Functional	100%	1281	0.80			
66 kV BATRA GRID	SBTRA127	11kV FDR O/G GALI NO 29 TUGHLAKABAD EXTN	TG-OKH021A-2	990	Commercial	AMR	Functional	100%	954	0.71			
220kV OKHLA TRANSCO GRID SST	TDTOG107	11kV FDR POKET A-8 KALKAJI EXTN.	TG-OKH076A-1	990	RESIDENTIAL		Functional	100%	1901	0.70			
220kV OKHLA TRANSCO GRID SST	TDTOG107	11kV FDR POKET A-8 KALKAJI EXTN.	TG-OKH194A-1	990	RESIDENTIAL		Functional	100%	558	0.67			
220kV OKHLA TRANSCO GRID SST	TDTOG107	11kV FDR POKET A-8 KALKAJI EXTN.	TG-OKH022A-1	990	RESIDENTIAL		Functional	100%	875	0.66			
33 kV TUGHLAKBAD GRID	STLBD111	11kV FDR TUGLAKABAD EXTN.	TG-OKH025A-1	990	RESIDENTIAL		Functional	100%	1462	0.66			
66 kV BATRA GRID	SBTRA111	11kV FDR O/G TARA APPARTMENT	TG-OKH043A-2	990	RESIDENTIAL		Functional	100%	0	0.63			
33 kV TUGHLAKBAD GRID	STLBD114	11kV FDR S/S NO.-1, TUGLAKABAD EXTN.	TK-OKH015A-1	990	RESIDENTIAL	AMR	Functional	100%	430	0.61			
33 kV TUGHLAKBAD GRID	STLBD114	11kV FDR S/S NO.-1, TUGLAKABAD EXTN.	TK-OKH019A-1	990	RESIDENTIAL		Functional	100%	1277	0.57			
220kV OKHLA TRANSCO GRID SST	TDTOG105	11kV FDR ALAKNANDA VIA TA	TX-OKH073A-1	990	RESIDENTIAL		Functional	100%	1090	0.57			
66 kV BATRA GRID	SBTRA111	11kV FDR O/G TARA APPARTMENT	TG-OKH057A-1	990	RESIDENTIAL		Functional	100%	2152	0.54			
66 kV BATRA GRID	SBTRA111	11kV FDR O/G TARA APPARTMENT	TG-OKH043A-1	990	RESIDENTIAL		Functional	100%	2043	0.52			
220kV OKHLA TRANSCO GRID SST	TDTOG105	11kV FDR ALAKNANDA VIA TA	TG-OKH026A-1	990	RESIDENTIAL		Functional	100%	1296	0.51			
33 kV TUGHLAKBAD GRID	STLBD114	11kV FDR S/S NO.-1, TUGLAKABAD EXTN.	510DDK-OKH019A	990	RESIDENTIAL		Functional	100%	0	0.51			
220kV OKHLA TRANSCO GRID SST	TDTOG105	11kV FDR ALAKNANDA VIA TA	TK-OKH020A-2	990	RESIDENTIAL		Functional	100%	1764	0.51			
220kV OKHLA TRANSCO GRID SST	TDTOG105	11kV FDR ALAKNANDA VIA TA	TG-OKH026A-2	630	RESIDENTIAL		Functional	100%	0	0.47			
33 kV TUGHLAKBAD GRID	STLBD111	11kV FDR TUGLAKABAD EXTN.	TG-OKH025A-2	630	RESIDENTIAL		Functional	100%	0	0.43			
66 kV BATRA GRID	SBTRA127	11kV FDR O/G GALI NO 29 TUGHLAKABAD EXTN	TG-OKH021A-1	990	MIXED	AMR	Functional	100%	549	0.39			
33 kV TUGHLAKBAD GRID	STLBD114	11kV FDR S/S NO.-1, TUGLAKABAD EXTN.	TG-OKH044A-2	630	RESIDENTIAL		Functional	100%	848	0.38			
220kV OKHLA TRANSCO GRID SST	TDTOG107	11kV FDR POKET A-8 KALKAJI EXTN.	TG-OKH022A-2	630	RESIDENTIAL		Functional	100%	0	0.38			
220kV OKHLA TRANSCO GRID SST	TDTOG105	11kV FDR ALAKNANDA VIA TA	TK-OKH020A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.34			
33 kV TUGHLAKBAD GRID	STLBD114	11kV FDR S/S NO.-1, TUGLAKABAD EXTN.	TG-OKH044A-1	400	RESIDENTIAL		Functional	100%	212	0.20			
220kV OKHLA TRANSCO GRID SST	TDTOG107	11kV FDR POKET A-8 KALKAJI EXTN.	TG-OKH076A-2	400	RESIDENTIAL		Functional	100%	0	0.16			

33 kV TUGHLAKBAD GRID	STLBD111	11kV FDR TUGHLAKBAD EXTN.	510DDK-OKH041A	630	RESIDENTIAL		Functional	100%	0	0.14			
33 kV TUGHLAKBAD GRID	STLBD111	11kV FDR TUGHLAKBAD EXTN.	TG-OKH056A-1	400	Commercial		Functional	100%	7	0.05			
33 kV TUGHLAKBAD GRID	STLBD104	11kV FDR O/G D.M.S TRUST	TG-KPR202A-1	990	RESIDENTIAL		Functional	100%	197	0.77	2.40	0.12	4.74%
33 kV TUGHLAKBAD GRID	STLBD104	11kV FDR O/G D.M.S TRUST	TP-KPR066A-1	990	RESIDENTIAL		Functional	100%	1824	0.66			
33 kV TUGHLAKBAD GRID	STLBD104	11kV FDR O/G D.M.S TRUST	TG-KPR065A-1	990	RESIDENTIAL		Functional	100%	1098	0.60			
33 kV TUGHLAKBAD GRID	STLBD104	11kV FDR O/G D.M.S TRUST	TG-KPR071A-1	630	RESIDENTIAL		Functional	100%	175	0.46			
33 kV TUGHLAKBAD GRID	STLBD104	11kV FDR O/G D.M.S TRUST	511DVR-KPR284A	250	RESIDENTIAL		Functional	100%	0	0.03			
66kV SANGAM VIHAR GRID	SSNGM127	11kV FDR STATION SANGWAN DP	TG-KPR189A-1	990	RESIDENTIAL		Functional	100%	124	0.80	2.99	0.02	0.66%
66kV SANGAM VIHAR GRID	SSNGM127	11kV FDR STATION SANGWAN DP	TG-KPR145A-1	990	RESIDENTIAL		Functional	100%	1031	0.68			
66 kV BATRA GRID	SBTRA114	11kV FDR O/G B-BLOCK DURGA VIHAR	TI-KPR070A-1	630	RESIDENTIAL		Functional	100%	205	0.57			
66kV SANGAM VIHAR GRID	SSNGM127	11kV FDR STATION SANGWAN DP	TG-KPR078A-1	990	RESIDENTIAL		Functional	100%	56	0.56			
66kV SANGAM VIHAR GRID	SSNGM128	11kV FDR STATION DEVLJI JOHAR	TP-KPR142A-1	400	RESIDENTIAL		Functional	100%	68	0.31			
33 kV TUGHLAKBAD GRID	STLBD104	11kV FDR O/G D.M.S TRUST	511DVR-KPR288A	250	MIXED		Functional	100%	0	0.10			
66 kV BATRA GRID	SBTRA125	11kV FDR O/G RMU L-1A SANGAM VIHAR	TP-KPR072A-1	100	RESIDENTIAL		Functional	100%	2346	0.00			
66kV SANGAM VIHAR GRID	SSNGM145	11kV FDR OG TO JHEEL DP NEAR MANDIR	KP-HVD069A-1	5550	RESIDENTIAL		Functional	100%	6274	2.12	12.39	0.83	6.28%
66 kV BATRA GRID	SBTRA114	11kV FDR O/G B-BLOCK DURGA VIHAR	KP-HVD051A-1	7630	RESIDENTIAL		Functional	100%	5454	2.08			
66kV SANGAM VIHAR GRID	SSNGM128	11kV FDR STATION DEVLJI JOHAR	KP-HVD101A-1	4125	RESIDENTIAL		Functional	100%	1838	1.69			
66 kV I.G.N.O.U GRID	SIGNO104	11kV FDR IGNOU CAMPUS S/S NO.-3 FDR.-1 (GALI NO.-5, SANGAM VIHAR)	KP-HVD050A-1	4475	RESIDENTIAL		Functional	100%	10	1.60			
66kV SANGAM VIHAR GRID	SSNGM145	11kV FDR OG TO JHEEL DP NEAR MANDIR	KP-HVD046A-1	3275	RESIDENTIAL		Functional	100%	475	1.27			
66 kV BATRA GRID	SBTRA125	11kV FDR O/G RMU L-1A SANGAM VIHAR	KP-HVD052A-1	2450	RESIDENTIAL		Functional	100%	18	1.11			
66 kV BATRA GRID	SBTRA126	11kV FDR O/G RMU L-15 SANGAM VIHAR	511DVR-HVD048A	3250	RESIDENTIAL		Functional	100%	1647	0.93			
66 kV I.G.N.O.U GRID	SIGNO104	11kV FDR IGNOU CAMPUS S/S NO.-3 FDR.-1 (GALI NO.-5, SANGAM VIHAR)	KP-HVD047A-1	2050	RESIDENTIAL		Functional	100%	36	0.66			
66kV SANGAM VIHAR GRID	SSNGM126	11kV FDR OG TO L-BLOCK SAINI WALA	KP-HVD044A-1	2525	RESIDENTIAL		Functional	100%	3192	0.62			
66 kV BATRA GRID	SBTRA122	11kV FDR O/G D-BLOCK SANGAM VIHAR	TG-KPR230B-1	990	RESIDENTIAL		Functional	100%	0	0.36			
66kV SANGAM VIHAR GRID	SSNGM126	11kV FDR OG TO L-BLOCK SAINI WALA	TG-KPR230A-1	990	RESIDENTIAL		Functional	100%	32	0.18			
66 kV I.G.N.O.U GRID	SIGNO104	11kV FDR IGNOU CAMPUS S/S NO.-3 FDR.-1 (GALI NO.-5, SANGAM VIHAR)	KP-HVD049A-1	1130	RESIDENTIAL		Functional	100%	491	0.17			
66 kV I.G.N.O.U GRID	SIGNO104	11kV FDR IGNOU CAMPUS S/S NO.-3 FDR.-1 (GALI NO.-5, SANGAM VIHAR)	511DVR-HVD079A	100	MIXED		Functional	100%	0	0.10			
66 kV I.G.N.O.U GRID	SIGNO104	11kV FDR IGNOU CAMPUS S/S NO.-3 FDR.-1 (GALI NO.-5, SANGAM VIHAR)	TP-KPR235A-1	100	RESIDENTIAL		Functional	100%	245	0.08			
66kV SANGAM VIHAR GRID	SSNGM128	11kV FDR STATION DEVLJI JOHAR	KP-HVD054A-1	100	RESIDENTIAL		Functional	100%	1	0.08			
66 kV BATRA GRID	SBTRA125	11kV FDR O/G RMU L-1A SANGAM VIHAR	TP-HVD086A-1	100	RESIDENTIAL		Functional	100%	1	0.07			
66kV SANGAM VIHAR GRID	SSNGM127	11kV FDR STATION SANGWAN DP	TP-HVD080A-1	100	RESIDENTIAL		Functional	100%	1	0.05			
66 kV I.G.N.O.U GRID	SIGNO104	11kV FDR IGNOU CAMPUS S/S NO.-3 FDR.-1 (GALI NO.-5, SANGAM VIHAR)	TP-KPR234A-1	100	RESIDENTIAL		Functional	100%	3	0.04			
66 kV I.G.N.O.U GRID	SIGNO104	11kV FDR IGNOU CAMPUS S/S NO.-3 FDR.-1 (GALI NO.-5, SANGAM VIHAR)	TG-HVD049A-2	100	RESIDENTIAL		Functional	100%	0	0.01			
66kV SANGAM VIHAR GRID	SSNGM126	11kV FDR OG TO L-BLOCK SAINI WALA	KP-HVD043A-1	6765	RESIDENTIAL		Functional	100%	690	2.07	4.71	0.23	4.62%
66 kV BATRA GRID	SBTRA124	11kV FDR O/G TO TIN WAKA S/STN. C-BLOCK SANGAM VHR.	KP-HVD042A-1	5700	RESIDENTIAL		Functional	100%	3496	1.98			
66kV SANGAM VIHAR GRID	SSNGM126	11kV FDR OG TO L-BLOCK SAINI WALA	TG-KPR236A-1	630	COMMERCIAL		Functional	100%	449	0.45			
66kV SANGAM VIHAR GRID	SSNGM145	11kV FDR OG TO JHEEL DP NEAR MANDIR	TG-KPR170A-1	630	RESIDENTIAL		Functional	100%	1001	0.41			
66kV SANGAM VIHAR GRID	SSNGM126	11kV FDR OG TO L-BLOCK SAINI WALA	511DVR-KPR209A	100	RESIDENTIAL		Functional	100%	2608	0.03			
66kV SANGAM VIHAR GRID	SSNGM145	11kV FDR OG TO JHEEL DP NEAR MANDIR	TP-KPR225A-1	100	RESIDENTIAL		Functional	100%	5	0.00			
66 kV BATRA GRID	SBTRA106	11kV FDR O/G DEVLJI EXTENSION	KP-HVD099A-1	3305	RESIDENTIAL		Functional	100%	203	1.04	3.59	0.24	6.28%
66 kV BATRA GRID	SBTRA114	11kV FDR O/G B-BLOCK DURGA VIHAR	KP-HVD003A-1	2790	RESIDENTIAL		Functional	100%	730	0.81			
66 kV BATRA GRID	SBTRA125	11kV FDR O/G RMU L-1A SANGAM VIHAR	KP-HVD053A-1	1425	RESIDENTIAL		Functional	100%	384	0.67			
66kV SANGAM VIHAR GRID	SSNGM128	11kV FDR STATION DEVLJI JOHAR	TG-KPR188A-1	990	RESIDENTIAL		Functional	100%	17	0.65			
66 kV BATRA GRID	SBTRA106	11kV FDR O/G DEVLJI EXTENSION	TI-KPR187A-1	630	RESIDENTIAL		Functional	100%	909	0.35			
66 kV BATRA GRID	SBTRA104	11kV FDR O/G D.D.A TIGRI	TG-KPR095A-1	630	RESIDENTIAL		Functional	100%	3000	0.28			
66 kV BATRA GRID	SBTRA106	11kV FDR O/G DEVLJI EXTENSION	TP-HVD083A-1	100	RESIDENTIAL		Functional	100%	3	0.04			

33 kV TUGHLAKBAD GRID	STLBD131	11 kV FDR O/G, RMU IN GRID	TI-KPR038A-2	990	RESIDENTIAL		Functional	100%	167	1.04	20.72	0.19	0.93%			
33 kV PUSHP VIHAR GRID	SPUSP120	11kV FDR O/G S/S NO.5 DAKSHINPURI	TG-KPR143A-1	990	MIXED		Functional	100%	1545	0.96						
33 kV PUSHP VIHAR GRID	SPUSP121	11kV FDR O/G MAITRIKA ASHRAM:PL	TK-KPR042A-2	990	MIXED		Functional	100%	2048	0.80						
33 kV PUSHP VIHAR GRID	SPUSP121	11kV FDR O/G MAITRIKA ASHRAM:PL	TK-KPR042A-1	990	MIXED		Functional	100%	1014	0.76						
33 kV D.C.SAKET GRID	SSAKT105	11kV FDR L.S.C NO.-1 MADANGIR	TG-KPR075A-1	990	RESIDENTIAL		Functional	100%	1879	0.75						
66 kV BATRA GRID	SBTRA110	11kV FDR O/G S/S NO.-3, DAKSHINPURI VIA BOOSTER PUMP	TI-KPR039A-1	990	RESIDENTIAL		Functional	100%	2252	0.74						
33 kV TUGHLAKBAD GRID	STLBD121	11kV FDR DAKSHIN PURI S/S NO.-II (NEW)	TG-KPR044A-1	990	MIXED		Functional	100%	911	0.74						
66 kV BATRA GRID	SBTRA110	11kV FDR O/G S/S NO.-3, DAKSHINPURI VIA BOOSTER PUMP	TI-KPR039A-2	990	RESIDENTIAL		Functional	100%	508	0.70						
33 kV D.C.SAKET GRID	SSAKT107	11kV FDR MADANGIR S/S NO.-1	TG-KPR222A-1	990	RESIDENTIAL		Functional	100%	3	0.70						
33 kV PUSHP VIHAR GRID	SPUSP120	11kV FDR O/G S/S NO.5 DAKSHINPURI	TI-KPR045A-1	1500	RESIDENTIAL		Functional	100%	1858	0.70						
33 kV PUSHP VIHAR GRID	SPUSP122	11kV FDR O/G S/S NO.4 DAKSHINPURI	TG-KPR158A-1	990	RESIDENTIAL		Functional	100%	1452	0.69						
33 kV D.C.SAKET GRID	SSAKT105	11kV FDR L.S.C NO.-1 MADANGIR	TG-KPR136A-1	630	RESIDENTIAL		Functional	100%	1345	0.67						
66 kV BATRA GRID	SBTRA119	11kV FDR O/G B-II/1, MADANGIR	TG-KPR164A-1	990	RESIDENTIAL		Functional	100%	1010	0.65						
66 kV BATRA GRID	SBTRA113	11kV FDR O/G DAKSHIN PURI S/S NO.-2	TI-KPR038A-1	990	RESIDENTIAL		Functional	100%	2273	0.64						
33 kV TUGHLAKBAD GRID	STLBD121	11kV FDR DAKSHIN PURI S/S NO.-II (NEW)	TP-KPR137A-1	630	MIXED		Functional	100%	1298	0.63						
33 kV TUGHLAKBAD GRID	STLBD121	11kV FDR DAKSHIN PURI S/S NO.-II (NEW)	TG-KPR077A-1	990	MIXED		Functional	100%	1741	0.61						
33 kV PUSHP VIHAR GRID	SPUSP121	11kV FDR O/G MAITRIKA ASHRAM:PL	TI-KPR043A-1	990	MIXED		Functional	100%	1003	0.61						
66 kV BATRA GRID	SBTRA119	11kV FDR O/G B-II/1, MADANGIR	TG-KPR076A-3	630	RESIDENTIAL		Functional	100%	0	0.59						
33 kV PUSHP VIHAR GRID	SPUSP120	11kV FDR O/G S/S NO.5 DAKSHINPURI	TG-KPR154A-1	990	RESIDENTIAL		Functional	100%	1005	0.58						
33 kV PUSHP VIHAR GRID	SPUSP120	11kV FDR O/G S/S NO.5 DAKSHINPURI	TK-KPR041A-3	990	RESIDENTIAL		Functional	100%	2110	0.56						
33 kV PUSHP VIHAR GRID	SPUSP122	11kV FDR O/G S/S NO.4 DAKSHINPURI	TK-KPR040A-2	990	RESIDENTIAL		Functional	100%	807	0.53						
33 kV TUGHLAKBAD GRID	STLBD121	11kV FDR DAKSHIN PURI S/S NO.-II (NEW)	TG-KPR077A-2	630	RESIDENTIAL		Functional	100%	0	0.53						
33 kV PUSHP VIHAR GRID	SPUSP120	11kV FDR O/G S/S NO.5 DAKSHINPURI	TI-KPR046A-1	630	RESIDENTIAL		Functional	100%	456	0.51						
33 kV PUSHP VIHAR GRID	SPUSP120	11kV FDR O/G S/S NO.5 DAKSHINPURI	TG-KPR041A-4	630	RESIDENTIAL		Functional	100%	0	0.50						
66 kV BATRA GRID	SBTRA119	11kV FDR O/G B-II/1, MADANGIR	TG-KPR076A-1	630	RESIDENTIAL		Functional	100%	918	0.49						
33 kV PUSHP VIHAR GRID	SPUSP122	11kV FDR O/G S/S NO.4 DAKSHINPURI	TK-KPR040A-1	990	RESIDENTIAL		Functional	100%	1344	0.46						
33 kV PUSHP VIHAR GRID	SPUSP121	11kV FDR O/G MAITRIKA ASHRAM:PL	TG-KPR155A-1	990	RESIDENTIAL		Functional	100%	1014	0.45						
33 kV PUSHP VIHAR GRID	SPUSP120	11kV FDR O/G S/S NO.5 DAKSHINPURI	TK-KPR041A-2	630	RESIDENTIAL		Functional	100%	598	0.44						
33 kV TUGHLAKBAD GRID	STLBD121	11kV FDR DAKSHIN PURI S/S NO.-II (NEW)	TG-KPR044A-2	630	MIXED		Functional	100%	916	0.43						
66 kV BATRA GRID	SBTRA112	11kV FDR O/G S/S NO.-7, DAKSHIN PURI	TI-KPR043A-2	750	MIXED		Functional	100%	705	0.43						
33 kV PUSHP VIHAR GRID	SPUSP120	11kV FDR O/G S/S NO.5 DAKSHINPURI	TK-KPR041A-1	630	RESIDENTIAL		Functional	100%	954	0.39						
66 kV BATRA GRID	SBTRA119	11kV FDR O/G B-II/1, MADANGIR	TG-KPR076A-2	630	RESIDENTIAL		Functional	100%	1003	0.34						
33 kV D.C.SAKET GRID	SSAKT105	11kV FDR L.S.C NO.-1 MADANGIR	TG-KPR075A-2	400	RESIDENTIAL		Functional	100%	0	0.30						
33 kV PUSHP VIHAR GRID	SPUSP120	11kV FDR O/G S/S NO.5 DAKSHINPURI	TP-KPR243A-1	400	RESIDENTIAL		Functional	100%	253	0.28						
33 kV PUSHP VIHAR GRID	SPUSP121	11kV FDR O/G MAITRIKA ASHRAM:PL	TG-KPR155B-1	990	RESIDENTIAL		Functional	100%	0	0.25						
66 kV BATRA GRID	SBTRA122	11kV FDR O/G TO S/S NO.-5 DAKSHIN PURI	511KPR-KPR260A-	630	RESIDENTIAL		Functional	100%	239	0.25						
33 kV PUSHP VIHAR GRID	SPUSP120	11kV FDR O/G S/S NO.5 DAKSHINPURI	TI-KPR046A-2	630	RESIDENTIAL		Functional	100%	445	0.20						
66 kV BATRA GRID	SBTRA108	11kV FDR O/G TUGLAKABAD INST. AREA	TI-KPR058A-1	1600	RESIDENTIAL		Functional	100%	1619	1.07				2.21	0.03	1.18%
66 kV BATRA GRID	SBTRA108	11kV FDR O/G TUGLAKABAD INST. AREA	TI-KPR058A-2	990	RESIDENTIAL		Functional	100%	844	0.44						
66 kV MALVIYA NAGAR GRID	SMALV127	11kV FDR O/G MCD SCHOOL ROAD KHANPUR	511KPR-KPR257A-	400	RESIDENTIAL	AMR	Functional	100%	8	0.37						
66 kV MALVIYA NAGAR GRID	SMALV127	11kV FDR O/G MCD SCHOOL ROAD KHANPUR	TG-KPR093A-1	990	RESIDENTIAL		Functional	100%	32	0.35						
66 kV BATRA GRID	SBTRA113	11kV FDR O/G DAKSHIN PURI S/S NO.-2	TI-KPR048A-2	990	MIXED		Functional	100%	160	0.79	5.17	0.53	9.26%			
66 kV BATRA GRID	SBTRA113	11kV FDR O/G DAKSHIN PURI S/S NO.-2	TG-KPR138A-1	990	MIXED		Functional	100%	722	0.79						
66 kV BATRA GRID	SBTRA113	11kV FDR O/G DAKSHIN PURI S/S NO.-2	TI-KPR171A-2	990	RESIDENTIAL		Functional	100%	1103	0.78						
66 kV BATRA GRID	SBTRA119	11kV FDR O/G B-II/1, MADANGIR	TG-KPR172A-1	990	RESIDENTIAL		Functional	100%	839	0.67						
66 kV BATRA GRID	SBTRA105	11kV FDR O/G RMU AT BATRA GRID	TG-KPR180A-1	990	RESIDENTIAL		Functional	100%	459	0.63						
66 kV BATRA GRID	SBTRA113	11kV FDR O/G DAKSHIN PURI S/S NO.-2	TI-KPR048A-1	990	RESIDENTIAL		Functional	100%	2874	0.48						

66 kv MALVIYA NAGAR GRID	SMALV102	11kv FDR KHANPUR COMP. CENTER	TI-KPR056A-1	990	MIXED		Functional	100%	110	0.45			
66 kv BATRA GRID	SBTRA105	11kv FDR O/G RMU AT BATRA GRID	TI-KPR056A-2	990	MIXED		Functional	100%	469	0.44			
66 kv BATRA GRID	SBTRA113	11kv FDR O/G DAKSHIN PURI S/S NO.-2	TG-KPR171A-3	630	RESIDENTIAL		Functional	100%	0	0.36			
66 kv BATRA GRID	SBTRA113	11kv FDR O/G DAKSHIN PURI S/S NO.-2	TG-KPR171A-1	630	RESIDENTIAL		Functional	100%	185	0.30			
33 kv TUGHLAKBAD GRID	STLBD120	11kv FDR TIGRI J J KHANPUR	KP-HVD010A-1	2475	RESIDENTIAL		Functional	100%	383	1.16	7.60	0.58	7.15%
66 kv BATRA GRID	SBTRA105	11kv FDR O/G RMU AT BATRA GRID	TG-KPR057A-2	990	RESIDENTIAL		Functional	100%	6485	0.89			
66 kv MALVIYA NAGAR GRID	SMALV127	11kv FDR O/G MCD SCHOOL ROAD KHANPUR	TG-KPR059A-1	990	RESIDENTIAL	AMR	Functional	100%	477	0.80			
66 kv BATRA GRID	SBTRA105	11kv FDR O/G RMU AT BATRA GRID	TG-KPR057A-1	630	RESIDENTIAL		Functional	100%	71	0.74			
66 kv BATRA GRID	SBTRA118	11kv FDR O/G KHANPUR (KHATTA WALA)	TG-KPR139A-1	990	RESIDENTIAL		Functional	100%	62	0.72			
66 kv MALVIYA NAGAR GRID	SMALV119	11kv FDR O/G J J KHANPUR	TI-KPR073A-2	990	RESIDENTIAL		Functional	100%	106	0.67			
33 kv TUGHLAKBAD GRID	STLBD120	11kv FDR TIGRI J J KHANPUR	TG-KPR052A-2	630	RESIDENTIAL		Functional	100%	198	0.53			
66 kv MALVIYA NAGAR GRID	SMALV119	11kv FDR O/G J J KHANPUR	511KPR-KPR197A-	630	RESIDENTIAL		Functional	100%	9	0.53			
66 kv MALVIYA NAGAR GRID	SMALV119	11kv FDR O/G J J KHANPUR	511KPR-KPR197A-	630	RESIDENTIAL		Functional	100%	0	0.45			
66 kv MALVIYA NAGAR GRID	SMALV119	11kv FDR O/G J J KHANPUR	TI-KPR073A-1	990	RESIDENTIAL		Functional	100%	504	0.42			
33 kv TUGHLAKBAD GRID	STLBD120	11kv FDR TIGRI J J KHANPUR	TG-KPR052A-1	990	RESIDENTIAL		Functional	100%	66	0.41			
66 kv MALVIYA NAGAR GRID	SMALV127	11kv FDR O/G MCD SCHOOL ROAD KHANPUR	TG-KPR059A-2	400	RESIDENTIAL		Functional	100%	0	0.38			
66 kv MALVIYA NAGAR GRID	SMALV119	11kv FDR O/G J J KHANPUR	TG-KPR034A-1	630	RESIDENTIAL		Functional	100%	128	0.27			
66 kv BATRA GRID	SBTRA108	11kv FDR O/G TUGLAKABAD INST. AREA	511KPR-KPR282A-	630	RESIDENTIAL		Functional	100%	180	0.20			
33 kv TUGHLAKBAD GRID	STLBD120	11kv FDR TIGRI J J KHANPUR	511KPR-KPR276A-	100	RESIDENTIAL		Functional	100%	2	0.01			
66 kv BATRA GRID	SBTRA118	11kv FDR O/G KHANPUR (KHATTA WALA)	TI-KPR110A-1	990	MIXED		Functional	100%	27	0.66	3.27	0.26	7.39%
66 kv BATRA GRID	SBTRA104	11kv FDR O/G D.D.A TIGRI	TG-KPR153A-1	990	MIXED	AMR	Functional	100%	41	0.60			
66 kv BATRA GRID	SBTRA104	11kv FDR O/G D.D.A TIGRI	TI-KPR053A-1	990	RESIDENTIAL		Functional	100%	195	0.54			
66 kv BATRA GRID	SBTRA104	11kv FDR O/G D.D.A TIGRI	TI-KPR053A-2	630	MIXED		Functional	100%	122	0.37			
66 kv BATRA GRID	SBTRA104	11kv FDR O/G D.D.A TIGRI	511KPR-KPR153A-	990	RESIDENTIAL	AMR	Functional	100%	0	0.35			
66 kv BATRA GRID	SBTRA104	11kv FDR O/G D.D.A TIGRI	KP-HVD011A-2	1030	RESIDENTIAL		Functional	100%	0	0.32			
66 kv BATRA GRID	SBTRA104	11kv FDR O/G D.D.A TIGRI	KP-HVD011A-1	612.5	RESIDENTIAL		Functional	100%	3303	0.31			
33 kv TUGHLAKBAD GRID	STLBD120	11kv FDR TIGRI J J KHANPUR	TG-KPR037A-1	400	RESIDENTIAL		Functional	100%	114	0.17			
33 kv TUGHLAKBAD GRID	STLBD127	11kv FDR O/G F-1 S.STN. NO.2 S. VIHAR (NEW)	511DSV-MOB001A	630	RESIDENTIAL		Functional	100%	0	0.11			
33 kv TUGHLAKBAD GRID	STLBD127	11kv FDR O/G F-1 S.STN. NO.2 S. VIHAR (NEW)	511DSV-MOB001A	990	RESIDENTIAL		Functional	100%	0	0.11			
66kv SANGAM VIHAR GRID	SSNGM129	11kv FDR STATION C-2 RAJU PARK	TG-KPR106A-1	990	RESIDENTIAL		Functional	100%	169	0.78	2.93	0.56	16.10%
66 kv BATRA GRID	SBTRA117	11kv FDR O/G A-BLOCK RAJU PARK	TP-KPR062A-1	990	MIXED		Functional	100%	258	0.74			
66kv SANGAM VIHAR GRID	SSNGM129	11kv FDR STATION C-2 RAJU PARK	TG-KPR106A-2	990	RESIDENTIAL		Functional	100%	427	0.69			
66kv SANGAM VIHAR GRID	SSNGM129	11kv FDR STATION C-2 RAJU PARK	KP-HVD001A-1	1475	RESIDENTIAL		Functional	100%	753	0.62			
66 kv BATRA GRID	SBTRA117	11kv FDR O/G A-BLOCK RAJU PARK	KP-HVD015A-1	2750	RESIDENTIAL		Functional	100%	174	0.40			
66kv SANGAM VIHAR GRID	SSNGM129	11kv FDR STATION C-2 RAJU PARK	TI-KPR124A-1	400	MIXED		Functional	100%	19	0.16			
66kv SANGAM VIHAR GRID	SSNGM129	11kv FDR STATION C-2 RAJU PARK	TI-KPR063A-1	630	RESIDENTIAL		Functional	100%	1704	0.10			
33 kv D.C.SAKET GRID	SSAKT110	11kv FDR DDA GALI NO.-20 MADANGIR	TG-KPR159A-1	990	RESIDENTIAL		Functional	100%	957	0.88	12.62	0.21	1.66%
33 kv D.C.SAKET GRID	SSAKT107	11kv FDR MADANGIR S/S NO.-1	TI-KPR030A-3	990	RESIDENTIAL		Functional	100%	886	0.84			
33 kv D.C.SAKET GRID	SSAKT107	11kv FDR MADANGIR S/S NO.-1	TG-KPR036A-1	990	RESIDENTIAL		Functional	100%	534	0.83			
33 kv D.C.SAKET GRID	SSAKT113	11kv FDR L.S.C NO-2 VIA SS NO-15	TP-KPR173A-1	990	RESIDENTIAL		Functional	100%	88	0.79			
33 kv D.C.SAKET GRID	SSAKT113	11kv FDR L.S.C NO-2 VIA SS NO-15	TG-KPR033A-2	990	RESIDENTIAL		Functional	100%	0	0.78			
66 kv BATRA GRID	SBTRA105	11kv FDR O/G RMU AT BATRA GRID	TG-KPR107A-1	990	MIXED		Functional	100%	1042	0.74			
66 kv BATRA GRID	SBTRA120	11kv FDR O/G TO E-1st MADANGIR PHASE-1(VIA C-BLOCK MCD SCHOOL) D.PURI	TI-KPR029A-1	990	RESIDENTIAL		Functional	100%	490	0.70			
33 kv D.C.SAKET GRID	SSAKT107	11kv FDR MADANGIR S/S NO.-1	TI-KPR030A-1	990	RESIDENTIAL		Functional	100%	425	0.67			
33 kv D.C.SAKET GRID	SSAKT110	11kv FDR DDA GALI NO.-20 MADANGIR	TG-KPR074A-1	990	MIXED		Functional	100%	1499	0.66			

66 kV BATRA GRID	SBTRA120	11kV FDR O/G TO E-1st MADANGIR PHASE-1(VIA C-BLOCK MCD SCHOOL) D.PURI	TG-KPR083A-1	990	RESIDENTIAL		Functional	100%	1385	0.66			
33 kV D.C.SAKET GRID	SSAKT110	11kV FDR DDA GALI NO.-20 MADANGIR	TK-KPR035A-2	990	RESIDENTIAL		Functional	100%	434	0.62			
33 kV D.C.SAKET GRID	SSAKT110	11kV FDR DDA GALI NO.-20 MADANGIR	TK-KPR035A-1	1600	RESIDENTIAL		Functional	100%	602	0.58			
33 kV D.C.SAKET GRID	SSAKT107	11kV FDR MADANGIR S/S NO.-1	TG-KPR036A-2	630	RESIDENTIAL		Functional	100%	0	0.55			
33 kV D.C.SAKET GRID	SSAKT113	11kV FDR L.S.C NO-2 VIA SS NO-15	TG-KPR033A-1	990	RESIDENTIAL		Functional	100%	1306	0.45			
33 kV D.C.SAKET GRID	SSAKT107	11kV FDR MADANGIR S/S NO.-1	TI-KPR030A-2	990	RESIDENTIAL		Functional	100%	383	0.43			
33 kV D.C.SAKET GRID	SSAKT113	11kV FDR L.S.C NO-2 VIA SS NO-15	TP-KPR032A-1	630	RESIDENTIAL		Functional	100%	78	0.43			
66 kV BATRA GRID	SBTRA120	11kV FDR O/G TO E-1st MADANGIR PHASE-1(VIA C-BLOCK MCD SCHOOL) D.PURI	TI-KPR029A-3	630	RESIDENTIAL		Functional	100%	518	0.42			
33 kV D.C.SAKET GRID	SSAKT110	11kV FDR DDA GALI NO.-20 MADANGIR	TG-KPR074A-2	990	MIXED		Functional	100%	5624	0.39			
66 kV BATRA GRID	SBTRA120	11kV FDR O/G TO E-1st MADANGIR PHASE-1(VIA C-BLOCK MCD SCHOOL) D.PURI	TI-KPR029A-2	990	RESIDENTIAL		Functional	100%	1032	0.39			
33 kV D.C.SAKET GRID	SSAKT110	11kV FDR DDA GALI NO.-20 MADANGIR	TG-KPR241A-1	990	RESIDENTIAL		Functional	100%	185	0.30			
33 kV D.C.SAKET GRID	SSAKT110	11kV FDR DDA GALI NO.-20 MADANGIR	511KPR-KPR261A-	630	RESIDENTIAL		Functional	100%	133	0.30			
33 kV D.C.SAKET GRID	SSAKT113	11kV FDR L.S.C NO-2 VIA SS NO-15	TG-KPR179A-1	630	RESIDENTIAL		Functional	100%	139	0.12			
33 kV D.C.SAKET GRID	SSAKT113	11kV FDR L.S.C NO-2 VIA SS NO-15	TI-KPR031A-2	990	RESIDENTIAL		Functional	100%	22	0.12			
33 kV D.C.SAKET GRID	SSAKT110	11kV FDR DDA GALI NO.-20 MADANGIR	511KPR-KPR261A-	630	RESIDENTIAL		Functional	100%	0	0.11			
33 kV D.C.SAKET GRID	SSAKT113	11kV FDR L.S.C NO-2 VIA SS NO-15	TI-KPR031A-1	990	RESIDENTIAL		Functional	100%	72	0.10			
66 kV MALVIYA NAGAR GRID	SMALV127	11kV FDR O/G MCD SCHOOL ROAD KHANPUR	KP-HVD012A-1	1025	RESIDENTIAL		Functional	100%	130	1.45	7.45	1.27	14.61%
66 kV BATRA GRID	SBTRA102	11kV FDR O/G TIGRI KIOSK	TG-KPR207A-1	990	RESIDENTIAL		Functional	100%	1996	0.79			
66 kV BATRA GRID	SBTRA102	11kV FDR O/G TIGRI KIOSK	TP-KPR051A-1	990	RESIDENTIAL		Functional	100%	1008	0.77			
66 kV BATRA GRID	SBTRA102	11kV FDR O/G TIGRI KIOSK	TK-KPR047A-2	990	MIXED		Functional	100%	2775	0.65			
33 kV TUGHLAKBAD GRID	STLBD120	11kV FDR TIGRI J.J KHANPUR	TI-KPR191A-1	990	RESIDENTIAL		Functional	100%	118	0.59			
33 kV TUGHLAKBAD GRID	STLBD107	11 kV FDR O/G S/S-5, H-BLK. TIGRI	TG-KPR140A-1	630	MIXED		Functional	100%	1478	0.56			
33 kV TUGHLAKBAD GRID	STLBD120	11kV FDR TIGRI J.J KHANPUR	TI-KPR191A-2	990	RESIDENTIAL		Functional	100%	308	0.56			
33 kV TUGHLAKBAD GRID	STLBD107	11 kV FDR O/G S/S-5, H-BLK. TIGRI	TG-KPR050A-2	630	RESIDENTIAL		Functional	100%	1836	0.55			
33 kV TUGHLAKBAD GRID	STLBD107	11 kV FDR O/G S/S-5, H-BLK. TIGRI	TG-KPR194A-1	630	RESIDENTIAL		Functional	100%	38	0.55			
33 kV TUGHLAKBAD GRID	STLBD120	11kV FDR TIGRI J.J KHANPUR	TI-KPR191A-3	630	RESIDENTIAL		Functional	100%	2329	0.49			
33 kV TUGHLAKBAD GRID	STLBD107	11 kV FDR O/G S/S-5, H-BLK. TIGRI	TP-KPR223A-1	630	MIXED		Functional	100%	38	0.46			
33 kV TUGHLAKBAD GRID	STLBD107	11 kV FDR O/G S/S-5, H-BLK. TIGRI	TG-KPR050A-1	630	RESIDENTIAL		Functional	100%	165	0.38			
33 kV TUGHLAKBAD GRID	STLBD107	11 kV FDR O/G S/S-5, H-BLK. TIGRI	TG-KPR140A-2	630	RESIDENTIAL		Functional	100%	0	0.31			
33 kV TUGHLAKBAD GRID	STLBD104	11kV FDR O/G D.M.S TRUST	TK-KPR047A-1	630	MIXED		Functional	100%	168	0.29			
66 kV MALVIYA NAGAR GRID	SMALV127	11kV FDR O/G MCD SCHOOL ROAD KHANPUR	KP-HVD012A-2	950	RESIDENTIAL		Functional	100%	0	0.17			
66 kV BATRA GRID	SBTRA102	11kV FDR O/G TIGRI KIOSK	511DSV-KPRX01A-	100	MIXED		Functional	100%	0	0.07			
66 kV BATRA GRID	SBTRA102	11kV FDR O/G TIGRI KIOSK	511DSV-KPR290A-	100	MIXED		Functional	100%	0	0.07			
33 kV TUGHLAKBAD GRID	STLBD117	11kV FDR O/G VAYUSENABAD	TP-KPR208A-1	400	RESIDENTIAL		Functional	100%	75	0.03			
33 kV TUGHLAKBAD GRID	STLBD106	11kV FDR O/G D-BLOCK, SANGA VIHAR S/STN.-8	511DSV-KPR099A-	990	MIXED		Functional	100%	108	0.98	3.14	0.52	14.13%
33 kV TUGHLAKBAD GRID	STLBD109	11kV FDR SSTN NO-1, FEEDER-1 SANGAM VIHAR	TP-KPR079A-1	990	RESIDENTIAL		Functional	100%	1990	0.96			
33 kV TUGHLAKBAD GRID	STLBD109	11kV FDR SSTN NO-1, FEEDER-1 SANGAM VIHAR	TG-KPR080A-1	990	RESIDENTIAL		Functional	100%	1330	0.86			
33 kV TUGHLAKBAD GRID	STLBD106	11kV FDR O/G D-BLOCK, SANGA VIHAR S/STN.-8	511DSV-KPR099A-	630	RESIDENTIAL		Functional	100%	0	0.40			
33 kV TUGHLAKBAD GRID	STLBD109	11kV FDR SSTN NO-1, FEEDER-1 SANGAM VIHAR	TG-KPR125A-1	400	RESIDENTIAL		Functional	100%	5	0.12			
66 kV BATRA GRID	SBTRA103	11kV FDR OG TO D-BLOCK SANGAM VIHAR (OLD)	511DSV-KPR289A-	250	MIXED		Functional	100%	0	0.00			

66 kV BATRA GRID	SBTRA103	11kV FDR OG TO D-BLOCK SANGAM VIHAR (OLD)	KP-HVD023A-1		RESIDENTIAL		Functional	100%	0	0.35			
33 kV TUGHLAKBAD GRID	STLBD131	11 KV FDR O/G, RMU IN GRID	KP-HVD029A-1	2250	RESIDENTIAL		Functional	100%	256	1.61	5.10	1.18	18.83%
33 kV TUGHLAKBAD GRID	STLBD110	11kV FDR G & H BLOCK S/VIHAR	TG-KPR086A-1	990	RESIDENTIAL		Functional	100%	2391	1.06			
33 kV TUGHLAKBAD GRID	STLBD110	11kV FDR G & H BLOCK S/VIHAR	TG-KPR141A-1	990	RESIDENTIAL		Functional	100%	870	0.98			
33 kV TUGHLAKBAD GRID	STLBD110	11kV FDR G & H BLOCK S/VIHAR	TG-KPR087A-1	990	MIXED		Functional	100%	1876	0.90			
33 kV TUGHLAKBAD GRID	STLBD110	11kV FDR G & H BLOCK S/VIHAR	TG-KPR086A-2	990	RESIDENTIAL		Functional	100%	0	0.70			
33 kV TUGHLAKBAD GRID	STLBD110	11kV FDR G & H BLOCK S/VIHAR	TP-KPR147A-1	630	RESIDENTIAL		Functional	100%	797	0.53			
33 kV TUGHLAKBAD GRID	STLBD108	11kV FDR O/G INSTITUTIONAL AREA NO-1	TG-KPR081A-1	630	COMMERCIAL		Functional	100%	5	0.40			
33 kV TUGHLAKBAD GRID	STLBD122	11kV FDR O/G LAL KUAN	511DSV-KPR175A-	400	COMMERCIAL		Functional	100%	1	0.06			
33 kV TUGHLAKBAD GRID	STLBD316	11kV STR 100kVA SATTION TRANSFORMER	TI-STC101A-1	100	COMMERCIAL		Functional	100%	1	0.02			
33 kV TUGHLAKBAD GRID	STLBD123	11kV FDR O/G DR. KARAN SINGH SHOOTING RANGE	TP-KPR166A-1	400	RESIDENTIAL		Functional	100%	0	0.02			
33 kV TUGHLAKBAD GRID	STLBD108	11kV FDR O/G INSTITUTIONAL AREA NO-1	TI-KPR055A-1	400	RESIDENTIAL		Functional	100%	5	0.01			
33 kV TUGHLAKBAD GRID	STLBD106	11kV FDR O/G D-BLOCK, SANGA VIHAR S/STN.-8	TI-KPR117A-1	990	MIXED		Functional	100%	1040	1.04	5.31	0.02	0.37%
66 kV BATRA GRID	SBTRA121	11kV FDR OG TO D-BLOCK SANGAM VIHAR (NEW)	TI-KPR097A-1	990	RESIDENTIAL		Functional	100%	1100	0.91			
33 kV TUGHLAKBAD GRID	STLBD106	11kV FDR O/G D-BLOCK, SANGA VIHAR S/STN.-8	TG-KPR098A-1	990	MIXED		Functional	100%	733	0.82			
66 kV BATRA GRID	SBTRA121	11kV FDR OG TO D-BLOCK SANGAM VIHAR (NEW)	TI-KPR100A-1	990	RESIDENTIAL		Functional	100%	1093	0.78			
33 kV TUGHLAKBAD GRID	STLBD106	11kV FDR O/G D-BLOCK, SANGA VIHAR S/STN.-8	TI-KPR116A-1	990	MIXED		Functional	100%	1695	0.70			
66 kV BATRA GRID	SBTRA103	11kV FDR OG TO D-BLOCK SANGAM VIHAR (OLD)	TI-KPR096A-1	990	MIXED		Functional	100%	838	0.69			
66 kV BATRA GRID	SBTRA121	11kV FDR OG TO D-BLOCK SANGAM VIHAR (NEW)	TI-KPR096A-2	630	MIXED		Functional	100%	737	0.26			
33 kV TUGHLAKBAD GRID	STLBD130	11kV FDR EO 325 RES FLATS AT 22BN ITBP CAMPUS	511PPR-KPR279A-	990	RESIDENTIAL		Functional	100%	147	0.06			
33 kV TUGHLAKBAD GRID	STLBD130	11kV FDR EO 325 RES FLATS AT 22BN ITBP CAMPUS	511PPR-KPR279A-	990	RESIDENTIAL		Functional	100%	0	0.05			
66 kV BATRA GRID	SBTRA102	11kV FDR O/G TIGRI KIOSK	511DSV-KPR291A-	100	MIXED		Functional	100%	0	0.02			
33 kV TUGHLAKBAD GRID	STLBD131	11 KV FDR O/G, RMU IN GRID	TI-KPR121A-1	990	RESIDENTIAL		Functional	100%	2329	0.89	4.10	0.01	0.27%
33 kV TUGHLAKBAD GRID	STLBD131	11 KV FDR O/G, RMU IN GRID	TG-KPR181A-1	990	RESIDENTIAL		Functional	100%	2569	0.82			
33 kV TUGHLAKBAD GRID	STLBD313	11kV FDR O/G F-2 PLINTH MOUNTED SANGAM VIHAR	TG-KPR183A-1	630	RESIDENTIAL		Functional	100%	154	0.73			
33 kV TUGHLAKBAD GRID	STLBD131	11 KV FDR O/G, RMU IN GRID	TP-KPR199A-1	630	RESIDENTIAL		Functional	100%	443	0.64			
33 kV TUGHLAKBAD GRID	STLBD127	11kV FDR O/G F-1 S.STN. NO.2 S. VIHAR (NEW)	TG-KPR150A-1	630	MIXED		Functional	100%	292	0.41			
33 kV TUGHLAKBAD GRID	STLBD131	11 KV FDR O/G, RMU IN GRID	TG-KPR182A-1	400	RESIDENTIAL		Functional	100%	463	0.41			
33 kV TUGHLAKBAD GRID	STLBD313	11kV FDR O/G F-2 PLINTH MOUNTED SANGAM VIHAR	TP-KPR184A-1	400	RESIDENTIAL		Functional	100%	230	0.20			
66 kV BATRA GRID	SBTRA103	11kV FDR OG TO D-BLOCK SANGAM VIHAR (OLD)	TG-KPR185A-1	990	RESIDENTIAL		Functional	100%	122	0.89	1.93	0.02	1.13%
66 kV BATRA GRID	SBTRA103	11kV FDR OG TO D-BLOCK SANGAM VIHAR (OLD)	TP-KPR226A-1	630	RESIDENTIAL		Functional	100%	1266	0.66			
33 kV TUGHLAKBAD GRID	STLBD109	11kV FDR SSTN NO-1, FEEDER-1 SANGAM VIHAR	TG-KPR227A-1	400	RESIDENTIAL		Functional	100%	1338	0.40			
33 kV TUGHLAKBAD GRID	STLBD313	11kV FDR O/G F-2 PLINTH MOUNTED SANGAM VIHAR	TG-KPR198A-1	990	RESIDENTIAL		Functional	100%	1088	0.80	1.86	0.22	10.75%
33 kV TUGHLAKBAD GRID	STLBD109	11kV FDR SSTN NO-1, FEEDER-1 SANGAM VIHAR	TP-KPR149A-1	990	RESIDENTIAL		Functional	100%	1869	0.73			
33 kV TUGHLAKBAD GRID	STLBD109	11kV FDR SSTN NO-1, FEEDER-1 SANGAM VIHAR	511DSV-KPR149A-	630	RESIDENTIAL		Functional	100%	0	0.41			
66 kV BATRA GRID	SBTRA124	11kV FDR O/G TO TIN WAKA S/STN. C-BLOCK SANGAM VHR.	TP-KPR200A-1	400	RESIDENTIAL		Functional	100%	20	0.14			

66KV SANGAM VIHAR GRID	SSNGM128	11kv FDR STATION DEVLJ JOHAR	KP-HVD024A-1	3675	RESIDENTIAL		Functional	100%	332	1.45	4.02	0.37	8.41%
66 kv BATRA GRID	SBTRA104	11kv FDR O/G D.D.A TIGRI	KP-HVD057A-1	3300	RESIDENTIAL		Functional	100%	453	1.21			
66 kv BATRA GRID	SBTRA104	11kv FDR O/G D.D.A TIGRI	KP-HVD056A-1	3350	RESIDENTIAL		Functional	100%	2824	0.98			
66 kv BATRA GRID	SBTRA124	11kv FDR O/G TO TIN WAKA S/STN. C-BLOCK SANGAM VHR.	TP-KPR192A-1	990	RESIDENTIAL		Functional	100%	153	0.75			
33 kv TUGHLAKBAD GRID	STLBD123	11kv FDR O/G DR. KARAN SINGH SHOOTING RANGE	KP-HVD030A-4	2150	RESIDENTIAL		Functional	100%	571	1.35	5.02	0.39	7.20%
33 kv TUGHLAKBAD GRID	STLBD123	11kv FDR O/G DR. KARAN SINGH SHOOTING RANGE	511DSV-HVD070A	3900	MIXED		Functional	100%	4255	1.24			
33 kv TUGHLAKBAD GRID	STLBD132	11kv FDR OG H-16 RAMNIWAS DP	511DSV-HVD073A	2475	MIXED		Functional	100%	1587	0.94			
33 kv TUGHLAKBAD GRID	STLBD132	11kv FDR OG H-16 RAMNIWAS DP	511DVR-KPR085A	3000	MIXED		Functional	100%	637	0.91			
33 kv TUGHLAKBAD GRID	STLBD123	11kv FDR O/G DR. KARAN SINGH SHOOTING RANGE	511DVR-KPR085A	3200	MIXED		Functional	100%	654	0.84			
33 kv TUGHLAKBAD GRID	STLBD123	11kv FDR O/G DR. KARAN SINGH SHOOTING RANGE	TG-KPR254A-1	630	RESIDENTIAL		Functional	100%	185	0.14			
33 kv TUGHLAKBAD GRID	STLBD123	11kv FDR O/G DR. KARAN SINGH SHOOTING RANGE	TP-KPR205A-1	100	RESIDENTIAL		Functional	100%	3	0.00			
66kv SANGAM VIHAR GRID	SSNGM114	11kv O/G FDR J-2B Makhan Chor	KP-HVD031A-1	8000	RESIDENTIAL		Functional	100%	4039	2.96	6.34	0.07	1.14%
66kv SANGAM VIHAR GRID	SSNGM114	11kv O/G FDR J-2B Makhan Chor	KP-HVD032A-1	4425	RESIDENTIAL		Functional	100%	2436	1.32			
33 kv TUGHLAKBAD GRID	STLBD127	11kv FDR O/G F-1 S.STN. NO.2 S. VIHAR (NEW)	KP-HVD058A-1	2710	RESIDENTIAL		Functional	100%	1636	1.26			
33 kv TUGHLAKBAD GRID	STLBD127	11kv FDR O/G F-1 S.STN. NO.2 S. VIHAR (NEW)	KP-HVD059A-1	1980	RESIDENTIAL		Functional	100%	2903	0.67			
33 kv TUGHLAKBAD GRID	STLBD127	11kv FDR O/G F-1 S.STN. NO.2 S. VIHAR (NEW)	TP-KPR224A-1	100	RESIDENTIAL		Functional	100%	25	0.11			
33 kv TUGHLAKBAD GRID	STLBD127	11kv FDR O/G F-1 S.STN. NO.2 S. VIHAR (NEW)	TP-KPR201A-1	100	RESIDENTIAL		Functional	100%	5	0.09			
33 kv TUGHLAKBAD GRID	STLBD312	11kv FDR G-2 K-19 SANGAM VIHAR	KP-HVD037A-1	6780	RESIDENTIAL		Functional	100%	1636	1.88	4.42	0.06	1.34%
33 kv TUGHLAKBAD GRID	STLBD312	11kv FDR G-2 K-19 SANGAM VIHAR	TG-KPR089A-1	990	RESIDENTIAL		Functional	100%	5877	1.14			
33 kv TUGHLAKBAD GRID	STLBD131	11 kv FDR O/G, R MU IN GRID	TP-KPR233A-1	990	RESIDENTIAL		Functional	100%	71	1.06			
33 kv TUGHLAKBAD GRID	STLBD312	11kv FDR G-2 K-19 SANGAM VIHAR	TG-KPR255A-1	630	RESIDENTIAL		Functional	100%	256	0.40			
66 kv OKHLA PHASE 1 GRID	SOKH1106	11kv FDR O/G HOT MIX PLANT	KP-HVD041A-1	1300	RESIDENTIAL		Functional	100%	2066	1.37	6.46	0.63	8.89%
66 kv OKHLA PHASE 1 GRID	SOKH1134	11kv FDR O/G I-BLOCK, LAL KUAN	TG-KPR011A-1	990	COMMERCIAL		Functional	100%	865	0.97			
66 kv OKHLA PHASE 1 GRID	SOKH1106	11kv FDR O/G HOT MIX PLANT	TG-KPR010A-1	990	RESIDENTIAL		Functional	100%	1070	0.75			
66 kv OKHLA PHASE 1 GRID	SOKH1134	11kv FDR O/G I-BLOCK, LAL KUAN	TG-KPR019A-1	990	COMMERCIAL		Functional	100%	800	0.68			
66 kv OKHLA PHASE 1 GRID	SOKH1134	11kv FDR O/G I-BLOCK, LAL KUAN	TG-KPR204A-1	990	RESIDENTIAL		Functional	100%	694	0.68			
66 kv OKHLA PHASE 1 GRID	SOKH1106	11kv FDR O/G HOT MIX PLANT	TG-KPR013A-1	990	COMMERCIAL		Functional	100%	297	0.61			
66 kv OKHLA PHASE 1 GRID	SOKH1106	11kv FDR O/G HOT MIX PLANT	TG-KPR014A-1	630	COMMERCIAL		Functional	100%	234	0.48			
66 kv OKHLA PHASE 1 GRID	SOKH1134	11kv FDR O/G I-BLOCK, LAL KUAN	TG-KPR203A-1	630	RESIDENTIAL		Functional	100%	482	0.43			
66 kv M.C.I.E GRID	SBDRP121	11kv FDR O/G RAVIDAS PRAHLADPUR	511PPR-HVD019A	630	RESIDENTIAL		Functional	100%	0	0.41			
66 kv OKHLA PHASE 1 GRID	SOKH1106	11kv FDR O/G HOT MIX PLANT	TP-KPR017A-1	400	RESIDENTIAL		Functional	100%	177	0.35			
66 kv M.C.I.E GRID	SBDRP121	11kv FDR O/G RAVIDAS PRAHLADPUR	511PPR-HVD019A	630	RESIDENTIAL		Functional	100%	754	0.24			
66 kv OKHLA PHASE 1 GRID	SOKH1106	11kv FDR O/G HOT MIX PLANT	511KPR-HVD106A	100	RESIDENTIAL		Functional	100%	88	0.05			
66 kv OKHLA PHASE 1 GRID	SOKH1106	11kv FDR O/G HOT MIX PLANT	511KPR-HVD105A	100	RESIDENTIAL		Functional	100%	76	0.05			
66 kv OKHLA PHASE 1 GRID	SOKH1134	11kv FDR O/G I-BLOCK, LAL KUAN	TG-KPR174A-1	500	RESIDENTIAL		Functional	100%	0	0.02			
33 kv TUGHLAKBAD GRID	STLBD122	11kv FDR O/G LAL KUAN	TG-KPR237A-1	630	RESIDENTIAL		Functional	100%	499	0.45	0.98	0.01	1.47%
33 kv TUGHLAKBAD GRID	STLBD122	11kv FDR O/G LAL KUAN	511PPR-KPR162A	630	RESIDENTIAL		Functional	100%	442	0.34			
33 kv TUGHLAKBAD GRID	STLBD122	11kv FDR O/G LAL KUAN	TP-KPR176A-1	400	RESIDENTIAL		Functional	100%	10	0.09			
33 kv TUGHLAKBAD GRID	STLBD122	11kv FDR O/G LAL KUAN	TG-KPR012A-1	400	RESIDENTIAL		Functional	100%	154	0.08			
33 kv TUGHLAKBAD GRID	STLBD122	11kv FDR O/G LAL KUAN	TP-KPR165A-1	100	RESIDENTIAL		Functional	100%	5	0.02			

33 kV TUGHLAKBAD GRID	STLBD122	11kV FDR O/G LAL KUAN	TP-KPR177A-1	100	RESIDENTIAL		Functional	100%	5	0.01			
66 kV M.C.I.E GRID	SBD RP121	11kV FDR O/G RAVIDAS PRAHLADPUR	511PPR-HVD020A-	3650	MIXED		Functional	100%	2534	1.61	11.99	1.09	8.30%
66 kV M.C.I.E GRID	SBD RP109	11kV FDR O/G PUL PRAHLADPUR SSTN NO-1	KP-HVD065A-1	3275	RESIDENTIAL		Functional	100%	2313	1.61			
66 kV M.C.I.E GRID	SBD RP122	11kV FDR HAMDARD D.P	KP-HVD018A-1	2875	RESIDENTIAL		Functional	100%	2024	1.41			
66 kV M.C.I.E GRID	SBD RP103	11kV FDR STORME WATER PUMPING STN.	511PPR-HVD066A-	1925	MIXED		Functional	100%	2018	1.29			
66 kV M.C.I.E GRID	SBD RP109	11kV FDR O/G PUL PRAHLADPUR SSTN NO-1	KP-HVD021A-1	1700	RESIDENTIAL		Functional	100%	1283	0.81			
66 kV M.C.I.E GRID	SBD RP122	11kV FDR HAMDARD D.P	TP-KPR160A-1	630	RESIDENTIAL		Functional	100%	944	0.65			
66 kV M.C.I.E GRID	SBD RP109	11kV FDR O/G PUL PRAHLADPUR SSTN NO-1	511PPR-KPR001A-	630	MIXED		Functional	100%	529	0.63			
66 kV M.C.I.E GRID	SBD RP122	11kV FDR HAMDARD D.P	TG-KPR018A-1	630	RESIDENTIAL		Functional	100%	384	0.56			
66 kV M.C.I.E GRID	SBD RP103	11kV FDR STORME WATER PUMPING STN.	KP-HVD022A-1	1125	RESIDENTIAL		Functional	100%	747	0.55			
66 kV M.C.I.E GRID	SBD RP122	11kV FDR HAMDARD D.P	TG-KPR021A-1	630	MIXED		Functional	100%	236	0.48			
66 kV M.C.I.E GRID	SBD RP122	11kV FDR HAMDARD D.P	TP-KPR015A-1	630	MIXED		Functional	100%	114	0.39			
66 kV M.C.I.E GRID	SBD RP122	11kV FDR HAMDARD D.P	KP-HVD040A-1	1400	RESIDENTIAL		Functional	100%	628	0.36			
66 kV M.C.I.E GRID	SBD RP126	11kV FDR KISHORE DP SSTN	TI-KPR005A-2	630	MIXED		Functional	100%	15	0.34			
66 kV M.C.I.E GRID	SBD RP103	11kV FDR STORME WATER PUMPING STN.	TP-KPR002A-2	400	RESIDENTIAL		Functional	100%	0	0.33			
66 kV M.C.I.E GRID	SBD RP103	11kV FDR STORME WATER PUMPING STN.	TI-KPR002A-1	630	MIXED		Functional	100%	321	0.32			
66 kV M.C.I.E GRID	SBD RP126	11kV FDR KISHORE DP SSTN	511PPR-KPR277A-	630	RESIDENTIAL	AMR	Functional	100%	127	0.25			
66 kV M.C.I.E GRID	SBD RP126	11kV FDR KISHORE DP SSTN	TI-KPR028A-1	630	RESIDENTIAL		Functional	100%	46	0.24			
66 kV M.C.I.E GRID	SBD RP126	11kV FDR KISHORE DP SSTN	TI-KPR004A-1	630	MIXED		Functional	100%	482	0.23			
66 kV M.C.I.E GRID	SBD RP126	11kV FDR KISHORE DP SSTN	TI-KPR005A-1	400	RESIDENTIAL		Functional	100%	951	0.18			
66 kV M.C.I.E GRID	SBD RP121	11kV FDR O/G RAVIDAS PRAHLADPUR	511PPR-KPR270A-	400	RESIDENTIAL	AMR	Functional	100%	170	0.16			
66 kV M.C.I.E GRID	SBD RP126	11kV FDR KISHORE DP SSTN	TI-KPR004A-2	400	MIXED		Functional	100%	5	0.15			
66 kV M.C.I.E GRID	SBD RP109	11kV FDR O/G PUL PRAHLADPUR SSTN NO-1	511PPR-KPR285A-	400	RESIDENTIAL	AMR	Functional	100%	0	0.11			
66 kV M.C.I.E GRID	SBD RP109	11kV FDR O/G PUL PRAHLADPUR SSTN NO-1	511PPR-KPR025A-	100	RESIDENTIAL		Functional	100%	3	0.09			
66 kV M.C.I.E GRID	SBD RP126	11kV FDR KISHORE DP SSTN	TI-KPR028A-2	630	RESIDENTIAL		Functional	100%	5	0.07			
66 kV M.C.I.E GRID	SBD RP126	11kV FDR KISHORE DP SSTN	TI-KPR027A-1	990	RESIDENTIAL		Functional	100%	4	0.06			
66 kV M.C.I.E GRID	SBD RP109	11kV FDR O/G PUL PRAHLADPUR SSTN NO-1	511PPR-KPR287A-	100	RESIDENTIAL		Functional	100%	0	0.05			
66 kV M.C.I.E GRID	SBD RP109	11kV FDR O/G PUL PRAHLADPUR SSTN NO-1	511PPR-KPR281A-	100	RESIDENTIAL	AMR	Functional	100%	37	0.04			
66 kV M.C.I.E GRID	SBD RP103	11kV FDR STORME WATER PUMPING STN.	511PPR-KPR280A-	100	RESIDENTIAL	AMR	Functional	100%	51	0.02			
66 kV M.C.I.E GRID	SBD RP121	11kV FDR O/G RAVIDAS PRAHLADPUR	TI-KPR023A-1	100	RESIDENTIAL		Functional	100%	5	0.02			
66 kV M.C.I.E GRID	SBD RP126	11kV FDR KISHORE DP SSTN	511KPR-KPR020A-	400	COMMERCIAL		Functional	100%	8	0.02			
66 kV M.C.I.E GRID	SBD RP109	11kV FDR O/G PUL PRAHLADPUR SSTN NO-1	511PPR-KPR286A-	100	RESIDENTIAL	AMR	Functional	100%	0	0.01			
66 kV M.C.I.E GRID	SBD RP121	11kV FDR O/G RAVIDAS PRAHLADPUR	511PPR-HVD107A-	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kV M.C.I.E GRID	SBD RP121	11kV FDR O/G RAVIDAS PRAHLADPUR	511PPR-HVD068A-	100	RESIDENTIAL	AMR	Functional	100%	0	0.01			
33 kV TUGHLAKBAD GRID	STLBD108	11kV FDR O/G INSTITUTIONAL AREA NO-1	TI-KPR054A-2	990	RESIDENTIAL		Functional	100%	7	0.17	0.46	0.05	9.08%
33 kV TUGHLAKBAD GRID	STLBD104	11kV FDR O/G D.M.S TRUST	TG-KPR144A-1	400	RESIDENTIAL		Functional	100%	11	0.16			
66 kV BATRA GRID	SBTRA108	11kV FDR O/G TUGLAKABAD INST. AREA	TI-KPR054A-1	630	RESIDENTIAL		Functional	100%	24	0.10			
33 kV TUGHLAKBAD GRID	STLBD104	11kV FDR O/G D.M.S TRUST	TG-KPR109A-1	400	RESIDENTIAL		Functional	100%	10	0.06			
66 kV BATRA GRID	SBTRA116	11kV STR 400kVA SATTION TRANSFORMER	KP-STC068A-1	400	COMMERCIAL		Functional	100%	1	0.01			
66 kV BATRA GRID	SBTRA104	11kV FDR O/G D.D.A TIGRI	KP-HVD002A-1	2692.5	RESIDENTIAL		Functional	100%	1355	0.98	5.05	0.06	1.15%
66 kV BATRA GRID	SBTRA104	11kV FDR O/G D.D.A TIGRI	TI-KPR060A-1	990	RESIDENTIAL		Functional	100%	841	0.76			
66kV SANGAM VIHAR GRID	SSNGM113	11kV FDR OG TO B&C BLOCK JAWAHAR PARK I/D	TI-KPR061A-1	1600	RESIDENTIAL	AMR	Functional	100%	500	0.73			
66kV SANGAM VIHAR GRID	SSNGM113	11kV FDR OG TO B&C BLOCK JAWAHAR PARK I/D	TI-KPR061A-2	990	MIXED	AMR	Functional	100%	1365	0.71			
66 kV MALVIYA NAGAR GRID	SMALV129	OG JAWAHAR PARK BLOCK A	TP-KPR231A-1	630	RESIDENTIAL		Functional	100%	198	0.40			
66 kV BATRA GRID	SBTRA104	11kV FDR O/G D.D.A TIGRI	TI-KPR060A-2	630	MIXED	AMR	Functional	100%	625	0.39			
66 kV MALVIYA NAGAR GRID	SMALV129	OG JAWAHAR PARK BLOCK A	511KPR-KPR168A-	630	COMMERCIAL	AMR	Functional	100%	191	0.15			
33 kV TUGHLAKBAD GRID	STLBD106	11kV FDR O/G D-BLOCK, SANGA VIHAR S/STN.-8	511DSV-KPR104A-	4300	MIXED		Functional	100%	4356	0.99			

33 kv D.C.SAKET GRID	SSAKT119	11KV FDR DMRC VIA ANDHRA SCHOOL S/S AND BLIND SCHOOL	520MGS-SK0150A-	100	RESIDENTIAL	AMR	Functional	100%	4	0.00	2.47	0.75	23.28%			
66 kv FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	TG-SKT147A-1	400	RESIDENTIAL	AMR	Functional	100%	56	0.32						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT178A-1	400	COMMERCIAL	AMR	Functional	100%	87	0.24						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT179A-1	400	COMMERCIAL	AMR	Functional	100%	40	0.21						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT181A-1	400	COMMERCIAL	AMR	Functional	100%	35	0.21						
220kv MEHRAULI TRANSCO GRID	TDTMG101	11kv FDR VSNL GATE	TG-SKT182A-1	400	RESIDENTIAL		Functional	100%	72	0.20						
66 kv C - DOT GRID	SCDOT127	11KV FDR O/G CHATTARPUR-2	TG-SKT172A-1	400	RESIDENTIAL	AMR	Functional	100%	19	0.20						
66 kv C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	TG-SKT897A-1	400	COMMERCIAL		Functional	100%	13	0.15						
66 kv C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	TP-SK0006A-1	400	COMMERCIAL	AMR	Functional	100%	2	0.14						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT089A-1	400	COMMERCIAL	AMR	Functional	100%	41	0.13						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TG-SKT180A-1	400	COMMERCIAL	AMR	Functional	100%	12	0.11						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT177A-1	400	COMMERCIAL	AMR	Functional	100%	44	0.10						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT176A-1	400	COMMERCIAL	AMR	Functional	100%	35	0.08						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	520CPR-SKT459A-	250	RESIDENTIAL		Functional	100%	13	0.07						
66 kv C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	TG-SKT661A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.06						
66 kv C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	TP-SKT653A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.05						
66 kv C - DOT GRID	SCDOT127	11KV FDR O/G CHATTARPUR-2	TP-SKT173A-1	100	RESIDENTIAL		Functional	100%	10	0.04						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT874A-1	100	RESIDENTIAL		Functional	100%	4	0.04						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT516A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.03						
66 kv C - DOT GRID	SCDOT127	11KV FDR O/G CHATTARPUR-2	TP-SKT887A-1	100	COMMERCIAL	AMR	Functional	100%	19	0.03						
66 kv C - DOT GRID	SCDOT132	11kv STR 100kVA STATION TRANSFORMER-2	TP-STC117A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02						
66 kv C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	TP-SKT949A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT649A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.02						
66 kv C - DOT GRID	SCDOT127	11KV FDR O/G CHATTARPUR-2	TP-SKT946A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT449A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT650A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.02						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT651A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT268A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01						
66 kv C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	TP-SKT654A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT994A-1	250	RESIDENTIAL	AMR	Functional	100%	1	0.01						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT954A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01						
66 kv C - DOT GRID	SCDOT127	11KV FDR O/G CHATTARPUR-2	TP-SKT904A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT646A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01						
66 kv C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	TG-SKT057A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01						
66 kv C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	TP-SKT626A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.01						
66 kv C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	TP-SKT450A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01						
66 kv C - DOT GRID	SCDOT106	11kv STR 100kVA STATION TRANSFORMER-1	TG-STC117A-2	100	COMMERCIAL	AMR	Functional	100%	0	0.01						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT648A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT647A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01						
66 kv C - DOT GRID	SCDOT122	11KV FDR O/G I.I.P.M NO.-2	TP-SKT822A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01						
66 kv C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	TP-SKT015A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00						
33 kv ANDHERIA BAGH GRID	SABAG113	11kv FDR O/G TO D.L.F CHATTARPUR	520CPR-SK0243A-	100	MIXED		Functional	100%	0	0.00						
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT645A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00						
66 kv C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	TP-SKT964A-1	400	COMMERCIAL	AMR	Functional	100%	3	0.00						
33 kv D.C.SAKET GRID	SSAKT119	11KV FDR PUSHP VIHAR S/S NO.-12	520FBR-MOB001A-	630	RESIDENTIAL		Functional	100%	0	0.21						
66 kv FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	520FBR-MOB001A-	990	MIXED		Functional	100%	0	0.20						
66 kv MALVIYA NAGAR GRID	SMALV132	11kv FDR OG TO J-12 SAKET	520FBR-MOB001A-	990	MIXED		Functional	100%	0	0.15						
66 kv C - DOT GRID	SCDOT127	11KV FDR O/G CHATTARPUR-2	SK-HVD009A-1	2375	COMMERCIAL		Functional	100%	1391	2.24				15.46	0.34	2.12%
66 kv C - DOT GRID	SCDOT127	11KV FDR O/G CHATTARPUR-2	SK-HVD009A-2	2815	COMMERCIAL		Functional	100%	5251	1.41						

66 kv C - DOT GRID	SCDOT130	11KV FDR DLF GATE NO.-2 (MAIDAN GARHI)	TP-SKT658A-1	990	RESIDENTIAL		Functional	100%	545	0.85			
220kv MEHRAULI TRANSCO GRID	TDTMG106	11kv FDR MEERA CHATTARPUR VILLAGE	TG-SKT452A-1	990	RESIDENTIAL	AMR	Functional	100%	615	0.81			
220kv MEHRAULI TRANSCO GRID	TDTMG105	11kv FDR RAJPUR EXTENSION	TG-SKT883A-1	990	RESIDENTIAL	AMR	Functional	100%	746	0.73			
33 kv ANDHERIA BAGH GRID	SABAG113	11kv FDR O/G TO D.L.F CHATTARPUR	TG-SKT085A-1	990	RESIDENTIAL		Functional	100%	366	0.72			
33 kv ANDHERIA BAGH GRID	SABAG117	11kv FDR O/G TO SATABARI	TG-SK0074A-1	630	RESIDENTIAL		Functional	100%	181	0.65			
66 kv C - DOT GRID	SCDOT127	11KV FDR O/G CHATTARPUR-2	TP-SKT041A-1	630	RESIDENTIAL	AMR	Functional	100%	830	0.65			
220kv MEHRAULI TRANSCO GRID	TDTMG106	11kv FDR MEERA CHATTARPUR VILLAGE	TG-SKT032A-1	990	RESIDENTIAL	AMR	Functional	100%	1219	0.58			
66 kv C - DOT GRID	SCDOT127	11KV FDR O/G CHATTARPUR-2	TP-SKT030A-1	630	RESIDENTIAL	AMR	Functional	100%	617	0.54			
66 kv C - DOT GRID	SCDOT103	11KV FDR O/G TO MCD PARK CHATTARPUR NO.-1	520CPR-SKT092A-	400	MIXED		Functional	100%	0	0.48			
66 kv C - DOT GRID	SCDOT129	11KV FDR D.L.F GATE NO.-1	TG-SKT228A-1	990	RESIDENTIAL	AMR	Functional	100%	654	0.48			
220kv MEHRAULI TRANSCO GRID	TDTMG105	11kv FDR RAJPUR EXTENSION	520CPR-SK0167A-	630	RESIDENTIAL		Functional	100%	150	0.48			
66 kv C - DOT GRID	SCDOT129	11KV FDR D.L.F GATE NO.-1	520CPR-SK0115A-	630	RESIDENTIAL		Functional	100%	140	0.48			
66 kv C - DOT GRID	SCDOT627	11kv FDR MAIDANGARHI EXTN TUBEWELL VIA MCD PARK CHATTERPUR	TG-SKT084A-1	990	COMMERCIAL	AMR	Functional	100%	184	0.42			
66 kv C - DOT GRID	SCDOT127	11KV FDR O/G CHATTARPUR-2	520CPR-SK0207A-	630	MIXED		Functional	100%	0	0.41			
66 kv C - DOT GRID	SCDOT129	11KV FDR D.L.F GATE NO.-1	TG-SKT923A-1	630	RESIDENTIAL		Functional	100%	150	0.40			
66 kv C - DOT GRID	SCDOT127	11KV FDR O/G CHATTARPUR-2	TG-SKT929A-1	400	RESIDENTIAL	AMR	Functional	100%	177	0.40			
66 kv C - DOT GRID	SCDOT129	11KV FDR D.L.F GATE NO.-1	TG-SKT849A-1	630	RESIDENTIAL		Functional	100%	257	0.37			
66 kv C - DOT GRID	SCDOT124	11KV FDR O/G D.J.B BOOSTER PUMP CHATTARPUR PAHARI	520CPR-HVD021A-	400	RESIDENTIAL		Functional	100%	162	0.33			
66 kv C - DOT GRID	SCDOT129	11KV FDR D.L.F GATE NO.-1	TG-SK0015A-1	400	RESIDENTIAL		Functional	100%	195	0.31			
66 kv C - DOT GRID	SCDOT124	11KV FDR O/G D.J.B BOOSTER PUMP CHATTARPUR PAHARI	520CPR-SK0120A-	400	RESIDENTIAL		Functional	100%	0	0.26			
66 kv C - DOT GRID	SCDOT129	11KV FDR D.L.F GATE NO.-1	520CPR-SKT228A-	400	RESIDENTIAL	AMR	Functional	100%	0	0.26			
66 kv C - DOT GRID	SCDOT103	11KV FDR O/G TO MCD PARK CHATTARPUR NO.-1	TP-SKT652A-1	400	RESIDENTIAL	AMR	Functional	100%	146	0.17			
66 kv FATEHPURBERI GRID	SFTPR115	11KV FDR RSSB SSTN NO-2	520CPR-SK0244A-	990	MIXED		Functional	100%	0	0.14			
66 kv C - DOT GRID	SCDOT124	11KV FDR O/G D.J.B BOOSTER PUMP CHATTARPUR PAHARI	520CPR-SK0039A-	400	MIXED		Functional	100%	0	0.14			
66 kv FATEHPURBERI GRID	SFTPR115	11KV FDR RSSB SSTN NO-2	520CPR-SK0244A-	990	MIXED		Functional	100%	0	0.14			
66 kv C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	520CPR-SK0206A-	400	MIXED	AMR	Functional	100%	820	0.13			
66 kv C - DOT GRID	SCDOT129	11KV FDR D.L.F GATE NO.-1	520CPR-SK0058A-	400	RESIDENTIAL		Functional	100%	105	0.13			
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C.Tr. DLF (MEHAR CHAND)	520CPR-SK0155A-	315	RESIDENTIAL	AMR	Functional	100%	50	0.12			
33 kv ANDHERIA BAGH GRID	SABAG111	11kv FDR O/G TO S.T.P MEHRAULI	520CPR-SK0211A-	630	MIXED		Functional	100%	0	0.12			
66 kv C - DOT GRID	SCDOT127	11KV FDR O/G CHATTARPUR-2	520CPR-SK0194A-	250	RESIDENTIAL		Functional	100%	0	0.09			
66 kv C - DOT GRID	SCDOT127	11KV FDR O/G CHATTARPUR-2	TP-SKT445A-1	400	RESIDENTIAL		Functional	100%	16	0.07			
33 kv ANDHERIA BAGH GRID	SABAG113	11KV FDR O/G TO D.L.F CHATTARPUR	520CPR-SK0238A-	100	MIXED		Functional	100%	0	0.06			
33 kv D.C.SAKET GRID	SSAKT124	11KV FDR S/S NO.-1, ADVOCATE CHEMBER NO.-1 (COURT COMPLEX)	520CPR-SKT876A-	100	MIXED		Functional	100%	0	0.04			
33 kv ANDHERIA BAGH GRID	SABAG113	11KV FDR O/G TO D.L.F CHATTARPUR	520CPR-HVDX12A-	100	MIXED		Functional	100%	0	0.04			
33 kv ANDHERIA BAGH GRID	SABAG117	11KV FDR O/G TO SATABARI	520CPR-SK0116A-	100	MIXED		Functional	100%	0	0.04			
66 kv C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C.Tr. DLF (MEHAR CHAND)	520CPR-SK0162A-	100	COMMERCIAL		Functional	100%	0	0.03			
66 kv C - DOT GRID	SCDOT112	11KV FDR O/G TO SULTANPUR COLONY	TP-SKT232A-1	400	COMMERCIAL		Functional	100%	0	0.03			
66 kv C - DOT GRID	SCDOT130	11KV FDR DLF GATE NO.-2 (MAIDAN GARHI)	TP-SKT845A-1	100	RESIDENTIAL		Functional	100%	10	0.02			
220kv MEHRAULI TRANSCO GRID	TDTMG104	11kv FDR CHATTARPUR ENCLAVE BARRIER	520CPR-SK0163A-	400	MIXED		Functional	100%	0	0.01			
66 kv C - DOT GRID	SCDOT127	11KV FDR O/G CHATTARPUR-2	520CPR-SKT929A-	100	COMMERCIAL	AMR	Functional	100%	27	0.01			
33 kv ANDHERIA BAGH GRID	SABAG111	11kv FDR O/G TO S.T.P MEHRAULI	520CPR-SK0191A-	100	MIXED		Functional	100%	0	0.00			
66 kv C - DOT GRID	SCDOT133	11KV FDR O/G TO RAJPUR KHURD	520CPR-SK0164A-	990	MIXED		Functional	100%	0	0.00			
66 kv C - DOT GRID	SCDOT124	11KV FDR O/G D.J.B BOOSTER PUMP CHATTARPUR PAHARI	SK-HVD006A-2	2360	COMMERCIAL		Functional	100%	0	2.30	11.55	0.14	1.21%
33 kv ANDHERIA BAGH GRID	SABAG113	11KV FDR O/G TO D.L.F CHATTARPUR	520CPR-HVD001A-	3350	COMMERCIAL		Functional	100%	3388	1.99			
33 kv ANDHERIA BAGH GRID	SABAG111	11KV FDR O/G TO S.T.P MEHRAULI	TG-SKT091A-1	990	COMMERCIAL	AMR	Functional	100%	795	1.08			
66 kv C - DOT GRID	SCDOT124	11KV FDR O/G D.J.B BOOSTER PUMP CHATTARPUR PAHARI	SK-HVD006A-1	1050	COMMERCIAL		Functional	100%	4780	0.74			
66 kv C - DOT GRID	SCDOT124	11KV FDR O/G D.J.B BOOSTER PUMP CHATTARPUR PAHARI	SK-HVD006A-5	1425	COMMERCIAL		Functional	100%	0	0.73			
33 kv ANDHERIA BAGH GRID	SABAG111	11kv FDR O/G TO S.T.P MEHRAULI	TG-SKT895A-1	990	MIXED	AMR	Functional	100%	0	0.66			
33 kv ANDHERIA BAGH GRID	SABAG111	11KV FDR O/G TO S.T.P MEHRAULI	SK-HVD005A-1	3380	COMMERCIAL		Functional	100%	590	0.57			

66 kv C - DOT GRID	SCDOT124	11KV FDR O/G D.J.B BOOSTER PUMP CHATTARPUR PAHARI	TP-SKT881A-1	400	COMMERCIAL		Functional	100%	65	0.47			
66 kv C - DOT GRID	SCDOT103	11KV FDR O/G TO MCD PARK CHATTARPUR NO.-1	TP-SKT921A-1	630	RESIDENTIAL		Functional	100%	456	0.44			
220kv MEHRAULI TRANSCO GRID	TDTMG104	11kv FDR CHATTARPUR ENCLAVE BARRIER	TP-SKT518A-1	400	COMMERCIAL		Functional	100%	435	0.36			
66 kv C - DOT GRID	SCDOT124	11KV FDR O/G D.J.B BOOSTER PUMP CHATTARPUR PAHARI	SK-HVD006A-3	2055	COMMERCIAL		Functional	100%	43	0.36			
66 kv C - DOT GRID	SCDOT124	11KV FDR O/G D.J.B BOOSTER PUMP CHATTARPUR PAHARI	SK-HVD006A-4	550	COMMERCIAL		Functional	100%	0	0.30			
33 kv ANDHERIA BAGH GRID	SABAG113	11kv FDR O/G TO D.L.F CHATTARPUR	TG-SKT027A-1	630	COMMERCIAL	AMR	Functional	100%	211	0.30			
33 kv ANDHERIA BAGH GRID	SABAG111	11kv FDR O/G TO S.T.P MEHRAULI	520CPR-SKT091A-	350	MIXED		Functional	100%	1941	0.30			
33 kv ANDHERIA BAGH GRID	SABAG113	11kv FDR O/G TO D.L.F CHATTARPUR	520CPR-HVD001A-	525	COMMERCIAL		Functional	100%	0	0.27			
33 kv ANDHERIA BAGH GRID	SABAG111	11kv FDR O/G TO S.T.P MEHRAULI	520CPR-HVD005A-	350	MIXED		Functional	100%	461	0.23			
33 kv ANDHERIA BAGH GRID	SABAG111	11kv FDR O/G TO S.T.P MEHRAULI	TP-SKT925A-1	100	COMMERCIAL	AMR	Functional	100%	53	0.11			
33 kv ANDHERIA BAGH GRID	SABAG113	11kv FDR O/G TO D.L.F CHATTARPUR	TG-SKT028A-1	630	COMMERCIAL	AMR	Functional	100%	91	0.09			
66 kv C - DOT GRID	SCDOT124	11KV FDR O/G D.J.B BOOSTER PUMP CHATTARPUR PAHARI	TP-SKT09A-1	100	RESIDENTIAL		Functional	100%	68	0.05			
220kv MEHRAULI TRANSCO GRID	TDTMG104	11kv FDR CHATTARPUR ENCLAVE BARRIER	520CPR-SK0152A-	400	RESIDENTIAL		Functional	100%	4	0.05			
33 kv ANDHERIA BAGH GRID	SABAG111	11kv FDR O/G TO S.T.P MEHRAULI	TP-SKT395A-1	100	COMMERCIAL	AMR	Functional	100%	15	0.05			
33 kv ANDHERIA BAGH GRID	SABAG113	11kv FDR O/G TO D.L.F CHATTARPUR	TP-SKT843A-1	100	COMMERCIAL	AMR	Functional	100%	12	0.05			
33 kv ANDHERIA BAGH GRID	SABAG111	11kv FDR O/G TO S.T.P MEHRAULI	TP-SKT24A-1	100	RESIDENTIAL	AMR	Functional	100%	57	0.04			
66 kv C - DOT GRID	SCDOT124	11KV FDR O/G D.J.B BOOSTER PUMP CHATTARPUR PAHARI	520CPR-SK0153A-	100	RESIDENTIAL		Functional	100%	24	0.03			
66 kv C - DOT GRID	SCDOT124	11KV FDR O/G D.J.B BOOSTER PUMP CHATTARPUR PAHARI	TP-SKT992A-1	250	RESIDENTIAL		Functional	100%	34	0.03			
66 kv C - DOT GRID	SCDOT103	11KV FDR O/G TO MCD PARK CHATTARPUR NO.-1	TP-SKT747A-1	100	RESIDENTIAL		Functional	100%	6	0.02			
33 kv ANDHERIA BAGH GRID	SABAG113	11kv FDR O/G TO D.L.F CHATTARPUR	TP-SKT755A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02			
33 kv ANDHERIA BAGH GRID	SABAG111	11kv FDR O/G TO S.T.P MEHRAULI	TP-SKT561A-1	100	COMMERCIAL	AMR	Functional	100%	4	0.01			
33 kv ANDHERIA BAGH GRID	SABAG113	11kv FDR O/G TO D.L.F CHATTARPUR	520CPR-SK0180A-	100	RESIDENTIAL	AMR	Functional	100%	18	0.01			
33 kv ANDHERIA BAGH GRID	SABAG111	11kv FDR O/G TO S.T.P MEHRAULI	TP-SKT898A-1	100	RESIDENTIAL		Functional	100%	6	0.01			
66 kv C - DOT GRID	SCDOT124	11KV FDR O/G D.J.B BOOSTER PUMP CHATTARPUR PAHARI	TP-SKT975A-1	100	RESIDENTIAL		Functional	100%	42	0.01			
66 kv C - DOT GRID	SCDOT103	11KV FDR O/G TO MCD PARK CHATTARPUR NO.-1	520CPR-SK0235A-	630	MIXED		Functional	100%	0	0.00			
220kv MEHRAULI TRANSCO GRID	TDTMG104	11kv FDR CHATTARPUR ENCLAVE BARRIER	520CPR-SKT199A-	100	RESIDENTIAL		Functional	100%	1	0.00			
66 kv I.G.N.O.U GRID	SIGNO113	11kv FDR MAIDAN GARHI VILLAGE	TP-SKT656A-1	990	COMMERCIAL	AMR	Functional	100%	1259	0.88	5.12	0.07	1.30%
66 kv I.G.N.O.U GRID	SIGNO109	11kv FDR IGNOU KIOSK	TG-SKT220A-1	990	COMMERCIAL	AMR	Functional	100%	696	0.76			
66 kv I.G.N.O.U GRID	SIGNO109	11kv FDR IGNOU KIOSK	520CPR-SKT034A-	2350	MIXED		Functional	100%	928	0.76			
66 kv I.G.N.O.U GRID	SIGNO113	11kv FDR MAIDAN GARHI VILLAGE	TG-SKT093A-1	990	COMMERCIAL	AMR	Functional	100%	522	0.68			
66 kv I.G.N.O.U GRID	SIGNO113	11kv FDR MAIDAN GARHI VILLAGE	TG-SKT656A-2	630	RESIDENTIAL	AMR	Functional	100%	190	0.62			
66 kv I.G.N.O.U GRID	SIGNO113	11kv FDR MAIDAN GARHI VILLAGE	TP-SKT223A-1	990	COMMERCIAL	AMR	Functional	100%	1056	0.61			
66 kv I.G.N.O.U GRID	SIGNO109	11kv FDR IGNOU KIOSK	TG-SKT034A-1	630	COMMERCIAL	AMR	Functional	100%	306	0.43			
66 kv C - DOT GRID	SCDOT627	11kv FDR MAIDANGARHI EXTN TUBEWELL VIA MCD PARK CHATTARPUR	520CPR-SK0230A-	400	MIXED		Functional	100%	0	0.09			
66 kv I.G.N.O.U GRID	SIGNO105	11kv FDR S/S NO.-09, IGNOU CAMPUS	TP-SKT416A-2	400	COMMERCIAL		Functional	100%	67	0.08			
66 kv I.G.N.O.U GRID	SIGNO105	11kv FDR S/S NO.-09, IGNOU CAMPUS	TP-SKT414A-2	400	COMMERCIAL		Functional	100%	79	0.08			
66 kv I.G.N.O.U GRID	SIGNO105	11kv FDR S/S NO.-09, IGNOU CAMPUS	TP-SKT415A-2	400	COMMERCIAL		Functional	100%	45	0.05			
66 kv I.G.N.O.U GRID	SIGNO105	11kv FDR S/S NO.-09, IGNOU CAMPUS	TP-SKT414A-1	400	COMMERCIAL		Functional	100%	19	0.04			
66 kv I.G.N.O.U GRID	SIGNO105	11kv FDR S/S NO.-09, IGNOU CAMPUS	TP-SKT416A-1	400	COMMERCIAL	AMR	Functional	100%	80	0.04			
66 kv I.G.N.O.U GRID	SIGNO105	11kv FDR S/S NO.-09, IGNOU CAMPUS	TP-SKT415A-1	400	COMMERCIAL		Functional	100%	68	0.03			
66 kv CAPFIMS MAIDAN GARHI GRID	SCAPF009	11kv STR 400kVA STATION TRF	520CPR-STC136A-	400	COMMERCIAL		Functional	100%	175	0.02			
66 kv I.G.N.O.U GRID	SIGNO112	11kv STR 100kVA STATION TRANS.	TG-STC128A-1	400	INDUSTRIAL	AMR	Functional	100%	1	0.01			
66 kv I.G.N.O.U GRID	SIGNO113	11kv FDR MAIDAN GARHI VILLAGE	TG-SKT094A-1	990	COMMERCIAL	AMR	Functional	100%	1109	1.06	7.21	0.03	0.48%
66 kv C - DOT GRID	SCDOT133	11KV FDR O/G TO RAJPUR KHURD	TG-SKT033A-1	990	COMMERCIAL	AMR	Functional	100%	1045	0.90			
220kv MEHRAULI TRANSCO GRID	TDTMG105	11kv FDR RAJPUR EXTENSION	SK-HVD008A-1	975	COMMERCIAL		Functional	100%	1266	0.86			
66 kv C - DOT GRID	SCDOT133	11KV FDR O/G TO RAJPUR KHURD	TG-SKT040A-1	990	COMMERCIAL	AMR	Functional	100%	800	0.69			
220kv MEHRAULI TRANSCO GRID	TDTMG105	11kv FDR RAJPUR EXTENSION	TP-SKT847A-1	990	COMMERCIAL	AMR	Functional	100%	693	0.67			
220kv MEHRAULI TRANSCO GRID	TDTMG105	11kv FDR RAJPUR EXTENSION	SK-HVD007A-1	1950	COMMERCIAL		Functional	100%	2335	0.60			
66 kv C - DOT GRID	SCDOT133	11KV FDR O/G TO RAJPUR KHURD	TG-SK0012A-1	630	RESIDENTIAL		Functional	100%	481	0.48			

220kV MEHRAULI TRANSCO GRID	TDTMG105	11kV FDR RAJPUR EXTENSION	TP-SKT517A-1	400	COMMERCIAL		Functional	100%	274	0.46			
66 kV I.G.N.O.U GRID	SIGNO113	11kV FDR MAIDAN GARHI VILLAGE	TP-SKT227A-1	400	COMMERCIAL	AMR	Functional	100%	185	0.40			
66 kV FATEHPURBERI GRID	SFTPR115	11kV FDR RSSB SSTN NO-2	TG-SKT982A-1	630	RESIDENTIAL	AMR	Functional	100%	539	0.39			
220kV MEHRAULI TRANSCO GRID	TDTMG105	11kV FDR RAJPUR EXTENSION	520CPR-HVD007A-	400	MIXED		Functional	100%	0	0.35			
220kV MEHRAULI TRANSCO GRID	TDTMG105	11kV FDR RAJPUR EXTENSION	TP-SKT983A-1	400	RESIDENTIAL		Functional	100%	168	0.18			
66 kV FATEHPURBERI GRID	SFTPR104	11kV FDR ANSAL FARMS	TP-SK0088A-1	250	RESIDENTIAL	AMR	Functional	100%	5	0.12			
220kV MEHRAULI TRANSCO GRID	TDTMG105	11kV FDR RAJPUR EXTENSION	TP-SKT086A-1	400	COMMERCIAL	AMR	Functional	100%	93	0.09			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT087A-1	400	RESIDENTIAL	AMR	Functional	100%	33	0.34	1.96	0.08	3.76%
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT222A-1	400	RESIDENTIAL	AMR	Functional	100%	40	0.24			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT088A-1	630	RESIDENTIAL	AMR	Functional	100%	25	0.22			
220kV MEHRAULI TRANSCO GRID	TDTMG105	11kV FDR RAJPUR EXTENSION	TP-SKT210A-2	400	COMMERCIAL		Functional	100%	132	0.17			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT643A-1	400	RESIDENTIAL	AMR	Functional	100%	15	0.16			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT095A-1	400	RESIDENTIAL	AMR	Functional	100%	27	0.11			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT446A-1	400	COMMERCIAL	AMR	Functional	100%	36	0.11			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SK0005A-1	400	RESIDENTIAL		Functional	100%	1	0.10			
220kV MEHRAULI TRANSCO GRID	TDTMG105	11kV FDR RAJPUR EXTENSION	TP-SKT984A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.10			
220kV MEHRAULI TRANSCO GRID	TDTMG105	11kV FDR RAJPUR EXTENSION	TP-SKT174A-1	400	COMMERCIAL	AMR	Functional	100%	12	0.08			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT660A-1	100	COMMERCIAL		Functional	100%	6	0.06			
66 kV C - DOT GRID	SCDOT130	11KV FDR DLF GATE NO.-2 (MAIDAN GARHI)	TP-SKT451A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.05			
66 kV C - DOT GRID	SCDOT130	11KV FDR DLF GATE NO.-2 (MAIDAN GARHI)	TP-SKT655A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.05			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT869A-2	100	RESIDENTIAL		Functional	100%	0	0.04			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	520CPR-SK0114A-	250	RESIDENTIAL		Functional	100%	24	0.03			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT644A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT924A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.03			
66 kV C - DOT GRID	SCDOT130	11KV FDR DLF GATE NO.-2 (MAIDAN GARHI)	TG-SKT211A-1	100	COMMERCIAL		Functional	100%	1	0.02			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT873A-1	100	COMMERCIAL		Functional	100%	2	0.02			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT642A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT872A-1	100	COMMERCIAL		Functional	100%	1	0.02			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT869A-1	100	RESIDENTIAL		Functional	100%	14	0.02			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT808A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.01			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TG-SKT934A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT756A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT448A-1	100	COMMERCIAL		Functional	100%	6	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT996A-1	250	RESIDENTIAL	AMR	Functional	100%	5	0.01			
66 kV C - DOT GRID	SCDOT102	11KV FDR O/G TO M.C Tr. DLF (MEHAR CHAND)	TP-SKT515A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TG-SKT082A-1	400	COMMERCIAL	AMR	Functional	100%	32	0.21	1.57	0.29	15.55%
66 kV FATEHPURBERI GRID	SFTPR104	11kV FDR ANSAL FARMS	TG-SKT073A-1	400	COMMERCIAL	AMR	Functional	100%	41	0.13			
66 kV FATEHPURBERI GRID	SFTPR104	11kV FDR ANSAL FARMS	TP-SKT436A-1	400	COMMERCIAL	AMR	Functional	100%	18	0.12			
66 kV FATEHPURBERI GRID	SFTPR109	11KV FDR O/G TO ASOLA VILLAGE	TP-SK0048A-1	400	RESIDENTIAL	AMR	Functional	100%	168	0.12			
66 kV FATEHPURBERI GRID	SFTPR104	11kV FDR ANSAL FARMS	TP-SKT161A-1	250	COMMERCIAL	AMR	Functional	100%	6	0.11			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT149A-1	400	COMMERCIAL	AMR	Functional	100%	13	0.09			
66 kV FATEHPURBERI GRID	SFTPR104	11kV FDR ANSAL FARMS	TG-SKT074A-1	400	COMMERCIAL		Functional	100%	33	0.09			
66 kV FATEHPURBERI GRID	SFTPR104	11kV FDR ANSAL FARMS	520FBR-SKT960A-	400	RESIDENTIAL	AMR	Functional	100%	12	0.08			
66 kV FATEHPURBERI GRID	SFTPR104	11kV FDR ANSAL FARMS	TP-SKT076A-1	400	COMMERCIAL		Functional	100%	5	0.07			

66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT862A-1	400	COMMERCIAL	AMR	Functional	100%	16	0.05
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SKT619A-1	100	COMMERCIAL		Functional	100%	2	0.05
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SKT764A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.05
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT159A-1	400	COMMERCIAL	AMR	Functional	100%	12	0.05
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SKT894A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.04
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT526A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.04
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SKT054A-2	100	RESIDENTIAL	AMR	Functional	100%	11	0.04
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SK0056A-1	400	RESIDENTIAL	AMR	Functional	100%	4	0.04
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT158A-1	100	COMMERCIAL	AMR	Functional	100%	8	0.03
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	2520FBR-SKT829A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.03
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TG-SKT961A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.03
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SKT879A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.03
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SKT807A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.03
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT453A-1	100	COMMERCIAL	AMR	Functional	100%	7	0.03
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT525A-1	100	COMMERCIAL		Functional	100%	2	0.02
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SKT624A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	2520FBR-SKT529A-1	400	RESIDENTIAL	AMR	Functional	100%	3	0.02
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SKT434A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SKT810A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.02
66 kV C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	TP-SKT757A-1	100	COMMERCIAL		Functional	100%	2	0.02
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	2520CPR-SKT16A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT870A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.02
66 kV FATEHPURBERI GRID	SFTPR109	11KV FDR O/G TO ASOLA VILLAGE	TG-SKT959A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SKT195A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SKT214A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT618A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	2520FBR-SK0131A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SK0033A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SKT473A-1	100	RESIDENTIAL		Functional	100%	1	0.01
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT435A-1	100	COMMERCIAL	AMR	Functional	100%	7	0.01
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT765A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.01
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT758A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.01
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	2520FBR-SKT800A-1	100	MIXED	AMR	Functional	100%	0	0.01

66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SKT926A-1	100	COMMERCIAL	AMR	Functional	100%	0	0.00	6.13	0.08	1.32%
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SKT763A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.00			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT844A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.00			
66 kV FATEHPURBERI GRID	SFTPR108	11KV FDR O/G TO FATEHPUR BERI C.C	TG-SKT501A-1	990	RESIDENTIAL	AMR	Functional	100%	1052	1.29			
66 kV FATEHPURBERI GRID	SFTPR109	11KV FDR O/G TO ASOLA VILLAGE	2520FBR-SK0218A-	990	MIXED	AMR	Functional	100%	0	0.84			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TG-SKT864A-1	630	RESIDENTIAL	AMR	Functional	100%	381	0.53			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TG-SKT071A-2	630	RESIDENTIAL		Functional	100%	0	0.40			
66 kV FATEHPURBERI GRID	SFTPR101	11KV FDR RSSB SSTN NO-4	2520FBR-SK0145A-	630	RESIDENTIAL	AMR	Functional	100%	8	0.36			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	2520FBR-SKT864A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.35			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TG-SKT143A-1	400	RESIDENTIAL	AMR	Functional	100%	84	0.33			
66 kV FATEHPURBERI GRID	SFTPR109	11KV FDR O/G TO ASOLA VILLAGE	2520FBR-SK0218A-	990	MIXED		Functional	100%	1688	0.31			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT865A-1	400	COMMERCIAL	AMR	Functional	100%	108	0.28			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SK0003A-1	400	RESIDENTIAL	AMR	Functional	100%	8	0.27			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SKT215A-1	400	RESIDENTIAL	AMR	Functional	100%	57	0.20			
66 kV FATEHPURBERI GRID	SFTPR101	11KV FDR RSSB SSTN NO-4	2520FBR-SK0212A-	630	MIXED		Functional	100%	0	0.11			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TG-SKT078A-1	400	RESIDENTIAL	AMR	Functional	100%	31	0.11			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SKT144A-1	400	COMMERCIAL	AMR	Functional	100%	42	0.11			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT071A-1	400	COMMERCIAL	AMR	Functional	100%	55	0.10			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SKT077A-1	400	RESIDENTIAL	AMR	Functional	100%	19	0.10			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT462A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.09			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SKT008A-1	400	RESIDENTIAL		Functional	100%	17	0.06			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SKT001A-1	250	RESIDENTIAL	AMR	Functional	100%	1	0.05			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SKT770A-1	400	RESIDENTIAL	AMR	Functional	100%	25	0.04			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TG-SKT007A-2	400	RESIDENTIAL	AMR	Functional	100%	4	0.04			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT522A-1	100	RESIDENTIAL		Functional	100%	2	0.03			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	2520FBR-SK0128A-	100	RESIDENTIAL	AMR	Functional	100%	12	0.03			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SKT620A-1	100	COMMERCIAL	AMR	Functional	100%	4	0.02			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT945A-1	100	RESIDENTIAL	AMR	Functional	100%	8	0.02			
66 kV FATEHPURBERI GRID	SFTPR109	11KV FDR O/G TO ASOLA VILLAGE	TP-SKT439A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.02			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT903A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.02			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SKT779A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SKT792A-1	100	COMMERCIAL		Functional	100%	2	0.01			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SKT197A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.01			

66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	2520FBR-SKT605A-	100	MIXED		Functional	100%	1	0.01			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	2520FBR-SK0102A-	100	RESIDENTIAL		Functional	100%	6	0.01			
66 kV FATEHPURBERI GRID	SFTPR106	11KV FDR O/G TO GATE NO.-2-C RADHA SWAMI	2520FBR-SK0139A-	100	RESIDENTIAL	AMR	Functional	100%	6	0.01			
66 kV FATEHPURBERI GRID	SFTPR108	11KV FDR O/G TO FATEHPUR BERI C.C	TP-SKT148A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	2520FBR-SKT605A-	100	MIXED	AMR	Functional	100%	1	0.01			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT781A-1	100	RESIDENTIAL	AMR	Functional	100%	11	0.01			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SKT780A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SKT766A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.00			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SKT528A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT782A-1	100	COMMERCIAL	AMR	Functional	100%	22	0.00			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TG-SKT192A-1	630	RESIDENTIAL	AMR	Functional	100%	1557	0.92	3.72	0.28	7.04%
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	2520FBR-SK0130A-	630	RESIDENTIAL	AMR	Functional	100%	92	0.85			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TG-SKT193A-1	630	COMMERCIAL	AMR	Functional	100%	1471	0.76			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT138A-1	630	RESIDENTIAL	AMR	Functional	100%	968	0.54			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SK0085A-1	400	RESIDENTIAL	AMR	Functional	100%	39	0.46			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TG-SKT137A-1	400	COMMERCIAL	AMR	Functional	100%	913	0.32			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT140A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.09			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	2520FBR-SK0117A-	400	RESIDENTIAL	AMR	Functional	100%	77	0.04			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT441A-1	400	RESIDENTIAL	AMR	Functional	100%	60	0.01			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT908A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.01			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT440A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.00			
66 kV FATEHPURBERI GRID	SFTPR103	11KV FDR O/G TO ANANT RAJ	SK-HVD010A-2	2980	COMMERCIAL		Functional	100%	0	1.32	3.15	0.14	4.15%
66 kV FATEHPURBERI GRID	SFTPR103	11KV FDR O/G TO ANANT RAJ	SK-HVD010A-1	1260	COMMERCIAL		Functional	100%	1696	0.79			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT433A-1	630	COMMERCIAL	AMR	Functional	100%	75	0.51			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	2520JPR-SK0178A-	400	RESIDENTIAL	AMR	Functional	100%	31	0.17			
66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	TG-SKT922A-1	630	COMMERCIAL	AMR	Functional	100%	7	0.13			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TG-SKT070A-1	400	COMMERCIAL	AMR	Functional	100%	63	0.11			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	2520FBR-SK0142A-	400	RESIDENTIAL	AMR	Functional	100%	99	0.09			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT068A-1	400	COMMERCIAL	AMR	Functional	100%	61	0.07			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT156A-1	100	RESIDENTIAL		Functional	100%	3	0.03			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT139A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT951A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV FATEHPURBERI GRID	SFTPR103	11KV FDR O/G TO ANANT RAJ	TP-SKT947A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	2520FBR-SK0154A-	400	RESIDENTIAL		Functional	100%	58	0.25	1.39	0.13	8.60%
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT201A-1	400	RESIDENTIAL	AMR	Functional	100%	51	0.21			

66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT063A-1	400	RESIDENTIAL		Functional	100%	40	0.18			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TG-SKT061A-1	400	COMMERCIAL	AMR	Functional	100%	24	0.11			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TG-SKT065A-1	400	RESIDENTIAL	AMR	Functional	100%	46	0.10			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT128A-1	400	COMMERCIAL	AMR	Functional	100%	25	0.08			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT123A-1	400	COMMERCIAL		Functional	100%	26	0.06			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT124A-1	100	COMMERCIAL	AMR	Functional	100%	30	0.05			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	2520FBR-SK0213A-	400	MIXED		Functional	100%	0	0.05			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT145A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.04			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT785A-1	100	RESIDENTIAL		Functional	100%	4	0.04			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT080A-1	400	RESIDENTIAL	AMR	Functional	100%	16	0.03			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT806A-1	100	COMMERCIAL		Functional	100%	2	0.03			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKTX07A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT127A-1	100	COMMERCIAL	AMR	Functional	100%	8	0.02			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SK0075A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.02			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT079A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT118A-1	100	COMMERCIAL		Functional	100%	1	0.02			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT968A-1	100	COMMERCIAL		Functional	100%	3	0.02			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT162A-1	100	COMMERCIAL	AMR	Functional	100%	50	0.02			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT973A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT761A-1	100	RESIDENTIAL	AMR	Functional	100%	24	0.02			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT880A-1	100	RESIDENTIAL		Functional	100%	0	0.02			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT784A-1	100	RESIDENTIAL	AMR	Functional	100%	25	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT788A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.01			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT146A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT786A-1	100	RESIDENTIAL	AMR	Functional	100%	51	0.01			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT790A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	2520JPR-SK0141A-	100	COMMERCIAL		Functional	100%	1	0.01			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT823A-1	100	RESIDENTIAL		Functional	100%	2	0.01			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT944A-1	100	COMMERCIAL	AMR	Functional	100%	38	0.01			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT126A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.00			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT117A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.00			
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	TG-SKT026A-1	990	RESIDENTIAL		Functional	100%	881	1.03	3.92	1.06	21.33%
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	TG-SKT059A-1	630	RESIDENTIAL	AMR	Functional	100%	383	0.62			
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	TG-SKT132A-1	630	COMMERCIAL	AMR	Functional	100%	444	0.46			

66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT121A-1	630	COMMERCIAL	AMR	Functional	100%	52	0.42			
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	TP-SKT636A-1	400	RESIDENTIAL	AMR	Functional	100%	171	0.32			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT131A-1	400	RESIDENTIAL	AMR	Functional	100%	209	0.31			
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	TG-SK0078A-1	990	RESIDENTIAL	AMR	Functional	100%	13	0.31			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT062A-1	400	COMMERCIAL	AMR	Functional	100%	125	0.25			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SK0076A-1	400	RESIDENTIAL	AMR	Functional	100%	4	0.22			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT235A-1	400	COMMERCIAL	AMR	Functional	100%	57	0.21			
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	TP-SKT130A-1	400	COMMERCIAL		Functional	100%	42	0.20			
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	TP-SKT011A-1	400	COMMERCIAL	AMR	Functional	100%	77	0.18			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT854A-1	400	RESIDENTIAL	AMR	Functional	100%	11	0.11			
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	TP-SKT083A-1	400	RESIDENTIAL	AMR	Functional	100%	151	0.10			
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	TP-SKT133A-1	100	COMMERCIAL		Functional	100%	5	0.03			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT855A-1	100	COMMERCIAL	AMR	Functional	100%	54	0.03			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT936A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	TP-SKT135A-1	100	COMMERCIAL	AMR	Functional	100%	5	0.03			
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	TP-SKT122A-1	100	COMMERCIAL	AMR	Functional	100%	45	0.03			
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	TP-SKT134A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	2520JPR-SK0159A-1	400	RESIDENTIAL	AMR	Functional	100%	10	0.02			
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	TP-SKT202A-1	400	COMMERCIAL	AMR	Functional	100%	3	0.01			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT969A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.01			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT157A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.01			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT767A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.01			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT610A-1	100	COMMERCIAL	AMR	Functional	100%	22	0.01			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT783A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.00			
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	TP-SKT550A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.00			
66 kV C - DOT GRID	SCDOT133	11KV FDR O/G TO RAJPUR KHURD	2520FBR-SK0225A-1	630	MIXED		Functional	100%	0	0.00			
66 kV FATEHPURBERI GRID	SFTPR110	11KV FDR O/G TO HARSWAROOP COLONY	TP-SKT503A-1	990	COMMERCIAL	AMR	Functional	100%	493	0.96	7.48	0.01	0.10%
66 kV FATEHPURBERI GRID	SFTPR110	11KV FDR O/G TO HARSWAROOP COLONY	TG-SKT504A-1	990	COMMERCIAL	AMR	Functional	100%	787	0.94			
66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	TG-SK0086A-1	990	RESIDENTIAL	AMR	Functional	100%	897	0.70			
66 kV FATEHPURBERI GRID	SFTPR110	11KV FDR O/G TO HARSWAROOP COLONY	TG-SKT219A-1	630	RESIDENTIAL		Functional	100%	290	0.69			
66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	2520FBR-SKT444A-1	990	COMMERCIAL	AMR	Functional	100%	3707	0.58			
66 kV FATEHPURBERI GRID	SFTPR110	11KV FDR O/G TO HARSWAROOP COLONY	TG-SKT956A-1	630	RESIDENTIAL	AMR	Functional	100%	127	0.54			
66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	TP-SKT060A-1	400	COMMERCIAL	AMR	Functional	100%	191	0.53			

66 kV FATEHPURBERI GRID	SFTPR108	11KV FDR O/G TO FATEHPUR BERI C.C	2520FBR-SKT023A-	990	COMMERCIAL	AMR	Functional	100%	688	0.45			
66 kV FATEHPURBERI GRID	SFTPR108	11KV FDR O/G TO FATEHPUR BERI C.C	2520FBR-SKT023A-	990	COMMERCIAL	AMR	Functional	100%	161	0.45			
66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	2520FBR-SKT444A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.36			
66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	TP-SKT985A-1	400	RESIDENTIAL	AMR	Functional	100%	64	0.31			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	2520FBR-SK0184A-	400	RESIDENTIAL	AMR	Functional	100%	176	0.15			
66 kV FATEHPURBERI GRID	SFTPR109	11KV FDR O/G TO ASOLA VILLAGE	2520FBR-SK0200A-	400	MIXED		Functional	100%	0	0.13			
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	2520FBR-SK0250A-	630	MIXED		Functional	100%	0	0.13			
66 kV FATEHPURBERI GRID	SFTPR110	11KV FDR O/G TO HARSWAROOP COLONY	2520FBR-SKT219A-	630	MIXED		Functional	100%	0	0.11			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	2520FBR-SK0220A-	400	MIXED		Functional	100%	0	0.10			
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	2520FBR-SK0171A-	400	RESIDENTIAL		Functional	100%	0	0.08			
66 kV FATEHPURBERI GRID	SFTPR105	11KV FDR O/G TO DERA BHATI	2520FBR-SK0217A-	630	MIXED		Functional	100%	0	0.07			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	2520FBR-SK0219A-	400	MIXED		Functional	100%	0	0.07			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	2520FBR-SK0179A-	400	RESIDENTIAL	AMR	Functional	100%	151	0.07			
66 kV FATEHPURBERI GRID	SFTPR121	11KV STR 100KVA STATION TRANSFORMER	2520FBR-STC119A-	400	COMMERCIAL	AMR	Functional	100%	0	0.03			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	2520FBR-SK0199A-	400	RESIDENTIAL		Functional	100%	0	0.02			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	2520FBR-SK0190A-	100	MIXED		Functional	100%	0	0.01			
66 kV C - DOT GRID	SCDOT133	11KV FDR O/G TO RAJPUR KHURD	2520FBR-SK0251A-	630	MIXED		Functional	100%	0	0.00			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT209A-1	400	COMMERCIAL		Functional	100%	60	0.26	1.41	0.01	1.02%
66 kV FATEHPURBERI GRID	SFTPR106	11KV FDR O/G TO GATE NO.-2-C RADHA SWAMI	TP-SKT520A-1	400	RESIDENTIAL	AMR	Functional	100%	101	0.24			
66 kV FATEHPURBERI GRID	SFTPR106	11KV FDR O/G TO GATE NO.-2-C RADHA SWAMI	TG-SKT142A-1	400	RESIDENTIAL		Functional	100%	842	0.21			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT081A-1	400	COMMERCIAL		Functional	100%	69	0.20			
66 kV FATEHPURBERI GRID	SFTPR106	11KV FDR O/G TO GATE NO.-2-C RADHA SWAMI	TP-SKT457A-1	400	RESIDENTIAL	AMR	Functional	100%	159	0.12			
66 kV FATEHPURBERI GRID	SFTPR106	11KV FDR O/G TO GATE NO.-2-C RADHA SWAMI	TG-SKT066A-1	400	RESIDENTIAL		Functional	100%	17	0.07			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SK0009A-1	250	RESIDENTIAL	AMR	Functional	100%	4	0.06			
66 kV FATEHPURBERI GRID	SFTPR106	11KV FDR O/G TO GATE NO.-2-C RADHA SWAMI	TP-SKT634A-2	250	MIXED		Functional	100%	0	0.06			
66 kV FATEHPURBERI GRID	SFTPR106	11KV FDR O/G TO GATE NO.-2-C RADHA SWAMI	TP-SKT521A-1	250	RESIDENTIAL	AMR	Functional	100%	10	0.04			
66 kV FATEHPURBERI GRID	SFTPR106	11KV FDR O/G TO GATE NO.-2-C RADHA SWAMI	TP-SKT634A-1	250	RESIDENTIAL	AMR	Functional	100%	30	0.04			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT635A-1	250	RESIDENTIAL	AMR	Functional	100%	32	0.03			
66 kV FATEHPURBERI GRID	SFTPR106	11KV FDR O/G TO GATE NO.-2-C RADHA SWAMI	TP-SKT987A-1	100	RESIDENTIAL		Functional	100%	18	0.03			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SKT812A-1	100	COMMERCIAL		Functional	100%	1	0.02			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT141A-1	400	COMMERCIAL	AMR	Functional	100%	11	0.02			
66 kV FATEHPURBERI GRID	SFTPR114	11KV FDR O/G TO ASOLA BANDH	TP-SKT191A-2	100	RESIDENTIAL		Functional	100%	2	0.01			
66 kV FATEHPURBERI GRID	SFTPR106	11KV FDR O/G TO GATE NO.-2-C RADHA SWAMI	TP-SKT787A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.01			
66 kV FATEHPURBERI GRID	SFTPR106	11KV FDR O/G TO GATE NO.-2-C RADHA SWAMI	TP-SKT544A-1	100	RESIDENTIAL		Functional	100%	6	0.00			

66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	TP-SKT965A-1	400	COMMERCIAL	AMR	Functional	100%	56	0.25	2.02	0.26	11.45%
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT213A-1	400	RESIDENTIAL	AMR	Functional	100%	3	0.21			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT773A-1	400	RESIDENTIAL		Functional	100%	34	0.18			
66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	TP-SKT200A-1	400	COMMERCIAL	AMR	Functional	100%	60	0.17			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT151A-1	100	COMMERCIAL	AMR	Functional	100%	16	0.12			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT155A-2	100	COMMERCIAL	AMR	Functional	100%	5	0.11			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TG-SKT069A-1	400	COMMERCIAL	AMR	Functional	100%	28	0.08			
66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	TP-SKT153A-1	400	COMMERCIAL		Functional	100%	16	0.08			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT206A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.06			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT848A-1	100	COMMERCIAL		Functional	100%	3	0.06			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT917A-1	250	COMMERCIAL	AMR	Functional	100%	2	0.05			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	520FBR-SKT160A-	100	RESIDENTIAL	AMR	Functional	100%	0	0.04			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	520FBR-SKT775A-	100	RESIDENTIAL	AMR	Functional	100%	1	0.04			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT058A-1	100	RESIDENTIAL	AMR	Functional	100%	10	0.04			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT791A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.04			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT428A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.04			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT152A-1	100	COMMERCIAL	AMR	Functional	100%	5	0.03			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT431A-1	100	COMMERCIAL	AMR	Functional	100%	5	0.03			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT778A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT630A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.03			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT889A-1	100	RESIDENTIAL	AMR	Functional	100%	15	0.03			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT830A-1	100	RESIDENTIAL	AMR	Functional	100%	22	0.03			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT751A-1	100	COMMERCIAL	AMR	Functional	100%	14	0.03			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT918A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT811A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.03			
66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	TP-SKT454A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.03			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	520FBR-SK0208A-	630	MIXED		Functional	100%	0	0.02			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT010A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TG-SKT885A-1	100	RESIDENTIAL		Functional	100%	2	0.02			
66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	520FBR-SK0132A-	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	TP-SKT825A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT819A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT584A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT771A-1	100	COMMERCIAL		Functional	100%	1	0.02			
66 kV FATEHPURBERI GRID	SFTPR112	11KV FDR O/G RUMALO DEVI	TP-SKT545A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.02			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT856A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01			
66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	TP-SKT628A-1	100	COMMERCIAL	AMR	Functional	100%	15	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT777A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKTX10A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT860A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	TP-SKT853A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT413A-1	100	RESIDENTIAL		Functional	100%	1	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	520FBR-SKT775A-	100	RESIDENTIAL	AMR	Functional	100%	0	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT818A-1	100	COMMERCIAL	AMR	Functional	100%	5	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT207A-1	100	RESIDENTIAL		Functional	100%	2	0.01			

66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT768A-1	100	RESIDENTIAL	AMR	Functional	100%	174	0.01			
66 kV FATEHPURBERI GRID	SFTPR111	11KV FDR O/G TO BHATI MINES	TP-SKT548A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	2520FBR-SKT431A-1	100	MIXED	AMR	Functional	100%	1	0.01			
66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	TP-SKT429A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT772A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT861A-1	100	RESIDENTIAL	AMR	Functional	100%	8	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SK0019A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT911A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT546A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT432A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT632A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT430A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT218A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	2520FBR-SKTX32A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TG-SKT896A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT437A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.00			
66 kV FATEHPURBERI GRID	SFTPR107	11KV FDR O/G TO SHANTI KHANNA	TP-SKT048A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.00			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT776A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.00			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT547A-1	100	COMMERCIAL		Functional	100%	0	0.00			
66 kV C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJSWARAJ)	TP-SKT160A-2	100	RESIDENTIAL	AMR	Functional	100%	5	0.00			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT458A-1	400	RESIDENTIAL	AMR	Functional	100%	856	0.34	1.84	0.12	6.26%
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT203A-1	250	RESIDENTIAL	AMR	Functional	100%	11	0.26			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	2520FBR-SK0125A-1	400	RESIDENTIAL	AMR	Functional	100%	4	0.19			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT165A-1	400	COMMERCIAL		Functional	100%	95	0.19			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	2520FBR-SK0126A-1	400	RESIDENTIAL	AMR	Functional	100%	6	0.15			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT166A-1	400	COMMERCIAL	AMR	Functional	100%	38	0.12			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT527A-1	400	COMMERCIAL	AMR	Functional	100%	7	0.10			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT988A-1	250	RESIDENTIAL		Functional	100%	139	0.09			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT072A-1	400	RESIDENTIAL	AMR	Functional	100%	15	0.08			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT125A-1	400	COMMERCIAL	AMR	Functional	100%	49	0.08			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT170A-1	400	RESIDENTIAL	AMR	Functional	100%	32	0.08			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT169A-1	100	RESIDENTIAL		Functional	100%	2	0.06			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT524A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.04			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT168A-1	100	RESIDENTIAL	AMR	Functional	100%	79	0.04			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TG-SKT119A-1	400	RESIDENTIAL		Functional	100%	16	0.03			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT438A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.02			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT789A-1	100	COMMERCIAL		Functional	100%	15	0.02			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT942A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.02			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT163A-1	100	COMMERCIAL	AMR	Functional	100%	51	0.01			

66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT625A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.01			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT150A-1	100	RESIDENTIAL	AMR	Functional	100%	164	0.01			
66 kV FATEHPURBERI GRID	SFTPR116	11KV FDR O/G TO CHADDA MURGI	TP-SKT523A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT833A-1	100	COMMERCIAL	AMR	Functional	100%	4	0.01			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	520FBR-SK0127A-	400	RESIDENTIAL	AMR	Functional	100%	3	0.01			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT167A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.00			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT623A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.00			
66 kV FATEHPURBERI GRID	SFTPR103	11KV FDR O/G TO ANANT RAJ	SK-HVD011A-2	2275	COMMERCIAL		Functional	100%	0	0.77	1.32	0.01	1.07%
66 kV FATEHPURBERI GRID	SFTPR103	11KV FDR O/G TO ANANT RAJ	SK-HVD011A-1	1255	COMMERCIAL		Functional	100%	971	0.25			
66 kV FATEHPURBERI GRID	SFTPR103	11KV FDR O/G TO ANANT RAJ	TG-SKT540A-1	250	RESIDENTIAL	AMR	Functional	100%	11	0.18			
66 kV FATEHPURBERI GRID	SFTPR103	11KV FDR O/G TO ANANT RAJ	520FBR-SKT530A-	100	MIXED	AMR	Functional	100%	0	0.03			
66 kV FATEHPURBERI GRID	SFTPR104	11KV FDR ANSAL FARMS	TP-SKT013A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.03			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TP-SKT306A-1	100	COMMERCIAL		Functional	100%	19	0.02			
66 kV FATEHPURBERI GRID	SFTPR103	11KV FDR O/G TO ANANT RAJ	TP-SKT394A-2	100	COMMERCIAL		Functional	100%	2	0.02			
66 kV FATEHPURBERI GRID	SFTPR109	11KV FDR O/G TO ASOLA VILLAGE	520FBR-SKT886A-	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV FATEHPURBERI GRID	SFTPR109	11KV FDR O/G TO ASOLA VILLAGE	TP-SKT006A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV FATEHPURBERI GRID	SFTPR122	11KV FDR O/G TO SHANIDHAM ROAD	TG-SKT659A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kV C - DOT GRID	SCDOT117	11KV FDR O/G PURANA AYA NAGAR	TP-SKT471A-1	990	RESIDENTIAL	AMR	Functional	100%	798	0.77	1.55	0.04	2.49%
66 kV C - DOT GRID	SCDOT117	11KV FDR O/G PURANA AYA NAGAR	TP-SKT472A-1	990	RESIDENTIAL	AMR	Functional	100%	456	0.60			
66 kV C - DOT GRID	SCDOT108	11KV FDR O/G ASHWANI KUMAR MEHRA HOTEL	520AYN-SK0209A-	400	MIXED		Functional	100%	0	0.14			
33 kV ANDHERIA BAGH GRID	SABAG102	11KV FDR O/G TO JONAPUR	TP-SKT827A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.05			
33 kV ANDHERIA BAGH GRID	SABAG102	11KV FDR O/G TO JONAPUR	TP-SKT675A-1	100	RESIDENTIAL	AMR	Functional	100%	14	0.01			
33 kV ANDHERIA BAGH GRID	SABAG102	11KV FDR O/G TO JONAPUR	TP-SKT846A-1	100	COMMERCIAL	AMR	Functional	100%	7	0.01			
66 kV C - DOT GRID	SCDOT117	11KV FDR O/G PURANA AYA NAGAR	TP-SKT674A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
33 kV ANDHERIA BAGH GRID	SABAG105	11KV FDR O/G TO N.B.C.C	TP-SKT480A-1	990	COMMERCIAL	AMR	Functional	100%	909	1.06	8.10	0.38	4.45%
66 kV FATEHPURBERI GRID	SFTPR102	11KV FDR OG TO G BLK AYA NAGAR	TG-SKT046A-1	990	COMMERCIAL		Functional	100%	958	0.97			
66 kV C - DOT GRID	SCDOT126	11KV FDR O/G NTRO CKT.-2	TP-SK0035A-1	990	RESIDENTIAL	AMR	Functional	100%	1051	0.77			
66 kV C - DOT GRID	SCDOT108	11KV FDR O/G ASHWANI KUMAR MEHRA HOTEL	TG-SK0034A-1	990	RESIDENTIAL	AMR	Functional	100%	982	0.69			
66 kV C - DOT GRID	SCDOT108	11KV FDR O/G ASHWANI KUMAR MEHRA HOTEL	TP-SKT498A-1	630	RESIDENTIAL	AMR	Functional	100%	833	0.63			
66 kV FATEHPURBERI GRID	SFTPR102	11KV FDR OG TO G BLK AYA NAGAR	TP-SKT484A-2	990	RESIDENTIAL	AMR	Functional	100%	974	0.58			
66 kV C - DOT GRID	SCDOT126	11KV FDR O/G NTRO CKT.-2	TP-SKT485A-1	990	COMMERCIAL		Functional	100%	965	0.55			
66 kV FATEHPURBERI GRID	SFTPR102	11KV FDR OG TO G BLK AYA NAGAR	TP-SKT486A-1	990	RESIDENTIAL	AMR	Functional	100%	483	0.44			
66 kV C - DOT GRID	SCDOT108	11KV FDR O/G ASHWANI KUMAR MEHRA HOTEL	TP-SKT986A-1	990	COMMERCIAL	AMR	Functional	100%	344	0.41			
66 kV C - DOT GRID	SCDOT108	11KV FDR O/G ASHWANI KUMAR MEHRA HOTEL	TG-SKT047A-1	990	RESIDENTIAL	AMR	Functional	100%	503	0.40			
66 kV C - DOT GRID	SCDOT126	11KV FDR O/G NTRO CKT.-2	TP-SK0001A-1	630	RESIDENTIAL	AMR	Functional	100%	687	0.39			
66 kV FATEHPURBERI GRID	SFTPR102	11KV FDR OG TO G BLK AYA NAGAR	TP-SKT487A-1	400	RESIDENTIAL	AMR	Functional	100%	413	0.35			
66 kV FATEHPURBERI GRID	SFTPR102	11KV FDR OG TO G BLK AYA NAGAR	TP-SKT481A-1	990	RESIDENTIAL		Functional	100%	378	0.26			
66 kV FATEHPURBERI GRID	SFTPR102	11KV FDR OG TO G BLK AYA NAGAR	TP-SKT483A-1	400	RESIDENTIAL	AMR	Functional	100%	289	0.25			

33 KV ANDHERIA BAGH GRID	SABAG105	11KV FDR O/G TO N.B.C.C	TP-SKT420A-1	630	RESIDENTIAL	AMR	Functional	100%	226	0.24			
66 kV FATEHPURBERI GRID	SFTPR102	11KV FDR OG TO G BLK AYA NAGAR	TP-SKT482A-1	400	RESIDENTIAL	AMR	Functional	100%	435	0.21			
66 kV C - DOT GRID	SCDOT108	11KV FDR O/G ASHWANI KUMAR MEHRA HOTEL	TP-SKT474A-1	400	RESIDENTIAL	AMR	Functional	100%	214	0.15			
66 kV FATEHPURBERI GRID	SFTPR102	11KV FDR OG TO G BLK AYA NAGAR	TP-SKT484A-1	400	RESIDENTIAL	AMR	Functional	100%	316	0.12			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT189A-1	400	COMMERCIAL	AMR	Functional	100%	283	0.14	0.47	0.00	0.12%
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	2520JPR-SK0187A-1	990	RESIDENTIAL		Functional	100%	0	0.10			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT190A-1	400	COMMERCIAL	AMR	Functional	100%	90	0.07			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT691A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.04			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAI PUR POLICE STN	2520JPR-SK0133A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT832A-1	100	COMMERCIAL	AMR	Functional	100%	23	0.02			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT850A-1	100	COMMERCIAL		Functional	100%	4	0.02			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT820A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT051A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TG-SKT933A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SK0055A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT953A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.01			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT050A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT212A-1	100	COMMERCIAL		Functional	100%	2	0.00			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TG-SKT038A-1	990	RESIDENTIAL	AMR	Functional	100%	780	0.90	4.14	0.05	1.29%
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT491A-1	630	RESIDENTIAL	AMR	Functional	100%	1875	0.48			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	2520JPR-SKT115A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.48			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT114A-1	630	RESIDENTIAL	AMR	Functional	100%	182	0.47			
66 kV C - DOT GRID	SCDOT120	11KV FDR O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	TG-SKT425A-1	400	RESIDENTIAL	AMR	Functional	100%	518	0.35			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT422A-1	990	RESIDENTIAL	AMR	Functional	100%	290	0.33			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT003A-1	400	RESIDENTIAL	AMR	Functional	100%	423	0.27			
66 kV C - DOT GRID	SCDOT120	11KV FDR O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	TP-SKT470A-1	400	RESIDENTIAL	AMR	Functional	100%	372	0.25			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT493A-1	250	COMMERCIAL	AMR	Functional	100%	11	0.19			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT115A-1	400	RESIDENTIAL	AMR	Functional	100%	56	0.16			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT204A-1	100	COMMERCIAL		Functional	100%	29	0.09			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	2520JPR-SK0136A-1	250	RESIDENTIAL	AMR	Functional	100%	11	0.07			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT226A-1	400	RESIDENTIAL	AMR	Functional	100%	34	0.05			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	2520JPR-SK0185A-1	400	RESIDENTIAL		Functional	100%	187	0.04			
66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	2520JPR-SK0135A-1	250	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT492A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.02			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT615A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.01			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT188A-1	100	RESIDENTIAL		Functional	100%	9	0.01			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT490A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			

66 kV FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	TP-SKT423A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00	7.80	0.76	8.86%
66 kV C - DOT GRID	SCDOT112	11KV FDR O/G TO SULTANPUR COLONY	TI-SKT022A-2	990	RESIDENTIAL	AMR	Functional	100%	1387	0.92			
66 kV C - DOT GRID	SCDOT112	11KV FDR O/G TO SULTANPUR COLONY	TP-SKT053A-1	990	COMMERCIAL	AMR	Functional	100%	39	0.88			
66 kV C - DOT GRID	SCDOT112	11KV FDR O/G TO SULTANPUR COLONY	TI-SKT022A-1	990	RESIDENTIAL	AMR	Functional	100%	1720	0.81			
66 kV C - DOT GRID	SCDOT112	11KV FDR O/G TO SULTANPUR COLONY	TG-SKT036A-1	630	RESIDENTIAL	AMR	Functional	100%	135	0.73			
66 kV C - DOT GRID	SCDOT134	11KV FDR CENTRUM MALL SULTANPUR	2520JPR-SKT196A-3	990	RESIDENTIAL		Functional	100%	0	0.51			
66 kV C - DOT GRID	SCDOT110	11KV O/G TO M.E.S	TG-SKT826A-1	990	RESIDENTIAL	AMR	Functional	100%	173	0.50			
66 kV C - DOT GRID	SCDOT112	11KV FDR O/G TO SULTANPUR COLONY	2520JPR-SKT500A-3	630	RESIDENTIAL		Functional	100%	468	0.43			
66 kV C - DOT GRID	SCDOT134	11KV FDR CENTRUM MALL SULTANPUR	2520JPR-SKT196A-2	990	RESIDENTIAL	AMR	Functional	100%	300	0.40			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	2520JPR-SK0168A-3	990	RESIDENTIAL	AMR	Functional	100%	31	0.39			
66 kV C - DOT GRID	SCDOT134	11KV FDR CENTRUM MALL SULTANPUR	2520JPR-SKT196A-3	990	RESIDENTIAL		Functional	100%	46	0.37			
66 kV C - DOT GRID	SCDOT134	11KV FDR CENTRUM MALL SULTANPUR	2520JPR-SKT196A-4	630	RESIDENTIAL		Functional	100%	0	0.31			
66 kV C - DOT GRID	SCDOT110	11KV O/G TO M.E.S	TG-SKT669A-1	630	COMMERCIAL	AMR	Functional	100%	117	0.28			
66 kV C - DOT GRID	SCDOT112	11KV FDR O/G TO SULTANPUR COLONY	TP-SKT042A-1	400	RESIDENTIAL	AMR	Functional	100%	119	0.28			
66 kV C - DOT GRID	SCDOT110	11KV O/G TO M.E.S	TP-SKT690A-1	400	RESIDENTIAL	AMR	Functional	100%	266	0.28			
66 kV C - DOT GRID	SCDOT112	11KV FDR O/G TO SULTANPUR COLONY	2520JPR-SKT500A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.24			
66 kV C - DOT GRID	SCDOT110	11KV O/G TO M.E.S	2520JPR-SKT826A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.22			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT102A-1	400	RESIDENTIAL	AMR	Functional	100%	43	0.19			
66 kV C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	2520JPR-SKT090A-3	630	RESIDENTIAL	AMR	Functional	100%	0	0.18			
66 kV C - DOT GRID	SCDOT110	11KV O/G TO M.E.S	TP-SK0079A-1	400	RESIDENTIAL	AMR	Functional	100%	187	0.17			
66 kV C - DOT GRID	SCDOT112	11KV FDR O/G TO SULTANPUR COLONY	TG-SKT877A-1	630	RESIDENTIAL	AMR	Functional	100%	30	0.16			
66 kV C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	2520JPR-SKT090A-3	400	RESIDENTIAL	AMR	Functional	100%	56	0.12			
66 kV C - DOT GRID	SCDOT122	11KV FDR O/G I.I.P.M NO.-2	TP-SKT966A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.05			
66 kV C - DOT GRID	SCDOT122	11KV FDR O/G I.I.P.M NO.-2	TG-SKT930A-1	100	RESIDENTIAL	AMR	Functional	100%	10	0.04			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT971A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.03			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT928A-1	100	RESIDENTIAL		Functional	100%	1	0.02			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT943A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.02			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT411A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT931A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kV C - DOT GRID	SCDOT134	11KV FDR CENTRUM MALL SULTANPUR	TP-SKT021A-1	630	RESIDENTIAL	AMR	Functional	100%	855	0.00			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TG-SKT037A-1	990	RESIDENTIAL	AMR	Functional	100%	695	0.63	1.51	0.16	9.55%
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT103A-1	630	RESIDENTIAL	AMR	Functional	100%	54	0.37			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TG-SKT106A-1	400	RESIDENTIAL	AMR	Functional	100%	52	0.27			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT101A-1	400	RESIDENTIAL	AMR	Functional	100%	74	0.20			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT107A-1	400	RESIDENTIAL	AMR	Functional	100%	23	0.20			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT871A-1	100	RESIDENTIAL		Functional	100%	24	0.00			
66 kV C - DOT GRID	SCDOT120	11KV FDR O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	TG-SKT513A-1	990	RESIDENTIAL	AMR	Functional	100%	416	0.95	5.05	0.29	5.46%
66 kV C - DOT GRID	SCDOT120	11KV FDR O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	TI-SKT097A-1	990	RESIDENTIAL		Functional	100%	594	0.83			
66 kV C - DOT GRID	SCDOT622	11KV FDR PANDIT MOHALLA VIA GADAIPUR CHECK POST	TP-SKT108A-1	990	RESIDENTIAL	AMR	Functional	100%	424	0.82			
66 kV C - DOT GRID	SCDOT120	11KV FDR O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	TG-SKT221A-1	990	RESIDENTIAL	AMR	Functional	100%	832	0.81			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT489A-1	630	RESIDENTIAL	AMR	Functional	100%	544	0.42			
66 kV C - DOT GRID	SCDOT120	11KV FDR O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	TI-SKT035A-1	400	RESIDENTIAL	AMR	Functional	100%	175	0.35			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	2520JPR-SK0111A-3	630	RESIDENTIAL	AMR	Functional	100%	203	0.25			
66 kV C - DOT GRID	SCDOT120	11KV FDR O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	TP-SKT110A-1	400	RESIDENTIAL	AMR	Functional	100%	160	0.21			
66 kV C - DOT GRID	SCDOT120	11KV FDR O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	TP-SKT096A-1	400	RESIDENTIAL	AMR	Functional	100%	61	0.15			
66 kV C - DOT GRID	SCDOT622	11KV FDR PANDIT MOHALLA VIA GADAIPUR CHECK POST	TP-SKT112A-1	400	RESIDENTIAL	AMR	Functional	100%	36	0.12			

66 kv C - DOT GRID	SCDOT120	11KV FDR O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	2520JPR-SK0204A-1	400	MIXED		Functional	100%	0	0.11			
66 kv C - DOT GRID	SCDOT622	11KV FDR PANDIT MOHALLA VIA GADAIPUR CHECK POST	TP-SKT186A-1	400	RESIDENTIAL	AMR	Functional	100%	25	0.08			
66 kv C - DOT GRID	SCDOT120	11KV FDR O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	TP-SKT185A-1	100	RESIDENTIAL	AMR	Functional	100%	11	0.06			
66 kv C - DOT GRID	SCDOT120	11KV FDR O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	TP-SKT113A-1	400	RESIDENTIAL		Functional	100%	17	0.05			
66 kv C - DOT GRID	SCDOT131	11KV FDR RMU AT BANDH ROAD (RAJWARAJ)	2520JPR-SK0143A-1	100	RESIDENTIAL		Functional	100%	3	0.04			
66 kv C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TG-SKT208A-2	100	RESIDENTIAL	AMR	Functional	100%	0	0.03			
66 kv C - DOT GRID	SCDOT120	11KV FDR O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	TP-SK0008A-1	250	RESIDENTIAL	AMR	Functional	100%	16	0.02			
66 kv C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT560A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02			
66 kv FATEHPURBERI GRID	SFTPR113	11KV FDR RSSB SSTN NO-1	2520JPR-SK0318A-1	100	RESIDENTIAL		Functional	100%	0	0.01			
66 kv C - DOT GRID	SCDOT120	11KV FDR O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	TP-SKT851A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kv C - DOT GRID	SCDOT622	11KV FDR PANDIT MOHALLA VIA GADAIPUR CHECK POST	TP-SKT957A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kv C - DOT GRID	SCDOT622	11KV FDR PANDIT MOHALLA VIA GADAIPUR CHECK POST	TP-SKT187A-1	100	RESIDENTIAL		Functional	100%	3	0.01			
66 kv C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TG-SKT208A-1	100	RESIDENTIAL	AMR	Functional	100%	90	0.01			
66 kv C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	2520JPR-SK0186A-1	400	RESIDENTIAL	AMR	Functional	100%	192	0.01			
66 kv C - DOT GRID	SCDOT122	11KV FDR O/G I.I.P.M NO.-2	520AYN-SK0221A-1	100	MIXED		Functional	100%	0	0.00			
66 kv C - DOT GRID	SCDOT117	11KV FDR O/G PURANA AYA NAGAR	TG-SKT019A-2	990	RESIDENTIAL	AMR	Functional	100%	303	0.95	6.13	0.41	6.25%
66 kv C - DOT GRID	SCDOT117	11KV FDR O/G PURANA AYA NAGAR	TG-SKT938A-1	1600	COMMERCIAL	AMR	Functional	100%	1359	0.90			
66 kv FATEHPURBERI GRID	SFTPR622	11KV FDR NICF VIA AYA NAGAR	TG-SKT116A-1	990	COMMERCIAL	AMR	Functional	100%	1108	0.74			
66 kv FATEHPURBERI GRID	SFTPR622	11KV FDR NICF VIA AYA NAGAR	TP-SK0028A-1	990	RESIDENTIAL	AMR	Functional	100%	693	0.73			
66 kv C - DOT GRID	SCDOT126	11KV FDR O/G NTRO CKT.-2	TG-SKT505A-1	630	RESIDENTIAL		Functional	100%	565	0.59			
66 kv FATEHPURBERI GRID	SFTPR622	11KV FDR NICF VIA AYA NAGAR	TG-SKT421A-1	990	RESIDENTIAL		Functional	100%	654	0.59			
66 kv C - DOT GRID	SCDOT117	11KV FDR O/G PURANA AYA NAGAR	TG-SKT198A-1	630	RESIDENTIAL	AMR	Functional	100%	335	0.40			
66 kv C - DOT GRID	SCDOT136	11KV FDR O/G AIR FORCE ARJANGARH NO-2	TG-SKT019A-1	990	RESIDENTIAL		Functional	100%	526	0.36			
66 kv C - DOT GRID	SCDOT117	11KV FDR O/G PURANA AYA NAGAR	TG-SKT198A-2	630	RESIDENTIAL	AMR	Functional	100%	298	0.28			
66 kv C - DOT GRID	SCDOT108	11KV FDR O/G ASHWANI KUMAR MEHRA HOTEL	TP-SKT494A-1	630	RESIDENTIAL	AMR	Functional	100%	451	0.28			
66 kv C - DOT GRID	SCDOT108	11KV FDR O/G ASHWANI KUMAR MEHRA HOTEL	TP-SKT495A-1	400	RESIDENTIAL		Functional	100%	246	0.22			
66 kv C - DOT GRID	SCDOT117	11KV FDR O/G PURANA AYA NAGAR	TG-SKT938A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.16			
66 kv C - DOT GRID	SCDOT126	11KV FDR O/G NTRO CKT.-2	TG-SK0043A-1	630	RESIDENTIAL	AMR	Functional	100%	268	0.16			
66 kv C - DOT GRID	SCDOT108	11KV FDR O/G ASHWANI KUMAR MEHRA HOTEL	2520JPR-SK0140A-1	990	RESIDENTIAL	AMR	Functional	100%	155	0.14			
66 kv FATEHPURBERI GRID	SFTPR102	11KV FDR OG TO G BLK AYA NAGAR	TP-SKT111A-1	400	RESIDENTIAL	AMR	Functional	100%	23	0.05			
33 kv ANDHERIA BAGH GRID	SABAG105	11KV FDR O/G TO N.B.C.C	520AYN-SK0192A-1	250	MIXED		Functional	100%	0	0.00			
66 kv C - DOT GRID	SCDOT122	11KV FDR O/G I.I.P.M NO.-2	TP-SKT184A-1	400	COMMERCIAL		Functional	100%	35	0.27	0.72	0.11	12.96%
66 kv FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT205A-1	400	RESIDENTIAL		Functional	100%	4	0.15			
66 kv C - DOT GRID	SCDOT122	11KV FDR O/G I.I.P.M NO.-2	TP-SK0031A-1	400	RESIDENTIAL	AMR	Functional	100%	3	0.11			
66 kv C - DOT GRID	SCDOT122	11KV FDR O/G I.I.P.M NO.-2	TP-SKT109A-1	400	RESIDENTIAL	AMR	Functional	100%	35	0.08			
66 kv C - DOT GRID	SCDOT122	11KV FDR O/G I.I.P.M NO.-2	TP-SKT511A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.04			
66 kv C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT539A-1	100	RESIDENTIAL		Functional	100%	8	0.03			
66 kv C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT813A-1	100	RESIDENTIAL		Functional	100%	5	0.03			
66 kv C - DOT GRID	SCDOT122	11KV FDR O/G I.I.P.M NO.-2	TP-SKT627A-1	250	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kv C - DOT GRID	SCDOT122	11KV FDR O/G I.I.P.M NO.-2	TP-SKT752A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02			
66 kv C - DOT GRID	SCDOT122	11KV FDR O/G I.I.P.M NO.-2	TP-SKT905A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02			
66 kv C - DOT GRID	SCDOT122	11KV FDR O/G I.I.P.M NO.-2	TP-SKT678A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02			
66 kv C - DOT GRID	SCDOT122	11KV FDR O/G I.I.P.M NO.-2	TP-SKT676A-1	100	COMMERCIAL	AMR	Functional	100%	6	0.01			
66 kv C - DOT GRID	SCDOT122	11KV FDR O/G I.I.P.M NO.-2	TP-SKT512A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kv C - DOT GRID	SCDOT122	11KV FDR O/G I.I.P.M NO.-2	TP-SKT465A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			
66 kv FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT012A-1	400	RESIDENTIAL		Functional	100%	30	1.44	2.02	0.50	19.72%

66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TG-SKT099A-1	400	RESIDENTIAL	AMR	Functional	100%	46	0.23			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT104A-1	400	COMMERCIAL	AMR	Functional	100%	18	0.15			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT183A-1	400	COMMERCIAL	AMR	Functional	100%	22	0.12			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	2520JPR-SK0161A-1	630	RESIDENTIAL		Functional	100%	6	0.10			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT105A-1	400	RESIDENTIAL	AMR	Functional	100%	30	0.09			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	2520JPR-SK0160A-1	400	COMMERCIAL	AMR	Functional	100%	9	0.08			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT225A-1	400	COMMERCIAL	AMR	Functional	100%	23	0.08			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TG-SKT427A-1	400	RESIDENTIAL		Functional	100%	10	0.08			
66 kV C - DOT GRID	SCDOT128	11KV FDR I.I.P.M NO.-1	2520JPR-SK0147A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT100A-1	400	RESIDENTIAL	AMR	Functional	100%	7	0.03			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT852A-1	100	RESIDENTIAL	AMR	Functional	100%	8	0.02			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT914A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.01			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT666A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT828A-1	400	COMMERCIAL	AMR	Functional	100%	5	0.01			
66 kV C - DOT GRID	SCDOT120	11KV FDR O/G DLF GATE NO.-3 (RMU) BEDI JONAPUR	2520JPR-SK0149A-1	400	RESIDENTIAL	AMR	Functional	100%	5	0.01			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT665A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.01			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT664A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT950A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.00			
66 kV C - DOT GRID	SCDOT110	11KV O/G TO M.E.S	TP-SKT469A-1	630	COMMERCIAL		Functional	100%	49	0.17	0.56	0.01	1.17%
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT815A-1	100	RESIDENTIAL		Functional	100%	1	0.08			
66 kV C - DOT GRID	SCDOT110	11KV O/G TO M.E.S	TG-SKT388A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.05			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT997A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.04			
66 kV C - DOT GRID	SCDOT110	11KV O/G TO M.E.S	2520JPR-SKT467A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.04			
66 kV C - DOT GRID	SCDOT137	11KV FDR O/G AIR FORCE ARJANGARH NO-1	2520JPR-SK0134A-1	250	MIXED		Functional	100%	2	0.04			
66 kV C - DOT GRID	SCDOT110	11KV O/G TO M.E.S	TP-SKT466A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kV C - DOT GRID	SCDOT110	11KV O/G TO M.E.S	TP-SKT866A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.03			
66 kV C - DOT GRID	SCDOT110	11KV O/G TO M.E.S	TP-SKT683A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT679A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.02			
66 kV C - DOT GRID	SCDOT110	11KV O/G TO M.E.S	TP-SKT468A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.01			
66 kV C - DOT GRID	SCDOT110	11KV O/G TO M.E.S	TP-SKT670A-1	100	RESIDENTIAL		Functional	100%	1	0.01			
66 kV FATEHPURBERI GRID	SFTPR621	11KV FDR O/G TO RMU NR GADAIPUR POLICE STN	TP-SKT098A-1	400	RESIDENTIAL	AMR	Functional	100%	15	0.01			
66 kV C - DOT GRID	SCDOT125	11KV FDR O/G JONAPUR	TP-SKT662A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV C - DOT GRID	SCDOT110	11KV O/G TO M.E.S	TP-SKT467A-1	100	RESIDENTIAL	AMR	Functional	100%	21	0.00			
33 kV PUSHP VIHAR GRID	SPUSP108	11KV FDR O/G CHIRAG DELHI KHATTA	TG-SKT349A-2	1600	RESIDENTIAL	AMR	Functional	100%	1513	0.97	6.35	0.32	4.73%
33 kV MASJID MOTH GRID	SMMOT109	11KV FDR O/G CHIRAG DELHI KIOSK	TK-SKT347A-4	990	RESIDENTIAL	AMR	Functional	100%	0	0.83			
33 kV MASJID MOTH GRID	SMMOT119	11KV FDR O/G BALMIKI MANDIR CHIRAG DELHI	TG-SKT396A-1	990	RESIDENTIAL		Functional	100%	765	0.80			
33 kV PUSHP VIHAR GRID	SPUSP108	11KV FDR O/G CHIRAG DELHI KHATTA	TG-SKT349A-1	990	RESIDENTIAL	AMR	Functional	100%	530	0.70			
33 kV MASJID MOTH GRID	SMMOT109	11KV FDR O/G CHIRAG DELHI KIOSK	TK-SKT347A-1	990	RESIDENTIAL	AMR	Functional	100%	928	0.67			
33 kV MASJID MOTH GRID	SMMOT109	11KV FDR O/G CHIRAG DELHI KIOSK	TG-SKT352A-1	630	RESIDENTIAL		Functional	100%	478	0.60			
33 kV MASJID MOTH GRID	SMMOT109	11KV FDR O/G CHIRAG DELHI KIOSK	TK-SKT347A-2	990	RESIDENTIAL	AMR	Functional	100%	1288	0.55			
33 kV PUSHP VIHAR GRID	SPUSP108	11KV FDR O/G CHIRAG DELHI KHATTA	TG-SKT349A-3	1600	RESIDENTIAL	AMR	Functional	100%	819	0.51			
33 kV MASJID MOTH GRID	SMMOT109	11KV FDR O/G CHIRAG DELHI KIOSK	TG-SKT352A-2	630	RESIDENTIAL	AMR	Functional	100%	203	0.49			

33 kv MASJID MOTH GRID	SMMOT119	11kv FDR O/G BALMIKI MANDIR CHIRAG DELHI	TP-SKT417A-1	630	RESIDENTIAL	AMR	Functional	100%	506	0.33			
33 kv MASJID MOTH GRID	SMMOT109	11kv FDR O/G CHIRAG DELHI KIOSK	TP-SKT353A-1	400	RESIDENTIAL		Functional	100%	121	0.23			
33 kv D.C.SAKET GRID	SSAKT109	11KV FDR JAHAPANAH NO.-1 + MGF MALL VIA RMU NEAR GATE	TG-SKT386A-1	1000	RESIDENTIAL	AMR	Functional	100%	768	1.36	6.87	0.31	4.28%
33 kv SHIVALIK GRID	SSHIV120	11kv FDR O/G F-BLOCK MALVIYA NAGAR	TG-SKT332A-1	990	MIXED	AMR	Functional	100%	858	0.81			
33 kv PUSHP VIHAR GRID	SPUSP102	11kv FDR O/G MAX DEVIKA DEVI HOSPITAL	TG-SKT385A-3	990	RESIDENTIAL		Functional	100%	752	0.76			
33 kv D.C.SAKET GRID	SSAKT109	11KV FDR JAHAPANAH NO.-1 + MGF MALL VIA RMU NEAR GATE	TI-SKT333A-2	1600	RESIDENTIAL	AMR	Functional	100%	1358	0.73			
33 kv PUSHP VIHAR GRID	SPUSP102	11kv FDR O/G MAX DEVIKA DEVI HOSPITAL	TG-SKT385A-1	990	RESIDENTIAL		Functional	100%	438	0.62			
33 kv D.C.SAKET GRID	SSAKT109	11KV FDR JAHAPANAH NO.-1 + MGF MALL VIA RMU NEAR GATE	TI-SKT333A-1	990	RESIDENTIAL	AMR	Functional	100%	0	0.60			
33 kv D.C.SAKET GRID	SSAKT109	11KV FDR JAHAPANAH NO.-1 + MGF MALL VIA RMU NEAR GATE	TI-SKT387A-2	630	RESIDENTIAL	AMR	Functional	100%	476	0.57			
33 kv SHIVALIK GRID	SSHIV105	11kv FDR O/G TO 80-BLOCK MALVIYA NAGAR	TG-SKT377A-1	630	RESIDENTIAL	AMR	Functional	100%	633	0.52			
33 kv PUSHP VIHAR GRID	SPUSP102	11kv FDR O/G MAX DEVIKA DEVI HOSPITAL	TG-SKT385A-2	630	RESIDENTIAL		Functional	100%	947	0.49			
33 kv SHIVALIK GRID	SSHIV120	11kv FDR O/G F-BLOCK MALVIYA NAGAR	TG-SKT332A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.41			
33 kv D.C.SAKET GRID	SSAKT109	11KV FDR JAHAPANAH NO.-1 + MGF MALL VIA RMU NEAR GATE	TI-SKT387A-1	400	RESIDENTIAL	AMR	Functional	100%	271	0.32			
33 kv SHIVALIK GRID	SSHIV113	11kv FDR O/G TO COMP. CENTER MALVIYA NAGAR	TI-SKT326A-1	1600	RESIDENTIAL	AMR	Functional	100%	627	0.96	8.12	0.27	3.17%
33 kv ADCHINI GRID	SADCN119	11kv FDR O/G MALVIYA NGR. HOSPITAL	TG-SKT327A-3	1600	RESIDENTIAL	AMR	Functional	100%	619	0.90			
33 kv SHIVALIK GRID	SSHIV112	11kv FDR O/G TO RPS\SAIKH SARAI PHASE-1	TG-SKT340A-2	990	MIXED	AMR	Functional	100%	829	0.82			
33 kv ADCHINI GRID	SADCN119	11kv FDR O/G MALVIYA NGR. HOSPITAL	TG-SKT324A-1	990	RESIDENTIAL	AMR	Functional	100%	1104	0.74			
33 kv SHIVALIK GRID	SSHIV113	11kv FDR O/G TO COMP. CENTER MALVIYA NAGAR	TI-SKT326A-2	990	RESIDENTIAL	AMR	Functional	100%	751	0.71			
33 kv SHIVALIK GRID	SSHIV112	11kv FDR O/G TO RPS\SAIKH SARAI PHASE-1	TG-SKT340A-1	990	MIXED	AMR	Functional	100%	284	0.66			
33 kv SHIVALIK GRID	SSHIV105	11kv FDR O/G TO 80-BLOCK MALVIYA NAGAR	TI-SKT328A-2	990	RESIDENTIAL	AMR	Functional	100%	193	0.58			
33 kv SHIVALIK GRID	SSHIV105	11kv FDR O/G TO 80-BLOCK MALVIYA NAGAR	TG-SKT327A-2	990	RESIDENTIAL	AMR	Functional	100%	0	0.51			
33 kv SHIVALIK GRID	SSHIV113	11kv FDR O/G TO COMP. CENTER MALVIYA NAGAR	TG-SKT325A-1	990	RESIDENTIAL	AMR	Functional	100%	0	0.50			
33 kv ADCHINI GRID	SADCN119	11kv FDR O/G MALVIYA NGR. HOSPITAL	TG-SKT327A-1	990	RESIDENTIAL	AMR	Functional	100%	818	0.48			
33 kv SHIVALIK GRID	SSHIV105	11kv FDR O/G TO 80-BLOCK MALVIYA NAGAR	TI-SKT328A-1	990	RESIDENTIAL		Functional	100%	365	0.44			
33 kv ADCHINI GRID	SADCN119	11kv FDR O/G MALVIYA NGR. HOSPITAL	TG-SKT324A-2	990	RESIDENTIAL	AMR	Functional	100%	1845	0.41			
33 kv SHIVALIK GRID	SSHIV113	11kv FDR O/G TO COMP. CENTER MALVIYA NAGAR	TG-SKT325A-2	990	RESIDENTIAL		Functional	100%	1442	0.35			
33 kv SHIVALIK GRID	SSHIV105	11kv FDR O/G TO 80-BLOCK MALVIYA NAGAR	TG-SKT327A-4	630	RESIDENTIAL	AMR	Functional	100%	0	0.34			
33 kv PUSHP VIHAR GRID	SPUSP107	11kv FDR O/G KHIRKI BANDH	TG-SKT164A-2	1600	RESIDENTIAL	AMR	Functional	100%	0	0.89	4.85	0.61	11.20%
33 kv D.C.SAKET GRID	SSAKT111	11KV FDR DDA KHIRIKI	TI-SKT323A-1	990	RESIDENTIAL	AMR	Functional	100%	0	0.78			
33 kv PUSHP VIHAR GRID	SPUSP107	11kv FDR O/G KHIRKI BANDH	TG-SKT322A-1	990	RESIDENTIAL		Functional	100%	801	0.72			
33 kv D.C.SAKET GRID	SSAKT111	11KV FDR DDA KHIRIKI	TG-SKT920A-1	990	RESIDENTIAL	AMR	Functional	100%	620	0.71			
33 kv PUSHP VIHAR GRID	SPUSP107	11kv FDR O/G KHIRKI BANDH	520MVN-SKT322A	990	RESIDENTIAL		Functional	100%	325	0.58			
33 kv D.C.SAKET GRID	SSAKT111	11KV FDR DDA KHIRIKI	TI-SKT323A-2	990	RESIDENTIAL	AMR	Functional	100%	2297	0.56			
33 kv PUSHP VIHAR GRID	SPUSP107	11kv FDR O/G KHIRKI BANDH	TG-SKT164A-1	990	RESIDENTIAL	AMR	Functional	100%	815	0.50			
33 kv D.C.SAKET GRID	SSAKT111	11KV FDR DDA KHIRIKI	TI-SKT323A-3	990	RESIDENTIAL	AMR	Functional	100%	0	0.37			
33 kv PUSHP VIHAR GRID	SPUSP107	11kv FDR O/G KHIRKI BANDH	TG-SKT322A-2	630	RESIDENTIAL		Functional	100%	276	0.35			
33 kv SHIVALIK GRID	SSHIV102	11kv FDR O/G TO SARVO PRIYA APATMENT	520MVN-SKT616A	990	RESIDENTIAL	AMR	Functional	100%	0	0.84	9.39	0.22	2.30%
33 kv SHIVALIK GRID	SSHIV102	11kv FDR O/G TO SARVO PRIYA APATMENT	TG-SKT339A-2	990	RESIDENTIAL	AMR	Functional	100%	990	0.80			
33 kv SHIVALIK GRID	SSHIV112	11kv FDR O/G TO RPS\SAIKH SARAI PHASE-1	TG-SKT617A-1	990	MIXED	AMR	Functional	100%	380	0.74			
33 kv SHIVALIK GRID	SSHIV102	11kv FDR O/G TO SARVO PRIYA APATMENT	TG-SKT616A-1	990	MIXED	AMR	Functional	100%	816	0.70			
33 kv ADCHINI GRID	SADCN107	11kv FDR O/G 11KV MALVIYA NAGAR (VIA MMTCC COLONEY)	TI-SKT336A-2	990	MIXED		Functional	100%	271	0.67			
33 kv SHIVALIK GRID	SSHIV113	11kv FDR O/G TO COMP. CENTER MALVIYA NAGAR	TI-SKT336A-1	990	MIXED		Functional	100%	324	0.60			
33 kv ADCHINI GRID	SADCN107	11kv FDR O/G 11KV MALVIYA NAGAR (VIA MMTCC COLONEY)	TG-SKT334A-2	1600	RESIDENTIAL	AMR	Functional	100%	163	0.59			
33 kv SHIVALIK GRID	SSHIV103	11kv FDR O/G TO C-BLOCK SHIVALIK	TI-SKT358A-2	990	RESIDENTIAL		Functional	100%	182	0.58			
33 kv SHIVALIK GRID	SSHIV124	11kv FDR O/G NIL BLOCK MALVIYA NAGAR	TK-SKT329A-2	990	MIXED	AMR	Functional	100%	469	0.58			
33 kv SHIVALIK GRID	SSHIV124	11kv FDR O/G NIL BLOCK MALVIYA NAGAR	TK-SKT329A-1	990	MIXED	AMR	Functional	100%	226	0.46			
33 kv SHIVALIK GRID	SSHIV124	11kv FDR O/G NIL BLOCK MALVIYA NAGAR	TX-SKT335A-1	990	MIXED	AMR	Functional	100%	78	0.45			
33 kv SHIVALIK GRID	SSHIV124	11kv FDR O/G NIL BLOCK MALVIYA NAGAR	TX-SKT335A-2	990	MIXED	AMR	Functional	100%	923	0.42			
33 kv SHIVALIK GRID	SSHIV124	11kv FDR O/G NIL BLOCK MALVIYA NAGAR	TK-SKT329A-3	630	RESIDENTIAL		Functional	100%	0	0.41			
33 kv SHIVALIK GRID	SSHIV102	11kv FDR O/G TO SARVO PRIYA APATMENT	TX-SKT338A-1	990	RESIDENTIAL	AMR	Functional	100%	1154	0.41			

33 kv SHIVALIK GRID	SSHIV102	11kv FDR O/G TO SARVO PRIYA APATMENT	520MVN-SKT338A	630	RESIDENTIAL	AMR	Functional	100%	0	0.34			
33 kv SHIVALIK GRID	SSHIV103	11kv FDR O/G TO C-BLOCK SHIVALIK	TI-SKT358A-1	630	RESIDENTIAL	AMR	Functional	100%	224	0.32			
33 kv SHIVALIK GRID	SSHIV102	11kv FDR O/G TO SARVO PRIYA APATMENT	TG-SKT339A-1	400	RESIDENTIAL	AMR	Functional	100%	737	0.26			
33 kv SHIVALIK GRID	SSHIV102	11kv FDR O/G TO SARVO PRIYA APATMENT	520MVN-SKT616A	630	RESIDENTIAL		Functional	100%	0	0.25			
33 kv ADCHINI GRID	SADCN107	11kv FDR O/G 11KV MALVIYA NAGAR (VIA MMT COLONEY)	TG-SKT334A-1	990	MIXED	AMR	Functional	100%	279	0.11			
33 kv SHIVALIK GRID	SSHIV107	11kv STR 400kVA STATION TRANSFORMER	TG-SKT099A-1	400	COMMERCIAL		Functional	100%	33	0.08			
33 kv SHIVALIK GRID	SSHIV120	11kv FDR O/G F-BLOCK MALVIYA NAGAR	TI-SKT376A-2	990	RESIDENTIAL		Functional	100%	179	0.82	8.89	0.21	2.35%
33 kv SHIVALIK GRID	SSHIV122	11kv FDR O/G TO F-BLOCK (K) S/STN.MALVIYA NAGAR -2	TK-SKT378A-3	1000	MIXED		Functional	100%	597	0.71			
33 kv SHIVALIK GRID	SSHIV120	11kv FDR O/G F-BLOCK MALVIYA NAGAR	TG-SKT331A-2	990	MIXED	AMR	Functional	100%	1054	0.70			
33 kv PUSHP VIHAR GRID	SPUSP102	11kv FDR O/G MAX DEVIKA DEVI HOSPITAL	TG-SKT390A-1	990	MIXED		Functional	100%	331	0.67			
33 kv ADCHINI GRID	SADCN104	11kv FDR SHIVALIK A-BLOCK	TG-SKT379A-3	990	RESIDENTIAL		Functional	100%	0	0.65			
33 kv ADCHINI GRID	SADCN104	11kv FDR SHIVALIK A-BLOCK	TX-SKT389A-1	990	MIXED		Functional	100%	160	0.65			
33 kv SHIVALIK GRID	SSHIV109	11kv FDR O/G TO L-BLOCK M. NAGAR	TK-SKT330A-1	990	MIXED	AMR	Functional	100%	348	0.63			
33 kv SHIVALIK GRID	SSHIV122	11kv FDR O/G TO F-BLOCK (K) S/STN.MALVIYA NAGAR -2	TK-SKT378A-2	1000	MIXED	AMR	Functional	100%	506	0.60			
33 kv SHIVALIK GRID	SSHIV120	11kv FDR O/G F-BLOCK MALVIYA NAGAR	TG-SKT331A-1	990	MIXED		Functional	100%	493	0.56			
33 kv SHIVALIK GRID	SSHIV109	11kv FDR O/G TO L-BLOCK M. NAGAR	TG-SKT867A-1	630	COMMERCIAL	AMR	Functional	100%	30	0.49			
33 kv ADCHINI GRID	SADCN104	11kv FDR SHIVALIK A-BLOCK	TI-SKT379A-2	990	RESIDENTIAL		Functional	100%	1161	0.49			
33 kv SHIVALIK GRID	SSHIV109	11kv FDR O/G TO L-BLOCK M. NAGAR	TK-SKT330A-2	990	MIXED		Functional	100%	199	0.42			
33 kv ADCHINI GRID	SADCN104	11kv FDR SHIVALIK A-BLOCK	TI-SKT379A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.39			
33 kv SHIVALIK GRID	SSHIV103	11kv FDR O/G TO C-BLOCK SHIVALIK	TI-SKT376A-3	630	RESIDENTIAL	AMR	Functional	100%	0	0.30			
33 kv SHIVALIK GRID	SSHIV122	11kv FDR O/G TO F-BLOCK (K) S/STN.MALVIYA NAGAR -2	TK-SKT378A-1	630	MIXED	AMR	Functional	100%	0	0.27			
33 kv SHIVALIK GRID	SSHIV109	11kv FDR O/G TO L-BLOCK M. NAGAR	TK-SKT330A-3	990	MIXED		Functional	100%	275	0.23			
33 kv ADCHINI GRID	SADCN104	11kv FDR SHIVALIK A-BLOCK	TX-SKT389A-2	990	MIXED		Functional	100%	264	0.23			
33 kv SHIVALIK GRID	SSHIV120	11kv FDR O/G F-BLOCK MALVIYA NAGAR	TI-SKT376A-1	630	RESIDENTIAL		Functional	100%	509	0.17			
33 kv ADCHINI GRID	SADCN104	11kv FDR SHIVALIK A-BLOCK	520MVN-SKT389A	400	RESIDENTIAL		Functional	100%	0	0.13			
33 kv MASJID MOTH GRID	SMMOT103	11kv FDR O/G R.P.S SEKH SARAI PHASE-1	TP-SKT345A-2	1600	RESIDENTIAL		Functional	100%	728	1.04	5.37	0.16	2.98%
33 kv D.C.SAKET GRID	SSAKT111	11kv FDR DDA KHIRIKI	TG-SKT606A-1	990	MIXED	AMR	Functional	100%	437	0.53			
33 kv MASJID MOTH GRID	SMMOT103	11kv FDR O/G R.P.S SEKH SARAI PHASE-1	TI-SKT342A-3	990	RESIDENTIAL	AMR	Functional	100%	0	0.52			
33 kv SHIVALIK GRID	SSHIV127	11kv FDR O/G P-BLOCK MALVIYA NAGAR S/STN.	TG-SKT343A-1	990	MIXED	AMR	Functional	100%	1158	0.52			
33 kv MASJID MOTH GRID	SMMOT103	11kv FDR O/G R.P.S SEKH SARAI PHASE-1	TI-SKT342A-1	990	RESIDENTIAL	AMR	Functional	100%	108	0.49			
33 kv MASJID MOTH GRID	SMMOT103	11kv FDR O/G R.P.S SEKH SARAI PHASE-1	TP-SKT345A-1	990	RESIDENTIAL	AMR	Functional	100%	653	0.47			
33 kv SHIVALIK GRID	SSHIV127	11kv FDR O/G P-BLOCK MALVIYA NAGAR S/STN.	TG-SKT344A-1	630	RESIDENTIAL		Functional	100%	798	0.45			
33 kv SHIVALIK GRID	SSHIV127	11kv FDR O/G P-BLOCK MALVIYA NAGAR S/STN.	TG-SKT341A-1	990	MIXED	AMR	Functional	100%	522	0.45			
33 kv SHIVALIK GRID	SSHIV112	11kv FDR O/G TO RPS(SAIKH SARAI PHASE-1)	TI-SKT342A-2	990	RESIDENTIAL	AMR	Functional	100%	433	0.41			
33 kv SHIVALIK GRID	SSHIV127	11kv FDR O/G P-BLOCK MALVIYA NAGAR S/STN.	TG-SKT341A-2	990	MIXED	AMR	Functional	100%	321	0.36			
33 kv SHIVALIK GRID	SSHIV127	11kv FDR O/G P-BLOCK MALVIYA NAGAR S/STN.	TG-SKT344A-2	990	RESIDENTIAL		Functional	100%	192	0.29			
33 kv MASJID MOTH GRID	SMMOT101	11kv FDR O/G C-1 SFS SEKH SARAI PHASE-1	TI-SKT354A-2	1500	RESIDENTIAL		Functional	100%	1123	0.88	2.54	0.19	6.85%
33 kv MASJID MOTH GRID	SMMOT101	11kv FDR O/G C-1 SFS SEKH SARAI PHASE-1	TI-SKT354A-1	1500	RESIDENTIAL		Functional	100%	168	0.86			
33 kv MASJID MOTH GRID	SMMOT101	11kv FDR O/G C-1 SFS SEKH SARAI PHASE-1	TI-SKT356A-1	990	RESIDENTIAL	AMR	Functional	100%	329	0.21			
33 kv MASJID MOTH GRID	SMMOT122	11kv O/G SFS B1 SHIEKH SARAI PH-1	TI-SKT346A-2	630	RESIDENTIAL	AMR	Functional	100%	165	0.20			
33 kv MASJID MOTH GRID	SMMOT122	11kv O/G SFS B1 SHIEKH SARAI PH-1	TI-SKT357A-1	630	RESIDENTIAL	AMR	Functional	100%	102	0.16			
33 kv MASJID MOTH GRID	SMMOT122	11kv O/G SFS B1 SHIEKH SARAI PH-1	TI-SKT355A-2	400	MIXED		Functional	100%	12	0.11			
33 kv MASJID MOTH GRID	SMMOT122	11kv O/G SFS B1 SHIEKH SARAI PH-1	TI-SKT357A-2	400	RESIDENTIAL	AMR	Functional	100%	30	0.10			
33 kv MASJID MOTH GRID	SMMOT122	11kv O/G SFS B1 SHIEKH SARAI PH-1	TI-SKT346A-1	400	RESIDENTIAL	AMR	Functional	100%	74	0.09			
33 kv MASJID MOTH GRID	SMMOT101	11kv FDR O/G C-1 SFS SEKH SARAI PHASE-1	TI-SKT356A-2	400	RESIDENTIAL		Functional	100%	138	0.08			
33 kv MASJID MOTH GRID	SMMOT122	11kv O/G SFS B1 SHIEKH SARAI PH-1	TI-SKT355A-1	630	MIXED		Functional	100%	80	0.04			
33 kv PUSHP VIHAR GRID	SPUSP108	11kv FDR O/G CHIRAG DELHI KHATTA	TI-SKT351A-1	990	RESIDENTIAL	AMR	Functional	100%	495	0.55	2.14	0.14	6.05%
33 kv PUSHP VIHAR GRID	SPUSP101	11kv FDR O/G S/S NO.-31. INDUS. AREA SAIKH SARAI PHASE-2	TI-SKT350A-1	990	RESIDENTIAL	AMR	Functional	100%	279	0.50			
33 kv PUSHP VIHAR GRID	SPUSP103	11kv FDR O/G S/S NO.-6 SAIKH SARAI PHASE-2	TI-SKT348A-2	990	RESIDENTIAL	AMR	Functional	100%	571	0.39			
33 kv PUSHP VIHAR GRID	SPUSP103	11kv FDR O/G S/S NO.-6 SAIKH SARAI PHASE-2	TI-SKT351A-2	630	RESIDENTIAL	AMR	Functional	100%	232	0.35			

33 kv PUSHP VIHAR GRID	SPUSP101	11kv FDR O/G S/S NO.-31. INDUS. AREA SAIKH SARAI PHASE-2	TI-SKT348A-1	630	RESIDENTIAL	AMR	Functional	100%	95	0.25			
33 kv PUSHP VIHAR GRID	SPUSP101	11kv FDR O/G S/S NO.-31. INDUS. AREA SAIKH SARAI PHASE-2	TI-SKT350A-2	400	RESIDENTIAL	AMR	Functional	100%	200	0.21			
33 kv PUSHP VIHAR GRID	SPUSP101	11kv FDR O/G S/S NO.-31. INDUS. AREA SAIKH SARAI PHASE-2	TP-SKT418A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.02			
66 kv MALVIYA NAGAR GRID	SMALV132	11kv FDR OG TO J-12 SAKET	TP-SKT599A-1	400	COMMERCIAL	AMR	Functional	100%	191	0.29	1.96	0.20	9.26%
66 kv I.G.N.O.U GRID	SIGNO110	11kv FDR ANUPAM GARDEN/SAINT MARRY	TP-SKT477A-1	400	RESIDENTIAL	AMR	Functional	100%	75	0.24			
66 kv I.G.N.O.U GRID	SIGNO110	11kv FDR ANUPAM GARDEN/SAINT MARRY	TP-SKT509A-1	400	COMMERCIAL	AMR	Functional	100%	63	0.24			
66 kv MALVIYA NAGAR GRID	SMALV108	11kv FDR O/G ANUPAM APPARTMENT	TI-SKT262A-2	630	RESIDENTIAL	AMR	Functional	100%	53	0.22			
66 kv MALVIYA NAGAR GRID	SMALV108	11kv FDR O/G ANUPAM APPARTMENT	TI-SKT262A-1	630	RESIDENTIAL	AMR	Functional	100%	275	0.18			
66 kv MALVIYA NAGAR GRID	SMALV132	11kv FDR OG TO J-12 SAKET	TP-SKT270A-1	400	RESIDENTIAL	AMR	Functional	100%	49	0.15			
66 kv I.G.N.O.U GRID	SIGNO110	11kv FDR ANUPAM GARDEN/SAINT MARRY	TP-SKT506A-1	400	COMMERCIAL	AMR	Functional	100%	52	0.13			
66 kv I.G.N.O.U GRID	SIGNO110	11kv FDR ANUPAM GARDEN/SAINT MARRY	TP-SKT559A-1	400	COMMERCIAL	AMR	Functional	100%	41	0.11			
66 kv I.G.N.O.U GRID	SIGNO110	11kv FDR ANUPAM GARDEN/SAINT MARRY	TP-SKT519A-1	400	RESIDENTIAL	AMR	Functional	100%	61	0.10			
66 kv MALVIYA NAGAR GRID	SMALV104	11kv FDR O/G CARRIAPPA MARG SAINIK FARM	TP-SKT555A-1	630	COMMERCIAL	AMR	Functional	100%	26	0.10			
66 kv MALVIYA NAGAR GRID	SMALV104	11kv FDR O/G CARRIAPPA MARG SAINIK FARM	TP-SKT554A-1	630	COMMERCIAL	AMR	Functional	100%	34	0.10			
66 kv MALVIYA NAGAR GRID	SMALV104	11kv FDR O/G CARRIAPPA MARG SAINIK FARM	TP-SKT553A-1	630	COMMERCIAL	AMR	Functional	100%	40	0.09			
66 kv I.G.N.O.U GRID	SIGNO110	11kv FDR ANUPAM GARDEN/SAINT MARRY	TP-SKT510A-1	400	COMMERCIAL	AMR	Functional	100%	48	0.06			
66 kv MALVIYA NAGAR GRID	SMALV104	11kv FDR O/G CARRIAPPA MARG SAINIK FARM	TP-SKT556A-1	630	COMMERCIAL	AMR	Functional	100%	23	0.06			
66 kv MALVIYA NAGAR GRID	SMALV132	11kv FDR OG TO J-12 SAKET	TG-SKT264A-1	400	RESIDENTIAL	AMR	Functional	100%	3	0.04			
66 kv MALVIYA NAGAR GRID	SMALV106	11kv FDR O/G IGNOU S/S NO.-5	TP-SKT962A-1	100	RESIDENTIAL		Functional	100%	3	0.03			
66 kv MALVIYA NAGAR GRID	SMALV132	11kv FDR OG TO J-12 SAKET	TP-SKT265A-1	400	RESIDENTIAL	AMR	Functional	100%	4	0.01			
66 kv I.G.N.O.U GRID	SIGNO101	11kv FDR N-BLOCK SAINIK FARM	TP-SKT590A-1	630	RESIDENTIAL	AMR	Functional	100%	61	0.27	1.29	0.23	14.91%
66 kv I.G.N.O.U GRID	SIGNO101	11kv FDR N-BLOCK SAINIK FARM	TP-SKT587A-1	630	RESIDENTIAL	AMR	Functional	100%	47	0.23			
66kv SANGAM VIHAR GRID	SSNGM142	11kv FDR OG W-5B SAINIK FARM	TP-SKT579A-1	630	COMMERCIAL	AMR	Functional	100%	49	0.21			
66 kv I.G.N.O.U GRID	SIGNO101	11kv FDR N-BLOCK SAINIK FARM	TG-SKT727A-1	630	COMMERCIAL	AMR	Functional	100%	31	0.14			
66 kv I.G.N.O.U GRID	SIGNO101	11kv FDR N-BLOCK SAINIK FARM	TG-SKT725A-1	630	RESIDENTIAL		Functional	100%	42	0.13			
66kv SANGAM VIHAR GRID	SSNGM142	11kv FDR OG W-5B SAINIK FARM	TP-SKT577A-1	630	COMMERCIAL	AMR	Functional	100%	91	0.10			
66 kv I.G.N.O.U GRID	SIGNO101	11kv FDR N-BLOCK SAINIK FARM	TP-SKT578A-1	630	RESIDENTIAL	AMR	Functional	100%	30	0.09			
66 kv I.G.N.O.U GRID	SIGNO101	11kv FDR N-BLOCK SAINIK FARM	TP-SKT588A-1	630	RESIDENTIAL	AMR	Functional	100%	45	0.09			
66 kv I.G.N.O.U GRID	SIGNO101	11kv FDR N-BLOCK SAINIK FARM	TG-SKT725A-2	630	RESIDENTIAL	AMR	Functional	100%	27	0.08			
66 kv I.G.N.O.U GRID	SIGNO101	11kv FDR N-BLOCK SAINIK FARM	TP-SKT589A-1	630	RESIDENTIAL	AMR	Functional	100%	18	0.07			
66kv SANGAM VIHAR GRID	SSNGM142	11kv FDR OG W-5B SAINIK FARM	TP-SKT266A-1	400	RESIDENTIAL	AMR	Functional	100%	13	0.05			
66kv SANGAM VIHAR GRID	SSNGM125	11kv STR STATION TRANSFORMER	520MGS-STC138A	400	COMMERCIAL	AMR	Functional	100%	1	0.03			
66 kv I.G.N.O.U GRID	SIGNO101	11kv FDR N-BLOCK SAINIK FARM	TP-SKT271A-1	100	RESIDENTIAL		Functional	100%	4	0.02			
33 kv D.C.SAKET GRID	SSAKT120	11KV FDR RES. S/S NO.-1, COURT COMPL.	TI-SKT639A-2	630	COMMERCIAL	AMR	Functional	100%	34	0.11	0.53	0.04	6.79%
33 kv D.C.SAKET GRID	SSAKT120	11KV FDR RES. S/S NO.-1, COURT COMPL.	TI-SKT639A-1	630	COMMERCIAL	AMR	Functional	100%	48	0.10			
33 kv D.C.SAKET GRID	SSAKT123	11KV FDR RES. S/S NO.-2, COURT COMPL.	TI-SKT640A-1	630	COMMERCIAL	AMR	Functional	100%	80	0.07			
33 kv D.C.SAKET GRID	SSAKT124	11KV FDR S/S NO.-1, ADVOCATE CHEMBER NO.-1 (COURT COMPLEX)	TI-SKT637A-1	630	COMMERCIAL		Functional	100%	0	0.06			
33 kv D.C.SAKET GRID	SSAKT123	11KV FDR RES. S/S NO.-2, COURT COMPL.	TI-SKT640A-2	630	COMMERCIAL	AMR	Functional	100%	5	0.05			
33 kv D.C.SAKET GRID	SSAKT124	11KV FDR S/S NO.-1, ADVOCATE CHEMBER NO.-1 (COURT COMPLEX)	TI-SKT637A-2	630	COMMERCIAL	AMR	Functional	100%	269	0.05			
33 kv D.C.SAKET GRID	SSAKT121	11KV FDR ADVOCATE CHEMBER NO.-2	TI-SKT638A-1	630	COMMERCIAL	AMR	Functional	100%	43	0.04			
33 kv D.C.SAKET GRID	SSAKT122	11KV FDR SAKET SPORTS COMPLEX	520MGS-SK0197A	400	MIXED		Functional	100%	0	0.04			
33 kv D.C.SAKET GRID	SSAKT121	11KV FDR ADVOCATE CHEMBER NO.-2	TI-SKT638A-2	630	COMMERCIAL	AMR	Functional	100%	228	0.04			
33 kv D.C.SAKET GRID	SSAKT118	11kv STR 100kVA STATION TRANSFORMER	TP-SC071A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.01			
33 kv D.C.SAKET GRID	SSAKT120	11KV FDR RES. S/S NO.-1, COURT COMPL.	TI-SKT639A-3	630	COMMERCIAL	AMR	Functional	100%	20	0.01			
66kv SANGAM VIHAR GRID	SSNGM144	11kv FDR OG TO W-2 SAINIK FARM	TP-SKT571A-1	630	RESIDENTIAL	AMR	Functional	100%	72	0.34	1.89	0.12	6.18%
66kv SANGAM VIHAR GRID	SSNGM144	11kv FDR OG TO W-2 SAINIK FARM	TP-SKT557A-1	630	RESIDENTIAL	AMR	Functional	100%	63	0.24			
66kv SANGAM VIHAR GRID	SSNGM144	11kv FDR OG TO W-2 SAINIK FARM	TP-SKT593A-1	630	COMMERCIAL	AMR	Functional	100%	67	0.23			
66kv SANGAM VIHAR GRID	SSNGM144	11kv FDR OG TO W-2 SAINIK FARM	TP-SKT570A-1	630	RESIDENTIAL	AMR	Functional	100%	37	0.17			
66kv SANGAM VIHAR GRID	SSNGM144	11kv FDR OG TO W-2 SAINIK FARM	TP-SKT568A-1	630	RESIDENTIAL	AMR	Functional	100%	34	0.15			
66kv SANGAM VIHAR GRID	SSNGM144	11kv FDR OG TO W-2 SAINIK FARM	TP-SKT564A-1	630	RESIDENTIAL		Functional	100%	64	0.13			

66KV SANGAM VIHAR GRID	SSNGM144	11KV FDR OG TO W-2 SAINIK FARM	TG-SKT569A-1	630	RESIDENTIAL	AMR	Functional	100%	34	0.13			
66KV SANGAM VIHAR GRID	SSNGM144	11KV FDR OG TO W-2 SAINIK FARM	TP-SKT565A-1	630	RESIDENTIAL		Functional	100%	38	0.12			
66KV SANGAM VIHAR GRID	SSNGM144	11KV FDR OG TO W-2 SAINIK FARM	TP-SKT566A-1	630	RESIDENTIAL		Functional	100%	32	0.12			
66KV SANGAM VIHAR GRID	SSNGM144	11KV FDR OG TO W-2 SAINIK FARM	TP-SKT563A-1	630	RESIDENTIAL		Functional	100%	86	0.11			
66KV SANGAM VIHAR GRID	SSNGM144	11KV FDR OG TO W-2 SAINIK FARM	TP-SKT269A-1	400	RESIDENTIAL	AMR	Functional	100%	37	0.10			
66KV SANGAM VIHAR GRID	SSNGM144	11KV FDR OG TO W-2 SAINIK FARM	TP-SKT567A-1	630	RESIDENTIAL		Functional	100%	32	0.10			
66KV SANGAM VIHAR GRID	SSNGM144	11KV FDR OG TO W-2 SAINIK FARM	TP-SKT224A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.02			
66KV SANGAM VIHAR GRID	SSNGM144	11KV FDR OG TO W-2 SAINIK FARM	TP-SKT735A-1	100	COMMERCIAL	AMR	Functional	100%	5	0.01			
66KV SANGAM VIHAR GRID	SSNGM144	11KV FDR OG TO W-2 SAINIK FARM	TP-SKT734A-1	100	RESIDENTIAL	AMR	Functional	100%	6	0.01			
66KV SANGAM VIHAR GRID	SSNGM144	11KV FDR OG TO W-2 SAINIK FARM	TP-SKT731A-1	100	COMMERCIAL		Functional	100%	13	0.01			
66KV SANGAM VIHAR GRID	SSNGM144	11KV FDR OG TO W-2 SAINIK FARM	TP-SKT732A-1	100	COMMERCIAL		Functional	100%	12	0.01			
66KV SANGAM VIHAR GRID	SSNGM144	11KV FDR OG TO W-2 SAINIK FARM	TP-SKT730A-1	100	COMMERCIAL		Functional	100%	5	0.01			
66KV SANGAM VIHAR GRID	SSNGM144	11KV FDR OG TO W-2 SAINIK FARM	TP-SKT733A-1	100	COMMERCIAL	AMR	Functional	100%	4	0.00			
66 kv I.G.N.O.U GRID	SIGNO109	11KV FDR IGNOU KIOSK	TG-SKT405A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.58	2.80	0.42	13.12%
66 kv I.G.N.O.U GRID	SIGNO108	11KV FDR S/S NO.-1, NEB SARAI EXTN. (GOEL S/S)	TP-SKT750A-1	990	RESIDENTIAL	AMR	Functional	100%	188	0.54			
66 kv I.G.N.O.U GRID	SIGNO110	11KV FDR ANUPAM GARDEN/SAINT MARRY	TP-SKT728A-1	400	COMMERCIAL	AMR	Functional	100%	3	0.34			
66 kv I.G.N.O.U GRID	SIGNO110	11KV FDR ANUPAM GARDEN/SAINT MARRY	TG-SKT595A-1	990	COMMERCIAL		Functional	100%	94	0.33			
66 kv I.G.N.O.U GRID	SIGNO108	11KV FDR S/S NO.-1, NEB SARAI EXTN. (GOEL S/S)	TP-SKT585A-1	630	COMMERCIAL	AMR	Functional	100%	56	0.25			
66 kv I.G.N.O.U GRID	SIGNO109	11KV FDR IGNOU KIOSK	TG-SKT405A-1	630	RESIDENTIAL	AMR	Functional	100%	802	0.24			
66 kv I.G.N.O.U GRID	SIGNO110	11KV FDR ANUPAM GARDEN/SAINT MARRY	TP-SKT596A-1	400	COMMERCIAL	AMR	Functional	100%	157	0.20			
66 kv I.G.N.O.U GRID	SIGNO108	11KV FDR S/S NO.-1, NEB SARAI EXTN. (GOEL S/S)	TP-SKT507A-1	400	RESIDENTIAL	AMR	Functional	100%	131	0.17			
66 kv I.G.N.O.U GRID	SIGNO107	11KV FDR O/G MAIN ROAD 192-SAINIK FARM	TP-SKT583A-1	630	COMMERCIAL	AMR	Functional	100%	96	0.15			
66KV SANGAM VIHAR GRID	SSNGM142	11KV FDR OG W-5B SAINIK FARM	TI-SKT586A-1	400	COMMERCIAL	AMR	Functional	100%	45	0.14			
66 kv I.G.N.O.U GRID	SIGNO110	11KV FDR ANUPAM GARDEN/SAINT MARRY	TG-SKT729A-1	630	COMMERCIAL	AMR	Functional	100%	61	0.13			
66 kv I.G.N.O.U GRID	SIGNO108	11KV FDR S/S NO.-1, NEB SARAI EXTN. (GOEL S/S)	TP-SKT514A-1	400	RESIDENTIAL	AMR	Functional	100%	83	0.09			
66 kv I.G.N.O.U GRID	SIGNO108	11KV FDR S/S NO.-1, NEB SARAI EXTN. (GOEL S/S)	TG-SKT402A-1	630	COMMERCIAL	AMR	Functional	100%	54	0.06			
33 kv ADCHINI GRID	SADCN101	11KV FDR LADO SARAI	TG-SKT302A-2	1600	RESIDENTIAL	AMR	Functional	100%	0	1.27	6.95	0.77	10.00%
66 kv MALVIYA NAGAR GRID	SMALV133	11KV FDR OG TO LADO SARAI PREM SINGH	TG-SKT803A-1	1600	RESIDENTIAL	AMR	Functional	100%	250	0.78			
33 kv ADCHINI GRID	SADCN121	11KV FDR ADCHINI CROSSING	TG-SKT277A-1	990	RESIDENTIAL		Functional	100%	813	0.78			
33 kv ADCHINI GRID	SADCN101	11KV FDR LADO SARAI	TI-SKT308A-2	990	RESIDENTIAL	AMR	Functional	100%	480	0.74			
66 kv MALVIYA NAGAR GRID	SMALV133	11KV FDR OG TO LADO SARAI PREM SINGH	TX-SKT303A-1	990	RESIDENTIAL	AMR	Functional	100%	1074	0.68			
66 kv MALVIYA NAGAR GRID	SMALV133	11KV FDR OG TO LADO SARAI PREM SINGH	TP-SKT307A-1	630	RESIDENTIAL	AMR	Functional	100%	639	0.68			
33 kv ADCHINI GRID	SADCN101	11KV FDR LADO SARAI	TG-SKT302A-1	990	RESIDENTIAL		Functional	100%	1481	0.61			
66 kv MALVIYA NAGAR GRID	SMALV133	11KV FDR OG TO LADO SARAI PREM SINGH	TG-SKT309A-1	630	COMMERCIAL		Functional	100%	368	0.33			
66 kv MALVIYA NAGAR GRID	SMALV133	11KV FDR OG TO LADO SARAI PREM SINGH	TG-SKT309A-2	990	COMMERCIAL	AMR	Functional	100%	346	0.31			
33 kv ADCHINI GRID	SADCN101	11KV FDR LADO SARAI	TI-SKT308A-1	630	RESIDENTIAL	AMR	Functional	100%	1474	0.29			
66 kv MALVIYA NAGAR GRID	SMALV133	11KV FDR OG TO LADO SARAI PREM SINGH	TP-SKT301A-1	400	RESIDENTIAL		Functional	100%	1	0.23			
66 kv MALVIYA NAGAR GRID	SMALV133	11KV FDR OG TO LADO SARAI PREM SINGH	TP-SKT404A-1	400	COMMERCIAL	AMR	Functional	100%	202	0.21			
66 kv MALVIYA NAGAR GRID	SMALV133	11KV FDR OG TO LADO SARAI PREM SINGH	TX-SKT303A-2	630	MIXED	AMR	Functional	100%	0	0.19			
66 kv MALVIYA NAGAR GRID	SMALV133	11KV FDR OG TO LADO SARAI PREM SINGH	TG-SKT309A-3	630	RESIDENTIAL	AMR	Functional	100%	0	0.17			
66 kv MALVIYA NAGAR GRID	SMALV107	11KV FDR O/G SEC-1 S/S NO.-1 PUSH P VIHAR	TG-SKT309B-2	990	COMMERCIAL	AMR	Functional	100%	0	0.17			
33 kv ADCHINI GRID	SADCN121	11KV FDR ADCHINI CROSSING	TP-SK0018A-1	250	COMMERCIAL		Functional	100%	2	0.15			
33 kv ADCHINI GRID	SADCN121	11KV FDR ADCHINI CROSSING	TG-SKT310A-1	400	RESIDENTIAL		Functional	100%	1	0.11			
66 kv MALVIYA NAGAR GRID	SMALV107	11KV FDR O/G SEC-1 S/S NO.-1 PUSH P VIHAR	TP-SKT304A-1	100	RESIDENTIAL	AMR	Functional	100%	29	0.04			
66 kv I.G.N.O.U GRID	SIGNO106	11KV FDR NEB SARAI VADERA P/M SSTN.	TG-SKT398A-1	990	RESIDENTIAL	AMR	Functional	100%	1323	1.10	4.81	0.07	1.38%
66 kv I.G.N.O.U GRID	SIGNO106	11KV FDR NEB SARAI VADERA P/M SSTN.	TP-SKT401A-1	990	RESIDENTIAL	AMR	Functional	100%	849	0.98			
66 kv I.G.N.O.U GRID	SIGNO109	11KV FDR IGNOU KIOSK	SK-HVD003A-1	1375	COMMERCIAL		Functional	100%	1494	0.98			
66 kv I.G.N.O.U GRID	SIGNO109	11KV FDR IGNOU KIOSK	TG-SKT802A-1	990	COMMERCIAL		Functional	100%	936	0.84			
66 kv I.G.N.O.U GRID	SIGNO106	11KV FDR NEB SARAI VADERA P/M SSTN.	TG-SKT398A-2	630	RESIDENTIAL		Functional	100%	423	0.59			
66 kv I.G.N.O.U GRID	SIGNO109	11KV FDR IGNOU KIOSK	TP-SKT399A-1	990	RESIDENTIAL	AMR	Functional	100%	297	0.37			

66 kv I.G.N.O.U GRID	SIGNO110	11kv FDR ANUPAM GARDEN/SAINT MARRY	SK-HVD002A-2	5055	COMMERCIAL		Functional	100%	0	1.59	6.58	0.07	1.03%			
66 kv MALVIYA NAGAR GRID	SMALV101	11kv FDR S/S NO.-11, SEC-4 PUSHV VIHAR	SK-HVD004A-1	2650	COMMERCIAL		Functional	100%	4515	0.86						
66 kv MALVIYA NAGAR GRID	SMALV131	11kv FDR OG TO J-57 PARYAVARAN VIA ANUPAM APARTMENT	TG-SK0069A-1	630	RESIDENTIAL	AMR	Functional	100%	11	0.63						
66 kv MALVIYA NAGAR GRID	SMALV106	11kv FDR O/G IGNOU S/S NO.-5	TG-SKT400A-1	990	RESIDENTIAL	AMR	Functional	100%	367	0.63						
66 kv MALVIYA NAGAR GRID	SMALV131	11kv FDR OG TO J-57 PARYAVARAN VIA ANUPAM APARTMENT	TG-SKT508A-1	630	RESIDENTIAL	AMR	Functional	100%	265	0.52						
66 kv MALVIYA NAGAR GRID	SMALV131	11kv FDR OG TO J-57 PARYAVARAN VIA ANUPAM APARTMENT	TG-SK0049A-1	630	RESIDENTIAL	AMR	Functional	100%	62	0.43						
66 kv MALVIYA NAGAR GRID	SMALV106	11kv FDR O/G IGNOU S/S NO.-5	TP-SK0080A-1	400	RESIDENTIAL	AMR	Functional	100%	12	0.41						
66 kv MALVIYA NAGAR GRID	SMALV131	11kv FDR OG TO J-57 PARYAVARAN VIA ANUPAM APARTMENT	TP-SK0083A-1	400	RESIDENTIAL	AMR	Functional	100%	98	0.40						
66 kv MALVIYA NAGAR GRID	SMALV132	11kv FDR OG TO J-12 SAKET	TP-SKT499A-1	400	RESIDENTIAL	AMR	Functional	100%	99	0.36						
66 kv I.G.N.O.U GRID	SIGNO110	11kv FDR ANUPAM GARDEN/SAINT MARRY	TP-SKT478A-1	400	RESIDENTIAL	AMR	Functional	100%	37	0.25						
66 kv MALVIYA NAGAR GRID	SMALV106	11kv FDR O/G IGNOU S/S NO.-5	TP-SK0081A-1	400	RESIDENTIAL	AMR	Functional	100%	89	0.21						
66 kv MALVIYA NAGAR GRID	SMALV132	11kv FDR OG TO J-12 SAKET	520MGS-SKT499A	400	MIXED		Functional	100%	0	0.13						
66 kv MALVIYA NAGAR GRID	SMALV101	11kv FDR S/S NO.-11, SEC-4 PUSHV VIHAR	SK-HVD004A-2	1775	COMMERCIAL		Functional	100%	0	0.12						
66 kv I.G.N.O.U GRID	SIGNO110	11kv FDR ANUPAM GARDEN/SAINT MARRY	SK-HVD002A-1	5660	COMMERCIAL		Functional	100%	3375	0.09						
66 kv MALVIYA NAGAR GRID	SMALV106	11kv FDR O/G IGNOU S/S NO.-5	TP-SKT276A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.02						
66 kv MALVIYA NAGAR GRID	SMALV135	11kv FDR OG TO E-2 SAKET	TP-SKT275A-1	100	RESIDENTIAL		Functional	100%	12	0.01						
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSHV VIHAR S/S NO.-12	TI-SKT252A-1	630	COMMERCIAL	AMR	Functional	100%	182	0.18				0.99	0.04	4.00%
66 kv MALVIYA NAGAR GRID	SMALV104	11kv FDR O/G DMRC	TG-SKT393A-1	630	RESIDENTIAL	AMR	Functional	100%	12	0.14						
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSHV VIHAR S/S NO.-12	TI-SKT254A-1	630	COMMERCIAL	AMR	Functional	100%	214	0.12						
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSHV VIHAR S/S NO.-12	TI-SKT254A-2	630	COMMERCIAL	AMR	Functional	100%	198	0.11						
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSHV VIHAR S/S NO.-12	TI-SKT255A-1	400	RESIDENTIAL	AMR	Functional	100%	349	0.10						
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSHV VIHAR S/S NO.-12	TI-SKT253A-1	400	COMMERCIAL	AMR	Functional	100%	138	0.09						
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSHV VIHAR S/S NO.-12	TI-SKT253A-2	630	COMMERCIAL	AMR	Functional	100%	148	0.08						
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSHV VIHAR S/S NO.-12	TI-SKT256A-1	400	COMMERCIAL	AMR	Functional	100%	102	0.07						
66 kv MALVIYA NAGAR GRID	SMALV104	11kv FDR O/G DMRC	TG-SKT393A-2	630	RESIDENTIAL	AMR	Functional	100%	111	0.04						
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR DMRC VIA ANDHRA SCHOOL S/S AND BLIND SCHOOL	TP-SKT502A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.03						
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR DMRC VIA ANDHRA SCHOOL S/S AND BLIND SCHOOL	TP-SK0057A-1	250	RESIDENTIAL	AMR	Functional	100%	1	0.02						
33 kv PUSHV VIHAR GRID	SPUSP112	11kv STR 100kVA STATION TRANSFORMER	TP-STC118A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01						
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR DMRC VIA ANDHRA SCHOOL S/S AND BLIND SCHOOL	TP-SKT948A-1	100	RESIDENTIAL	AMR	Functional	100%	13	0.01						
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR DMRC VIA ANDHRA SCHOOL S/S AND BLIND SCHOOL	TP-SKT410A-1	100	COMMERCIAL	AMR	Functional	100%	25	0.01						
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR DMRC VIA ANDHRA SCHOOL S/S AND BLIND SCHOOL	TP-SKT603A-1	100	COMMERCIAL		Functional	100%	1	0.01						
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR DMRC VIA ANDHRA SCHOOL S/S AND BLIND SCHOOL	TI-SKT912A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.00						
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSHV VIHAR S/S NO.-12	TP-SKT804A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.00						
66 kv MALVIYA NAGAR GRID	SMALV107	11kv FDR O/G SEC-1 S/S NO.-1 PUSHV VIHAR	TI-SKT244A-2	630	COMMERCIAL	AMR	Functional	100%	396	0.28	2.31	0.19	7.50%			
66 kv MALVIYA NAGAR GRID	SMALV107	11kv FDR O/G SEC-1 S/S NO.-1 PUSHV VIHAR	TI-SKT245A-1	630	COMMERCIAL	AMR	Functional	100%	263	0.27						
33 kv D.C.SAKET GRID	SSAKT104	11kv FDR MODI HOSPITAL	TI-SKT246A-1	630	COMMERCIAL	AMR	Functional	100%	206	0.25						
66 kv MALVIYA NAGAR GRID	SMALV107	11kv FDR O/G SEC-1 S/S NO.-1 PUSHV VIHAR	TI-SKT244A-1	630	COMMERCIAL	AMR	Functional	100%	115	0.20						
33 kv D.C.SAKET GRID	SSAKT103	11kv FDR PUSHV VIHAR SEC.-1, S/S NO.-5	TI-SKT247A-2	630	COMMERCIAL	AMR	Functional	100%	305	0.19						
33 kv D.C.SAKET GRID	SSAKT103	11kv FDR PUSHV VIHAR SEC.-1, S/S NO.-5	TI-SKT250A-1	630	COMMERCIAL	AMR	Functional	100%	283	0.19						
33 kv D.C.SAKET GRID	SSAKT103	11kv FDR PUSHV VIHAR SEC.-1, S/S NO.-5	TI-SKT247A-1	630	COMMERCIAL	AMR	Functional	100%	185	0.17						
33 kv D.C.SAKET GRID	SSAKT104	11kv FDR MODI HOSPITAL	TI-SKT246A-2	630	COMMERCIAL	AMR	Functional	100%	66	0.14						
66 kv MALVIYA NAGAR GRID	SMALV107	11kv FDR O/G SEC-1 S/S NO.-1 PUSHV VIHAR	TI-SKT245A-2	400	COMMERCIAL	AMR	Functional	100%	91	0.13						
66 kv MALVIYA NAGAR GRID	SMALV107	11kv FDR O/G SEC-1 S/S NO.-1 PUSHV VIHAR	TI-SKT249A-1	400	COMMERCIAL	AMR	Functional	100%	104	0.12						
33 kv D.C.SAKET GRID	SSAKT103	11kv FDR PUSHV VIHAR SEC.-1, S/S NO.-5	TI-SKT251A-2	630	COMMERCIAL	AMR	Functional	100%	304	0.12						
33 kv D.C.SAKET GRID	SSAKT103	11kv FDR PUSHV VIHAR SEC.-1, S/S NO.-5	TI-SKT248A-1	400	COMMERCIAL	AMR	Functional	100%	249	0.12						
33 kv D.C.SAKET GRID	SSAKT103	11kv FDR PUSHV VIHAR SEC.-1, S/S NO.-5	TI-SKT251A-1	630	COMMERCIAL	AMR	Functional	100%	368	0.11						
66 kv MALVIYA NAGAR GRID	SMALV107	11kv FDR O/G SEC-1 S/S NO.-1 PUSHV VIHAR	TI-SKT249A-2	400	COMMERCIAL		Functional	100%	91	0.11						
33 kv D.C.SAKET GRID	SSAKT103	11kv FDR PUSHV VIHAR SEC.-1, S/S NO.-5	TI-SKT248A-2	400	COMMERCIAL	AMR	Functional	100%	187	0.10						
66 kv MALVIYA NAGAR GRID	SMALV134	11kv FDR OG TO BANERJEE HOSPITAL SAIDULAJAB	TG-SKT274A-1	990	RESIDENTIAL	AMR	Functional	100%	962	0.94				8.53	1.15	11.87%
66 kv MALVIYA NAGAR GRID	SMALV101	11kv FDR S/S NO.-11, SEC-4 PUSHV VIHAR	TG-SKT311A-2	990	RESIDENTIAL		Functional	100%	233	0.79						

66 kv MALVIYA NAGAR GRID	SMALV101	11kv FDR S/S NO.-11, SEC-4 PUSHV VIHAR	TG-SKT311A-3	990	RESIDENTIAL	AMR	Functional	100%	1019	0.75			
66 kv MALVIYA NAGAR GRID	SMALV101	11kv FDR S/S NO.-11, SEC-4 PUSHV VIHAR	TX-SKT263A-1	990	RESIDENTIAL		Functional	100%	401	0.72			
66 kv MALVIYA NAGAR GRID	SMALV134	11kv FDR OG TO BANERJEE HOSPITAL SAIDULAJAB	TG-SKT794A-1	1600	COMMERCIAL	AMR	Functional	100%	162	0.70			
66 kv MALVIYA NAGAR GRID	SMALV101	11kv FDR S/S NO.-11, SEC-4 PUSHV VIHAR	TG-SKT602A-1	990	RESIDENTIAL	AMR	Functional	100%	197	0.69			
66 kv MALVIYA NAGAR GRID	SMALV126	11kv FDR SPORTS COMPLEX SAKET	TG-SKT280A-1	990	RESIDENTIAL	AMR	Functional	100%	781	0.66			
66 kv MALVIYA NAGAR GRID	SMALV134	11kv FDR OG TO BANERJEE HOSPITAL SAIDULAJAB	TG-SKT274A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.54			
66 kv MALVIYA NAGAR GRID	SMALV107	11kv FDR O/G SEC-1 S/S NO.-1 PUSHV VIHAR	TX-SKT279A-1	990	RESIDENTIAL	AMR	Functional	100%	721	0.54			
66 kv MALVIYA NAGAR GRID	SMALV101	11kv FDR S/S NO.-11, SEC-4 PUSHV VIHAR	TG-SKT311A-1	630	RESIDENTIAL	AMR	Functional	100%	256	0.45			
66 kv MALVIYA NAGAR GRID	SMALV126	11kv FDR SPORTS COMPLEX SAKET	TG-SKT970A-1	630	RESIDENTIAL		Functional	100%	171	0.44			
66 kv MALVIYA NAGAR GRID	SMALV126	11kv FDR SPORTS COMPLEX SAKET	TG-SKT280A-2	990	RESIDENTIAL	AMR	Functional	100%	103	0.42			
66 kv MALVIYA NAGAR GRID	SMALV126	11kv FDR SPORTS COMPLEX SAKET	TP-SKT443A-1	990	RESIDENTIAL	AMR	Functional	100%	149	0.42			
66 kv MALVIYA NAGAR GRID	SMALV126	11kv FDR SPORTS COMPLEX SAKET	TG-SKT857A-1	990	RESIDENTIAL	AMR	Functional	100%	171	0.38			
66 kv MALVIYA NAGAR GRID	SMALV101	11kv FDR S/S NO.-11, SEC-4 PUSHV VIHAR	TI-SKT614A-1	630	RESIDENTIAL	AMR	Functional	100%	184	0.33			
66 kv MALVIYA NAGAR GRID	SMALV101	11kv FDR S/S NO.-11, SEC-4 PUSHV VIHAR	TI-SKT407A-1	630	RESIDENTIAL	AMR	Functional	100%	50	0.30			
66 kv MALVIYA NAGAR GRID	SMALV134	11kv FDR OG TO BANERJEE HOSPITAL SAIDULAJAB	520MGS-SKT274A	630	MIXED		Functional	100%	0	0.19			
66 kv MALVIYA NAGAR GRID	SMALV101	11kv FDR S/S NO.-11, SEC-4 PUSHV VIHAR	520MGS-SKT35A	400	RESIDENTIAL	AMR	Functional	100%	162	0.19			
66 kv MALVIYA NAGAR GRID	SMALV126	11kv FDR SPORTS COMPLEX SAKET	TK-SKT279A-2	990	RESIDENTIAL	AMR	Functional	100%	0	0.17			
66 kv MALVIYA NAGAR GRID	SMALV106	11kv FDR O/G IGNOU S/S NO.-5	TP-SKT909A-1	100	COMMERCIAL	AMR	Functional	100%	13	0.04			
66 kv MALVIYA NAGAR GRID	SMALV101	11kv FDR S/S NO.-11, SEC-4 PUSHV VIHAR	520MGS-SKT312A	100	RESIDENTIAL	AMR	Functional	100%	38	0.02			
66 kv MALVIYA NAGAR GRID	SMALV108	11kv FDR O/G ANUPAM APPARTMENT	TI-SKT290A-2	990	COMMERCIAL		Functional	100%	142	0.56	6.55	0.27	4.00%
33 kv D.C.SAKET GRID	SSAKT106	11kv FDR C.C ANUPAM	TI-SKT297A-3	1000	COMMERCIAL		Functional	100%	40	0.55			
33 kv D.C.SAKET GRID	SSAKT106	11kv FDR C.C ANUPAM	TI-SKT298A-2	1000	COMMERCIAL	AMR	Functional	100%	184	0.52			
66 kv MALVIYA NAGAR GRID	SMALV117	11kv FDR O/G MIG DDA FLATS SAKET	TI-SKT296A-2	990	COMMERCIAL	AMR	Functional	100%	262	0.49			
66 kv MALVIYA NAGAR GRID	SMALV108	11kv FDR O/G ANUPAM APPARTMENT	TG-SKT609A-1	630	RESIDENTIAL	AMR	Functional	100%	112	0.44			
66 kv MALVIYA NAGAR GRID	SMALV105	11kv FDR J-BLOCK SAKET	TG-SKT611A-1	630	COMMERCIAL		Functional	100%	96	0.37			
33 kv D.C.SAKET GRID	SSAKT106	11kv FDR C.C ANUPAM	TI-SKT612A-1	990	COMMERCIAL	AMR	Functional	100%	171	0.37			
66 kv MALVIYA NAGAR GRID	SMALV117	11kv FDR O/G MIG DDA FLATS SAKET	TI-SKT296A-1	990	COMMERCIAL	AMR	Functional	100%	238	0.33			
33 kv D.C.SAKET GRID	SSAKT106	11kv FDR C.C ANUPAM	TI-SKT298A-1	630	COMMERCIAL	AMR	Functional	100%	148	0.32			
33 kv D.C.SAKET GRID	SSAKT106	11kv FDR C.C ANUPAM	TX-SKT273A-1	990	COMMERCIAL	AMR	Functional	100%	189	0.27			
33 kv D.C.SAKET GRID	SSAKT106	11kv FDR C.C ANUPAM	TI-SKT297A-2	1000	COMMERCIAL		Functional	100%	80	0.27			
66 kv MALVIYA NAGAR GRID	SMALV117	11kv FDR O/G MIG DDA FLATS SAKET	TG-SKT272A-1	630	RESIDENTIAL	AMR	Functional	100%	283	0.26			
66 kv MALVIYA NAGAR GRID	SMALV117	11kv FDR O/G MIG DDA FLATS SAKET	TI-SKT295A-1	630	COMMERCIAL		Functional	100%	192	0.26			
33 kv D.C.SAKET GRID	SSAKT106	11kv FDR C.C ANUPAM	TI-SKT293A-2	990	RESIDENTIAL	AMR	Functional	100%	169	0.26			
66 kv MALVIYA NAGAR GRID	SMALV108	11kv FDR O/G ANUPAM APPARTMENT	TI-SKT290A-1	630	COMMERCIAL	AMR	Functional	100%	344	0.24			
66 kv MALVIYA NAGAR GRID	SMALV117	11kv FDR O/G MIG DDA FLATS SAKET	TI-SKT294A-2	630	COMMERCIAL	AMR	Functional	100%	47	0.22			
33 kv D.C.SAKET GRID	SSAKT106	11kv FDR C.C ANUPAM	TI-SKT293A-1	1000	COMMERCIAL	AMR	Functional	100%	151	0.22			
66 kv MALVIYA NAGAR GRID	SMALV117	11kv FDR O/G MIG DDA FLATS SAKET	TI-SKT294A-1	630	COMMERCIAL		Functional	100%	119	0.21			
66 kv MALVIYA NAGAR GRID	SMALV135	11kv FDR OG TO E-2 SAKET	TG-SKT291A-1	990	COMMERCIAL		Functional	100%	69	0.18			
66 kv MALVIYA NAGAR GRID	SMALV117	11kv FDR O/G MIG DDA FLATS SAKET	TI-SKT295A-2	630	COMMERCIAL	AMR	Functional	100%	66	0.15			
33 kv D.C.SAKET GRID	SSAKT106	11kv FDR C.C ANUPAM	TI-SKT297A-1	400	COMMERCIAL	AMR	Functional	100%	4	0.15			
66 kv MALVIYA NAGAR GRID	SMALV135	11kv FDR OG TO E-2 SAKET	TG-SKT299A-1	400	COMMERCIAL	AMR	Functional	100%	33	0.10			
66 kv MALVIYA NAGAR GRID	SMALV135	11kv FDR OG TO E-2 SAKET	TG-SKT292A-1	630	COMMERCIAL	AMR	Functional	100%	76	0.09			
66 kv MALVIYA NAGAR GRID	SMALV105	11kv FDR J-BLOCK SAKET	TX-SKT300A-1	990	COMMERCIAL	AMR	Functional	100%	250	0.59	5.65	0.32	5.29%
66 kv MALVIYA NAGAR GRID	SMALV105	11kv FDR J-BLOCK SAKET	TI-SKT283A-1	990	COMMERCIAL		Functional	100%	223	0.52			
33 kv D.C.SAKET GRID	SSAKT104	11kv FDR MODI HOSPITAL	TG-SKT285A-1	990	COMMERCIAL		Functional	100%	204	0.48			
66 kv MALVIYA NAGAR GRID	SMALV105	11kv FDR J-BLOCK SAKET	TG-SKT284A-1	630	COMMERCIAL		Functional	100%	177	0.47			
66 kv MALVIYA NAGAR GRID	SMALV105	11kv FDR J-BLOCK SAKET	TI-SKT281A-1	990	COMMERCIAL	AMR	Functional	100%	324	0.45			
66 kv MALVIYA NAGAR GRID	SMALV105	11kv FDR J-BLOCK SAKET	TI-SKT613A-1	630	COMMERCIAL	AMR	Functional	100%	75	0.45			
66 kv MALVIYA NAGAR GRID	SMALV105	11kv FDR J-BLOCK SAKET	TI-SKT281A-2	990	COMMERCIAL	AMR	Functional	100%	185	0.44			
33 kv D.C.SAKET GRID	SSAKT104	11kv FDR MODI HOSPITAL	TI-SKT287A-1	990	COMMERCIAL		Functional	100%	297	0.35			

33 kv D.C.SAKET GRID	SSAKT104	11KV FDR MODI HOSPITAL	TI-SKT288A-2	990	COMMERCIAL		Functional	100%	437	0.35			
66 kv MALVIYA NAGAR GRID	SMALV105	11kv FDR J-BLOCK SAKET	TG-SKT282A-1	990	COMMERCIAL	AMR	Functional	100%	128	0.34			
66 kv MALVIYA NAGAR GRID	SMALV105	11kv FDR J-BLOCK SAKET	TI-SKT283A-2	630	COMMERCIAL		Functional	100%	265	0.31			
33 kv D.C.SAKET GRID	SSAKT104	11KV FDR MODI HOSPITAL	TG-SKT793A-1	630	COMMERCIAL	AMR	Functional	100%	111	0.25			
33 kv D.C.SAKET GRID	SSAKT104	11KV FDR MODI HOSPITAL	TI-SKT287A-2	990	COMMERCIAL		Functional	100%	214	0.22			
33 kv D.C.SAKET GRID	SSAKT104	11KV FDR MODI HOSPITAL	TI-SKT288A-1	630	COMMERCIAL	AMR	Functional	100%	56	0.21			
33 kv D.C.SAKET GRID	SSAKT104	11KV FDR MODI HOSPITAL	TI-SKT286A-1	990	RESIDENTIAL		Functional	100%	107	0.20			
33 kv D.C.SAKET GRID	SSAKT104	11KV FDR MODI HOSPITAL	TI-SKT286A-2	630	COMMERCIAL		Functional	100%	106	0.17			
33 kv D.C.SAKET GRID	SSAKT122	11KV FDR SAKET SPORTS COMPLEX	TG-SKT289A-1	400	COMMERCIAL		Functional	100%	256	0.16			
66 kv MALVIYA NAGAR GRID	SMALV107	11kv FDR O/G SEC-1 S/S NO.-1 PUSH P VIHAR	TP-SKT305A-1	100	COMMERCIAL		Functional	100%	3	0.00			
66 kv MALVIYA NAGAR GRID	SMALV104	11kv FDR O/G CARRIAPPA MARG SAINIK FARM	TG-SKT572A-1	630	RESIDENTIAL	AMR	Functional	100%	67	0.30	2.11	0.03	1.52%
66 kv I.G.N.O.U GRID	SIGNO107	11kv FDR O/G MAIN ROAD 192-SAINIK FARM	TP-SKT574A-1	630	COMMERCIAL	AMR	Functional	100%	87	0.25			
66 kv I.G.N.O.U GRID	SIGNO107	11kv FDR O/G MAIN ROAD 192-SAINIK FARM	TP-SKT575A-1	630	RESIDENTIAL		Functional	100%	56	0.22			
66 kv I.G.N.O.U GRID	SIGNO107	11kv FDR O/G MAIN ROAD 192-SAINIK FARM	TP-SKT581A-1	630	COMMERCIAL	AMR	Functional	100%	70	0.22			
66 kv MALVIYA NAGAR GRID	SMALV104	11kv FDR O/G CARRIAPPA MARG SAINIK FARM	TP-SKT580A-1	630	COMMERCIAL	AMR	Functional	100%	147	0.21			
66kv SANGAM VIHAR GRID	SSNGM142	11kv FDR OG W-5B SAINIK FARM	TP-SKT598A-1	630	COMMERCIAL	AMR	Functional	100%	41	0.19			
66 kv I.G.N.O.U GRID	SIGNO107	11kv FDR O/G MAIN ROAD 192-SAINIK FARM	TG-SKT573A-1	630	RESIDENTIAL	AMR	Functional	100%	58	0.16			
66kv SANGAM VIHAR GRID	SSNGM142	11kv FDR OG W-5B SAINIK FARM	TP-SKT597A-1	630	RESIDENTIAL		Functional	100%	56	0.16			
66kv SANGAM VIHAR GRID	SSNGM142	11kv FDR OG W-5B SAINIK FARM	TP-SKT591A-1	630	COMMERCIAL	AMR	Functional	100%	33	0.15			
66 kv I.G.N.O.U GRID	SIGNO107	11kv FDR O/G MAIN ROAD 192-SAINIK FARM	TG-SKT582A-1	630	COMMERCIAL	AMR	Functional	100%	68	0.12			
66 kv I.G.N.O.U GRID	SIGNO107	11kv FDR O/G MAIN ROAD 192-SAINIK FARM	TP-SKT592A-1	630	RESIDENTIAL	AMR	Functional	100%	46	0.10			
66kv SANGAM VIHAR GRID	SSNGM142	11kv FDR OG W-5B SAINIK FARM	TP-SKT594A-1	630	COMMERCIAL	AMR	Functional	100%	25	0.06			
33 kv SHIVALIK GRID	SSHIV128	11kv FDR O/G TO SARVAPRIYA VIHAR I/D STN.	TI-SKT372A-2	990	RESIDENTIAL	AMR	Functional	100%	131	0.66	3.53	0.24	6.39%
33 kv SHIVALIK GRID	SSHIV128	11kv FDR O/G TO SARVAPRIYA VIHAR I/D STN.	TI-SKT363A-2	990	RESIDENTIAL	AMR	Functional	100%	305	0.48			
33 kv SHIVALIK GRID	SSHIV128	11kv FDR O/G TO SARVAPRIYA VIHAR I/D STN.	TI-SKT360A-2	990	RESIDENTIAL	AMR	Functional	100%	433	0.44			
33 kv SHIVALIK GRID	SSHIV104	11kv FDR O/G TO BHAVISHAYA NIDHI ENC.	TG-SKT361A-1	990	RESIDENTIAL	AMR	Functional	100%	182	0.43			
33 kv SHIVALIK GRID	SSHIV128	11kv FDR O/G TO SARVAPRIYA VIHAR I/D STN.	TI-SKT363A-1	990	RESIDENTIAL	AMR	Functional	100%	190	0.38			
33 kv SHIVALIK GRID	SSHIV104	11kv FDR O/G TO BHAVISHAYA NIDHI ENC.	TI-SKT360A-1	630	RESIDENTIAL	AMR	Functional	100%	120	0.33			
33 kv SHIVALIK GRID	SSHIV102	11kv FDR O/G TO SARVO PRIYA APATMENT	TI-SKT362A-2	990	RESIDENTIAL	AMR	Functional	100%	191	0.32			
33 kv SHIVALIK GRID	SSHIV128	11kv FDR O/G TO SARVAPRIYA VIHAR I/D STN.	TI-SKT372A-1	990	RESIDENTIAL	AMR	Functional	100%	448	0.31			
33 kv SHIVALIK GRID	SSHIV102	11kv FDR O/G TO SARVO PRIYA APATMENT	TI-SKT362A-1	630	RESIDENTIAL		Functional	100%	76	0.14			
33 kv SHIVALIK GRID	SSHIV128	11kv FDR O/G TO SARVAPRIYA VIHAR I/D STN.	TI-SKT373A-1	300	RESIDENTIAL	AMR	Functional	100%	3	0.11			
33 kv SHIVALIK GRID	SSHIV104	11kv FDR O/G TO BHAVISHAYA NIDHI ENC.	TI-SKT359A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.08			
33 kv SHIVALIK GRID	SSHIV104	11kv FDR O/G TO BHAVISHAYA NIDHI ENC.	TP-SKT744A-1	400	COMMERCIAL	AMR	Functional	100%	1	0.06			
33 kv SHIVALIK GRID	SSHIV104	11kv FDR O/G TO BHAVISHAYA NIDHI ENC.	TI-SKT359A-1	400	RESIDENTIAL	AMR	Functional	100%	168	0.03			
33 kv ADCHINI GRID	SADCN102	11kv FDR SARVODAYA ENCLAVE	TI-SKT369A-1	990	COMMERCIAL		Functional	100%	389	0.65	3.43	0.24	6.54%
33 kv ADCHINI GRID	SADCN102	11kv FDR SARVODAYA ENCLAVE	TI-SKT369A-2	990	COMMERCIAL		Functional	100%	410	0.60			
33 kv SHIVALIK GRID	SSHIV104	11kv FDR O/G TO BHAVISHAYA NIDHI ENC.	TG-SKT371A-2	630	RESIDENTIAL		Functional	100%	405	0.45			
33 kv SHIVALIK GRID	SSHIV103	11kv FDR O/G TO C-BLOCK SHIVALIK	TP-SKT740A-1	630	RESIDENTIAL		Functional	100%	197	0.41			
33 kv ADCHINI GRID	SADCN102	11kv FDR SARVODAYA ENCLAVE	TG-SKT370A-1	990	COMMERCIAL	AMR	Functional	100%	173	0.35			
33 kv ADCHINI GRID	SADCN102	11kv FDR SARVODAYA ENCLAVE	TP-SKT739A-1	630	COMMERCIAL		Functional	100%	139	0.34			
33 kv SHIVALIK GRID	SSHIV104	11kv FDR O/G TO BHAVISHAYA NIDHI ENC.	TG-SKT371A-1	630	RESIDENTIAL		Functional	100%	196	0.30			
33 kv ADCHINI GRID	SADCN102	11kv FDR SARVODAYA ENCLAVE	TX-SKT365A-1	990	RESIDENTIAL	AMR	Functional	100%	330	0.26			
33 kv ADCHINI GRID	SADCN102	11kv FDR SARVODAYA ENCLAVE	TI-SKT364A-1	990	RESIDENTIAL	AMR	Functional	100%	108	0.25			
33 kv ADCHINI GRID	SADCN113	11kv FDR AUROBINDO MARG	TP-SKT842A-1	400	COMMERCIAL	AMR	Functional	100%	11	0.04			
33 kv ADCHINI GRID	SADCN113	11kv FDR AUROBINDO MARG	TP-SKT842A-2	400	COMMERCIAL	AMR	Functional	100%	5	0.02			
33 kv ADCHINI GRID	SADCN106	11KV FDR MMTT (VIA 81/3 ADCHINI)	TK-SKT374A-1	630	MIXED		Functional	100%	180	0.37	2.01	0.03	1.44%
33 kv ADCHINI GRID	SADCN113	11kv FDR AUROBINDO MARG	TP-SKT366A-1	630	RESIDENTIAL		Functional	100%	249	0.30			
33 kv ADCHINI GRID	SADCN113	11kv FDR AUROBINDO MARG	TP-SKT367A-1	400	RESIDENTIAL	AMR	Functional	100%	220	0.26			
33 kv ADCHINI GRID	SADCN106	11KV FDR MMTT (VIA 81/3 ADCHINI)	TK-SKT374A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.22			

33 kv ADCHINI GRID	SADCN106	11KV FDR MMTc (VIA 81/3 ADCHINI)	TP-SKT743A-1	630	RESIDENTIAL	AMR	Functional	100%	89	0.21			
33 kv ADCHINI GRID	SADCN106	11KV FDR MMTc (VIA 81/3 ADCHINI)	TI-SKT375A-2	630	RESIDENTIAL		Functional	100%	173	0.19			
33 kv ADCHINI GRID	SADCN102	11kv FDR SARVODAYA ENCLAVE	TG-SKT741A-1	630	RESIDENTIAL	AMR	Functional	100%	126	0.14			
33 kv ADCHINI GRID	SADCN107	11kv FDR O/G 11KV MALVIYA NAGAR (VIA MMTc COLONEY)	TI-SKT375A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.14			
33 kv ADCHINI GRID	SADCN113	11kv FDR AUROBINDO MARG	TI-SKT368A-1	400	RESIDENTIAL	AMR	Functional	100%	118	0.13			
33 kv ADCHINI GRID	SADCN114	11kv STR LOCAL TR	TG-SKT641A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.07			
33 kv ADCHINI GRID	SADCN113	11kv FDR AUROBINDO MARG	520MMT-SK0146A	400	RESIDENTIAL	AMR	Functional	100%	0	0.01			
33 kv SHIVALIK GRID	SSHIV125	11kv FDR O/G TO ORTHO NOVA HOSPITAL	TI-SKT383A-2	1000	RESIDENTIAL	AMR	Functional	100%	266	0.45	2.48	0.01	0.33%
33 kv ADCHINI GRID	SADCN107	11kv FDR O/G 11KV MALVIYA NAGAR (VIA MMTc COLONEY)	TG-SKT742A-1	630	RESIDENTIAL	AMR	Functional	100%	73	0.42			
33 kv SHIVALIK GRID	SSHIV125	11kv FDR O/G TO ORTHO NOVA HOSPITAL	TI-SKT383A-1	990	RESIDENTIAL	AMR	Functional	100%	155	0.37			
33 kv SHIVALIK GRID	SSHIV125	11kv FDR O/G TO ORTHO NOVA HOSPITAL	TX-SKT384A-1	990	RESIDENTIAL	AMR	Functional	100%	117	0.35			
33 kv ADCHINI GRID	SADCN106	11kv FDR MMTc (VIA 81/3 ADCHINI)	TI-SKT380A-1	990	RESIDENTIAL	AMR	Functional	100%	245	0.31			
33 kv ADCHINI GRID	SADCN112	11kv FDR P.T.S COLONY	TI-SKT381A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.20			
33 kv ADCHINI GRID	SADCN106	11kv FDR MMTc (VIA 81/3 ADCHINI)	TG-SKT382A-1	630	RESIDENTIAL	AMR	Functional	100%	172	0.19			
33 kv ADCHINI GRID	SADCN112	11kv FDR P.T.S COLONY	TI-SKT381A-2	630	RESIDENTIAL	AMR	Functional	100%	370	0.18			
33 kv SHIVALIK GRID	SSHIV125	11kv FDR O/G TO ORTHO NOVA HOSPITAL	TP-SKT412A-1	400	RESIDENTIAL	AMR	Functional	100%	3	0.01			
66 kv C - DOT GRID	SCDOT109	11kv FDR O/G TO MANGALAPURI	TK-SKT055A-2	990	RESIDENTIAL	AMR	Functional	100%	597	0.84	1.65	0.20	10.80%
33 kv ANDHERIA BAGH GRID	SABAG102	11kv FDR O/G TO JONAPUR	TI-SKT464A-1	630	RESIDENTIAL	AMR	Functional	100%	393	0.51			
66 kv C - DOT GRID	SCDOT109	11kv FDR O/G TO MANGALAPURI	TK-SKT055A-1	630	RESIDENTIAL		Functional	100%	261	0.29			
66 kv C - DOT GRID	SCDOT110	11kv O/G TO M.E.S	TG-SK0087A-1	630	RESIDENTIAL	AMR	Functional	100%	56	0.20			
66 kv C - DOT GRID	SCDOT108	11kv FDR O/G ASHWANI KUMAR MEHRA HOTEL	TP-SKT831A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.00			
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSH P VIHAR S/S NO.-12	TI-SKT259A-1	990	COMMERCIAL	AMR	Functional	100%	644	0.32	1.72	0.26	13.34%
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSH P VIHAR S/S NO.-12	TI-SKT258A-1	630	COMMERCIAL	AMR	Functional	100%	379	0.26			
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSH P VIHAR S/S NO.-12	TI-SKT257A-1	630	COMMERCIAL	AMR	Functional	100%	175	0.21			
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSH P VIHAR S/S NO.-12	TI-SKT242A-1	630	COMMERCIAL	AMR	Functional	100%	122	0.19			
66 kv MALVIYA NAGAR GRID	SMALV107	11kv FDR O/G SEC-1 S/S NO.-1 PUSH P VIHAR	TI-SKT240A-1	400	COMMERCIAL	AMR	Functional	100%	175	0.17			
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSH P VIHAR S/S NO.-12	TI-SKT258A-2	400	COMMERCIAL	AMR	Functional	100%	368	0.13			
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSH P VIHAR S/S NO.-12	TI-SKT260A-2	630	COMMERCIAL	AMR	Functional	100%	225	0.13			
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSH P VIHAR S/S NO.-12	TI-SKT241A-1	630	COMMERCIAL	AMR	Functional	100%	187	0.11			
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSH P VIHAR S/S NO.-12	TI-SKT257A-2	630	COMMERCIAL	AMR	Functional	100%	230	0.09			
66 kv MALVIYA NAGAR GRID	SMALV107	11kv FDR O/G SEC-1 S/S NO.-1 PUSH P VIHAR	TI-SKT240A-2	400	COMMERCIAL	AMR	Functional	100%	240	0.09			
66 kv MALVIYA NAGAR GRID	SMALV103	11kv FDR S/STN. NO.-04, SECTOR-3 PUSH P VIHAR (VIA NEW RMU OUT SIDE GRID)	TI-SKT243A-1	630	COMMERCIAL	AMR	Functional	100%	12	0.08			
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSH P VIHAR S/S NO.-12	TI-SKT242A-2	630	COMMERCIAL	AMR	Functional	100%	383	0.08			
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSH P VIHAR S/S NO.-12	TI-SKT260A-1	630	COMMERCIAL	AMR	Functional	100%	189	0.07			
66 kv MALVIYA NAGAR GRID	SMALV103	11kv FDR S/STN. NO.-04, SECTOR-3 PUSH P VIHAR (VIA NEW RMU OUT SIDE GRID)	TP-SKT261A-1	100	COMMERCIAL	AMR	Functional	100%	6	0.04			
66 kv MALVIYA NAGAR GRID	SMALV103	11kv FDR S/STN. NO.-04, SECTOR-3 PUSH P VIHAR (VIA NEW RMU OUT SIDE GRID)	TI-SKT243A-2	400	COMMERCIAL	AMR	Functional	100%	171	0.02			
66 kv MALVIYA NAGAR GRID	SMALV103	11kv FDR S/STN. NO.-04, SECTOR-3 PUSH P VIHAR (VIA NEW RMU OUT SIDE GRID)	TP-SKT403A-1	100	COMMERCIAL	AMR	Functional	100%	33	0.01			
66 kv MALVIYA NAGAR GRID	SMALV123	11kv STR 100kVA STATION TRANSFORMER	TP-STC083A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01			
33 kv D.C.SAKET GRID	SSAKT119	11kv FDR PUSH P VIHAR S/S NO.-12	520MGS-SK0166A	990	RESIDENTIAL	AMR	Functional	100%	190	0.00			
33 kv ANDHERIA BAGH GRID	SABAG102	11kv FDR O/G TO JONAPUR	TP-SKT488A-1	990	RESIDENTIAL		Functional	100%	24	0.34	0.56	0.29	34.00%
66 kv C - DOT GRID	SCDOT108	11kv FDR O/G ASHWANI KUMAR MEHRA HOTEL	2520JPR-SK0044A-	630	RESIDENTIAL	AMR	Functional	100%	14	0.23			
66 kv C - DOT GRID	SCDOT108	11kv FDR O/G ASHWANI KUMAR MEHRA HOTEL	TP-SKT801A-1	400	RESIDENTIAL	AMR	Functional	100%	41	0.19			
33 kv ANDHERIA BAGH GRID	SABAG102	11kv FDR O/G TO JONAPUR	2520JPR-SK0096A-	400	RESIDENTIAL	AMR	Functional	100%	4	0.03			
66 kv C - DOT GRID	SCDOT108	11kv FDR O/G ASHWANI KUMAR MEHRA HOTEL	TP-SKT056A-1	100	RESIDENTIAL		Functional	100%	5	0.02			
66 kv C - DOT GRID	SCDOT108	11kv FDR O/G ASHWANI KUMAR MEHRA HOTEL	TP-SKT671A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02			
33 kv ANDHERIA BAGH GRID	SABAG105	11kv FDR O/G TO N.B.C.C	TP-SKT673A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kv C - DOT GRID	SCDOT108	11kv FDR O/G ASHWANI KUMAR MEHRA HOTEL	TP-SKT672A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kv C - DOT GRID	SCDOT104	11kv FDR NICF GHITORNI	521D4V-VKJ891A-	400	MIXED		Functional	100%	0	0.01	0.92	1.57	63.01%

66 kV C - DOT GRID	SCDOT104	11kV FDR NICF GHITORNI	521D4V-VKJ891A-	400	MIXED		Functional	100%	0	0.01			
66 kV VASANT KUNJ D - BLK GRID	SVKJD111	11kV FDR O/G NANGAL DAIRY NO.-II	TP-VKJ442A-1	990	RESIDENTIAL	AMR	Functional	100%	526	0.98			
220kV VASANT KUNJ TRANSCO GR	TDTVG104	11kV FDR RANG PURI PAHARI	TP-VKJ269A-1	990	RESIDENTIAL	AMR	Functional	100%	338	0.77			
66 kV VASANT KUNJ D - BLK GRID	SVKJD111	11kV FDR O/G NANGAL DAIRY NO.-II	TP-VKJ515A-1	990	RESIDENTIAL	AMR	Functional	100%	578	0.58			
220kV VASANT KUNJ TRANSCO GR	TDTVG104	11kV FDR RANG PURI PAHARI	TP-VKJ233A-1	400	RESIDENTIAL	AMR	Functional	100%	29	0.15			
220kV VASANT KUNJ TRANSCO GR	TDTVG108	11kV FDR NAGAL DAIRY	TG-VKJ487A-1	1600	MIXED		Functional	100%	1322	1.49	14.52	0.76	4.96%
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA116	11kV FDR O/G TO S/STN No 3, DDA FLATS SULTANGARHI	TG-VKJ370A-1	1600	RESIDENTIAL		Functional	100%	1625	1.29			
220kV VASANT KUNJ TRANSCO GR	TDTVG109	11kV FDR A.B HOTEL	TG-VKJ135A-1	1600	RESIDENTIAL	AMR	Functional	100%	1030	1.13			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA116	11kV FDR O/G TO S/STN No 3, DDA FLATS SULTANGARHI	TG-VKJ143A-3	990	RESIDENTIAL	AMR	Functional	100%	257	1.10			
66 kV VASANT KUNJ D - BLK GRID	SVKJD101	11kV FDR NANGAL DAIRY NO.-1	TG-VKJ138A-2	990	RESIDENTIAL		Functional	100%	396	1.01			
220kV VASANT KUNJ TRANSCO GR	TDTVG108	11kV FDR NAGAL DAIRY	TG-VKJ133A-1	990	RESIDENTIAL	AMR	Functional	100%	912	0.98			
66 kV PALAM GRID	SPLAP120	11kV FDR O/G GMR OPPOSITE PALAM GRID	TG-VKJ137A-1	990	COMMERCIAL		Functional	100%	548	0.97			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA116	11kV FDR O/G TO S/STN No 3, DDA FLATS SULTANGARHI	TG-VKJ282A-1	990	RESIDENTIAL	AMR	Functional	100%	277	0.82			
220kV VASANT KUNJ TRANSCO GR	TDTVG108	11kV FDR NAGAL DAIRY	TG-VKJ496A-1	990	RESIDENTIAL	AMR	Functional	100%	672	0.82			
66 kV VASANT KUNJ D - BLK GRID	SVKJD112	11kV FDR O/G TO CENTAUR HOTEL	TG-VKJ167A-1	990	COMMERCIAL		Functional	100%	99	0.79			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA116	11kV FDR O/G TO S/STN No 3, DDA FLATS SULTANGARHI	521MPR-VKJ796A-	630	RESIDENTIAL	AMR	Functional	100%	445	0.73			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA109	11kV FDR O/G TO DJB MAHIPALPUR	TG-VKJ500A-1	990	RESIDENTIAL	AMR	Functional	100%	456	0.68			
66 kV VASANT KUNJ D - BLK GRID	SVKJD101	11kV FDR NANGAL DAIRY NO.-1	TG-VKJ138A-1	630	COMMERCIAL	AMR	Functional	100%	396	0.54			
66 kV VASANT KUNJ D - BLK GRID	SVKJD101	11kV FDR NANGAL DAIRY NO.-1	TP-VKJ235A-1	400	RESIDENTIAL	AMR	Functional	100%	205	0.47			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA116	11kV FDR O/G TO S/STN No 3, DDA FLATS SULTANGARHI	TG-VKJ143A-2	630	RESIDENTIAL		Functional	100%	1368	0.45			
220kV VASANT KUNJ TRANSCO GR	TDTVG108	11kV FDR NAGAL DAIRY	TG-VKJ608A-2	630	RESIDENTIAL	AMR	Functional	100%	532	0.34			
220kV VASANT KUNJ TRANSCO GR	TDTVG109	11kV FDR A.B HOTEL	TP-VKJ368A-1	400	RESIDENTIAL	AMR	Functional	100%	2	0.31			
220kV VASANT KUNJ TRANSCO GR	TDTVG105	11kV FDR I.A.A.I COLONY	TP-VKJ256A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.30			
66 kV PALAM GRID	SPLAP115	11kV FDR O/G EIH OBERAI CATTERING	521MPR-VKJ647A-	250	MIXED	AMR	Functional	100%	1	0.28			
66 kV AEROCTY GRID	SAERO103	11kV FDR OUTGOING TO ASSET NO.-13	521MPR-000005A-	400	MIXED		Functional	100%	0	0.22			
66 kV VASANT KUNJ D - BLK GRID	SVKJD101	11kV FDR NANGAL DAIRY NO.-1	TP-VKJ441A-1	400	RESIDENTIAL	AMR	Functional	100%	190	0.21			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA116	11kV FDR O/G TO S/STN No 3, DDA FLATS SULTANGARHI	TG-VKJ282A-2	990	RESIDENTIAL	AMR	Functional	100%	924	0.10			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA116	11kV FDR O/G TO S/STN No 3, DDA FLATS SULTANGARHI	521MPR-VKJ875A-	400	MIXED		Functional	100%	0	0.10			
220kV VASANT KUNJ TRANSCO GR	TDTVG105	11kV FDR I.A.A.I COLONY	TP-VKJ247A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.06			
66 kV PALAM GRID	SPLAP120	11kV FDR O/G GMR OPPOSITE PALAM GRID	TP-VKJ499A-1	400	RESIDENTIAL		Functional	100%	4	0.05			
220kV VASANT KUNJ TRANSCO GR	TDTVG104	11kV FDR RANG PURI PAHARI	TG-VKJ282B-2	990	RESIDENTIAL	AMR	Functional	100%	0	0.03			
66 kV PALAM GRID	SPLAP116	11kV STR 400KVA STATION TRANS.	PM-STC093A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02			
66 kV VASANT KUNJ D - BLK GRID	SVKJD112	11kV FDR O/G TO CENTAUR HOTEL	TP-VKJ443A-1	990	COMMERCIAL		Functional	100%	237	1.29	10.40	0.12	1.17%
66 kV PALAM GRID	SPLAP120	11kV FDR O/G GMR OPPOSITE PALAM GRID	TG-VKJ136A-1	990	COMMERCIAL	AMR	Functional	100%	771	1.09			
66 kV PALAM GRID	SPLAP120	11kV FDR O/G GMR OPPOSITE PALAM GRID	TP-VKJ165A-1	990	COMMERCIAL	AMR	Functional	100%	1109	0.91			
66 kV VASANT KUNJ D - BLK GRID	SVKJD112	11kV FDR O/G TO CENTAUR HOTEL	TP-VKJ443A-2	990	COMMERCIAL		Functional	100%	453	0.87			

220kV VASANT KUNJ TRANSCO GR	TDTVG110	11kV FDR MAHIPAL PUR	TG-VKJ117A-2	990	COMMERCIAL		Functional	100%	503	0.76			
66 kV VASANT KUNJ D - BLK GRID	SVKJD112	11kV FDR O/G TO CENTAUR HOTEL	TG-VKJ118A-1	1600	COMMERCIAL	AMR	Functional	100%	310	0.75			
66 kV VASANT KUNJ D - BLK GRID	SVKJD112	11kV FDR O/G TO CENTAUR HOTEL	TG-VKJ118A-2	1600	COMMERCIAL	AMR	Functional	100%	125	0.75			
66 kV PALAM GRID	SPLAP120	11kV FDR O/G GMR OPPOSITE PALAM GRID	521MPR-VKJ006A-	630	MIXED		Functional	100%	0	0.72			
66 kV PALAM GRID	SPLAP117	11kV FDR O/G MEHRAM NAGAR	TG-VKJ384A-1	990	COMMERCIAL	AMR	Functional	100%	108	0.64			
220kV VASANT KUNJ TRANSCO GR	TDTVG110	11kV FDR MAHIPAL PUR	TG-VKJ117A-1	630	COMMERCIAL		Functional	100%	491	0.54			
66 kV PALAM GRID	SPLAP120	11kV FDR O/G GMR OPPOSITE PALAM GRID	TG-VKJ139A-1	990	COMMERCIAL		Functional	100%	2067	0.52			
66 kV PALAM GRID	SPLAP117	11kV FDR O/G MEHRAM NAGAR	TG-VKJ342A-1	630	MIXED		Functional	100%	211	0.51			
66 kV PALAM GRID	SPLAP120	11kV FDR O/G GMR OPPOSITE PALAM GRID	TG-VKJ006A-1	630	RESIDENTIAL		Functional	100%	204	0.47			
66 kV PALAM GRID	SPLAP117	11kV FDR O/G MEHRAM NAGAR	TG-VKJ342A-2	630	RESIDENTIAL		Functional	100%	0	0.19			
66 kV PALAM GRID	SPLAP120	11kV FDR O/G GMR OPPOSITE PALAM GRID	TG-VKJ139A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.18			
66 kV PALAM GRID	SPLAP120	11kV FDR O/G GMR OPPOSITE PALAM GRID	521MPR-VKJ139A-	630	RESIDENTIAL		Functional	100%	0	0.15			
66 kV PALAM GRID	SPLAP117	11kV FDR O/G MEHRAM NAGAR	521MPR-VKJ384A-	630	MIXED		Functional	100%	0	0.14			
66 kV PALAM GRID	SPLAP117	11kV FDR O/G MEHRAM NAGAR	521MPR-VKJ761A-	100	RESIDENTIAL		Functional	100%	0	0.04			
66 kV PALAM GRID	SPLAP117	11kV FDR O/G MEHRAM NAGAR	TP-VKJ489A-1	100	MIXED	AMR	Functional	100%	0	0.02			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA115	11kV FDR O/G TO CISF CAMP MAHIPAL PUR	TP-VKJ288A-1	990	MIXED	AMR	Functional	100%	927	0.00			
66 kV PALAM GRID	SPLAP117	11kV FDR O/G MEHRAM NAGAR	TG-VKJ634A-1	990	MIXED	AMR	Functional	100%	123	0.00			
33 kV VASANT VIHAR GRID	SVVHR117	11kV FDR O/G PALAM MEHRAM NAGAR	TG-VKJ183A-1	990	RESIDENTIAL		Functional	100%	870	1.00	2.51	0.09	3.47%
33 kV VASANT VIHAR GRID	SVVHR117	11kV FDR O/G PALAM MEHRAM NAGAR	TG-VKJ184A-1	990	RESIDENTIAL	AMR	Functional	100%	869	0.66			
33 kV VASANT VIHAR GRID	SVVHR117	11kV FDR O/G PALAM MEHRAM NAGAR	TG-VKJ185A-1	400	RESIDENTIAL		Functional	100%	193	0.25			
33 kV VASANT VIHAR GRID	SVVHR117	11kV FDR O/G PALAM MEHRAM NAGAR	TP-VKJ120A-1	400	RESIDENTIAL		Functional	100%	119	0.22			
33 kV VASANT VIHAR GRID	SVVHR117	11kV FDR O/G PALAM MEHRAM NAGAR	521MPR-VKJ184A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.18			
33 kV VASANT VIHAR GRID	SVVHR117	11kV FDR O/G PALAM MEHRAM NAGAR	TP-VKJ497A-1	400	RESIDENTIAL	AMR	Functional	100%	3	0.12			
33 kV VASANT VIHAR GRID	SVVHR117	11kV FDR O/G PALAM MEHRAM NAGAR	TP-VKJ498A-1	100	MIXED	AMR	Functional	100%	3	0.12			
66 kV PALAM GRID	SPLAP117	11kV FDR O/G MEHRAM NAGAR	TP-VKJ492A-1	100	RESIDENTIAL		Functional	100%	1	0.04			
33 kV VASANT VIHAR GRID	SVVHR117	11kV FDR O/G PALAM MEHRAM NAGAR	521MPR-VKJ839A-	100	RESIDENTIAL	AMR	Functional	100%	2	0.00			
220kV VASANT KUNJ TRANSCO GR	TDTVG105	11kV FDR I.A.A.I COLONY	TG-VKJ134A-1	990	RESIDENTIAL	AMR	Functional	100%	1131	1.09	5.79	0.82	12.41%
220kV VASANT KUNJ TRANSCO GR	TDTVG104	11kV FDR RANG PURI PAHARI	TG-VKJ486A-1	990	RESIDENTIAL	AMR	Functional	100%	1518	0.85			
220kV VASANT KUNJ TRANSCO GR	TDTVG105	11kV FDR I.A.A.I COLONY	TG-VKJ164A-2	990	RESIDENTIAL	AMR	Functional	100%	389	0.82			
220kV VASANT KUNJ TRANSCO GR	TDTVG105	11kV FDR I.A.A.I COLONY	TG-VKJ164A-1	990	RESIDENTIAL		Functional	100%	516	0.58			
220kV VASANT KUNJ TRANSCO GR	TDTVG104	11kV FDR RANG PURI PAHARI	521MPR-VKJ840A-	630	RESIDENTIAL	AMR	Functional	100%	193	0.56			
220kV VASANT KUNJ TRANSCO GR	TDTVG104	11kV FDR RANG PURI PAHARI	521MPR-VKJ683A-	630	RESIDENTIAL	AMR	Functional	100%	170	0.53			
220kV VASANT KUNJ TRANSCO GR	TDTVG104	11kV FDR RANG PURI PAHARI	TG-VKJ447A-1	630	RESIDENTIAL		Functional	100%	821	0.48			
220kV VASANT KUNJ TRANSCO GR	TDTVG104	11kV FDR RANG PURI PAHARI	TG-VKJ447A-2	630	RESIDENTIAL		Functional	100%	1	0.40			
220kV VASANT KUNJ TRANSCO GR	TDTVG105	11kV FDR I.A.A.I COLONY	TG-VKJ134A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.28			
66 kV PALAM GRID	SPLAP122	11kV FDR AVIJIT MAHIPALPUR	TP-VKJ250A-1	400	RESIDENTIAL	AMR	Functional	100%	15	0.25			
220kV VASANT KUNJ TRANSCO GR	TDTVG104	11kV FDR RANG PURI PAHARI	TP-VKJ752A-1	400	RESIDENTIAL		Functional	100%	188	0.25			
220kV VASANT KUNJ TRANSCO GR	TDTVG105	11kV FDR I.A.A.I COLONY	TG-VKJ230A-1	630	RESIDENTIAL	AMR	Functional	100%	4	0.17			
66 kV PALAM GRID	SPLAP122	11kV FDR AVIJIT MAHIPALPUR	TG-VKJ369A-1	630	RESIDENTIAL		Functional	100%	5	0.16			
220kV VASANT KUNJ TRANSCO GR	TDTVG104	11kV FDR RANG PURI PAHARI	521MPR-VKJ864A-	630	RESIDENTIAL	AMR	Functional	100%	3	0.11			
220kV VASANT KUNJ TRANSCO GR	TDTVG104	11kV FDR RANG PURI PAHARI	TG-VKJ486A-2	1600	RESIDENTIAL		Functional	100%	72	0.07			

66 kV PALAM GRID	SPLAP122	11kV FDR AVIJIT MAHIPALPUR	TP-VKJ495A-1	100	RESIDENTIAL		Functional	100%	0	0.00			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA108	11kV FDR O/G TO S/STN No 6, DDA FLATS SULTANGARHI	521MPR-VKJ818A-	630	RESIDENTIAL	AMR	Functional	100%	81	0.13	1.91	0.02	1.14%
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA108	11kV FDR O/G TO S/STN No 6, DDA FLATS SULTANGARHI	521MPR-VKJ811A-	630	RESIDENTIAL	AMR	Functional	100%	15	0.12			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA116	11kV FDR O/G TO S/STN No 3, DDA FLATS SULTANGARHI	521MPR-VKJ813A-	630	RESIDENTIAL	AMR	Functional	100%	129	0.11			
66 kV VASANT KUNJ D - BLK GRID	SVKJD124	11kV FDR SULTAN GARHI S/S -II DDA FLATS 850 MASS HOUSING	TG-VKJ459A-2	400	RESIDENTIAL	AMR	Functional	100%	60	0.11			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA108	11kV FDR O/G TO S/STN No 6, DDA FLATS SULTANGARHI	521MPR-VKJ817A-	630	RESIDENTIAL	AMR	Functional	100%	108	0.10			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA116	11kV FDR O/G TO S/STN No 3, DDA FLATS SULTANGARHI	521MPR-VKJ812A-	630	RESIDENTIAL	AMR	Functional	100%	21	0.10			
66 kV VASANT KUNJ D - BLK GRID	SVKJD123	11kV FDR SULTAN GARHI S/S -III DDA FLATS 850 MASS HOUSING	TG-VKJ460A-2	400	RESIDENTIAL	AMR	Functional	100%	117	0.10			
66 kV VASANT KUNJ D - BLK GRID	SVKJD124	11kV FDR SULTAN GARHI S/S -II DDA FLATS 850 MASS HOUSING	TG-VKJ458A-2	630	RESIDENTIAL	AMR	Functional	100%	11	0.09			
66 kV VASANT KUNJ D - BLK GRID	SVKJD123	11kV FDR SULTAN GARHI S/S -III DDA FLATS 850 MASS HOUSING	TG-VKJ460A-1	400	RESIDENTIAL	AMR	Functional	100%	22	0.09			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA108	11kV FDR O/G TO S/STN No 6, DDA FLATS SULTANGARHI	521MPR-VKJ815A-	630	RESIDENTIAL	AMR	Functional	100%	96	0.09			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA108	11kV FDR O/G TO S/STN No 6, DDA FLATS SULTANGARHI	521MPR-VKJ816A-	630	RESIDENTIAL	AMR	Functional	100%	67	0.09			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA116	11kV FDR O/G TO S/STN No 3, DDA FLATS SULTANGARHI	521MPR-VKJ813A-	630	RESIDENTIAL	AMR	Functional	100%	75	0.09			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA116	11kV FDR O/G TO S/STN No 3, DDA FLATS SULTANGARHI	521MPR-VKJ812A-	630	RESIDENTIAL		Functional	100%	170	0.08			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA108	11kV FDR O/G TO S/STN No 6, DDA FLATS SULTANGARHI	521MPR-VKJ817A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.08			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA108	11kV FDR O/G TO S/STN No 6, DDA FLATS SULTANGARHI	521MPR-VKJ815A-	630	RESIDENTIAL	AMR	Functional	100%	108	0.08			
66 kV VASANT KUNJ D - BLK GRID	SVKJD123	11kV FDR SULTAN GARHI S/S -III DDA FLATS 850 MASS HOUSING	TG-VKJ460A-3	400	RESIDENTIAL	AMR	Functional	100%	428	0.08			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA108	11kV FDR O/G TO S/STN No 6, DDA FLATS SULTANGARHI	521MPR-VKJ818A-	630	RESIDENTIAL	AMR	Functional	100%	18	0.07			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA108	11kV FDR O/G TO S/STN No 6, DDA FLATS SULTANGARHI	521MPR-VKJ814A-	630	RESIDENTIAL	AMR	Functional	100%	56	0.07			
66 kV VASANT KUNJ D - BLK GRID	SVKJD124	11kV FDR SULTAN GARHI S/S -II DDA FLATS 850 MASS HOUSING	TG-VKJ458A-1	400	RESIDENTIAL	AMR	Functional	100%	6	0.07			
66 kV VASANT KUNJ D - BLK GRID	SVKJD124	11kV FDR SULTAN GARHI S/S -II DDA FLATS 850 MASS HOUSING	TG-VKJ459A-1	400	RESIDENTIAL		Functional	100%	83	0.05			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA108	11kV FDR O/G TO S/STN No 6, DDA FLATS SULTANGARHI	521MPR-VKJ811A-	630	RESIDENTIAL	AMR	Functional	100%	88	0.05			
66 kV VASANT KUNJ D - BLK GRID	SVKJD124	11kV FDR SULTAN GARHI S/S -II DDA FLATS 850 MASS HOUSING	TG-VKJ458A-3	400	RESIDENTIAL	AMR	Functional	100%	98	0.03			
66 kV VASANT KUNJ D - BLK GRID	SVKJD124	11kV FDR SULTAN GARHI S/S -II DDA FLATS 850 MASS HOUSING	TG-VKJ459A-3	400	RESIDENTIAL	AMR	Functional	100%	155	0.03			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA108	11kV FDR O/G TO S/STN No 6, DDA FLATS SULTANGARHI	521MPR-VKJ814A-	630	RESIDENTIAL	AMR	Functional	100%	3	0.02			
66 kV PALAM GRID	SPLAP122	11kV FDR AVIJIT MAHIPALPUR	TP-VKJ736A-1	400	COMMERCIAL	AMR	Functional	100%	5	0.18	0.76	0.17	18.65%
66 kV PALAM GRID	SPLAP122	11kV FDR AVIJIT MAHIPALPUR	TP-VKJ225A-1	400	RESIDENTIAL	AMR	Functional	100%	25	0.17			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ268A-1	400	COMMERCIAL	AMR	Functional	100%	28	0.17			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ728A-1	400	COMMERCIAL	AMR	Functional	100%	18	0.13			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	521MPR-VKJ884A-	400	MIXED		Functional	100%	0	0.08			
66 kV PALAM GRID	SPLAP122	11kV FDR AVIJIT MAHIPALPUR	TP-VKJ229A-1	400	RESIDENTIAL	AMR	Functional	100%	13	0.08			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ226A-1	400	COMMERCIAL		Functional	100%	13	0.04			
66 kV PALAM GRID	SPLAP122	11kV FDR AVIJIT MAHIPALPUR	TP-VKJ738A-1	400	COMMERCIAL		Functional	100%	12	0.03			
66 kV PALAM GRID	SPLAP122	11kV FDR AVIJIT MAHIPALPUR	TP-VKJ707A-1	100	RESIDENTIAL		Functional	100%	2	0.03			
66 kV PALAM GRID	SPLAP122	11kV FDR AVIJIT MAHIPALPUR	TP-VKJ740A-1	100	COMMERCIAL		Functional	100%	4	0.02			

66 kV I.O.C.BIJWASAN GRID	SBWSN130	11KV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	521MPR-VKJ633A-	100	COMMERCIAL	AMR	Functional	100%	1	0.00			
66 kV PALAM GRID	SPLAP122	11KV FDR AVUIT MAHIPALPUR	TP-VKJ267A-1	100	COMMERCIAL	AMR	Functional	100%	4	0.00			
66 kV C - DOT GRID	SCDOT123	11KV FDR O/G TEMPO STAND	TG-VKJ043A-1	990	COMMERCIAL	AMR	Functional	100%	939	0.83	3.68	0.03	0.94%
66 kV C - DOT GRID	SCDOT123	11KV FDR O/G TEMPO STAND	TG-VKJ473A-1	990	COMMERCIAL		Functional	100%	888	0.81			
33 kV ANDHERIA BAGH GRID	SABAG106	11KV FDR O/G TO TEMPO STAND	TP-VKJ395A-1	990	COMMERCIAL	AMR	Functional	100%	2131	0.69			
33 kV ANDHERIA BAGH GRID	SABAG106	11KV FDR O/G TO TEMPO STAND	TG-VKJ171A-1	400	RESIDENTIAL		Functional	100%	113	0.36			
33 kV ANDHERIA BAGH GRID	SABAG106	11KV FDR O/G TO TEMPO STAND	521B1V-VKJ053B-	990	MIXED	AMR	Functional	100%	0	0.28			
33 kV ANDHERIA BAGH GRID	SABAG106	11KV FDR O/G TO TEMPO STAND	521B1V-VKJ053A-	990	MIXED		Functional	100%	463	0.25			
66 kV C - DOT GRID	SCDOT123	11KV FDR O/G TEMPO STAND	521B1V-VKJ473A-	250	RESIDENTIAL	AMR	Functional	100%	0	0.19			
33 kV ANDHERIA BAGH GRID	SABAG106	11KV FDR O/G TO TEMPO STAND	521B1V-VKJ868A-	400	MIXED		Functional	100%	0	0.17			
66 kV C - DOT GRID	SCDOT123	11KV FDR O/G TEMPO STAND	TG-VKJ474A-1	630	COMMERCIAL	AMR	Functional	100%	7	0.11			
33 kV ANDHERIA BAGH GRID	SABAG112	11KV STR 100kVA STATION TRANS.-1	TP-STC067A-1	100	COMMERCIAL		Functional	100%	1	0.02			
66 kV C - DOT GRID	SCDOT123	11KV FDR O/G TEMPO STAND	TP-VKJ622A-1	100	MIXED	AMR	Functional	100%	35	0.00			
66 kV VASANT KUNJ B - BLK GRID	SVKGB121	11KV FDR MOTHER DAIRY S/S VIA WARD NO.2 (RMU)	TP-VKJ037A-1	990	INDUSTRIAL		Functional	100%	1261	0.77	7.08	0.14	1.97%
33 kV ADCHINI GRID	SADCN111	11KV FDR T.B HOSPITAL	TP-VKJ709A-1	990	RESIDENTIAL	AMR	Functional	100%	12	0.71			
66 kV VASANT KUNJ B - BLK GRID	SVKGB106	11KV FDR WARD-2 MEHRAULI	TG-VKJ630A-1	990	MIXED	AMR	Functional	100%	627	0.61			
33 kV ADCHINI GRID	SADCN111	11KV FDR T.B HOSPITAL	TG-VKJ552A-1	630	INDUSTRIAL	AMR	Functional	100%	734	0.56			
33 kV ADCHINI GRID	SADCN111	11KV FDR T.B HOSPITAL	TG-VKJ046A-1	630	INDUSTRIAL		Functional	100%	547	0.54			
33 kV ADCHINI GRID	SADCN111	11KV FDR T.B HOSPITAL	TG-VKJ042A-2	990	INDUSTRIAL	AMR	Functional	100%	61	0.52			
33 kV ANDHERIA BAGH GRID	SABAG118	11KV FDR O/G PICNIC HUT VIA TEMPO STAND	TG-VKJ708A-1	630	MIXED		Functional	100%	336	0.42			
33 kV ANDHERIA BAGH GRID	SABAG118	11KV FDR O/G PICNIC HUT VIA TEMPO STAND	TP-VKJ408A-1	630	RESIDENTIAL		Functional	100%	308	0.40			
33 kV ADCHINI GRID	SADCN111	11KV FDR T.B HOSPITAL	TP-VKJ385A-1	630	INDUSTRIAL		Functional	100%	676	0.36			
33 kV ADCHINI GRID	SADCN111	11KV FDR T.B HOSPITAL	521B1V-VKJ385A-	630	RESIDENTIAL		Functional	100%	1	0.35			
33 kV ADCHINI GRID	SADCN111	11KV FDR T.B HOSPITAL	TP-VKJ325A-1	630	INDUSTRIAL	AMR	Functional	100%	253	0.34			
33 kV ADCHINI GRID	SADCN111	11KV FDR T.B HOSPITAL	TG-VKJ042A-1	630	INDUSTRIAL	AMR	Functional	100%	7	0.27			
33 kV ADCHINI GRID	SADCN111	11KV FDR T.B HOSPITAL	TP-VKJ386A-1	400	INDUSTRIAL	AMR	Functional	100%	2	0.26			
33 kV ADCHINI GRID	SADCN111	11KV FDR T.B HOSPITAL	TG-VKJ046A-3	400	RESIDENTIAL	AMR	Functional	100%	123	0.25			
33 kV ADCHINI GRID	SADCN111	11KV FDR T.B HOSPITAL	TG-VKJ046A-2	630	INDUSTRIAL	AMR	Functional	100%	499	0.21			
33 kV ADCHINI GRID	SADCN121	11KV FDR ADCHINI CROSSING	TG-VKJ479A-1	400	RESIDENTIAL	AMR	Functional	100%	6	0.16			
66 kV VASANT KUNJ B - BLK GRID	SVKGB121	11KV FDR MOTHER DAIRY S/S VIA WARD NO.2 (RMU)	521B1V-VKJ872A-	400	MIXED		Functional	100%	0	0.16			
33 kV ADCHINI GRID	SADCN111	11KV FDR T.B HOSPITAL	TP-VKJ396A-1	400	INDUSTRIAL	AMR	Functional	100%	2	0.16			
33 kV ADCHINI GRID	SADCN111	11KV FDR T.B HOSPITAL	TP-VKJ732A-1	250	COMMERCIAL		Functional	100%	2	0.11			
33 kV ADCHINI GRID	SADCN121	11KV FDR ADCHINI CROSSING	TP-VKJ067A-1	100	INDUSTRIAL		Functional	100%	9	0.04			
33 kV ADCHINI GRID	SADCN111	11KV FDR T.B HOSPITAL	521B1V-VKJ857A-	250	MIXED		Functional	100%	0	0.04			
33 kV ANDHERIA BAGH GRID	SABAG118	11KV FDR O/G PICNIC HUT VIA TEMPO STAND	TG-VKJ041A-1	1600	RESIDENTIAL	AMR	Functional	100%	844	1.16	7.92	0.96	10.78%
66 kV VASANT KUNJ B - BLK GRID	SVKGB101	11KV FDR SECTOR A-2 VASANT KUNJ	TG-VKJ047A-1	1600	RESIDENTIAL	AMR	Functional	100%	1718	0.96			
33 kV ANDHERIA BAGH GRID	SABAG106	11KV FDR O/G TO TEMPO STAND	TG-VKJ327A-1	990	RESIDENTIAL		Functional	100%	1359	0.78			
66 kV C - DOT GRID	SCDOT123	11KV FDR O/G TEMPO STAND	TP-VKJ470A-1	990	RESIDENTIAL	AMR	Functional	100%	1197	0.78			
33 kV ANDHERIA BAGH GRID	SABAG118	11KV FDR O/G PICNIC HUT VIA TEMPO STAND	TG-VKJ041A-2	990	RESIDENTIAL	AMR	Functional	100%	817	0.71			
66 kV VASANT KUNJ B - BLK GRID	SVKGB105	11KV FDR S.T.P FEEDER	TG-VKJ048A-2	990	RESIDENTIAL	AMR	Functional	100%	66	0.69			
33 kV ANDHERIA BAGH GRID	SABAG106	11KV FDR O/G TO TEMPO STAND	521B1V-VKJ343A-	630	RESIDENTIAL	AMR	Functional	100%	1	0.59			
66 kV VASANT KUNJ B - BLK GRID	SVKGB101	11KV FDR SECTOR A-2 VASANT KUNJ	TG-VKJ049A-1	990	RESIDENTIAL	AMR	Functional	100%	968	0.53			
66 kV VASANT KUNJ B - BLK GRID	SVKGB101	11KV FDR SECTOR A-2 VASANT KUNJ	TP-VKJ064A-1	990	RESIDENTIAL	AMR	Functional	100%	812	0.51			
66 kV VASANT KUNJ B - BLK GRID	SVKGB101	11KV FDR SECTOR A-2 VASANT KUNJ	VK-HVD003A-1	1125	MIXED		Functional	100%	440	0.39			
33 kV ANDHERIA BAGH GRID	SABAG118	11KV FDR O/G PICNIC HUT VIA TEMPO STAND	TG-VKJ057A-1	630	RESIDENTIAL	AMR	Functional	100%	188	0.38			
66 kV C - DOT GRID	SCDOT123	11KV FDR O/G TEMPO STAND	521B1V-VKJ470A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.37			
66 kV VASANT KUNJ B - BLK GRID	SVKGB105	11KV FDR S.T.P FEEDER	TG-VKJ048A-1	990	RESIDENTIAL	AMR	Functional	100%	1380	0.30			
33 kV ANDHERIA BAGH GRID	SABAG106	11KV FDR O/G TO TEMPO STAND	TP-VKJ343A-1	400	RESIDENTIAL	AMR	Functional	100%	181	0.22			
33 kV ANDHERIA BAGH GRID	SABAG106	11KV FDR O/G TO TEMPO STAND	521B1V-VKJ834A-	630	RESIDENTIAL		Functional	100%	58	0.17			
33 kV ANDHERIA BAGH GRID	SABAG106	11KV FDR O/G TO TEMPO STAND	TG-VKJ791A-1	990	RESIDENTIAL	AMR	Functional	100%	123	0.15			

33 kV ANDHERIA BAGH GRID	SABAG118	11kV FDR O/G PICNIC HUT VIA TEMPO STAND	521B1V-VKJ057A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.07			
33 kV ANDHERIA BAGH GRID	SABAG106	11kV FDR O/G TO TEMPO STAND	TP-VKJ326A-1	100	RESIDENTIAL		Functional	100%	1	0.04			
33 kV ADCHINI GRID	SADCN111	11kV FDR T.B HOSPITAL	521B1V-VKJ797A-1	100	COMMERCIAL		Functional	100%	2	0.04			
33 kV ANDHERIA BAGH GRID	SABAG118	11kV FDR O/G PICNIC HUT VIA TEMPO STAND	TP-VKJ475A-1	100	COMMERCIAL	AMR	Functional	100%	6	0.03			
33 kV ANDHERIA BAGH GRID	SABAG115	11kV FDR O/G APEX HOMES PRIVATE LIMITED	TG-VKJ014A-2	630	COMMERCIAL		Functional	100%	352	0.51	2.75	0.17	5.76%
33 kV ANDHERIA BAGH GRID	SABAG115	11kV FDR O/G APEX HOMES PRIVATE LIMITED	TG-VKJ013A-1	630	COMMERCIAL	AMR	Functional	100%	112	0.27			
33 kV ANDHERIA BAGH GRID	SVKJD118	11kV FDR O/G TO V. KUNJ SECT.-A	TG-VKJ020A-2	630	RESIDENTIAL	AMR	Functional	100%	92	0.23			
33 kV ANDHERIA BAGH GRID	SABAG115	11kV FDR O/G APEX HOMES PRIVATE LIMITED	TG-VKJ016A-1	630	COMMERCIAL	AMR	Functional	100%	84	0.23			
33 kV ANDHERIA BAGH GRID	SABAG115	11kV FDR O/G APEX HOMES PRIVATE LIMITED	TG-VKJ016A-2	630	COMMERCIAL	AMR	Functional	100%	164	0.22			
33 kV ANDHERIA BAGH GRID	SVKJD118	11kV FDR O/G TO V. KUNJ SECT.-A	TG-VKJ019A-1	630	COMMERCIAL		Functional	100%	225	0.22			
33 kV ANDHERIA BAGH GRID	SVKJD118	11kV FDR O/G TO V. KUNJ SECT.-A	TG-VKJ019A-2	630	COMMERCIAL	AMR	Functional	100%	74	0.22			
33 kV ANDHERIA BAGH GRID	SVKJD118	11kV FDR O/G TO V. KUNJ SECT.-A	TG-VKJ020A-1	630	COMMERCIAL	AMR	Functional	100%	122	0.20			
33 kV ANDHERIA BAGH GRID	SVKJD118	11kV FDR O/G TO V. KUNJ SECT.-A	TG-VKJ017A-1	630	COMMERCIAL	AMR	Functional	100%	133	0.18			
33 kV ANDHERIA BAGH GRID	SVKJD118	11kV FDR O/G TO V. KUNJ SECT.-A	TG-VKJ017A-2	630	COMMERCIAL		Functional	100%	168	0.18			
33 kV ANDHERIA BAGH GRID	SVKJD118	11kV FDR O/G TO V. KUNJ SECT.-A	TG-VKJ018A-2	630	COMMERCIAL	AMR	Functional	100%	90	0.13			
33 kV ANDHERIA BAGH GRID	SVKJD118	11kV FDR O/G TO V. KUNJ SECT.-A	TG-VKJ018A-1	630	COMMERCIAL	AMR	Functional	100%	91	0.13			
33 kV ANDHERIA BAGH GRID	SABAG115	11kV FDR O/G APEX HOMES PRIVATE LIMITED	TG-VKJ014A-1	630	COMMERCIAL		Functional	100%	171	0.12			
33 kV ANDHERIA BAGH GRID	SVKJD118	11kV FDR O/G TO V. KUNJ SECT.-A	TP-VKJ389A-1	630	COMMERCIAL		Functional	100%	44	0.06			
66 kV VASANT KUNJ B - BLK GRID	SVKGB108	11kV FDR B-1, S/S NO.-1, VASANT KUNJ	TG-VKJ005A-1	630	COMMERCIAL		Functional	100%	184	0.27	2.75	0.11	3.84%
66 kV VASANT KUNJ B - BLK GRID	SVKGB104	11kV FDR SECTOR B-4 VASANT KUNJ	TG-VKJ025A-1	630	RESIDENTIAL	AMR	Functional	100%	167	0.26			
66 kV VASANT KUNJ B - BLK GRID	SVKGB104	11kV FDR SECTOR B-4 VASANT KUNJ	TG-VKJ025A-2	630	RESIDENTIAL	AMR	Functional	100%	135	0.22			
66 kV VASANT KUNJ B - BLK GRID	SVKGB108	11kV FDR B-1, S/S NO.-1, VASANT KUNJ	TG-VKJ387A-1	630	COMMERCIAL	AMR	Functional	100%	31	0.21			
66 kV VASANT KUNJ B - BLK GRID	SVKGB628	11kV 160 HIG DDA FLATS S/S B-2 VKJ	TG-VKJ010A-1	630	COMMERCIAL	AMR	Functional	100%	92	0.20			
66 kV VASANT KUNJ B - BLK GRID	SVKGB108	11kV FDR B-1, S/S NO.-1, VASANT KUNJ	TG-VKJ387A-2	630	RESIDENTIAL	AMR	Functional	100%	23	0.19			
66 kV VASANT KUNJ B - BLK GRID	SVKGB108	11kV FDR B-1, S/S NO.-1, VASANT KUNJ	TG-VKJ004A-2	630	COMMERCIAL	AMR	Functional	100%	132	0.18			
66 kV VASANT KUNJ B - BLK GRID	SVKGB108	11kV FDR B-1, S/S NO.-1, VASANT KUNJ	TG-VKJ003A-2	630	COMMERCIAL	AMR	Functional	100%	82	0.17			
66 kV VASANT KUNJ B - BLK GRID	SVKGB108	11kV FDR B-1, S/S NO.-1, VASANT KUNJ	TI-VKJ001A-2	630	COMMERCIAL	AMR	Functional	100%	127	0.17			
66 kV VASANT KUNJ B - BLK GRID	SVKGB108	11kV FDR B-1, S/S NO.-1, VASANT KUNJ	TG-VKJ003A-1	630	COMMERCIAL	AMR	Functional	100%	117	0.16			
66 kV VASANT KUNJ B - BLK GRID	SVKGB108	11kV FDR B-1, S/S NO.-1, VASANT KUNJ	TI-VKJ001A-1	630	COMMERCIAL	AMR	Functional	100%	104	0.16			
66 kV VASANT KUNJ B - BLK GRID	SVKGB108	11kV FDR B-1, S/S NO.-1, VASANT KUNJ	TG-VKJ004A-1	400	COMMERCIAL	AMR	Functional	100%	1	0.15			
66 kV VASANT KUNJ B - BLK GRID	SVKGB108	11kV FDR B-1, S/S NO.-1, VASANT KUNJ	TG-VKJ002A-2	630	COMMERCIAL	AMR	Functional	100%	132	0.14			
66 kV VASANT KUNJ B - BLK GRID	SVKGB628	11kV 160 HIG DDA FLATS S/S B-2 VKJ	TG-VKJ010A-2	630	COMMERCIAL	AMR	Functional	100%	94	0.14			
66 kV VASANT KUNJ B - BLK GRID	SVKGB108	11kV FDR B-1, S/S NO.-1, VASANT KUNJ	TG-VKJ002A-1	630	COMMERCIAL	AMR	Functional	100%	118	0.12			
66 kV VASANT KUNJ B - BLK GRID	SVKGB628	11kV 160 HIG DDA FLATS S/S B-2 VKJ	TG-VKJ773A-1	630	RESIDENTIAL	AMR	Functional	100%	42	0.07			
66 kV VASANT KUNJ B - BLK GRID	SVKGB116	11kV FDR FORTIS HOSPITAL FEEDER-2 DAHYA KISANGARH (RMU IN GRID)	TP-VKJ174A-1	100	RESIDENTIAL		Functional	100%	3	0.02			
66 kV VASANT KUNJ B - BLK GRID	SVKGB105	11kV FDR S.T.P FEEDER	TP-VKJ044A-1	630	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV VASANT KUNJ B - BLK GRID	SVKGB104	11kV FDR SECTOR B-4 VASANT KUNJ	TP-VKJ009A-1	400	COMMERCIAL		Functional	100%	584	0.38	2.07	0.02	1.14%
66 kV VASANT KUNJ B - BLK GRID	SVKGB104	11kV FDR SECTOR B-4 VASANT KUNJ	TP-VKJ009A-2	630	COMMERCIAL	AMR	Functional	100%	170	0.30			
66 kV VASANT KUNJ B - BLK GRID	SVKGB104	11kV FDR SECTOR B-4 VASANT KUNJ	TG-VKJ022A-2	630	COMMERCIAL		Functional	100%	185	0.29			
66 kV VASANT KUNJ B - BLK GRID	SVKGB628	11kV 160 HIG DDA FLATS S/S B-2 VKJ	TG-VKJ022A-1	630	COMMERCIAL	AMR	Functional	100%	156	0.25			
66 kV VASANT KUNJ B - BLK GRID	SVKGB104	11kV FDR SECTOR B-4 VASANT KUNJ	TG-VKJ024A-1	630	COMMERCIAL	AMR	Functional	100%	180	0.23			
66 kV VASANT KUNJ B - BLK GRID	SVKGB104	11kV FDR SECTOR B-4 VASANT KUNJ	TG-VKJ023A-2	630	COMMERCIAL	AMR	Functional	100%	131	0.21			
66 kV VASANT KUNJ B - BLK GRID	SVKGB104	11kV FDR SECTOR B-4 VASANT KUNJ	TG-VKJ023A-1	630	COMMERCIAL	AMR	Functional	100%	159	0.20			
66 kV VASANT KUNJ B - BLK GRID	SVKGB628	11kV 160 HIG DDA FLATS S/S B-2 VKJ	TP-VKJ021A-1	400	COMMERCIAL	AMR	Functional	100%	52	0.09			
66 kV VASANT KUNJ B - BLK GRID	SVKGB628	11kV 160 HIG DDA FLATS S/S B-2 VKJ	TP-VKJ021A-2	400	COMMERCIAL	AMR	Functional	100%	41	0.06			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11kV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	521D4V-VKJ866A-1	400	MIXED		Functional	100%	0	0.04			
66 kV VASANT KUNJ B - BLK GRID	SVKGB110	11kV STR 100kVA STATION TRANS.	VK-STC103A-1	400	MIXED	AMR	Functional	100%	1	0.03			
66 kV VASANT KUNJ B - BLK GRID	SVKGB105	11kV FDR S.T.P FEEDER	TP-VKJ058A-1	1600	RESIDENTIAL	AMR	Functional	100%	1017	0.98	9.45	0.12	1.20%
66 kV VASANT KUNJ B - BLK GRID	SVKGB105	11kV FDR S.T.P FEEDER	TG-VKJ012A-1	990	COMMERCIAL	AMR	Functional	100%	70	0.85			
66 kV VASANT KUNJ B - BLK GRID	SVKGB107	11kV FDR LIVER HOSPITAL(DIVISION VASANT KUNJ)	TG-VKJ045A-1	990	RESIDENTIAL		Functional	100%	1114	0.79			

66 kV VASANT KUNJ B - BLK GRID	SVKGB116	11kV FDR FORTIS HOSPITAL FEEDER-2 DAHYA KISANGARH (RMU IN GRID)	2521B1V-VKJ333A-	990	RESIDENTIAL	AMR	Functional	100%	1126	0.79			
66 kV VASANT KUNJ B - BLK GRID	SVKGB107	11kV FDR LIVER HOSPITAL(DIVISION VASANT KUNJ)	TG-VKJ448A-1	990	RESIDENTIAL	AMR	Functional	100%	519	0.75			
66 kV VASANT KUNJ B - BLK GRID	SVKGB116	11kV FDR FORTIS HOSPITAL FEEDER-2 DAHYA KISANGARH (RMU IN GRID)	2521B1V-VKJ333A-	990	RESIDENTIAL	AMR	Functional	100%	426	0.75			
66 kV VASANT KUNJ B - BLK GRID	SVKGB107	11kV FDR LIVER HOSPITAL(DIVISION VASANT KUNJ)	TG-VKJ050A-1	990	RESIDENTIAL	AMR	Functional	100%	1024	0.73			
66 kV VASANT KUNJ B - BLK GRID	SVKGB105	11kV FDR S.T.P FEEDER	TG-VKJ511A-1	630	RESIDENTIAL	AMR	Functional	100%	319	0.58			
66 kV VASANT KUNJ B - BLK GRID	SVKGB105	11kV FDR S.T.P FEEDER	TP-VKJ564A-1	630	RESIDENTIAL	AMR	Functional	100%	756	0.50			
33 kv ANDHERIA BAGH GRID	SABAG115	11kV FDR O/G APEX HOMES PRIVATE LIMITED	TG-VKJ652A-1	630	MIXED	AMR	Functional	100%	482	0.44			
33 kv ANDHERIA BAGH GRID	SABAG115	11kV FDR O/G APEX HOMES PRIVATE LIMITED	TP-VKJ381A-1	630	INDUSTRIAL	AMR	Functional	100%	594	0.44			
66 kV VASANT KUNJ B - BLK GRID	SVKGB107	11kV FDR LIVER HOSPITAL(DIVISION VASANT KUNJ)	TG-VKJ763A-1	630	RESIDENTIAL	AMR	Functional	100%	771	0.41			
66 kV VASANT KUNJ B - BLK GRID	SVKGB105	11kV FDR S.T.P FEEDER	TP-VKJ564A-2	990	RESIDENTIAL	AMR	Functional	100%	101	0.39			
33 kv ANDHERIA BAGH GRID	SABAG115	11kV FDR O/G APEX HOMES PRIVATE LIMITED	TP-VKJ381A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.29			
66 kV VASANT KUNJ B - BLK GRID	SVKGB105	11kV FDR S.T.P FEEDER	TG-VKJ012A-2	630	COMMERCIAL	AMR	Functional	100%	587	0.22			
33 kv ANDHERIA BAGH GRID	SABAG119	11kV FDR O/G SALOON APPARTMENT	2521B1V-VKJ825A-	400	RESIDENTIAL	AMR	Functional	100%	158	0.19			
66 kV VASANT KUNJ B - BLK GRID	SVKGB101	11kV FDR SECTOR A-2 VASANT KUNJ	TP-VKJ011A-1	400	COMMERCIAL	AMR	Functional	100%	199	0.17			
33 kv ANDHERIA BAGH GRID	SABAG115	11kV FDR O/G APEX HOMES PRIVATE LIMITED	TP-VKJ015A-2	400	COMMERCIAL		Functional	100%	22	0.15			
33 kv ANDHERIA BAGH GRID	SABAG115	11kV FDR O/G APEX HOMES PRIVATE LIMITED	TP-VKJ015A-1	630	COMMERCIAL	AMR	Functional	100%	126	0.15			
66 kV VASANT KUNJ B - BLK GRID	SVKGB116	11kV FDR FORTIS HOSPITAL FEEDER-2 DAHYA KISANGARH (RMU IN GRID)	VK-HVD002A-1	2795	MIXED		Functional	100%	1473	1.18	7.27	0.54	6.97%
66 kV VASANT KUNJ B - BLK GRID	SVKGB106	11kV FDR WARD-2 MEHRAULI	TG-VKJ764A-1	1600	RESIDENTIAL		Functional	100%	2829	1.17			
66 kV VASANT KUNJ B - BLK GRID	SVKGB121	11kV FDR MOTHER DAIRY S/S VIA WARD NO.2 (RMU)	TG-VKJ040A-1	1600	INDUSTRIAL		Functional	100%	1745	0.95			
33 kv ANDHERIA BAGH GRID	SABAG119	11kV FDR O/G SALOON APPARTMENT	TG-VKJ632A-1	630	RESIDENTIAL		Functional	100%	330	0.80			
66 kV VASANT KUNJ B - BLK GRID	SVKGB106	11kV FDR WARD-2 MEHRAULI	TP-VKJ051A-1	990	INDUSTRIAL		Functional	100%	1498	0.59			
66 kV VASANT KUNJ B - BLK GRID	SVKGB116	11kV FDR FORTIS HOSPITAL FEEDER-2 DAHYA KISANGARH (RMU IN GRID)	TP-VKJ727A-1	630	COMMERCIAL	AMR	Functional	100%	38	0.48			
66 kV VASANT KUNJ B - BLK GRID	SVKGB121	11kV FDR MOTHER DAIRY S/S VIA WARD NO.2 (RMU)	TG-VKJ471A-1	990	INDUSTRIAL	AMR	Functional	100%	1066	0.46			
66 kV VASANT KUNJ B - BLK GRID	SVKGB121	11kV FDR MOTHER DAIRY S/S VIA WARD NO.2 (RMU)	TG-VKJ471A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.45			
66 kV VASANT KUNJ B - BLK GRID	SVKGB106	11kV FDR WARD-2 MEHRAULI	TG-VKJ051A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.44			
66 kV VASANT KUNJ B - BLK GRID	SVKGB121	11kV FDR MOTHER DAIRY S/S VIA WARD NO.2 (RMU)	TP-VKJ331A-1	630	RESIDENTIAL	AMR	Functional	100%	179	0.41			
66 kV VASANT KUNJ B - BLK GRID	SVKGB101	11kV FDR SECTOR A-2 VASANT KUNJ	2521B1V-VKJ846A-	400	RESIDENTIAL		Functional	100%	223	0.30			
66 kV VASANT KUNJ B - BLK GRID	SVKGB116	11kV FDR FORTIS HOSPITAL FEEDER-2 DAHYA KISANGARH (RMU IN GRID)	TP-VKJ629A-1	630	RESIDENTIAL	AMR	Functional	100%	123	0.25			
66 kV VASANT KUNJ B - BLK GRID	SVKGB106	11kV FDR WARD-2 MEHRAULI	2521B1V-VKJ887A-	990	MIXED		Functional	100%	0	0.17			
66 kV VASANT KUNJ B - BLK GRID	SVKGB121	11kV FDR MOTHER DAIRY S/S VIA WARD NO.2 (RMU)	2521B1V-VKJ040A-	400	MIXED		Functional	100%	0	0.16			
33 kv ANDHERIA BAGH GRID	SABAG120	11kV FDR O/G TO GHITORANI	TP-VKJ332A-2	630	RESIDENTIAL	AMR	Functional	100%	4	0.65	1.86	0.24	11.23%
33 kv ANDHERIA BAGH GRID	SABAG120	11kV FDR O/G TO GHITORANI	TP-VKJ311A-1	990	COMMERCIAL		Functional	100%	123	0.50			
33 kv ANDHERIA BAGH GRID	SABAG120	11kV FDR O/G TO GHITORANI	TP-VKJ332A-1	630	COMMERCIAL		Functional	100%	696	0.24			
33 kv ANDHERIA BAGH GRID	SABAG104	11kV FDR O/G TO MANGALAPURI	TP-VKJ617A-1	400	RESIDENTIAL	AMR	Functional	100%	89	0.22			
33 kv ANDHERIA BAGH GRID	SABAG104	11kV FDR O/G TO MANGALAPURI	TP-VKJ476A-1	400	COMMERCIAL	AMR	Functional	100%	102	0.16			
33 kv ANDHERIA BAGH GRID	SABAG104	11kV FDR O/G TO MANGALAPURI	TP-VKJ624A-1	400	MIXED	AMR	Functional	100%	24	0.09			
33 kv ANDHERIA BAGH GRID	SABAG104	11kV FDR O/G TO MANGALAPURI	2521D4V-VKJ344A-	400	MIXED	AMR	Functional	100%	4	0.07			
33 kv ANDHERIA BAGH GRID	SABAG104	11kV FDR O/G TO MANGALAPURI	TP-VKJ482A-1	100	COMMERCIAL		Functional	100%	4	0.05			
33 kv ANDHERIA BAGH GRID	SABAG104	11kV FDR O/G TO MANGALAPURI	TP-VKJ631A-1	400	RESIDENTIAL		Functional	100%	12	0.04			
33 kv ANDHERIA BAGH GRID	SABAG104	11kV FDR O/G TO MANGALAPURI	TP-VKJ768A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.03			
33 kv ANDHERIA BAGH GRID	SABAG104	11kV FDR O/G TO MANGALAPURI	TP-VKJ480A-2	100	RESIDENTIAL	AMR	Functional	100%	3	0.02			
33 kv ANDHERIA BAGH GRID	SABAG104	11kV FDR O/G TO MANGALAPURI	TP-VKJ481A-2	100	COMMERCIAL		Functional	100%	2	0.01			
33 kv ANDHERIA BAGH GRID	SABAG104	11kV FDR O/G TO MANGALAPURI	TP-VKJ484A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.01			
33 kv ANDHERIA BAGH GRID	SABAG104	11kV FDR O/G TO MANGALAPURI	TP-VKJ743A-1	100	RESIDENTIAL		Functional	100%	3	0.01			
33 kv ANDHERIA BAGH GRID	SABAG120	11kV FDR O/G TO GHITORANI	TG-VKJ140A-1	990	RESIDENTIAL	AMR	Functional	100%	288	0.96	7.78	0.06	0.71%
33 kv ANDHERIA BAGH GRID	SABAG120	11kV FDR O/G TO GHITORANI	TG-VKJ359A-1	990	RESIDENTIAL	AMR	Functional	100%	602	0.83			
66 kV C - DOT GRID	SCDOT107	11KV FDR NTRO NO.-1 (OPP. GHITORANI BUS STAND)	TP-VKJ399A-1	990	COMMERCIAL	AMR	Functional	100%	571	0.76			
66 kV C - DOT GRID	SCDOT107	11KV FDR NTRO NO.-1 (OPP. GHITORANI BUS STAND)	TG-VKJ334A-1	990	RESIDENTIAL		Functional	100%	1208	0.68			
66 kV C - DOT GRID	SCDOT104	11kV FDR NICF GHITORNI	TG-VKJ576A-1	630	RESIDENTIAL	AMR	Functional	100%	752	0.63			
66 kV C - DOT GRID	SCDOT107	11KV FDR NTRO NO.-1 (OPP. GHITORANI BUS STAND)	TG-VKJ615A-2	990	RESIDENTIAL		Functional	100%	0	0.62			

66 kV C - DOT GRID	SCDOT107	11KV FDR NTRO NO.-1 (OPP. GHITORANI BUS STAND)	TP-VKJ401A-1	990	COMMERCIAL	AMR	Functional	100%	1383	0.57			
66 kV C - DOT GRID	SCDOT107	11KV FDR NTRO NO.-1 (OPP. GHITORANI BUS STAND)	TP-VKJ615A-1	630	RESIDENTIAL		Functional	100%	523	0.55			
66 kV C - DOT GRID	SCDOT107	11KV FDR NTRO NO.-1 (OPP. GHITORANI BUS STAND)	TP-VKJ401A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.54			
33 kV ANDHERIA BAGH GRID	SABAG120	11KV FDR O/G TO GHITORANI	TP-VKJ062A-1	990	COMMERCIAL		Functional	100%	1229	0.50			
66 kV C - DOT GRID	SCDOT107	11KV FDR NTRO NO.-1 (OPP. GHITORANI BUS STAND)	TP-VKJ774A-1	400	RESIDENTIAL		Functional	100%	175	0.45			
66 kV C - DOT GRID	SCDOT104	11KV FDR NICF GHITORNI	TP-VKJ330A-1	400	RESIDENTIAL	AMR	Functional	100%	242	0.30			
66 kV C - DOT GRID	SCDOT107	11KV FDR NTRO NO.-1 (OPP. GHITORANI BUS STAND)	521D4V-VKJ844A-	630	RESIDENTIAL	AMR	Functional	100%	169	0.16			
66 kV C - DOT GRID	SCDOT104	11KV FDR NICF GHITORNI	521D4V-VKJ899A-	630	MIXED		Functional	100%	0	0.15			
66 kV C - DOT GRID	SCDOT107	11KV FDR NTRO NO.-1 (OPP. GHITORANI BUS STAND)	TP-VKJ729A-1	400	RESIDENTIAL	AMR	Functional	100%	9	0.07			
33 kV ANDHERIA BAGH GRID	SABAG120	11KV FDR O/G TO GHITORANI	521D4V-VKJ799A-	100	RESIDENTIAL	AMR	Functional	100%	102	0.06			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ390A-1	400	COMMERCIAL	AMR	Functional	100%	34	0.56	4.98	0.23	4.47%
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	521D4V-VKJ829A-	630	RESIDENTIAL	AMR	Functional	100%	130	0.35			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TI-VKJ435A-1	400	COMMERCIAL	AMR	Functional	100%	140	0.35			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TG-VKJ516A-1	630	RESIDENTIAL	AMR	Functional	100%	188	0.32			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ758A-1	400	RESIDENTIAL		Functional	100%	22	0.32			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ394A-1	400	COMMERCIAL	AMR	Functional	100%	101	0.23			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ316A-1	400	RESIDENTIAL	AMR	Functional	100%	66	0.23			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ645A-1	400	RESIDENTIAL	AMR	Functional	100%	175	0.23			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TG-VKJ434A-1	400	COMMERCIAL		Functional	100%	3	0.21			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ454A-1	400	COMMERCIAL	AMR	Functional	100%	57	0.17			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ318A-1	400	COMMERCIAL	AMR	Functional	100%	83	0.17			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ654A-1	400	RESIDENTIAL	AMR	Functional	100%	102	0.16			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ313A-1	400	RESIDENTIAL		Functional	100%	49	0.16			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ392A-1	400	RESIDENTIAL		Functional	100%	109	0.14			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ398A-1	400	RESIDENTIAL	AMR	Functional	100%	7	0.13			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ068A-1	400	RESIDENTIAL	AMR	Functional	100%	90	0.13			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ315A-1	400	RESIDENTIAL		Functional	100%	59	0.12			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ391A-1	400	RESIDENTIAL	AMR	Functional	100%	31	0.11			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ444A-1	100	RESIDENTIAL		Functional	100%	32	0.10			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ060A-1	400	RESIDENTIAL		Functional	100%	39	0.09			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	521D4V-VKJ878A-	400	RESIDENTIAL		Functional	100%	0	0.09			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ745A-1	250	RESIDENTIAL	AMR	Functional	100%	1	0.08			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	521D4V-VKJ522A-	400	COMMERCIAL	AMR	Functional	100%	6	0.06			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	521D4V-VKJ800A-	250	RESIDENTIAL	AMR	Functional	100%	2	0.06			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	521D4V-VKJ858A-	400	RESIDENTIAL	AMR	Functional	100%	2	0.06			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ563A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.05			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ314A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.05			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ417A-1	100	RESIDENTIAL		Functional	100%	2	0.05			
66 kV C - DOT GRID	SCDOT104	11KV FDR NICF GHITORNI	TP-VKJ559A-1	100	RESIDENTIAL	AMR	Functional	100%	6	0.04			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ659A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.04			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ561A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.04			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ733A-1	100	COMMERCIAL	AMR	Functional	100%	14	0.04			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ452A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.02			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ328A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ681A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	521D4V-VKJ855A-	100	RESIDENTIAL		Functional	100%	1	0.02			
33 kV ANDHERIA BAGH GRID	SABAG114	11 kV FDR O/G TO LIVER INSTITUTE VASANT KUNJ	TP-VKJ362A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ438A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ749A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11KV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ227A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02			

66 kv VASANT KUNJ B - BLK GRID	SVKGB115	11kv FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ661A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02			
66 kv VASANT KUNJ B - BLK GRID	SVKGB115	11kv FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ351A-1	100	COMMERCIAL	AMR	Functional	100%	23	0.02			
66 kv VASANT KUNJ B - BLK GRID	SVKGB115	11kv FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ521A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.01			
66 kv VASANT KUNJ B - BLK GRID	SVKGB115	11kv FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ730A-1	100	COMMERCIAL		Functional	100%	2	0.01			
33 kv ANDHERIA BAGH GRID	SABAG114	11 kv FDR O/G TO LIVER INSTITUTE VASANT KUNJ	521D4V-VKJ837A-	250	RESIDENTIAL		Functional	100%	1	0.01			
66 kv VASANT KUNJ B - BLK GRID	SVKGB115	11kv FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ365A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kv VASANT KUNJ B - BLK GRID	SVKGB115	11kv FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ367A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kv VASANT KUNJ B - BLK GRID	SVKGB115	11kv FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ582A-1	100	RESIDENTIAL		Functional	100%	1	0.00			
66 kv C - DOT GRID	SCDOT104	11kv FDR NICF GHITORNI	TP-VKJ308A-1	400	COMMERCIAL	AMR	Functional	100%	116	0.42	1.17	0.12	9.32%
66 kv C - DOT GRID	SCDOT104	11kv FDR NICF GHITORNI	TP-VKJ427A-1	400	COMMERCIAL	AMR	Functional	100%	299	0.34			
66 kv C - DOT GRID	SCDOT104	11kv FDR NICF GHITORNI	521D4V-VKJ854A-	630	RESIDENTIAL	AMR	Functional	100%	32	0.17			
66 kv C - DOT GRID	SCDOT104	11kv FDR NICF GHITORNI	TG-VKJ734A-1	630	COMMERCIAL	AMR	Functional	100%	58	0.16			
66 kv C - DOT GRID	SCDOT104	11kv FDR NICF GHITORNI	TP-VKJ409A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.13			
66 kv C - DOT GRID	SCDOT104	11kv FDR NICF GHITORNI	TP-VKJ662A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.03			
66 kv C - DOT GRID	SCDOT104	11kv FDR NICF GHITORNI	TP-VKJ554A-1	400	COMMERCIAL	AMR	Functional	100%	1	0.02			
66 kv C - DOT GRID	SCDOT104	11kv FDR NICF GHITORNI	TP-VKJ668A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kv C - DOT GRID	SCDOT104	11kv FDR NICF GHITORNI	TP-VKJ765A-1	100	RESIDENTIAL		Functional	100%	1	0.00			
66 kv C - DOT GRID	SCDOT107	11kv FDR NITRO NO.-1 (OPP. GHITORANI BUS STAND)	TG-VKJ008A-1	630	RESIDENTIAL	AMR	Functional	100%	9	0.24	1.38	0.11	7.18%
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ404A-1	400	COMMERCIAL		Functional	100%	12	0.20			
33 kv ANDHERIA BAGH GRID	SABAG120	11kv FDR O/G TO GHITORANI	TP-VKJ407A-1	400	RESIDENTIAL	AMR	Functional	100%	17	0.19			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ477A-1	400	COMMERCIAL		Functional	100%	39	0.17			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ517A-1	400	COMMERCIAL	AMR	Functional	100%	27	0.10			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ619A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.09			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ483A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.09			
220KV MEHRAULI TRANSCO GRID	TDTMG106	11kv FDR MEERA CHATTARPUR VILLAGE	TP-VKJ621A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.07			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ312A-1	400	RESIDENTIAL		Functional	100%	36	0.05			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ485A-1	100	COMMERCIAL	AMR	Functional	100%	0	0.05			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ414A-1	100	RESIDENTIAL		Functional	100%	1	0.04			
33 kv ANDHERIA BAGH GRID	SABAG120	11kv FDR O/G TO GHITORANI	TP-VKJ406A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.04			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ518A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.03			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ455A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.03			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ776A-1	400	RESIDENTIAL		Functional	100%	3	0.03			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ658A-1	100	MIXED	AMR	Functional	100%	14	0.01			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ620A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ405A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ746A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ478A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.01			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ616A-1	100	MIXED	AMR	Functional	100%	1	0.01			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ618A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
33 kv ANDHERIA BAGH GRID	SABAG104	11kv FDR O/G TO MANGALAPURI	TP-VKJ578A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.00			
66 kv VASANT KUNJ D - BLK GRID	SVKJD113	11kv FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	TP-VKJ397A-1	400	COMMERCIAL	AMR	Functional	100%	52	0.37	2.30	0.09	3.63%
66 kv VASANT KUNJ D - BLK GRID	SVKJD113	11kv FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	TG-VKJ324A-1	400	COMMERCIAL	AMR	Functional	100%	124	0.25			
66 kv VASANT KUNJ D - BLK GRID	SVKJD113	11kv FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	TG-VKJ035A-1	630	COMMERCIAL	AMR	Functional	100%	150	0.22			
66 kv VASANT KUNJ D - BLK GRID	SVKJD113	11kv FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	TG-VKJ033A-1	630	COMMERCIAL	AMR	Functional	100%	144	0.20			
66 kv VASANT KUNJ D - BLK GRID	SVKJD113	11kv FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	TG-VKJ033A-2	630	COMMERCIAL	AMR	Functional	100%	223	0.18			
66 kv VASANT KUNJ B - BLK GRID	SVKGB115	11kv FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TG-VKJ032A-2	990	COMMERCIAL	AMR	Functional	100%	102	0.17			
66 kv VASANT KUNJ B - BLK GRID	SVKGB115	11kv FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TG-VKJ032A-1	630	COMMERCIAL	AMR	Functional	100%	125	0.16			
66 kv VASANT KUNJ D - BLK GRID	SVKJD113	11kv FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	TG-VKJ035A-2	630	COMMERCIAL	AMR	Functional	100%	115	0.14			
66 kv VASANT KUNJ D - BLK GRID	SVKJD113	11kv FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	TP-VKJ034A-1	630	COMMERCIAL	AMR	Functional	100%	95	0.14			
66 kv VASANT KUNJ D - BLK GRID	SVKJD113	11kv FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	TP-VKJ034A-2	400	COMMERCIAL	AMR	Functional	100%	77	0.12			

66 kV VASANT KUNJ D - BLK GRID	SVKJD113	11kV FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	521C9V-VKJ876A-	100	RESIDENTIAL		Functional	100%	32	0.10			
66 kV VASANT KUNJ D - BLK GRID	SVKJD113	11kV FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	TP-VKJ036A-1	400	COMMERCIAL	AMR	Functional	100%	74	0.10			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11kV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	521D4V-VKJ896A-	400	MIXED		Functional	100%	52	0.07			
66 kV VASANT KUNJ D - BLK GRID	SVKJD113	11kV FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	TP-VKJ566A-1	400	RESIDENTIAL		Functional	100%	1	0.06			
66 kV VASANT KUNJ D - BLK GRID	SVKJD113	11kV FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	TP-VKJ457A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.03			
66 kV VASANT KUNJ D - BLK GRID	SVKJD113	11kV FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	TP-VKJ437A-1	100	COMMERCIAL		Functional	100%	1	0.03			
66 kV VASANT KUNJ D - BLK GRID	SVKJD113	11kV FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	TP-VKJ436A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.02			
66 kV VASANT KUNJ D - BLK GRID	SVKJD113	11kV FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	TP-VKJ567A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01			
66 kV VASANT KUNJ D - BLK GRID	SVKJD113	11kV FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	TP-VKJ568A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.01			
66 kV VASANT KUNJ D - BLK GRID	SVKJD113	11kV FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	521B1V-VKJ851A-	250	COMMERCIAL		Functional	100%	1	0.01			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11kV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ472A-1	990	COMMERCIAL	AMR	Functional	100%	211	0.75	3.17	0.20	5.86%
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11kV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TG-VKJ026A-1	990	COMMERCIAL	AMR	Functional	100%	152	0.27			
33 kV ANDHERIA BAGH GRID	SABAG110	11kV FDR O/G TO VASANT KUNJ SECTOR-6, D-1	TP-VKJ029A-1	630	COMMERCIAL	AMR	Functional	100%	216	0.26			
33 kV ANDHERIA BAGH GRID	SABAG110	11kV FDR O/G TO VASANT KUNJ SECTOR-6, D-1	TG-VKJ031A-1	630	COMMERCIAL		Functional	100%	109	0.22			
33 kV ANDHERIA BAGH GRID	SABAG110	11kV FDR O/G TO VASANT KUNJ SECTOR-6, D-1	TG-VKJ028A-2	990	COMMERCIAL	AMR	Functional	100%	181	0.20			
33 kV ANDHERIA BAGH GRID	SABAG110	11kV FDR O/G TO VASANT KUNJ SECTOR-6, D-1	TG-VKJ031A-2	630	COMMERCIAL	AMR	Functional	100%	110	0.18			
33 kV ANDHERIA BAGH GRID	SABAG110	11kV FDR O/G TO VASANT KUNJ SECTOR-6, D-1	TP-VKJ029A-2	630	COMMERCIAL	AMR	Functional	100%	48	0.17			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11kV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TG-VKJ027A-1	630	COMMERCIAL	AMR	Functional	100%	131	0.16			
33 kV ANDHERIA BAGH GRID	SABAG104	11kV FDR O/G TO MANGALAPURI	TG-VKJ066A-2	400	COMMERCIAL	AMR	Functional	100%	15	0.15			
33 kV ANDHERIA BAGH GRID	SABAG110	11kV FDR O/G TO VASANT KUNJ SECTOR-6, D-1	521D4V-VKJ237A-	400	RESIDENTIAL	AMR	Functional	100%	2	0.15			
33 kV ANDHERIA BAGH GRID	SABAG110	11kV FDR O/G TO VASANT KUNJ SECTOR-6, D-1	TP-VKJ030A-1	630	COMMERCIAL	AMR	Functional	100%	253	0.15			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11kV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ553A-1	400	COMMERCIAL		Functional	100%	78	0.14			
33 kV ANDHERIA BAGH GRID	SABAG110	11kV FDR O/G TO VASANT KUNJ SECTOR-6, D-1	TP-VKJ030A-2	400	COMMERCIAL	AMR	Functional	100%	5	0.14			
66 kV VASANT KUNJ D - BLK GRID	SVKJD113	11kV FDR O/G TO S/STN. NO.-11,D-4 V.KUNJ	521D4V-VKJ877A-	400	MIXED		Functional	100%	0	0.09			
33 kV ANDHERIA BAGH GRID	SABAG110	11kV FDR O/G TO VASANT KUNJ SECTOR-6, D-1	TP-VKJ393A-1	100	COMMERCIAL	AMR	Functional	100%	66	0.08			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11kV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TG-VKJ562A-1	630	COMMERCIAL		Functional	100%	33	0.08			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11kV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TG-VKJ562A-2	400	COMMERCIAL		Functional	100%	12	0.06			
33 kV ANDHERIA BAGH GRID	SABAG110	11kV FDR O/G TO VASANT KUNJ SECTOR-6, D-1	TP-VKJ321A-1	100	COMMERCIAL		Functional	100%	7	0.05			
33 kV ANDHERIA BAGH GRID	SABAG110	11kV FDR O/G TO VASANT KUNJ SECTOR-6, D-1	TG-VKJ028A-1	400	COMMERCIAL	AMR	Functional	100%	1	0.04			
66 kV VASANT KUNJ B - BLK GRID	SVKGB115	11kV FDR S/S NO.-1, B-5 & 6 VASANT KUNJ	TP-VKJ007A-1	400	COMMERCIAL		Functional	100%	0	0.03			
66 kV C - DOT GRID	SCDOT104	11kV FDR NICF GHITORNI	TG-VKJ558A-1	400	RESIDENTIAL	AMR	Functional	100%	83	0.27	0.68	0.12	14.43%
66 kV C - DOT GRID	SCDOT104	11kV FDR NICF GHITORNI	TP-VKJ557A-1	400	COMMERCIAL	AMR	Functional	100%	117	0.16			
66 kV C - DOT GRID	SCDOT104	11kV FDR NICF GHITORNI	TP-VKJ555A-1	400	COMMERCIAL		Functional	100%	31	0.11			
66 kV C - DOT GRID	SCDOT104	11kV FDR NICF GHITORNI	TP-VKJ795A-1	250	RESIDENTIAL	AMR	Functional	100%	1	0.07			
66 kV C - DOT GRID	SCDOT104	11kV FDR NICF GHITORNI	TP-VKJ429A-1	100	COMMERCIAL		Functional	100%	2	0.06			
66 kV C - DOT GRID	SCDOT104	11kV FDR NICF GHITORNI	TP-VKJ310A-1	400	COMMERCIAL		Functional	100%	28	0.05			
66 kV C - DOT GRID	SCDOT104	11kV FDR NICF GHITORNI	TP-VKJ430A-1	100	COMMERCIAL		Functional	100%	1	0.03			
66 kV C - DOT GRID	SCDOT104	11kV FDR NICF GHITORNI	521D4V-VKJ859A-	100	RESIDENTIAL	AMR	Functional	100%	2	0.02			
66 kV C - DOT GRID	SCDOT104	11kV FDR NICF GHITORNI	TP-VKJ415A-1	100	COMMERCIAL		Functional	100%	2	0.02			
66 kV C - DOT GRID	SCDOT104	11kV FDR NICF GHITORNI	TP-VKJ560A-1	100	RESIDENTIAL		Functional	100%	8	0.01			
66 kV C - DOT GRID	SCDOT104	11kV FDR NICF GHITORNI	TP-VKJ556A-1	100	COMMERCIAL		Functional	100%	2	0.01			
66 kV C - DOT GRID	SCDOT104	11kV FDR NICF GHITORNI	TP-VKJ635A-1	100	MIXED		Functional	100%	1	0.00			
66 kV C - DOT GRID	SCDOT104	11kV FDR NICF GHITORNI	TP-VKJ416A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.00			
66 kV VASANT KUNJ D - BLK GRID	SVKJD117	11kV FDR O/G S/STN. NO.-3,805 MEGHA HOUSING V. KUNJ	TI-VKJ692A-2	990	MIXED		Functional	100%	121	0.12	0.60	0.03	5.01%
66 kV VASANT KUNJ D - BLK GRID	SVKJD117	11kV FDR O/G S/STN. NO.-3,805 MEGHA HOUSING V. KUNJ	TI-VKJ691A-2	990	MIXED	AMR	Functional	100%	44	0.11			
66 kV VASANT KUNJ D - BLK GRID	SVKJD117	11kV FDR O/G S/STN. NO.-3,805 MEGHA HOUSING V. KUNJ	TI-VKJ693A-1	400	MIXED	AMR	Functional	100%	49	0.09			
66 kV VASANT KUNJ D - BLK GRID	SVKJD117	11kV FDR O/G S/STN. NO.-3,805 MEGHA HOUSING V. KUNJ	TI-VKJ694A-1	990	MIXED	AMR	Functional	100%	167	0.08			
66 kV VASANT KUNJ D - BLK GRID	SVKJD117	11kV FDR O/G S/STN. NO.-3,805 MEGHA HOUSING V. KUNJ	TI-VKJ693A-2	990	MIXED	AMR	Functional	100%	190	0.08			
66 kV VASANT KUNJ D - BLK GRID	SVKJD117	11kV FDR O/G S/STN. NO.-3,805 MEGHA HOUSING V. KUNJ	TI-VKJ694A-2	990	MIXED	AMR	Functional	100%	64	0.07			
66 kV VASANT KUNJ D - BLK GRID	SVKJD117	11kV FDR O/G S/STN. NO.-3,805 MEGHA HOUSING V. KUNJ	TI-VKJ691A-1	990	MIXED	AMR	Functional	100%	90	0.05			

66 kV VASANT KUNJ D - BLK GRID	SVKJD117	11kV FDR O/G S/STN. NO.-3,805 MEGHA HOUSING V. KUNJ	TI-VKJ692A-1	990	MIXED	AMR	Functional	100%	115	0.04	4.99	0.14	2.76%
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TG-VKJ131A-1	990	COMMERCIAL		Functional	100%	554	0.84			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11kV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	TG-VKJ162A-1	990	RESIDENTIAL		Functional	100%	432	0.57			
66 kV PALAM GRID	SPLAP121	11kV FDR GOLDEN GATE WESTERN GREEN	TG-VKJ132A-1	990	RESIDENTIAL	AMR	Functional	100%	761	0.57			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TP-VKJ178A-1	990	COMMERCIAL		Functional	100%	723	0.52			
66 kV PALAM GRID	SPLAP121	11kV FDR GOLDEN GATE WESTERN GREEN	TP-VKJ731A-1	630	RESIDENTIAL	AMR	Functional	100%	430	0.46			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11kV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	TG-VKJ195A-1	400	RESIDENTIAL	AMR	Functional	100%	335	0.43			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TG-VKJ373A-1	630	COMMERCIAL	AMR	Functional	100%	605	0.43			
66 kV PALAM GRID	SPLAP121	11kV FDR GOLDEN GATE WESTERN GREEN	2521KPS-VKJ445A-1	630	RESIDENTIAL	AMR	Functional	100%	75	0.34			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11kV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	TP-VKJ161A-1	400	RESIDENTIAL		Functional	100%	345	0.32			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11kV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	TP-VKJ503A-1	400	RESIDENTIAL	AMR	Functional	100%	356	0.26			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TP-VKJ453A-1	400	COMMERCIAL		Functional	100%	37	0.14			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TG-VKJ637A-1	400	MIXED	AMR	Functional	100%	22	0.13			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TP-VKJ193A-1	400	COMMERCIAL		Functional	100%	21	0.08			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TP-VKJ055A-1	100	COMMERCIAL		Functional	100%	4	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TP-VKJ276A-1	100	COMMERCIAL		Functional	100%	6	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11kV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	TP-VKJ194A-1	100	RESIDENTIAL		Functional	100%	1	0.01			
66 kV VASANT KUNJ C- BLK GRID	SVKJC108	11kV FDR NANGAL DAIRY O/H	TP-VKJ180A-1	990	COMMERCIAL	AMR	Functional	100%	14	0.35	0.53	0.02	2.94%
66 kV VASANT KUNJ C- BLK GRID	SVKJC108	11kV FDR NANGAL DAIRY O/H	TP-VKJ684A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.08			
66 kV VASANT KUNJ C- BLK GRID	SVKJC104	11kV FDR INSITUTIONAL AREA VASANT KUNJ.	TP-VKJ705A-1	400	COMMERCIAL	AMR	Functional	100%	4	0.04			
66 kV VASANT KUNJ C- BLK GRID	SVKJC108	11kV FDR L.I.G MASOODPUR + I.S.I.D.V. KUNJ	TP-VKJ418A-1	400	COMMERCIAL	AMR	Functional	100%	5	0.03			
66 kV VASANT KUNJ INSTITUTIONAL AREA G	SVKIA102	11kV STR 400kVA STATION TRF.	TP-STC125A-1	400	COMMERCIAL		Functional	100%	1	0.02			
66 kV VASANT KUNJ C- BLK GRID	SVKJC104	11kV FDR INSITUTIONAL AREA VASANT KUNJ.	2521C9V-VKJ871A-1	100	COMMERCIAL	AMR	Functional	100%	0	0.01			
66 kV VASANT KUNJ C- BLK GRID	SVKJC107	11kV FDR S/STN. NO.-15, B-11 V. KUNJ	TG-VKJ144A-1	990	RESIDENTIAL	AMR	Functional	100%	435	0.96			
66 kV VASANT KUNJ C- BLK GRID	SVKJC102	11kV FDR S/STN. NO.-7, B-7, V. KUNJ	TG-VKJ283A-1	990	RESIDENTIAL	AMR	Functional	100%	1116	0.79			
66 kV VASANT KUNJ C- BLK GRID	SVKJC107	11kV FDR S/STN. NO.-15, B-11 V. KUNJ	TP-VKJ565A-1	630	AGRICULTURE	AMR	Functional	100%	206	0.50			
66 kV VASANT KUNJ C- BLK GRID	SVKJC107	11kV FDR S/STN. NO.-15, B-11 V. KUNJ	TP-VKJ103A-2	990	RESIDENTIAL	AMR	Functional	100%	85	0.48			
66 kV VASANT KUNJ C- BLK GRID	SVKJC107	11kV FDR S/STN. NO.-15, B-11 V. KUNJ	TP-VKJ104A-1	400	RESIDENTIAL	AMR	Functional	100%	367	0.37			
66 kV VASANT KUNJ C- BLK GRID	SVKJC107	11kV FDR S/STN. NO.-15, B-11 V. KUNJ	TP-VKJ103A-1	400	RESIDENTIAL	AMR	Functional	100%	986	0.25			
66 kV VASANT KUNJ C- BLK GRID	SVKJC107	11kV FDR S/STN. NO.-15, B-11 V. KUNJ	TP-VKJ104A-2	400	RESIDENTIAL	AMR	Functional	100%	117	0.14			
66 kV VASANT KUNJ C- BLK GRID	SVKJC107	11kV FDR S/STN. NO.-15, B-11 V. KUNJ	TP-VKJ423A-1	400	RESIDENTIAL	AMR	Functional	100%	46	0.07			
66 kV VASANT KUNJ C- BLK GRID	SVKJC107	11kV FDR S/STN. NO.-15, B-11 V. KUNJ	TP-VKJ383A-1	100	COMMERCIAL	AMR	Functional	100%	5	0.01			
66 kV VASANT KUNJ D - BLK GRID	SVKJD125	11kV FDR O/G TO RANGPURI NO.-1	TG-VKJ424A-1	990	RESIDENTIAL		Functional	100%	1380	0.78	4.05	0.09	2.12%
66 kV VASANT KUNJ D - BLK GRID	SVKJD125	11kV FDR O/G TO RANGPURI NO.-1	TP-VKJ335A-1	990	RESIDENTIAL	AMR	Functional	100%	535	0.66			
66 kV VASANT KUNJ D - BLK GRID	SVKJD125	11kV FDR O/G TO RANGPURI NO.-1	TG-VKJ432A-1	990	RESIDENTIAL	AMR	Functional	100%	129	0.54			
66 kV VASANT KUNJ D - BLK GRID	SVKJD116	11kV FDR O/G RANG PURI NO-II	TG-VKJ412A-1	630	RESIDENTIAL	AMR	Functional	100%	148	0.43			
66 kV VASANT KUNJ D - BLK GRID	SVKJD125	11kV FDR O/G TO RANGPURI NO.-1	TP-VKJ339A-1	990	RESIDENTIAL	AMR	Functional	100%	531	0.39			
66 kV VASANT KUNJ D - BLK GRID	SVKJD116	11kV FDR O/G RANG PURI NO-II	2521C9V-VKJ852A-1	630	RESIDENTIAL	AMR	Functional	100%	304	0.38			
66 kV VASANT KUNJ D - BLK GRID	SVKJD116	11kV FDR O/G RANG PURI NO-II	TG-VKJ413A-1	630	RESIDENTIAL		Functional	100%	198	0.30			
66 kV VASANT KUNJ D - BLK GRID	SVKJD116	11kV FDR O/G RANG PURI NO-II	TG-VKJ413A-2	630	RESIDENTIAL	AMR	Functional	100%	499	0.29			
66 kV VASANT KUNJ D - BLK GRID	SVKJD116	11kV FDR O/G RANG PURI NO-II	TG-VKJ412A-2	630	RESIDENTIAL	AMR	Functional	100%	461	0.27			
66 kV VASANT KUNJ D - BLK GRID	SVKJD125	11kV FDR O/G TO RANGPURI NO.-1	TP-VKJ514A-1	400	COMMERCIAL		Functional	100%	1	0.04			

66 kV VASANT KUNJ D - BLK GRID	SVKJD125	11kV FDR O/G TO RANGPURI NO.-1	TP-VKJ181A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kV VASANT KUNJ D - BLK GRID	SVKJD125	11kV FDR O/G TO RANGPURI NO.-1	TP-VKJ182A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.02			
66 kV VASANT KUNJ D - BLK GRID	SVKJD125	11kV FDR O/G TO RANGPURI NO.-1	TP-VKJ253A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV VASANT KUNJ D - BLK GRID	SVKJD125	11kV FDR O/G TO RANGPURI NO.-1	TP-VKJ513A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			
66 kV VASANT KUNJ D - BLK GRID	SVKJD125	11kV FDR O/G TO RANGPURI NO.-1	TP-VKJ762A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.00			
66 kV VASANT KUNJ D - BLK GRID	SVKJD125	11kV FDR O/G TO RANGPURI NO.-1	TP-VKJ244A-1	100	RESIDENTIAL	AMR	Functional	100%	0	0.00			
66 kV VASANT KUNJ C - BLK GRID	SVKJC101	11kV FDR S/STN. NO.-12, B-10 V. KUNJ	TP-VKJ094A-1	630	COMMERCIAL	AMR	Functional	100%	149	0.25	1.47	0.09	5.76%
66 kV VASANT KUNJ D - BLK GRID	SVKJD116	11kV FDR O/G RANG PURI NO-II	2521C9V-VKJ886A-	630	MIXED		Functional	100%	0	0.24			
66 kV VASANT KUNJ C - BLK GRID	SVKJC101	11kV FDR S/STN. NO.-12, B-10 V. KUNJ	TP-VKJ094A-2	630	COMMERCIAL	AMR	Functional	100%	69	0.20			
66 kV VASANT KUNJ C - BLK GRID	SVKJC110	11kV FDR B-8 V. KUNJ (VIA GOINKA SCHOOL)	TG-VKJ097A-2	630	COMMERCIAL	AMR	Functional	100%	86	0.17			
66 kV VASANT KUNJ C - BLK GRID	SVKJC110	11kV FDR B-8 V. KUNJ (VIA GOINKA SCHOOL)	TG-VKJ097A-1	630	COMMERCIAL	AMR	Functional	100%	92	0.17			
66 kV VASANT KUNJ C - BLK GRID	SVKJC101	11kV FDR S/STN. NO.-12, B-10 V. KUNJ	TG-VKJ095A-1	630	COMMERCIAL	AMR	Functional	100%	192	0.12			
66 kV VASANT KUNJ C - BLK GRID	SVKJC101	11kV FDR S/STN. NO.-12, B-10 V. KUNJ	TG-VKJ095A-2	630	COMMERCIAL	AMR	Functional	100%	103	0.11			
66 kV VASANT KUNJ C - BLK GRID	SVKJC101	11kV FDR S/STN. NO.-12, B-10 V. KUNJ	TG-VKJ093A-1	630	COMMERCIAL	AMR	Functional	100%	6	0.10			
66 kV VASANT KUNJ C - BLK GRID	SVKJC101	11kV FDR S/STN. NO.-12, B-10 V. KUNJ	TG-VKJ093A-2	630	COMMERCIAL	AMR	Functional	100%	58	0.08			
66 kV VASANT KUNJ C - BLK GRID	SVKJC101	11kV FDR S/STN. NO.-12, B-10 V. KUNJ	TG-VKJ096A-1	630	COMMERCIAL		Functional	100%	61	0.06			
66 kV VASANT KUNJ C - BLK GRID	SVKJC101	11kV FDR S/STN. NO.-12, B-10 V. KUNJ	TP-VKJ425A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.04			
66 kV VASANT KUNJ C - BLK GRID	SVKJC107	11kV FDR S/STN. NO.-15, B-11 V. KUNJ	TG-VKJ099A-1	630	COMMERCIAL	AMR	Functional	100%	185	0.22	0.50	0.01	1.53%
66 kV VASANT KUNJ C - BLK GRID	SVKJC102	11kV FDR S/STN. NO.-7, B-7,V. KUNJ	TG-VKJ098A-1	630	COMMERCIAL	AMR	Functional	100%	114	0.22			
66 kV VASANT KUNJ C - BLK GRID	SVKJC102	11kV FDR S/STN. NO.-7, B-7,V. KUNJ	TP-VKJ255A-1	400	COMMERCIAL	AMR	Functional	100%	5	0.08			
66 kV VASANT KUNJ C - BLK GRID	SVKJC102	11kV FDR S/STN. NO.-7, B-7,V. KUNJ	TG-VKJ341A-1	630	RESIDENTIAL	AMR	Functional	100%	190	0.35	1.63	0.01	0.44%
66 kV VASANT KUNJ C - BLK GRID	SVKJC101	11kV FDR S/STN. NO.-12, B-10 V. KUNJ	TP-VKJ100A-2	630	COMMERCIAL	AMR	Functional	100%	164	0.22			
66 kV VASANT KUNJ C - BLK GRID	SVKJC102	11kV FDR S/STN. NO.-7, B-7,V. KUNJ	TP-VKJ168A-1	400	RESIDENTIAL	AMR	Functional	100%	217	0.21			
66 kV VASANT KUNJ C - BLK GRID	SVKJC101	11kV FDR S/STN. NO.-12, B-10 V. KUNJ	TP-VKJ100A-1	400	COMMERCIAL	AMR	Functional	100%	155	0.20			
66 kV VASANT KUNJ C - BLK GRID	SVKJC110	11kV FDR B-8 V. KUNJ (VIA GOINKA SCHOOL)	TG-VKJ101A-2	630	RESIDENTIAL	AMR	Functional	100%	106	0.20			
66 kV VASANT KUNJ C - BLK GRID	SVKJC110	11kV FDR B-8 V. KUNJ (VIA GOINKA SCHOOL)	TG-VKJ101A-1	630	RESIDENTIAL	AMR	Functional	100%	162	0.17			
66 kV VASANT KUNJ C - BLK GRID	SVKJC102	11kV FDR S/STN. NO.-7, B-7,V. KUNJ	TG-VKJ102A-2	630	RESIDENTIAL	AMR	Functional	100%	135	0.16			
66 kV VASANT KUNJ C - BLK GRID	SVKJC102	11kV FDR S/STN. NO.-7, B-7,V. KUNJ	TG-VKJ102A-1	630	RESIDENTIAL	AMR	Functional	100%	76	0.13			
66 kV VASANT KUNJ C - BLK GRID	SVKJC111	11kV FDR S/STN NO.-2, C-4 V KUNJ VIA POLICE STATION	TP-VKJ421A-1	630	COMMERCIAL	AMR	Functional	100%	16	0.17	0.45	0.01	2.16%
66 kV VASANT KUNJ C - BLK GRID	SVKJC111	11kV FDR S/STN NO.-2, C-4 V KUNJ VIA POLICE STATION	TP-VKJ078A-1	400	COMMERCIAL	AMR	Functional	100%	128	0.14			
66 kV VASANT KUNJ C - BLK GRID	SVKJC111	11kV FDR S/STN NO.-2, C-4 V KUNJ VIA POLICE STATION	TP-VKJ077A-1	400	COMMERCIAL		Functional	100%	57	0.11			
66 kV VASANT KUNJ C - BLK GRID	SVKJC111	11kV FDR S/STN NO.-2, C-4 V KUNJ VIA POLICE STATION	TP-VKJ421A-2	630	COMMERCIAL	AMR	Functional	100%	12	0.02			
66 kV VASANT KUNJ C - BLK GRID	SVKJC115	11kV STR 400kVA STATION TRANS.	VK-STC104A-1	400	MIXED	AMR	Functional	100%	1	0.02			
220kV VASANT KUNJ TRANSCO GR	TDTV107	11kV FDR C-8 S/S NO.-1 VASANT KUNJ	TG-VKJ084A-2	630	COMMERCIAL	AMR	Functional	100%	318	0.42	1.75	0.02	1.27%
220kV VASANT KUNJ TRANSCO GR	TDTV107	11kV FDR C-8 S/S NO.-1 VASANT KUNJ	TG-VKJ084A-1	630	COMMERCIAL		Functional	100%	5	0.25			
220kV VASANT KUNJ TRANSCO GR	TDTV107	11kV FDR C-8 S/S NO.-1 VASANT KUNJ	TI-VKJ085A-1	630	COMMERCIAL	AMR	Functional	100%	252	0.24			
220kV VASANT KUNJ TRANSCO GR	TDTV107	11kV FDR C-8 S/S NO.-1 VASANT KUNJ	TG-VKJ086A-1	630	COMMERCIAL		Functional	100%	524	0.20			
220kV VASANT KUNJ TRANSCO GR	TDTV107	11kV FDR C-8 S/S NO.-1 VASANT KUNJ	TG-VKJ085A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.18			
220kV VASANT KUNJ TRANSCO GR	TDTV107	11kV FDR C-8 S/S NO.-1 VASANT KUNJ	TG-VKJ086A-2	630	COMMERCIAL		Functional	100%	43	0.16			
220kV VASANT KUNJ TRANSCO GR	TDTV107	11kV FDR C-8 S/S NO.-1 VASANT KUNJ	TP-VKJ083A-1	400	COMMERCIAL	AMR	Functional	100%	77	0.13			
220kV VASANT KUNJ TRANSCO GR	TDTV107	11kV FDR C-8 S/S NO.-1 VASANT KUNJ	TP-VKJ083A-2	400	COMMERCIAL	AMR	Functional	100%	64	0.12			
66 kV VASANT KUNJ D - BLK GRID	SVKJD101	11kV FDR NANGAL DAIRY NO.-1	TP-VKJ239A-2	400	MIXED	AMR	Functional	100%	1	0.04			
66 kV VASANT KUNJ D - BLK GRID	SVKJD101	11kV FDR NANGAL DAIRY NO.-1	TP-VKJ240A-1	100	COMMERCIAL	AMR	Functional	100%	7	0.02			
220kV VASANT KUNJ TRANSCO GR	TDTV102	11kV FDR C-8 S/S NO.-1 F-2	TP-VKJ781A-1	400	RESIDENTIAL	AMR	Functional	100%	2	0.02			
66 kV VASANT KUNJ C - BLK GRID	SVKJC107	11kV FDR S/STN. NO.-15, B-11 V. KUNJ	2521C9V-VKJ900A-	990	MIXED		Functional	100%	0	0.47	2.36	0.09	3.84%

220kV VASANT KUNJ TRANSCO GR	TDTVG103	11kV FDR C-9 S/S NO.-5 VASANT KUNJ	TG-VKJ087A-2	990	COMMERCIAL	AMR	Functional	100%	186	0.27			
220kV VASANT KUNJ TRANSCO GR	TDTVG106	11kV FDR C-9 S/S NO.-2 VASANT KUNJ	TG-VKJ090A-1	630	COMMERCIAL	AMR	Functional	100%	147	0.24			
220kV VASANT KUNJ TRANSCO GR	TDTVG106	11kV FDR C-9 S/S NO.-2 VASANT KUNJ	TG-VKJ089A-1	630	COMMERCIAL		Functional	100%	117	0.23			
220kV VASANT KUNJ TRANSCO GR	TDTVG106	11kV FDR C-9 S/S NO.-2 VASANT KUNJ	TG-VKJ088A-1	630	COMMERCIAL	AMR	Functional	100%	128	0.21			
220kV VASANT KUNJ TRANSCO GR	TDTVG103	11kV FDR C-9 S/S NO.-5 VASANT KUNJ	TG-VKJ087A-1	630	COMMERCIAL		Functional	100%	18	0.19			
66 kV VASANT KUNJ D - BLK GRID	SVKJD125	11kV FDR O/G TO RANGPURI NO.-1	2521C9V-VKJ901A-	400	MIXED		Functional	100%	0	0.14			
220kV VASANT KUNJ TRANSCO GR	TDTVG106	11kV FDR C-9 S/S NO.-2 VASANT KUNJ	TG-VKJ090A-2	630	COMMERCIAL	AMR	Functional	100%	72	0.14			
220kV VASANT KUNJ TRANSCO GR	TDTVG106	11kV FDR C-9 S/S NO.-2 VASANT KUNJ	TG-VKJ089A-2	630	COMMERCIAL	AMR	Functional	100%	119	0.14			
220kV VASANT KUNJ TRANSCO GR	TDTVG103	11kV FDR C-9 S/S NO.-5 VASANT KUNJ	TG-VKJ092A-1	400	COMMERCIAL	AMR	Functional	100%	50	0.11			
220kV VASANT KUNJ TRANSCO GR	TDTVG103	11kV FDR C-9 S/S NO.-5 VASANT KUNJ	TG-VKJ092A-2	400	COMMERCIAL		Functional	100%	103	0.11			
220kV VASANT KUNJ TRANSCO GR	TDTVG103	11kV FDR C-9 S/S NO.-5 VASANT KUNJ	TP-VKJ091A-1	400	COMMERCIAL		Functional	100%	79	0.11			
220kV VASANT KUNJ TRANSCO GR	TDTVG103	11kV FDR C-9 S/S NO.-5 VASANT KUNJ	TP-VKJ091A-2	400	COMMERCIAL	AMR	Functional	100%	40	0.10			
66 kV VASANT KUNJ D - BLK GRID	SVKJD119	11kV FDR 11kV O/G S/STN. NO.-1,1904 MEGHA HOUSING V. KUNJ	2521C9V-VKJ908A-	100	MIXED		Functional	100%	0	0.00			
66 kV VASANT KUNJ C- BLK GRID	SVKJC106	11kV FDR S/STN. NO.-5, C-2 V. KUNJ	TG-VKJ074A-1	630	COMMERCIAL	AMR	Functional	100%	221	0.31	3.36	0.12	3.37%
66 kV VASANT KUNJ C- BLK GRID	SVKJC106	11kV FDR S/STN. NO.-5, C-2 V. KUNJ	TG-VKJ073A-1	630	COMMERCIAL	AMR	Functional	100%	168	0.29			
66 kV VASANT KUNJ C- BLK GRID	SVKJC105	11kV FDR S/STN. NO.-6, C-3, V. KUNJ	TP-VKJ076A-1	630	COMMERCIAL	AMR	Functional	100%	195	0.27			
66 kV VASANT KUNJ C- BLK GRID	SVKJC105	11kV FDR S/STN. NO.-6, C-3, V. KUNJ	TG-VKJ071A-2	630	COMMERCIAL	AMR	Functional	100%	132	0.26			
66 kV VASANT KUNJ C- BLK GRID	SVKJC106	11kV FDR S/STN. NO.-5, C-2 V. KUNJ	TG-VKJ073A-2	630	COMMERCIAL	AMR	Functional	100%	124	0.26			
66 kV VASANT KUNJ C- BLK GRID	SVKJC105	11kV FDR S/STN. NO.-6, C-3, V. KUNJ	TG-VKJ071A-1	630	COMMERCIAL	AMR	Functional	100%	201	0.23			
66 kV VASANT KUNJ C- BLK GRID	SVKJC106	11kV FDR S/STN. NO.-5, C-2 V. KUNJ	TG-VKJ075A-1	630	COMMERCIAL		Functional	100%	135	0.22			
66 kV VASANT KUNJ C- BLK GRID	SVKJC111	11kV FDR S/STN NO.-2, C-4 V KUNJ VIA POLICE STATION	TG-VKJ079A-1	630	COMMERCIAL		Functional	100%	141	0.20			
66 kV VASANT KUNJ C- BLK GRID	SVKJC105	11kV FDR S/STN. NO.-6, C-3, V. KUNJ	TG-VKJ072A-1	630	COMMERCIAL		Functional	100%	117	0.20			
66 kV VASANT KUNJ C- BLK GRID	SVKJC106	11kV FDR S/STN. NO.-5, C-2 V. KUNJ	TG-VKJ075A-2	630	COMMERCIAL	AMR	Functional	100%	177	0.19			
66 kV VASANT KUNJ C- BLK GRID	SVKJC106	11kV FDR S/STN. NO.-5, C-2 V. KUNJ	TP-VKJ272A-2	630	COMMERCIAL	AMR	Functional	100%	7	0.19			
66 kV VASANT KUNJ C- BLK GRID	SVKJC111	11kV FDR S/STN NO.-2, C-4 V KUNJ VIA POLICE STATION	TG-VKJ079A-2	630	COMMERCIAL	AMR	Functional	100%	31	0.18			
66 kV VASANT KUNJ C- BLK GRID	SVKJC105	11kV FDR S/STN. NO.-6, C-3, V. KUNJ	TG-VKJ072A-2	630	COMMERCIAL	AMR	Functional	100%	149	0.17			
66 kV VASANT KUNJ C- BLK GRID	SVKJC105	11kV FDR S/STN. NO.-6, C-3, V. KUNJ	TP-VKJ076A-2	400	COMMERCIAL	AMR	Functional	100%	105	0.16			
66 kV VASANT KUNJ C- BLK GRID	SVKJC106	11kV FDR S/STN. NO.-5, C-2 V. KUNJ	TP-VKJ272A-1	400	COMMERCIAL	AMR	Functional	100%	13	0.12			
66 kV VASANT KUNJ C- BLK GRID	SVKJC105	11kV FDR S/STN. NO.-6, C-3, V. KUNJ	TG-VKJ273A-1	630	COMMERCIAL	AMR	Functional	100%	8	0.11			
66 kV VASANT KUNJ C- BLK GRID	SVKJC105	11kV FDR S/STN. NO.-6, C-3, V. KUNJ	TG-VKJ273A-2	630	COMMERCIAL		Functional	100%	7	0.07			
66 kV VASANT KUNJ D - BLK GRID	SVKJD101	11kV FDR NANGAL DAIRY NO.-1	TP-VKJ512A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.03			
66 kV VASANT KUNJ C- BLK GRID	SVKJC108	11kV FDR NANGAL DAIRY O/H	2521C9V-VKJ832A-	100	COMMERCIAL	AMR	Functional	100%	3	0.01			
66 kV VASANT KUNJ C- BLK GRID	SVKJC103	11kV FDR S/STN. NO.-1, C-6 & 7 V. KUNJ	TG-VKJ080A-2	630	COMMERCIAL	AMR	Functional	100%	176	0.23	0.94	0.02	2.57%
66 kV VASANT KUNJ C- BLK GRID	SVKJC103	11kV FDR S/STN. NO.-1, C-6 & 7 V. KUNJ	TG-VKJ080A-1	630	COMMERCIAL		Functional	100%	107	0.21			
66 kV VASANT KUNJ C- BLK GRID	SVKJC103	11kV FDR S/STN. NO.-1, C-6 & 7 V. KUNJ	TG-VKJ082A-1	630	COMMERCIAL	AMR	Functional	100%	100	0.15			
66 kV VASANT KUNJ C- BLK GRID	SVKJC103	11kV FDR S/STN. NO.-1, C-6 & 7 V. KUNJ	TP-VKJ081A-2	400	COMMERCIAL	AMR	Functional	100%	49	0.14			
66 kV VASANT KUNJ C- BLK GRID	SVKJC103	11kV FDR S/STN. NO.-1, C-6 & 7 V. KUNJ	TP-VKJ081A-1	400	COMMERCIAL		Functional	100%	109	0.12			
66 kV VASANT KUNJ C- BLK GRID	SVKJC103	11kV FDR S/STN. NO.-1, C-6 & 7 V. KUNJ	TG-VKJ082A-2	630	COMMERCIAL	AMR	Functional	100%	60	0.12			
66 kV VASANT KUNJ D - BLK GRID	SVKJD105	11kV FDR V. KUNJ S/STN. NO.-3 D-6	TI-VKJ113A-2	630	COMMERCIAL		Functional	100%	158	0.19	1.25	0.08	6.04%
66 kV VASANT KUNJ D - BLK GRID	SVKJD103	11kV FDR O/G S/STN. NO.-1, D-6 V. KUNJ	TP-VKJ110A-2	400	COMMERCIAL	AMR	Functional	100%	7	0.16			
66 kV VASANT KUNJ D - BLK GRID	SVKJD103	11kV FDR O/G S/STN. NO.-1, D-6 V. KUNJ	TP-VKJ110A-1	400	COMMERCIAL	AMR	Functional	100%	197	0.15			
66 kV VASANT KUNJ D - BLK GRID	SVKJD105	11kV FDR V. KUNJ S/STN. NO.-3 D-6	TI-VKJ113A-1	630	COMMERCIAL		Functional	100%	101	0.14			
66 kV VASANT KUNJ D - BLK GRID	SVKJD103	11kV FDR O/G S/STN. NO.-1, D-6 V. KUNJ	TG-VKJ111A-1	630	COMMERCIAL	AMR	Functional	100%	139	0.14			
66 kV VASANT KUNJ D - BLK GRID	SVKJD103	11kV FDR O/G S/STN. NO.-1, D-6 V. KUNJ	TG-VKJ111A-2	630	COMMERCIAL		Functional	100%	96	0.13			

66 kV VASANT KUNJ D - BLK GRID	SVKJD105	11kV FDR V. KUNJ S/STN. NO.-3 D-6	TP-VKJ114A-2	400	COMMERCIAL	AMR	Functional	100%	93	0.12			
66 kV VASANT KUNJ D - BLK GRID	SVKJD105	11kV FDR V. KUNJ S/STN. NO.-3 D-6	TP-VKJ114A-1	400	COMMERCIAL	AMR	Functional	100%	75	0.11			
66 kV VASANT KUNJ D - BLK GRID	SVKJD105	11kV FDR V. KUNJ S/STN. NO.-3 D-6	TG-VKJ112A-2	630	COMMERCIAL	AMR	Functional	100%	135	0.10			
66 kV VASANT KUNJ D - BLK GRID	SVKJD105	11kV FDR V. KUNJ S/STN. NO.-3 D-6	TG-VKJ112A-1	630	COMMERCIAL	AMR	Functional	100%	132	0.09			
66 kV VASANT KUNJ D - BLK GRID	SVKJD122	11kV FDR O/G S/STN. NO.-4,1904 MEGHA HOUSING V. KUNJ	TI-VKJ380A-2	990	COMMERCIAL	AMR	Functional	100%	69	0.30	1.58	0.00	0.22%
66 kV VASANT KUNJ D - BLK GRID	SVKJD122	11kV FDR O/G S/STN. NO.-4,1904 MEGHA HOUSING V. KUNJ	TI-VKJ380A-1	990	COMMERCIAL	AMR	Functional	100%	159	0.28			
66 kV VASANT KUNJ D - BLK GRID	SVKJD118	11kV FDR O/G S/STN. NO.-13,1904 MEGHA HOUSING V. KUNJ	TI-VKJ364A-2	990	COMMERCIAL	AMR	Functional	100%	78	0.12			
66 kV VASANT KUNJ D - BLK GRID	SVKJD122	11kV FDR O/G S/STN. NO.-4,1904 MEGHA HOUSING V. KUNJ	TI-VKJ461A-2	990	COMMERCIAL	AMR	Functional	100%	151	0.11			
66 kV VASANT KUNJ D - BLK GRID	SVKJD122	11kV FDR O/G S/STN. NO.-4,1904 MEGHA HOUSING V. KUNJ	TI-VKJ462A-1	630	COMMERCIAL	AMR	Functional	100%	124	0.10			
66 kV VASANT KUNJ D - BLK GRID	SVKJD118	11kV FDR O/G S/STN. NO.-13,1904 MEGHA HOUSING V. KUNJ	TI-VKJ363A-2	630	COMMERCIAL	AMR	Functional	100%	61	0.10			
66 kV VASANT KUNJ D - BLK GRID	SVKJD118	11kV FDR O/G S/STN. NO.-13,1904 MEGHA HOUSING V. KUNJ	TI-VKJ463A-2	630	MIXED	AMR	Functional	100%	34	0.08			
66 kV VASANT KUNJ D - BLK GRID	SVKJD122	11kV FDR O/G S/STN. NO.-4,1904 MEGHA HOUSING V. KUNJ	TI-VKJ464A-2	630	MIXED	AMR	Functional	100%	25	0.07			
66 kV VASANT KUNJ D - BLK GRID	SVKJD118	11kV FDR O/G S/STN. NO.-13,1904 MEGHA HOUSING V. KUNJ	TI-VKJ363A-1	630	COMMERCIAL	AMR	Functional	100%	20	0.07			
66 kV VASANT KUNJ D - BLK GRID	SVKJD122	11kV FDR O/G S/STN. NO.-4,1904 MEGHA HOUSING V. KUNJ	TI-VKJ462A-2	630	COMMERCIAL	AMR	Functional	100%	29	0.06			
66 kV VASANT KUNJ D - BLK GRID	SVKJD119	11kV FDR 11kV O/G S/STN. NO.-1,1904 MEGHA HOUSING V. KUNJ	TP-VKJ246A-1	100	COMMERCIAL	AMR	Functional	100%	12	0.06			
66 kV VASANT KUNJ D - BLK GRID	SVKJD122	11kV FDR O/G S/STN. NO.-4,1904 MEGHA HOUSING V. KUNJ	TI-VKJ461A-1	990	COMMERCIAL	AMR	Functional	100%	58	0.06			
66 kV VASANT KUNJ D - BLK GRID	SVKJD122	11kV FDR O/G S/STN. NO.-4,1904 MEGHA HOUSING V. KUNJ	TI-VKJ464A-1	630	MIXED		Functional	100%	70	0.06			
66 kV VASANT KUNJ D - BLK GRID	SVKJD118	11kV FDR O/G S/STN. NO.-13,1904 MEGHA HOUSING V. KUNJ	TI-VKJ364A-1	990	COMMERCIAL	AMR	Functional	100%	96	0.04			
66 kV VASANT KUNJ D - BLK GRID	SVKJD118	11kV FDR O/G S/STN. NO.-13,1904 MEGHA HOUSING V. KUNJ	TI-VKJ463A-1	630	MIXED	AMR	Functional	100%	91	0.03			
66 kV VASANT KUNJ D - BLK GRID	SVKJD119	11kV FDR 11kV O/G S/STN. NO.-1,1904 MEGHA HOUSING V. KUNJ	TP-VKJ245A-1	100	COMMERCIAL	AMR	Functional	100%	7	0.03			
66 kV VASANT KUNJ D - BLK GRID	SVKJD102	11kV FDR O/G S/STN. NO.-3,1904-MEGHA HOUSING V. KUNJ	TI-VKJ169A-2	990	COMMERCIAL	AMR	Functional	100%	166	0.12	1.31	0.02	1.39%
66 kV VASANT KUNJ D - BLK GRID	SVKJD119	11kV FDR 11kV O/G S/STN. NO.-1,1904 MEGHA HOUSING V. KUNJ	TI-VKJ650A-1	990	MIXED		Functional	100%	86	0.08			
66 kV VASANT KUNJ D - BLK GRID	SVKJD121	11kV FDR O/G S/STN. NO.-7 1904 MEGHA HOUSING V. KUNJ	TI-VKJ677A-2	630	COMMERCIAL	AMR	Functional	100%	41	0.08			
66 kV VASANT KUNJ D - BLK GRID	SVKJD122	11kV FDR O/G S/STN. NO.-4,1904 MEGHA HOUSING V. KUNJ	TI-VKJ172A-2	630	MIXED	AMR	Functional	100%	20	0.08			
66 kV VASANT KUNJ D - BLK GRID	SVKJD120	11kV FDR O/G S/STN. NO.-10,1904 MEGHA HOUSING V. KUNJ	TI-VKJ357A-1	630	COMMERCIAL	AMR	Functional	100%	82	0.08			
66 kV VASANT KUNJ D - BLK GRID	SVKJD120	11kV FDR O/G S/STN. NO.-10,1904 MEGHA HOUSING V. KUNJ	TI-VKJ356A-2	630	COMMERCIAL	AMR	Functional	100%	35	0.07			
66 kV VASANT KUNJ D - BLK GRID	SVKJD102	11kV FDR O/G S/STN. NO.-3,1904-MEGHA HOUSING V. KUNJ	TI-VKJ169A-1	990	COMMERCIAL	AMR	Functional	100%	0	0.07			
66 kV VASANT KUNJ D - BLK GRID	SVKJD120	11kV FDR O/G S/STN. NO.-10,1904 MEGHA HOUSING V. KUNJ	TI-VKJ358A-2	630	COMMERCIAL	AMR	Functional	100%	34	0.07			
66 kV VASANT KUNJ D - BLK GRID	SVKJD121	11kV FDR O/G S/STN. NO.-7 1904 MEGHA HOUSING V. KUNJ	TI-VKJ677A-1	630	COMMERCIAL	AMR	Functional	100%	59	0.07			
66 kV VASANT KUNJ D - BLK GRID	SVKJD121	11kV FDR O/G S/STN. NO.-7 1904 MEGHA HOUSING V. KUNJ	TI-VKJ173A-2	630	COMMERCIAL	AMR	Functional	100%	61	0.07			
66 kV VASANT KUNJ D - BLK GRID	SVKJD121	11kV FDR O/G S/STN. NO.-7 1904 MEGHA HOUSING V. KUNJ	TI-VKJ173A-1	630	COMMERCIAL		Functional	100%	38	0.07			
66 kV VASANT KUNJ D - BLK GRID	SVKJD120	11kV FDR O/G S/STN. NO.-10,1904 MEGHA HOUSING V. KUNJ	TI-VKJ358A-1	630	COMMERCIAL	AMR	Functional	100%	78	0.05			
66 kV VASANT KUNJ D - BLK GRID	SVKJD120	11kV FDR O/G S/STN. NO.-10,1904 MEGHA HOUSING V. KUNJ	TI-VKJ356A-1	630	COMMERCIAL	AMR	Functional	100%	14	0.05			
66 kV VASANT KUNJ D - BLK GRID	SVKJD120	11kV FDR O/G S/STN. NO.-10,1904 MEGHA HOUSING V. KUNJ	TI-VKJ357A-2	630	COMMERCIAL	AMR	Functional	100%	24	0.05			
66 kV VASANT KUNJ D - BLK GRID	SVKJD120	11kV FDR O/G S/STN. NO.-10,1904 MEGHA HOUSING V. KUNJ	TI-VKJ678A-1	630	COMMERCIAL		Functional	100%	58	0.05			
66 kV VASANT KUNJ D - BLK GRID	SVKJD121	11kV FDR O/G S/STN. NO.-7 1904 MEGHA HOUSING V. KUNJ	TI-VKJ252A-2	630	COMMERCIAL		Functional	100%	119	0.05			
66 kV VASANT KUNJ D - BLK GRID	SVKJD102	11kV FDR O/G S/STN. NO.-3,1904-MEGHA HOUSING V. KUNJ	TI-VKJ170A-2	630	MIXED	AMR	Functional	100%	54	0.04			
66 kV VASANT KUNJ D - BLK GRID	SVKJD120	11kV FDR O/G S/STN. NO.-10,1904 MEGHA HOUSING V. KUNJ	TI-VKJ678A-2	630	COMMERCIAL	AMR	Functional	100%	29	0.04			
66 kV VASANT KUNJ D - BLK GRID	SVKJD121	11kV FDR O/G S/STN. NO.-7 1904 MEGHA HOUSING V. KUNJ	TI-VKJ252A-1	630	COMMERCIAL	AMR	Functional	100%	7	0.04			
66 kV VASANT KUNJ D - BLK GRID	SVKJD102	11kV FDR O/G S/STN. NO.-3,1904-MEGHA HOUSING V. KUNJ	TI-VKJ170A-1	630	MIXED	AMR	Functional	100%	21	0.04			
66 kV VASANT KUNJ D - BLK GRID	SVKJD122	11kV FDR O/G S/STN. NO.-4,1904 MEGHA HOUSING V. KUNJ	TI-VKJ172A-1	400	MIXED	AMR	Functional	100%	84	0.02			
66 kV VASANT KUNJ D - BLK GRID	SVKJD119	11kV FDR 11kV O/G S/STN. NO.-1,1904 MEGHA HOUSING V. KUNJ	TI-VKJ650A-2	990	MIXED	AMR	Functional	100%	17	0.02			
66 kV VASANT KUNJ D - BLK GRID	SVKJD104	11kV FDR V. KUNJ S/STN. NO.-1, D-7 & 8	TG-VKJ106A-2	630	COMMERCIAL	AMR	Functional	100%	134	0.20	1.11	0.03	2.39%
66 kV VASANT KUNJ D - BLK GRID	SVKJD114	11kV FDR S/STN. NO.-3, D-7 & 8 V.KUNJ	TG-VKJ109A-1	630	COMMERCIAL	AMR	Functional	100%	167	0.19			
66 kV VASANT KUNJ D - BLK GRID	SVKJD104	11kV FDR V. KUNJ S/STN. NO.-1, D-7 & 8	TG-VKJ106A-1	630	COMMERCIAL	AMR	Functional	100%	82	0.17			
66 kV VASANT KUNJ D - BLK GRID	SVKJD104	11kV FDR V. KUNJ S/STN. NO.-1, D-7 & 8	TP-VKJ105A-1	400	COMMERCIAL	AMR	Functional	100%	91	0.17			
66 kV VASANT KUNJ D - BLK GRID	SVKJD114	11kV FDR S/STN. NO.-3, D-7 & 8 V.KUNJ	TG-VKJ107A-2	630	COMMERCIAL	AMR	Functional	100%	156	0.16			
66 kV VASANT KUNJ D - BLK GRID	SVKJD114	11kV FDR S/STN. NO.-3, D-7 & 8 V.KUNJ	TG-VKJ107A-1	630	COMMERCIAL	AMR	Functional	100%	76	0.16			
66 kV VASANT KUNJ D - BLK GRID	SVKJD114	11kV FDR S/STN. NO.-3, D-7 & 8 V.KUNJ	TP-VKJ108A-1	400	COMMERCIAL	AMR	Functional	100%	132	0.07			
66 kV VASANT KUNJ D - BLK GRID	SVKJD108	11kV STR 400KVA STATION TRANS.	VK-STC105A-1	400	MIXED	AMR	Functional	100%	1	0.01			

66 kV VASANT KUNJ D - BLK GRID	SVKJD111	11kV FDR O/G NANGAL DAIRY NO.-II	TP-VKJ241A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01	0.52	0.05	8.10%
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	TP-VKJ213A-1	400	MIXED		Functional	100%	230	0.21			
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	TG-VKJ207A-1	400	MIXED		Functional	100%	14	0.10			
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	TP-VKJ208A-1	400	MIXED		Functional	100%	81	0.10			
66 kV I.O.C.BIJWASAN GRID	SBWSN107	11kV FDR BIJWASAN	TP-VKJ211A-1	400	INDUSTRIAL	AMR	Functional	100%	40	0.06			
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	TP-VKJ205A-1	400	MIXED		Functional	100%	36	0.04			
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	TP-VKJ716A-1	100	COMMERCIAL		Functional	100%	5	0.02			
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	TP-VKJ439A-1	100	COMMERCIAL		Functional	100%	2	0.02			
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	TP-VKJ510A-1	100	RESIDENTIAL		Functional	100%	2	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ217A-1	400	MIXED	AMR	Functional	100%	43	0.19	0.71	0.02	2.83%
66 kV I.O.C.BIJWASAN GRID	SBWSN120	11kV FDR O/G HOLY CHOWK BIJWASAN	2521BIJ-VKJ894A-1	630	MIXED		Functional	100%	0	0.16			
66 kV I.O.C.BIJWASAN GRID	SBWSN116	11kV FDR KAPASHERA O/H	TP-VKJ287A-1	400	MIXED	AMR	Functional	100%	63	0.15			
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	TP-VKJ166A-1	400	COMMERCIAL	AMR	Functional	100%	20	0.06			
66 kV I.O.C.BIJWASAN GRID	SBWSN107	11kV FDR BIJWASAN	2521BIJ-VKJ862A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.06			
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	TG-VKJ147A-1	990	INDUSTRIAL	AMR	Functional	100%	70	0.05			
66 kV I.O.C.BIJWASAN GRID	SBWSN116	11kV FDR KAPASHERA O/H	TP-VKJ450A-1	100	MIXED		Functional	100%	1	0.03			
66 kV I.O.C.BIJWASAN GRID	SBWSN116	11kV FDR KAPASHERA O/H	TP-VKJ673A-1	100	COMMERCIAL		Functional	100%	3	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN107	11kV FDR BIJWASAN	TP-VKJ052A-1	100	RESIDENTIAL		Functional	100%	3	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN116	11kV FDR KAPASHERA O/H	TG-VKJ674A-1	100	MIXED		Functional	100%	3	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN120	11kV FDR O/G HOLY CHOWK BIJWASAN	TG-VKJ123A-1	990	MIXED	AMR	Functional	100%	923	0.88			
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	TG-VKJ151A-1	990	RESIDENTIAL	AMR	Functional	100%	683	0.73			
66 kV I.O.C.BIJWASAN GRID	SBWSN125	11kV FDR O/G JAI SINGH	TG-VKJ146A-1	990	INDUSTRIAL	AMR	Functional	100%	585	0.72			
66 kV I.O.C.BIJWASAN GRID	SBWSN120	11kV FDR O/G HOLY CHOWK BIJWASAN	2521BIJ-VKJ187A-2	990	COMMERCIAL	AMR	Functional	100%	436	0.56			
66 kV I.O.C.BIJWASAN GRID	SBWSN125	11kV FDR O/G JAI SINGH	TG-VKJ279A-1	630	INDUSTRIAL		Functional	100%	492	0.51			
66 kV I.O.C.BIJWASAN GRID	SBWSN120	11kV FDR O/G HOLY CHOWK BIJWASAN	TG-VKJ122A-1	630	INDUSTRIAL	AMR	Functional	100%	662	0.50			
66 kV I.O.C.BIJWASAN GRID	SBWSN120	11kV FDR O/G HOLY CHOWK BIJWASAN	TP-VKJ469A-1	630	INDUSTRIAL	AMR	Functional	100%	523	0.45			
66 kV I.O.C.BIJWASAN GRID	SBWSN125	11kV FDR O/G JAI SINGH	TG-VKJ419A-2	630	INDUSTRIAL		Functional	100%	481	0.42			
66 kV I.O.C.BIJWASAN GRID	SBWSN107	11kV FDR BIJWASAN	TP-VKJ440A-1	400	INDUSTRIAL	AMR	Functional	100%	174	0.40			
66 kV I.O.C.BIJWASAN GRID	SBWSN125	11kV FDR O/G JAI SINGH	TG-VKJ145A-1	630	INDUSTRIAL	AMR	Functional	100%	895	0.39			
66 kV I.O.C.BIJWASAN GRID	SBWSN120	11kV FDR O/G HOLY CHOWK BIJWASAN	TG-VKJ123A-2	630	RESIDENTIAL	AMR	Functional	100%	3	0.38			
66 kV I.O.C.BIJWASAN GRID	SBWSN125	11kV FDR O/G JAI SINGH	TP-VKJ770A-1	990	RESIDENTIAL		Functional	100%	144	0.34			
66 kV I.O.C.BIJWASAN GRID	SBWSN120	11kV FDR O/G HOLY CHOWK BIJWASAN	TI-VKJ504A-1	630	INDUSTRIAL	AMR	Functional	100%	228	0.33			
66 kV I.O.C.BIJWASAN GRID	SBWSN120	11kV FDR O/G HOLY CHOWK BIJWASAN	TG-VKJ150A-1	630	INDUSTRIAL	AMR	Functional	100%	281	0.33			
66 kV I.O.C.BIJWASAN GRID	SBWSN120	11kV FDR O/G HOLY CHOWK BIJWASAN	TG-VKJ150A-1	630	INDUSTRIAL	AMR	Functional	100%	281	0.33	7.84	0.12	1.53%

66 kV I.O.C.BIJWASAN GRID	SBWSN125	11kV FDR O/G JAI SINGH	TG-VKJ419A-1	400	INDUSTRIAL	AMR	Functional	100%	835	0.32			
66 kV I.O.C.BIJWASAN GRID	SBWSN120	11kV FDR O/G HOLY CHOWK BIJWASAN	TG-VKJ723A-1	400	RESIDENTIAL		Functional	100%	438	0.29			
66 kV I.O.C.BIJWASAN GRID	SBWSN116	11kV FDR KAPASHERA O/H	2521BIJ-VKJ892A-1	400	MIXED		Functional	100%	0	0.18			
66 kV I.O.C.BIJWASAN GRID	SBWSN125	11kV FDR O/G JAI SINGH	2521BIJ-VKJ187A-1	630	RESIDENTIAL	AMR	Functional	100%	302	0.11			
66 kV I.O.C.BIJWASAN GRID	SBWSN625	11kV STR 100kVA STATION TRF. NO.-2	2521BIJ-STC070A-2	100	MIXED		Functional	100%	0	0.06			
66 kV I.O.C.BIJWASAN GRID	SBWSN107	11kV FDR BIJWASAN	2521BIJ-VKJ842A-1	100	RESIDENTIAL		Functional	100%	1	0.03			
66 kV I.O.C.BIJWASAN GRID	SBWSN113	11kV STR 100kVA STATION TRANS.	VK-STC070A-1	100	MIXED	AMR	Functional	100%	1	0.03			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ216A-1	400	RESIDENTIAL		Functional	100%	45	0.27	1.93	0.16	7.86%
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ290A-1	400	RESIDENTIAL	AMR	Functional	100%	18	0.26			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.-2(KAPASHERA)	TP-VKJ271A-1	630	COMMERCIAL	AMR	Functional	100%	10	0.19			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ219A-1	400	RESIDENTIAL	AMR	Functional	100%	17	0.18			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ222A-1	400	RESIDENTIAL	AMR	Functional	100%	12	0.13			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.-2(KAPASHERA)	TP-VKJ220A-1	400	RESIDENTIAL		Functional	100%	15	0.11			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ223A-1	400	RESIDENTIAL	AMR	Functional	100%	9	0.10			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ639A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.09			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ224A-1	400	RESIDENTIAL	AMR	Functional	100%	19	0.08			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	2521BIJ-VKJ880A-1	400	COMMERCIAL		Functional	100%	9	0.08			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ509A-1	400	RESIDENTIAL		Functional	100%	1	0.06			
66 kV I.O.C.BIJWASAN GRID	SBWSN116	11kV FDR KAPASHERA O/H	TP-VKJ675A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.06			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ259A-1	100	RESIDENTIAL		Functional	100%	5	0.05			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ221A-1	400	RESIDENTIAL	AMR	Functional	100%	10	0.05			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TG-VKJ278A-1	630	RESIDENTIAL		Functional	100%	15	0.04			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TG-VKJ278B-1	630	RESIDENTIAL		Functional	100%	0	0.04			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ289A-1	400	RESIDENTIAL	AMR	Functional	100%	10	0.04			
66 kV I.O.C.BIJWASAN GRID	SBWSN107	11kV FDR BIJWASAN	2521BIJ-VKJ879A-1	250	MIXED		Functional	100%	0	0.04			
66 kV I.O.C.BIJWASAN GRID	SBWSN107	11kV FDR BIJWASAN	TP-VKJ218A-1	400	COMMERCIAL	AMR	Functional	100%	18	0.03			
66 kV PALAM GRID	SPLAP118	11kV FDR O/G RAJOKARI	2521BIJ-VKJ869A-1	400	MIXED		Functional	100%	0	0.03			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ215A-1	100	COMMERCIAL		Functional	100%	8	0.03			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ679A-1	100	MIXED	AMR	Functional	100%	1	0.03			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	2521BIJ-VKJ827A-1	250	RESIDENTIAL		Functional	100%	1	0.02			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ249A-1	100	COMMERCIAL		Functional	100%	1	0.02			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.-1(KAPASHERA)	TP-VKJ242A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.02			
66 kV I.O.C.BIJWASAN GRID	SBWSN103	11kV FDR VILLAGE SAHIBABAD MOHD. PUR	2521BIJ-VKJ870A-1	400	MIXED		Functional	100%	0	0.01			

66 kV I.O.C.BIJWASAN GRID	SBWSN116	11kV FDR KAPASHERA O/H	TP-VKJ676A-1	100	RESIDENTIAL		Functional	100%	5	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN105	11kV FDR INTERCONNECTOTR NO.- 1(KAPASHERA)	2521BIJ-VKJ873A-1	100	MIXED		Functional	100%	1	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN127	11kV FDR SAMALKHA VILLAGE VIA G8 B	TP-VKJ220A-2	100	RESIDENTIAL	AMR	Functional	100%	0	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN107	11kV FDR BIJWASAN	TP-VKJ719A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.00			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.- 2(KAPASHERA)	TP-VKJ371A-1	100	COMMERCIAL		Functional	100%	1	0.00			
66 kV I.O.C.BIJWASAN GRID	SBWSN107	11kV FDR BIJWASAN	TP-VKJ210A-1	400	INDUSTRIAL		Functional	100%	119	0.27	0.44	0.01	1.18%
66 kV I.O.C.BIJWASAN GRID	SBWSN107	11kV FDR BIJWASAN	TG-VKJ212A-1	400	INDUSTRIAL	AMR	Functional	100%	37	0.08			
66 kV I.O.C.BIJWASAN GRID	SBWSN107	11kV FDR BIJWASAN	TP-VKJ340A-1	100	COMMERCIAL		Functional	100%	15	0.04			
66 kV I.O.C.BIJWASAN GRID	SBWSN107	11kV FDR BIJWASAN	TP-VKJ636A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.04			
66 kV I.O.C.BIJWASAN GRID	SBWSN107	11kV FDR BIJWASAN	TP-VKJ651A-1	100	RESIDENTIAL		Functional	100%	5	0.03			
66 kV I.O.C.BIJWASAN GRID	SBWSN127	11kV FDR SAMALKHA VILLAGE VIA G8 B	TP-VKJ277A-1	990	RESIDENTIAL		Functional	100%	1013	1.25	6.13	0.25	3.86%
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.- 2(KAPASHERA)	TG-VKJ129A-1	990	RESIDENTIAL		Functional	100%	619	0.89			
66 kV I.O.C.BIJWASAN GRID	SBWSN102	11kV FDR KAPASHERA U/G	TG-VKJ501A-1	630	RESIDENTIAL		Functional	100%	1158	0.67			
66 kV I.O.C.BIJWASAN GRID	SBWSN102	11kV FDR KAPASHERA U/G	TG-VKJ163A-1	630	RESIDENTIAL		Functional	100%	541	0.59			
66 kV I.O.C.BIJWASAN GRID	SBWSN116	11kV FDR KAPASHERA O/H	TP-VKJ451A-1	630	RESIDENTIAL		Functional	100%	304	0.44			
66 kV I.O.C.BIJWASAN GRID	SBWSN127	11kV FDR SAMALKHA VILLAGE VIA G8 B	TG-VKJ130A-1	630	RESIDENTIAL		Functional	100%	197	0.39			
66 kV I.O.C.BIJWASAN GRID	SBWSN127	11kV FDR SAMALKHA VILLAGE VIA G8 B	TP-VKJ690A-1	990	RESIDENTIAL		Functional	100%	96	0.38			
66 kV I.O.C.BIJWASAN GRID	SBWSN127	11kV FDR SAMALKHA VILLAGE VIA G8 B	TP-VKJ627A-1	400	RESIDENTIAL	AMR	Functional	100%	285	0.37			
66 kV PALAM GRID	SPLAP118	11kV FDR O/G RAJOKARI	TI-VKJ201A-1	630	RESIDENTIAL	AMR	Functional	100%	381	0.36			
66 kV I.O.C.BIJWASAN GRID	SBWSN127	11kV FDR SAMALKHA VILLAGE VIA G8 B	2521KPS-VKJ865A-1	630	RESIDENTIAL	AMR	Functional	100%	121	0.36			
66 kV I.O.C.BIJWASAN GRID	SBWSN116	11kV FDR KAPASHERA O/H	2521KPS-VKJ520A-1	400	RESIDENTIAL	AMR	Functional	100%	335	0.24			
66 kV PALAM GRID	SPLAP118	11kV FDR O/G RAJOKARI	TG-VKJ203A-1	400	RESIDENTIAL	AMR	Functional	100%	5	0.24			
66 kV I.O.C.BIJWASAN GRID	SBWSN127	11kV FDR SAMALKHA VILLAGE VIA G8 B	TP-VKJ257A-1	400	RESIDENTIAL	AMR	Functional	100%	15	0.12			
66 kV PALAM GRID	SPLAP118	11kV FDR O/G RAJOKARI	TP-VKJ038A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.05			
66 kV I.O.C.BIJWASAN GRID	SBWSN127	11kV FDR SAMALKHA VILLAGE VIA G8 B	TP-VKJ277A-2	100	RESIDENTIAL	AMR	Functional	100%	20	0.02			
66 kV PALAM GRID	SPLAP118	11kV FDR O/G RAJOKARI	TP-VKJ261A-1	100	COMMERCIAL		Functional	100%	4	0.01			
66 kV PALAM GRID	SPLAP118	11kV FDR O/G RAJOKARI	TP-VKJ202A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.00			
66 kV PALAM GRID	SPLAP118	11kV FDR O/G RAJOKARI	TP-VKJ262A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	TG-VKJ360A-1	990	MIXED	AMR	Functional	100%	1040	0.87	2.07	0.13	6.02%
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	TG-VKJ360A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.63			
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	2521BIJ-VKJ792A-1	630	MIXED		Functional	100%	0	0.39			
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	TP-VKJ236A-1	400	RESIDENTIAL		Functional	100%	615	0.26			
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	2521BIJ-VKJ234A-1	400	RESIDENTIAL		Functional	100%	23	0.05			
66 kV I.O.C.BIJWASAN GRID	SBWSN129	11KV FRD SHALAHPUR VILLAGE VIA RANG BIHARI BIJWASAN	TP-VKJ206A-1	100	RESIDENTIAL		Functional	100%	1	0.00			
66 kV I.O.C.BIJWASAN GRID	SBWSN103	11kV FDR VILLAGE SAHIBABAD MOHD. PUR	TG-VKJ142A-1	990	RESIDENTIAL	AMR	Functional	100%	1116	0.95	3.59	0.24	6.33%

66 kV I.O.C.BIJWASAN GRID	SBWSN103	11kV FDR VILLAGE SAHIBABAD MOHD. PUR	TG-VKJ175A-1	990	RESIDENTIAL		Functional	100%	490	0.79			
66 kV I.O.C.BIJWASAN GRID	SBWSN103	11kV FDR VILLAGE SAHIBABAD MOHD. PUR	TG-VKJ141A-1	990	RESIDENTIAL	AMR	Functional	100%	964	0.66			
66 kV I.O.C.BIJWASAN GRID	SBWSN108	11kV FDR S.P.G	2521BIJ-VKJ826A-1	630	RESIDENTIAL		Functional	100%	20	0.48			
66 kV I.O.C.BIJWASAN GRID	SBWSN108	11kV FDR S.P.G	TG-VKJ748A-1	630	RESIDENTIAL	AMR	Functional	100%	1134	0.43			
66 kV I.O.C.BIJWASAN GRID	SBWSN103	11kV FDR VILLAGE SAHIBABAD MOHD. PUR	TG-VKJ782A-1	630	RESIDENTIAL	AMR	Functional	100%	55	0.35			
66 kV I.O.C.BIJWASAN GRID	SBWSN103	11kV FDR VILLAGE SAHIBABAD MOHD. PUR	2521BIJ-VKJ849A-1	630	RESIDENTIAL	AMR	Functional	100%	26	0.18			
66 kV I.O.C.BIJWASAN GRID	SBWSN102	11kV FDR KAPASHERA U/G	TP-VKJ286A-1	990	COMMERCIAL	AMR	Functional	100%	237	1.00	3.48	0.40	10.27%
66 kV I.O.C.BIJWASAN GRID	SBWSN119	11kV FDR O/G NAVAL KAPASHERA	TG-VKJ153A-1	990	RESIDENTIAL	AMR	Functional	100%	227	0.63			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.- 2(KAPASHERA)	TG-VKJ126A-1	630	RESIDENTIAL	AMR	Functional	100%	260	0.57			
66 kV I.O.C.BIJWASAN GRID	SBWSN119	11kV FDR O/G NAVAL KAPASHERA	TP-VKJ152A-1	400	COMMERCIAL	AMR	Functional	100%	31	0.38			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.- 2(KAPASHERA)	TP-VKJ154A-1	400	COMMERCIAL	AMR	Functional	100%	20	0.25			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TG-VKJ155A-1	400	COMMERCIAL	AMR	Functional	100%	22	0.21			
66 kV PALAM GRID	SPLAP118	11kV FDR O/G RAJOKARI	TP-VKJ198A-1	400	COMMERCIAL	AMR	Functional	100%	52	0.16			
66 kV I.O.C.BIJWASAN GRID	SBWSN119	11kV FDR O/G NAVAL KAPASHERA	TP-VKJ468A-1	400	MIXED		Functional	100%	1	0.10			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TG-VKJ177A-1	250	RESIDENTIAL		Functional	100%	4	0.09			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.- 2(KAPASHERA)	TP-VKJ506A-1	400	COMMERCIAL	AMR	Functional	100%	40	0.08			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TP-VKJ204A-1	400	COMMERCIAL	AMR	Functional	100%	17	0.08			
66 kV PALAM GRID	SPLAP118	11kV FDR O/G RAJOKARI	TP-VKJ254A-1	400	COMMERCIAL	AMR	Functional	100%	11	0.07			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.- 2(KAPASHERA)	TP-VKJ382A-1	400	COMMERCIAL	AMR	Functional	100%	9	0.07			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.- 2(KAPASHERA)	TP-VKJ507A-1	250	COMMERCIAL	AMR	Functional	100%	1	0.06			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.- 2(KAPASHERA)	TP-VKJ672A-1	100	MIXED	AMR	Functional	100%	1	0.05			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.- 2(KAPASHERA)	TP-VKJ671A-1	100	MIXED	AMR	Functional	100%	2	0.03			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TP-VKJ323A-1	100	COMMERCIAL	AMR	Functional	100%	8	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.- 2(KAPASHERA)	TP-VKJ710A-1	100	MIXED	AMR	Functional	100%	2	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.- 2(KAPASHERA)	TP-VKJ726A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN110	11kV FDR HINDUSTAN PETROLIUM	TG-VKJ149A-1	990	RESIDENTIAL	AMR	Functional	100%	1074	1.19	13.10	1.26	8.77%
66 kV I.O.C.BIJWASAN GRID	SBWSN110	11kV FDR HINDUSTAN PETROLIUM	TG-VKJ186A-1	990	RESIDENTIAL	AMR	Functional	100%	1020	0.95			
66 kV I.O.C.BIJWASAN GRID	SBWSN119	11kV FDR O/G NAVAL KAPASHERA	TG-VKJ128A-1	990	RESIDENTIAL		Functional	100%	851	0.89			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.- 2(KAPASHERA)	TG-VKJ456A-1	990	RESIDENTIAL		Functional	100%	712	0.88			
66 kV I.O.C.BIJWASAN GRID	SBWSN110	11kV FDR HINDUSTAN PETROLIUM	TP-VKJ379A-1	630	RESIDENTIAL		Functional	100%	454	0.87			
66 kV I.O.C.BIJWASAN GRID	SBWSN128	11kV FDR O/G BLUE DARK KAPASHERA	TP-VKJ376A-1	630	COMMERCIAL	AMR	Functional	100%	931	0.86			
66 kV I.O.C.BIJWASAN GRID	SBWSN116	11kV FDR KAPASHERA O/H	TG-VKJ125A-1	990	RESIDENTIAL	AMR	Functional	100%	543	0.82			
66 kV I.O.C.BIJWASAN GRID	SBWSN110	11kV FDR HINDUSTAN PETROLIUM	TG-VKJ148A-1	990	RESIDENTIAL	AMR	Functional	100%	875	0.78			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.- 2(KAPASHERA)	TG-VKJ156A-1	990	COMMERCIAL	AMR	Functional	100%	722	0.76			

66 kV I.O.C.BIJWASAN GRID	SBWSN116	11kV FDR KAPASHERA O/H	TP-VKJ270A-1	990	RESIDENTIAL		Functional	100%	336	0.70			
66 kV I.O.C.BIJWASAN GRID	SBWSN128	11KV FDR O/G BLUE DARK KAPASHERA	TP-VKJ747A-1	990	RESIDENTIAL		Functional	100%	40	0.64			
66 kV I.O.C.BIJWASAN GRID	SBWSN119	11kV FDR O/G NAVAL KAPASHERA	TP-VKJ209A-1	630	RESIDENTIAL	AMR	Functional	100%	472	0.58			
66 kV I.O.C.BIJWASAN GRID	SBWSN128	11kV FDR O/G BLUE DARK KAPASHERA	TP-VKJ374A-1	630	RESIDENTIAL	AMR	Functional	100%	234	0.58			
66 kV I.O.C.BIJWASAN GRID	SBWSN119	11kV FDR O/G NAVAL KAPASHERA	TP-VKJ377A-1	630	RESIDENTIAL		Functional	100%	490	0.51			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11KV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	TP-VKJ179A-1	630	RESIDENTIAL	AMR	Functional	100%	118	0.50			
66 kV I.O.C.BIJWASAN GRID	SBWSN119	11kV FDR O/G NAVAL KAPASHERA	2521KPS-VKJ833A-	400	RESIDENTIAL	AMR	Functional	100%	173	0.44			
66 kV I.O.C.BIJWASAN GRID	SBWSN116	11kV FDR KAPASHERA O/H	TP-VKJ502A-1	630	RESIDENTIAL	AMR	Functional	100%	230	0.43			
66 kV I.O.C.BIJWASAN GRID	SBWSN119	11kV FDR O/G NAVAL KAPASHERA	TP-VKJ128A-2	990	RESIDENTIAL		Functional	100%	0	0.42			
66 kV I.O.C.BIJWASAN GRID	SBWSN119	11kV FDR O/G NAVAL KAPASHERA	TP-VKJ284A-1	990	COMMERCIAL	AMR	Functional	100%	341	0.37			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.-2(KAPASHERA)	TP-VKJ505A-1	400	RESIDENTIAL	AMR	Functional	100%	256	0.33			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11KV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	2521KPS-VKJ160A-	400	MIXED		Functional	100%	0	0.32			
66 kV I.O.C.BIJWASAN GRID	SBWSN115	11kV FDR INTERCONNECTOTR NO.-2(KAPASHERA)	TG-VKJ127A-1	990	RESIDENTIAL	AMR	Functional	100%	600	0.31			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11KV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	2521C9V-VKJ847A-	100	RESIDENTIAL	AMR	Functional	100%	2	0.12			
66 kV I.O.C.BIJWASAN GRID	SBWSN119	11kV FDR O/G NAVAL KAPASHERA	2521KPS-VKJ128A-	250	RESIDENTIAL	AMR	Functional	100%	0	0.04			
66 kV I.O.C.BIJWASAN GRID	SBWSN116	11kV FDR KAPASHERA O/H	TP-VKJ712A-1	100	MIXED		Functional	100%	1	0.03			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	2521KPS-VKJ853A-	250	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TP-VKJ197A-1	400	COMMERCIAL	AMR	Functional	100%	242	0.27	1.10	0.12	9.74%
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TP-VKJ251A-1	400	RESIDENTIAL	AMR	Functional	100%	2	0.21			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11KV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	TG-VKJ159A-1	630	COMMERCIAL	AMR	Functional	100%	15	0.19			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TP-VKJ199A-1	400	COMMERCIAL	AMR	Functional	100%	11	0.13			
66 kV PALAM GRID	SPLAP118	11kV FDR O/G RAJOKARI	TG-VKJ196A-1	630	COMMERCIAL	AMR	Functional	100%	103	0.12			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	2521KPS-VKJ861A-	400	RESIDENTIAL		Functional	100%	5	0.08			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11KV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	TP-VKJ685A-1	100	COMMERCIAL	AMR	Functional	100%	11	0.08			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11KV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	TP-VKJ420A-1	100	COMMERCIAL	AMR	Functional	100%	17	0.06			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11KV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	TP-VKJ742A-1	100	COMMERCIAL		Functional	100%	1	0.04			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TP-VKJ449A-1	100	MIXED		Functional	100%	13	0.03			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11KV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	TP-VKJ704A-1	100	MIXED		Functional	100%	1	0.02			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11KV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	2521KPS-VKJ802A-	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11KV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	2521KPS-VKJ803A-	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	TP-VKJ200A-1	100	COMMERCIAL		Functional	100%	1	0.00			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ320A-1	400	RESIDENTIAL	AMR	Functional	100%	9	0.23	2.51	0.38	13.13%
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ322A-1	400	RESIDENTIAL	AMR	Functional	100%	27	0.17			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ352A-1	400	RESIDENTIAL	AMR	Functional	100%	17	0.16			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ192A-1	400	COMMERCIAL	AMR	Functional	100%	14	0.15			

66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ353A-1	400	RESIDENTIAL	AMR	Functional	100%	12	0.11			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ266A-1	400	COMMERCIAL	AMR	Functional	100%	6	0.11			
66 kV PALAM GRID	SPLAP122	11kV FDR AVIJIT MAHIPALPUR	2521KPS-VKJ760A-1	400	COMMERCIAL	AMR	Functional	100%	1	0.10			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ265A-1	400	COMMERCIAL	AMR	Functional	100%	12	0.08			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ350A-1	400	RESIDENTIAL		Functional	100%	9	0.08			
66 kV PALAM GRID	SPLAP121	11kV FDR GOLDEN GATE WESTERN GREEN	TP-VKJ319A-1	400	RESIDENTIAL	AMR	Functional	100%	11	0.08			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ190A-1	400	COMMERCIAL	AMR	Functional	100%	6	0.07			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ347A-1	400	RESIDENTIAL	AMR	Functional	100%	11	0.06			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ354A-1	400	RESIDENTIAL	AMR	Functional	100%	6	0.06			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	2521KPS-VKJ850A-1	250	RESIDENTIAL	AMR	Functional	100%	1	0.06			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11KV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	TP-VKJ737A-1	400	COMMERCIAL	AMR	Functional	100%	5	0.06			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11KV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	TP-VKJ189A-1	400	COMMERCIAL	AMR	Functional	100%	10	0.04			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TG-VKJ264A-1	100	COMMERCIAL	AMR	Functional	100%	16	0.04			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ666A-1	100	MIXED	AMR	Functional	100%	1	0.04			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ667A-1	100	RESIDENTIAL	AMR	Functional	100%	6	0.03			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ191A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.03			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ467A-1	100	COMMERCIAL		Functional	100%	2	0.02			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ508A-1	100	COMMERCIAL	AMR	Functional	100%	4	0.02			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ778A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.02			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ466A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN130	11KV FRD THE GREEN RAJOKARI VIA TANEJA KAPASHERA	TP-VKJ465A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.01			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ188A-1	400	COMMERCIAL	AMR	Functional	100%	1	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN123	11kV FDR O/G AIRFORCE RAJOKARI	2521KPS-VKJ807A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ111A-1	100	MIXED		Functional	100%	0	0.01			
66 kV PALAM GRID	SPLAP119	11kV FDR O/G NSG WESTERN GREEN	TP-VKJ258A-1	100	COMMERCIAL		Functional	100%	3	0.00			
66 kV VASANT KUNJ D - BLK GRID	SVKJD111	11kV FDR O/G NANGAL DAIRY NO.-II	521BJ-MOB0003A	630	RESIDENTIAL		Functional	100%	0	0.58			
33 kV ANDHERIA BAGH GRID	SABAG119	11kV FDR O/G SALOON APPARTMENT	2521B1V-VKJ841A-1	630	RESIDENTIAL	AMR	Functional	100%	3	0.43			
33 kV H.U.D.C.O GRID	SHUDC102	11kV FDR O/G OLD HUDCO KIOSK	TG-GK1034A-1	990	RESIDENTIAL		Functional	100%	142	0.57	2.86	0.14	4.55%
33 kV MASJID MOTH GRID	SMMOT112	11kV FDR DDA FLATS MASJID MOTH PHASE-1 G.K-1 NHP	TG-GK1051A-2	990	RESIDENTIAL		Functional	100%	35	0.51			
33 kV MASJID MOTH GRID	SMMOT102	11kV FDR O/G W-BLOCK G.K-1 (VIA A-BLK. NAL G.K.-1)	TG-GK1070A-1	990	MIXED		Functional	100%	153	0.50			
33 kV MASJID MOTH GRID	SMMOT112	11kV FDR DDA FLATS MASJID MOTH PHASE-1 G.K-1 NHP	TG-GK1051A-1	630	RESIDENTIAL		Functional	100%	200	0.36			
33 kV MASJID MOTH GRID	SMMOT112	11kV FDR DDA FLATS MASJID MOTH PHASE-1 G.K-1 NHP	TI-GK1083A-1	630	RESIDENTIAL		Functional	100%	192	0.31			
33 kV H.U.D.C.O GRID	SHUDC102	11kV FDR O/G OLD HUDCO KIOSK	TG-GK1076A-1	630	MIXED		Functional	100%	48	0.13			
33 kV V.S.N.L. GRID	SVSNL102	11kV STR 400KVA SATTION TRANSFORMER	TI-STC102A-1	400	COMMERCIAL		Functional	100%	1	0.06			
33 kV H.U.D.C.O GRID	SHUDC102	11kV FDR O/G OLD HUDCO KIOSK	TI-GK1056A-1	630	RESIDENTIAL		Functional	100%	18	0.04			
33 kV H.U.D.C.O GRID	SHUDC120	11kV FDR O/G NATIONAL PARK	530LN4-GAR074A-1	250	RESIDENTIAL		Functional	100%	4	0.06			
33 kV EAST OF KAILASH GRID	SKLSH105	11kV FDR B-BLOCK EAST OF KAILASH (VIA C-BLOCK)	530O23-MOB002A	990	RESIDENTIAL		Functional	100%	0	0.37			
33 kV NEHRU PLACE GRID	SNPHG105	11kV O/G BULDING NO-37 NHP NO.2	530O23-MOB002A	990	MIXED		Functional	100%	0	0.08			
33 kV DEFENCE COLONY GRID	SDCOL111	11kV FDR O/G VIKRAM HOTEL	530O23-MOB002A	630	MIXED		Functional	100%	0	0.02			
33 kV OKHLA PHASE-2 GRID	SOKH2108	11kV FDR S/S NO.-4, OKHLA PHASE-2	TG-OIS137A-1	630	RESIDENTIAL		Functional	100%	15	0.50	2.36	0.18	7.06%
33 kV OKHLA PHASE-2 GRID	SOKH2119	11kV FDR O/H S/S NO.-2 PHASE-2	TG-OIS044A-2	1000	INDUSTRIAL		Functional	100%	193	0.40			
33 kV OKHLA PHASE-2 GRID	SOKH2120	11kV FDR S/S NO.-4, FEEDER-2 PHASE-2	TX-OIS095A-1	990	INDUSTRIAL		Functional	100%	196	0.28			
33 kV OKHLA PHASE-2 GRID	SOKH2119	11kV FDR O/H S/S NO.-2 PHASE-2	TX-OIS093A-1	990	INDUSTRIAL		Functional	100%	115	0.27			
33 kV OKHLA PHASE-2 GRID	SOKH2119	11kV FDR O/H S/S NO.-2 PHASE-2	TI-OIS002A-3	990	RESIDENTIAL		Functional	100%	0	0.26			
33 kV OKHLA PHASE-2 GRID	SOKH2119	11kV FDR O/H S/S NO.-2 PHASE-2	TI-OIS002A-1	1000	INDUSTRIAL		Functional	100%	1026	0.23			
33 kV OKHLA PHASE-2 GRID	SOKH2119	11kV FDR O/H S/S NO.-2 PHASE-2	TG-OIS042A-2	990	INDUSTRIAL		Functional	100%	75	0.20			
33 kV OKHLA PHASE-2 GRID	SOKH2119	11kV FDR O/H S/S NO.-2 PHASE-2	TI-OIS002A-2	990	INDUSTRIAL		Functional	100%	72	0.18			

33 kv OKHLA PHASE-2 GRID	SOKH2119	11kv FDR O/H S/S NO.-2 PHASE-2	TG-OIS042A-1	400	INDUSTRIAL		Functional	100%	23	0.11			
33 kv OKHLA PHASE-2 GRID	SOKH2119	11kv FDR O/H S/S NO.-2 PHASE-2	TG-OIS044A-1	630	INDUSTRIAL		Functional	100%	195	0.10			
33 kv BALAJI STATE GRID	SBALA113	11KV FDR OKHLA SSTN NO-80 PH-3	TG-OIS097A-2	990	MIXED		Functional	100%	28	0.46	3.47	0.07	2.05%
33 kv NEHRU PLACE GRID	SNPHG137	11kv FDR O/G BAHAI MANDIR	TG-OIS035A-1	990	MIXED		Functional	100%	98	0.46			
33 kv EAST OF KAILASH GRID	SKLSH107	11kv FDR SSTN SABJI MANDI OKHLA PHASE-3	TI-OIS024A-1	990	MIXED		Functional	100%	44	0.43			
33 kv BALAJI STATE GRID	SBALA113	11KV FDR OKHLA SSTN NO-80 PH-3	TI-OIS025A-2	990	MIXED		Functional	100%	9	0.33			
33 kv EAST OF KAILASH GRID	SKLSH117	11kv FDR S.B.I NO.-2	TG-OIS037A-2	990	MIXED		Functional	100%	12	0.29			
33 kv BALAJI STATE GRID	SBALA113	11KV FDR OKHLA SSTN NO-80 PH-3	TI-OIS047A-2	990	MIXED		Functional	100%	16	0.26			
33 kv NEHRU PLACE GRID	SNPHG137	11kv FDR O/G BAHAI MANDIR	TG-OIS153A-1	630	MIXED		Functional	100%	7	0.21			
33 kv EAST OF KAILASH GRID	SKLSH107	11kv FDR SSTN SABJI MANDI OKHLA PHASE-3	TI-OIS024A-2	990	MIXED		Functional	100%	20	0.19			
33 kv EAST OF KAILASH GRID	SKLSH109	11kv FDR S.B.I NO.-1	TG-OIS038A-1	990	MIXED		Functional	100%	14	0.19			
33 kv NEHRU PLACE GRID	SNPHG137	11kv FDR O/G BAHAI MANDIR	TG-OIS032A-1	630	RESIDENTIAL		Functional	100%	177	0.18			
33 kv EAST OF KAILASH GRID	SKLSH117	11kv FDR S.B.I NO.-2	TI-OIS025A-1	990	COMMERCIAL		Functional	100%	46	0.15			
33 kv BALAJI STATE GRID	SBALA113	11KV FDR OKHLA SSTN NO-80 PH-3	TI-OIS047A-1	630	RESIDENTIAL		Functional	100%	74	0.11			
33 kv EAST OF KAILASH GRID	SKLSH107	11kv FDR SSTN SABJI MANDI OKHLA PHASE-3	530023-OIS170A-	400	RESIDENTIAL		Functional	100%	5	0.09			
33 kv EAST OF KAILASH GRID	SKLSH109	11kv FDR S.B.I NO.-1	530023-OIS179A-	400	MIXED		Functional	100%	0	0.08			
33 kv BALAJI STATE GRID	SBALA113	11KV FDR OKHLA SSTN NO-80 PH-3	TG-OIS097A-1	630	RESIDENTIAL		Functional	100%	13	0.07			
33 kv EAST OF KAILASH GRID	SKLSH117	11kv FDR S.B.I NO.-2	TG-OIS037A-1	400	MIXED		Functional	100%	3	0.04			
33 kv EAST OF KAILASH GRID	SKLSH103	11KV FDR S/S NO.-6 OKHLA PHASE-3	530023-OIS180A-	400	MIXED		Functional	100%	0	0.00			
33 kv EAST OF KAILASH GRID	SKLSH101	11kv FDR KAILASH APPARTMENT	TG-GK1074A-1	990	RESIDENTIAL		Functional	100%	396	0.72	4.58	0.20	4.10%
33 kv EAST OF KAILASH GRID	SKLSH101	11kv FDR KAILASH APPARTMENT	TG-GK1063A-2	990	MIXED		Functional	100%	323	0.67			
33 kv H.U.D.C.O GRID	SHUDC117	11kv FDR O/G JAMRUPPUR S/S NO.-2 NHP	TI-GK1037A-1	990	RESIDENTIAL		Functional	100%	197	0.53			
33 kv H.U.D.C.O GRID	SHUDC117	11kv FDR O/G JAMRUPPUR S/S NO.-2 NHP	TG-GK1082A-1	630	RESIDENTIAL		Functional	100%	337	0.47			
33 kv EAST OF KAILASH GRID	SKLSH101	11kv FDR KAILASH APPARTMENT	TG-GK1066A-1	990	RESIDENTIAL		Functional	100%	72	0.37			
33 kv EAST OF KAILASH GRID	SKLSH101	11kv FDR KAILASH APPARTMENT	TG-GK1063A-1	630	MIXED		Functional	100%	284	0.35			
33 kv H.U.D.C.O GRID	SHUDC117	11kv FDR O/G JAMRUPPUR S/S NO.-2 NHP	TI-GK1039A-2	630	RESIDENTIAL		Functional	100%	94	0.32			
33 kv H.U.D.C.O GRID	SHUDC117	11kv FDR O/G JAMRUPPUR S/S NO.-2 NHP	TI-GK1037A-2	630	RESIDENTIAL		Functional	100%	208	0.26			
33 kv EAST OF KAILASH GRID	SKLSH101	11kv FDR KAILASH APPARTMENT	TG-GK1066A-2	990	RESIDENTIAL		Functional	100%	341	0.25			
33 kv H.U.D.C.O GRID	SHUDC117	11kv FDR O/G JAMRUPPUR S/S NO.-2 NHP	TI-GK1039A-1	990	RESIDENTIAL		Functional	100%	55	0.24			
33 kv H.U.D.C.O GRID	SHUDC117	11kv FDR O/G JAMRUPPUR S/S NO.-2 NHP	TI-GK1038A-2	630	RESIDENTIAL		Functional	100%	8	0.21			
33 kv EAST OF KAILASH GRID	SKLSH101	11kv FDR KAILASH APPARTMENT	TI-GK1033A-1	1000	RESIDENTIAL		Functional	100%	157	0.18			
33 kv H.U.D.C.O GRID	SHUDC117	11kv FDR O/G JAMRUPPUR S/S NO.-2 NHP	TI-GK1039A-3	630	RESIDENTIAL		Functional	100%	68	0.13			
33 kv H.U.D.C.O GRID	SHUDC117	11kv FDR O/G JAMRUPPUR S/S NO.-2 NHP	TI-GK1038A-1	630	RESIDENTIAL		Functional	100%	75	0.08			
33 kv NEHRU PLACE GRID	SNPHG118	11KV FDR O/G BUILDING NO.-75 & 76 NHP.	TI-GK1016A-1	1000	MIXED		Functional	100%	212	0.29	8.02	0.12	1.46%
33 kv NEHRU PLACE GRID	SNPHG122	11kv FDR O/G S/S NO.-5 NEHRU PLACE	TI-GK1015A-1	1000	COMMERCIAL		Functional	100%	193	0.26			
33 kv NEHRU PLACE GRID	SNPHG122	11kv FDR O/G S/S NO.-5 NEHRU PLACE	TI-GK1001A-2	630	MIXED		Functional	100%	0	0.26			
33 kv NEHRU PLACE GRID	SNPHG106	11KV FDR O/G S/S NO.-16 NHP	TI-GK1025A-1	990	COMMERCIAL		Functional	100%	90	0.25			
33 kv NEHRU PLACE GRID	SNPHG106	11KV FDR O/G S/S NO.-16 NHP	TI-GK1025A-2	990	RESIDENTIAL		Functional	100%	108	0.23			
33 kv NEHRU PLACE GRID	SNPHG105	11KV O/G BUILDING NO-37 NHP NO.2	TI-GK1008A-1	630	COMMERCIAL		Functional	100%	95	0.22			
33 kv NEHRU PLACE GRID	SNPHG125	11kv FDR O/G DEVIKA TOWER NHP	TI-GK1003A-1	990	COMMERCIAL		Functional	100%	302	0.21			
33 kv NEHRU PLACE GRID	SNPHG125	11kv FDR O/G DEVIKA TOWER NHP	TI-GK1031A-1	990	COMMERCIAL		Functional	100%	57	0.20			
33 kv NEHRU PLACE GRID	SNPHG112	11kv FDR O/G BUILDING NO.-43 NHP	TI-GK1012A-1	990	COMMERCIAL		Functional	100%	107	0.20			
33 kv NEHRU PLACE GRID	SNPHG117	11KV FDR O/G TELEPHONE EXCHANGE NHP.	TI-GK1026A-3	1000	COMMERCIAL		Functional	100%	46	0.20			
33 kv NEHRU PLACE GRID	SNPHG104	11KV FDR O/G BUILDING NO.-89 NHP.	TI-GK1020A-2	1000	COMMERCIAL		Functional	100%	14	0.19			
33 kv NEHRU PLACE GRID	SNPHG112	11kv FDR O/G BUILDING NO.-43 NHP	TI-GK1011A-2	630	COMMERCIAL		Functional	100%	0	0.19			
33 kv NEHRU PLACE GRID	SNPHG116	11KV FDR O/G BUILDING NO.-37 NHP	530GK1-GK1009A-	990	RESIDENTIAL		Functional	100%	49	0.19			
33 kv NEHRU PLACE GRID	SNPHG122	11kv FDR O/G S/S NO.-5 NEHRU PLACE	TI-GK1014A-1	1000	COMMERCIAL		Functional	100%	186	0.19			
33 kv NEHRU PLACE GRID	SNPHG120	11kv FDR O/G NEHRU PLACE HOTEL COMPLEX FEEDER NO.-2	TI-GK1027A-3	990	COMMERCIAL		Functional	100%	0	0.19			
33 kv NEHRU PLACE GRID	SNPHG122	11kv FDR O/G S/S NO.-5 NEHRU PLACE	TI-GK1014A-2	990	COMMERCIAL		Functional	100%	20	0.19			
33 kv NEHRU PLACE GRID	SNPHG117	11KV FDR O/G TELEPHONE EXCHANGE NHP.	TI-GK1026A-2	1000	COMMERCIAL		Functional	100%	0	0.18			

33 kV NEHRU PLACE GRID	SNPHG105	11KV O/G BUILDING NO-37 NHP NO.2	530GK1-GK1009A-	630	COMMERCIAL		Functional	100%	71	0.18			
33 kV NEHRU PLACE GRID	SNPHG106	11KV FDR O/G S/S NO.-16 NHP	TI-GK1024A-1	1000	COMMERCIAL		Functional	100%	238	0.17			
33 kV NEHRU PLACE GRID	SNPHG104	11KV FDR O/G BUILDING NO.-89 NHP.	TI-GK1022A-2	990	MIXED		Functional	100%	7	0.15			
33 kV NEHRU PLACE GRID	SNPHG106	11KV FDR O/G S/S NO.-16 NHP	TI-GK1023A-2	1000	COMMERCIAL		Functional	100%	17	0.15			
33 kV NEHRU PLACE GRID	SNPHG104	11KV FDR O/G BUILDING NO.-89 NHP.	TI-GK1030A-1	990	MIXED		Functional	100%	67	0.15			
33 kV NEHRU PLACE GRID	SNPHG134	11KV FDR O/G BUILDING NO.-38	TI-GK1099A-2	630	COMMERCIAL		Functional	100%	27	0.15			
33 kV NEHRU PLACE GRID	SNPHG106	11KV FDR O/G S/S NO.-16 NHP	TI-GK1024A-2	1000	COMMERCIAL		Functional	100%	16	0.15			
33 kV NEHRU PLACE GRID	SNPHG112	11KV FDR O/G BUILDING NO.-43 NHP	TI-GK1011A-3	990	COMMERCIAL		Functional	100%	0	0.14			
33 kV NEHRU PLACE GRID	SNPHG104	11KV FDR O/G BUILDING NO.-89 NHP.	TI-GK1020A-3	630	COMMERCIAL		Functional	100%	0	0.14			
33 kV NEHRU PLACE GRID	SNPHG134	11KV FDR O/G BUILDING NO.-38	TI-GK1099A-1	990	COMMERCIAL		Functional	100%	194	0.14			
33 kV NEHRU PLACE GRID	SNPHG104	11KV FDR O/G BUILDING NO.-89 NHP.	TI-GK1022A-1	990	MIXED		Functional	100%	120	0.14			
33 kV NEHRU PLACE GRID	SNPHG120	11KV FDR O/G NEHRU PLACE HOTEL COMPLEX FEEDER NO.-2	TI-GK1027A-2	990	COMMERCIAL		Functional	100%	0	0.14			
33 kV NEHRU PLACE GRID	SNPHG120	11KV FDR O/G NEHRU PLACE HOTEL COMPLEX FEEDER NO.-2	TI-GK1027A-1	990	COMMERCIAL		Functional	100%	158	0.13			
33 kV NEHRU PLACE GRID	SNPHG117	11KV FDR O/G TELEPHONE EXCHANGE NHP.	TI-GK1026A-1	990	COMMERCIAL		Functional	100%	233	0.13			
33 kV NEHRU PLACE GRID	SNPHG125	11KV FDR O/G DEVIKA TOWER NHP	TI-GK1031A-2	630	COMMERCIAL		Functional	100%	0	0.13			
33 kV NEHRU PLACE GRID	SNPHG106	11KV FDR O/G S/S NO.-16 NHP	TI-GK1023A-1	1000	COMMERCIAL		Functional	100%	170	0.13			
33 kV NEHRU PLACE GRID	SNPHG134	11KV FDR O/G BUILDING NO.-38	TI-GK1099A-3	990	COMMERCIAL		Functional	100%	55	0.12			
33 kV NEHRU PLACE GRID	SNPHG112	11KV FDR O/G BUILDING NO.-43 NHP	TI-GK1011A-1	1000	COMMERCIAL		Functional	100%	199	0.12			
33 kV NEHRU PLACE GRID	SNPHG125	11KV FDR O/G DEVIKA TOWER NHP	TI-GK1003A-3	990	COMMERCIAL		Functional	100%	0	0.12			
33 kV NEHRU PLACE GRID	SNPHG106	11KV FDR O/G S/S NO.-16 NHP	TI-GK1006A-1	990	COMMERCIAL		Functional	100%	74	0.12			
33 kV NEHRU PLACE GRID	SNPHG125	11KV FDR O/G DEVIKA TOWER NHP	TI-GK1003A-2	990	COMMERCIAL		Functional	100%	0	0.11			
33 kV NEHRU PLACE GRID	SNPHG117	11KV FDR O/G TELEPHONE EXCHANGE NHP.	TI-GK1004A-1	630	COMMERCIAL		Functional	100%	113	0.11			
33 kV NEHRU PLACE GRID	SNPHG112	11KV FDR O/G BUILDING NO.-43 NHP	TI-GK1013A-1	990	COMMERCIAL		Functional	100%	24	0.11			
33 kV NEHRU PLACE GRID	SNPHG118	11KV FDR O/G BUILDING NO.-75 & 76 NHP.	TI-GK1018A-2	400	MIXED		Functional	100%	16	0.11			
33 kV NEHRU PLACE GRID	SNPHG125	11KV FDR O/G DEVIKA TOWER NHP	TI-GK1007A-2	630	COMMERCIAL		Functional	100%	4	0.10			
33 kV NEHRU PLACE GRID	SNPHG104	11KV FDR O/G BUILDING NO.-89 NHP.	TI-GK1030A-2	630	MIXED		Functional	100%	27	0.10			
33 kV NEHRU PLACE GRID	SNPHG104	11KV FDR O/G BUILDING NO.-89 NHP.	TI-GK1019A-2	630	MIXED		Functional	100%	1	0.10			
33 kV NEHRU PLACE GRID	SNPHG104	11KV FDR O/G BUILDING NO.-89 NHP.	TI-GK1019A-1	630	MIXED		Functional	100%	167	0.10			
33 kV NEHRU PLACE GRID	SNPHG122	11KV FDR O/G S/S NO.-5 NEHRU PLACE	TI-GK1015A-2	630	COMMERCIAL		Functional	100%	0	0.10			
33 kV NEHRU PLACE GRID	SNPHG104	11KV FDR O/G BUILDING NO.-89 NHP.	TI-GK1020A-1	630	COMMERCIAL		Functional	100%	254	0.09			
33 kV NEHRU PLACE GRID	SNPHG118	11KV FDR O/G BUILDING NO.-75 & 76 NHP.	TI-GK1017A-1	400	MIXED		Functional	100%	107	0.09			
33 kV NEHRU PLACE GRID	SNPHG118	11KV FDR O/G BUILDING NO.-75 & 76 NHP.	TI-GK1017A-2	400	MIXED		Functional	100%	0	0.08			
33 kV NEHRU PLACE GRID	SNPHG125	11KV FDR O/G DEVIKA TOWER NHP	TI-GK1007A-1	630	COMMERCIAL		Functional	100%	3	0.08			
33 kV NEHRU PLACE GRID	SNPHG105	11KV O/G BUILDING NO-37 NHP NO.2	TI-GK1008A-2	630	RESIDENTIAL		Functional	100%	0	0.08			
33 kV NEHRU PLACE GRID	SNPHG112	11KV FDR O/G BUILDING NO.-43 NHP	TI-GK1013A-2	630	COMMERCIAL		Functional	100%	37	0.08			
33 kV NEHRU PLACE GRID	SNPHG122	11KV FDR O/G S/S NO.-5 NEHRU PLACE	TI-GK1001A-1	630	MIXED		Functional	100%	153	0.06			
33 kV NEHRU PLACE GRID	SNPHG118	11KV FDR O/G BUILDING NO.-75 & 76 NHP.	530GK1-OIS169A-	400	COMMERCIAL		Functional	100%	3	0.06			
33 kV NEHRU PLACE GRID	SNPHG118	11KV FDR O/G BUILDING NO.-75 & 76 NHP.	TI-GK1018A-1	400	MIXED		Functional	100%	51	0.04			
33 kV NEHRU PLACE GRID	SNPHG112	11KV FDR O/G BUILDING NO.-43 NHP	TI-GK1012A-2	630	COMMERCIAL		Functional	100%	0	0.04			
33 kV NEHRU PLACE GRID	SNPHG117	11KV FDR O/G TELEPHONE EXCHANGE NHP.	TI-GK1005A-1	630	COMMERCIAL		Functional	100%	4	0.04			
33 kV NEHRU PLACE GRID	SNPHG117	11KV FDR O/G TELEPHONE EXCHANGE NHP.	TI-GK1005A-2	630	COMMERCIAL		Functional	100%	5	0.02			
33 kV NEHRU PLACE GRID	SNPHG118	11KV FDR O/G BUILDING NO.-75 & 76 NHP.	530GK1-OIS174A-	250	MIXED		Functional	100%	3	0.01			
33 kV NEHRU PLACE GRID	SNPHG124	11KV FDR O/G NEHRU PLACE HOTEL COMPLEX FEEDER NO.-1	TI-GK1027A-4	630	COMMERCIAL		Functional	100%	13	0.00			
33 kV EAST OF KAILASH GRID	SKLSH110	11KV FDR DAYANAND KIOSK	TK-GAR006A-1	990	RESIDENTIAL		Functional	100%	1201	0.66	4.63	0.05	1.08%
33 kV EAST OF KAILASH GRID	SKLSH110	11KV FDR DAYANAND KIOSK	TK-GAR006A-2	990	RESIDENTIAL		Functional	100%	1729	0.64			
33 kV LAJPAT NAGAR-3 GRID	SLJPT120	11KV FDR O/G 39 RING ROAD	TX-GAR007A-2	990	RESIDENTIAL		Functional	100%	0	0.56			
33 kV EAST OF KAILASH GRID	SKLSH114	11KV FDR D-BLOCK EAST OF KAILASH	TG-GAR005A-1	990	RESIDENTIAL		Functional	100%	1208	0.56			
33 kV LAJPAT NAGAR-3 GRID	SLJPT120	11KV FDR O/G 39 RING ROAD	TX-GAR007A-1	630	RESIDENTIAL		Functional	100%	1701	0.56			
33 kV EAST OF KAILASH GRID	SKLSH110	11KV FDR DAYANAND KIOSK	TG-GAR045A-2	990	RESIDENTIAL		Functional	100%	1557	0.53			
33 kV EAST OF KAILASH GRID	SKLSH114	11KV FDR D-BLOCK EAST OF KAILASH	TG-GAR005A-2	990	RESIDENTIAL		Functional	100%	0	0.45			

33 kv EAST OF KAILASH GRID	SKLSH110	11kv FDR DAYANAND KIOSK	TG-GAR045A-1	990	RESIDENTIAL		Functional	100%	0	0.38			
33 kv EAST OF KAILASH GRID	SKLSH116	11kv FDR KALA KUTIR	TG-GAR051A-1	630	RESIDENTIAL		Functional	100%	522	0.33			
33 kv OKHLA PHASE-2 GRID	SOKH2126	11kv FDR O/G Z-BLOCK VIA -X-BLOCK OKHLA PHASE-II	TG-OIS092A-2	990	RESIDENTIAL		Functional	100%	0	0.67	4.27	0.05	1.26%
33 kv OKHLA PHASE-2 GRID	SOKH2107	11kv FDR DSIDC SCHEME NO.-1 PHASE-2	TI-OIS031A-1	990	RESIDENTIAL		Functional	100%	99	0.59			
33 kv OKHLA PHASE-2 GRID	SOKH2124	11kv FDR O/G C-46, O.I.A PHASE-2	TI-OIS020A-1	990	RESIDENTIAL		Functional	100%	174	0.48			
33 kv OKHLA PHASE-2 GRID	SOKH2124	11kv FDR O/G C-46, O.I.A PHASE-2	TI-OIS020A-2	990	RESIDENTIAL		Functional	100%	107	0.43			
33 kv OKHLA PHASE-2 GRID	SOKH2125	11kv FDR SHED NO.-8,DSIDC SC-III	TI-OIS012A-2	1000	RESIDENTIAL		Functional	100%	46	0.39			
33 kv OKHLA PHASE-2 GRID	SOKH2121	11kv FDR S/S NO.-5, OIA PHASE-2	TI-OIS005A-1	990	RESIDENTIAL		Functional	100%	497	0.34			
33 kv OKHLA PHASE-2 GRID	SOKH2107	11kv FDR DSIDC SCHEME NO.-1 PHASE-2	TI-OIS031A-2	990	RESIDENTIAL		Functional	100%	42	0.30			
33 kv OKHLA PHASE-2 GRID	SOKH2125	11kv FDR SHED NO.-8,DSIDC SC-III	TI-OIS012A-1	630	RESIDENTIAL		Functional	100%	37	0.29			
33 kv OKHLA PHASE-2 GRID	SOKH2121	11kv FDR S/S NO.-5, OIA PHASE-2	TI-OIS005A-3	990	RESIDENTIAL		Functional	100%	0	0.29			
33 kv OKHLA PHASE-2 GRID	SOKH2121	11kv FDR S/S NO.-5, OIA PHASE-2	TI-OIS005A-2	630	RESIDENTIAL		Functional	100%	0	0.20			
33 kv OKHLA PHASE-2 GRID	SOKH2125	11kv FDR SHED NO.-8,DSIDC SC-III	TX-OIS091A-1	990	RESIDENTIAL		Functional	100%	81	0.18			
33 kv OKHLA PHASE-2 GRID	SOKH2126	11kv FDR O/G Z-BLOCK VIA -X-BLOCK OKHLA PHASE-II	TX-OIS092A-1	990	RESIDENTIAL		Functional	100%	155	0.16			
33 kv NEHRU PLACE GRID	SNPHG105	11kv O/G BULDING NO-37 NHP NO.2	TG-GAR022A-2	990	RESIDENTIAL		Functional	100%	173	0.79	5.23	0.16	2.88%
33 kv NEHRU PLACE GRID	SNPHG105	11kv O/G BULDING NO-37 NHP NO.2	TG-GAR036A-2	990	COMMERCIAL		Functional	100%	80	0.72			
33 kv NEHRU PLACE GRID	SNPHG105	11kv O/G BULDING NO-37 NHP NO.2	TG-GAR022A-1	990	RESIDENTIAL		Functional	100%	427	0.56			
33 kv EAST OF KAILASH GRID	SKLSH101	11kv FDR KAILASH APPARTMENT	TG-GAR061A-1	990	RESIDENTIAL		Functional	100%	251	0.51			
33 kv NEHRU PLACE GRID	SNPHG105	11kv O/G BULDING NO-37 NHP NO.2	TG-GAR039A-2	990	RESIDENTIAL		Functional	100%	196	0.49			
33 kv NEHRU PLACE GRID	SNPHG105	11kv O/G BULDING NO-37 NHP NO.2	TG-GAR036A-1	990	COMMERCIAL		Functional	100%	237	0.48			
33 kv EAST OF KAILASH GRID	SKLSH104	11kv FDR E-BLOCK EAST OF KAILASH	TG-GAR031A-2	990	RESIDENTIAL		Functional	100%	53	0.34			
33 kv EAST OF KAILASH GRID	SKLSH104	11kv FDR E-BLOCK EAST OF KAILASH	TG-GAR038A-1	990	RESIDENTIAL		Functional	100%	82	0.34			
33 kv EAST OF KAILASH GRID	SKLSH104	11kv FDR E-BLOCK EAST OF KAILASH	TI-GAR021A-3	990	RESIDENTIAL		Functional	100%	50	0.29			
33 kv NEHRU PLACE GRID	SNPHG105	11kv O/G BULDING NO-37 NHP NO.2	TG-GAR039A-1	630	RESIDENTIAL		Functional	100%	43	0.28			
33 kv EAST OF KAILASH GRID	SKLSH104	11kv FDR E-BLOCK EAST OF KAILASH	TG-GAR031A-1	630	RESIDENTIAL		Functional	100%	74	0.23			
33 kv EAST OF KAILASH GRID	SKLSH104	11kv FDR E-BLOCK EAST OF KAILASH	TI-GAR021A-1	990	RESIDENTIAL		Functional	100%	229	0.20			
33 kv EAST OF KAILASH GRID	SKLSH104	11kv FDR E-BLOCK EAST OF KAILASH	TI-GAR021A-2	630	RESIDENTIAL		Functional	100%	27	0.17			
33 kv EAST OF KAILASH GRID	SKLSH104	11kv FDR E-BLOCK EAST OF KAILASH	TG-GAR023A-1	100	RESIDENTIAL		Functional	100%	3	0.00			
33 kv OKHLA PHASE-2 GRID	SOKH2108	11kv FDR S/S NO.-4, OKHLA PHASE-2	TI-OIS004A-1	990	RESIDENTIAL		Functional	100%	50	0.47	3.39	0.13	3.63%
220kv OKHLA TRANSCO GRID SST	TDTOG101	11kv FDR D.D.A LSC OKHLA PH.-2	TI-OIS003A-1	990	INDUSTRIAL		Functional	100%	154	0.40			
33 kv OKHLA PHASE-2 GRID	SOKH2108	11kv FDR S/S NO.-4, OKHLA PHASE-2	TG-OIS041A-1	990	RESIDENTIAL		Functional	100%	42	0.36			
220kv OKHLA TRANSCO GRID SST	TDTOG101	11kv FDR D.D.A LSC OKHLA PH.-2	TG-OIS152A-1	990	INDUSTRIAL		Functional	100%	9	0.35			
220kv OKHLA TRANSCO GRID SST	TDTOG101	11kv FDR D.D.A LSC OKHLA PH.-2	TI-OIS003A-3	990	INDUSTRIAL		Functional	100%	0	0.33			
220kv OKHLA TRANSCO GRID SST	TDTOG101	11kv FDR D.D.A LSC OKHLA PH.-2	TX-OIS094A-1	990	INDUSTRIAL		Functional	100%	10	0.33			
33 kv OKHLA PHASE-2 GRID	SOKH2108	11kv FDR S/S NO.-4, OKHLA PHASE-2	TI-OIS004A-2	990	INDUSTRIAL		Functional	100%	0	0.31			
220kv OKHLA TRANSCO GRID SST	TDTOG101	11kv FDR D.D.A LSC OKHLA PH.-2	TI-OIS003A-2	1000	INDUSTRIAL		Functional	100%	0	0.26			
33 kv OKHLA PHASE-2 GRID	SOKH2108	11kv FDR S/S NO.-4, OKHLA PHASE-2	TG-OIS056A-2	990	INDUSTRIAL		Functional	100%	27	0.22			
33 kv OKHLA PHASE-2 GRID	SOKH2120	11kv FDR S/S NO.-4, FEEDER-2 PHASE-2	TI-OIS004A-3	990	INDUSTRIAL		Functional	100%	0	0.18			
33 kv OKHLA PHASE-2 GRID	SOKH2108	11kv FDR S/S NO.-4, OKHLA PHASE-2	TG-OIS056A-1	990	INDUSTRIAL		Functional	100%	10	0.18			
220kv OKHLA TRANSCO GRID SST	TDTOG101	11kv FDR D.D.A LSC OKHLA PH.-2	TG-OIS003A-4	630	MIXED		Functional	100%	0	0.12			
33 kv OKHLA PHASE-2 GRID	SOKH2120	11kv FDR S/S NO.-4, FEEDER-2 PHASE-2	2530023-OIS175A-	400	COMMERCIAL		Functional	100%	1	0.01			
33 kv NEHRU PLACE GRID	SNPHG131	11kv STR 990kVA LOCAL TRF. NO.-2	TI-GK1028A-1	1000	COMMERCIAL		Functional	100%	5	0.33	0.41	0.05	11.70%
33 kv NEHRU PLACE GRID	SNPHG130	11kv STR 990kVA LOCAL TRF. NO.-1	TI-GK1028A-2	1000	COMMERCIAL		Functional	100%	0	0.10			
33 kv NEHRU PLACE GRID	SNPHG137	11kv FDR O/G BAHAI MANDIR	TI-GK1029A-1	400	MIXED		Functional	100%	29	0.03			
33 kv NEHRU PLACE GRID	SNPHG137	11kv FDR O/G BAHAI MANDIR	TI-GK1029A-2	400	MIXED		Functional	100%	0	0.01			
33 kv EAST OF KAILASH GRID	SKLSH116	11kv FDR KALA KUTIR	TG-GAR032A-1	1600	RESIDENTIAL		Functional	100%	1251	1.30	4.40	0.16	3.43%
33 kv EAST OF KAILASH GRID	SKLSH116	11kv FDR KALA KUTIR	TG-GAR052A-1	990	RESIDENTIAL		Functional	100%	780	0.75			

33 kv EAST OF KAILASH GRID	SKLSH116	11kv FDR KALA KUTIR	TG-GAR032A-2	990	RESIDENTIAL	Functional	100%	532	0.65			
33 kv EAST OF KAILASH GRID	SKLSH116	11kv FDR KALA KUTIR	TG-GAR008A-1	630	RESIDENTIAL	Functional	100%	921	0.56			
33 kv EAST OF KAILASH GRID	SKLSH116	11kv FDR KALA KUTIR	TG-GAR008A-2	630	RESIDENTIAL	Functional	100%	19	0.55			
33 kv EAST OF KAILASH GRID	SKLSH105	11kv FDR B-BLOCK EAST OF KAILASH (VIA C-BLOCK)	TG-GAR040A-1	990	RESIDENTIAL	Functional	100%	624	0.50			
33 kv EAST OF KAILASH GRID	SKLSH105	11kv FDR B-BLOCK EAST OF KAILASH (VIA C-BLOCK)	TG-GAR040A-2	630	RESIDENTIAL	Functional	100%	0	0.25			
33 kv MASJID MOTH GRID	SMMOT112	11kv FDR DDA FLATS MASJID MOTH PHASE-1 G.K-1 NHP	TX-GK1088A-1	990	RESIDENTIAL	Functional	100%	139	0.28	0.60	0.04	5.52%
33 kv MASJID MOTH GRID	SMMOT112	11kv FDR DDA FLATS MASJID MOTH PHASE-1 G.K-1 NHP	TI-GK1055A-1	630	RESIDENTIAL	Functional	100%	287	0.27			
33 kv MASJID MOTH GRID	SMMOT112	11kv FDR DDA FLATS MASJID MOTH PHASE-1 G.K-1 NHP	TI-GK1055A-2	400	RESIDENTIAL	Functional	100%	0	0.09			
33 kv NEHRU PLACE GRID	SNPHG103	11kv FDR O/G R-BLOCK G.K-1	TG-GK1067A-2	990	RESIDENTIAL	Functional	100%	405	0.67	6.02	0.56	8.54%
33 kv NEHRU PLACE GRID	SNPHG114	11kv FDR O/G S-BLOCK G.K-1	TK-GK1048A-1	990	RESIDENTIAL	Functional	100%	430	0.59			
33 kv V.S.N.L. GRID	SVSNL103	11kv FDR OUT GOING FEEDER-5, M-BLOCK (K) S/STN. G.K-I	530GK1-GK1104A-	990	RESIDENTIAL	Functional	100%	95	0.58			
33 kv NEHRU PLACE GRID	SNPHG114	11kv FDR O/G S-BLOCK G.K-1	TK-GK1048A-2	990	RESIDENTIAL	Functional	100%	88	0.56			
33 kv NEHRU PLACE GRID	SNPHG114	11kv FDR O/G S-BLOCK G.K-1	TG-GK1050A-1	990	RESIDENTIAL	Functional	100%	307	0.48			
33 kv NEHRU PLACE GRID	SNPHG103	11kv FDR O/G R-BLOCK G.K-1	TG-GK1067A-1	990	RESIDENTIAL	Functional	100%	0	0.48			
33 kv NEHRU PLACE GRID	SNPHG114	11kv FDR O/G S-BLOCK G.K-1	TK-GK1048A-3	990	RESIDENTIAL	Functional	100%	144	0.42			
33 kv V.S.N.L. GRID	SVSNL107	11kv FDR OUT GOING FEEDER-4, E-BLOCK (K) S/STN. G.K-I	TG-GK1072A-1	990	RESIDENTIAL	Functional	100%	152	0.41			
33 kv V.S.N.L. GRID	SVSNL103	11kv FDR OUT GOING FEEDER-5, M-BLOCK (K) S/STN. G.K-I	530GK1-GK1104A-	990	RESIDENTIAL	Functional	100%	49	0.36			
33 kv NEHRU PLACE GRID	SNPHG103	11kv FDR O/G R-BLOCK G.K-1	TG-GK1081A-1	990	RESIDENTIAL	Functional	100%	165	0.33			
33 kv NEHRU PLACE GRID	SNPHG114	11kv FDR O/G S-BLOCK G.K-1	TG-GK1047A-1	990	RESIDENTIAL	Functional	100%	104	0.31			
33 kv V.S.N.L. GRID	SVSNL103	11kv FDR OUT GOING FEEDER-5, M-BLOCK (K) S/STN. G.K-I	TG-GK1086A-1	990	RESIDENTIAL	Functional	100%	114	0.31			
33 kv NEHRU PLACE GRID	SNPHG114	11kv FDR O/G S-BLOCK G.K-1	TG-GK1047A-2	990	RESIDENTIAL	Functional	100%	177	0.29			
33 kv NEHRU PLACE GRID	SNPHG114	11kv FDR O/G S-BLOCK G.K-1	TG-GK1071A-1	630	RESIDENTIAL	Functional	100%	183	0.24			
33 kv V.S.N.L. GRID	SVSNL103	11kv FDR OUT GOING FEEDER-5, M-BLOCK (K) S/STN. G.K-I	TG-GK1086A-2	990	RESIDENTIAL	Functional	100%	0	0.23			
33 kv V.S.N.L. GRID	SVSNL103	11kv FDR OUT GOING FEEDER-5, M-BLOCK (K) S/STN. G.K-I	TG-GK1115A-1	990	RESIDENTIAL	Functional	100%	200	0.20			
33 kv V.S.N.L. GRID	SVSNL103	11kv FDR OUT GOING FEEDER-5, M-BLOCK (K) S/STN. G.K-I	530GK1-GK1104A-	630	RESIDENTIAL	Functional	100%	196	0.13			
33 kv OKHLA PHASE-2 GRID	SOKH2101	11kv FDR Y-POKET OKHLA PHASE-2	TG-OIS030A-2	990	RESIDENTIAL	Functional	100%	516	0.96	4.46	0.05	1.18%
33 kv NEHRU PLACE GRID	SNPHG137	11kv FDR O/G BAHAI MANDIR	TG-OIS048A-1	990	RESIDENTIAL	Functional	100%	1280	0.81			
33 kv NEHRU PLACE GRID	SNPHG137	11kv FDR O/G BAHAI MANDIR	TG-OIS048A-2	990	RESIDENTIAL	Functional	100%	649	0.69			
33 kv NEHRU PLACE GRID	SNPHG137	11kv FDR O/G BAHAI MANDIR	TG-OIS033A-1	990	RESIDENTIAL	Functional	100%	284	0.63			
33 kv EAST OF KAILASH GRID	SKLSH103	11kv FDR S/S NO.-6 OKHLA PHASE-3	TG-OIS101A-1	630	RESIDENTIAL	Functional	100%	407	0.50			
33 kv OKHLA PHASE-2 GRID	SOKH2101	11kv FDR Y-POKET OKHLA PHASE-2	TG-OIS030A-1	630	RESIDENTIAL	Functional	100%	1214	0.48			
33 kv BALAJI STATE GRID	SBALA117	11kv FDR O/G RMU NEAR BALAJI GRID	TG-OIS154A-1	630	RESIDENTIAL	Functional	100%	326	0.39			
33 kv BALAJI STATE GRID	SBALA111	11kv FDR G.B. PANT STAFF QUARTERS	TI-OIS090A-1	400	RESIDENTIAL	Functional	100%	76	0.05			
33 kv NEHRU PLACE GRID	SNPHG121	11kv FDR O/G KAILASH COLONY DISPENSARY	TI-GK1040A-2	990	RESIDENTIAL	Functional	100%	112	0.67	7.58	0.15	1.94%
33 kv NEHRU PLACE GRID	SNPHG121	11kv FDR O/G KAILASH COLONY DISPENSARY	TG-GK1042A-1	990	RESIDENTIAL	Functional	100%	197	0.62			
33 kv NEHRU PLACE GRID	SNPHG121	11kv FDR O/G KAILASH COLONY DISPENSARY	TK-GK1041A-1	990	RESIDENTIAL	Functional	100%	312	0.62			
33 kv NEHRU PLACE GRID	SNPHG121	11kv FDR O/G KAILASH COLONY DISPENSARY	TI-GK1040A-1	990	RESIDENTIAL	Functional	100%	299	0.58			
33 kv NEHRU PLACE GRID	SNPHG102	11kv FDR O/G TO DELHI ADMN. FLATS	TX-GK1073A-1	990	RESIDENTIAL	Functional	100%	182	0.54			
33 kv V.S.N.L. GRID	SVSNL107	11kv FDR OUT GOING FEEDER-4, E-BLOCK (K) S/STN. G.K-I	TK-GK1045A-1	1000	RESIDENTIAL	Functional	100%	176	0.52			
33 kv NEHRU PLACE GRID	SNPHG102	11kv FDR O/G TO DELHI ADMN. FLATS	TI-GK1043A-1	990	RESIDENTIAL	Functional	100%	195	0.48			
33 kv V.S.N.L. GRID	SVSNL110	11kv FDR OUT GOING FEEDER-8,R-BLOCK G.K-I	TX-GK1065A-1	990	RESIDENTIAL	Functional	100%	251	0.48			
33 kv V.S.N.L. GRID	SVSNL107	11kv FDR OUT GOING FEEDER-4, E-BLOCK (K) S/STN. G.K-I	TK-GK1090A-1	990	RESIDENTIAL	Functional	100%	603	0.46			
33 kv V.S.N.L. GRID	SVSNL107	11kv FDR OUT GOING FEEDER-4, E-BLOCK (K) S/STN. G.K-I	TG-GK1077A-1	990	RESIDENTIAL	Functional	100%	140	0.45			
33 kv V.S.N.L. GRID	SVSNL107	11kv FDR OUT GOING FEEDER-4, E-BLOCK (K) S/STN. G.K-I	TK-GK1090A-2	990	RESIDENTIAL	Functional	100%	0	0.45			
33 kv NEHRU PLACE GRID	SNPHG102	11kv FDR O/G TO DELHI ADMN. FLATS	TG-GK1105A-1	990	RESIDENTIAL	Functional	100%	23	0.33			
33 kv NEHRU PLACE GRID	SNPHG102	11kv FDR O/G TO DELHI ADMN. FLATS	TG-GK1079A-2	990	RESIDENTIAL	Functional	100%	0	0.33			
33 kv NEHRU PLACE GRID	SNPHG121	11kv FDR O/G KAILASH COLONY DISPENSARY	TG-GK1085A-1	630	RESIDENTIAL	Functional	100%	232	0.24			
33 kv NEHRU PLACE GRID	SNPHG102	11kv FDR O/G TO DELHI ADMN. FLATS	TG-GK1079A-1	630	RESIDENTIAL	Functional	100%	291	0.23			
33 kv NEHRU PLACE GRID	SNPHG121	11kv FDR O/G KAILASH COLONY DISPENSARY	TK-GK1041A-2	1000	RESIDENTIAL	Functional	100%	0	0.22			
33 kv NEHRU PLACE GRID	SNPHG121	11kv FDR O/G KAILASH COLONY DISPENSARY	TG-GK1085A-2	990	RESIDENTIAL	Functional	100%	0	0.22			

33 kv V.S.N.L. GRID	SVSNL107	11kv FDR OUT GOING FEEDER-4, E-BLOCK (K) S/STN. G.K-1	TK-GK1045A-2	630	RESIDENTIAL	Functional	100%	0	0.20			
33 kv NEHRU PLACE GRID	SNPHG102	11kv FDR O/G TO DELHI ADMN. FLATS	TI-GK1043A-2	630	RESIDENTIAL	Functional	100%	0	0.09			
33 kv MASJID MOTH GRID	SMMOT112	11kv FDR DDA FLATS MASJID MOTH PHASE-1 G.K-1 NHP	TI-GK1054A-1	630	RESIDENTIAL	Functional	100%	195	0.17	0.17	0.01	4.03%
33 kv MASJID MOTH GRID	SMMOT112	11kv FDR DDA FLATS MASJID MOTH PHASE-1 G.K-1 NHP	TI-GK1053A-1	400	RESIDENTIAL	Functional	100%	6	0.00			
33 kv H.U.D.C.O GRID	SHUDC120	11kv FDR O/G NATIONAL PARK	TG-GAR047A-1	990	COMMERCIAL	Functional	100%	376	0.50	1.06	0.05	4.48%
33 kv DEFENCE COLONY GRID	SDCOL111	11kv FDR O/G VIKRAM HOTEL	TI-GAR025A-1	630	COMMERCIAL	Functional	100%	77	0.29			
33 kv H.U.D.C.O GRID	SHUDC119	11kv FDR O/G SDM OFFICE VIA NURSING HOSTEL	TI-GAR027A-1	630	COMMERCIAL	Functional	100%	48	0.21			
33 kv DEFENCE COLONY GRID	SDCOL111	11kv FDR O/G VIKRAM HOTEL	TP-GAR070A-1	400	RESIDENTIAL	Functional	100%	18	0.09			
33 kv DEFENCE COLONY GRID	SDCOL111	11kv FDR O/G VIKRAM HOTEL	TI-GAR026A-1	100	COMMERCIAL	Functional	100%	4	0.02			
33 kv OKHLA PHASE-2 GRID	SOKH2101	11kv FDR Y-POKET OKHLA PHASE-2	TI-OIS008A-2	990	COMMERCIAL	Functional	100%	139	0.64	3.48	0.20	5.38%
33 kv OKHLA PHASE-2 GRID	SOKH2126	11kv FDR O/G Z-BLOCK VIA -X-BLOCK OKHLA PHASE-II	TI-OIS009A-2	990	INDUSTRIAL	Functional	100%	102	0.57			
33 kv OKHLA PHASE-2 GRID	SOKH2126	11kv FDR O/G Z-BLOCK VIA -X-BLOCK OKHLA PHASE-II	TI-OIS009A-3	990	INDUSTRIAL	Functional	100%	0	0.53			
33 kv OKHLA PHASE-2 GRID	SOKH2101	11kv FDR Y-POKET OKHLA PHASE-2	TI-OIS008A-3	990	COMMERCIAL	Functional	100%	170	0.35			
33 kv OKHLA PHASE-2 GRID	SOKH2101	11kv FDR Y-POKET OKHLA PHASE-2	TI-OIS008A-1	990	COMMERCIAL	Functional	100%	689	0.33			
33 kv OKHLA PHASE-2 GRID	SOKH2126	11kv FDR O/G Z-BLOCK VIA -X-BLOCK OKHLA PHASE-II	TI-OIS009A-1	630	INDUSTRIAL	Functional	100%	310	0.30			
33 kv OKHLA PHASE-2 GRID	SOKH2101	11kv FDR Y-POKET OKHLA PHASE-2	TX-OIS096A-1	990	MIXED	Functional	100%	17	0.29			
33 kv OKHLA PHASE-2 GRID	SOKH2120	11kv FDR S/S NO.-4, FEEDER-2 PHASE-2	TI-OIS011A-1	990	MIXED	Functional	100%	117	0.22			
33 kv OKHLA PHASE-2 GRID	SOKH2120	11kv FDR S/S NO.-4, FEEDER-2 PHASE-2	TI-OIS011A-2	1000	MIXED	Functional	100%	127	0.21			
33 kv OKHLA PHASE-2 GRID	SOKH2118	11kv FDR SEWAGE PUMPING STATION Z-BLOCK PHASE-2	TP-OIS099A-1	400	MIXED	Functional	100%	16	0.14			
33 kv OKHLA PHASE-2 GRID	SOKH2101	11kv FDR Y-POKET OKHLA PHASE-2	TG-OIS160A-1	630	INDUSTRIAL	Functional	100%	12	0.09			
33 kv EAST OF KAILASH GRID	SKLSH118	11kv FDR G-BLOCK EAST OF KAILASH	TI-GAR014A-2	990	RESIDENTIAL	Functional	100%	453	0.67	4.21	0.12	2.67%
33 kv EAST OF KAILASH GRID	SKLSH118	11kv FDR G-BLOCK EAST OF KAILASH	TI-GAR013A-2	990	MIXED	Functional	100%	0	0.54			
33 kv EAST OF KAILASH GRID	SKLSH118	11kv FDR G-BLOCK EAST OF KAILASH	TI-GAR013A-3	1000	MIXED	Functional	100%	0	0.54			
33 kv EAST OF KAILASH GRID	SKLSH118	11kv FDR G-BLOCK EAST OF KAILASH	TI-GAR014A-3	990	RESIDENTIAL	Functional	100%	207	0.50			
33 kv EAST OF KAILASH GRID	SKLSH105	11kv FDR B-BLOCK EAST OF KAILASH (VIA C-BLOCK)	TG-GAR049A-1	990	MIXED	Functional	100%	267	0.41			
33 kv EAST OF KAILASH GRID	SKLSH118	11kv FDR G-BLOCK EAST OF KAILASH	TI-GAR013A-1	990	MIXED	Functional	100%	912	0.39			
33 kv EAST OF KAILASH GRID	SKLSH118	11kv FDR G-BLOCK EAST OF KAILASH	TI-GAR014A-1	630	RESIDENTIAL	Functional	100%	410	0.27			
33 kv EAST OF KAILASH GRID	SKLSH114	11kv FDR D-BLOCK EAST OF KAILASH	TI-GAR028A-2	630	COMMERCIAL	Functional	100%	0	0.22			
33 kv EAST OF KAILASH GRID	SKLSH117	11kv FDR S.B.I NO.-2	TI-GAR015A-1	630	MIXED	Functional	100%	168	0.17			
33 kv EAST OF KAILASH GRID	SKLSH114	11kv FDR D-BLOCK EAST OF KAILASH	TI-GAR030A-1	400	COMMERCIAL	Functional	100%	65	0.16			
33 kv NEHRU PLACE GRID	SNPHG105	11kv O/G BULDING NO-37 NHP NO.2	TI-GAR029A-2	630	COMMERCIAL	Functional	100%	4	0.13			
33 kv NEHRU PLACE GRID	SNPHG105	11kv O/G BULDING NO-37 NHP NO.2	TI-GAR029A-1	630	COMMERCIAL	Functional	100%	141	0.13			
33 kv EAST OF KAILASH GRID	SKLSH114	11kv FDR D-BLOCK EAST OF KAILASH	TI-GAR028A-1	630	COMMERCIAL	Functional	100%	249	0.13			
33 kv EAST OF KAILASH GRID	SKLSH114	11kv FDR D-BLOCK EAST OF KAILASH	TI-GAR030A-2	630	COMMERCIAL	Functional	100%	53	0.06			
33 kv EAST OF KAILASH GRID	SKLSH113	11kv STR 100kVA SATTION TRANSFORMER	TP-STC073A-1	100	RESIDENTIAL	Functional	100%	1	0.01			
33 kv OKHLA PHASE-2 GRID	SOKH2102	11kv FDR S/S NO.-1, FEEDER-1 PHASE-2 VIA B-18/2	TI-OIS001A-1	990	INDUSTRIAL	Functional	100%	289	0.78	6.42	0.15	2.29%
33 kv OKHLA PHASE-2 GRID	SOKH2102	11kv FDR S/S NO.-1, FEEDER-1 PHASE-2 VIA B-18/2	TG-OIS115A-1	990	RESIDENTIAL	Functional	100%	115	0.69			
33 kv OKHLA PHASE-2 GRID	SOKH2115	11kv FDR S/S NO.-1, OKHLA PHASE-2, FEEDER-2	TI-OIS001A-3	990	INDUSTRIAL	Functional	100%	70	0.57			
33 kv OKHLA PHASE-2 GRID	SOKH2115	11kv FDR S/S NO.-1, OKHLA PHASE-2, FEEDER-2	TI-OIS010A-1	990	INDUSTRIAL	Functional	100%	490	0.49			
33 kv OKHLA PHASE-2 GRID	SOKH2126	11kv FDR O/G Z-BLOCK VIA -X-BLOCK OKHLA PHASE-II	TI-OIS007A-2	990	INDUSTRIAL	Functional	100%	0	0.47			
33 kv OKHLA PHASE-2 GRID	SOKH2101	11kv FDR Y-POKET OKHLA PHASE-2	TI-OIS006A-1	990	RESIDENTIAL	Functional	100%	645	0.46			
33 kv OKHLA PHASE-2 GRID	SOKH2101	11kv FDR Y-POKET OKHLA PHASE-2	TI-OIS006A-3	990	INDUSTRIAL	Functional	100%	0	0.45			
33 kv OKHLA PHASE-2 GRID	SOKH2102	11kv FDR S/S NO.-1, FEEDER-1 PHASE-2 VIA B-18/2	TI-OIS001A-2	990	RESIDENTIAL	Functional	100%	749	0.45			
33 kv OKHLA PHASE-2 GRID	SOKH2126	11kv FDR O/G Z-BLOCK VIA -X-BLOCK OKHLA PHASE-II	TI-OIS007A-3	990	INDUSTRIAL	Functional	100%	30	0.43			
33 kv OKHLA PHASE-2 GRID	SOKH2101	11kv FDR Y-POKET OKHLA PHASE-2	TI-OIS006A-2	990	INDUSTRIAL	Functional	100%	203	0.35			
33 kv OKHLA PHASE-2 GRID	SOKH2126	11kv FDR O/G Z-BLOCK VIA -X-BLOCK OKHLA PHASE-II	TI-OIS007A-4	990	INDUSTRIAL	Functional	100%	0	0.32			
33 kv OKHLA PHASE-2 GRID	SOKH2125	11kv FDR SHED NO.-8, DSIDC SC-III	TG-OIS043A-1	990	INDUSTRIAL	Functional	100%	103	0.30			
33 kv OKHLA PHASE-2 GRID	SOKH2115	11kv FDR S/S NO.-1, OKHLA PHASE-2, FEEDER-2	TI-OIS010B-2	990	INDUSTRIAL	Functional	100%	0	0.23			
33 kv OKHLA PHASE-2 GRID	SOKH2126	11kv FDR O/G Z-BLOCK VIA -X-BLOCK OKHLA PHASE-II	TI-OIS007A-1	990	INDUSTRIAL	Functional	100%	92	0.21			
33 kv OKHLA PHASE-2 GRID	SOKH2115	11kv FDR S/S NO.-1, OKHLA PHASE-2, FEEDER-2	TI-OIS010A-2	990	INDUSTRIAL	Functional	100%	0	0.16			

33 KV OKHLA PHASE-2 GRID	SOKH2102	11KV FDR S/S NO.-1, FEEDER-1 PHASE-2 VIA B-18/2	TG-OIS115A-2	630	RESIDENTIAL	Functional	100%	0	0.15			
33 KV OKHLA PHASE-2 GRID	SOKH2102	11KV FDR S/S NO.-1, FEEDER-1 PHASE-2 VIA B-18/2	530023-OIS171A-	400	RESIDENTIAL	Functional	100%	2	0.07			
33 KV OKHLA PHASE-2 GRID	SOKH2106	11KV FDR RMU AT GRID	530023-OIS181A-	630	MIXED	Functional	100%	0	0.00			
33 KV OKHLA PHASE-2 GRID	SOKH2106	11KV FDR RMU AT GRID	530GK1-OIS168A-1		RESIDENTIAL	Functional	100%	0	0.00			
33 KV BALAJI STATE GRID	SBALA113	11KV FDR OKHLA SSTN NO-80 PH-3	TG-OIS046A-1	990	INDUSTRIAL	Functional	100%	15	0.43	2.16	0.19	8.24%
33 KV BALAJI STATE GRID	SBALA111	11KV FDR G.B. PANT STAFF QUARTERS	TG-OIS036A-1	990	INDUSTRIAL	Functional	100%	16	0.27			
33 KV EAST OF KAILASH GRID	SKLSH107	11KV FDR SSTN SABJI MANDI OKHLA PHASE-3	TI-OIS026A-2	990	INDUSTRIAL	Functional	100%	0	0.27			
33 KV EAST OF KAILASH GRID	SKLSH107	11KV FDR SSTN SABJI MANDI OKHLA PHASE-3	TI-OIS026A-1	990	INDUSTRIAL	Functional	100%	28	0.20			
33 KV EAST OF KAILASH GRID	SKLSH109	11KV FDR S.B.I NO.-1	TI-OIS027A-2	990	INDUSTRIAL	Functional	100%	0	0.20			
33 KV EAST OF KAILASH GRID	SKLSH103	11KV FDR S/S NO.-6 OKHLA PHASE-3	TI-OIS029A-2	630	INDUSTRIAL	Functional	100%	11	0.20			
33 KV EAST OF KAILASH GRID	SKLSH103	11KV FDR S/S NO.-6 OKHLA PHASE-3	TI-OIS029A-1	990	INDUSTRIAL	Functional	100%	10	0.17			
33 KV EAST OF KAILASH GRID	SKLSH103	11KV FDR S/S NO.-6 OKHLA PHASE-3	TI-OIS028A-3	990	INDUSTRIAL	Functional	100%	0	0.17			
33 KV EAST OF KAILASH GRID	SKLSH109	11KV FDR S.B.I NO.-1	TI-OIS027A-1	990	INDUSTRIAL	Functional	100%	19	0.15			
33 KV NEHRU PLACE GRID	SNPHG137	11KV FDR O/G BAHAI MANDIR	TI-OIS028A-1	630	INDUSTRIAL	Functional	100%	0	0.14			
33 KV EAST OF KAILASH GRID	SKLSH103	11KV FDR S/S NO.-6 OKHLA PHASE-3	TI-OIS028A-2	990	INDUSTRIAL	Functional	100%	17	0.11			
33 KV EAST OF KAILASH GRID	SKLSH109	11KV FDR S.B.I NO.-1	TP-OIS127A-1	400	INDUSTRIAL	Functional	100%	9	0.04			
33 KV EAST OF KAILASH GRID	SKLSH109	11KV FDR S.B.I NO.-1	TI-OIS027A-3	990	INDUSTRIAL	Functional	100%	0	0.01			
33 KV V.S.N.L. GRID	SVSNL109	11KV FDR OUT GOING FEEDER-7,EPR CLY.-1	TI-GK1061A-3	1000	RESIDENTIAL	Functional	100%	145	0.77	3.03	0.11	3.40%
33 KV V.S.N.L. GRID	SVSNL127	11 KV FDR CHIRAG ENCLAVE G.K.-1	TI-GK1060A-2	990	COMMERCIAL	Functional	100%	0	0.55			
33 KV V.S.N.L. GRID	SVSNL127	11 KV FDR CHIRAG ENCLAVE G.K.-1	TI-GK1059A-1	990	RESIDENTIAL	Functional	100%	201	0.43			
33 KV V.S.N.L. GRID	SVSNL109	11KV FDR OUT GOING FEEDER-7,EPR CLY.-1	TI-GK1061A-2	1000	RESIDENTIAL	Functional	100%	198	0.41			
33 KV V.S.N.L. GRID	SVSNL109	11KV FDR OUT GOING FEEDER-7,EPR CLY.-1	TI-GK1061A-1	630	RESIDENTIAL	Functional	100%	285	0.41			
33 KV V.S.N.L. GRID	SVSNL127	11 KV FDR CHIRAG ENCLAVE G.K.-1	TI-GK1060A-1	990	COMMERCIAL	Functional	100%	239	0.36			
33 KV V.S.N.L. GRID	SVSNL127	11 KV FDR CHIRAG ENCLAVE G.K.-1	TI-GK1059A-2	630	RESIDENTIAL	Functional	100%	48	0.20			
33 KV EAST OF KAILASH GRID	SKLSH107	11KV FDR SSTN SABJI MANDI OKHLA PHASE-3	TI-OIS022A-2	990	MIXED	Functional	100%	248	0.49	1.51	0.20	11.89%
33 KV EAST OF KAILASH GRID	SKLSH106	11KV FDR FLATTED FACTORY	TI-OIS023A-1	990	MIXED	Functional	100%	371	0.48			
33 KV EAST OF KAILASH GRID	SKLSH107	11KV FDR SSTN SABJI MANDI OKHLA PHASE-3	TI-OIS022A-1	630	MIXED	Functional	100%	362	0.23			
33 KV EAST OF KAILASH GRID	SKLSH106	11KV FDR FLATTED FACTORY	TI-OIS023A-2	990	MIXED	Functional	100%	168	0.20			
33 KV EAST OF KAILASH GRID	SKLSH107	11KV FDR SSTN SABJI MANDI OKHLA PHASE-3	TG-OIS039A-1	400	MIXED	Functional	100%	87	0.17			
33 KV EAST OF KAILASH GRID	SKLSH107	11KV FDR SSTN SABJI MANDI OKHLA PHASE-3	TP-OIS080A-1	400	COMMERCIAL	Functional	100%	30	0.12			
33 KV EAST OF KAILASH GRID	SKLSH106	11KV FDR FLATTED FACTORY	TG-OIS034A-1	100	MIXED	Functional	100%	4	0.01			
33 KV OKHLA PHASE-2 GRID	SOKH2106	11KV FDR RMU AT GRID	TI-OIS019A-1	990	COMMERCIAL	Functional	100%	55	0.49	4.61	0.25	5.19%
33 KV OKHLA PHASE-2 GRID	SOKH2106	11KV FDR RMU AT GRID	TG-OIS045A-1	990	COMMERCIAL	Functional	100%	74	0.43			
33 KV OKHLA PHASE-2 GRID	SOKH2103	11KV FDR W-BLOCK OKHLA PHASE-2	TI-OIS013A-2	990	RESIDENTIAL	Functional	100%	303	0.35			
33 KV OKHLA PHASE-2 GRID	SOKH2106	11KV FDR RMU AT GRID	TG-OIS139A-1	990	COMMERCIAL	Functional	100%	9	0.35			
33 KV OKHLA PHASE-2 GRID	SOKH2106	11KV FDR RMU AT GRID	TI-OIS014A-1	990	COMMERCIAL	Functional	100%	77	0.32			
33 KV OKHLA PHASE-2 GRID	SOKH2106	11KV FDR RMU AT GRID	TI-OIS014A-2	990	COMMERCIAL	Functional	100%	4	0.28			
33 KV OKHLA PHASE-2 GRID	SOKH2103	11KV FDR W-BLOCK OKHLA PHASE-2	TI-OIS016A-1	630	COMMERCIAL	Functional	100%	81	0.23			
33 KV OKHLA PHASE-2 GRID	SOKH2115	11KV FDR S/S NO.-1, OKHLA PHASE-2, FEEDER-2	TI-OIS021A-2	630	COMMERCIAL	Functional	100%	156	0.23			
33 KV OKHLA PHASE-2 GRID	SOKH2103	11KV FDR W-BLOCK OKHLA PHASE-2	TI-OIS016A-2	630	COMMERCIAL	Functional	100%	77	0.21			
33 KV OKHLA PHASE-2 GRID	SOKH2115	11KV FDR S/S NO.-1, OKHLA PHASE-2, FEEDER-2	TI-OIS021A-1	630	COMMERCIAL	Functional	100%	112	0.18			
33 KV OKHLA PHASE-2 GRID	SOKH2103	11KV FDR W-BLOCK OKHLA PHASE-2	TI-OIS015B-1	990	COMMERCIAL	Functional	100%	0	0.17			
33 KV OKHLA PHASE-2 GRID	SOKH2103	11KV FDR W-BLOCK OKHLA PHASE-2	TI-OIS017A-1	630	RESIDENTIAL	Functional	100%	60	0.17			
33 KV OKHLA PHASE-2 GRID	SOKH2103	11KV FDR W-BLOCK OKHLA PHASE-2	TI-OIS015A-1	990	COMMERCIAL	Functional	100%	29	0.17			
220KV OKHLA TRANSCO GRID SST	TDTOG101	11KV FDR D.D.A LSC OKHLA PH.-2	TI-OIS018A-2	630	COMMERCIAL	Functional	100%	15	0.16			
33 KV OKHLA PHASE-2 GRID	SOKH2103	11KV FDR W-BLOCK OKHLA PHASE-2	TI-OIS013A-1	630	COMMERCIAL	Functional	100%	53	0.16			
220KV OKHLA TRANSCO GRID SST	TDTOG101	11KV FDR D.D.A LSC OKHLA PH.-2	TI-OIS018A-1	630	COMMERCIAL	Functional	100%	14	0.14			
33 KV OKHLA PHASE-2 GRID	SOKH2103	11KV FDR W-BLOCK OKHLA PHASE-2	TI-OIS017A-2	630	RESIDENTIAL	Functional	100%	42	0.13			
33 KV OKHLA PHASE-2 GRID	SOKH2104	11KV FDR DDA LSC OKH PHASE-2	TI-OIS161A-3	990	COMMERCIAL	Functional	100%	0	0.11			

33 kv OKHLA PHASE-2 GRID	SOKH2105	11kv FDR FIEE COMPLEX S/S NO.-1, OKHLA PH.-2	TG-OIS157A-3	630	RESIDENTIAL		Functional	100%	17	0.11			
33 kv OKHLA PHASE-2 GRID	SOKH2105	11kv FDR FIEE COMPLEX S/S NO.-1, OKHLA PH.-2	TG-OIS157A-4	630	RESIDENTIAL		Functional	100%	16	0.11			
33 kv OKHLA PHASE-2 GRID	SOKH2104	11kv FDR DDA LSC OKH PHASE-2	TI-OIS161A-1	990	COMMERCIAL		Functional	100%	4	0.09			
33 kv OKHLA PHASE-2 GRID	SOKH2105	11kv FDR FIEE COMPLEX S/S NO.-1, OKHLA PH.-2	TG-OIS157A-2	630	RESIDENTIAL		Functional	100%	5	0.07			
33 kv OKHLA PHASE-2 GRID	SOKH2104	11kv FDR DDA LSC OKH PHASE-2	TI-OIS161A-2	990	COMMERCIAL		Functional	100%	0	0.05			
33 kv OKHLA PHASE-2 GRID	SOKH2105	11kv FDR FIEE COMPLEX S/S NO.-1, OKHLA PH.-2	TG-OIS157A-1	630	RESIDENTIAL		Functional	100%	45	0.05			
33 kv OKHLA PHASE-2 GRID	SOKH2105	11kv FDR FIEE COMPLEX S/S NO.-1, OKHLA PH.-2	TG-OIS157A-5	630	RESIDENTIAL		Functional	100%	7	0.04			
33 kv OKHLA PHASE-2 GRID	SOKH2105	11kv FDR FIEE COMPLEX S/S NO.-1, OKHLA PH.-2	TG-OIS157B-1	630	RESIDENTIAL		Functional	100%	0	0.04			
33 kv OKHLA PHASE-2 GRID	SOKH2127	11kv STR 400KVA STATION TRANSFORMER	TI-STC091A-1	400	COMMERCIAL		Functional	100%	1	0.03			
33 kv V.S.N.L. GRID	SVSNL109	11kv FDR OUT GOING FEEDER-7,EPR CLY.-1	TG-GK1080A-1	990	RESIDENTIAL		Functional	100%	191	0.41	1.21	0.06	4.80%
33 kv V.S.N.L. GRID	SVSNL109	11kv FDR OUT GOING FEEDER-7,EPR CLY.-1	TI-GK1062A-2	990	RESIDENTIAL		Functional	100%	61	0.39			
33 kv V.S.N.L. GRID	SVSNL109	11kv FDR OUT GOING FEEDER-7,EPR CLY.-1	TG-GK1102A-1	990	RESIDENTIAL		Functional	100%	148	0.24			
33 kv V.S.N.L. GRID	SVSNL109	11kv FDR OUT GOING FEEDER-7,EPR CLY.-1	TI-GK1062A-1	990	RESIDENTIAL		Functional	100%	388	0.23			
33 kv NEHRU PLACE GRID	SNPHG123	11kv FDR S/S NO.-4 NHP	TG-GK1075A-1	1000	RESIDENTIAL		Functional	100%	191	0.50	1.29	0.02	1.23%
33 kv NEHRU PLACE GRID	SNPHG123	11kv FDR S/S NO.-4 NHP	TI-GK1044A-1	990	RESIDENTIAL		Functional	100%	519	0.39			
33 kv NEHRU PLACE GRID	SNPHG123	11kv FDR S/S NO.-4 NHP	TI-GK1044A-3	990	RESIDENTIAL		Functional	100%	0	0.31			
33 kv NEHRU PLACE GRID	SNPHG123	11kv FDR S/S NO.-4 NHP	TI-GK1044A-2	630	RESIDENTIAL		Functional	100%	0	0.11			
33 kv V.S.N.L. GRID	SVSNL110	11kv FDR OUT GOING FEEDER-8,R-BLOCK G.K-1	TG-GK1103A-1	990	RESIDENTIAL		Functional	100%	133	0.64	1.97	0.14	6.50%
33 kv V.S.N.L. GRID	SVSNL110	11kv FDR OUT GOING FEEDER-8,R-BLOCK G.K-1	TI-GK1058A-1	1000	RESIDENTIAL		Functional	100%	601	0.55			
33 kv V.S.N.L. GRID	SVSNL110	11kv FDR OUT GOING FEEDER-8,R-BLOCK G.K-1	TI-GK1058A-2	1000	RESIDENTIAL		Functional	100%	0	0.36			
33 kv V.S.N.L. GRID	SVSNL110	11kv FDR OUT GOING FEEDER-8,R-BLOCK G.K-1	TG-GK1087A-1	630	RESIDENTIAL		Functional	100%	161	0.29			
33 kv NEHRU PLACE GRID	SNPHG103	11kv FDR O/G R-BLOCK G.K-1	TX-GK1064A-1	990	RESIDENTIAL		Functional	100%	72	0.27			
33 kv H.U.D.C.O GRID	SHUDC102	11kv FDR O/G OLD HUDCO KIOSK	TG-GK1078A-2	990	MIXED		Functional	100%	133	0.62	2.04	0.10	4.69%
33 kv MASJID MOTH GRID	SMMOT102	11kv FDR O/G W-BLOCK G.K-1 (VIA A-BLK. NAL G.K.-1)	TG-GK1069A-1	990	MIXED		Functional	100%	203	0.46			
33 kv H.U.D.C.O GRID	SHUDC102	11kv FDR O/G OLD HUDCO KIOSK	TI-GK1057A-2	990	MIXED		Functional	100%	14	0.39			
33 kv H.U.D.C.O GRID	SHUDC102	11kv FDR O/G OLD HUDCO KIOSK	TG-GK1078A-1	990	MIXED		Functional	100%	196	0.31			
33 kv H.U.D.C.O GRID	SHUDC102	11kv FDR O/G OLD HUDCO KIOSK	TI-GK1057A-1	990	MIXED		Functional	100%	236	0.31			
33 kv V.S.N.L. GRID	SVSNL127	11 kv FDR CHIRAG ENCLAVE G.K.-1	TP-OIS162A-1	400	RESIDENTIAL		Functional	100%	18	0.03			
33 kv H.U.D.C.O GRID	SHUDC102	11kv FDR O/G OLD HUDCO KIOSK	530GK1-GK1139A	500	MIXED		Functional	100%	2	0.00			
33 kv EAST OF KAILASH GRID	SKLSH108	11kv FDR SAI PLAZA	TG-GAR017A-2	1000	COMMERCIAL		Functional	100%	565	0.77	3.77	0.20	5.04%
33 kv EAST OF KAILASH GRID	SKLSH108	11kv FDR SAI PLAZA	TG-GAR018A-3	990	COMMERCIAL		Functional	100%	296	0.71			
33 kv EAST OF KAILASH GRID	SKLSH119	11kv FDR O/G INDOOR GARI S/STN	TG-GAR050A-3	990	COMMERCIAL		Functional	100%	80	0.60			
33 kv EAST OF KAILASH GRID	SKLSH119	11kv FDR O/G INDOOR GARI S/STN	TG-GAR050A-2	990	COMMERCIAL		Functional	100%	1226	0.58			
33 kv EAST OF KAILASH GRID	SKLSH108	11kv FDR SAI PLAZA	TG-GAR017A-1	990	COMMERCIAL		Functional	100%	112	0.38			
33 kv EAST OF KAILASH GRID	SKLSH108	11kv FDR SAI PLAZA	TG-GAR018A-2	990	RESIDENTIAL		Functional	100%	694	0.33			
33 kv EAST OF KAILASH GRID	SKLSH119	11kv FDR O/G INDOOR GARI S/STN	TG-GAR050A-1	990	COMMERCIAL		Functional	100%	0	0.31			
33 kv EAST OF KAILASH GRID	SKLSH108	11kv FDR SAI PLAZA	TG-GAR018A-1	630	COMMERCIAL		Functional	100%	0	0.29			
33 kv DEFENCE COLONY GRID	SDCOL111	11kv FDR O/G VIKRAM HOTEL	TG-GAR037A-1	990	COMMERCIAL		Functional	100%	336	0.60	1.60	0.18	10.08%
33 kv H.U.D.C.O GRID	SHUDC120	11kv FDR O/G NATIONAL PARK	TG-GAR053A-1	990	COMMERCIAL		Functional	100%	409	0.52			
33 kv H.U.D.C.O GRID	SHUDC120	11kv FDR O/G NATIONAL PARK	TG-GAR043A-1	990	COMMERCIAL		Functional	100%	331	0.44			
33 kv DEFENCE COLONY GRID	SDCOL107	11kv FDR O/G LAJPAT NAGAR-4	530LN4-GAR071A	630	RESIDENTIAL		Functional	100%	80	0.21			
33 kv MASJID MOTH GRID	SMMOT102	11kv FDR O/G W-BLOCK G.K-1 (VIA A-BLK. NAL G.K.-1)	TI-GK1035A-2	990	MIXED		Functional	100%	66	0.55	2.40	0.11	4.36%
33 kv V.S.N.L. GRID	SVSNL107	11kv FDR OUT GOING FEEDER-4, E-BLOCK (K) S/STN. G.K-1	TG-GK1068A-1	990	RESIDENTIAL		Functional	100%	79	0.51			
33 kv NEHRU PLACE GRID	SNPHG114	11kv FDR O/G S-BLOCK G.K-1	TG-GK1084A-1	990	RESIDENTIAL		Functional	100%	162	0.50			
33 kv MASJID MOTH GRID	SMMOT102	11kv FDR O/G W-BLOCK G.K-1 (VIA A-BLK. NAL G.K.-1)	TI-GK1035A-1	990	MIXED		Functional	100%	358	0.49			
33 kv MASJID MOTH GRID	SMMOT102	11kv FDR O/G W-BLOCK G.K-1 (VIA A-BLK. NAL G.K.-1)	TI-GK1035A-3	990	RESIDENTIAL		Functional	100%	54	0.28			
33 kv V.S.N.L. GRID	SVSNL107	11kv FDR OUT GOING FEEDER-4, E-BLOCK (K) S/STN. G.K-1	TG-GK1128A-1	630	MIXED		Functional	100%	72	0.17			
33 kv EAST OF KAILASH GRID	SKLSH114	11kv FDR D-BLOCK EAST OF KAILASH	TG-GAR004A-1	990	RESIDENTIAL		Functional	100%	488	0.70	7.84	0.19	2.34%
33 kv LAJPAT NAGAR-3 GRID	SLJPT108	11kv FDR O/G LAJPAT NAGAR-IV	TG-GAR048A-1	990	RESIDENTIAL		Functional	100%	625	0.67			
33 kv LAJPAT NAGAR-3 GRID	SLJPT108	11kv FDR O/G LAJPAT NAGAR-IV	TG-GAR044A-2	990	RESIDENTIAL		Functional	100%	453	0.67			

33 kv DEFENCE COLONY GRID	SDCOL107	11kv FDR O/G LAJPAT NAGAR-4	TX-GAR002A-2	990	RESIDENTIAL	Functional	100%	194	0.62			
33 kv DEFENCE COLONY GRID	SDCOL107	11kv FDR O/G LAJPAT NAGAR-4	TX-GAR002A-1	990	RESIDENTIAL	Functional	100%	473	0.61			
33 kv LAJPAT NAGAR-3 GRID	SLJPT108	11kv FDR O/G LAJPAT NAGAR-IV	TI-GAR001A-1	990	RESIDENTIAL	Functional	100%	601	0.53			
33 kv EAST OF KAILASH GRID	SKLSH114	11kv FDR D-BLOCK EAST OF KAILASH	TI-GAR042A-1	990	RESIDENTIAL	Functional	100%	322	0.52			
33 kv LAJPAT NAGAR-3 GRID	SLJPT108	11kv FDR O/G LAJPAT NAGAR-IV	TI-GAR001A-2	990	RESIDENTIAL	Functional	100%	0	0.51			
33 kv LAJPAT NAGAR-3 GRID	SLJPT120	11kv FDR O/G 39 RING ROAD	TG-GAR046A-1	990	RESIDENTIAL	Functional	100%	0	0.50			
33 kv EAST OF KAILASH GRID	SKLSH104	11kv FDR E-BLOCK EAST OF KAILASH	TG-GAR024A-2	990	RESIDENTIAL	Functional	100%	337	0.49			
33 kv EAST OF KAILASH GRID	SKLSH110	11kv FDR DAYANAND KIOSK	TG-GAR046A-2	990	RESIDENTIAL	Functional	100%	773	0.48			
33 kv H.U.D.C.O GRID	SHUDC119	11kv FDR O/G SDM OFFICE VIA NURSING HOSTEL	TX-GAR003A-1	990	RESIDENTIAL	Functional	100%	262	0.43			
33 kv H.U.D.C.O GRID	SHUDC119	11kv FDR O/G SDM OFFICE VIA NURSING HOSTEL	TX-GAR003A-2	990	RESIDENTIAL	Functional	100%	0	0.39			
33 kv EAST OF KAILASH GRID	SKLSH104	11kv FDR E-BLOCK EAST OF KAILASH	TG-GAR024A-1	630	RESIDENTIAL	Functional	100%	253	0.37			
33 kv H.U.D.C.O GRID	SHUDC120	11kv FDR O/G NATIONAL PARK	530LN4-GAR073A	990	RESIDENTIAL	Functional	100%	21	0.32			
33 kv LAJPAT NAGAR-3 GRID	SLJPT108	11kv FDR O/G LAJPAT NAGAR-IV	TG-GAR044A-1	630	RESIDENTIAL	Functional	100%	45	0.23			
33 kv NEHRU PLACE GRID	SNPHG109	11kv FDR O/G D-BLOCK EAST OF KAILASH	TG-GAR034A-2	990	RESIDENTIAL	Functional	100%	231	0.77	4.68	0.37	7.24%
33 kv NEHRU PLACE GRID	SNPHG109	11kv FDR O/G D-BLOCK EAST OF KAILASH	TG-GAR034A-1	1600	RESIDENTIAL	Functional	100%	1241	0.69			
33 kv EAST OF KAILASH GRID	SKLSH108	11kv FDR SAI PLAZA	TG-GAR020A-2	990	RESIDENTIAL	Functional	100%	114	0.60			
33 kv EAST OF KAILASH GRID	SKLSH110	11kv FDR DAYANAND KIOSK	TG-GAR033A-1	990	RESIDENTIAL	Functional	100%	915	0.59			
33 kv EAST OF KAILASH GRID	SKLSH110	11kv FDR DAYANAND KIOSK	TG-GAR033A-2	990	RESIDENTIAL	Functional	100%	168	0.57			
33 kv NEHRU PLACE GRID	SNPHG109	11kv FDR O/G D-BLOCK EAST OF KAILASH	TG-GAR054A-1	990	RESIDENTIAL	Functional	100%	191	0.44			
33 kv EAST OF KAILASH GRID	SKLSH104	11kv FDR E-BLOCK EAST OF KAILASH	TG-GAR055A-2	990	RESIDENTIAL	Functional	100%	155	0.39			
33 kv EAST OF KAILASH GRID	SKLSH114	11kv FDR D-BLOCK EAST OF KAILASH	TI-GAR019A-2	990	COMMERCIAL	Functional	100%	60	0.36			
33 kv EAST OF KAILASH GRID	SKLSH108	11kv FDR SAI PLAZA	TG-GAR020A-1	990	RESIDENTIAL	Functional	100%	372	0.34			
33 kv EAST OF KAILASH GRID	SKLSH114	11kv FDR D-BLOCK EAST OF KAILASH	TI-GAR019A-1	1000	COMMERCIAL	Functional	100%	213	0.30			
33 kv EAST OF KAILASH GRID	SKLSH119	11kv FDR O/G INDOOR GARI S/STN	TK-GAR010A-2	990	RESIDENTIAL	Functional	100%	303	0.74	5.73	0.07	1.19%
33 kv NEHRU PLACE GRID	SNPHG108	11kv FDR O/G D.D.A SFS GARHI	TI-GAR011A-1	990	RESIDENTIAL	Functional	100%	347	0.68			
33 kv EAST OF KAILASH GRID	SKLSH119	11kv FDR O/G INDOOR GARI S/STN	TI-GAR011A-3	990	RESIDENTIAL	Functional	100%	251	0.63			
33 kv EAST OF KAILASH GRID	SKLSH105	11kv FDR B-BLOCK EAST OF KAILASH (VIA C-BLOCK)	TI-GAR016A-3	990	MIXED	Functional	100%	30	0.59			
33 kv EAST OF KAILASH GRID	SKLSH119	11kv FDR O/G INDOOR GARI S/STN	TK-GAR010A-1	990	RESIDENTIAL	Functional	100%	1270	0.56			
33 kv EAST OF KAILASH GRID	SKLSH119	11kv FDR O/G INDOOR GARI S/STN	TI-GAR011A-2	990	RESIDENTIAL	Functional	100%	1362	0.56			
33 kv EAST OF KAILASH GRID	SKLSH105	11kv FDR B-BLOCK EAST OF KAILASH (VIA C-BLOCK)	TI-GAR016A-2	990	MIXED	Functional	100%	1028	0.55			
33 kv LAJPAT NAGAR-3 GRID	SLJPT119	11kv FDR O/G A BLK MINI MARKET	TI-GAR009A-1	990	RESIDENTIAL	Functional	100%	348	0.54			
33 kv EAST OF KAILASH GRID	SKLSH105	11kv FDR B-BLOCK EAST OF KAILASH (VIA C-BLOCK)	TI-GAR016A-1	990	MIXED	Functional	100%	0	0.37			
33 kv EAST OF KAILASH GRID	SKLSH119	11kv FDR O/G INDOOR GARI S/STN	TG-GAR035A-1	630	RESIDENTIAL	Functional	100%	259	0.32			
33 kv NEHRU PLACE GRID	SNPHG108	11kv FDR O/G D.D.A SFS GARHI	TI-GAR012A-1	630	RESIDENTIAL	Functional	100%	260	0.26			
33 kv DEFENCE COLONY GRID	SDCOL101	11kv FDR O/G C-BLOCK, DEFENCE COLY. FDR.-1	TK-DEF040A-2	990	RESIDENTIAL	Functional	100%	177	0.61	4.10	0.30	6.75%
33 kv DEFENCE COLONY GRID	SDCOL105	11kv FDR O/G A-BLOCK DEFENCE COLONY	TK-DEF021A-2	990	MIXED	Functional	100%	249	0.55			
33 kv DEFENCE COLONY GRID	SDCOL101	11kv FDR O/G C-BLOCK, DEFENCE COLY. FDR.-1	TK-DEF040A-1	990	RESIDENTIAL	Functional	100%	231	0.52			
33 kv DEFENCE COLONY GRID	SDCOL105	11kv FDR O/G A-BLOCK DEFENCE COLONY	TK-DEF021A-1	990	MIXED	Functional	100%	235	0.47			
33 kv DEFENCE COLONY GRID	SDCOL101	11kv FDR O/G C-BLOCK, DEFENCE COLY. FDR.-1	TX-DEF036A-1	990	MIXED	Functional	100%	172	0.46			
33 kv DEFENCE COLONY GRID	SDCOL105	11kv FDR O/G A-BLOCK DEFENCE COLONY	TX-DEF109A-1	990	MIXED	Functional	100%	218	0.46			
33 kv DEFENCE COLONY GRID	SDCOL112	11kv FDR O/G C-BLOCK, DEFENCE COLY. FDR.-2	TG-DEF023A-1	990	MIXED	Functional	100%	212	0.41			
33 kv DEFENCE COLONY GRID	SDCOL101	11kv FDR O/G C-BLOCK, DEFENCE COLY. FDR.-1	TX-DEF076A-1	990	RESIDENTIAL	Functional	100%	194	0.39			
33 kv DEFENCE COLONY GRID	SDCOL105	11kv FDR O/G A-BLOCK DEFENCE COLONY	TX-DEF022A-1	990	MIXED	Functional	100%	181	0.28			
33 kv DEFENCE COLONY GRID	SDCOL105	11kv FDR O/G A-BLOCK DEFENCE COLONY	TX-DEF108A-1	990	MIXED	Functional	100%	119	0.26			
33 kv DEFENCE COLONY GRID	SDCOL114	11kv FDR O/G B-BLOCK, DEFENCE COLONY	TK-DEF035A-2	990	MIXED	Functional	100%	89	0.59	6.17	0.30	4.56%
33 kv DEFENCE COLONY GRID	SDCOL114	11kv FDR O/G B-BLOCK, DEFENCE COLONY	TX-DEF025A-1	990	MIXED	Functional	100%	196	0.54			
33 kv DEFENCE COLONY GRID	SDCOL114	11kv FDR O/G B-BLOCK, DEFENCE COLONY	TX-DEF042A-1	990	MIXED	Functional	100%	150	0.52			
33 kv DEFENCE COLONY GRID	SDCOL114	11kv FDR O/G B-BLOCK, DEFENCE COLONY	TG-DEF034A-1	990	MIXED	Functional	100%	254	0.45			
33 kv H.U.D.C.O GRID	SHUDC108	11kv FDR D-430 DEFENCE COLONY	TX-DEF038A-2	990	MIXED	Functional	100%	144	0.45			
33 kv DEFENCE COLONY GRID	SDCOL114	11kv FDR O/G B-BLOCK, DEFENCE COLONY	TX-DEF043A-1	990	MIXED	Functional	100%	189	0.43			

33 kv DEFENCE COLONY GRID	SDCOL114	11kv FDR O/G B-BLOCK, DEFENCE COLONY	TK-DEF033A-1	990	MIXED		Functional	100%	121	0.42			
33 kv DEFENCE COLONY GRID	SDCOL114	11kv FDR O/G B-BLOCK, DEFENCE COLONY	TK-DEF035A-1	990	MIXED		Functional	100%	154	0.40			
33 kv H.U.D.C.O GRID	SHUDC108	11kv FDR D-430 DEFENCE COLONY	TX-DEF038A-1	990	MIXED		Functional	100%	180	0.34			
33 kv H.U.D.C.O GRID	SHUDC108	11kv FDR D-430 DEFENCE COLONY	TX-DEF031A-2	990	MIXED		Functional	100%	144	0.33			
33 kv DEFENCE COLONY GRID	SDCOL104	11kv FDR O/G MOOLCHAND BOOSTER PUMP	TX-DEF085A-1	990	MIXED		Functional	100%	139	0.32			
33 kv DEFENCE COLONY GRID	SDCOL104	11kv FDR O/G MOOLCHAND BOOSTER PUMP	TI-DEF041A-1	630	MIXED		Functional	100%	45	0.28			
33 kv DEFENCE COLONY GRID	SDCOL104	11kv FDR O/G MOOLCHAND BOOSTER PUMP	TI-DEF037A-1	630	MIXED		Functional	100%	45	0.26			
33 kv DEFENCE COLONY GRID	SDCOL114	11kv FDR O/G B-BLOCK, DEFENCE COLONY	TK-DEF033A-2	990	MIXED		Functional	100%	169	0.25			
33 kv H.U.D.C.O GRID	SHUDC108	11kv FDR D-430 DEFENCE COLONY	TI-DEF039A-1	990	MIXED		Functional	100%	125	0.22			
33 kv H.U.D.C.O GRID	SHUDC108	11kv FDR D-430 DEFENCE COLONY	TX-DEF031A-1	990	MIXED		Functional	100%	89	0.22			
33 kv H.U.D.C.O GRID	SHUDC108	11kv FDR D-430 DEFENCE COLONY	TI-DEF039A-2	990	MIXED		Functional	100%	84	0.20			
33 kv DEFENCE COLONY GRID	SDCOL104	11kv FDR O/G MOOLCHAND BOOSTER PUMP	TI-DEF037A-2	990	MIXED		Functional	100%	115	0.17			
33 kv DEFENCE COLONY GRID	SDCOL104	11kv FDR O/G MOOLCHAND BOOSTER PUMP	TI-DEF041A-2	400	MIXED		Functional	100%	83	0.08			
33 kv NIZAMUDDIN GRID	SNZMD107	11kv FDR O/G TO JANGPURA	TG-LPN097A-1	990	RESIDENTIAL		Functional	100%	693	0.78	6.93	0.50	6.79%
33 kv NIZAMUDDIN GRID	SNZMD120	11kv FDR NIZAMUDDINE TIE-3	TG-LPN040A-1	990	RESIDENTIAL		Functional	100%	707	0.71			
33 kv NIZAMUDDIN GRID	SNZMD107	11kv FDR O/G TO JANGPURA	TG-LPN046A-2	630	RESIDENTIAL		Functional	100%	624	0.54			
33 kv NIZAMUDDIN GRID	SNZMD107	11kv FDR O/G TO JANGPURA	TG-LPN046A-1	990	RESIDENTIAL		Functional	100%	423	0.53			
33 kv NIZAMUDDIN GRID	SNZMD124	11kv FDR KASHMIRI PRAK JANGPURA	TX-LPN047A-2	990	RESIDENTIAL		Functional	100%	857	0.51			
33 kv NIZAMUDDIN GRID	SNZMD124	11kv FDR KASHMIRI PRAK JANGPURA	TX-LPN047A-1	630	RESIDENTIAL		Functional	100%	0	0.48			
33 kv NIZAMUDDIN GRID	SNZMD106	11kv FDR NIZAMUDDINE TIE-1	TG-LPN044A-1	630	RESIDENTIAL		Functional	100%	754	0.48			
33 kv NIZAMUDDIN GRID	SNZMD106	11kv FDR NIZAMUDDINE TIE-1	TG-LPN044A-2	630	RESIDENTIAL		Functional	100%	271	0.47			
33 kv NIZAMUDDIN GRID	SNZMD106	11kv FDR NIZAMUDDINE TIE-1	TG-LPN043A-2	630	RESIDENTIAL		Functional	100%	0	0.45			
33 kv NIZAMUDDIN GRID	SNZMD106	11kv FDR NIZAMUDDINE TIE-1	TG-LPN045A-1	630	RESIDENTIAL		Functional	100%	435	0.44			
33 kv NIZAMUDDIN GRID	SNZMD120	11kv FDR NIZAMUDDINE TIE-3	TI-LPN041A-1	630	RESIDENTIAL		Functional	100%	0	0.42			
33 kv NIZAMUDDIN GRID	SNZMD120	11kv FDR NIZAMUDDINE TIE-3	TI-LPN041A-2	990	RESIDENTIAL		Functional	100%	938	0.41			
33 kv NIZAMUDDIN GRID	SNZMD106	11kv FDR NIZAMUDDINE TIE-1	TG-LPN043A-1	990	RESIDENTIAL		Functional	100%	878	0.39			
33 kv NIZAMUDDIN GRID	SNZMD120	11kv FDR NIZAMUDDINE TIE-3	TG-LPN042A-2	630	RESIDENTIAL		Functional	100%	194	0.35			
33 kv NIZAMUDDIN GRID	SNZMD106	11kv FDR NIZAMUDDINE TIE-1	TG-LPN045A-2	630	RESIDENTIAL		Functional	100%	227	0.32			
33 kv NIZAMUDDIN GRID	SNZMD120	11kv FDR NIZAMUDDINE TIE-3	TG-LPN042A-1	630	RESIDENTIAL		Functional	100%	153	0.18			
33 kv KILOKARI GRID	SKKRI108	11kv FDR D.V.B COLONY SARAI KALE KHAN	TI-KIL092A-1	990	RESIDENTIAL		Functional	100%	276	0.15	0.87	0.08	7.94%
33 kv KILOKARI GRID	SKKRI110	11kv FDR SIDDHARTHA EXTN.	TP-KIL148A-1	400	COMMERCIAL		Functional	100%	10	0.15			
33 kv KILOKARI GRID	SKKRI124	11kv FDR O/G DTL	TG-KIL004A-1	400	COMMERCIAL		Functional	100%	170	0.13			
33 kv KILOKARI GRID	SKKRI108	11kv FDR D.V.B COLONY SARAI KALE KHAN	TI-KIL092A-2	630	COMMERCIAL		Functional	100%	118	0.10			
33 kv KILOKARI GRID	SKKRI124	11kv FDR O/G DTL	TG-KIL008A-1	400	COMMERCIAL		Functional	100%	11	0.09			
33 kv KILOKARI GRID	SKKRI123	11kv O/G D.J.B VIA CNG SARAI KALE KHAN	TG-KIL152A-1	400	COMMERCIAL		Functional	100%	8	0.08			
33 kv KILOKARI GRID	SKKRI110	11kv FDR SIDDHARTHA EXTN.	TG-KIL005A-1	400	COMMERCIAL		Functional	100%	36	0.08			
33 kv KILOKARI GRID	SKKRI110	11kv FDR SIDDHARTHA EXTN.	TG-KIL129A-1	400	COMMERCIAL		Functional	100%	105	0.07			
33 kv KILOKARI GRID	SKKRI110	11kv FDR SIDDHARTHA EXTN.	TP-KIL149A-1	400	COMMERCIAL		Functional	100%	14	0.05			
33 kv KILOKARI GRID	SKKRI110	11kv FDR SIDDHARTHA EXTN.	TP-KIL147A-1	100	RESIDENTIAL		Functional	100%	8	0.01			
33 kv KILOKARI GRID	SKKRI110	11kv FDR SIDDHARTHA EXTN.	TG-KIL126A-1	400	RESIDENTIAL		Functional	100%	3	0.01			
33 kv KILOKARI GRID	SKKRI108	11kv FDR D.V.B COLONY SARAI KALE KHAN	TG-KIL132A-1	100	COMMERCIAL		Functional	100%	2	0.00			
33 kv KILOKARI GRID	SKKRI110	11kv FDR SIDDHARTHA EXTN.	TG-KIL125A-1	400	RESIDENTIAL		Functional	100%	5	0.00			

33 kV KILOKARI GRID	SKKRI123	111kV O/G D.J.B VIA CNG SARAI KALE KHAN	TP-KIL140A-1	400	COMMERCIAL		Functional	100%	7	0.00	3.17	0.11	3.46%			
220kV LODHI ROAD TRANSCO GRID	TDTLR117	11kV O/G FDR UNIDO	TI-DEF005A-1	990	MIXED		Functional	100%	708	0.36						
220kV LODHI ROAD TRANSCO GRID	TDTLR104	11kV FDR LODHI COLONEY COMP. CENTER	TX-DEF008A-1	990	MIXED		Functional	100%	338	0.35						
220kV LODHI ROAD TRANSCO GRID	TDTLR104	11kV FDR LODHI COLONEY COMP. CENTER	TG-DEF009A-1	990	MIXED		Functional	100%	355	0.28						
220kV LODHI ROAD TRANSCO GRID	TDTLR117	11kV O/G FDR UNIDO	TI-DEF006A-2	630	MIXED		Functional	100%	380	0.28						
220kV LODHI ROAD TRANSCO GRID	TDTLR117	11kV O/G FDR UNIDO	TI-DEF007A-1	990	MIXED		Functional	100%	148	0.27						
220kV LODHI ROAD TRANSCO GRID	TDTLR104	11kV FDR LODHI COLONEY COMP. CENTER	TP-DEF086A-1	630	MIXED		Functional	100%	200	0.24						
220kV LODHI ROAD TRANSCO GRID	TDTLR104	11kV FDR LODHI COLONEY COMP. CENTER	TG-DEF010A-2	630	MIXED		Functional	100%	222	0.21						
220kV LODHI ROAD TRANSCO GRID	TDTLR116	11kV FDR INSTITUTIONAL AREA	TI-DEF004A-2	990	RESIDENTIAL		Functional	100%	95	0.17						
220kV LODHI ROAD TRANSCO GRID	TDTLR117	11kV O/G FDR UNIDO	TI-DEF006A-1	630	MIXED		Functional	100%	291	0.16						
220kV LODHI ROAD TRANSCO GRID	TDTLR116	11kV FDR INSTITUTIONAL AREA	TI-DEF004A-1	630	MIXED		Functional	100%	28	0.16						
220kV LODHI ROAD TRANSCO GRID	TDTLR117	11kV O/G FDR UNIDO	TI-DEF007A-2	630	MIXED		Functional	100%	353	0.14						
220kV LODHI ROAD TRANSCO GRID	TDTLR104	11kV FDR LODHI COLONEY COMP. CENTER	TG-DEF010A-1	630	MIXED		Functional	100%	202	0.13						
220kV LODHI ROAD TRANSCO GRID	TDTLR116	11kV FDR INSTITUTIONAL AREA	TI-DEF004A-3	990	MIXED		Functional	100%	74	0.13						
220kV LODHI ROAD TRANSCO GRID	TDTLR117	11kV O/G FDR UNIDO	TI-DEF005A-2	630	MIXED		Functional	100%	99	0.11						
220kV LODHI ROAD TRANSCO GRID	TDTLR104	11kV FDR LODHI COLONEY COMP. CENTER	TI-DEF011A-1	400	MIXED		Functional	100%	196	0.10						
220kV LODHI ROAD TRANSCO GRID	TDTLR116	11kV FDR INSTITUTIONAL AREA	TP-DEF020A-1	630	MIXED		Functional	100%	9	0.09						
220kV LODHI ROAD TRANSCO GRID	TDTLR104	11kV FDR LODHI COLONEY COMP. CENTER	TI-DEF011A-2	990	MIXED		Functional	100%	28	0.08						
220kV LODHI ROAD TRANSCO GRID	TDTLR104	11kV FDR LODHI COLONEY COMP. CENTER	TP-DEF111A-1	100	MIXED		Functional	100%	1	0.01						
33 kV DEFENCE COLONY GRID	SDCOL106	11kV FDR O/G D-337, DEFENCE COLONY	TI-DEF032A-2	990	RESIDENTIAL		Functional	100%	294	0.78				6.15	0.28	4.42%
33 kV DEFENCE COLONY GRID	SDCOL106	11kV FDR O/G D-337, DEFENCE COLONY	TI-DEF030A-2	990	RESIDENTIAL		Functional	100%	279	0.71						
33 kV DEFENCE COLONY GRID	SDCOL106	11kV FDR O/G D-337, DEFENCE COLONY	TI-DEF032A-1	990	RESIDENTIAL		Functional	100%	185	0.54						
33 kV DEFENCE COLONY GRID	SDCOL106	11kV FDR O/G D-337, DEFENCE COLONY	TI-DEF030A-1	990	RESIDENTIAL		Functional	100%	187	0.49						
33 kV DEFENCE COLONY GRID	SDCOL112	11kV FDR O/G C-BLOCK, DEFENCE COLY. FDR.-2	TX-DEF027A-1	990	RESIDENTIAL		Functional	100%	122	0.48						
33 kV DEFENCE COLONY GRID	SDCOL112	11kV FDR O/G C-BLOCK, DEFENCE COLY. FDR.-2	TI-DEF028A-2	990	RESIDENTIAL		Functional	100%	130	0.46						
33 kV DEFENCE COLONY GRID	SDCOL112	11kV FDR O/G C-BLOCK, DEFENCE COLY. FDR.-2	TI-DEF028A-3	990	RESIDENTIAL		Functional	100%	291	0.45						
33 kV DEFENCE COLONY GRID	SDCOL112	11kV FDR O/G C-BLOCK, DEFENCE COLY. FDR.-2	TI-DEF026A-1	990	RESIDENTIAL		Functional	100%	124	0.44						
33 kV DEFENCE COLONY GRID	SDCOL106	11kV FDR O/G D-337, DEFENCE COLONY	TG-DEF128A-1	630	RESIDENTIAL		Functional	100%	46	0.41						
33 kV DEFENCE COLONY GRID	SDCOL112	11kV FDR O/G C-BLOCK, DEFENCE COLY. FDR.-2	TX-DEF024A-1	990	RESIDENTIAL		Functional	100%	178	0.38						
33 kV DEFENCE COLONY GRID	SDCOL101	11kV FDR O/G C-BLOCK, DEFENCE COLY. FDR.-1	TI-DEF028A-1	990	RESIDENTIAL		Functional	100%	171	0.36						
33 kV DEFENCE COLONY GRID	SDCOL106	11kV FDR O/G D-337, DEFENCE COLONY	TX-DEF029A-1	990	RESIDENTIAL		Functional	100%	162	0.34						
33 kV DEFENCE COLONY GRID	SDCOL112	11kV FDR O/G C-BLOCK, DEFENCE COLY. FDR.-2	TI-DEF026A-2	630	RESIDENTIAL		Functional	100%	192	0.32						
33 kV DEFENCE COLONY GRID	SDCOL112	11kV FDR O/G C-BLOCK, DEFENCE COLY. FDR.-2	TX-DEF092A-1	990	RESIDENTIAL		Functional	100%	93	0.25						
33 kV DEFENCE COLONY GRID	SDCOL108	11kV STR 100kVA STATION TRF. NO.-1	NZ-STC072A-1	100	RESIDENTIAL		Functional	100%	1	0.01						
33 kV N.D.S.E.-2 GRID	SNDSE119	11kV FDR O/G WAZIR NAGAR GALI NO.-5	TG-DEF056A-2	1600	MIXED		Functional	100%	1475	0.96	9.32	0.17	1.79%			
33 kV N.D.S.E.-2 GRID	SNDSE119	11kV FDR O/G WAZIR NAGAR GALI NO.-5	TG-DEF056A-1	990	MIXED		Functional	100%	1021	0.89						
33 kV DEFENCE COLONY GRID	SDCOL120	11kV FDR O/G PILANJI S/STN. K.M. PUR	TG-DEF070A-2	990	COMMERCIAL		Functional	100%	1007	0.89						
33 kV N.D.S.E.-2 GRID	SNDSE111	11kV FDR O/G C-57, NDSE-1	TG-DEF069A-2	990	COMMERCIAL		Functional	100%	229	0.86						
33 kV DEFENCE COLONY GRID	SDCOL113	11kV FDR O/G BAPU PARK TRAINING CENTER	TI-DEF068A-1	990	COMMERCIAL		Functional	100%	671	0.85						
33 kV DEFENCE COLONY GRID	SDCOL120	11kV FDR O/G PILANJI S/STN. K.M. PUR	TG-DEF070A-1	990	COMMERCIAL		Functional	100%	910	0.72						
33 kV DEFENCE COLONY GRID	SDCOL113	11kV FDR O/G BAPU PARK TRAINING CENTER	TG-DEF067A-1	990	COMMERCIAL		Functional	100%	989	0.66						

33 kv DEFENCE COLONY GRID	SDCOL113	11kV FDR O/G BAPU PARK TRAINING CENTER	TI-DEF068A-2	1600	COMMERCIAL		Functional	100%	705	0.65			
33 kv N.D.S.E.-2 GRID	SNDSE111	11kV FDR O/G C-57, NDSE-1	TG-DEF069A-1	990	COMMERCIAL		Functional	100%	1002	0.64			
33 kv DEFENCE COLONY GRID	SDCOL113	11kV FDR O/G BAPU PARK TRAINING CENTER	TG-DEF067A-2	990	COMMERCIAL		Functional	100%	711	0.61			
33 kv DEFENCE COLONY GRID	SDCOL113	11kV FDR O/G BAPU PARK TRAINING CENTER	TP-DEF078A-1	630	COMMERCIAL		Functional	100%	435	0.60			
33 kv N.D.S.E.-2 GRID	SNDSE112	11kV FDR O/G B-BLOCK DEFENCE COLONY	TX-DEF062A-1	990	MIXED		Functional	100%	541	0.58			
33 kv DEFENCE COLONY GRID	SDCOL120	11kV FDR O/G PILANJI S/STN. K.M. PUR	TG-DEF074A-1	630	COMMERCIAL		Functional	100%	184	0.33			
33 kv DEFENCE COLONY GRID	SDCOL120	11kV FDR O/G PILANJI S/STN. K.M. PUR	TG-DEF070A-3	630	RESIDENTIAL		Functional	100%	0	0.23			
33 kv N.D.S.E.-2 GRID	SNDSE111	11kV FDR O/G C-57, NDSE-1	TX-DEF049A-1	990	COMMERCIAL		Functional	100%	300	0.68	4.01	0.20	4.67%
33 kv DEFENCE COLONY GRID	SDCOL121	11kV FDR OG DHARAM BHAWAN (NEW)	TG-DEF053A-2	990	MIXED	AMR	Functional	100%	184	0.66			
33 kv N.D.S.E.-2 GRID	SNDSE111	11kV FDR O/G C-57, NDSE-1	TG-DEF053B-2	990	COMMERCIAL		Functional	100%	0	0.57			
33 kv DEFENCE COLONY GRID	SDCOL110	11kV FDR O/G DHARAM BHAWAN	TI-DEF045A-1	990	MIXED		Functional	100%	202	0.53			
33 kv DEFENCE COLONY GRID	SDCOL121	11kV FDR OG DHARAM BHAWAN (NEW)	TG-DEF047A-1	630	MIXED		Functional	100%	126	0.41			
33 kv DEFENCE COLONY GRID	SDCOL110	11kV FDR O/G DHARAM BHAWAN	TI-DEF045A-2	990	INDUSTRIAL		Functional	100%	258	0.38			
33 kv N.D.S.E.-2 GRID	SNDSE103	11kV O/G G-BLOCK NDSE-1	TI-DEF045A-3	990	RESIDENTIAL		Functional	100%	317	0.30			
33 kv DEFENCE COLONY GRID	SDCOL121	11kV FDR OG DHARAM BHAWAN (NEW)	TG-DEF047A-2	630	MIXED		Functional	100%	188	0.28			
33 kv N.D.S.E.-2 GRID	SNDSE111	11kV FDR O/G C-57, NDSE-1	TK-DEF082A-1	630	COMMERCIAL		Functional	100%	154	0.22			
33 kv DEFENCE COLONY GRID	SDCOL121	11kV FDR OG DHARAM BHAWAN (NEW)	540DFC-DEF045A-1	630	MIXED		Functional	100%	0	0.11			
33 kv DEFENCE COLONY GRID	SDCOL121	11kV FDR OG DHARAM BHAWAN (NEW)	TG-DEF053A-1	630	MIXED		Functional	100%	134	0.08			
33 kv N.D.S.E.-2 GRID	SNDSE115	11kV FDR 11KV O/G I.N.A COLONY	TI-DEF060A-1	990	INDUSTRIAL		Functional	100%	305	0.30	1.62	0.05	3.04%
33 kv DEFENCE COLONY GRID	SDCOL120	11kV FDR O/G PILANJI S/STN. K.M. PUR	TI-DEF057A-1	630	INDUSTRIAL		Functional	100%	216	0.25			
33 kv N.D.S.E.-2 GRID	SNDSE115	11kV FDR 11KV O/G I.N.A COLONY	TI-DEF060A-2	990	INDUSTRIAL		Functional	100%	0	0.21			
33 kv N.D.S.E.-2 GRID	SNDSE115	11kV FDR 11KV O/G I.N.A COLONY	TI-DEF060B-2	990	INDUSTRIAL		Functional	100%	0	0.21			
33 kv N.D.S.E.-2 GRID	SNDSE115	11kV FDR 11KV O/G I.N.A COLONY	TI-DEF113A-2	630	INDUSTRIAL		Functional	100%	136	0.11			
33 kv N.D.S.E.-2 GRID	SNDSE115	11kV FDR 11KV O/G I.N.A COLONY	TI-DEF058A-1	630	INDUSTRIAL		Functional	100%	20	0.08			
33 kv N.D.S.E.-2 GRID	SNDSE115	11kV FDR 11KV O/G I.N.A COLONY	TI-DEF113A-1	630	INDUSTRIAL		Functional	100%	77	0.08			
33 kv N.D.S.E.-2 GRID	SNDSE115	11kV FDR 11KV O/G I.N.A COLONY	TI-DEF075A-1	400	INDUSTRIAL		Functional	100%	62	0.07			
220kV LODHI ROAD TRANSCO GRID	TDTLR104	11kV FDR LODHI COLONEY COMP. CENTER	TG-DEF016A-1	990	RESIDENTIAL		Functional	100%	108	0.07			
33 kv N.D.S.E.-2 GRID	SNDSE115	11kV FDR 11KV O/G I.N.A COLONY	TI-DEF112A-1	630	INDUSTRIAL		Functional	100%	60	0.07			
33 kv N.D.S.E.-2 GRID	SNDSE115	11kV FDR 11KV O/G I.N.A COLONY	TG-DEF059A-1	400	INDUSTRIAL		Functional	100%	51	0.06			
33 kv N.D.S.E.-2 GRID	SNDSE115	11kV FDR 11KV O/G I.N.A COLONY	TI-DEF112A-2	630	INDUSTRIAL		Functional	100%	40	0.05			
33 kv DEFENCE COLONY GRID	SDCOL120	11kV FDR O/G PILANJI S/STN. K.M. PUR	TI-DEF057A-2	630	INDUSTRIAL		Functional	100%	24	0.04			
33 kv N.D.S.E.-2 GRID	SNDSE115	11kV FDR 11KV O/G I.N.A COLONY	TI-DEF075A-2	400	INDUSTRIAL		Functional	100%	58	0.04			
33 kv N.D.S.E.-2 GRID	SNDSE115	11kV FDR 11KV O/G I.N.A COLONY	TI-DEF058A-2	400	INDUSTRIAL		Functional	100%	42	0.03			
33 kv NIZAMUDDIN GRID	SNZMD111	11kV FDR BIRBAL PARK	TG-LPN061A-1	990	RESIDENTIAL		Functional	100%	777	0.87	9.62	0.40	4.02%
33 kv NIZAMUDDIN GRID	SNZMD106	11kV FDR NIZAMUDDINE TIE-1	TG-LPN060A-1	990	RESIDENTIAL		Functional	100%	286	0.69			
33 kv NIZAMUDDIN GRID	SNZMD107	11kV FDR O/G TO JANGPURA	TI-LPN059A-1	990	RESIDENTIAL		Functional	100%	547	0.66			
33 kv NIZAMUDDIN GRID	SNZMD111	11kV FDR BIRBAL PARK	TK-LPN057A-2	990	RESIDENTIAL		Functional	100%	272	0.59			
33 kv NIZAMUDDIN GRID	SNZMD107	11kV FDR O/G TO JANGPURA	TI-LPN059A-3	990	RESIDENTIAL		Functional	100%	484	0.58			
33 kv NIZAMUDDIN GRID	SNZMD111	11kV FDR BIRBAL PARK	TG-LPN055A-1	990	RESIDENTIAL		Functional	100%	369	0.55			
220kV LODHI ROAD TRANSCO GRID	TDTLR102	11kV FDR DEFENCE UNDER FLYOVER (JANGPURA)	TG-LPN051A-1	630	RESIDENTIAL		Functional	100%	304	0.48			
33 kv NIZAMUDDIN GRID	SNZMD109	11kV FDR DEFENCE COLONY (NIZAMUDDINE WEST G-BLOCK)	TG-LPN056A-1	630	RESIDENTIAL		Functional	100%	79	0.40			
220kV LODHI ROAD TRANSCO GRID	TDTLR102	11kV FDR DEFENCE UNDER FLYOVER (JANGPURA)	TK-LPN049A-2	630	RESIDENTIAL		Functional	100%	282	0.40			
33 kv NIZAMUDDIN GRID	SNZMD111	11kV FDR BIRBAL PARK	TK-LPN057A-1	630	RESIDENTIAL		Functional	100%	346	0.39			
33 kv NIZAMUDDIN GRID	SNZMD107	11kV FDR O/G TO JANGPURA	TI-LPN059A-2	990	RESIDENTIAL		Functional	100%	613	0.38			

33 kv NIZAMUDDIN GRID	SNZMD109	11kv FDR DEFENCE COLONY (NIZAMUDDINE WEST G-BLOCK)	TK-LPN058A-1	630	RESIDENTIAL	Functional	100%	134	0.37			
220kv LODHI ROAD TRANSCO GRID	TDTLR102	11kv FDR DEFENCE UNDER FLYOVER (JANGPURA)	TK-LPN052A-2	990	RESIDENTIAL	Functional	100%	93	0.36			
33 kv NIZAMUDDIN GRID	SNZMD109	11kv FDR DEFENCE COLONY (NIZAMUDDINE WEST G-BLOCK)	TK-LPN058A-2	990	RESIDENTIAL	Functional	100%	636	0.36			
33 kv NIZAMUDDIN GRID	SNZMD106	11kv FDR NIZAMUDDINE TIE-1	TG-LPN060A-2	990	RESIDENTIAL	Functional	100%	353	0.34			
220kv LODHI ROAD TRANSCO GRID	TDTLR102	11kv FDR DEFENCE UNDER FLYOVER (JANGPURA)	TG-LPN054A-1	990	RESIDENTIAL	Functional	100%	181	0.34			
220kv LODHI ROAD TRANSCO GRID	TDTLR102	11kv FDR DEFENCE UNDER FLYOVER (JANGPURA)	TX-LPN050A-2	990	RESIDENTIAL	Functional	100%	317	0.33			
220kv LODHI ROAD TRANSCO GRID	TDTLR102	11kv FDR DEFENCE UNDER FLYOVER (JANGPURA)	TI-LPN048A-2	630	RESIDENTIAL	Functional	100%	186	0.32			
220kv LODHI ROAD TRANSCO GRID	TDTLR102	11kv FDR DEFENCE UNDER FLYOVER (JANGPURA)	TI-LPN053A-1	630	RESIDENTIAL	Functional	100%	106	0.30			
220kv LODHI ROAD TRANSCO GRID	TDTLR102	11kv FDR DEFENCE UNDER FLYOVER (JANGPURA)	TI-LPN048A-1	630	RESIDENTIAL	Functional	100%	170	0.27			
220kv LODHI ROAD TRANSCO GRID	TDTLR102	11kv FDR DEFENCE UNDER FLYOVER (JANGPURA)	TK-LPN052A-1	630	RESIDENTIAL	Functional	100%	257	0.27			
220kv LODHI ROAD TRANSCO GRID	TDTLR102	11kv FDR DEFENCE UNDER FLYOVER (JANGPURA)	TK-LPN049A-1	630	RESIDENTIAL	Functional	100%	155	0.26			
220kv LODHI ROAD TRANSCO GRID	TDTLR102	11kv FDR DEFENCE UNDER FLYOVER (JANGPURA)	TX-LPN050A-1	990	RESIDENTIAL	Functional	100%	174	0.24			
33 kv NIZAMUDDIN GRID	SNZMD109	11kv FDR DEFENCE COLONY (NIZAMUDDINE WEST G-BLOCK)	TG-LPN056A-2	990	RESIDENTIAL	Functional	100%	204	0.18			
220kv LODHI ROAD TRANSCO GRID	TDTLR102	11kv FDR DEFENCE UNDER FLYOVER (JANGPURA)	TI-LPN053A-2	400	RESIDENTIAL	Functional	100%	58	0.10			
33 kv KILOKARI GRID	SKKRI101	11kv FDR ASHRAM CHOWK VIA MTNL	TI-KIL001A-2	990	COMMERCIAL	Functional	100%	514	0.79	4.71	0.25	5.05%
33 kv KILOKARI GRID	SKKRI108	11kv FDR D.V.B COLONY SARAI KALE KHAN	TG-KIL141A-1	990	COMMERCIAL	Functional	100%	772	0.76			
33 kv KILOKARI GRID	SKKRI325	11kv FDR SUNLIGHT COLONY NO-2	TG-KIL056A-1	990	COMMERCIAL	Functional	100%	866	0.72			
33 kv KILOKARI GRID	SKKRI110	11kv FDR SIDDHARTHA EXTN.	TG-KIL133A-1	990	COMMERCIAL	Functional	100%	166	0.52			
33 kv KILOKARI GRID	SKKRI108	11kv FDR D.V.B COLONY SARAI KALE KHAN	TI-KIL055A-1	990	COMMERCIAL	Functional	100%	556	0.47			
33 kv KILOKARI GRID	SKKRI326	11kv FDR AMBEDKAR PARK SIDDHARTH	TG-KIL093A-1	990	COMMERCIAL	Functional	100%	479	0.43			
33 kv KILOKARI GRID	SKKRI101	11kv FDR ASHRAM CHOWK VIA MTNL	TI-KIL001A-1	990	COMMERCIAL	Functional	100%	1208	0.40			
33 kv KILOKARI GRID	SKKRI108	11kv FDR D.V.B COLONY SARAI KALE KHAN	TI-KIL055A-2	630	COMMERCIAL	Functional	100%	466	0.31			
33 kv KILOKARI GRID	SKKRI110	11kv FDR SIDDHARTHA EXTN.	TG-KIL133A-2	990	COMMERCIAL	Functional	100%	782	0.21			
33 kv KILOKARI GRID	SKKRI108	11kv FDR D.V.B COLONY SARAI KALE KHAN	TI-KIL055A-3	630	COMMERCIAL	Functional	100%	192	0.19			
33 kv KILOKARI GRID	SKKRI106	11kv FDR GENERATION COLONY	TI-KIL054A-1	630	COMMERCIAL	Functional	100%	52	0.11			
33 kv KILOKARI GRID	SKKRI106	11kv FDR GENERATION COLONY	TI-KIL054A-2	990	COMMERCIAL	Functional	100%	167	0.06			
33 kv DEFENCE COLONY GRID	SDCOL117	11kv FDR O/G KRISHNA MARKET	TI-LPN034A-1	990	MIXED	Functional	100%	466	0.83	8.37	0.24	2.83%
33 kv NIZAMUDDIN GRID	SNZMD104	11kv FDR LAJPAT NAGAR-1, FEEDER-2, I-BLOCK	TK-LPN098A-2	1600	MIXED	Functional	100%	496	0.67			
33 kv DEFENCE COLONY GRID	SDCOL117	11kv FDR O/G KRISHNA MARKET	TG-LPN001A-1	990	MIXED	Functional	100%	475	0.61			
33 kv NIZAMUDDIN GRID	SNZMD104	11kv FDR LAJPAT NAGAR-1, FEEDER-2, I-BLOCK	TX-LPN106A-1	990	MIXED	Functional	100%	647	0.54			
33 kv DEFENCE COLONY GRID	SDCOL117	11kv FDR O/G KRISHNA MARKET	TP-LPN033A-1	630	MIXED	Functional	100%	257	0.52			
33 kv NIZAMUDDIN GRID	SNZMD108	11kv FDR LAJPAT NAGAR 1, FEEDER NO.-1	TG-LPN032A-2	990	MIXED	Functional	100%	362	0.52			
33 kv NIZAMUDDIN GRID	SNZMD108	11kv FDR LAJPAT NAGAR 1, FEEDER NO.-1	TG-LPN032A-1	990	MIXED	Functional	100%	755	0.51			
33 kv DEFENCE COLONY GRID	SDCOL117	11kv FDR O/G KRISHNA MARKET	TI-LPN034A-2	990	MIXED	Functional	100%	493	0.50			
33 kv LAJPAT NAGAR-3 GRID	SLJPT116	11kv FDR O/G F- BLOCK LAJPAT NAGAR NO-2	TK-LPN025A-2	990	MIXED	Functional	100%	597	0.49			
33 kv LAJPAT NAGAR-3 GRID	SLJPT116	11kv FDR O/G F- BLOCK LAJPAT NAGAR NO-2	TG-LPN037A-1	630	MIXED	Functional	100%	334	0.44			
33 kv LAJPAT NAGAR-3 GRID	SLJPT116	11kv FDR O/G F- BLOCK LAJPAT NAGAR NO-2	TX-LPN036A-1	990	MIXED	Functional	100%	580	0.44			
33 kv DEFENCE COLONY GRID	SDCOL117	11kv FDR O/G KRISHNA MARKET	TG-LPN035A-1	990	MIXED	Functional	100%	321	0.39			
33 kv DEFENCE COLONY GRID	SDCOL117	11kv FDR O/G KRISHNA MARKET	TP-LPN033A-2	990	MIXED	Functional	100%	591	0.38			
33 kv LAJPAT NAGAR-3 GRID	SLJPT116	11kv FDR O/G F- BLOCK LAJPAT NAGAR NO-2	TK-LPN025A-1	990	MIXED	Functional	100%	111	0.24			

33 kv NIZAMUDDIN GRID	SNZMD104	11kv FDR LAJPAT NAGAR-1, FEEDER-2, I-BLOCK	TG-LPN106A-2	630	RESIDENTIAL		Functional	100%	0	0.24			
33 kv NIZAMUDDIN GRID	SNZMD101	11kv FDR O/G KILOKARI SEWAGE	TP-LPN114A-2	630	MIXED		Functional	100%	436	0.24			
33 kv LAJPAT NAGAR-3 GRID	SLJPT116	11kv FDR O/G F- BLOCK LAJPAT NAGAR NO-2	TG-LPN036A-2	630	RESIDENTIAL		Functional	100%	0	0.22			
33 kv NIZAMUDDIN GRID	SNZMD101	11kv FDR O/G KILOKARI SEWAGE	TP-LPN114A-1	400	MIXED		Functional	100%	126	0.22			
33 kv NIZAMUDDIN GRID	SNZMD108	11kv FDR LAJPAT NAGAR 1, FEEDER NO.-1	TG-LPN032A-3	630	RESIDENTIAL		Functional	100%	0	0.20			
33 kv NIZAMUDDIN GRID	SNZMD101	11kv FDR O/G KILOKARI SEWAGE	TI-LPN039A-2	630	MIXED		Functional	100%	105	0.17			
33 kv NIZAMUDDIN GRID	SNZMD104	11kv FDR LAJPAT NAGAR-1, FEEDER-2, I-BLOCK	TK-LPN098A-1	630	MIXED		Functional	100%	250	0.15			
33 kv NIZAMUDDIN GRID	SNZMD101	11kv FDR O/G KILOKARI SEWAGE	TI-LPN039A-1	400	MIXED		Functional	100%	255	0.09			
33 kv LAJPAT NAGAR-3 GRID	SLJPT105	11kv FDR O/G LAJPAT NAGAR-3 MAIN FDR-1	TG-LPN101A-1	990	RESIDENTIAL		Functional	100%	567	0.81	15.37	0.91	5.58%
33 kv LAJPAT NAGAR-3 GRID	SLJPT117	11kv FDR O/G TIKONA PARK LAJPAT NAGAR NO - 2	TK-LPN023A-2	990	RESIDENTIAL		Functional	100%	362	0.77			
33 kv NIZAMUDDIN GRID	SNZMD114	11kv FDR LAJPAT NAGAR-2, FDR.-3	TG-LPN026A-2	1000	RESIDENTIAL		Functional	100%	58	0.74			
33 kv NIZAMUDDIN GRID	SNZMD114	11kv FDR LAJPAT NAGAR-2, FDR.-3	TI-LPN016A-2	1600	RESIDENTIAL		Functional	100%	332	0.72			
33 kv DEFENCE COLONY GRID	SDCOL117	11kv FDR O/G KRISHNA MARKET	TX-LPN024A-1	990	RESIDENTIAL		Functional	100%	559	0.71			
33 kv LAJPAT NAGAR-3 GRID	SLJPT104	11kv FDR O/G M-BLOCK LAJPAT NAGAR-2	TG-LPN012A-2	990	RESIDENTIAL		Functional	100%	400	0.69			
33 kv LAJPAT NAGAR-3 GRID	SLJPT117	11kv FDR O/G TIKONA PARK LAJPAT NAGAR NO - 2	TK-LPN023A-1	990	RESIDENTIAL		Functional	100%	234	0.68			
33 kv LAJPAT NAGAR-3 GRID	SLJPT114	11kv FDR O/G KASTURBA NIKETAN (HVDS)	NZ-HVD001A-1	1175	MIXED		Functional	100%	740	0.68			
33 kv LAJPAT NAGAR-3 GRID	SLJPT104	11kv FDR O/G M-BLOCK LAJPAT NAGAR-2	TG-LPN011A-1	990	RESIDENTIAL		Functional	100%	197	0.60			
33 kv LAJPAT NAGAR-3 GRID	SLJPT118	11kv FDR O/G MCD DISPENSARY LPN-2	TX-LPN015A-1	990	RESIDENTIAL		Functional	100%	443	0.56			
33 kv LAJPAT NAGAR-3 GRID	SLJPT118	11kv FDR O/G MCD DISPENSARY LPN-2	TX-LPN030A-2	990	RESIDENTIAL		Functional	100%	221	0.55			
33 kv NIZAMUDDIN GRID	SNZMD108	11kv FDR LAJPAT NAGAR 1, FEEDER NO.-1	TI-LPN016A-3	990	RESIDENTIAL		Functional	100%	359	0.53			
33 kv LAJPAT NAGAR-3 GRID	SLJPT118	11kv FDR O/G MCD DISPENSARY LPN-2	TI-LPN031A-3	990	RESIDENTIAL		Functional	100%	554	0.52			
33 kv LAJPAT NAGAR-3 GRID	SLJPT104	11kv FDR O/G M-BLOCK LAJPAT NAGAR-2	TK-LPN014A-2	990	RESIDENTIAL		Functional	100%	230	0.52			
33 kv LAJPAT NAGAR-3 GRID	SLJPT104	11kv FDR O/G M-BLOCK LAJPAT NAGAR-2	TG-LPN013A-1	990	RESIDENTIAL		Functional	100%	430	0.50			
33 kv LAJPAT NAGAR-3 GRID	SLJPT112	11kv FDR O/G ALANKAR CINEMA	TG-LPN029A-3	990	RESIDENTIAL		Functional	100%	77	0.50			
33 kv NIZAMUDDIN GRID	SNZMD108	11kv FDR LAJPAT NAGAR 1, FEEDER NO.-1	TI-LPN016A-1	990	RESIDENTIAL		Functional	100%	358	0.49			
33 kv LAJPAT NAGAR-3 GRID	SLJPT118	11kv FDR O/G MCD DISPENSARY LPN-2	TI-LPN031A-1	990	RESIDENTIAL		Functional	100%	176	0.48			
33 kv LAJPAT NAGAR-3 GRID	SLJPT118	11kv FDR O/G MCD DISPENSARY LPN-2	TX-LPN030A-1	990	RESIDENTIAL		Functional	100%	180	0.47			
33 kv LAJPAT NAGAR-3 GRID	SLJPT117	11kv FDR O/G TIKONA PARK LAJPAT NAGAR NO - 2	TK-LPN023A-3	990	RESIDENTIAL		Functional	100%	755	0.45			
33 kv LAJPAT NAGAR-3 GRID	SLJPT118	11kv FDR O/G MCD DISPENSARY LPN-2	TI-LPN031A-2	1600	RESIDENTIAL		Functional	100%	0	0.45			
33 kv LAJPAT NAGAR-3 GRID	SLJPT112	11kv FDR O/G ALANKAR CINEMA	TG-LPN100A-1	990	RESIDENTIAL		Functional	100%	227	0.45			
33 kv LAJPAT NAGAR-3 GRID	SLJPT112	11kv FDR O/G ALANKAR CINEMA	TG-LPN029A-1	990	RESIDENTIAL		Functional	100%	302	0.42			
33 kv NIZAMUDDIN GRID	SNZMD114	11kv FDR LAJPAT NAGAR-2, FDR.-3	TG-LPN026A-1	1000	RESIDENTIAL		Functional	100%	221	0.41			
33 kv LAJPAT NAGAR-3 GRID	SLJPT112	11kv FDR O/G ALANKAR CINEMA	TG-LPN029A-2	990	RESIDENTIAL		Functional	100%	288	0.41			
33 kv LAJPAT NAGAR-3 GRID	SLJPT104	11kv FDR O/G M-BLOCK LAJPAT NAGAR-2	TG-LPN012A-1	630	RESIDENTIAL		Functional	100%	258	0.36			
33 kv LAJPAT NAGAR-3 GRID	SLJPT104	11kv FDR O/G M-BLOCK LAJPAT NAGAR-2	TK-LPN014A-1	990	RESIDENTIAL		Functional	100%	293	0.36			
33 kv LAJPAT NAGAR-3 GRID	SLJPT118	11kv FDR O/G MCD DISPENSARY LPN-2	TX-LPN015A-2	990	RESIDENTIAL		Functional	100%	132	0.36			
33 kv LAJPAT NAGAR-3 GRID	SLJPT118	11kv FDR O/G MCD DISPENSARY LPN-2	TX-LPN030A-3	990	RESIDENTIAL		Functional	100%	237	0.30			
33 kv DEFENCE COLONY GRID	SDCOL117	11kv FDR O/G KRISHNA MARKET	TG-LPN024A-2	630	RESIDENTIAL		Functional	100%	0	0.27			
33 kv LAJPAT NAGAR-3 GRID	SLJPT118	11kv FDR O/G MCD DISPENSARY LPN-2	TI-LPN031A-4	630	RESIDENTIAL		Functional	100%	168	0.27			
33 kv LAJPAT NAGAR-3 GRID	SLJPT104	11kv FDR O/G M-BLOCK LAJPAT NAGAR-2	TP-LPN087A-1	400	RESIDENTIAL		Functional	100%	65	0.16			
33 kv LAJPAT NAGAR-3 GRID	SLJPT104	11kv FDR O/G M-BLOCK LAJPAT NAGAR-2	540LN2-LPN134A-	400	RESIDENTIAL		Functional	100%	1	0.07			
33 kv DEFENCE COLONY GRID	SDCOL109	11kv FDR O/G LAJPAT NAGAR-3	TG-LPN019A-1	990	MIXED		Functional	100%	219	0.71	7.95	0.39	4.66%
33 kv DEFENCE COLONY GRID	SDCOL109	11kv FDR O/G LAJPAT NAGAR-3	TG-LPN020A-1	990	MIXED		Functional	100%	244	0.64			
33 kv DEFENCE COLONY GRID	SDCOL109	11kv FDR O/G LAJPAT NAGAR-3	TG-LPN019A-2	990	MIXED		Functional	100%	279	0.63			

33 kV LAJPAT NAGAR-3 GRID	SLJPT107	11kV FDR O/G LAJPAT NAGAR-3 MAIN FDR-2	TX-LPN038A-1	990	MIXED		Functional	100%	127	0.57			
33 kV LAJPAT NAGAR-3 GRID	SLJPT105	11kV FDR O/G LAJPAT NAGAR-3 MAIN FDR-1	TG-LPN027A-2	990	MIXED		Functional	100%	206	0.56			
33 kV LAJPAT NAGAR-3 GRID	SLJPT103	11kV FDR O/G 6-FIROZ GANDHI ROAD	TK-LPN018A-1	990	MIXED		Functional	100%	161	0.55			
33 kV LAJPAT NAGAR-3 GRID	SLJPT107	11kV FDR O/G LAJPAT NAGAR-3 MAIN FDR-2	TI-LPN028A-1	990	MIXED		Functional	100%	247	0.54			
33 kV LAJPAT NAGAR-3 GRID	SLJPT105	11kV FDR O/G LAJPAT NAGAR-3 MAIN FDR-1	TG-LPN027A-1	630	MIXED		Functional	100%	234	0.50			
33 kV LAJPAT NAGAR-3 GRID	SLJPT107	11kV FDR O/G LAJPAT NAGAR-3 MAIN FDR-2	TI-LPN028A-3	1000	MIXED		Functional	100%	160	0.50			
33 kV DEFENCE COLONY GRID	SDCOL109	11kV FDR O/G LAJPAT NAGAR-3	540LN2-LPN017A-	990	RESIDENTIAL		Functional	100%	177	0.50			
33 kV LAJPAT NAGAR-3 GRID	SLJPT103	11kV FDR O/G 6-FIROZ GANDHI ROAD	TK-LPN018A-2	990	MIXED		Functional	100%	182	0.45			
33 kV LAJPAT NAGAR-3 GRID	SLJPT105	11kV FDR O/G LAJPAT NAGAR-3 MAIN FDR-1	TI-LPN028A-2	990	MIXED		Functional	100%	173	0.45			
33 kV DEFENCE COLONY GRID	SDCOL109	11kV FDR O/G LAJPAT NAGAR-3	540LN2-LPN017A-	990	RESIDENTIAL		Functional	100%	214	0.44			
33 kV DEFENCE COLONY GRID	SDCOL109	11kV FDR O/G LAJPAT NAGAR-3	TG-LPN020A-2	630	MIXED		Functional	100%	222	0.43			
33 kV LAJPAT NAGAR-3 GRID	SLJPT107	11kV FDR O/G LAJPAT NAGAR-3 MAIN FDR-2	TG-LPN021A-1	630	MIXED		Functional	100%	170	0.30			
33 kV LAJPAT NAGAR-3 GRID	SLJPT107	11kV FDR O/G LAJPAT NAGAR-3 MAIN FDR-2	TG-LPN021A-2	630	MIXED		Functional	100%	192	0.28			
33 kV LAJPAT NAGAR-3 GRID	SLJPT103	11kV FDR O/G 6-FIROZ GANDHI ROAD	TG-LPN018A-2	630	RESIDENTIAL		Functional	100%	0	0.27			
33 kV LAJPAT NAGAR-3 GRID	SLJPT106	11kV STR 100kVA STATION TRF. NO.-1	NZ-STC082A-1	100	RESIDENTIAL		Functional	100%	1	0.01			
220kV LODHI ROAD TRANSCO GRID	TDTLR117	11kV O/G FDR UNIDO	TG-DEF001A-2	990	INDUSTRIAL		Functional	100%	364	0.29	2.13	0.25	10.46%
220kV LODHI ROAD TRANSCO GRID	TDTLR117	11kV O/G FDR UNIDO	TG-DEF001A-1	990	INDUSTRIAL		Functional	100%	549	0.29			
220kV LODHI ROAD TRANSCO GRID	TDTLR117	11kV O/G FDR UNIDO	TI-DEF003A-1	630	INDUSTRIAL		Functional	100%	375	0.26			
33 kV N.D.S.E.-2 GRID	SNDSE118	11kV FDR 11KV O/G TYAGARAJ STADIUM	540LDR-DEF141A-	990	MIXED		Functional	100%	0	0.19			
33 kV N.D.S.E.-2 GRID	SNDSE118	11kV FDR 11KV O/G TYAGARAJ STADIUM	540LDR-DEF141A-	990	MIXED		Functional	100%	0	0.17			
33 kV NIZAMUDDIN GRID	SNZMD109	11kV FDR DEFENCE COLONY (NIZAMUDDINE WEST G-BLOCK)	TG-DEF087A-1	630	INDUSTRIAL	AMR	Functional	100%	5	0.16			
220kV LODHI ROAD TRANSCO GRID	TDTLR117	11kV O/G FDR UNIDO	TI-DEF003A-2	630	INDUSTRIAL		Functional	100%	363	0.13			
33 kV N.D.S.E.-2 GRID	SNDSE118	11kV FDR 11KV O/G TYAGARAJ STADIUM	540LDR-DEF141A-	990	RESIDENTIAL		Functional	100%	555	0.13			
220kV LODHI ROAD TRANSCO GRID	TDTLR107	11kV FDR N.B.C.C EAST BLOCK	TG-DEF080A-2	630	INDUSTRIAL		Functional	100%	2	0.10			
220kV LODHI ROAD TRANSCO GRID	TDTLR107	11kV FDR N.B.C.C EAST BLOCK	TG-DEF080A-1	630	INDUSTRIAL		Functional	100%	5	0.10			
220kV LODHI ROAD TRANSCO GRID	TDTLR111	11kV FDR N.B.C.C	TP-DEF018A-1	400	INDUSTRIAL		Functional	100%	15	0.10			
220kV LODHI ROAD TRANSCO GRID	TDTLR107	11kV FDR N.B.C.C EAST BLOCK	TG-DEF081A-2	630	INDUSTRIAL		Functional	100%	11	0.10			
220kV LODHI ROAD TRANSCO GRID	TDTLR116	11kV FDR INSTITUTIONAL AREA	TG-DEF114A-1	400	INDUSTRIAL		Functional	100%	26	0.10			
33 kV N.D.S.E.-2 GRID	SNDSE118	11kV FDR 11KV O/G TYAGARAJ STADIUM	540LDR-DEF141A-	990	MIXED		Functional	100%	0	0.08			
33 kV N.D.S.E.-2 GRID	SNDSE118	11kV FDR 11KV O/G TYAGARAJ STADIUM	540LDR-DEF141A-	990	RESIDENTIAL		Functional	100%	88	0.08			
220kV LODHI ROAD TRANSCO GRID	TDTLR107	11kV FDR N.B.C.C EAST BLOCK	TG-DEF081A-1	630	INDUSTRIAL		Functional	100%	16	0.05			
220kV LODHI ROAD TRANSCO GRID	TDTLR113	11kV FDR DEFENCE COLONY VIA NARULA SHIRAJ	TP-DEF120A-1	100	RESIDENTIAL	AMR	Functional	100%	6	0.01			
33kV A.I.I.M.S GRID SUB STATION (N.D.M.C)	SAIMS104	11kV FDR KASHMIRI MARKET INA (BRPL FEEDER)	540LDR-DEF140A-	400	RESIDENTIAL		Functional	100%	57	0.01			
220kV LODHI ROAD TRANSCO GRID	TDTLR109	11kV FDR TELEPHONE EXCHANGE	TP-DEF019A-1	400	INDUSTRIAL		Functional	100%	5	0.01			
33 kV N.D.S.E.-2 GRID	SNDSE118	11kV FDR 11KV O/G TYAGARAJ STADIUM	540LDR-DEF141A-	990	MIXED		Functional	100%	0	0.00			
33 kV EXHIBITION GROUND - 2 GRID	SEXN2112	11kV FDR BHAIROD ROAD	TP-KILO06A-1	400	RESIDENTIAL		Functional	100%	11	0.36	0.41	0.00	1.20%
33 kV EXHIBITION GROUND - 2 GRID	SEXN2112	11kV FDR BHAIROD ROAD	TG-KIL120A-1	400	RESIDENTIAL		Functional	100%	9	0.02			
33 kV EXHIBITION GROUND - 2 GRID	SEXN2112	11kV FDR BHAIROD ROAD	TP-KIL127A-1	400	RESIDENTIAL		Functional	100%	7	0.02			
33 kV EXHIBITION GROUND - 2 GRID	SEXN2112	11kV FDR BHAIROD ROAD	TG-KIL122A-1	400	RESIDENTIAL		Functional	100%	3	0.01			
33 kV NIZAMUDDIN GRID	SNZMD105	11kV FDR O/G NIZAMUDDINE TIE-II	TG-LPN069A-2	990	RESIDENTIAL		Functional	100%	1135	0.84	3.89	0.04	1.03%
33 kV NIZAMUDDIN GRID	SNZMD105	11kV FDR O/G NIZAMUDDINE TIE-II	TK-LPN068A-1	990	RESIDENTIAL		Functional	100%	499	0.41			

33 kv NIZAMUDDIN GRID	SNZMD105	11kv FDR O/G NIZAMUDDINE TIE-II	TG-LPN069A-1	630	RESIDENTIAL		Functional	100%	426	0.37			
33 kv NIZAMUDDIN GRID	SNZMD110	11kv FDR O/G FEEDER SUNDER NAGAR	TG-LPN078A-1	990	RESIDENTIAL		Functional	100%	67	0.27			
33 kv NIZAMUDDIN GRID	SNZMD110	11kv FDR O/G FEEDER SUNDER NAGAR	TX-LPN074A-1	990	RESIDENTIAL		Functional	100%	37	0.27			
33 kv NIZAMUDDIN GRID	SNZMD110	11kv FDR O/G FEEDER SUNDER NAGAR	TX-LPN077A-1	990	RESIDENTIAL		Functional	100%	69	0.25			
33 kv ITPO GRID, PRAGATI MAIDAN	SITPO109	11kv FDR OG SUNDER NAGAR	TI-LPN079A-1	630	RESIDENTIAL		Functional	100%	117	0.21			
33 kv NIZAMUDDIN GRID	SNZMD105	11kv FDR O/G NIZAMUDDINE TIE-II	TG-LPN068A-2	630	RESIDENTIAL		Functional	100%	230	0.21			
33 kv ITPO GRID, PRAGATI MAIDAN	SITPO109	11kv FDR OG SUNDER NAGAR	TI-LPN073A-2	990	RESIDENTIAL		Functional	100%	129	0.21			
33 kv NIZAMUDDIN GRID	SNZMD110	11kv FDR O/G FEEDER SUNDER NAGAR	TX-LPN076A-1	990	RESIDENTIAL		Functional	100%	61	0.19			
33 kv NIZAMUDDIN GRID	SNZMD110	11kv FDR O/G FEEDER SUNDER NAGAR	TK-LPN075A-2	990	RESIDENTIAL		Functional	100%	38	0.18			
33 kv EXHIBITION GROUND - 1 GRID	SEXN2112	11KV FDR O/G SUNDER NAGAR	TI-LPN073B-2	990	RESIDENTIAL		Functional	100%	0	0.15			
33 kv NIZAMUDDIN GRID	SNZMD110	11kv FDR O/G FEEDER SUNDER NAGAR	TI-LPN073A-1	630	RESIDENTIAL		Functional	100%	57	0.15			
33 kv NIZAMUDDIN GRID	SNZMD110	11kv FDR O/G FEEDER SUNDER NAGAR	TK-LPN075A-1	630	RESIDENTIAL		Functional	100%	16	0.14			
33 kv ITPO GRID, PRAGATI MAIDAN	SITPO109	11KV FDR OG SUNDER NAGAR	TI-LPN079A-2	500	RESIDENTIAL		Functional	100%	47	0.10			
33 kv DEFENCE COLONY GRID	SDCOL110	11kv FDR O/G DHARAM BHAWAN	TG-DEF048A-2	990	INDUSTRIAL		Functional	100%	399	0.52	4.85	0.43	8.13%
33 kv N.D.S.E.-2 GRID	SNDSE103	11KV O/G G-BLOCK NDSE-1	TX-DEF044A-1	990	INDUSTRIAL		Functional	100%	144	0.44			
33 kv N.D.S.E.-2 GRID	SNDSE112	11kv FDR O/G B-BLOCK DEFENCE COLONY	TX-DEF077A-1	990	MIXED		Functional	100%	160	0.43			
33 kv N.D.S.E.-2 GRID	SNDSE103	11KV O/G G-BLOCK NDSE-1	TX-DEF110A-1	990	INDUSTRIAL		Functional	100%	57	0.42			
33kv A.I.I.M.S GRID SUB STATION (N.D.M.C)	SAIMS101	11kv FDR J-BLOCK N.D.S.E-2(BRPL FEEDER)	TI-DEF046A-2	990	INDUSTRIAL		Functional	100%	155	0.40			
33 kv N.D.S.E.-2 GRID	SNDSE112	11kv FDR O/G B-BLOCK DEFENCE COLONY	TG-DEF051A-1	990	MIXED		Functional	100%	77	0.33			
33 kv N.D.S.E.-2 GRID	SNDSE112	11kv FDR O/G B-BLOCK DEFENCE COLONY	TG-DEF051A-2	990	MIXED		Functional	100%	121	0.31			
33 kv DEFENCE COLONY GRID	SDCOL121	11kv FDR OG DHARAM BHAWAN (NEW)	TX-DEF090A-1	990	INDUSTRIAL		Functional	100%	119	0.31			
33kv A.I.I.M.S GRID SUB STATION (N.D.M.C)	SAIMS101	11kv FDR J-BLOCK N.D.S.E-2(BRPL FEEDER)	TG-DEF054A-1	990	INDUSTRIAL		Functional	100%	25	0.28			
33kv A.I.I.M.S GRID SUB STATION (N.D.M.C)	SAIMS101	11kv FDR J-BLOCK N.D.S.E-2(BRPL FEEDER)	TI-DEF046A-3	990	INDUSTRIAL		Functional	100%	94	0.27			
33 kv DEFENCE COLONY GRID	SDCOL110	11kv FDR O/G DHARAM BHAWAN	TG-DEF048A-1	990	INDUSTRIAL		Functional	100%	109	0.26			
33kv A.I.I.M.S GRID SUB STATION (N.D.M.C)	SAIMS101	11kv FDR J-BLOCK N.D.S.E-2(BRPL FEEDER)	TG-DEF054A-2	630	INDUSTRIAL		Functional	100%	134	0.25			
33 kv N.D.S.E.-2 GRID	SNDSE103	11KV O/G G-BLOCK NDSE-1	TX-DEF050A-1	990	INDUSTRIAL		Functional	100%	31	0.24			
33kv A.I.I.M.S GRID SUB STATION (N.D.M.C)	SAIMS101	11kv FDR J-BLOCK N.D.S.E-2(BRPL FEEDER)	TI-DEF046A-1	990	INDUSTRIAL		Functional	100%	84	0.19			
33kv A.I.I.M.S GRID SUB STATION (N.D.M.C)	SAIMS101	11kv FDR J-BLOCK N.D.S.E-2(BRPL FEEDER)	TP-DEF089A-1	400	INDUSTRIAL		Functional	100%	152	0.18			
33kv A.I.I.M.S GRID SUB STATION (N.D.M.C)	SAIMS101	11kv FDR J-BLOCK N.D.S.E-2(BRPL FEEDER)	TP-DEF052A-1	400	INDUSTRIAL		Functional	100%	77	0.17			
33 kv N.D.S.E.-2 GRID	SNDSE103	11KV O/G G-BLOCK NDSE-1	TX-DEF050A-2	990	INDUSTRIAL		Functional	100%	42	0.16			
33kv A.I.I.M.S GRID SUB STATION (N.D.M.C)	SAIMS101	11kv FDR J-BLOCK N.D.S.E-2(BRPL FEEDER)	TP-DEF088A-1	400	INDUSTRIAL		Functional	100%	135	0.10			
33 kv LAJPAT NAGAR-3 GRID	SLJPT110	11kv FDR O/G VIMHANS HOSPITAL NEHRU NGR.	TG-LPN113A-1	630	COMMERCIAL		Functional	100%	1219	0.63	3.31	0.17	4.83%
33 kv LAJPAT NAGAR-3 GRID	SLJPT110	11kv FDR O/G VIMHANS HOSPITAL NEHRU NGR.	TK-LPN007A-1	990	COMMERCIAL		Functional	100%	880	0.60			
33 kv LAJPAT NAGAR-3 GRID	SLJPT110	11kv FDR O/G VIMHANS HOSPITAL NEHRU NGR.	TG-LPN006A-1	630	COMMERCIAL		Functional	100%	443	0.46			
33 kv LAJPAT NAGAR-3 GRID	SLJPT110	11kv FDR O/G VIMHANS HOSPITAL NEHRU NGR.	TG-LPN008A-1	630	COMMERCIAL		Functional	100%	280	0.41			
33 kv LAJPAT NAGAR-3 GRID	SLJPT110	11kv FDR O/G VIMHANS HOSPITAL NEHRU NGR.	TK-LPN007A-2	630	COMMERCIAL		Functional	100%	388	0.40			
33 kv LAJPAT NAGAR-3 GRID	SLJPT110	11kv FDR O/G VIMHANS HOSPITAL NEHRU NGR.	TI-LPN009A-1	630	COMMERCIAL		Functional	100%	661	0.39			

33 kv LAJPAT NAGAR-3 GRID	SLJPT110	11kv FDR O/G VIMHANS HOSPITAL NEHRU NGR.	TG-LPN008A-2	630	COMMERCIAL		Functional	100%	315	0.24			
33 kv LAJPAT NAGAR-3 GRID	SLJPT110	11kv FDR O/G VIMHANS HOSPITAL NEHRU NGR.	TG-LPN120A-1	630	COMMERCIAL		Functional	100%	167	0.18			
33 kv LAJPAT NAGAR-3 GRID	SLJPT110	11kv FDR O/G VIMHANS HOSPITAL NEHRU NGR.	TG-LPN010A-1	630	COMMERCIAL		Functional	100%	221	0.17			
33 kv NIZAMUDDIN GRID	SNZMD105	11kv FDR O/G NIZAMUDDINE TIE-II	TG-LPN067A-2	990	RESIDENTIAL		Functional	100%	560	0.88	5.89	0.32	5.20%
33 kv NIZAMUDDIN GRID	SNZMD109	11kv FDR DEFENCE COLONY (NIZAMUDDINE WEST G-BLOCK)	TG-LPN071A-1	990	RESIDENTIAL		Functional	100%	584	0.77			
33 kv NIZAMUDDIN GRID	SNZMD106	11kv FDR NIZAMUDDINE TIE-1	TX-LPN062A-1	990	RESIDENTIAL		Functional	100%	149	0.64			
33 kv NIZAMUDDIN GRID	SNZMD105	11kv FDR O/G NIZAMUDDINE TIE-II	TX-LPN062A-2	990	RESIDENTIAL		Functional	100%	524	0.57			
33 kv NIZAMUDDIN GRID	SNZMD112	11kv FDR C-BLOCK, NZD EAST	TX-LPN063A-2	990	RESIDENTIAL		Functional	100%	266	0.53			
33 kv NIZAMUDDIN GRID	SNZMD112	11kv FDR C-BLOCK, NZD EAST	TX-LPN063A-1	990	RESIDENTIAL		Functional	100%	125	0.45			
33 kv NIZAMUDDIN GRID	SNZMD112	11kv FDR C-BLOCK, NZD EAST	TX-LPN065A-1	990	RESIDENTIAL		Functional	100%	267	0.44			
33 kv NIZAMUDDIN GRID	SNZMD112	11kv FDR C-BLOCK, NZD EAST	TK-LPN066A-2	990	RESIDENTIAL		Functional	100%	167	0.39			
33 kv NIZAMUDDIN GRID	SNZMD106	11kv FDR NIZAMUDDINE TIE-1	TX-LPN070A-1	990	RESIDENTIAL		Functional	100%	176	0.36			
33 kv NIZAMUDDIN GRID	SNZMD105	11kv FDR O/G NIZAMUDDINE TIE-II	TG-LPN067A-1	990	RESIDENTIAL		Functional	100%	357	0.36			
33 kv NIZAMUDDIN GRID	SNZMD112	11kv FDR C-BLOCK, NZD EAST	TK-LPN066A-1	990	RESIDENTIAL		Functional	100%	168	0.35			
33 kv NIZAMUDDIN GRID	SNZMD112	11kv FDR C-BLOCK, NZD EAST	TX-LPN064A-1	990	RESIDENTIAL		Functional	100%	157	0.26			
33 kv NIZAMUDDIN GRID	SNZMD105	11kv FDR O/G NIZAMUDDINE TIE-II	TI-LPN080A-1	400	RESIDENTIAL		Functional	100%	35	0.10			
33 kv NIZAMUDDIN GRID	SNZMD105	11kv FDR O/G NIZAMUDDINE TIE-II	TP-LPN072A-1	100	RESIDENTIAL		Functional	100%	2	0.07			
33 kv NIZAMUDDIN GRID	SNZMD116	11kv STR 400kVA LOCAL TRF. NO.-1	NZ-STC089A-1	400	RESIDENTIAL		Functional	100%	1	0.02			
33 kv ITPO GRID, PRAGATI MAIDAN	SITPO109	11KV FDR OG SUNDER NAGAR	TP-LPN083A-1	400	RESIDENTIAL		Functional	100%	3	0.01			
33 kv NIZAMUDDIN GRID	SNZMD105	11kv FDR O/G NIZAMUDDINE TIE-II	540JP-LPN133A-	400	MIXED		Functional	100%	2	0.01			
33 kv NIZAMUDDIN GRID	SNZMD113	11kv FDR MICROWAVE,NZD EAST	TI-KIL049A-2	990	RESIDENTIAL		Functional	100%	483	0.83	4.97	1.06	17.51%
33 kv KILOKARI GRID	SKKRI324	11kv FDR DDA SLUM QUTRS SKK	TG-KIL050A-2	630	RESIDENTIAL		Functional	100%	458	0.82			
33 kv KILOKARI GRID	SKKRI324	11kv FDR DDA SLUM QUTRS SKK	TG-KIL050A-1	990	RESIDENTIAL		Functional	100%	623	0.72			
33 kv KILOKARI GRID	SKKRI324	11kv FDR DDA SLUM QUTRS SKK	TG-KIL121A-1	990	RESIDENTIAL		Functional	100%	689	0.70			
33 kv NIZAMUDDIN GRID	SNZMD113	11kv FDR MICROWAVE,NZD EAST	TG-KIL155A-1	630	COMMERCIAL		Functional	100%	304	0.62			
33 kv NIZAMUDDIN GRID	SNZMD113	11kv FDR MICROWAVE,NZD EAST	TP-KIL085A-1	630	RESIDENTIAL		Functional	100%	502	0.51			
33 kv NIZAMUDDIN GRID	SNZMD113	11kv FDR MICROWAVE,NZD EAST	TG-KIL048A-1	630	RESIDENTIAL		Functional	100%	306	0.51			
33 kv NIZAMUDDIN GRID	SNZMD113	11kv FDR MICROWAVE,NZD EAST	TG-KIL048A-2	630	RESIDENTIAL		Functional	100%	594	0.47			
33 kv NIZAMUDDIN GRID	SNZMD113	11kv FDR MICROWAVE,NZD EAST	TI-KIL049A-1	630	RESIDENTIAL		Functional	100%	571	0.42			
33 kv EXHIBITION GROUND - 2 GRID	SEXN2112	11kv FDR BHAIKON ROAD	TI-KIL072A-1	400	RESIDENTIAL		Functional	100%	438	0.22			
33 kv EXHIBITION GROUND - 2 GRID	SEXN2112	11kv FDR BHAIKON ROAD	TG-KIL098A-1	400	RESIDENTIAL		Functional	100%	8	0.16			
33 kv EXHIBITION GROUND - 2 GRID	SEXN2112	11kv FDR BHAIKON ROAD	TG-KIL091A-1	990	RESIDENTIAL		Functional	100%	89	0.04			
33 kv NIZAMUDDIN GRID	SNZMD113	11kv FDR MICROWAVE,NZD EAST	TP-KIL119A-1	400	COMMERCIAL		Functional	100%	13	0.01			
33 kv ITPO GRID, PRAGATI MAIDAN	SITPO110	11KV FDR OG TILAK BRIDGE RAILWAY COLONY	TI-LPN084A-1	400	RESIDENTIAL		Functional	100%	36	0.26	0.66	0.04	6.11%
33 kv ITPO GRID, PRAGATI MAIDAN	SITPO108	11KV FDR SUPREME COURT	TP-LPN081A-1	400	RESIDENTIAL		Functional	100%	39	0.14			
33 kv ITPO GRID, PRAGATI MAIDAN	SITPO106	11KV FDR OG BHAIKON ROAD	TP-LPN117A-1	100	RESIDENTIAL		Functional	100%	24	0.09			
33 kv ITPO GRID, PRAGATI MAIDAN	SITPO108	11KV FDR SUPREME COURT	TX-LPN127A-1	990	MIXED		Functional	100%	174	0.09			
33 kv ITPO GRID, PRAGATI MAIDAN	SITPO106	11KV FDR OG BHAIKON ROAD	TP-LPN082A-1	400	RESIDENTIAL		Functional	100%	16	0.06			

33 kv ITPO GRID, PRAGATI MAIDAN	SITPO106	11KV FDR OG BHAIRON ROAD	2540JGP-LPN130A-	100	COMMERCIAL		Functional	100%	4	0.02			
33 kv ITPO GRID, PRAGATI MAIDAN	SITPO106	11KV FDR OG BHAIRON ROAD	TP-LPN111A-1	100	RESIDENTIAL		Functional	100%	15	0.02			
33 kv ITPO GRID, PRAGATI MAIDAN	SITPO105	11kv STR 100KVA STATION TRANSFORMER	2540JGP-STC137A-	100	COMMERCIAL		Functional	100%	1	0.01			
33 kv EXHIBITION GROUND - 2 GRID	SEXN2101	11kv STR 100KVA STATION TRF.	NZ-STC075A-1	100	RESIDENTIAL		Functional	100%	1	0.00			
33 kv ITPO GRID, PRAGATI MAIDAN	SITPO108	11KV FDR SUPREME COURT	2540JGP-LPN124A-	100	COMMERCIAL		Functional	100%	2	0.00			
33 kv ITPO GRID, PRAGATI MAIDAN	SITPO103	11kv STR 100KVA STATION TRANSFORMER NO-2	2540JGP-STC137A-	100	RESIDENTIAL		Functional	100%	0	0.00			
33 kv DEFENCE COLONY GRID	SDCOL103	11KV FDR O/G SUKHDEV MARKET	TK-DEF073A-1	1600	RESIDENTIAL		Functional	100%	573	1.21	8.05	0.08	1.03%
33 kv DEFENCE COLONY GRID	SDCOL103	11KV FDR O/G SUKHDEV MARKET	TX-DEF063A-1	1600	RESIDENTIAL		Functional	100%	694	0.93			
33 kv DEFENCE COLONY GRID	SDCOL113	11KV FDR O/G BAPU PARK TRAINING CENTER	TG-DEF072A-1	990	RESIDENTIAL		Functional	100%	1104	0.88			
33 kv DEFENCE COLONY GRID	SDCOL102	11KV FDR O/G SEWA NAGAR	TG-DEF071A-2	990	RESIDENTIAL		Functional	100%	856	0.88			
33 kv DEFENCE COLONY GRID	SDCOL113	11KV FDR O/G BAPU PARK TRAINING CENTER	TG-DEF072A-2	990	RESIDENTIAL		Functional	100%	669	0.71			
33 kv DEFENCE COLONY GRID	SDCOL102	11KV FDR O/G SEWA NAGAR	TG-DEF066A-1	990	RESIDENTIAL		Functional	100%	809	0.63			
33 kv DEFENCE COLONY GRID	SDCOL103	11KV FDR O/G SUKHDEV MARKET	TX-DEF063A-2	1600	RESIDENTIAL		Functional	100%	1250	0.60			
33 kv DEFENCE COLONY GRID	SDCOL102	11KV FDR O/G SEWA NAGAR	TG-DEF071A-1	630	RESIDENTIAL		Functional	100%	611	0.57			
33 kv DEFENCE COLONY GRID	SDCOL103	11kv FDR O/G SUKHDEV MARKET	TK-DEF073A-2	990	RESIDENTIAL		Functional	100%	926	0.39			
33 kv DEFENCE COLONY GRID	SDCOL102	11KV FDR O/G SEWA NAGAR	TG-DEF064A-1	630	RESIDENTIAL		Functional	100%	457	0.29			
33 kv N.D.S.E.-2 GRID	SNDS119	11KV FDR O/G WAZIR NAGAR GALI NO.-5	TP-DEF055A-1	400	MIXED		Functional	100%	747	0.25			
33 kv N.D.S.E.-2 GRID	SNDS119	11KV FDR O/G WAZIR NAGAR GALI NO.-5	TP-DEF055A-2	400	MIXED		Functional	100%	414	0.25			
33 kv DEFENCE COLONY GRID	SDCOL102	11KV FDR O/G SEWA NAGAR	TI-DEF065A-1	630	RESIDENTIAL		Functional	100%	508	0.21			
33 kv DEFENCE COLONY GRID	SDCOL102	11KV FDR O/G SEWA NAGAR	TI-DEF065A-3	990	RESIDENTIAL		Functional	100%	196	0.19			
33 kv DEFENCE COLONY GRID	SDCOL102	11KV FDR O/G SEWA NAGAR	TI-DEF065A-2	630	RESIDENTIAL		Functional	100%	169	0.14			
33 kv KILOKARI GRID	SKKRI101	11KV FDR ASHRAM CHOWK VIA MTNL	TG-KIL124A-1	990	MIXED		Functional	100%	442	0.79	3.54	0.12	3.19%
33 kv KILOKARI GRID	SKKRI101	11KV FDR ASHRAM CHOWK VIA MTNL	TG-KIL124A-2	990	MIXED		Functional	100%	1124	0.72			
33 kv KILOKARI GRID	SKKRI101	11KV FDR ASHRAM CHOWK VIA MTNL	TG-KIL095A-1	990	MIXED		Functional	100%	757	0.64			
33 kv KILOKARI GRID	SKKRI106	11KV FDR GENERATION COLONY	TI-KIL052A-2	630	RESIDENTIAL		Functional	100%	226	0.42			
33 kv KILOKARI GRID	SKKRI101	11KV FDR ASHRAM CHOWK VIA MTNL	TP-KIL065A-1	990	MIXED		Functional	100%	263	0.41			
33 kv KILOKARI GRID	SKKRI106	11KV FDR GENERATION COLONY	TI-KIL052A-1	990	MIXED		Functional	100%	511	0.34			
33 kv KILOKARI GRID	SKKRI106	11KV FDR GENERATION COLONY	TI-KIL053A-1	990	MIXED		Functional	100%	171	0.28			
33 kv KILOKARI GRID	SKKRI325	11KV FDR SUNLIGHT COLONY NO-2	TP-KIL09A-1	400	MIXED		Functional	100%	21	0.06			
33 kv KILOKARI GRID	SKKRI326	11KV FDR AMBEDKAR PARK SIDDHARTH	TK-KIL060A-2	990	RESIDENTIAL		Functional	100%	980	0.81	7.79	0.37	4.51%
33 kv KILOKARI GRID	SKKRI326	11KV FDR AMBEDKAR PARK SIDDHARTH	TK-KIL060A-1	990	RESIDENTIAL		Functional	100%	976	0.77			
33 kv KILOKARI GRID	SKKRI110	11KV FDR SIDDHARTHA EXTN.	TI-KIL059A-2	990	RESIDENTIAL		Functional	100%	839	0.73			
33 kv KILOKARI GRID	SKKRI325	11KV FDR SUNLIGHT COLONY NO-2	TI-KIL058A-3	990	RESIDENTIAL		Functional	100%	1170	0.72			
33 kv NIZAMUDDIN GRID	SNZMD102	11KV FDR SHALIMAR CINEMA VIA SAM INDIA LTD	TG-KIL123A-1	1600	RESIDENTIAL		Functional	100%	964	0.70			
33 kv KILOKARI GRID	SKKRI327	11KV FDR TIKONA PARK SIDDHARTH BASTI VIA JEEVAN HOSP	TG-KIL061A-1	990	RESIDENTIAL		Functional	100%	713	0.68			
33 kv KILOKARI GRID	SKKRI325	11KV FDR SUNLIGHT COLONY NO-2	TI-KIL058A-2	990	RESIDENTIAL		Functional	100%	922	0.64			
33 kv KILOKARI GRID	SKKRI325	11KV FDR SUNLIGHT COLONY NO-2	TP-KIL002A-1	990	RESIDENTIAL		Functional	100%	608	0.49			
33 kv KILOKARI GRID	SKKRI110	11KV FDR SIDDHARTHA EXTN.	TI-KIL062A-2	630	RESIDENTIAL		Functional	100%	153	0.48			
33 kv KILOKARI GRID	SKKRI325	11KV FDR SUNLIGHT COLONY NO-2	TI-KIL058A-1	630	RESIDENTIAL		Functional	100%	311	0.35			
33 kv KILOKARI GRID	SKKRI110	11KV FDR SIDDHARTHA EXTN.	TI-KIL059A-1	630	RESIDENTIAL		Functional	100%	252	0.34			
33 kv KILOKARI GRID	SKKRI110	11KV FDR SIDDHARTHA EXTN.	TI-KIL062A-1	990	RESIDENTIAL		Functional	100%	375	0.33			
33 kv KILOKARI GRID	SKKRI327	11KV FDR TIKONA PARK SIDDHARTH BASTI VIA JEEVAN HOSP	TI-KIL064A-2	990	RESIDENTIAL		Functional	100%	342	0.31			
33 kv KILOKARI GRID	SKKRI327	11KV FDR TIKONA PARK SIDDHARTH BASTI VIA JEEVAN HOSP	TI-KIL063A-2	630	RESIDENTIAL		Functional	100%	158	0.28			
33 kv KILOKARI GRID	SKKRI327	11KV FDR TIKONA PARK SIDDHARTH BASTI VIA JEEVAN HOSP	TI-KIL064A-1	630	RESIDENTIAL		Functional	100%	66	0.16			
33 kv NIZAMUDDIN GRID	SNZMD102	11KV FDR SHALIMAR CINEMA VIA SAM INDIA LTD	2540KKR-KIL159A-	400	RESIDENTIAL		Functional	100%	1	0.16			
33 kv KILOKARI GRID	SKKRI327	11KV FDR TIKONA PARK SIDDHARTH BASTI VIA JEEVAN HOSP	TI-KIL063A-1	630	RESIDENTIAL		Functional	100%	188	0.13			
33 kv KILOKARI GRID	SKKRI327	11KV FDR TIKONA PARK SIDDHARTH BASTI VIA JEEVAN HOSP	TP-KIL099A-2	400	RESIDENTIAL		Functional	100%	100	0.04			
33 kv KILOKARI GRID	SKKRI327	11KV FDR TIKONA PARK SIDDHARTH BASTI VIA JEEVAN HOSP	TP-KIL099A-1	400	RESIDENTIAL		Functional	100%	37	0.03			
33 kv KILOKARI GRID	SKKRI116	11kv STR 100KVA STATION TRF. NO.-1	NZ-STC080A-1	100	RESIDENTIAL		Functional	100%	0	0.02			

33 KV LAJPAT NAGAR-3 GRID	SLJPT114	11kv FDR O/G KASTURBA NIKETAN (HVDS)	540LN2-LPN129A-	400	RESIDENTIAL		Functional	100%	44	0.11	0.08	0.02	20.14%
220KV SARITA VHR TRANSCO GRID	TDTSG103	11kv FDR INDIAN OIL CORPO	TG-SVR456A-1	990	MIXED		Functional	100%	883	0.71	2.43	0.33	11.81%
66 KV SARITA VIHAR GRID	SSARI104	11kv FDR O/G MADANPUR KHADAR TRANSIT CAMP NO.-2	541KCK-HVD056A-	1625	MIXED		Functional	100%	775	0.68			
66 kv M.C.I.E GRID	SBDPR120	11kv FDR S/S NO.-2 M.B EXTN.	541KCK-SVR692A-	630	RESIDENTIAL		Functional	100%	0	0.38			
66 KV SARITA VIHAR GRID	SSARI104	11kv FDR O/G MADANPUR KHADAR TRANSIT CAMP NO.-2	541SVR-SVR659A-	630	RESIDENTIAL	AMR	Functional	100%	216	0.29			
66 KV SARITA VIHAR GRID	SSARI104	11kv FDR O/G MADANPUR KHADAR TRANSIT CAMP NO.-2	541KCK-SVR715A-	400	MIXED		Functional	100%	0	0.17			
220KV SARITA VHR TRANSCO GRID	TDTSG103	11kv FDR INDIAN OIL CORPO	541KCK-SVR713A-	630	MIXED		Functional	100%	0	0.17			
220KV SARITA VHR TRANSCO GRID	TDTSG103	11kv FDR INDIAN OIL CORPO	TG-SVR454A-1	400	MIXED	AMR	Functional	100%	150	0.16			
66 KV SARITA VIHAR GRID	SSARI104	11kv FDR O/G MADANPUR KHADAR TRANSIT CAMP NO.-2	541KCK-SVR703A-	630	MIXED		Functional	100%	0	0.13			
220KV SARITA VHR TRANSCO GRID	TDTSG107	11kv FDR JAIPUR	541KCK-SVR701A-	100	RESIDENTIAL		Functional	100%	0	0.04			
220KV SARITA VHR TRANSCO GRID	TDTSG103	11kv FDR INDIAN OIL CORPO	TP-SVR638A-1	100	COMMERCIAL		Functional	100%	4	0.02			
220KV SARITA VHR TRANSCO GRID	TDTSG103	11kv FDR INDIAN OIL CORPO	TP-SVR109A-1	100	MIXED	AMR	Functional	100%	3	0.00			
66 KV MATHURA ROAD GRID	SMTRD129	11kv FDR SSTN PRIYANKA CAMP	TP-SVR518A-1	630	RESIDENTIAL		Functional	100%	561	0.79	4.72	0.06	1.24%
66 KV MATHURA ROAD GRID	SMTRD106	11kv FDR BADARPUR O/H	TP-SVR379A-1	990	RESIDENTIAL	AMR	Functional	100%	2111	0.76			
220KV SARITA VHR TRANSCO GRID	TDTSG101	11kv FDR ALI VILLAGE	TG-SVR156A-1	990	RESIDENTIAL		Functional	100%	1169	0.71			
220KV SARITA VHR TRANSCO GRID	TDTSG101	11kv FDR ALI VILLAGE	TG-SVR156A-2	630	RESIDENTIAL		Functional	100%	86	0.57			
220KV SARITA VHR TRANSCO GRID	TDTSG101	11kv FDR ALI VILLAGE	TG-SVR379A-2	630	RESIDENTIAL		Functional	100%	0	0.56			
66 KV MATHURA ROAD GRID	SMTRD106	11kv FDR BADARPUR O/H	541SVR-HVD006A-	1050	RESIDENTIAL	AMR	Functional	100%	1188	0.49			
220KV SARITA VHR TRANSCO GRID	TDTSG101	11kv FDR ALI VILLAGE	SV-HVD060A-1	2400	RESIDENTIAL	AMR	Functional	100%	9	0.43			
220KV SARITA VHR TRANSCO GRID	TDTSG101	11kv FDR ALI VILLAGE	TP-SVR155A-1	400	RESIDENTIAL	AMR	Functional	100%	74	0.30			
220KV SARITA VHR TRANSCO GRID	TDTSG101	11kv FDR ALI VILLAGE	TG-SVR565A-1	100	RESIDENTIAL		Functional	100%	4	0.09			
220KV SARITA VHR TRANSCO GRID	TDTSG101	11kv FDR ALI VILLAGE	541SVR-SVR694A-	400	MIXED		Functional	100%	0	0.08			
66 kv M.C.I.E GRID	SBDPR119	11kv FDR O/G NEHRU MARKET	TG-SVR484A-2	990	RESIDENTIAL	AMR	Functional	100%	1200	0.92	3.47	0.53	13.17%
66 kv M.C.I.E GRID	SBDPR119	11kv FDR O/G NEHRU MARKET	TG-SVR378A-1	990	MIXED	AMR	Functional	100%	628	0.77			
66 kv M.C.I.E GRID	SBDPR119	11kv FDR O/G NEHRU MARKET	TG-SVR368A-1	630	RESIDENTIAL	AMR	Functional	100%	705	0.59			
66 kv M.C.I.E GRID	SBDPR119	11kv FDR O/G NEHRU MARKET	TG-SVR159A-2	630	MIXED	AMR	Functional	100%	1193	0.48			
66 kv M.C.I.E GRID	SBDPR119	11kv FDR O/G NEHRU MARKET	TG-SVR378A-2	630	MIXED		Functional	100%	704	0.39			
66 kv M.C.I.E GRID	SBDPR119	11kv FDR O/G NEHRU MARKET	TG-SVR159A-1	630	MIXED	AMR	Functional	100%	324	0.37			
66 kv M.C.I.E GRID	SBDPR119	11kv FDR O/G NEHRU MARKET	TG-SVR484A-1	630	RESIDENTIAL	AMR	Functional	100%	228	0.27			
66 kv M.C.I.E GRID	SBDPR102	11kv FDR O/G D.P NTPC	541BPR-SVR684A-	630	RESIDENTIAL		Functional	100%	0	0.16			
66 kv M.C.I.E GRID	SBDPR102	11kv FDR O/G D.P NTPC	541BPR-SVR685A-	400	RESIDENTIAL		Functional	100%	6	0.03			
66 kv M.C.I.E GRID	SBDPR102	11kv FDR O/G D.P NTPC	541BPR-SVR684A-	630	RESIDENTIAL		Functional	100%	2	0.02			
66 kv M.C.I.E GRID	SBDPR119	11kv FDR O/G NEHRU MARKET	TG-SVR678A-1	400	RESIDENTIAL		Functional	100%	1	0.01			
66 kv M.C.I.E GRID	SBDPR124	11kv FDR O/G LUV KUSH D.P	TG-SVR190A-1	990	RESIDENTIAL	AMR	Functional	100%	560	0.52	1.11	0.01	1.15%
66 kv M.C.I.E GRID	SBDPR124	11kv FDR O/G LUV KUSH D.P	TG-SVR189A-1	990	MIXED		Functional	100%	735	0.45			
66 kv M.C.I.E GRID	SBDPR124	11kv FDR O/G LUV KUSH D.P	541SOV-HVD016A-	525	RESIDENTIAL		Functional	100%	426	0.14			
66 kv M.C.I.E GRID	SBDPR124	11kv FDR O/G LUV KUSH D.P	TP-SVR402A-1	100	RESIDENTIAL		Functional	100%	2	0.01			
66 KV MATHURA ROAD GRID	SMTRD130	11kv FDR S/S NO.-22, SARITA VIHAR	TG-SVR139A-1	990	COMMERCIAL		Functional	100%	796	0.87	3.82	0.35	8.33%
66 KV MATHURA ROAD GRID	SMTRD130	11kv FDR S/S NO.-22, SARITA VIHAR	TG-SVR140A-1	990	RESIDENTIAL		Functional	100%	1259	0.85			
66 KV MATHURA ROAD GRID	SMTRD130	11kv FDR S/S NO.-22, SARITA VIHAR	TG-SVR140A-2	990	COMMERCIAL		Functional	100%	146	0.78			
66 KV MATHURA ROAD GRID	SMTRD130	11kv FDR S/S NO.-22, SARITA VIHAR	TG-SVR320A-1	990	COMMERCIAL	AMR	Functional	100%	169	0.61			
66 KV MATHURA ROAD GRID	SMTRD130	11kv FDR S/S NO.-22, SARITA VIHAR	TG-SVR251A-1	990	COMMERCIAL	AMR	Functional	100%	628	0.57			
66 KV MATHURA ROAD GRID	SMTRD130	11kv FDR S/S NO.-22, SARITA VIHAR	541SVR-SVR006A-	400	RESIDENTIAL		Functional	100%	629	0.28			
66 KV MATHURA ROAD GRID	SMTRD130	11kv FDR S/S NO.-22, SARITA VIHAR	TP-SVR549A-1	400	RESIDENTIAL	AMR	Functional	100%	509	0.20			
66 KV MATHURA ROAD GRID	SMTRD122	11kv FDR DMRC FLAT SARITA VIHAR	TP-SVR013A-2	630	RESIDENTIAL	AMR	Functional	100%	279	0.10	0.31	0.01	1.59%
66 KV MATHURA ROAD GRID	SMTRD122	11kv FDR DMRC FLAT SARITA VIHAR	TG-SVR595A-1	630	RESIDENTIAL		Functional	100%	56	0.07			
66 KV MATHURA ROAD GRID	SMTRD122	11kv FDR DMRC FLAT SARITA VIHAR	TP-SVR013A-4	630	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66 KV MATHURA ROAD GRID	SMTRD122	11kv FDR DMRC FLAT SARITA VIHAR	TP-SVR013A-1	630	RESIDENTIAL	AMR	Functional	100%	3	0.05			
66 KV MATHURA ROAD GRID	SMTRD122	11kv FDR DMRC FLAT SARITA VIHAR	TP-SVR013A-3	630	RESIDENTIAL		Functional	100%	0	0.04			
66 KV MATHURA ROAD GRID	SMTRD109	11kv FDR S/S NO.-7 M.C.I.E	TG-SVR144A-1	990	INDUSTRIAL	AMR	Functional	100%	10	0.28	1.75	0.20	10.31%

66 kv MATHURA ROAD GRID	SMTRD119	11kv FDR S/S NO.-2	TG-SVR142A-2	630	INDUSTRIAL	AMR	Functional	100%	9	0.21			
66 kv MATHURA ROAD GRID	SMTRD127	11kv FDR B-1/H-8 MCIE HALDI RAM	TG-SVR384A-1	630	COMMERCIAL	AMR	Functional	100%	9	0.20			
66 kv SARITA VIHAR GRID	SSARI103	11kv FDR O/G AMERIKAN EXPRESS	TG-SVR151A-1	990	INDUSTRIAL		Functional	100%	6	0.14			
66 kv SARITA VIHAR GRID	SSARI103	11kv FDR O/G AMERIKAN EXPRESS	TP-SVR219A-1	400	INDUSTRIAL	AMR	Functional	100%	9	0.13			
66 kv SARITA VIHAR GRID	SSARI103	11kv FDR O/G AMERIKAN EXPRESS	TP-SVR222A-1	400	INDUSTRIAL	AMR	Functional	100%	4	0.12			
66 kv MATHURA ROAD GRID	SMTRD109	11kv FDR S/S NO.-7 M.C.I.E	TG-SVR551A-1	630	INDUSTRIAL	AMR	Functional	100%	12	0.12			
66 kv MATHURA ROAD GRID	SMTRD109	11kv FDR S/S NO.-7 M.C.I.E	TP-SVR229A-1	400	INDUSTRIAL		Functional	100%	0	0.12			
66 kv MATHURA ROAD GRID	SMTRD123	11kv FDR S/S NO.-1 M.C.I.E.	TP-SVR143A-1	630	INDUSTRIAL		Functional	100%	5	0.11			
66 kv MATHURA ROAD GRID	SMTRD119	11kv FDR S/S NO.-2	TG-SVR142A-1	990	INDUSTRIAL	AMR	Functional	100%	0	0.11			
66 kv MATHURA ROAD GRID	SMTRD109	11kv FDR S/S NO.-7 M.C.I.E	TP-SVR635A-1	400	COMMERCIAL		Functional	100%	6	0.08			
66 kv MATHURA ROAD GRID	SMTRD105	11kv FDR MOHAN BABA NAGAR FDR. NO.-1	TG-SVR193A-2	400	INDUSTRIAL	AMR	Functional	100%	1	0.07			
66 kv MATHURA ROAD GRID	SMTRD123	11kv FDR S/S NO.-1 M.C.I.E.	TG-SVR141A-1	630	INDUSTRIAL	AMR	Functional	100%	6	0.07			
66 kv MATHURA ROAD GRID	SMTRD127	11kv FDR B-1/H-8 MCIE HALDI RAM	TP-SVR223A-1	990	INDUSTRIAL	AMR	Functional	100%	4	0.07			
66 kv MATHURA ROAD GRID	SMTRD105	11kv FDR MOHAN BABA NAGAR FDR. NO.-1	TG-SVR363A-1	630	INDUSTRIAL		Functional	100%	3	0.04			
66 kv MATHURA ROAD GRID	SMTRD106	11kv FDR BADARPUR O/H	TP-SVR509A-1	630	INDUSTRIAL	AMR	Functional	100%	2	0.03			
66 kv MATHURA ROAD GRID	SMTRD106	11kv FDR BADARPUR O/H	TG-SVR193A-1	400	INDUSTRIAL	AMR	Functional	100%	0	0.02			
66 kv MATHURA ROAD GRID	SMTRD105	11kv FDR MOHAN BABA NAGAR FDR. NO.-1	TP-SVR208A-1	400	RESIDENTIAL		Functional	100%	1	0.02			
66 kv MATHURA ROAD GRID	SMTRD105	11kv FDR MOHAN BABA NAGAR FDR. NO.-1	TP-SVR224A-1	630	INDUSTRIAL		Functional	100%	1	0.02			
66 kv SARITA VIHAR GRID	SSARI103	11kv FDR O/G AMERIKAN EXPRESS	541SVR-SVR222A-	100	MIXED		Functional	100%	1	0.01			
66 kv MATHURA ROAD GRID	SMTRD109	11kv FDR S/S NO.-7 M.C.I.E	TG-SVR144A-2	630	INDUSTRIAL	AMR	Functional	100%	1	0.01			
66 kv MATHURA ROAD GRID	SMTRD128	11kv FDR SUBSTN NO.-3 MCIE B-1 BLK VIA A-33	TG-SVR198A-1	990	INDUSTRIAL		Functional	100%	17	0.48	3.28	0.15	4.29%
66 kv MATHURA ROAD GRID	SMTRD128	11kv FDR SUBSTN NO.-3 MCIE B-1 BLK VIA A-33	541BPR-SVR440A-	990	RESIDENTIAL	AMR	Functional	100%	49	0.47			
66 kv MATHURA ROAD GRID	SMTRD124	11kv FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-1	TP-SVR207A-1	630	INDUSTRIAL	AMR	Functional	100%	14	0.35			
66 kv MATHURA ROAD GRID	SMTRD128	11kv FDR SUBSTN NO.-3 MCIE B-1 BLK VIA A-33	TG-SVR448A-1	630	INDUSTRIAL		Functional	100%	25	0.28			
66 kv M.C.I.E GRID	SBDRP110	11kv FDR O/G S/S NO.-5 M.C.I.E	TG-SVR146A-1	630	INDUSTRIAL		Functional	100%	14	0.27			
66 kv M.C.I.E GRID	SBDRP110	11kv FDR O/G S/S NO.-5 M.C.I.E	TP-SVR358A-1	400	INDUSTRIAL		Functional	100%	209	0.24			
66 kv MATHURA ROAD GRID	SMTRD124	11kv FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-1	541SVR-SVR265A-	630	INDUSTRIAL		Functional	100%	25	0.24			
66 kv M.C.I.E GRID	SBDRP110	11kv FDR O/G S/S NO.-5 M.C.I.E	TG-SVR212A-1	990	INDUSTRIAL		Functional	100%	23	0.23			
66 kv MATHURA ROAD GRID	SMTRD124	11kv FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-1	TG-SVR199A-1	990	INDUSTRIAL	AMR	Functional	100%	16	0.20			
66 kv MATHURA ROAD GRID	SMTRD128	11kv FDR SUBSTN NO.-3 MCIE B-1 BLK VIA A-33	TP-SVR200A-2	990	INDUSTRIAL		Functional	100%	12	0.17			
66 kv MATHURA ROAD GRID	SMTRD128	11kv FDR SUBSTN NO.-3 MCIE B-1 BLK VIA A-33	TG-SVR347A-1	630	INDUSTRIAL	AMR	Functional	100%	18	0.11			
66 kv M.C.I.E GRID	SBDRP110	11kv FDR O/G S/S NO.-5 M.C.I.E	TG-SVR146A-2	630	INDUSTRIAL		Functional	100%	185	0.10			
66 kv MATHURA ROAD GRID	SMTRD124	11kv FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-1	541BPR-SVR688A-	400	RESIDENTIAL		Functional	100%	2	0.07			
66 kv M.C.I.E GRID	SBDRP110	11kv FDR O/G S/S NO.-5 M.C.I.E	541SVR-SVR010A-	400	RESIDENTIAL		Functional	100%	4	0.07			
66 kv MATHURA ROAD GRID	SMTRD124	11kv FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-1	TP-SVR476A-1	400	COMMERCIAL	AMR	Functional	100%	3	0.05			
66 kv MATHURA ROAD GRID	SMTRD124	11kv FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-1	TP-SVR152A-1	400	INDUSTRIAL		Functional	100%	6	0.05			
66 kv MATHURA ROAD GRID	SMTRD124	11kv FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-1	TP-SVR637A-1	400	RESIDENTIAL		Functional	100%	1	0.05			
66 kv MITHAPUR GRID	SMTPR115	11kv FDR LAKHPAT COLONY PART-2	TP-SVR163A-1	990	RESIDENTIAL		Functional	100%	1328	0.94	5.19	0.25	4.50%
66 kv M.C.I.E GRID	SBDRP123	11kv FDR O/G MEETHAPUR AGGARWAL DHARM SHALA	TP-SVR180A-1	990	RESIDENTIAL	AMR	Functional	100%	1069	0.88			
66 kv M.C.I.E GRID	SBDRP123	11kv FDR O/G MEETHAPUR AGGARWAL DHARM SHALA	TG-SVR178A-2	630	RESIDENTIAL		Functional	100%	28	0.67			
66 kv MITHAPUR GRID	SMTPR106	11kv FDR OM NAGAR GALI NO-10 A,B&C BLOCK	TP-SVR243A-1	990	MIXED	AMR	Functional	100%	414	0.56			
66 kv M.C.I.E GRID	SBDRP123	11kv FDR O/G MEETHAPUR AGGARWAL DHARM SHALA	TP-SVR242A-1	630	RESIDENTIAL		Functional	100%	1573	0.52			
66 kv M.C.I.E GRID	SBDRP123	11kv FDR O/G MEETHAPUR AGGARWAL DHARM SHALA	TP-SVR180A-2	400	RESIDENTIAL	AMR	Functional	100%	77	0.48			
66 kv M.C.I.E GRID	SBDRP123	11kv FDR O/G MEETHAPUR AGGARWAL DHARM SHALA	TG-SVR242A-2	630	RESIDENTIAL		Functional	100%	0	0.47			
66 kv M.C.I.E GRID	SBDRP123	11kv FDR O/G MEETHAPUR AGGARWAL DHARM SHALA	TG-SVR178A-1	630	RESIDENTIAL		Functional	100%	1146	0.39			
66 kv MITHAPUR GRID	SMTPR115	11kv FDR LAKHPAT COLONY PART-2	541SOV-SVR711A-	630	MIXED		Functional	100%	0	0.26			
66 kv M.C.I.E GRID	SBDRP123	11kv FDR O/G MEETHAPUR AGGARWAL DHARM SHALA	541SOV-SVR681A-	630	RESIDENTIAL		Functional	100%	228	0.24			
66 kv MITHAPUR GRID	SMTPR121	11kv STR 400kVA STATION TRANSFORMER	541SOV-STC122A-	400	COMMERCIAL		Functional	100%	1	0.02			
66 kv M.C.I.E GRID	SBDRP104	11kv FDR S/S NO.-5 M.B EXTN.	541BPR-HVD014A-	2600	RESIDENTIAL	AMR	Functional	100%	1545	1.32	14.39	0.15	1.03%
66 kv M.C.I.E GRID	SBDRP120	11kv FDR S/S NO.-2 M.B EXTN.	541BPR-SVR514A-	2500	MIXED	AMR	Functional	100%	310	1.20			

66 kv M.C.I.E GRID	SBDPR120	11kv FDR S/S NO.-2 M.B EXTN.	541BPR-SVR171A-	3100	MIXED	AMR	Functional	100%	0	1.16			
66 kv MITHAPUR GRID	SMTPR109	11kv FDR MANBHARI KUNJ	541BPR-SVR174A-	3100	MIXED		Functional	100%	0	1.01			
66 kv MITHAPUR GRID	SMTPR109	11kv FDR MANBHARI KUNJ	541BPR-SVR173A-	2850	MIXED	AMR	Functional	100%	5895	1.00			
66 kv M.C.I.E GRID	SBDPR120	11kv FDR S/S NO.-2 M.B EXTN.	541BPR-SVR514A-	2500	MIXED	AMR	Functional	100%	0	0.97			
66 kv M.C.I.E GRID	SBDPR105	11kv FDR S/S NO.-3 M.B EXTN.	541BPR-SVR170A-	2800	MIXED		Functional	100%	0	0.96			
66 kv MITHAPUR GRID	SMTPR109	11kv FDR MANBHARI KUNJ	541BPR-SVR258A-	2350	MIXED	AMR	Functional	100%	0	0.91			
66 kv M.C.I.E GRID	SBDPR113	11kv FDR O/G MEETHAPUR WATER PMP. STN.	541BPR-SVR175A-	2075	MIXED	AMR	Functional	100%	2950	0.81			
66 kv M.C.I.E GRID	SBDPR105	11kv FDR S/S NO.-3 M.B EXTN.	541BPR-SVR011A-	990	RESIDENTIAL	AMR	Functional	100%	685	0.72			
66 kv M.C.I.E GRID	SBDPR108	11kv FDR DP SKS	TG-SVR082A-1	990	RESIDENTIAL		Functional	100%	612	0.66			
66 kv M.C.I.E GRID	SBDPR108	11kv FDR DP SKS	TP-SVR176A-2	990	MIXED		Functional	100%	25	0.60			
66 kv M.C.I.E GRID	SBDPR104	11kv FDR S/S NO.-5 M.B EXTN.	541BPR-SVR689A-	990	RESIDENTIAL	AMR	Functional	100%	635	0.57			
66 kv M.C.I.E GRID	SBDPR104	11kv FDR S/S NO.-5 M.B EXTN.	TK-SVR677A-1	990	RESIDENTIAL		Functional	100%	176	0.52			
66 kv M.C.I.E GRID	SBDPR108	11kv FDR DP SKS	TP-SVR176A-1	630	MIXED	AMR	Functional	100%	1336	0.50			
66 kv M.C.I.E GRID	SBDPR108	11kv FDR DP SKS	TG-SVR255A-1	630	MIXED		Functional	100%	69	0.34			
66 kv M.C.I.E GRID	SBDPR104	11kv FDR S/S NO.-5 M.B EXTN.	TG-SVR361A-1	630	MIXED		Functional	100%	289	0.32			
66 kv M.C.I.E GRID	SBDPR105	11kv FDR S/S NO.-2 M.B EXTN.	TG-SVR612A-1	630	COMMERCIAL		Functional	100%	508	0.25			
66 kv M.C.I.E GRID	SBDPR104	11kv FDR S/S NO.-5 M.B EXTN.	TG-SVR172A-1	990	RESIDENTIAL		Functional	100%	348	0.17			
66 kv M.C.I.E GRID	SBDPR104	11kv FDR S/S NO.-5 M.B EXTN.	TP-SVR455A-1	400	RESIDENTIAL	AMR	Functional	100%	198	0.16			
66 kv MITHAPUR GRID	SMTPR109	11kv FDR MANBHARI KUNJ	TP-SVR360A-1	400	COMMERCIAL	AMR	Functional	100%	1883	0.12			
66 kv M.C.I.E GRID	SBDPR120	11kv FDR S/S NO.-2 M.B EXTN.	TG-SVR169A-1	630	MIXED		Functional	100%	11	0.08			
66 kv M.C.I.E GRID	SBDPR113	11kv FDR O/G MEETHAPUR WATER PMP. STN.	TG-SVR175A-1	630	MIXED		Functional	100%	10	0.07			
66 kv M.C.I.E GRID	SBDPR120	11kv FDR S/S NO.-2 M.B EXTN.	541SOV-SVR514A-	400	RESIDENTIAL		Functional	100%	6	0.05			
66 kv MITHAPUR GRID	SMTPR109	11kv FDR MANBHARI KUNJ	541BPR-SVR012A-	400	RESIDENTIAL		Functional	100%	0	0.04			
66 kv M.C.I.E GRID	SBDPR105	11kv FDR S/S NO.-3 M.B EXTN.	TG-SVR170A-1	630	MIXED		Functional	100%	291	0.02			
66 kv M.C.I.E GRID	SBDPR113	11kv FDR O/G MEETHAPUR WATER PMP. STN.	TP-SVR404A-1	100	RESIDENTIAL		Functional	100%	58	0.01			
66 kv MATHURA ROAD GRID	SMTRD130	11kv FDR S/S NO.-22, SARITA VIHAR	TG-SVR133A-3	630	RESIDENTIAL		Functional	100%	0	0.33	5.00	0.51	9.18%
66 kv SARITA VIHAR GRID	SSARI106	11kv FDR O/G S/S NO.-13, SARITA VIHAR	541SVR-SVR122A-	630	MIXED		Functional	100%	22	0.25			
66 kv SARITA VIHAR GRID	SSARI106	11kv FDR O/G S/S NO.-13, SARITA VIHAR	TG-SVR125A-1	630	MIXED	AMR	Functional	100%	6	0.25			
66 kv SARITA VIHAR GRID	SSARI106	11kv FDR O/G S/S NO.-13, SARITA VIHAR	TG-SVR130A-1	630	MIXED		Functional	100%	7	0.24			
66 kv SARITA VIHAR GRID	SSARI106	11kv FDR O/G S/S NO.-13, SARITA VIHAR	TG-SVR130A-2	630	MIXED		Functional	100%	38	0.23			
66 kv SARITA VIHAR GRID	SSARI106	11kv FDR O/G S/S NO.-13, SARITA VIHAR	TG-SVR126A-1	630	MIXED		Functional	100%	106	0.23			
66 kv SARITA VIHAR GRID	SSARI106	11kv FDR O/G S/S NO.-13, SARITA VIHAR	TG-SVR127A-2	630	MIXED		Functional	100%	9	0.23			
66 kv SARITA VIHAR GRID	SSARI106	11kv FDR O/G S/S NO.-13, SARITA VIHAR	TG-SVR125A-2	630	MIXED	AMR	Functional	100%	16	0.21			
220kv SARITA VHR TRANSCO GRID	TDTSG105	11kv FDR S/S NO.-21, SARITA VIHAR	TG-SVR134A-2	630	RESIDENTIAL	AMR	Functional	100%	257	0.20			
66 kv SARITA VIHAR GRID	SSARI106	11kv FDR O/G S/S NO.-13, SARITA VIHAR	TG-SVR123A-1	630	MIXED	AMR	Functional	100%	15	0.20			
66 kv SARITA VIHAR GRID	SSARI106	11kv FDR O/G S/S NO.-13, SARITA VIHAR	TG-SVR131A-2	630	MIXED	AMR	Functional	100%	19	0.20			
66 kv SARITA VIHAR GRID	SSARI106	11kv FDR O/G S/S NO.-13, SARITA VIHAR	TG-SVR124A-1	630	MIXED	AMR	Functional	100%	1802	0.19			
220kv SARITA VHR TRANSCO GRID	TDTSG104	11kv FDR S/S NO.-22, SARITA VIHAR	TG-SVR133A-2	400	COMMERCIAL	AMR	Functional	100%	4	0.19			
66 kv SARITA VIHAR GRID	SSARI106	11kv FDR O/G S/S NO.-13, SARITA VIHAR	TG-SVR127A-1	630	MIXED	AMR	Functional	100%	3	0.18			
66 kv SARITA VIHAR GRID	SSARI106	11kv FDR O/G S/S NO.-13, SARITA VIHAR	TG-SVR131A-1	630	MIXED	AMR	Functional	100%	3	0.16			
220kv SARITA VHR TRANSCO GRID	TDTSG105	11kv FDR S/S NO.-21, SARITA VIHAR	TG-SVR134A-1	630	COMMERCIAL	AMR	Functional	100%	4	0.16			
220kv SARITA VHR TRANSCO GRID	TDTSG104	11kv FDR S/S NO.-22, SARITA VIHAR	TG-SVR133A-1	630	COMMERCIAL	AMR	Functional	100%	0	0.16			
66 kv SARITA VIHAR GRID	SSARI101	11kv FDR O/G S/S NO.-18, SARITA VIHAR	TG-SVR129A-1	630	MIXED	AMR	Functional	100%	2	0.15			
66 kv SARITA VIHAR GRID	SSARI106	11kv FDR O/G S/S NO.-13, SARITA VIHAR	TG-SVR124A-2	630	MIXED	AMR	Functional	100%	36	0.15			
66 kv MATHURA ROAD GRID	SMTRD112	11kv FDR SUKHDEV VIHAR O/H	TP-SVR377A-1	400	MIXED		Functional	100%	2	0.14			
66 kv SARITA VIHAR GRID	SSARI106	11kv FDR O/G S/S NO.-13, SARITA VIHAR	TG-SVR126A-2	630	MIXED		Functional	100%	62	0.14			
66 kv SARITA VIHAR GRID	SSARI116	11kv FDR O/G K-POCKET SARITA VIHAR	TG-SVR439A-1	630	MIXED	AMR	Functional	100%	20	0.13			
220kv SARITA VHR TRANSCO GRID	TDTSG105	11kv FDR S/S NO.-21, SARITA VIHAR	TG-SVR132A-1	630	COMMERCIAL	AMR	Functional	100%	1	0.13			
220kv SARITA VHR TRANSCO GRID	TDTSG105	11kv FDR S/S NO.-21, SARITA VIHAR	TG-SVR132A-2	630	RESIDENTIAL		Functional	100%	255	0.13			
66 kv SARITA VIHAR GRID	SSARI116	11kv FDR O/G K-POCKET SARITA VIHAR	TG-SVR439A-2	630	MIXED	AMR	Functional	100%	0	0.12			

66 kV SARITA VIHAR GRID	SSARI116	11kV FDR O/G K-POCKET SARITA VIHAR	TG-SVR438A-1	630	MIXED	AMR	Functional	100%	3	0.11			
66 kV SARITA VIHAR GRID	SSARI106	11kV FDR O/G S/S NO.-13, SARITA VIHAR	TG-SVR128A-1	630	MIXED		Functional	100%	12	0.11			
66 kV SARITA VIHAR GRID	SSARI116	11kV FDR O/G K-POCKET SARITA VIHAR	TG-SVR438A-2	630	MIXED		Functional	100%	25	0.10			
66 kV SARITA VIHAR GRID	SSARI106	11kV FDR O/G S/S NO.-13, SARITA VIHAR	541SVR-SVR122A-	630	MIXED	AMR	Functional	100%	42	0.09			
66 kV SARITA VIHAR GRID	SSARI116	11kV FDR O/G K-POCKET SARITA VIHAR	TG-SVR436A-1	630	MIXED	AMR	Functional	100%	0	0.08			
66 kV SARITA VIHAR GRID	SSARI101	11kV FDR O/G S/S NO.-18, SARITA VIHAR	TG-SVR129A-2	630	MIXED	AMR	Functional	100%	271	0.08			
66 kV SARITA VIHAR GRID	SSARI116	11kV FDR O/G K-POCKET SARITA VIHAR	TG-SVR437A-1	630	MIXED	AMR	Functional	100%	2	0.07			
66 kV SARITA VIHAR GRID	SSARI116	11kV FDR O/G K-POCKET SARITA VIHAR	TG-SVR437A-2	630	MIXED	AMR	Functional	100%	41	0.07			
66 kV SARITA VIHAR GRID	SSARI116	11kV FDR O/G K-POCKET SARITA VIHAR	TG-SVR436A-2	630	MIXED		Functional	100%	1	0.05			
66 kV MATHURA ROAD GRID	SMTRD104	11kV FDR S/S NO.-4 SARITA VIHAR	541SVR-SVR477A-	400	MIXED		Functional	100%	0	0.03			
66 kV MATHURA ROAD GRID	SMTRD104	11kV FDR S/S NO.-4 SARITA VIHAR	TI-SVR137A-1	630	COMMERCIAL	AMR	Functional	100%	109	0.73	4.59	0.01	0.32%
66 kV MATHURA ROAD GRID	SMTRD113	11kV FDR S/S NO.-8 SARITA VIHAR	TP-SVR119A-1	630	COMMERCIAL		Functional	100%	759	0.32			
66 kV SARITA VIHAR GRID	SSARI101	11kV FDR O/G S/S NO.-18, SARITA VIHAR	TG-SVR114A-1	630	COMMERCIAL	AMR	Functional	100%	2	0.28			
66 kV MATHURA ROAD GRID	SMTRD104	11kV FDR S/S NO.-4 SARITA VIHAR	TI-SVR137A-2	400	COMMERCIAL		Functional	100%	16	0.27			
66 kV MATHURA ROAD GRID	SMTRD113	11kV FDR S/S NO.-8 SARITA VIHAR	TG-SVR121A-2	630	COMMERCIAL		Functional	100%	174	0.26			
66 kV SARITA VIHAR GRID	SSARI101	11kV FDR O/G S/S NO.-18, SARITA VIHAR	TG-SVR114A-2	630	COMMERCIAL	AMR	Functional	100%	262	0.24			
66 kV MATHURA ROAD GRID	SMTRD113	11kV FDR S/S NO.-8 SARITA VIHAR	TG-SVR116A-2	630	COMMERCIAL	AMR	Functional	100%	0	0.21			
66 kV SARITA VIHAR GRID	SSARI101	11kV FDR O/G S/S NO.-18, SARITA VIHAR	TG-SVR113A-2	630	COMMERCIAL	AMR	Functional	100%	294	0.21			
66 kV MATHURA ROAD GRID	SMTRD113	11kV FDR S/S NO.-8 SARITA VIHAR	TG-SVR120A-1	630	COMMERCIAL	AMR	Functional	100%	96	0.20			
66 kV MATHURA ROAD GRID	SMTRD113	11kV FDR S/S NO.-8 SARITA VIHAR	TG-SVR121A-1	630	COMMERCIAL		Functional	100%	4	0.20			
66 kV SARITA VIHAR GRID	SSARI101	11kV FDR O/G S/S NO.-18, SARITA VIHAR	TG-SVR115A-1	630	COMMERCIAL	AMR	Functional	100%	86	0.20			
66 kV SARITA VIHAR GRID	SSARI101	11kV FDR O/G S/S NO.-18, SARITA VIHAR	TG-SVR112A-2	630	COMMERCIAL	AMR	Functional	100%	292	0.19			
66 kV MATHURA ROAD GRID	SMTRD113	11kV FDR S/S NO.-8 SARITA VIHAR	541SVR-SVR118A-	630	COMMERCIAL		Functional	100%	7	0.19			
66 kV SARITA VIHAR GRID	SSARI101	11kV FDR O/G S/S NO.-18, SARITA VIHAR	TG-SVR115A-2	630	COMMERCIAL	AMR	Functional	100%	317	0.18			
66 kV MATHURA ROAD GRID	SMTRD113	11kV FDR S/S NO.-8 SARITA VIHAR	TP-SVR117A-1	630	COMMERCIAL	AMR	Functional	100%	41	0.16			
66 kV MATHURA ROAD GRID	SMTRD113	11kV FDR S/S NO.-8 SARITA VIHAR	TG-SVR116A-1	630	COMMERCIAL	AMR	Functional	100%	194	0.15			
66 kV SARITA VIHAR GRID	SSARI101	11kV FDR O/G S/S NO.-18, SARITA VIHAR	TG-SVR112A-1	630	COMMERCIAL		Functional	100%	0	0.13			
66 kV SARITA VIHAR GRID	SSARI101	11kV FDR O/G S/S NO.-18, SARITA VIHAR	TP-SVR111A-1	400	COMMERCIAL	AMR	Functional	100%	0	0.11			
66 kV MATHURA ROAD GRID	SMTRD104	11kV FDR S/S NO.-4 SARITA VIHAR	TG-SVR639A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.08			
66 kV SARITA VIHAR GRID	SSARI101	11kV FDR O/G S/S NO.-18, SARITA VIHAR	TP-SVR111A-2	400	COMMERCIAL	AMR	Functional	100%	41	0.08			
66 kV SARITA VIHAR GRID	SSARI101	11kV FDR O/G S/S NO.-18, SARITA VIHAR	TG-SVR113A-1	630	COMMERCIAL	AMR	Functional	100%	0	0.08			
66 kV MATHURA ROAD GRID	SMTRD113	11kV FDR O/G S/S NO.-8 SARITA VIHAR	541SVR-SVR118B-	630	COMMERCIAL	AMR	Functional	100%	0	0.07			
66 kV MATHURA ROAD GRID	SMTRD113	11kV FDR S/S NO.-8 SARITA VIHAR	541SVR-SVR118A-	630	COMMERCIAL	AMR	Functional	100%	191	0.06			
66 kV MATHURA ROAD GRID	SMTRD116	11kV STR 100kVA STATION TRF. NO.-1	541SVR-STC085A-	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV M.C.I.E GRID	SBDRP125	11kV FDR O/G BADARPUR THANA	541BPR-HVD013A-	3275	RESIDENTIAL		Functional	100%	2100	1.21	5.80	0.30	4.99%
66 kV M.C.I.E GRID	SBDRP101	11kV FDR O/G 4-POLE POLICE STATION	TG-SVR370A-1	990	MIXED		Functional	100%	152	0.93			
66 kV M.C.I.E GRID	SBDRP101	11kV FDR O/G 4-POLE POLICE STATION	TG-SVR369A-1	990	MIXED		Functional	100%	1249	0.82			
66 kV M.C.I.E GRID	SBDRP113	11kV FDR O/G MEETHAPUR WATER PMP. STN.	541BPR-HVD001A-	1475	MIXED	AMR	Functional	100%	530	0.66			
66 kV M.C.I.E GRID	SBDRP101	11kV FDR O/G 4-POLE POLICE STATION	TG-SVR164A-2	1000	RESIDENTIAL	AMR	Functional	100%	501	0.56			
66 kV M.C.I.E GRID	SBDRP125	11kV FDR O/G BADARPUR THANA	TP-SVR424A-1	630	MIXED		Functional	100%	1085	0.49			
66 kV M.C.I.E GRID	SBDRP108	11kV FDR DP SKS	TP-SVR408A-1	400	MIXED	AMR	Functional	100%	445	0.32			
66 kV M.C.I.E GRID	SBDRP108	11kV FDR DP SKS	TP-SVR407A-1	400	MIXED	AMR	Functional	100%	347	0.28			
66 kV M.C.I.E GRID	SBDRP101	11kV FDR O/G 4-POLE POLICE STATION	TG-SVR164A-1	630	RESIDENTIAL		Functional	100%	52	0.21			
66 kV M.C.I.E GRID	SBDRP125	11kV FDR O/G BADARPUR THANA	TP-SVR424A-2	400	RESIDENTIAL		Functional	100%	0	0.20			
66 kV M.C.I.E GRID	SBDRP125	11kV FDR O/G BADARPUR THANA	TG-SVR423A-1	990	MIXED		Functional	100%	869	0.19			
66 kV M.C.I.E GRID	SBDRP108	11kV FDR DP SKS	TP-SVR407A-2	400	MIXED	AMR	Functional	100%	398	0.17			
66 kV M.C.I.E GRID	SBDRP113	11kV FDR O/G MEETHAPUR WATER PMP. STN.	TP-SVR668A-1	100	RESIDENTIAL		Functional	100%	14	0.02			
66 kV M.C.I.E GRID	SBDRP125	11kV FDR O/G BADARPUR THANA	541BPR-SVR002A-	400	RESIDENTIAL		Functional	100%	1	0.01			
66 kV M.C.I.E GRID	SBDRP113	11kV FDR O/G MEETHAPUR WATER PMP. STN.	TP-SVR415A-1	100	MIXED		Functional	100%	172	0.01			
66 kV M.C.I.E GRID	SBDRP125	11kV FDR O/G BADARPUR THANA	541BPR-SVR001A-	100	MIXED		Functional	100%	1	0.01			

66 kV MATHURA ROAD GRID	SMTRD114	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	TX-SVR555A-1	990	RESIDENTIAL		Functional	100%	965	0.51	4.21	0.45	9.62%			
66 kV MATHURA ROAD GRID	SMTRD114	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	TX-SVR557A-1	990	RESIDENTIAL		Functional	100%	8	0.50						
66 kV MATHURA ROAD GRID	SMTRD114	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	TG-SVR235A-2	990	RESIDENTIAL		Functional	100%	1595	0.43						
66 kV MATHURA ROAD GRID	SMTRD114	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	TG-SVR371A-1	990	RESIDENTIAL		Functional	100%	576	0.35						
66 kV MATHURA ROAD GRID	SMTRD114	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	TG-SVR235A-1	990	RESIDENTIAL		Functional	100%	778	0.29						
66 kV MATHURA ROAD GRID	SMTRD114	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	541BPR-SVR556A-	990	RESIDENTIAL		Functional	100%	10	0.29						
66 kV MATHURA ROAD GRID	SMTRD114	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	TG-SVR589A-1	990	RESIDENTIAL		Functional	100%	502	0.27						
66 kV MATHURA ROAD GRID	SMTRD114	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	TI-SVR362A-2	990	RESIDENTIAL		Functional	100%	18	0.26						
66 kV MATHURA ROAD GRID	SMTRD114	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	541BPR-SVR556A-	990	RESIDENTIAL		Functional	100%	0	0.25						
66 kV MATHURA ROAD GRID	SMTRD114	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	TI-SVR362A-1	990	RESIDENTIAL		Functional	100%	0	0.23						
66 kV MATHURA ROAD GRID	SMTRD114	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	TX-SVR557A-2	990	RESIDENTIAL		Functional	100%	742	0.22						
66 kV MATHURA ROAD GRID	SMTRD114	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	TX-SVR374A-1	990	RESIDENTIAL		Functional	100%	45	0.19						
66 kV MATHURA ROAD GRID	SMTRD114	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	TG-SVR366A-1	990	RESIDENTIAL		Functional	100%	251	0.18						
66 kV MATHURA ROAD GRID	SMTRD114	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	TG-SVR192A-1	990	RESIDENTIAL		Functional	100%	20	0.17						
66 kV MATHURA ROAD GRID	SMTRD124	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-1	TI-SVR346A-2	630	RESIDENTIAL		Functional	100%	167	0.11						
66 kV MATHURA ROAD GRID	SMTRD124	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-1	TG-SVR543A-1	630	RESIDENTIAL		Functional	100%	1	0.10						
66 kV MATHURA ROAD GRID	SMTRD124	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-1	TI-SVR346A-1	630	RESIDENTIAL		Functional	100%	72	0.08						
66 kV MATHURA ROAD GRID	SMTRD124	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-1	TG-SVR563A-1	630	RESIDENTIAL		Functional	100%	293	0.08						
66 kV MATHURA ROAD GRID	SMTRD124	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-1	TG-SVR563A-2	630	RESIDENTIAL		Functional	100%	0	0.07						
66 kV MATHURA ROAD GRID	SMTRD124	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-1	TG-SVR543A-2	630	RESIDENTIAL		Functional	100%	212	0.06						
66 kV MATHURA ROAD GRID	SMTRD114	11kV FDR MIG DDA FLAT MOLAR BAND EXTN.FDR. NO.-2	TP-SVR233A-1	100	RESIDENTIAL		Functional	100%	1	0.01						
220kV SARITA VHR TRANSCO GRID	TDTSG109	11kV FDR AMERICAN EXPRESS	541KCK-SVR683A-	2650	MIXED		Functional	100%	3246	1.27				4.27	0.14	3.20%
66 kV SARITA VIHAR GRID	SSARI114	11kV FDR O/G MADANPUR KHADAR TRANSIT CAMP NO.-1	SV-HVD050A-1	1575	RESIDENTIAL		Functional	100%	1477	1.00						
220kV SARITA VHR TRANSCO GRID	TDTSG109	11kV FDR AMERICAN EXPRESS	SV-HVD052A-1	2675	RESIDENTIAL		Functional	100%	1335	0.94						
220kV SARITA VHR TRANSCO GRID	TDTSG109	11kV FDR AMERICAN EXPRESS	SV-HVD051A-1	2150	RESIDENTIAL		Functional	100%	749	0.73						
220kV SARITA VHR TRANSCO GRID	TDTSG109	11kV FDR AMERICAN EXPRESS	541KCK-HVD067A-	1575	MIXED		Functional	100%	0	0.33						
66 kV SARITA VIHAR GRID	SSARI114	11kV FDR O/G MADANPUR KHADAR TRANSIT CAMP NO.-1	TP-SVR661A-2	400	RESIDENTIAL		Functional	100%	157	0.13						
66 kV SARITA VIHAR GRID	SSARI114	11kV FDR O/G MADANPUR KHADAR TRANSIT CAMP NO.-1	TP-SVR661A-1	100	RESIDENTIAL		Functional	100%	0	0.00						
66 kV MITHAPUR GRID	SMTPR113	11kV FDR HARI NAGAR PART-2	541SOV-SVR704A-	630	MIXED		Functional	100%	0	0.31						
66 kV MITHAPUR GRID	SMTPR113	11kV FDR HARI NAGAR PART-2	541SOV-SVR682A-	630	RESIDENTIAL	AMR	Functional	100%	189	0.62						
66 kV MITHAPUR GRID	SMTPR113	11kV FDR HARI NAGAR PART-2	TP-SVR385A-1	630	RESIDENTIAL	AMR	Functional	100%	768	0.53						
66 kV MITHAPUR GRID	SMTPR113	11kV FDR HARI NAGAR PART-2	TG-SVR658A-1	630	RESIDENTIAL		Functional	100%	686	0.52						
66 kV MITHAPUR GRID	SMTPR113	11kV FDR HARI NAGAR PART-2	TG-SVR184A-1	630	MIXED		Functional	100%	395	0.47						
66 kV MITHAPUR GRID	SMTPR113	11kV FDR HARI NAGAR PART-2	TP-SVR237A-1	630	MIXED		Functional	100%	553	0.46						
66 kV MITHAPUR GRID	SMTPR113	11kV FDR HARI NAGAR PART-2	TG-SVR400A-2	630	RESIDENTIAL	AMR	Functional	100%	1187	0.36						
66 kV MITHAPUR GRID	SMTPR113	11kV FDR HARI NAGAR PART-2	TG-SVR400A-1	400	RESIDENTIAL	AMR	Functional	100%	171	0.30						
220kV SARITA VHR TRANSCO GRID	TDTSG102	11kV FDR SOURABH VIHAR-1	TP-SVR422A-1	400	RESIDENTIAL	AMR	Functional	100%	2	0.07						
66 kV MITHAPUR GRID	SMTPR106	11kV FDR OM NAGAR GALI NO-10 A,B&C BLOCK	541SOV-HVD022A-	1325	RESIDENTIAL	AMR	Functional	100%	2952	1.08	3.82	0.18	4.45%			
66 kV MITHAPUR GRID	SMTPR112	11kV FDR SHARDA KUNJ A-BLK OM NAGAR	TP-SVR185A-1	990	RESIDENTIAL	AMR	Functional	100%	105	0.80						
66 kV MITHAPUR GRID	SMTPR103	11kV FDR MADRASI COLONY	541SOV-HVD038A-	2800	RESIDENTIAL		Functional	100%	704	0.72						
66 kV MITHAPUR GRID	SMTPR106	11kV FDR OM NAGAR GALI NO-10 A,B&C BLOCK	541SOV-HVD022A-	1700	RESIDENTIAL		Functional	100%	0	0.55						
66 kV MITHAPUR GRID	SMTPR103	11kV FDR MADRASI COLONY	541SOV-SVR413A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.40						
66 kV MITHAPUR GRID	SMTPR103	11kV FDR MADRASI COLONY	TP-SVR413A-1	400	MIXED	AMR	Functional	100%	477	0.27						
66 kV MITHAPUR GRID	SMTPR106	11kV FDR OM NAGAR GALI NO-10 A,B&C BLOCK	TG-SVR165A-1	400	MIXED	AMR	Functional	100%	25	0.18						
66 kV MITHAPUR GRID	SMTPR101	11kV FDR GYAN MANDIR	TP-SVR411A-2	630	RESIDENTIAL		Functional	100%	0	0.69						
66 kV M.C.I.E GRID	SBDRP124	11kV FDR O/G LUV KUSH D.P	TG-SVR238A-1	990	MIXED		Functional	100%	1212	0.61						
66 kV M.C.I.E GRID	SBDRP124	11kV FDR O/G LUV KUSH D.P	TG-SVR405A-1	990	RESIDENTIAL	AMR	Functional	100%	1078	0.61						
66 kV M.C.I.E GRID	SBDRP124	11kV FDR O/G LUV KUSH D.P	541SOV-SVR238A-	630	RESIDENTIAL		Functional	100%	0	0.53						
66 kV MITHAPUR GRID	SMTPR101	11kV FDR GYAN MANDIR	TP-SVR411A-1	630	MIXED		Functional	100%	1386	0.48						
66 kV MITHAPUR GRID	SMTPR101	11kV FDR GYAN MANDIR	TP-SVR578A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.00	2.44	0.48	16.28%			

66 kv MITHAPUR GRID	SMTPR102	11kv FDR H-BLK KHADDA COLONY	541SOV-HVD039A-	4500	RESIDENTIAL		Functional	100%	1192	1.71	4.42	0.58	11.58%			
66 kv MITHAPUR GRID	SMTPR104	11kv FDR O/G PUSTA ROAD KHADDA COLONY	541KCK-HVD034A-	5325	MIXED	AMR	Functional	100%	0	1.28						
66 kv MITHAPUR GRID	SMTPR102	11kv FDR H-BLK KHADDA COLONY	541SOV-HVD037A-	1025	RESIDENTIAL	AMR	Functional	100%	1745	0.95						
220kv SARITA VHR TRANSCO GRID	TDTSG107	11kv FDR JAIPUR	541KCK-HVD069A-	475	MIXED		Functional	100%	3519	0.49						
66 kv MITHAPUR GRID	SMTPR102	11kv FDR H-BLK KHADDA COLONY	TP-SVR254A-1	400	RESIDENTIAL	AMR	Functional	100%	250	0.16						
66 kv MITHAPUR GRID	SMTPR102	11kv FDR H-BLK KHADDA COLONY	TP-SVR177A-1	100	RESIDENTIAL		Functional	100%	11	0.09						
66 kv MITHAPUR GRID	SMTPR102	11kv FDR H-BLK KHADDA COLONY	TP-SVR409A-1	100	RESIDENTIAL	AMR	Functional	100%	185	0.09						
66 kv MITHAPUR GRID	SMTPR102	11kv FDR H-BLK KHADDA COLONY	TP-SVR149A-1	100	RESIDENTIAL		Functional	100%	4	0.07						
66 kv MITHAPUR GRID	SMTPR102	11kv FDR H-BLK KHADDA COLONY	TP-SVR297A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.05						
66 kv MITHAPUR GRID	SMTPR104	11kv FDR O/G PUSTA ROAD KHADDA COLONY	541KCK-SVR705A-	400	MIXED		Functional	100%	0	0.04						
220kv SARITA VHR TRANSCO GRID	TDTSG102	11kv FDR SOURABH VIHAR-1	541SOV-SVR680A-	400	COMMERCIAL		Functional	100%	35	0.04						
220kv SARITA VHR TRANSCO GRID	TDTSG103	11kv FDR INDIAN OIL CORPO	541KCK-SVR712A-	630	MIXED		Functional	100%	0	0.02						
66 kv MITHAPUR GRID	SMTPR102	11kv FDR H-BLK KHADDA COLONY	TP-SVR087A-1	100	MIXED		Functional	100%	0	0.01						
66 kv M.C.I.E GRID	SBDRP113	11kv FDR O/G MEETHAPUR WATER PMP. STN.	TP-SVR003A-1	630	MIXED		Functional	100%	818	0.64				2.22	0.21	8.54%
66 kv M.C.I.E GRID	SBDRP113	11kv FDR O/G MEETHAPUR WATER PMP. STN.	TG-SVR107A-1	630	MIXED		Functional	100%	1497	0.51						
66 kv M.C.I.E GRID	SBDRP113	11kv FDR O/G MEETHAPUR WATER PMP. STN.	TG-SVR107A-2	630	MIXED		Functional	100%	1684	0.50						
66 kv M.C.I.E GRID	SBDRP113	11kv FDR O/G MEETHAPUR WATER PMP. STN.	TP-SVR213A-1	400	MIXED		Functional	100%	933	0.45						
66 kv M.C.I.E GRID	SBDRP113	11kv FDR O/G MEETHAPUR WATER PMP. STN.	541BPR-HVD002A-	600	RESIDENTIAL	AMR	Functional	100%	0	0.32						
220kv SARITA VHR TRANSCO GRID	TDTSG108	11kv FDR SAURABH VIHAR-2	541SOV-HVD024A-	3600	RESIDENTIAL		Functional	100%	486	1.06	2.65	0.05	1.91%			
220kv SARITA VHR TRANSCO GRID	TDTSG102	11kv FDR SOURABH VIHAR-1	541SOV-HVD031A-	2625	RESIDENTIAL		Functional	100%	1264	0.73						
220kv SARITA VHR TRANSCO GRID	TDTSG102	11kv FDR SOURABH VIHAR-1	541SOV-HVD026A-	2225	RESIDENTIAL	AMR	Functional	100%	1231	0.57						
220kv SARITA VHR TRANSCO GRID	TDTSG102	11kv FDR SOURABH VIHAR-1	541SOV-HVD027A-	2250	RESIDENTIAL		Functional	100%	979	0.28						
66 kv MITHAPUR GRID	SMTPR112	11kv FDR SHARDA KUNJ A-BLK OM NAGAR	541SOV-SVR709A-	990	MIXED		Functional	100%	0	0.07						
66 kv M.C.I.E GRID	SBDRP106	11kv FDR P/M OPPOSIT B-2/66MCIE-2	TP-SVR206A-1	400	INDUSTRIAL	AMR	Functional	100%	46	0.17	0.60	0.08	11.92%			
66 kv M.C.I.E GRID	SBDRP106	11kv FDR P/M OPPOSIT B-2/66MCIE-2	TG-SVR147A-2	630	INDUSTRIAL	AMR	Functional	100%	10	0.15						
66 kv M.C.I.E GRID	SBDRP106	11kv FDR P/M OPPOSIT B-2/66MCIE-2	541BPR-SVR679A-	400	INDUSTRIAL	AMR	Functional	100%	88	0.12						
66 kv M.C.I.E GRID	SBDRP106	11kv FDR P/M OPPOSIT B-2/66MCIE-2	TG-SVR147A-1	630	INDUSTRIAL	AMR	Functional	100%	12	0.11						
66 kv M.C.I.E GRID	SBDRP106	11kv FDR P/M OPPOSIT B-2/66MCIE-2	TG-SVR365A-1	630	INDUSTRIAL	AMR	Functional	100%	4	0.10						
66 kv M.C.I.E GRID	SBDRP116	11kv STR 400kVA STATION TRANSFORMER	541BPR-STC086A-	400	COMMERCIAL		Functional	100%	1	0.02						
66 kv M.C.I.E GRID	SBDRP106	11kv FDR P/M OPPOSIT B-2/66MCIE-2	TP-SVR005A-1	100	RESIDENTIAL		Functional	100%	4	0.01						
66 kv M.C.I.E GRID	SBDRP106	11kv FDR P/M OPPOSIT B-2/66MCIE-2	TP-SVR367A-1	400	INDUSTRIAL	AMR	Functional	100%	3	0.01						
66 kv MATHURA ROAD GRID	SMTRD129	11kv FDR SSTN PRIYANKA CAMP	541SVR-SVR516A-	3275	RESIDENTIAL		Functional	100%	0	0.86	2.30	0.77	25.03%			
66 kv MATHURA ROAD GRID	SMTRD129	11kv FDR SSTN PRIYANKA CAMP	TG-SVR517A-1	630	RESIDENTIAL	AMR	Functional	100%	1474	0.72						
66 kv MATHURA ROAD GRID	SMTRD129	11kv FDR SSTN PRIYANKA CAMP	541SVR-HVD047A-	2800	RESIDENTIAL		Functional	100%	0	0.71						
66 kv MATHURA ROAD GRID	SMTRD129	11kv FDR SSTN PRIYANKA CAMP	541SVR-SVR516A-	756	RESIDENTIAL		Functional	100%	1	0.28						
66 kv MATHURA ROAD GRID	SMTRD129	11kv FDR SSTN PRIYANKA CAMP	TP-SVR236A-1	630	COMMERCIAL	AMR	Functional	100%	567	0.26						
66 kv MATHURA ROAD GRID	SMTRD129	11kv FDR SSTN PRIYANKA CAMP	TP-SVR157A-1	400	RESIDENTIAL	AMR	Functional	100%	645	0.23						
66 kv MATHURA ROAD GRID	SMTRD129	11kv FDR SSTN PRIYANKA CAMP	TP-SVR665A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.01						
66 kv SARITA VIHAR GRID	SSARI104	11kv FDR O/G MADANPUR KHADAR TRANSIT CAMP NO.-2	SV-HVD053A-1	3825	RESIDENTIAL		Functional	100%	1772	1.08				5.83	0.02	0.39%
66 kv SARITA VIHAR GRID	SSARI104	11kv FDR O/G MADANPUR KHADAR TRANSIT CAMP NO.-2	SV-HVD055A-1	3000	RESIDENTIAL		Functional	100%	818	1.05						
66 kv SARITA VIHAR GRID	SSARI104	11kv FDR O/G MADANPUR KHADAR TRANSIT CAMP NO.-2	SV-HVD054A-1	3275	RESIDENTIAL		Functional	100%	1809	0.95						
220kv SARITA VHR TRANSCO GRID	TDTSG103	11kv FDR INDIAN OIL CORPO	SV-HVD059A-1	2280	RESIDENTIAL		Functional	100%	377	0.88						
220kv SARITA VHR TRANSCO GRID	TDTSG103	11kv FDR INDIAN OIL CORPO	SV-HVD058A-1	1575	RESIDENTIAL		Functional	100%	1330	0.82						
220kv SARITA VHR TRANSCO GRID	TDTSG103	11kv FDR INDIAN OIL CORPO	SV-HVD057A-1	3605	RESIDENTIAL		Functional	100%	898	0.73						
220kv SARITA VHR TRANSCO GRID	TDTSG103	11kv FDR INDIAN OIL CORPO	TP-SVR462A-1	400	MIXED		Functional	100%	405	0.22						
220kv SARITA VHR TRANSCO GRID	TDTSG103	11kv FDR INDIAN OIL CORPO	541SVR-SVR691A-	630	RESIDENTIAL		Functional	100%	120	0.11						
220kv SARITA VHR TRANSCO GRID	TDTSG103	11kv FDR INDIAN OIL CORPO	TP-SVR611A-1	100	RESIDENTIAL	AMR	Functional	100%	0	0.02						
66 kv SARITA VIHAR GRID	SSARI124	11kv FDR O/G M PKT. SARITA VIHAR JANTA FLAT	TG-SVR138A-1	990	MIXED		Functional	100%	127	0.96	5.22	0.34	6.20%			
66 kv MATHURA ROAD GRID	SMTRD104	11kv FDR S/S NO.-4 SARITA VIHAR	TG-SVR309A-1	990	RESIDENTIAL	AMR	Functional	100%	564	0.82						
66 kv SARITA VIHAR GRID	SSARI124	11kv FDR O/G M PKT. SARITA VIHAR JANTA FLAT	TG-SVR138A-2	990	MIXED		Functional	100%	700	0.65						

66 kv MATHURA ROAD GRID	SMTRD104	11kv FDR S/S NO.-4 SARITA VIHAR	TG-SVR338A-1	990	MIXED	AMR	Functional	100%	885	0.60			
66 kv SARITA VIHAR GRID	SSARI124	11kv FDR O/G M PKT. SARITA VIHAR JANTA FLAT	TI-SVR135A-2	630	MIXED	AMR	Functional	100%	1664	0.54			
66 kv SARITA VIHAR GRID	SSARI124	11kv FDR O/G M PKT. SARITA VIHAR JANTA FLAT	TG-SVR136A-1	630	MIXED	AMR	Functional	100%	821	0.34			
66 kv MATHURA ROAD GRID	SMTRD104	11kv FDR S/S NO.-4 SARITA VIHAR	TP-SVR451A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.30			
66 kv SARITA VIHAR GRID	SSARI109	11kv FDR O/G SAHEEN BAGH	TP-SVR645A-1	400	RESIDENTIAL	AMR	Functional	100%	217	0.30			
66 kv SARITA VIHAR GRID	SSARI124	11kv FDR O/G M PKT. SARITA VIHAR JANTA FLAT	TG-SVR136A-2	400	MIXED	AMR	Functional	100%	0	0.26			
66 kv SARITA VIHAR GRID	SSARI124	11kv FDR O/G M PKT. SARITA VIHAR JANTA FLAT	TI-SVR135A-1	400	MIXED	AMR	Functional	100%	0	0.24			
66 kv MATHURA ROAD GRID	SMTRD104	11kv FDR S/S NO.-4 SARITA VIHAR	TP-SVR451A-1	400	MIXED	AMR	Functional	100%	297	0.21			
66 kv SARITA VIHAR GRID	SSARI101	11kv FDR O/G S/S NO.-18, SARITA VIHAR	541SVR-MOB002A	990	RESIDENTIAL		Functional	100%	0	0.13			
66 kv SARITA VIHAR GRID	SSARI118	11kv FDR O/G N POCKET S/S NO.-1 SARITA VIHAR	TG-SVR447A-1	630	MIXED	AMR	Functional	100%	130	0.12			
66 kv SARITA VIHAR GRID	SSARI109	11kv FDR O/G SAHEEN BAGH	TP-SVR594A-1	400	RESIDENTIAL		Functional	100%	8	0.05			
66 kv SARITA VIHAR GRID	SSARI115	11kv STR 400kVA STATION TRANSFORMER	541SVR-STC098A	400	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kv SARITA VIHAR GRID	SSARI118	11kv FDR O/G N POCKET S/S NO.-1 SARITA VIHAR	TG-SVR487A-1	630	RESIDENTIAL	AMR	Functional	100%	84	0.02			
66 kv MITHAPUR GRID	SMTPR101	11kv FDR GYAN MANDIR	TP-HVD062A-1	3000	RESIDENTIAL	AMR	Functional	100%	1278	0.98	2.55	0.35	12.21%
66 kv MITHAPUR GRID	SMTPR101	11kv FDR GYAN MANDIR	541SOV-HVD003A	2700	RESIDENTIAL	AMR	Functional	100%	776	0.82			
66 kv MITHAPUR GRID	SMTPR101	11kv FDR GYAN MANDIR	TP-SVR217A-1	990	MIXED	AMR	Functional	100%	1510	0.81			
66 kv MITHAPUR GRID	SMTPR101	11kv FDR GYAN MANDIR	TP-SVR160A-1	400	MIXED		Functional	100%	611	0.29			
220kv SARITA VHR TRANSCO GRID	TDTSG107	11kv FDR JAIPUR	541KCK-HVD036A	3900	MIXED		Functional	100%	0	2.26	4.66	0.23	4.66%
220kv SARITA VHR TRANSCO GRID	TDTSG107	11kv FDR JAIPUR	541SOV-HVD036A	475	RESIDENTIAL		Functional	100%	977	1.14			
66 kv MITHAPUR GRID	SMTPR104	11kv FDR O/G PUSTA ROAD KHADDA COLONY	541KCK-HVD068A	2750	MIXED		Functional	100%	6784	0.82			
66 kv MITHAPUR GRID	SMTPR104	11kv FDR O/G PUSTA ROAD KHADDA COLONY	TP-SVR622A-1	400	RESIDENTIAL		Functional	100%	174	0.29			
66 kv MITHAPUR GRID	SMTPR104	11kv FDR O/G PUSTA ROAD KHADDA COLONY	541SOV-HVD018A	1320	RESIDENTIAL		Functional	100%	584	0.23			
220kv SARITA VHR TRANSCO GRID	TDTSG107	11kv FDR JAIPUR	TP-SVR406A-1	400	RESIDENTIAL		Functional	100%	49	0.13			
66 kv MITHAPUR GRID	SMTPR104	11kv FDR O/G PUSTA ROAD KHADDA COLONY	TP-SVR420A-1	400	RESIDENTIAL		Functional	100%	0	0.01			
66 kv MITHAPUR GRID	SMTPR104	11kv FDR O/G PUSTA ROAD KHADDA COLONY	TG-SVR623A-1	990	RESIDENTIAL	AMR	Functional	100%	144	0.77	1.54	0.34	18.14%
66 kv MITHAPUR GRID	SMTPR102	11kv FDR H-BLK KHADDA COLONY	TX-SVR676A-1	990	RESIDENTIAL		Functional	100%	478	0.53			
66 kv MITHAPUR GRID	SMTPR104	11kv FDR O/G PUSTA ROAD KHADDA COLONY	TG-SVR598A-1	630	RESIDENTIAL	AMR	Functional	100%	1400	0.35			
66 kv MITHAPUR GRID	SMTPR104	11kv FDR O/G PUSTA ROAD KHADDA COLONY	541KCK-SVR623A	630	MIXED		Functional	100%	0	0.24			
66 kv MITHAPUR GRID	SMTPR114	11kv FDR OM NAGAR BARAT GHAR	TG-SVR474A-1	990	RESIDENTIAL	AMR	Functional	100%	1088	1.03	3.25	0.04	1.19%
66 kv MITHAPUR GRID	SMTPR106	11kv FDR OM NAGAR GALI NO-10 A,B&C BLOCK	TG-SVR412A-1	990	RESIDENTIAL	AMR	Functional	100%	1105	0.94			
66 kv MITHAPUR GRID	SMTPR106	11kv FDR OM NAGAR GALI NO-10 A,B&C BLOCK	TG-SVR247A-1	990	RESIDENTIAL		Functional	100%	2290	0.94			
66 kv MITHAPUR GRID	SMTPR116	11kv FDR HARIJAN BASTI	TG-SVR616A-1	630	RESIDENTIAL	AMR	Functional	100%	543	0.36			
66 kv MITHAPUR GRID	SMTPR106	11kv FDR OM NAGAR GALI NO-10 A,B&C BLOCK	TP-SVR414A-1	100	RESIDENTIAL		Functional	100%	113	0.02			
66 kv MITHAPUR GRID	SMTPR116	11kv FDR HARIJAN BASTI	541SOV-SVR182A	990	RESIDENTIAL		Functional	100%	1711	0.85	3.21	0.57	15.18%
66 kv MITHAPUR GRID	SMTPR116	11kv FDR HARIJAN BASTI	TG-SVR383A-1	630	RESIDENTIAL	AMR	Functional	100%	939	0.62			
66 kv MITHAPUR GRID	SMTPR116	11kv FDR HARIJAN BASTI	TG-SVR215A-1	630	RESIDENTIAL	AMR	Functional	100%	996	0.60			
66 kv MITHAPUR GRID	SMTPR105	11kv FDR SR. SEC. SCHOOL MEETHAPUR	TG-SVR602A-1	630	RESIDENTIAL	AMR	Functional	100%	77	0.55			
66 kv MITHAPUR GRID	SMTPR116	11kv FDR HARIJAN BASTI	TG-SVR215A-2	990	RESIDENTIAL	AMR	Functional	100%	0	0.49			
66 kv MITHAPUR GRID	SMTPR105	11kv FDR SR. SEC. SCHOOL MEETHAPUR	TG-SVR248A-1	630	RESIDENTIAL	AMR	Functional	100%	770	0.43			
66 kv MITHAPUR GRID	SMTPR105	11kv FDR SR. SEC. SCHOOL MEETHAPUR	TG-SVR179A-1	630	RESIDENTIAL	AMR	Functional	100%	13	0.24			
220kv SARITA VHR TRANSCO GRID	TDTSG108	11kv FDR SAURABH VIHAR-2	541SOV-HVD028A	2975	RESIDENTIAL		Functional	100%	668	0.90	4.23	0.45	9.61%
66 kv MITHAPUR GRID	SMTPR103	11kv FDR MADRASI COLONY	541SOV-HVD025A	2200	RESIDENTIAL	AMR	Functional	100%	500	0.86			
220kv SARITA VHR TRANSCO GRID	TDTSG102	11kv FDR SOURABH VIHAR-1	541SOV-HVD030A	3350	RESIDENTIAL	AMR	Functional	100%	1220	0.74			
220kv SARITA VHR TRANSCO GRID	TDTSG107	11kv FDR JAIPUR	TP-SVR221A-1	100	RESIDENTIAL		Functional	100%	7	0.65			
66 kv MITHAPUR GRID	SMTPR103	11kv FDR MADRASI COLONY	SV-HVD064A-1	875	RESIDENTIAL		Functional	100%	1820	0.60			
220kv SARITA VHR TRANSCO GRID	TDTSG108	11kv FDR SAURABH VIHAR-2	541SOV-HVD028A	1487	RESIDENTIAL		Functional	100%	0	0.38			
66 kv MITHAPUR GRID	SMTPR103	11kv FDR MADRASI COLONY	541SOV-HVD033A	1875	RESIDENTIAL	AMR	Functional	100%	400	0.30			
220kv SARITA VHR TRANSCO GRID	TDTSG107	11kv FDR JAIPUR	541SOV-SVR446A	625	MIXED		Functional	100%	0	0.21			
220kv SARITA VHR TRANSCO GRID	TDTSG107	11kv FDR JAIPUR	TP-SVR446A-1	100	RESIDENTIAL	AMR	Functional	100%	48	0.02			
66 kv SARITA VIHAR GRID	SSARI109	11kv FDR O/G SAHEEN BAGH	541SOV-SVR702A	100	MIXED		Functional	100%	0	0.02			

220KV SARITA VHR TRANSOCO GRID	TDTSG107	11kv FDR JAIPUR	TP-SVR078A-1	100	RESIDENTIAL		Functional	100%	8	0.01			
66 kv MITHAPUR GRID	SMTPR115	11kv FDR LAKHPAT COLONY PART-2	TG-SVR181A-1	1600	RESIDENTIAL		Functional	100%	1389	1.33	2.96	0.20	6.31%
66 kv M.C.I.E GRID	SBDPR123	11kv FDR O/G MEETHAPUR AGGARWAL DHARM SHALA	TG-SVR241A-1	990	RESIDENTIAL	AMR	Functional	100%	1313	1.10			
66 kv MITHAPUR GRID	SMTPR115	11kv FDR LAKHPAT COLONY PART-2	TP-SVR240A-1	990	RESIDENTIAL	AMR	Functional	100%	1467	0.73			
66 kv MITHAPUR GRID	SMTPR112	11kv FDR SHARDA KUNJ A-BLK OM NAGAR	TG-SVR244A-1	990	MIXED		Functional	100%	2068	1.02	3.65	0.30	7.57%
66 kv MITHAPUR GRID	SMTPR114	11kv FDR OM NAGAR BARAT GHAR	541SOV-HVD023A-	2425	RESIDENTIAL	AMR	Functional	100%	265	0.66			
66 kv MITHAPUR GRID	SMTPR112	11kv FDR SHARDA KUNJ A-BLK OM NAGAR	TG-SVR244A-2	990	RESIDENTIAL		Functional	100%	848	0.60			
66 kv MITHAPUR GRID	SMTPR106	11kv FDR OM NAGAR GALI NO-10 A,B&C BLOCK	TG-SVR232A-1	990	RESIDENTIAL		Functional	100%	1004	0.54			
66 kv MITHAPUR GRID	SMTPR101	11kv FDR GYAN MANDIR	541SOV-SVR009A-	400	RESIDENTIAL		Functional	100%	27	0.39			
66 kv MITHAPUR GRID	SMTPR114	11kv FDR OM NAGAR BARAT GHAR	TP-SVR245A-1	400	RESIDENTIAL		Functional	100%	1178	0.34			
66 kv M.C.I.E GRID	SBDPR124	11kv FDR O/G LUV KUSH D.P	541SOV-SVR686A-	400	RESIDENTIAL		Functional	100%	5	0.26			
66 kv MITHAPUR GRID	SMTPR114	11kv FDR OM NAGAR BARAT GHAR	TP-SVR245A-2	630	RESIDENTIAL		Functional	100%	0	0.15			
66 kv SARITA VIHAR GRID	SSARI121	11kv FDR O/G THOKER NO.-5 DHARAM KANTA	542ABF-AFZ043A-	990	RESIDENTIAL	AMR	Functional	100%	1281	1.20	14.57	1.23	7.76%
66 kv SARITA VIHAR GRID	SSARI121	11kv FDR O/G THOKER NO.-5 DHARAM KANTA	542ABF-AFZ058A-	990	RESIDENTIAL	AMR	Functional	100%	1999	1.18			
66 kv SARITA VIHAR GRID	SSARI125	11kv FDR A.F.E. M-BLOCK	542ABF-AFZ044A-	990	RESIDENTIAL	AMR	Functional	100%	334	1.00			
66 kv SARITA VIHAR GRID	SSARI125	11kv FDR A.F.E. M-BLOCK	542ABF-AFZ045A-	990	RESIDENTIAL	AMR	Functional	100%	1405	0.95			
66 kv SARITA VIHAR GRID	SSARI119	11kv FDR O/G N-BLOCK ABUL FAZAL	542ABF-AFZ012A-	990	RESIDENTIAL	AMR	Functional	100%	195	0.90			
33 kv JAMIA MILLIA GRID	SJAMI123	11kv FDR B BLOCK ABUL FAZAL	542ABF-AFZ057A-	990	RESIDENTIAL	AMR	Functional	100%	1388	0.88			
66 kv SARITA VIHAR GRID	SSARI125	11kv FDR A.F.E. M-BLOCK	542ABF-AFZ044A-	990	RESIDENTIAL	AMR	Functional	100%	1915	0.87			
66 kv SARITA VIHAR GRID	SSARI121	11kv FDR O/G THOKER NO.-5 DHARAM KANTA	542ABF-AFZ003A-	990	RESIDENTIAL	AMR	Functional	100%	1324	0.83			
66 kv SARITA VIHAR GRID	SSARI121	11kv FDR O/G THOKER NO.-5 DHARAM KANTA	542ABF-AFZ089A-	1600	RESIDENTIAL	AMR	Functional	100%	924	0.82			
66 kv SARITA VIHAR GRID	SSARI121	11kv FDR O/G THOKER NO.-5 DHARAM KANTA	542ABF-AFZ058A-	990	RESIDENTIAL	AMR	Functional	100%	0	0.81			
66 kv SARITA VIHAR GRID	SSARI119	11kv FDR O/G N-BLOCK ABUL FAZAL	542ABF-AFZ002A-	990	RESIDENTIAL	AMR	Functional	100%	0	0.81			
66 kv SARITA VIHAR GRID	SSARI119	11kv FDR O/G N-BLOCK ABUL FAZAL	542ABF-AFZ002A-	990	RESIDENTIAL	AMR	Functional	100%	1598	0.77			
66 kv SARITA VIHAR GRID	SSARI119	11kv FDR O/G N-BLOCK ABUL FAZAL	542ABF-AFZ116A-	630	RESIDENTIAL		Functional	100%	167	0.66			
66 kv SARITA VIHAR GRID	SSARI119	11kv FDR O/G N-BLOCK ABUL FAZAL	542ABF-AFZ004A-	990	RESIDENTIAL	AMR	Functional	100%	1314	0.63			
66 kv SARITA VIHAR GRID	SSARI121	11kv FDR O/G THOKER NO.-5 DHARAM KANTA	TG-AFZ109A-1	630	RESIDENTIAL	AMR	Functional	100%	403	0.62			
66 kv SARITA VIHAR GRID	SSARI121	11kv FDR O/G THOKER NO.-5 DHARAM KANTA	542ABF-AFZ003A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.62			
66 kv SARITA VIHAR GRID	SSARI121	11kv FDR O/G THOKER NO.-5 DHARAM KANTA	542ABF-AFZ003A-	990	RESIDENTIAL	AMR	Functional	100%	1138	0.60			
66 kv SARITA VIHAR GRID	SSARI119	11kv FDR O/G N-BLOCK ABUL FAZAL	542ABF-AFZ022A-	630	RESIDENTIAL	AMR	Functional	100%	185	0.52			
66 kv SARITA VIHAR GRID	SSARI125	11kv FDR A.F.E. M-BLOCK	542ABF-AFZ045B-	990	RESIDENTIAL	AMR	Functional	100%	0	0.51			
66 kv SARITA VIHAR GRID	SSARI125	11kv FDR A.F.E. M-BLOCK	542ABF-AFZ045A-	990	RESIDENTIAL	AMR	Functional	100%	1728	0.27			
66 kv JASOLA GRID	SJASL113	11kv FDR O/G S/S NO.-2, F.C-33, JASOLA	542ABF-AFZ130A-	630	MIXED		Functional	100%	0	0.26			
66 kv SARITA VIHAR GRID	SSARI109	11kv FDR O/G SAHEEN BAGH	542ABF-AFZ128A-	100	MIXED		Functional	100%	0	0.08			
33 kv JAMIA MILLIA GRID	SJAMI111	11kv FDR O/G SANJAY JHEEL	542OKH-OKH019A	990	MIXED		Functional	100%	1005	1.12	10.20	1.06	9.39%
33 kv JAMIA MILLIA GRID	SJAMI120	11kv FDR O/G TO P BLOCK NAFEEZ ROAD	542OKH-OKH001A	990	MIXED		Functional	100%	382	1.09			
33 kv JAMIA MILLIA GRID	SJAMI120	11kv FDR O/G TO P BLOCK NAFEEZ ROAD	542OKH-OKH001A	990	MIXED	AMR	Functional	100%	3806	0.97			
33 kv SARAI JULLENA GRID	SSJNA107	11kv FDR JAMIA PLINTH S/S	542OKH-OKH002A	1600	MIXED	AMR	Functional	100%	1362	0.95			
33 kv SARAI JULLENA GRID	SSJNA107	11kv FDR JAMIA PLINTH S/S	542OKH-OKH002A	990	RESIDENTIAL	AMR	Functional	100%	748	0.92			
33 kv JAMIA MILLIA GRID	SJAMI111	11kv FDR O/G SANJAY JHEEL	542OKH-OKH018A	990	MIXED	AMR	Functional	100%	619	0.87			
33 kv JAMIA MILLIA GRID	SJAMI111	11kv FDR O/G SANJAY JHEEL	542OKH-OKH016A	990	MIXED	AMR	Functional	100%	976	0.66			
33 kv JAMIA MILLIA GRID	SJAMI114	11kv FDR RMU-3 ZAKIR NAGAR NO-22	542OKH-OKH079A	990	RESIDENTIAL	AMR	Functional	100%	175	0.59			
33 kv SARAI JULLENA GRID	SSJNA107	11kv FDR JAMIA PLINTH S/S	542OKH-OKH002A	990	MIXED	AMR	Functional	100%	1967	0.54			
33 kv SARAI JULLENA GRID	SSJNA107	11kv FDR JAMIA PLINTH S/S	542OKH-OKH019A	400	MIXED	AMR	Functional	100%	636	0.41			
33 kv JAMIA MILLIA GRID	SJAMI115	11kv FDR JAMIA STADIUM	542OKH-OKH074A	400	RESIDENTIAL	AMR	Functional	100%	93	0.39			
33 kv JAMIA MILLIA GRID	SJAMI111	11kv FDR O/G SANJAY JHEEL	542OKH-OKH018A	630	MIXED	AMR	Functional	100%	636	0.39			
33 kv JAMIA MILLIA GRID	SJAMI114	11kv FDR RMU-3 ZAKIR NAGAR NO-22	542OKH-OKH079A	400	RESIDENTIAL	AMR	Functional	100%	152	0.37			
33 kv SARAI JULLENA GRID	SSJNA107	11kv FDR JAMIA PLINTH S/S	542OKH-OKH002A	990	RESIDENTIAL	AMR	Functional	100%	1640	0.33			
33 kv SARAI JULLENA GRID	SSJNA102	11kv FDR ESCORTS HEART INST.-2	542OKH-OKH078A	400	RESIDENTIAL	AMR	Functional	100%	139	0.33			
33 kv JAMIA MILLIA GRID	SJAMI125	11kv FDR O/G TO KHAJOURI ROAD	542OKH-OKH077A	400	RESIDENTIAL	AMR	Functional	100%	0	0.33			

33 KV SARAI JULLENA GRID	SSJNA102	11KV FDR ESCORTS HEART INST.-2	542OKH-OKH078A	400	RESIDENTIAL	AMR	Functional	100%	416	0.33			
33 KV JAMIA MILLIA GRID	SJAMI125	11KV FDR O/G TO KHAJOORI ROAD	542OKH-OKH077A	400	RESIDENTIAL	AMR	Functional	100%	76	0.28			
33 KV JAMIA MILLIA GRID	SJAMI125	11KV FDR O/G TO KHAJOORI ROAD	542OKH-OKH077A	400	RESIDENTIAL	AMR	Functional	100%	251	0.21			
33 KV JAMIA MILLIA GRID	SJAMI125	11KV FDR O/G TO KHAJOORI ROAD	542OKH-OKH077A	400	RESIDENTIAL	AMR	Functional	100%	72	0.20			
33 KV JAMIA MILLIA GRID	SJAMI101	11KV FDR O/G GAFFAR MANZIL	542OKH-OKH008A	990	RESIDENTIAL	AMR	Functional	100%	698	0.78	1.67	0.17	9.12%
33 KV JAMIA MILLIA GRID	SJAMI101	11KV FDR O/G GAFFAR MANZIL	542OKH-OKH010A	630	RESIDENTIAL	AMR	Functional	100%	640	0.39			
33 KV JAMIA MILLIA GRID	SJAMI101	11KV FDR O/G GAFFAR MANZIL	542OKH-OKH010A	630	RESIDENTIAL	AMR	Functional	100%	0	0.38			
33 KV JAMIA MILLIA GRID	SJAMI101	11KV FDR O/G GAFFAR MANZIL	542OKH-OKH008A	400	RESIDENTIAL	AMR	Functional	100%	449	0.29			
33 KV SARAI JULLENA GRID	SSJNA105	11KV FDR TAIMOOR NAGAR	542KCL-KAL059A-	990	RESIDENTIAL	AMR	Functional	100%	1145	1.21	3.33	0.63	15.89%
33 KV SARAI JULLENA GRID	SSJNA105	11KV FDR TAIMOOR NAGAR	542KCL-KAL055A-	990	RESIDENTIAL	AMR	Functional	100%	707	0.73			
33 KV SARAI JULLENA GRID	SSJNA105	11KV FDR TAIMOOR NAGAR	542KCL-KAL071A-	990	RESIDENTIAL		Functional	100%	585	0.64			
33 KV SARAI JULLENA GRID	SSJNA105	11KV FDR TAIMOOR NAGAR	542KCL-KAL087A-	990	RESIDENTIAL	AMR	Functional	100%	445	0.57			
33 KV SARAI JULLENA GRID	SSJNA115	11KV FDR NFC. S/S NO.-3	542KCL-KAL112A-	400	MIXED		Functional	100%	0	0.42			
33 KV SARAI JULLENA GRID	SSJNA105	11KV FDR TAIMOOR NAGAR	542KCL-KAL055A-	1000	RESIDENTIAL	AMR	Functional	100%	338	0.38			
66 KV SARITA VIHAR GRID	SSARI107	11KV FDR O/G S/S NO.-2 DDA JASOLA	542ABF-AFZ037A-	630	MIXED	AMR	Functional	100%	869	0.61	6.09	1.03	14.52%
66 KV JASOLA GRID	SJASL115	11KV FDR O/G RMU NO.-1	542ABF-AFZ023A-	990	RESIDENTIAL	AMR	Functional	100%	173	0.53			
66 KV JASOLA GRID	SJASL116	11KV FDR O/G S/S NO.-1, PLOT NO.-1, JASOLA	542ABF-AFZ025A-	630	RESIDENTIAL		Functional	100%	108	0.40			
66 KV JASOLA GRID	SJASL116	11KV FDR O/G S/S NO.-1, PLOT NO.-1, JASOLA	542ABF-AFZ021A-	630	RESIDENTIAL	AMR	Functional	100%	163	0.32			
66 KV JASOLA GRID	SJASL115	11KV FDR O/G RMU NO.-1	542ABF-AFZ023A-	400	RESIDENTIAL	AMR	Functional	100%	17	0.28			
66 KV JASOLA GRID	SJASL115	11KV FDR O/G RMU NO.-1	542ABF-AFZ019A-	400	RESIDENTIAL	AMR	Functional	100%	67	0.28			
66 KV JASOLA GRID	SJASL116	11KV FDR O/G S/S NO.-1, PLOT NO.-1, JASOLA	542ABF-AFZ025A-	630	RESIDENTIAL		Functional	100%	83	0.25			
66 KV JASOLA GRID	SJASL115	11KV FDR O/G RMU NO.-1	542ABF-AFZ024A-	630	RESIDENTIAL	AMR	Functional	100%	44	0.24			
66 KV MATHURA ROAD GRID	SMTRD112	11KV FDR SUKHDEV VIHAR O/H	542ABF-AFZ032A-	400	RESIDENTIAL	AMR	Functional	100%	45	0.22			
66 KV SARITA VIHAR GRID	SSARI107	11KV FDR O/G S/S NO.-2 DDA JASOLA	542ABF-AFZ005A-	630	MIXED	AMR	Functional	100%	129	0.22			
66 KV SARITA VIHAR GRID	SSARI107	11KV FDR O/G S/S NO.-2 DDA JASOLA	542ABF-AFZ036A-	630	MIXED	AMR	Functional	100%	1097	0.21			
66 KV JASOLA GRID	SJASL116	11KV FDR O/G S/S NO.-1, PLOT NO.-1, JASOLA	542ABF-AFZ020A-	630	RESIDENTIAL		Functional	100%	23	0.20			
66 KV JASOLA GRID	SJASL116	11KV FDR O/G S/S NO.-1, PLOT NO.-1, JASOLA	542ABF-AFZ020A-	630	RESIDENTIAL		Functional	100%	165	0.20			
66 KV SARITA VIHAR GRID	SSARI107	11KV FDR O/G S/S NO.-2 DDA JASOLA	542ABF-AFZ100A-	630	MIXED	AMR	Functional	100%	176	0.17			
66 KV SARITA VIHAR GRID	SSARI107	11KV FDR O/G S/S NO.-2 DDA JASOLA	542ABF-AFZ009A-	630	RESIDENTIAL	AMR	Functional	100%	84	0.17			
66 KV SARITA VIHAR GRID	SSARI108	11KV FDR O/G S/S NO.-1 DDA JASOLA	542ABF-AFZ007A-	630	RESIDENTIAL	AMR	Functional	100%	187	0.16			
66 KV SARITA VIHAR GRID	SSARI107	11KV FDR O/G S/S NO.-2 DDA JASOLA	542ABF-AFZ010A-	400	RESIDENTIAL	AMR	Functional	100%	191	0.16			
66 KV JASOLA GRID	SJASL136	11KV FDR O/G UDYOG SHEEL MAHILA	542ABF-AFZ104A-	400	RESIDENTIAL	AMR	Functional	100%	44	0.16			
66 KV SARITA VIHAR GRID	SSARI108	11KV FDR O/G S/S NO.-1 DDA JASOLA	542ABF-AFZ007A-	630	RESIDENTIAL	AMR	Functional	100%	4	0.15			
66 KV JASOLA GRID	SJASL115	11KV FDR O/G RMU NO.-1	542ABF-AFZ019A-	400	RESIDENTIAL	AMR	Functional	100%	90	0.15			
66 KV SARITA VIHAR GRID	SSARI107	11KV FDR O/G S/S NO.-2 DDA JASOLA	542ABF-AFZ009A-	630	RESIDENTIAL	AMR	Functional	100%	591	0.15			
66 KV SARITA VIHAR GRID	SSARI107	11KV FDR O/G S/S NO.-2 DDA JASOLA	542ABF-AFZ036A-	630	MIXED	AMR	Functional	100%	269	0.14			
66 KV JASOLA GRID	SJASL131	11KV FDR O/G 140 LIG FLAT PKT-12	542ABF-AFZ083A-	630	MIXED	AMR	Functional	100%	159	0.14			
66 KV JASOLA GRID	SJASL134	11KV FDR O/G RMU NO.-2 JASOLA	542ABF-AFZ091A-	630	RESIDENTIAL	AMR	Functional	100%	10	0.13			
66 KV SARITA VIHAR GRID	SSARI107	11KV FDR O/G S/S NO.-2 DDA JASOLA	542ABF-AFZ100A-	630	MIXED	AMR	Functional	100%	136	0.13			
66 KV SARITA VIHAR GRID	SSARI107	11KV FDR O/G S/S NO.-2 DDA JASOLA	542ABF-AFZ010A-	400	RESIDENTIAL	AMR	Functional	100%	1	0.12			
66 KV SARITA VIHAR GRID	SSARI108	11KV FDR O/G S/S NO.-1 DDA JASOLA	542ABF-AFZ008A-	400	RESIDENTIAL	AMR	Functional	100%	84	0.12			
66 KV SARITA VIHAR GRID	SSARI108	11KV FDR O/G S/S NO.-1 DDA JASOLA	542ABF-AFZ008A-	400	RESIDENTIAL	AMR	Functional	100%	74	0.11			
66 KV JASOLA GRID	SJASL131	11KV FDR O/G 140 LIG FLAT PKT-12	542ABF-AFZ092A-	630	RESIDENTIAL	AMR	Functional	100%	63	0.09			
66 KV JASOLA GRID	SJASL113	11KV FDR O/G S/S NO.-2, F.C-33, JASOLA	542ABF-AFZ080A-	400	RESIDENTIAL	AMR	Functional	100%	209	0.09			
66 KV SARITA VIHAR GRID	SSARI107	11KV FDR O/G S/S NO.-2 DDA JASOLA	542ABF-AFZ005A-	630	MIXED	AMR	Functional	100%	167	0.09			
66 KV JASOLA GRID	SJASL134	11KV FDR O/G RMU NO.-2 JASOLA	542ABF-AFZ093A-	630	RESIDENTIAL	AMR	Functional	100%	111	0.09			
66 KV JASOLA GRID	SJASL131	11KV FDR O/G 140 LIG FLAT PKT-12	542ABF-AFZ092A-	630	RESIDENTIAL	AMR	Functional	100%	33	0.09			
66 KV JASOLA GRID	SJASL134	11KV FDR O/G RMU NO.-2 JASOLA	542ABF-AFZ093A-	630	RESIDENTIAL	AMR	Functional	100%	23	0.09			
66 KV JASOLA GRID	SJASL116	11KV FDR O/G S/S NO.-1, PLOT NO.-1, JASOLA	542ABF-AFZ021A-	630	RESIDENTIAL	AMR	Functional	100%	65	0.09			
66 KV JASOLA GRID	SJASL113	11KV FDR O/G S/S NO.-2, F.C-33, JASOLA	542ABF-AFZ079A-	400	RESIDENTIAL	AMR	Functional	100%	55	0.07			

66 kV JASOLA GRID	SJASL113	11kV FDR O/G S/S NO.-2, F.C-33, JASOLA	542ABF-AFZ064A-	400	RESIDENTIAL	AMR	Functional	100%	4	0.07			
66 kV JASOLA GRID	SJASL113	11kV FDR O/G S/S NO.-2, F.C-33, JASOLA	542ABF-AFZ079A-	400	RESIDENTIAL	AMR	Functional	100%	61	0.06			
66 kV JASOLA GRID	SJASL134	11kV FDR O/G RMU NO.-2 JASOLA	542ABF-AFZ091A-	630	RESIDENTIAL	AMR	Functional	100%	48	0.06			
66 kV JASOLA GRID	SJASL110	11kV FDR S/S NO.-4, F.C-33, JASOLA	542ABF-AFZ065A-	630	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kV JASOLA GRID	SJASL118	11kV STR 400kVA STATION TRANSFORMER	TG-STC111A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV JASOLA GRID	SJASL110	11kV FDR S/S NO.-4, F.C-33, JASOLA	542ABF-AFZ066A-	630	RESIDENTIAL		Functional	100%	11	0.02			
66 kV JASOLA GRID	SJASL134	11kV FDR O/G RMU NO.-2 JASOLA	542ABF-AFZ126A-	630	RESIDENTIAL		Functional	100%	43	0.01			
66 kV JASOLA GRID	SJASL134	11kV FDR O/G RMU NO.-2 JASOLA	542ABF-AFZ127A-	630	RESIDENTIAL		Functional	100%	36	0.01			
66 kV JASOLA GRID	SJASL113	11kV FDR O/G S/S NO.-2, F.C-33, JASOLA	542ABF-AFZ063A-	630	RESIDENTIAL	AMR	Functional	100%	331	0.00			
66 kV JASOLA GRID	SJASL134	11kV FDR O/G RMU NO.-2 JASOLA	542ABF-AFZ127A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.00			
66 kV JASOLA GRID	SJASL134	11kV FDR O/G RMU NO.-2 JASOLA	542ABF-AFZ126A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.00			
33 kV SARAI JULLENA GRID	SSJNA111	11kV FDR C.S.I.R STAFF QUARTER	542KCL-KAL041A-	990	COMMERCIAL	AMR	Functional	100%	161	0.60	4.59	0.73	13.75%
66 kV MATHURA ROAD GRID	SMTRD110	11kV FDR B-BLOCK FRIENDS COLONEY	542KCL-KAL027A-	990	RESIDENTIAL	AMR	Functional	100%	96	0.53			
33 kV SARAI JULLENA GRID	SSJNA116	11kV FDR COMMUNITY CENTER	542KCL-KAL065A-	990	COMMERCIAL		Functional	100%	193	0.51			
33 kV KILOKARI GRID	SKKRI104	11kV FDR MAHARANI BAGH-1	542KCL-KAL012A-	990	COMMERCIAL	AMR	Functional	100%	50	0.37			
33 kV SARAI JULLENA GRID	SSJNA104	11kV FDR B-BLOCK F.COLONY	542KCL-KAL027A-	990	RESIDENTIAL	AMR	Functional	100%	566	0.37			
33 kV KILOKARI GRID	SKKRI104	11kV FDR MAHARANI BAGH-1	542KCL-KAL014A-	990	COMMERCIAL		Functional	100%	49	0.32			
33 kV SARAI JULLENA GRID	SSJNA104	11kV FDR B-BLOCK F.COLONY	542KCL-KAL007A-	630	RESIDENTIAL	AMR	Functional	100%	38	0.30			
33 kV SARAI JULLENA GRID	SSJNA111	11kV FDR C.S.I.R STAFF QUARTER	542KCL-KAL013A-	630	COMMERCIAL	AMR	Functional	100%	0	0.29			
33 kV SARAI JULLENA GRID	SSJNA104	11kV FDR B-BLOCK F.COLONY	542KCL-KAL006A-	990	RESIDENTIAL	AMR	Functional	100%	41	0.27			
33 kV SARAI JULLENA GRID	SSJNA111	11kV FDR C.S.I.R STAFF QUARTER	542KCL-KAL011A-	630	COMMERCIAL	AMR	Functional	100%	78	0.25			
33 kV SARAI JULLENA GRID	SSJNA111	11kV FDR C.S.I.R STAFF QUARTER	542KCL-KAL041A-	990	RESIDENTIAL	AMR	Functional	100%	65	0.24			
33 kV SARAI JULLENA GRID	SSJNA104	11kV FDR B-BLOCK F.COLONY	542KCL-KAL007A-	400	RESIDENTIAL	AMR	Functional	100%	36	0.18			
33 kV SARAI JULLENA GRID	SSJNA104	11kV FDR B-BLOCK F.COLONY	542KCL-KAL005A-	630	RESIDENTIAL	AMR	Functional	100%	20	0.17			
33 kV SARAI JULLENA GRID	SSJNA104	11kV FDR B-BLOCK F.COLONY	542KCL-KAL005A-	990	RESIDENTIAL	AMR	Functional	100%	52	0.17			
33 kV SARAI JULLENA GRID	SSJNA111	11kV FDR C.S.I.R STAFF QUARTER	542KCL-KAL013A-	630	COMMERCIAL	AMR	Functional	100%	99	0.14			
66 kV MATHURA ROAD GRID	SMTRD110	11kV FDR B-BLOCK FRIENDS COLONEY	542KCL-KAL004A-	400	COMMERCIAL	AMR	Functional	100%	33	0.13			
33 kV SARAI JULLENA GRID	SSJNA104	11kV FDR B-BLOCK F.COLONY	542KCL-KAL078A-	400	RESIDENTIAL	AMR	Functional	100%	22	0.13			
66 kV MATHURA ROAD GRID	SMTRD110	11kV FDR B-BLOCK FRIENDS COLONEY	542KCL-KAL056A-	630	RESIDENTIAL	AMR	Functional	100%	17	0.09			
66 kV MATHURA ROAD GRID	SMTRD110	11kV FDR B-BLOCK FRIENDS COLONEY	542KCL-KAL039A-	400	COMMERCIAL	AMR	Functional	100%	2	0.07			
33 kV SARAI JULLENA GRID	SSJNA111	11kV FDR C.S.I.R STAFF QUARTER	542KCL-KAL092A-	630	RESIDENTIAL		Functional	100%	12	0.06			
66 kV MATHURA ROAD GRID	SMTRD110	11kV FDR B-BLOCK FRIENDS COLONEY	542KCL-KAL058A-	630	RESIDENTIAL	AMR	Functional	100%	58	0.05			
66 kV MATHURA ROAD GRID	SMTRD110	11kV FDR B-BLOCK FRIENDS COLONEY	542KCL-KAL058A-	630	RESIDENTIAL	AMR	Functional	100%	2	0.05			
66 kV MATHURA ROAD GRID	SMTRD110	11kV FDR B-BLOCK FRIENDS COLONEY	542KCL-KAL056A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.04			
33 kV JAMIA MILLIA GRID	SJAMI110	11kV FDR O/G MEDICAL COLLEGE NO.-2	542OKH-OKH059A	630	MIXED	AMR	Functional	100%	433	0.47	1.25	0.14	10.35%
33 kV JAMIA MILLIA GRID	SJAMI113	11kV FDR DELHI JAL BOARD	542OKH-OKH012A	630	COMMERCIAL	AMR	Functional	100%	173	0.45			
33 kV JAMIA MILLIA GRID	SJAMI108	11kV FDR RMU NO.-1,11kV FDR O/G RMU JAMIA	542OKH-OKH053A	400	MIXED	AMR	Functional	100%	31	0.27			
33 kV JAMIA MILLIA GRID	SJAMI108	11kV FDR RMU NO.-1,11kV FDR O/G RMU JAMIA	542OKH-OKH053A	400	MIXED	AMR	Functional	100%	33	0.08			
33 kV SARAI JULLENA GRID	SSJNA109	11kV FDR OKHLA FILTRATION PLANT	542OKH-OKH032A	400	MIXED	AMR	Functional	100%	58	0.07			
33 kV JAMIA MILLIA GRID	SJAMI106	11kV STR 400kVA STATION TRANSFORMER 1	SV-STC077A-1	400	MIXED	AMR	Functional	100%	1	0.04			
33 kV JAMIA MILLIA GRID	SJAMI104	11kV FDR O/G FILTRATION PLANT	542OKH-OKH035A	100	RESIDENTIAL	AMR	Functional	100%	3	0.01			
33 kV JAMIA MILLIA GRID	SJAMI109	11kV FDR O/G NOOR NAGAR	542OKH-OKH013A	990	RESIDENTIAL	AMR	Functional	100%	514	0.49	1.45	0.16	9.95%
33 kV JAMIA MILLIA GRID	SJAMI109	11kV FDR O/G NOOR NAGAR	542OKH-OKH013A	990	RESIDENTIAL	AMR	Functional	100%	618	0.33			
33 kV JAMIA MILLIA GRID	SJAMI119	11kV FDR O/G OKHLA VIHAR MASJID	TP-OKH086A-1	400	RESIDENTIAL	AMR	Functional	100%	80	0.24			
33 kV JAMIA MILLIA GRID	SJAMI119	11kV FDR O/G OKHLA VIHAR MASJID	TP-OKH086A-2	400	RESIDENTIAL	AMR	Functional	100%	120	0.23			
33 kV JAMIA MILLIA GRID	SJAMI113	11kV FDR DELHI JAL BOARD	542OKH-OKH052A	630	COMMERCIAL	AMR	Functional	100%	43	0.08			
33 kV JAMIA MILLIA GRID	SJAMI113	11kV FDR DELHI JAL BOARD	542OKH-OKH011A	990	RESIDENTIAL	AMR	Functional	100%	107	0.08			
33 kV JAMIA MILLIA GRID	SJAMI113	11kV FDR DELHI JAL BOARD	542OKH-OKH011A	630	RESIDENTIAL	AMR	Functional	100%	80	0.07			
33 kV JAMIA MILLIA GRID	SJAMI113	11kV FDR DELHI JAL BOARD	542OKH-OKH052A	630	COMMERCIAL	AMR	Functional	100%	90	0.04			
33 kV EAST OF KAILASH GRID	SKLSH102	11kV FDR SRINIWASHPURI	542KCL-KAL114A-	630	MIXED		Functional	100%	0	0.04			

33 KV SARAI JULLENA GRID	SSJNA123	11kV FDR O/G SDMC CAR PARKING NFC	2542KCL-KAL110A-	630	RESIDENTIAL		Functional	100%	0	0.00	18.73	2.60	12.20%
66 KV SARITA VIHAR GRID	SSARI109	11kV FDR O/G SAHEEN BAGH	542ABF-HVD001A-	1525	RESIDENTIAL		Functional	100%	3630	1.18			
66 KV JASOLA GRID	SJASL135	11kV FDR O/G THOKAR NO.-6	542ABF-AFZ084A-	990	MIXED	AMR	Functional	100%	974	1.05			
66 KV SARITA VIHAR GRID	SSARI123	11kV FDR O/G D-BLOCK SAHEEN BAGH	542ABF-AFZ106A-	990	RESIDENTIAL	AMR	Functional	100%	433	1.04			
66 KV SARITA VIHAR GRID	SSARI102	11kV FDR O/G F-BLK MOTHER DIARY SHAHEEN BAGH	542ABF-AFZ027A-	990	RESIDENTIAL		Functional	100%	1936	0.97			
66 KV SARITA VIHAR GRID	SSARI120	11kV FDR O/G G-4, SHAHEEN BAGH	542ABF-AFZ070A-	990	MIXED		Functional	100%	2647	0.97			
66 KV SARITA VIHAR GRID	SSARI123	11kV FDR O/G D-BLOCK SAHEEN BAGH	542ABF-AFZ106A-	990	RESIDENTIAL	AMR	Functional	100%	370	0.93			
66 KV SARITA VIHAR GRID	SSARI109	11kV FDR O/G SAHEEN BAGH	542ABF-AFZ049A-	990	MIXED		Functional	100%	547	0.89			
66 KV JASOLA GRID	SJASL135	11kV FDR O/G THOKAR NO.-6	542ABF-AFZ028A-	990	MIXED	AMR	Functional	100%	495	0.78			
66 KV JASOLA GRID	SJASL135	11kV FDR O/G THOKAR NO.-6	542ABF-AFZ013A-	990	MIXED	AMR	Functional	100%	2434	0.78			
66 KV SARITA VIHAR GRID	SSARI122	11kV FDR O/G ABU BAKAR MASJID	542ABF-AFZ094A-	990	MIXED	AMR	Functional	100%	1158	0.77			
66 KV SARITA VIHAR GRID	SSARI122	11kV FDR O/G ABU BAKAR MASJID	542ABF-AFZ095A-	990	MIXED	AMR	Functional	100%	600	0.76			
66 KV JASOLA GRID	SJASL135	11kV FDR O/G THOKAR NO.-6	542ABF-AFZ112A-	990	RESIDENTIAL	AMR	Functional	100%	177	0.70			
66 KV SARITA VIHAR GRID	SSARI122	11kV FDR O/G ABU BAKAR MASJID	542ABF-AFZ095A-	630	RESIDENTIAL	AMR	Functional	100%	1046	0.70			
66 KV SARITA VIHAR GRID	SSARI122	11kV FDR O/G ABU BAKAR MASJID	542ABF-AFZ056A-	630	MIXED	AMR	Functional	100%	328	0.68			
66 KV SARITA VIHAR GRID	SSARI120	11kV FDR O/G G-4, SHAHEEN BAGH	542ABF-AFZ034A-	630	RESIDENTIAL	AMR	Functional	100%	56	0.67			
66 KV SARITA VIHAR GRID	SSARI120	11kV FDR O/G G-4, SHAHEEN BAGH	542ABF-AFZ070A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.64			
66 KV JASOLA GRID	SJASL117	11kV FDR O/G SPORTS COMPLEX JASOLA	542ABF-AFZ124A-	990	RESIDENTIAL	AMR	Functional	100%	306	0.62			
66 KV SARITA VIHAR GRID	SSARI122	11kV FDR O/G ABU BAKAR MASJID	542ABF-AFZ099A-	630	RESIDENTIAL	AMR	Functional	100%	7	0.61			
66 KV SARITA VIHAR GRID	SSARI102	11kV FDR O/G F-BLK MOTHER DIARY SHAHEEN BAGH	542ABF-AFZ027A-	630	RESIDENTIAL		Functional	100%	0	0.60			
66 KV SARITA VIHAR GRID	SSARI120	11kV FDR O/G G-4, SHAHEEN BAGH	542ABF-AFZ113A-	630	RESIDENTIAL		Functional	100%	125	0.59			
66 KV SARITA VIHAR GRID	SSARI123	11kV FDR O/G D-BLOCK SAHEEN BAGH	542ABF-AFZ125A-	630	RESIDENTIAL		Functional	100%	199	0.58			
66 KV SARITA VIHAR GRID	SSARI122	11kV FDR O/G ABU BAKAR MASJID	542ABF-AFZ094A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.56			
66 KV JASOLA GRID	SJASL135	11kV FDR O/G THOKAR NO.-6	542ABF-AFZ085A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.51			
66 KV SARITA VIHAR GRID	SSARI109	11kV FDR O/G SAHEEN BAGH	542ABF-AFZ107A-	400	RESIDENTIAL	AMR	Functional	100%	51	0.43			
66 KV JASOLA GRID	SJASL135	11kV FDR O/G THOKAR NO.-6	542ABF-AFZ038A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.42			
66 KV SARITA VIHAR GRID	SSARI109	11kV FDR O/G SAHEEN BAGH	542ABF-AFZ069A-	630	RESIDENTIAL	AMR	Functional	100%	182	0.41			
66 KV SARITA VIHAR GRID	SSARI120	11kV FDR O/G G-4, SHAHEEN BAGH	542ABF-AFZ114A-	630	RESIDENTIAL		Functional	100%	191	0.40			
66 KV JASOLA GRID	SJASL135	11kV FDR O/G THOKAR NO.-6	542ABF-AFZ085A-	630	MIXED	AMR	Functional	100%	827	0.40			
66 KV SARITA VIHAR GRID	SSARI122	11kV FDR O/G ABU BAKAR MASJID	542ABF-HVD006A-	675	RESIDENTIAL		Functional	100%	1043	0.39			
66 KV SARITA VIHAR GRID	SSARI122	11kV FDR O/G ABU BAKAR MASJID	542ABF-AFZ121A-	400	RESIDENTIAL		Functional	100%	415	0.39			
66 KV JASOLA GRID	SJASL135	11kV FDR O/G THOKAR NO.-6	542ABF-AFZ110A-	400	RESIDENTIAL	AMR	Functional	100%	132	0.23			
66 KV JASOLA GRID	SJASL135	11kV FDR O/G THOKAR NO.-6	542ABF-AFZ038A-	630	RESIDENTIAL		Functional	100%	88	0.22			
66 KV JASOLA GRID	SJASL135	11kV FDR O/G THOKAR NO.-6	542ABF-AFZ110A-	400	RESIDENTIAL	AMR	Functional	100%	80	0.19			
66 KV JASOLA GRID	SJASL135	11kV FDR O/G THOKAR NO.-6	542ABF-AFZ108A-	100	RESIDENTIAL	AMR	Functional	100%	9	0.09			
66 KV SARITA VIHAR GRID	SSARI109	11kV FDR O/G SAHEEN BAGH	542ABF-AFZ119A-	100	RESIDENTIAL		Functional	100%	20	0.07			
66 KV SARITA VIHAR GRID	SSARI109	11kV FDR O/G SAHEEN BAGH	542ABF-AFZ098A-	100	RESIDENTIAL	AMR	Functional	100%	95	0.06			
66 KV SARITA VIHAR GRID	SSARI109	11kV FDR O/G SAHEEN BAGH	542ABF-AFZ090A-	400	RESIDENTIAL	AMR	Functional	100%	1	0.05			
66 KV SARITA VIHAR GRID	SSARI120	11kV FDR O/G G-4, SHAHEEN BAGH	542ABF-HVD008A-	630	RESIDENTIAL		Functional	100%	83	0.01			
66 KV SARITA VIHAR GRID	SSARI109	11kV FDR O/G SAHEEN BAGH	542ABF-AFZ050A-	400	MIXED	AMR	Functional	100%	0	0.01			
33 KV LAJPAT NAGAR-3 GRID	SLJPT111	11kV FDR O/G NURSING STAFF QURTERS S.N PURI	2542KCL-KAL050A-	630	MIXED		Functional	100%	0	0.41	1.05	0.28	21.39%
33 KV KILOKARI GRID	SKKRI109	11kV FDR O/G SRINIWAS PURI S/STN.	2542KCL-KAL085A-	400	MIXED	AMR	Functional	100%	710	0.41			
33 KV EAST OF KAILASH GRID	SKLSH102	11kV FDR SRINIWASHPURI	2542KCL-KAL054A-	990	MIXED	AMR	Functional	100%	282	0.24			
33 KV LAJPAT NAGAR-3 GRID	SLJPT111	11kV FDR O/G NURSING STAFF QURTERS S.N PURI	2542KCL-KAL083A-	250	MIXED	AMR	Functional	100%	28	0.12			
33 KV LAJPAT NAGAR-3 GRID	SLJPT111	11kV FDR O/G NURSING STAFF QURTERS S.N PURI	2542KCL-KAL050A-	630	MIXED	AMR	Functional	100%	499	0.09			
33 KV EAST OF KAILASH GRID	SKLSH102	11kV FDR SRINIWASHPURI	2542KCL-KAL079A-	630	MIXED	AMR	Functional	100%	44	0.05			
33 KV EAST OF KAILASH GRID	SKLSH102	11kV FDR SRINIWASHPURI	2542KCL-KAL054A-	750	MIXED	AMR	Functional	100%	72	0.02			
33 KV JAMIA MILLIA GRID	SJAMI105	11kV FDR O/G ZAKIR NAGAR	542OKH-OKH021A-	2000	RESIDENTIAL	AMR	Functional	100%	1332	1.27	9.14	2.12	18.86%
33 KV JAMIA MILLIA GRID	SJAMI121	11kV FDR O/G TO MEHBOOB NAGAR VIA REHMANI MASJID	542OKH-OKH071A-	1600	RESIDENTIAL	AMR	Functional	100%	0	1.11			
33 KV JAMIA MILLIA GRID	SJAMI114	11kV FDR RMU-3 ZAKIR NAGAR NO-22	542OKH-OKH007A-	990	RESIDENTIAL	AMR	Functional	100%	322	1.00			

33 kv JAMIA MILLIA GRID	SJAMI121	11kv FDR O/G TO MEHBOOB NAGAR VIA REHMANI MASJID	542OKH-OKH026A	990	MIXED	AMR	Functional	100%	1026	0.92			
33 kv JAMIA MILLIA GRID	SJAMI121	11kv FDR O/G TO MEHBOOB NAGAR VIA REHMANI MASJID	542OKH-OKH020A	990	COMMERCIAL	AMR	Functional	100%	890	0.86			
33 kv JAMIA MILLIA GRID	SJAMI108	11kv FDR RMU NO.-1,11kv FDR O/G RMU JAMIA	542OKH-OKH021A	990	COMMERCIAL	AMR	Functional	100%	1227	0.84			
33 kv JAMIA MILLIA GRID	SJAMI114	11kv FDR RMU-3 ZAKIR NAGAR NO-22	542OKH-OKH007A	990	COMMERCIAL	AMR	Functional	100%	1203	0.82			
33 kv JAMIA MILLIA GRID	SJAMI105	11kv FDR O/G ZAKIR NAGAR	542OKH-OKH021A	990	RESIDENTIAL	AMR	Functional	100%	285	0.72			
33 kv JAMIA MILLIA GRID	SJAMI108	11kv FDR RMU NO.-1,11kv FDR O/G RMU JAMIA	542OKH-OKH050A	990	COMMERCIAL	AMR	Functional	100%	1088	0.67			
33 kv JAMIA MILLIA GRID	SJAMI108	11kv FDR RMU NO.-1,11kv FDR O/G RMU JAMIA	542OKH-OKH050A	990	RESIDENTIAL	AMR	Functional	100%	0	0.63			
33 kv JAMIA MILLIA GRID	SJAMI114	11kv FDR RMU-3 ZAKIR NAGAR NO-22	542OKH-OKH007A	990	RESIDENTIAL	AMR	Functional	100%	0	0.60			
33 kv JAMIA MILLIA GRID	SJAMI114	11kv FDR RMU-3 ZAKIR NAGAR NO-22	542OKH-OKH007A	990	COMMERCIAL	AMR	Functional	100%	2013	0.47			
33 kv JAMIA MILLIA GRID	SJAMI108	11kv FDR RMU NO.-1,11kv FDR O/G RMU JAMIA	542OKH-OKH049A	990	RESIDENTIAL	AMR	Functional	100%	17	0.46			
33 kv JAMIA MILLIA GRID	SJAMI115	11kv FDR JAMIA STADIUM	NF-OKH085A-2	400	RESIDENTIAL	AMR	Functional	100%	116	0.36			
33 kv SARAI JULLENA GRID	SSJNA115	11kv FDR NFC. S/S NO.-3	542OKH-OKH049A	630	COMMERCIAL	AMR	Functional	100%	659	0.28			
33 kv JAMIA MILLIA GRID	SJAMI115	11kv FDR JAMIA STADIUM	NF-OKH085A-1	400	RESIDENTIAL	AMR	Functional	100%	152	0.25			
66 kv MATHURA ROAD GRID	SMTRD107	11kv FDR OKHLA SEWAGE	542KCL-KAL034A-	990	COMMERCIAL	AMR	Functional	100%	227	0.74	4.25	0.42	9.01%
66 kv MATHURA ROAD GRID	SMTRD107	11kv FDR OKHLA SEWAGE	542KCL-KAL069A-	990	COMMERCIAL	AMR	Functional	100%	604	0.70			
33 kv SARAI JULLENA GRID	SSJNA108	11kv FDR SUKHADEV VIHAR	542KCL-KAL034A-	990	COMMERCIAL	AMR	Functional	100%	662	0.63			
33 kv SARAI JULLENA GRID	SSJNA125	11kv FDR SFS NO 1 SUKHDEV VIHAR	542KCL-KAL033A-	990	COMMERCIAL	AMR	Functional	100%	166	0.52			
66 kv MATHURA ROAD GRID	SMTRD111	11kv FDR GEETA NURSERY STG. LTG.	542KCL-KAL108A-	990	MIXED	AMR	Functional	100%	81	0.34			
33 kv SARAI JULLENA GRID	SSJNA125	11kv FDR SFS NO 1 SUKHDEV VIHAR	542KCL-KAL032A-	1000	COMMERCIAL	AMR	Functional	100%	95	0.28			
33 kv SARAI JULLENA GRID	SSJNA125	11kv FDR SFS NO 1 SUKHDEV VIHAR	542KCL-KAL032A-	630	COMMERCIAL	AMR	Functional	100%	196	0.25			
33 kv SARAI JULLENA GRID	SSJNA125	11kv FDR SFS NO 1 SUKHDEV VIHAR	542KCL-KAL031A-	630	COMMERCIAL	AMR	Functional	100%	262	0.23			
33 kv SARAI JULLENA GRID	SSJNA125	11kv FDR SFS NO 1 SUKHDEV VIHAR	542KCL-KAL033A-	990	COMMERCIAL	AMR	Functional	100%	283	0.19			
33 kv SARAI JULLENA GRID	SSJNA125	11kv FDR SFS NO 1 SUKHDEV VIHAR	542KCL-KAL031A-	990	COMMERCIAL	AMR	Functional	100%	178	0.17			
66 kv MATHURA ROAD GRID	SMTRD111	11kv FDR GEETA NURSERY STG. LTG.	542KCL-KAL068A-	400	RESIDENTIAL	AMR	Functional	100%	22	0.15			
66 kv MATHURA ROAD GRID	SMTRD111	11kv FDR GEETA NURSERY STG. LTG.	542KCL-KAL095A-	400	RESIDENTIAL	AMR	Functional	100%	244	0.13			
66 kv MATHURA ROAD GRID	SMTRD111	11kv FDR GEETA NURSERY STG. LTG.	542KCL-KAL091A-	100	COMMERCIAL	AMR	Functional	100%	83	0.09			
33 kv SARAI JULLENA GRID	SSJNA120	11kv FDR O S D PLANT	542KCL-KAL028A-	400	COMMERCIAL	AMR	Functional	100%	69	0.08			
33 kv SARAI JULLENA GRID	SSJNA125	11kv FDR SFS NO 1 SUKHDEV VIHAR	542KCL-KAL070A-	400	COMMERCIAL	AMR	Functional	100%	51	0.07			
33 kv SARAI JULLENA GRID	SSJNA108	11kv FDR SUKHADEV VIHAR	542KCL-KAL003A-	400	MIXED		Functional	100%	1	0.04			
33 kv SARAI JULLENA GRID	SSJNA125	11kv FDR SFS NO 1 SUKHDEV VIHAR	542KCL-KAL070A-	400	COMMERCIAL	AMR	Functional	100%	0	0.03			
66 kv MATHURA ROAD GRID	SMTRD111	11kv FDR GEETA NURSERY STG. LTG.	542KCL-KAL040A-	100	RESIDENTIAL		Functional	100%	19	0.02			
33 kv SARAI JULLENA GRID	SSJNA108	11kv FDR SUKHADEV VIHAR	542KCL-KAL102A-	400	INDUSTRIAL	AMR	Functional	100%	8	0.01			
33 kv SARAI JULLENA GRID	SSJNA121	11kv STR 100KVA STATION TRANSF.	542KCL-STC097A-	100	COMMERCIAL		Functional	100%	1	0.01			
33 kv KILOKARI GRID	SKKRI105	11kv FDR MAHARANI BAGH NO.-2	542KCL-KAL036A-	990	COMMERCIAL		Functional	100%	360	0.78	4.10	0.54	11.59%
33 kv KILOKARI GRID	SKKRI104	11kv FDR MAHARANI BAGH-1	542KCL-KAL015A-	630	COMMERCIAL	AMR	Functional	100%	39	0.66			
33 kv KILOKARI GRID	SKKRI104	11kv FDR MAHARANI BAGH-1	542KCL-KAL036A-	990	COMMERCIAL	AMR	Functional	100%	93	0.43			
33 kv KILOKARI GRID	SKKRI104	11kv FDR MAHARANI BAGH-1	542KCL-KAL026A-	990	RESIDENTIAL	AMR	Functional	100%	180	0.41			
33 kv KILOKARI GRID	SKKRI104	11kv FDR MAHARANI BAGH-1	542KCL-KAL020A-	990	RESIDENTIAL	AMR	Functional	100%	169	0.40			
33 kv KILOKARI GRID	SKKRI105	11kv FDR MAHARANI BAGH NO.-2	542KCL-KAL018A-	990	COMMERCIAL	AMR	Functional	100%	92	0.39			
33 kv KILOKARI GRID	SKKRI104	11kv FDR MAHARANI BAGH-1	542KCL-KAL015A-	630	COMMERCIAL	AMR	Functional	100%	97	0.38			
33 kv KILOKARI GRID	SKKRI104	11kv FDR MAHARANI BAGH-1	542KCL-KAL026A-	630	RESIDENTIAL	AMR	Functional	100%	103	0.32			
33 kv KILOKARI GRID	SKKRI104	11kv FDR MAHARANI BAGH-1	542KCL-KAL017A-	990	COMMERCIAL	AMR	Functional	100%	181	0.31			
33 kv KILOKARI GRID	SKKRI105	11kv FDR MAHARANI BAGH NO.-2	542KCL-KAL036A-	630	COMMERCIAL	AMR	Functional	100%	85	0.26			
33 kv KILOKARI GRID	SKKRI104	11kv FDR MAHARANI BAGH-1	542KCL-KAL088A-	400	RESIDENTIAL	AMR	Functional	100%	1	0.08			
33 kv SARAI JULLENA GRID	SSJNA111	11kv FDR C.S.I.R STAFF QUARTER	542KCL-KAL086A-	630	COMMERCIAL	AMR	Functional	100%	110	0.08			
33 kv SARAI JULLENA GRID	SSJNA111	11kv FDR C.S.I.R STAFF QUARTER	542KCL-KAL086A-	630	COMMERCIAL	AMR	Functional	100%	90	0.04			
33 kv KILOKARI GRID	SKKRI104	11kv FDR MAHARANI BAGH-1	542KCL-KAL021A-	630	RESIDENTIAL	AMR	Functional	100%	12	0.04			
33 kv KILOKARI GRID	SKKRI104	11kv FDR MAHARANI BAGH-1	542KCL-KAL082A-	400	RESIDENTIAL		Functional	100%	36	0.03			
33 kv KILOKARI GRID	SKKRI103	11kv FDR NEW FRIENDS COLONY S/S NO.-1	542KCL-KAL106A-	400	AGRICULTURE	AMR	Functional	100%	3	0.03			
33 kv SARAI JULLENA GRID	SSJNA103	11kv FDR NFC. S/S NO.-5	542OKH-OKH042A	990	COMMERCIAL	AMR	Functional	100%	70	0.42	1.67	0.36	17.84%

33 KV SARAI JULLENA GRID	SSJNA101	11kv FDR DDA FLATS S. JULENA	2542KCL-KAL001A-	400	COMMERCIAL	AMR	Functional	100%	82	0.16			
33 KV SARAI JULLENA GRID	SSJNA101	11kv FDR DDA FLATS S. JULENA	2542KCL-KAL030A-	990	COMMERCIAL		Functional	100%	87	0.15			
33 KV SARAI JULLENA GRID	SSJNA101	11kv FDR DDA FLATS S. JULENA	2542KCL-KAL030A-	990	COMMERCIAL	AMR	Functional	100%	112	0.15			
33 KV JAMIA MILLIA GRID	SJAMI103	11kv FDR O/G OKHLA VILLAGE	542OKH-OKH004A-	400	RESIDENTIAL	AMR	Functional	100%	169	0.21	0.27	0.00	1.49%
33 KV JAMIA MILLIA GRID	SJAMI103	11kv FDR O/G OKHLA VILLAGE	542OKH-OKH004A-	400	RESIDENTIAL	AMR	Functional	100%	96	0.07			
33 KV SARAI JULLENA GRID	SSJNA115	11kv FDR NFC. S/S NO.-3	2542KCL-KAL008A-	990	RESIDENTIAL		Functional	100%	1082	1.07	2.46	0.73	22.84%
33 KV SARAI JULLENA GRID	SSJNA115	11kv FDR NFC. S/S NO.-3	2542KCL-KAL009A-	990	COMMERCIAL	AMR	Functional	100%	333	0.86			
33 KV SARAI JULLENA GRID	SSJNA115	11kv FDR NFC. S/S NO.-3	2542KCL-KAL009A-	1600	RESIDENTIAL	AMR	Functional	100%	861	0.84			
33 KV SARAI JULLENA GRID	SSJNA115	11kv FDR NFC. S/S NO.-3	2542KCL-KAL073A-	990	COMMERCIAL	AMR	Functional	100%	123	0.41			
33 KV EAST OF KAILASH GRID	SKLSH102	11kv FDR SRINIWASHPURI	2542KCL-KAL051A-	990	MIXED	AMR	Functional	100%	1103	0.90	3.70	0.14	3.61%
33 KV EAST OF KAILASH GRID	SKLSH102	11kv FDR SRINIWASHPURI	2542KCL-KAL051A-	990	MIXED	AMR	Functional	100%	1139	0.80			
33 KV EAST OF KAILASH GRID	SKLSH102	11kv FDR SRINIWASHPURI	2542KCL-KAL052A-	990	MIXED	AMR	Functional	100%	993	0.65			
33 KV EAST OF KAILASH GRID	SKLSH102	11kv FDR SRINIWASHPURI	2542KCL-KAL052A-	990	MIXED	AMR	Functional	100%	475	0.57			
33 KV EAST OF KAILASH GRID	SKLSH102	11kv FDR SRINIWASHPURI	2542KCL-KAL051A-	630	RESIDENTIAL		Functional	100%	0	0.44			
33 KV EAST OF KAILASH GRID	SKLSH102	11kv FDR SRINIWASHPURI	2542KCL-KAL053A-	630	MIXED		Functional	100%	599	0.31			
33 KV EAST OF KAILASH GRID	SKLSH102	11kv FDR SRINIWASHPURI	2542KCL-KAL053A-	400	MIXED		Functional	100%	185	0.17			
33 KV JAMIA MILLIA GRID	SJAMI101	11kv FDR O/G GAFFAR MANZIL	542OKH-OKH025A-	990	RESIDENTIAL	AMR	Functional	100%	1052	0.67	1.40	0.22	13.83%
33 KV JAMIA MILLIA GRID	SJAMI101	11kv FDR O/G GAFFAR MANZIL	542OKH-OKH025A-	990	RESIDENTIAL	AMR	Functional	100%	683	0.65			
33 KV JAMIA MILLIA GRID	SJAMI101	11kv FDR O/G GAFFAR MANZIL	542OKH-OKH009A-	400	RESIDENTIAL	AMR	Functional	100%	169	0.31			
33 KV JAMIA MILLIA GRID	SJAMI119	11kv FDR O/G OKHLA VIHAR MASJID	542OKH-OKH048A-	1600	COMMERCIAL	AMR	Functional	100%	1647	1.12	3.07	0.59	16.08%
33 KV JAMIA MILLIA GRID	SJAMI119	11kv FDR O/G OKHLA VIHAR MASJID	542OKH-OKH047A-	990	COMMERCIAL	AMR	Functional	100%	1526	0.87			
33 KV JAMIA MILLIA GRID	SJAMI119	11kv FDR O/G OKHLA VIHAR MASJID	542OKH-OKH037A-	990	COMMERCIAL	AMR	Functional	100%	1092	0.72			
33 KV JAMIA MILLIA GRID	SJAMI119	11kv FDR O/G OKHLA VIHAR MASJID	542OKH-OKH047A-	990	RESIDENTIAL	AMR	Functional	100%	0	0.54			
33 KV JAMIA MILLIA GRID	SJAMI119	11kv FDR O/G OKHLA VIHAR MASJID	542OKH-OKH037A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.41			
33 KV JAMIA MILLIA GRID	SJAMI109	11kv FDR O/G NOOR NAGAR	542OKH-OKH014A-	990	RESIDENTIAL	AMR	Functional	100%	727	0.88	2.66	0.54	16.82%
33 KV JAMIA MILLIA GRID	SJAMI109	11kv FDR O/G NOOR NAGAR	542OKH-OKH014A-	1000	RESIDENTIAL	AMR	Functional	100%	922	0.81			
33 KV JAMIA MILLIA GRID	SJAMI109	11kv FDR O/G NOOR NAGAR	542OKH-OKH034A-	990	RESIDENTIAL	AMR	Functional	100%	95	0.57			
33 KV JAMIA MILLIA GRID	SJAMI109	11kv FDR O/G NOOR NAGAR	542OKH-OKH055A-	630	RESIDENTIAL	AMR	Functional	100%	730	0.56			
33 KV JAMIA MILLIA GRID	SJAMI109	11kv FDR O/G NOOR NAGAR	542OKH-OKH055A-	400	RESIDENTIAL		Functional	100%	0	0.20			
33 KV JAMIA MILLIA GRID	SJAMI109	11kv FDR O/G NOOR NAGAR	542OKH-OKH055A-	400	RESIDENTIAL	AMR	Functional	100%	193	0.18			
66 KV JASOLA GRID	SJASL117	11kv FDR O/G SPORTS COMPLEX JASOLA	2542ABF-AFZ033A-	990	MIXED	AMR	Functional	100%	681	1.01	4.42	0.32	6.72%
66 KV JASOLA GRID	SJASL117	11kv FDR O/G SPORTS COMPLEX JASOLA	2542ABF-AFZ039A-	990	RESIDENTIAL	AMR	Functional	100%	151	0.78			
66 KV JASOLA GRID	SJASL117	11kv FDR O/G SPORTS COMPLEX JASOLA	2542ABF-AFZ067A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.75			
66 KV JASOLA GRID	SJASL117	11kv FDR O/G SPORTS COMPLEX JASOLA	2542ABF-AFZ067A-	990	RESIDENTIAL	AMR	Functional	100%	1131	0.73			
66 KV JASOLA GRID	SJASL117	11kv FDR O/G SPORTS COMPLEX JASOLA	2542ABF-AFZ011A-	630	MIXED	AMR	Functional	100%	1126	0.65			
66 KV JASOLA GRID	SJASL117	11kv FDR O/G SPORTS COMPLEX JASOLA	2542ABF-AFZ115A-	630	RESIDENTIAL	AMR	Functional	100%	88	0.43			
66 KV JASOLA GRID	SJASL117	11kv FDR O/G SPORTS COMPLEX JASOLA	2542ABF-AFZ068A-	400	RESIDENTIAL	AMR	Functional	100%	242	0.20			
66 KV JASOLA GRID	SJASL117	11kv FDR O/G SPORTS COMPLEX JASOLA	2542ABF-AFZ029A-	400	MIXED	AMR	Functional	100%	42	0.18			
33 KV JAMIA MILLIA GRID	SJAMI120	11kv FDR O/G TO P BLOCK NAFEEZ ROAD	542OKH-OKH036A-	990	RESIDENTIAL	AMR	Functional	100%	335	1.15	4.15	2.38	36.45%
33 KV JAMIA MILLIA GRID	SJAMI120	11kv FDR O/G TO P BLOCK NAFEEZ ROAD	542OKH-OKH082A-	990	RESIDENTIAL		Functional	100%	141	0.90			
33 KV JAMIA MILLIA GRID	SJAMI120	11kv FDR O/G TO P BLOCK NAFEEZ ROAD	542OKH-OKH080A-	990	RESIDENTIAL	AMR	Functional	100%	0	0.77			
33 KV JAMIA MILLIA GRID	SJAMI115	11kv FDR JAMIA STADIUM	542OKH-OKH056A-	990	RESIDENTIAL	AMR	Functional	100%	1721	0.66			
33 KV JAMIA MILLIA GRID	SJAMI115	11kv FDR JAMIA STADIUM	542OKH-OKH056A-	990	RESIDENTIAL	AMR	Functional	100%	0	0.65			
33 KV JAMIA MILLIA GRID	SJAMI120	11kv FDR O/G TO P BLOCK NAFEEZ ROAD	542OKH-OKH082A-	990	RESIDENTIAL		Functional	100%	0	0.56			
33 KV JAMIA MILLIA GRID	SJAMI120	11kv FDR O/G TO P BLOCK NAFEEZ ROAD	542OKH-OKH080A-	990	RESIDENTIAL	AMR	Functional	100%	372	0.55			
33 KV JAMIA MILLIA GRID	SJAMI115	11kv FDR JAMIA STADIUM	542OKH-OKH088A-	400	RESIDENTIAL	AMR	Functional	100%	176	0.41			
33 KV JAMIA MILLIA GRID	SJAMI115	11kv FDR JAMIA STADIUM	542OKH-OKH088A-	400	RESIDENTIAL	AMR	Functional	100%	0	0.33			
33 KV JAMIA MILLIA GRID	SJAMI115	11kv FDR JAMIA STADIUM	542OKH-OKH089A-	400	RESIDENTIAL	AMR	Functional	100%	0	0.29			
33 KV JAMIA MILLIA GRID	SJAMI115	11kv FDR JAMIA STADIUM	542OKH-OKH089A-	400	RESIDENTIAL	AMR	Functional	100%	114	0.27			
33 KV JAMIA MILLIA GRID	SJAMI115	11kv FDR JAMIA STADIUM	542OKH-OKH054A-	2000	MIXED	AMR	Functional	100%	1581	1.34	6.55	0.69	9.49%

33 kv JAMIA MILLIA GRID	SJAMI115	11kv FDR JAMIA STADIUM	542OKH-OKH054A	1600	MIXED	AMR	Functional	100%	2276	1.25			
33 kv SARAI JULLENA GRID	SSJNA102	11kv FDR ESCORTS HEART INST.-2	542OKH-OKH072A	990	RESIDENTIAL		Functional	100%	0	0.99			
33 kv JAMIA MILLIA GRID	SJAMI115	11kv FDR JAMIA STADIUM	542OKH-OKH054A	990	MIXED	AMR	Functional	100%	2448	0.97			
33 kv SARAI JULLENA GRID	SSJNA102	11kv FDR ESCORTS HEART INST.-2	542OKH-OKH015A	990	MIXED	AMR	Functional	100%	821	0.77			
33 kv SARAI JULLENA GRID	SSJNA102	11kv FDR ESCORTS HEART INST.-2	542OKH-OKH072A	990	RESIDENTIAL	AMR	Functional	100%	383	0.75			
33 kv SARAI JULLENA GRID	SSJNA102	11kv FDR ESCORTS HEART INST.-2	542OKH-OKH015A	990	MIXED	AMR	Functional	100%	1964	0.73			
33 kv JAMIA MILLIA GRID	SJAMI111	11kv FDR O/G SANJAY JHEEL	542OKH-OKH076A	630	RESIDENTIAL	AMR	Functional	100%	120	0.43			
66 kv J.N.U GRID	SJNUG105	11kv FDR O/G HOTEL SIDDHARTHA VASANT LOK VASANT VIHAR	TI-VVR068A-2	630	COMMERCIAL		Functional	100%	463	0.24	1.53	0.26	14.52%
66 kv J.N.U GRID	SJNUG105	11kv FDR O/G HOTEL SIDDHARTHA VASANT LOK VASANT VIHAR	TI-VVR068A-1	990	RESIDENTIAL		Functional	100%	237	0.20			
66 kv J.N.U GRID	SJNUG107	11kv FDR SFS VASANT VIHAR	TI-VVR069A-1	630	COMMERCIAL		Functional	100%	223	0.20			
66 kv J.N.U GRID	SJNUG105	11kv FDR O/G HOTEL SIDDHARTHA VASANT LOK VASANT VIHAR	TI-VVR067A-2	630	COMMERCIAL		Functional	100%	266	0.15			
66 kv J.N.U GRID	SJNUG105	11kv FDR O/G HOTEL SIDDHARTHA VASANT LOK VASANT VIHAR	TI-VVR067A-1	630	COMMERCIAL		Functional	100%	138	0.14			
66 kv J.N.U GRID	SJNUG107	11kv FDR SFS VASANT VIHAR	TI-VVR065A-1	630	COMMERCIAL		Functional	100%	114	0.12			
66 kv J.N.U GRID	SJNUG107	11kv FDR SFS VASANT VIHAR	TI-VVR066A-1	400	COMMERCIAL		Functional	100%	59	0.07			
66 kv J.N.U GRID	SJNUG107	11kv FDR SFS VASANT VIHAR	TI-VVR069A-2	630	COMMERCIAL		Functional	100%	248	0.07			
33 kv R.K.PURAM - 2 GRID	SRKP2129	11kv FDR 3W O/D RMU INSIDE GRID	550RKP-RKZ174A-	990	RESIDENTIAL		Functional	100%	212	0.20			
33 kv R.K.PURAM - 2 GRID	SRKP2129	11kv FDR 3W O/D RMU INSIDE GRID	550RKP-RKZ175A-	990	MIXED		Functional	100%	24	0.16			
33 kv R.K.PURAM - 2 GRID	SRKP2129	11kv FDR 3W O/D RMU INSIDE GRID	550RKP-RKZ176A-	990	COMMERCIAL		Functional	100%	86	0.13			
33 kv R.K.PURAM - 2 GRID	SRKP2129	11kv FDR 3W O/D RMU INSIDE GRID	550RKP-RKZ175A-	990	MIXED		Functional	100%	194	0.11			
33 kv R.K.PURAM - 2 GRID	SRKP2129	11kv FDR 3W O/D RMU INSIDE GRID	550RKP-RKZ176A-	990	MIXED		Functional	100%	66	0.00			
33 kv R.K.PURAM - 2 GRID	SRKP2129	11kv FDR 3W O/D RMU INSIDE GRID	550RKP-RKZ174A-	990	MIXED		Functional	100%	80	0.00			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM127	11kv FDR N.B.C.C.TOWER	TI-RKZ003A-1	630	COMMERCIAL		Functional	100%	8	0.22	1.99	0.09	4.38%
33 kv BHIKAJI CAMA PLACE GRID	SBKCM127	11kv FDR N.B.C.C.TOWER	TI-RKZ003A-2	630	COMMERCIAL		Functional	100%	10	0.17			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM117	11kv FDR PLOT NO.-6, B.C PLACE	TI-RKZ026A-2	630	COMMERCIAL		Functional	100%	96	0.17			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM102	11kv FDR B.C PLACE S/S NO.-3	TI-RKZ025A-2	990	COMMERCIAL		Functional	100%	147	0.17			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM115	11kv FDR PLOT NO.-11, B.C PLACE	TI-RKZ028A-1	990	COMMERCIAL		Functional	100%	33	0.16			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM114	11kv FDR S/S NO.-5, B.C PLACE	TI-RKZ023A-2	630	COMMERCIAL		Functional	100%	185	0.14			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM117	11kv FDR PLOT NO.-6, B.C PLACE	TI-RKZ027A-2	630	COMMERCIAL		Functional	100%	130	0.14			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM102	11kv FDR B.C PLACE S/S NO.-3	TI-RKZ025A-1	630	COMMERCIAL		Functional	100%	166	0.14			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM114	11kv FDR S/S NO.-5, B.C PLACE	TI-RKZ023A-1	630	COMMERCIAL		Functional	100%	158	0.13			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM117	11kv FDR PLOT NO.-6, B.C PLACE	TI-RKZ026A-1	630	COMMERCIAL		Functional	100%	117	0.13			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM115	11kv FDR PLOT NO.-11, B.C PLACE	TI-RKZ028A-2	990	COMMERCIAL		Functional	100%	73	0.12			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM117	11kv FDR PLOT NO.-6, B.C PLACE	TI-RKZ027A-1	630	COMMERCIAL		Functional	100%	226	0.11			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM117	11kv FDR PLOT NO.-6, B.C PLACE	TI-RKZ026A-3	630	COMMERCIAL		Functional	100%	164	0.08			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM117	11kv FDR PLOT NO.-6, B.C PLACE	TI-RKZ027A-3	630	COMMERCIAL		Functional	100%	15	0.07			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM102	11kv FDR B.C PLACE S/S NO.-3	TI-RKZ024A-1	630	COMMERCIAL		Functional	100%	8	0.04			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM114	11kv FDR S/S NO.-5, B.C PLACE	TI-RKZ022A-1	630	COMMERCIAL		Functional	100%	32	0.02			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM120	11kv STR 100kVA STATION TRANSFORMER	RK-STC069A-1	100	RESIDENTIAL		Functional	100%	1	0.02			
33 kv R.K.PURAM - 2 GRID	SRKP2115	11kv STR 100kVA STATION TRANSFORMER	550RKP-STC095A-	100	RESIDENTIAL		Functional	100%	0	0.02			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM107	11 kv PLOT NO-16 (GAIL)	TI-RKZ019A-1	400	COMMERCIAL		Functional	100%	19	0.02			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM107	11 kv PLOT NO-16 (GAIL)	TI-RKZ019A-2	400	COMMERCIAL		Functional	100%	8	0.01			
33 kv R.K.PURAM - 1 GRID	SRKP1118	11kv STR 100kVA STATION TRF NO.-1	RK-STC094A-1	100	RESIDENTIAL		Functional	100%	1	0.01			
33 kv R.K.PURAM - 2 GRID	SRKP2115	11kv STR 100kVA STATION TRANSFORMER	550RKP-STC095A-	100	RESIDENTIAL		Functional	100%	1	0.00			
33 kv R.K.PURAM - 2 GRID	SRKP2120	11kv FDR O/G SEWA BHAWAN	TG-RKZ158A-1	630	RESIDENTIAL		Functional	100%	994	0.48	0.87	0.03	3.48%
33 kv R.K.PURAM - 2 GRID	SRKP2120	11kv FDR O/G SEWA BHAWAN	TG-VVR021A-1	630	RESIDENTIAL		Functional	100%	252	0.37			
33 kv R.K.PURAM - 2 GRID	SRKP2109	11kv FDR O/G R.K PURAM SECTOR-7	TG-VVR100A-1	400	RESIDENTIAL		Functional	100%	2	0.03			
33 kv R.K.PURAM - 1 GRID	SRKP1105	11kv FDR O/G R.K PURAM WEST BLOCK	TP-VVR130A-1	100	RESIDENTIAL		Functional	100%	22	0.02			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM126	11kv FDR MOHAMEDPUR VILLAGE	TG-RKZ001A-1	990	RESIDENTIAL		Functional	100%	385	0.51	3.42	0.16	4.40%
33 kv BHIKAJI CAMA PLACE GRID	SBKCM126	11kv FDR MOHAMEDPUR VILLAGE	TG-RKZ008A-1	630	RESIDENTIAL		Functional	100%	424	0.50			
33 kv R.K.PURAM - 2 GRID	SRKP2122	11kv FDR O/G S/S NO.-1, SECTOR-1, R.K PURAM	TG-RKZ165A-1	630	RESIDENTIAL		Functional	100%	884	0.50			

33 kv BHIKAJI CAMA PLACE GRID	SBKCM126	11kv FDR MOHAMEDPUR VILLAGE	TG-RKZ008A-2	630	RESIDENTIAL	Functional	100%	606	0.47			
33 kv R.K.PURAM - 2 GRID	SRKP2122	11kv FDR O/G S/S NO.-1, SECTOR-1, R.K PURAM	TX-RKZ051A-1	990	RESIDENTIAL	Functional	100%	708	0.46			
33 kv R.K.PURAM - 2 GRID	SRKP2122	11kv FDR O/G S/S NO.-1, SECTOR-1, R.K PURAM	TI-RKZ029A-2	630	RESIDENTIAL	Functional	100%	292	0.43			
33 kv R.K.PURAM - 2 GRID	SRKP2122	11kv FDR O/G S/S NO.-1, SECTOR-1, R.K PURAM	TI-RKZ029A-1	630	RESIDENTIAL	Functional	100%	471	0.37			
33 kv R.K.PURAM - 2 GRID	SRKP2122	11kv FDR O/G S/S NO.-1, SECTOR-1, R.K PURAM	550RKP-RK2165A-	630	RESIDENTIAL	Functional	100%	0	0.34			
33 kv R.K.PURAM - 2 GRID	SRKP2114	11kv FDR NIVEDITA KUNJ S/S NO.-1	TI-VVR080A-2	400	MIXED	Functional	100%	46	0.11	0.79	0.01	1.36%
33 kv R.K.PURAM - 2 GRID	SRKP2111	11kv FDR O/G NIVEDITA KUNJ S/S NO-2	TI-VVR081A-2	630	MIXED	Functional	100%	78	0.10			
33 kv R.K.PURAM - 2 GRID	SRKP2114	11kv FDR NIVEDITA KUNJ S/S NO.-1	TI-VVR080A-1	400	MIXED	Functional	100%	120	0.08			
33 kv R.K.PURAM - 1 GRID	SRKP1108	11kv FDR O/G SCIENTIFIC HOSTEL	TI-VVR011A-1	630	MIXED	Functional	100%	105	0.08			
33 kv R.K.PURAM - 2 GRID	SRKP2110	11kv FDR NIVEDITA KUNJ S/S NO.-5	TI-VVR084A-2	630	MIXED	Functional	100%	118	0.06			
33 kv R.K.PURAM - 2 GRID	SRKP2111	11kv FDR O/G NIVEDITA KUNJ S/S NO-2	TI-VVR081A-1	630	MIXED	Functional	100%	29	0.06			
33 kv R.K.PURAM - 2 GRID	SRKP2110	11kv FDR NIVEDITA KUNJ S/S NO.-5	TI-VVR084A-1	630	MIXED	Functional	100%	57	0.05			
33 kv R.K.PURAM - 2 GRID	SRKP2114	11kv FDR NIVEDITA KUNJ S/S NO.-1	TI-VVR082A-2	400	MIXED	Functional	100%	92	0.05			
33 kv R.K.PURAM - 2 GRID	SRKP2110	11kv FDR NIVEDITA KUNJ S/S NO.-5	TI-VVR083A-2	400	MIXED	Functional	100%	112	0.05			
33 kv R.K.PURAM - 2 GRID	SRKP2111	11kv FDR O/G NIVEDITA KUNJ S/S NO-2	TI-VVR085A-2	400	MIXED	Functional	100%	90	0.04			
33 kv R.K.PURAM - 1 GRID	SRKP1108	11kv FDR O/G SCIENTIFIC HOSTEL	TI-VVR011A-2	630	MIXED	Functional	100%	87	0.04			
33 kv R.K.PURAM - 2 GRID	SRKP2111	11kv FDR O/G NIVEDITA KUNJ S/S NO-2	TI-VVR085A-1	400	MIXED	Functional	100%	15	0.04			
33 kv R.K.PURAM - 2 GRID	SRKP2110	11kv FDR NIVEDITA KUNJ S/S NO.-5	TI-VVR083A-1	400	MIXED	Functional	100%	31	0.03			
33 kv R.K.PURAM - 2 GRID	SRKP2114	11kv FDR NIVEDITA KUNJ S/S NO.-1	TI-VVR082A-1	400	MIXED	Functional	100%	42	0.00			
33 kv R.K.PURAM - 1 GRID	SRKP1104	11kv FDR O/G MUNRIKA (DDA FLAT)	TI-RKZ013A-2	990	MIXED	Functional	100%	300	0.62	4.56	0.19	3.96%
33 kv R.K.PURAM - 1 GRID	SRKP1104	11kv FDR O/G MUNRIKA (DDA FLAT)	TI-RKZ013A-1	990	MIXED	Functional	100%	231	0.59			
33 kv R.K.PURAM - 2 GRID	SRKP2113	11kv FDR O/G CANERA BANK	TI-RKZ015A-2	990	MIXED	Functional	100%	581	0.53			
33 kv R.K.PURAM - 1 GRID	SRKP1104	11kv FDR O/G MUNRIKA (DDA FLAT)	TP-VVR138A-1	630	MIXED	Functional	100%	859	0.46			
66 kv J.N.U GRID	SJNUG104	11kv FDR O/G DDA FLATS MUNREKA S/S NO.¿III	TI-RKZ013A-3	990	MIXED	Functional	100%	1057	0.41			
33 kv R.K.PURAM - 1 GRID	SRKP1104	11kv FDR O/G MUNRIKA (DDA FLAT)	TI-RKZ016A-1	990	MIXED	Functional	100%	258	0.33			
33 kv R.K.PURAM - 2 GRID	SRKP2113	11kv FDR O/G CANERA BANK	TI-RKZ015A-1	630	MIXED	Functional	100%	77	0.31			
66 kv J.N.U GRID	SJNUG104	11kv FDR O/G DDA FLATS MUNREKA S/S NO.¿III	TI-RKZ018A-1	990	MIXED	Functional	100%	68	0.30			
33 kv R.K.PURAM - 1 GRID	SRKP1104	11kv FDR O/G MUNRIKA (DDA FLAT)	TI-RKZ017A-2	990	MIXED	Functional	100%	305	0.28			
66 kv J.N.U GRID	SJNUG108	11kv FDR BUDH VIHAR O/H VIA 3WAY O/D RMU INSTALLED AT GRID	TI-RKZ018A-2	630	MIXED	Functional	100%	639	0.27			
66 kv J.N.U GRID	SJNUG104	11kv FDR O/G DDA FLATS MUNREKA S/S NO.¿III	TI-RKZ017A-1	500	MIXED	Functional	100%	182	0.27			
33 kv R.K.PURAM - 1 GRID	SRKP1104	11kv FDR O/G MUNRIKA (DDA FLAT)	TI-RKZ016A-2	630	MIXED	Functional	100%	154	0.20			
66 kv J.N.U GRID	SJNUG108	11kv FDR BUDH VIHAR O/H VIA 3WAY O/D RMU INSTALLED AT GRID	TI-RKZ031A-2	630	MIXED	Functional	100%	53	0.07			
33 kv I.I.T. GRID	SIITG112	11kv FDR O/G FSI MUNERKA JNU OLD CAMPUS	TI-RKZ004A-1	630	MIXED	Functional	100%	152	0.06			
66 kv J.N.U GRID	SJNUG108	11kv FDR BUDH VIHAR O/H VIA 3WAY O/D RMU INSTALLED AT GRID	TI-RKZ031A-1	630	MIXED	Functional	100%	121	0.05			
220/66/33/11 kv RIDGE VALLEY GRID	SRVAL110	11kv FDR MOTI BAGH	TI-VVR022A-1	990	MIXED	Functional	100%	1131	0.85	3.22	0.22	6.28%
220/66/33/11 kv RIDGE VALLEY GRID	SRVAL105	11kv FDR SOUTH CAMPUS NEW	TX-VVR091A-1	990	RESIDENTIAL	Functional	100%	533	0.51			
220/66/33/11 kv RIDGE VALLEY GRID	SRVAL110	11kv FDR MOTI BAGH	TX-VVR033A-1	990	RESIDENTIAL	Functional	100%	422	0.41			
220/66/33/11 kv RIDGE VALLEY GRID	SRVAL105	11kv FDR SOUTH CAMPUS NEW	TX-VVR023A-1	990	RESIDENTIAL	Functional	100%	368	0.39			
220/66/33/11 kv RIDGE VALLEY GRID	SRVAL136	11kv FDR VENKTESHWAR COLLEGE	TX-VVR078A-1	990	RESIDENTIAL	Functional	100%	267	0.34			
220/66/33/11 kv RIDGE VALLEY GRID	SRVAL105	11kv FDR SOUTH CAMPUS NEW	TI-VVR032A-2	990	RESIDENTIAL	Functional	100%	291	0.33			
220/66/33/11 kv RIDGE VALLEY GRID	SRVAL105	11kv FDR SOUTH CAMPUS NEW	TI-VVR032A-1	630	RESIDENTIAL	Functional	100%	639	0.32			
220/66/33/11 kv RIDGE VALLEY GRID	SRVAL110	11kv FDR MOTI BAGH	TX-VVR089A-1	990	RESIDENTIAL	Functional	100%	323	0.29			
33 kv VASANT VIHAR GRID	SVVHR110	11kv FDR O/G SUBROTO PARK (MES)	TG-VVR030A-1	990	MIXED	Functional	100%	701	0.74	2.19	0.32	12.84%
33 kv VASANT VIHAR GRID	SVVHR110	11kv FDR O/G SUBROTO PARK (MES)	TG-VVR140A-2	990	RESIDENTIAL	Functional	100%	144	0.70			
33 kv VASANT VIHAR GRID	SVVHR110	11kv FDR O/G SUBROTO PARK (MES)	TG-VVR030A-2	630	RESIDENTIAL	Functional	100%	441	0.48			
33 kv VASANT VIHAR GRID	SVVHR110	11kv FDR O/G SUBROTO PARK (MES)	TG-VVR140A-1	630	MIXED	Functional	100%	932	0.32			

33 kV VASANT VIHAR GRID	SVVHR110	11kV FDR O/G SUBROTO PARK (MES)	550MBG-VVR183A	400	RESIDENTIAL		Functional	100%	204	0.26			
33 kV VASANT VIHAR GRID	SVVHR110	11kV FDR O/G SUBROTO PARK (MES)	TP-VVR096A-1	400	MIXED		Functional	100%	4	0.26	0.64	0.02	3.67%
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL108	11kV FDR ST. LTG. NO.-1	TP-VVR027A-1	250	COMMERCIAL		Functional	100%	3	0.13			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL108	11kV FDR ST. LTG. NO.-1	TP-VVR039A-1	400	MIXED		Functional	100%	2	0.07			
33 kV VASANT VIHAR GRID	SVVHR110	11kV FDR O/G SUBROTO PARK (MES)	TP-VVR142A-1	250	COMMERCIAL		Functional	100%	5	0.06			
33 kV VASANT VIHAR GRID	SVVHR110	11kV FDR O/G SUBROTO PARK (MES)	TP-VVR040A-1	100	MIXED		Functional	100%	6	0.06			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL128	11kV FDR PWD FLYOVER DHOLAKAUN	TP-VVR171A-1	250	RESIDENTIAL		Functional	100%	0	0.04			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL108	11kV FDR ST. LTG. NO.-1	TP-VVR038A-1	100	COMMERCIAL		Functional	100%	5	0.03			
33 kV VASANT VIHAR GRID	SVVHR110	11kV FDR O/G SUBROTO PARK (MES)	TP-VVR029A-1	100	MIXED		Functional	100%	46	0.01			
33 kV VASANT VIHAR GRID	SVVHR119	11kV FDR O/G BASANT LOK COMM. CENTER	TG-VVR062A-2	990	COMMERCIAL		Functional	100%	41	0.52	2.02	0.10	4.57%
66 kV J.N.U GRID	SJNUG103	11kV FDR VASANT LOK	TI-VVR061A-2	990	COMMERCIAL		Functional	100%	93	0.43			
33 kV VASANT VIHAR GRID	SVVHR119	11kV FDR O/G BASANT LOK COMM. CENTER	TX-VVR064A-1	990	COMMERCIAL		Functional	100%	34	0.35			
33 kV VASANT VIHAR GRID	SVVHR119	11kV FDR O/G BASANT LOK COMM. CENTER	TX-VVR063A-1	990	COMMERCIAL		Functional	100%	28	0.24			
66 kV J.N.U GRID	SJNUG103	11kV FDR VASANT LOK	TI-VVR061A-3	630	COMMERCIAL		Functional	100%	53	0.22			
66 kV J.N.U GRID	SJNUG103	11kV FDR VASANT LOK	TI-VVR061A-1	990	COMMERCIAL		Functional	100%	35	0.20			
33 kV VASANT VIHAR GRID	SVVHR119	11kV FDR O/G BASANT LOK COMM. CENTER	TG-VVR062A-1	990	COMMERCIAL		Functional	100%	22	0.16			
33 kV R.K.PURAM - 1 GRID	SRKP1101	11kV FDR O/G TO R.K PURAM SECTOR-6	TI-VVR006A-1	990	RESIDENTIAL		Functional	100%	769	0.65	2.46	0.17	6.53%
33 kV R.K.PURAM - 2 GRID	SRKP2112	11kV FDR O/G SECTOR-4 R.K PURAM	TI-VVR001A-2	630	RESIDENTIAL		Functional	100%	159	0.35			
33 kV R.K.PURAM - 1 GRID	SRKP1101	11kV FDR O/G TO R.K PURAM SECTOR-6	TI-VVR005A-1	630	RESIDENTIAL		Functional	100%	392	0.32			
33 kV R.K.PURAM - 1 GRID	SRKP1101	11kV FDR O/G TO R.K PURAM SECTOR-6	TI-VVR004A-1	630	RESIDENTIAL		Functional	100%	276	0.30			
33 kV R.K.PURAM - 1 GRID	SRKP1105	11kV FDR O/G R.K PURAM WEST BLOCK	TP-RK2150A-1	630	COMMERCIAL		Functional	100%	90	0.29			
33 kV R.K.PURAM - 2 GRID	SRKP2112	11kV FDR O/G SECTOR-4 R.K PURAM	TX-VVR002A-1	990	RESIDENTIAL		Functional	100%	549	0.28			
33 kV R.K.PURAM - 1 GRID	SRKP1101	11kV FDR O/G TO R.K PURAM SECTOR-6	TI-VVR001A-1	630	RESIDENTIAL		Functional	100%	931	0.24			
33 kV R.K.PURAM - 1 GRID	SRKP1101	11kV FDR O/G TO R.K PURAM SECTOR-6	TP-RK2159A-1	400	RESIDENTIAL		Functional	100%	290	0.19			
33 kV R.K.PURAM - 1 GRID	SRKP1110	11kV FDR O/G R.K PURAM EAST BLOCK	TP-VVR131A-1	100	RESIDENTIAL		Functional	100%	11	0.01			
33 kV R.K.PURAM - 1 GRID	SRKP1105	11kV FDR O/G R.K PURAM WEST BLOCK	TP-VVR127A-1	100	RESIDENTIAL		Functional	100%	4	0.01			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL106	11kV FDR ARSD COLLEGE	TG-VVR036A-2	990	COMMERCIAL		Functional	100%	624	0.85	4.31	0.06	1.46%
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL637	11kV FDR GURUDWARA MOTIBAGH	TX-VVR043A-1	990	RESIDENTIAL		Functional	100%	907	0.69			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL106	11kV FDR ARSD COLLEGE	TX-VVR090A-1	990	COMMERCIAL		Functional	100%	677	0.68			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL106	11kV FDR ARSD COLLEGE	TG-VVR036A-1	990	COMMERCIAL		Functional	100%	398	0.64			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL637	11kV FDR GURUDWARA MOTIBAGH	TX-VVR035A-1	990	COMMERCIAL		Functional	100%	498	0.62			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL637	11kV FDR GURUDWARA MOTIBAGH	TP-VVR043A-2	400	RESIDENTIAL		Functional	100%	354	0.36			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL106	11kV FDR ARSD COLLEGE	550MBG-VVR184A	400	MIXED		Functional	100%	0	0.18			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL106	11kV FDR ARSD COLLEGE	TI-VVR034A-1	630	COMMERCIAL		Functional	100%	46	0.16			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL136	11kV FDR VENKTESHWAR COLLEGE	TI-VVR124A-1	400	RESIDENTIAL		Functional	100%	5	0.09			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL105	11kV FDR SOUTH CAMPUS NEW	TI-VVR031A-1	400	COMMERCIAL		Functional	100%	1	0.06			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL104	11kV STR 400kVA STATION TRANS.	TG-STC096A-2	400	COMMERCIAL		Functional	100%	1	0.03			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL137	11kV STR 630kVA STATION TRANS.	TG-STC096A-1	630	MIXED		Functional	100%	0	0.01			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL106	11kV FDR ARSD COLLEGE	550MBG-VVR090A	400	MIXED		Functional	100%	0	0.00			
33 kV R.K.PURAM - 1 GRID	SRKP1113	11kV FDR O/G TO R.K PURAM SECTOR-12	TI-VVR013A-1	630	RESIDENTIAL		Functional	100%	645	0.50	2.16	0.20	8.48%
33 kV R.K.PURAM - 1 GRID	SRKP1113	11kV FDR O/G TO R.K PURAM SECTOR-12	TI-VVR013A-2	990	RESIDENTIAL		Functional	100%	740	0.35			

33 kv R.K.PURAM - 1 GRID	SRKP1113	11kv FDR O/G TO R.K PURAM SECTOR-12	TI-VVR012A-1	990	RESIDENTIAL	Functional	100%	734	0.31			
33 kv R.K.PURAM - 1 GRID	SRKP1113	11kv FDR O/G TO R.K PURAM SECTOR-12	TI-VVR012A-2	630	RESIDENTIAL	Functional	100%	48	0.24			
33 kv R.K.PURAM - 1 GRID	SRKP1105	11kv FDR O/G R.K PURAM WEST BLOCK	TP-VVR099A-1	400	RESIDENTIAL	Functional	100%	32	0.22			
33 kv R.K.PURAM - 1 GRID	SRKP1113	11kv FDR O/G TO R.K PURAM SECTOR-12	TI-VVR016A-1	400	RESIDENTIAL	Functional	100%	194	0.20			
33 kv R.K.PURAM - 1 GRID	SRKP1113	11kv FDR O/G TO R.K PURAM SECTOR-12	550MBG-VVR176A	250	RESIDENTIAL	Functional	100%	61	0.13			
33 kv R.K.PURAM - 1 GRID	SRKP1113	11kv FDR O/G TO R.K PURAM SECTOR-12	TI-VVR014A-1	630	RESIDENTIAL	Functional	100%	197	0.13			
33 kv R.K.PURAM - 1 GRID	SRKP1113	11kv FDR O/G TO R.K PURAM SECTOR-12	550RKP-VVR013A	400	COMMERCIAL	Functional	100%	0	0.11			
33 kv R.K.PURAM - 1 GRID	SRKP1113	11kv FDR O/G TO R.K PURAM SECTOR-12	TI-VVR015A-1	630	RESIDENTIAL	Functional	100%	171	0.09			
33 kv R.K.PURAM - 1 GRID	SRKP1107	11kv FDR O/G TO R.K PURAM SECTOR-9	550RKP-VVR181A	400	RESIDENTIAL	Functional	100%	1	0.07			
33 kv R.K.PURAM - 2 GRID	SRKP2109	11kv FDR O/G R.K PURAM SECTOR-7	TI-VVR009A-2	990	RESIDENTIAL	Functional	100%	251	0.75	5.13	0.08	1.47%
33 kv R.K.PURAM - 2 GRID	SRKP2109	11kv FDR O/G R.K PURAM SECTOR-7	TX-VVR008A-1	990	MIXED	Functional	100%	932	0.74			
33 kv R.K.PURAM - 1 GRID	SRKP1107	11kv FDR O/G TO R.K PURAM SECTOR-9	TI-VVR010A-1	990	RESIDENTIAL	Functional	100%	1288	0.66			
33 kv R.K.PURAM - 2 GRID	SRKP2109	11kv FDR O/G R.K PURAM SECTOR-7	TI-VVR009A-1	990	RESIDENTIAL	Functional	100%	1030	0.56			
33 kv R.K.PURAM - 2 GRID	SRKP2109	11kv FDR O/G R.K PURAM SECTOR-7	TI-VVR007A-1	990	RESIDENTIAL	Functional	100%	947	0.55			
33 kv R.K.PURAM - 2 GRID	SRKP2109	11kv FDR O/G R.K PURAM SECTOR-7	TI-VVR007A-2	990	RESIDENTIAL	Functional	100%	224	0.52			
33 kv R.K.PURAM - 2 GRID	SRKP2109	11kv FDR O/G R.K PURAM SECTOR-7	TG-RK2157A-1	630	RESIDENTIAL	Functional	100%	852	0.38			
33 kv R.K.PURAM - 2 GRID	SRKP2109	11kv FDR O/G R.K PURAM SECTOR-7	TX-VVR115A-1	990	RESIDENTIAL	Functional	100%	511	0.31			
33 kv R.K.PURAM - 1 GRID	SRKP1108	11kv FDR O/G SCIENTIFIC HOSTEL	TP-RK2153A-1	400	RESIDENTIAL	Functional	100%	367	0.28			
33 kv R.K.PURAM - 1 GRID	SRKP1107	11kv FDR O/G TO R.K PURAM SECTOR-9	TG-VVR166A-1	630	RESIDENTIAL	Functional	100%	135	0.28			
33 kv R.K.PURAM - 2 GRID	SRKP2109	11kv FDR O/G R.K PURAM SECTOR-7	TP-VVR086A-1	400	MIXED	Functional	100%	199	0.18			
33 kv R.K.PURAM - 2 GRID	SRKP2112	11kv FDR O/G SECTOR-4 R.K PURAM	TI-RK2048A-2	990	RESIDENTIAL	Functional	100%	697	0.52	3.31	0.05	1.50%
33 kv R.K.PURAM - 1 GRID	SRKP1109	11kv FDR O/G J.N.U ACADEMEY	TI-RK2043A-1	990	RESIDENTIAL	Functional	100%	793	0.50			
33 kv R.K.PURAM - 1 GRID	SRKP1112	11kv FDR O/G SECTOR-2 R.K PURAM	TI-RK2010A-1	990	RESIDENTIAL	Functional	100%	817	0.49			
33 kv R.K.PURAM - 1 GRID	SRKP1109	11kv FDR O/G J.N.U ACADEMEY	TI-RK2043A-2	990	RESIDENTIAL	Functional	100%	378	0.49			
33 kv R.K.PURAM - 2 GRID	SRKP2112	11kv FDR O/G SECTOR-4 R.K PURAM	TI-RK2048A-1	990	RESIDENTIAL	Functional	100%	635	0.48			
33 kv R.K.PURAM - 2 GRID	SRKP2112	11kv FDR O/G SECTOR-4 R.K PURAM	TG-RK2042A-1	630	RESIDENTIAL	Functional	100%	450	0.30			
33 kv R.K.PURAM - 1 GRID	SRKP1109	11kv FDR O/G J.N.U ACADEMEY	TG-VVR169A-1	990	RESIDENTIAL	Functional	100%	169	0.21			
33 kv R.K.PURAM - 1 GRID	SRKP1110	11kv FDR O/G R.K PURAM EAST BLOCK	550RKP-RK2173A	400	RESIDENTIAL	Functional	100%	101	0.14			
33 kv R.K.PURAM - 1 GRID	SRKP1109	11kv FDR O/G J.N.U ACADEMEY	TG-RK2152A-2	400	RESIDENTIAL	Functional	100%	136	0.13			
33 kv R.K.PURAM - 1 GRID	SRKP1109	11kv FDR O/G J.N.U ACADEMEY	TP-RK2053A-1	400	RESIDENTIAL	Functional	100%	251	0.11			
33 kv R.K.PURAM - 2 GRID	SRKP2132	11 kv FDR CAR PARKING MUNIRKA	TX-RK2049A-1	1600	RESIDENTIAL	Functional	100%	730	1.15	9.75	0.45	4.37%
66 kv J.N.U GRID	SJNUG108	11kv FDR BUDH VIHAR O/H VIA 3WAY O/D RMU INSTALLED AT GRID	TG-RK2044A-1	990	RESIDENTIAL	Functional	100%	1327	0.89			
33 kv R.K.PURAM - 2 GRID	SRKP2113	11kv FDR O/G CANERA BANK	TG-RK2009A-3	990	RESIDENTIAL	Functional	100%	1281	0.87			
33 kv R.K.PURAM - 1 GRID	SRKP1104	11kv FDR O/G MUNRIKA (DDA FLAT)	TG-RK2169A-1	990	RESIDENTIAL	Functional	100%	391	0.83			
33 kv R.K.PURAM - 2 GRID	SRKP2113	11kv FDR O/G CANERA BANK	TG-RK2009A-2	990	RESIDENTIAL	Functional	100%	759	0.82			
33 kv R.K.PURAM - 2 GRID	SRKP2113	11kv FDR O/G CANERA BANK	TG-RK2009A-1	990	RESIDENTIAL	Functional	100%	230	0.74			
33 kv R.K.PURAM - 2 GRID	SRKP2132	11 kv FDR CAR PARKING MUNIRKA	TI-RK2014A-1	990	RESIDENTIAL	Functional	100%	603	0.71			
33 kv R.K.PURAM - 2 GRID	SRKP2132	11 kv FDR CAR PARKING MUNIRKA	TI-RK2012A-2	990	RESIDENTIAL	Functional	100%	467	0.66			
66 kv J.N.U GRID	SJNUG102	11kv FDR MUNREKA VIHAR	TX-RK2052A-1	990	RESIDENTIAL	Functional	100%	1015	0.61			
66 kv J.N.U GRID	SJNUG102	11kv FDR MUNREKA VIHAR	TI-RK2011A-2	990	RESIDENTIAL	Functional	100%	637	0.55			
66 kv J.N.U GRID	SJNUG102	11kv FDR MUNREKA VIHAR	TG-VVR152A-1	630	MIXED	Functional	100%	542	0.54			
66 kv J.N.U GRID	SJNUG108	11kv FDR BUDH VIHAR O/H VIA 3WAY O/D RMU INSTALLED AT GRID	TG-VVR154A-1	990	RESIDENTIAL	Functional	100%	1340	0.53			
66 kv J.N.U GRID	SJNUG102	11kv FDR MUNREKA VIHAR	TI-RK2011A-1	400	RESIDENTIAL	Functional	100%	710	0.44			
66 kv J.N.U GRID	SJNUG102	11kv FDR MUNREKA VIHAR	TI-RK2011A-3	990	RESIDENTIAL	Functional	100%	404	0.32			
DELHI JAL BOARD NAJAFGARH GRID SSTN	SJNUG108	11kv FDR ROSHAN PURA X-1 BLOCK	TG-RK2011B-2	990	RESIDENTIAL	Functional	100%	0	0.29			
33 kv R.K.PURAM - 2 GRID	SRKP2132	11 kv FDR CAR PARKING MUNIRKA	TI-RK2012A-1	630	RESIDENTIAL	Functional	100%	342	0.22			
66 kv J.N.U GRID	SJNUG102	11kv FDR MUNREKA VIHAR	TP-RK2054A-1	100	RESIDENTIAL	Functional	100%	5	0.02			
33 kv VASANT VIHAR GRID	SVVHR104	11kv FDR O/G WEST END COLONY	TI-VVR024A-2	990	MIXED	Functional	100%	128	0.66	3.35	0.05	1.45%
33 kv VASANT VIHAR GRID	SVVHR105	11kv FDR O/G TO ANAND NIKETAN	TI-VVR024A-1	990	MIXED	Functional	100%	243	0.62			
33 kv VASANT VIHAR GRID	SVVHR105	11kv FDR O/G TO ANAND NIKETAN	TX-VVR044A-1	990	MIXED	Functional	100%	132	0.57			

220/66/33/11 kV RIDGE VALLEY GRID	SRVAL110	11kV FDR MOTI BAGH	TI-VVR025A-1	990	MIXED		Functional	100%	173	0.56			
33 kV VASANT VIHAR GRID	SVVHR105	11kV FDR O/G TO ANAND NIKETAN	TX-VVR093A-1	990	MIXED		Functional	100%	154	0.46			
33 kV VASANT VIHAR GRID	SVVHR105	11kV FDR O/G TO ANAND NIKETAN	550MBG-VVR186A	630	MIXED		Functional	100%	0	0.35			
33 kV VASANT VIHAR GRID	SVVHR104	11kV FDR O/G WEST END COLONY	550MBG-VVR187A	250	MIXED		Functional	100%	0	0.14			
33 kV VASANT VIHAR GRID	SVVHR105	11kV FDR O/G TO ANAND NIKETAN	550MBG-VVR175A	250	RESIDENTIAL		Functional	100%	13	0.03			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL637	11kV FDR GURUDWARA MOTIBAGH	550MBG-VVR189A	400	MIXED		Functional	100%	0	0.01			
66 kV J.N.U GRID	SJNUG107	11kV FDR SFS VASANT VIHAR	TG-VVR079A-1	990	COMMERCIAL		Functional	100%	1885	0.71	2.31	0.20	7.80%
66 kV J.N.U GRID	SJNUG107	11kV FDR SFS VASANT VIHAR	TG-VVR134A-1	990	COMMERCIAL		Functional	100%	1317	0.56			
66 kV J.N.U GRID	SJNUG107	11kV FDR SFS VASANT VIHAR	550VVR-VVR079A	630	RESIDENTIAL		Functional	100%	0	0.43			
66 kV J.N.U GRID	SJNUG107	11kV FDR SFS VASANT VIHAR	TG-VVR164A-1	630	RESIDENTIAL		Functional	100%	748	0.43			
66 kV J.N.U GRID	SJNUG103	11kV FDR VASANT LOK	550VVR-VVR185A	400	MIXED		Functional	100%	0	0.18			
33 kV VASANT VIHAR GRID	SVVHR103	11kV FDR O/G F-BLOCK VASANT VIHAR	TI-VVR049A-2	630	MIXED		Functional	100%	167	0.07			
33 kV VASANT VIHAR GRID	SVVHR103	11kV FDR O/G F-BLOCK VASANT VIHAR	TI-VVR050A-2	630	MIXED		Functional	100%	252	0.03			
33 kV VASANT VIHAR GRID	SVVHR103	11kV FDR O/G F-BLOCK VASANT VIHAR	TI-VVR050A-1	400	MIXED		Functional	100%	61	0.03			
33 kV VASANT VIHAR GRID	SVVHR103	11kV FDR O/G F-BLOCK VASANT VIHAR	TI-VVR051A-2	630	MIXED		Functional	100%	105	0.02			
33 kV VASANT VIHAR GRID	SVVHR103	11kV FDR O/G F-BLOCK VASANT VIHAR	TI-VVR049A-1	400	MIXED		Functional	100%	167	0.02			
33 kV VASANT VIHAR GRID	SVVHR103	11kV FDR O/G F-BLOCK VASANT VIHAR	TI-VVR051A-3	630	MIXED		Functional	100%	15	0.01			
33 kV VASANT VIHAR GRID	SVVHR103	11kV FDR O/G F-BLOCK VASANT VIHAR	TI-VVR051A-1	630	MIXED		Functional	100%	7	0.01			
33 kV VASANT VIHAR GRID	SVVHR109	11kV FDR O/G VASANT ENCLAVE S/S NO.-2	TI-VVR045A-1	990	MIXED		Functional	100%	849	0.68	4.05	0.06	1.38%
33 kV VASANT VIHAR GRID	SVVHR111	11kV FDR O/G TO VASANT ENCLAVE NO.-1	TG-VVR128A-2	990	MIXED		Functional	100%	806	0.60			
33 kV VASANT VIHAR GRID	SVVHR111	11kV FDR O/G TO VASANT ENCLAVE NO.-1	TI-VVR046A-1	990	RESIDENTIAL		Functional	100%	604	0.58			
33 kV VASANT VIHAR GRID	SVVHR109	11kV FDR O/G VASANT ENCLAVE S/S NO.-2	TI-VVR047A-3	990	MIXED		Functional	100%	297	0.51			
33 kV VASANT VIHAR GRID	SVVHR111	11kV FDR O/G TO VASANT ENCLAVE NO.-1	TG-VVR128A-1	630	MIXED		Functional	100%	187	0.41			
33 kV VASANT VIHAR GRID	SVVHR109	11kV FDR O/G VASANT ENCLAVE S/S NO.-2	TI-VVR047A-1	990	MIXED		Functional	100%	401	0.41			
33 kV VASANT VIHAR GRID	SVVHR120	11kV FDR O/G C-BLOCK VASANT VIHAR	550VVR-VVR168A	630	RESIDENTIAL		Functional	100%	493	0.39			
33 kV VASANT VIHAR GRID	SVVHR109	11kV FDR O/G VASANT ENCLAVE S/S NO.-2	TI-VVR047A-2	630	MIXED		Functional	100%	234	0.29			
33 kV VASANT VIHAR GRID	SVVHR109	11kV FDR O/G VASANT ENCLAVE S/S NO.-2	TI-VVR048A-1	630	MIXED		Functional	100%	118	0.24			
33 kV VASANT VIHAR GRID	SVVHR116	11kV STR 100kVA STATION TRANSFORMER. NO.-1	VK-STC106A-1	100	MIXED		Functional	100%	1	0.02			
33 kV VASANT VIHAR GRID	SVVHR118	11kV FDR O/G NIRYAT BHAWAN	TP-VVR037A-1	100	MIXED		Functional	100%	5	0.01			
33 kV R.K.PURAM - 1 GRID	SRKP1106	11kV FDR O/G E-1 VASANT VIHAR	TI-VVR058A-1	990	RESIDENTIAL		Functional	100%	286	0.74	5.35	0.02	0.32%
33 kV R.K.PURAM - 1 GRID	SRKP1106	11kV FDR O/G E-1 VASANT VIHAR	TI-VVR058A-2	990	RESIDENTIAL		Functional	100%	145	0.62			
33 kV VASANT VIHAR GRID	SVVHR112	11kV FDR O/G VASANT MARG COMPLAINT CENTER	TI-VVR059A-2	990	RESIDENTIAL		Functional	100%	177	0.59			
33 kV R.K.PURAM - 1 GRID	SRKP1106	11kV FDR O/G E-1 VASANT VIHAR	TG-VVR153A-1	630	RESIDENTIAL		Functional	100%	168	0.58			
33 kV R.K.PURAM - 1 GRID	SRKP1106	11kV FDR O/G E-1 VASANT VIHAR	TX-VVR095A-1	990	MIXED		Functional	100%	150	0.49			
33 kV VASANT VIHAR GRID	SVVHR112	11kV FDR O/G VASANT MARG COMPLAINT CENTER	TG-VVR070A-1	630	RESIDENTIAL		Functional	100%	199	0.45			
33 kV VASANT VIHAR GRID	SVVHR112	11kV FDR O/G VASANT MARG COMPLAINT CENTER	TG-VVR070A-2	990	RESIDENTIAL		Functional	100%	129	0.42			
33 kV VASANT VIHAR GRID	SVVHR103	11kV FDR O/G F-BLOCK VASANT VIHAR	TI-VVR060A-1	630	MIXED		Functional	100%	114	0.38			
33 kV VASANT VIHAR GRID	SVVHR120	11kV FDR O/G C-BLOCK VASANT VIHAR	TX-VVR092A-1	990	RESIDENTIAL		Functional	100%	91	0.34			
33 kV VASANT VIHAR GRID	SVVHR112	11kV FDR O/G VASANT MARG COMPLAINT CENTER	TI-VVR059B-1	990	RESIDENTIAL		Functional	100%	0	0.30			
33 kV VASANT VIHAR GRID	SVVHR103	11kV FDR O/G F-BLOCK VASANT VIHAR	TI-VVR060A-2	990	MIXED		Functional	100%	173	0.26			
33 kV VASANT VIHAR GRID	SVVHR112	11kV FDR O/G VASANT MARG COMPLAINT CENTER	TI-VVR059A-1	990	RESIDENTIAL		Functional	100%	181	0.18			
33 kV VASANT VIHAR GRID	SVVHR107	11kV FDR O/G D-BLOCK VASANT VIHAR	TG-VVR088A-2	990	RESIDENTIAL		Functional	100%	140	0.59	3.86	0.22	5.46%
33 kV VASANT VIHAR GRID	SVVHR120	11kV FDR O/G C-BLOCK VASANT VIHAR	TX-VVR072A-1	990	RESIDENTIAL		Functional	100%	167	0.58			
33 kV VASANT VIHAR GRID	SVVHR107	11kV FDR O/G D-BLOCK VASANT VIHAR	TI-VVR056A-1	990	RESIDENTIAL		Functional	100%	484	0.56			
33 kV VASANT VIHAR GRID	SVVHR103	11kV FDR O/G F-BLOCK VASANT VIHAR	TI-VVR077A-1	990	RESIDENTIAL		Functional	100%	1053	0.54			
33 kV VASANT VIHAR GRID	SVVHR107	11kV FDR O/G D-BLOCK VASANT VIHAR	TK-VVR076A-2	630	RESIDENTIAL		Functional	100%	135	0.49			
33 kV VASANT VIHAR GRID	SVVHR103	11kV FDR O/G F-BLOCK VASANT VIHAR	TX-VVR057A-1	990	RESIDENTIAL		Functional	100%	171	0.47			
33 kV VASANT VIHAR GRID	SVVHR107	11kV FDR O/G D-BLOCK VASANT VIHAR	TK-VVR076A-1	990	RESIDENTIAL		Functional	100%	96	0.32			
33 kV VASANT VIHAR GRID	SVVHR107	11kV FDR O/G D-BLOCK VASANT VIHAR	TG-VVR170A-1	630	RESIDENTIAL		Functional	100%	35	0.30			

33 kV VASANT VIHAR GRID	SVVHR107	11kV FDR O/G D-BLOCK VASANT VIHAR	TG-VVR088A-1	990	RESIDENTIAL	Functional	100%	169	0.24			
33 kV VASANT VIHAR GRID	SVVHR103	11kV FDR O/G F-BLOCK VASANT VIHAR	TP-VVR003A-1	100	RESIDENTIAL	Functional	100%	1	0.01			
33 kV VASANT VIHAR GRID	SVVHR120	11kV FDR O/G C-BLOCK VASANT VIHAR	TI-VVR055A-1	990	RESIDENTIAL	Functional	100%	180	0.68	5.64	0.11	1.95%
33 kV VASANT VIHAR GRID	SVVHR102	11kV FDR O/G VASANT VIHAR B-BLOCK FDR.-1	TI-VVR052A-1	990	RESIDENTIAL	Functional	100%	215	0.50			
33 kV VASANT VIHAR GRID	SVVHR113	11kV FDR O/G VASANT VIHAR B-BLOCK FDR.-2	TI-VVR052A-2	990	RESIDENTIAL	Functional	100%	100	0.50			
33 kV VASANT VIHAR GRID	SVVHR113	11kV FDR O/G VASANT VIHAR B-BLOCK FDR.-2	TG-VVR071A-2	630	RESIDENTIAL	Functional	100%	267	0.46			
33 kV VASANT VIHAR GRID	SVVHR113	11kV FDR O/G VASANT VIHAR B-BLOCK FDR.-2	TG-VVR075A-2	630	RESIDENTIAL	Functional	100%	179	0.45			
33 kV VASANT VIHAR GRID	SVVHR112	11kV FDR O/G VASANT MARG COMPLAINT CENTER	TI-VVR053A-1	990	RESIDENTIAL	Functional	100%	159	0.44			
33 kV VASANT VIHAR GRID	SVVHR112	11kV FDR O/G VASANT MARG COMPLAINT CENTER	TI-VVR053A-2	990	RESIDENTIAL	Functional	100%	69	0.44			
33 kV VASANT VIHAR GRID	SVVHR120	11kV FDR O/G C-BLOCK VASANT VIHAR	TG-VVR125A-1	990	RESIDENTIAL	Functional	100%	112	0.42			
33 kV VASANT VIHAR GRID	SVVHR102	11kV FDR O/G VASANT VIHAR B-BLOCK FDR.-1	TG-VVR074A-2	630	RESIDENTIAL	Functional	100%	114	0.39			
33 kV VASANT VIHAR GRID	SVVHR102	11kV FDR O/G VASANT VIHAR B-BLOCK FDR.-1	TG-VVR074A-1	630	RESIDENTIAL	Functional	100%	96	0.38			
33 kV VASANT VIHAR GRID	SVVHR120	11kV FDR O/G C-BLOCK VASANT VIHAR	TG-VVR125A-2	990	RESIDENTIAL	Functional	100%	204	0.37			
33 kV VASANT VIHAR GRID	SVVHR113	11kV FDR O/G VASANT VIHAR B-BLOCK FDR.-2	TG-VVR071A-1	630	RESIDENTIAL	Functional	100%	70	0.34			
33 kV VASANT VIHAR GRID	SVVHR113	11kV FDR O/G VASANT VIHAR B-BLOCK FDR.-2	TG-VVR075A-1	630	RESIDENTIAL	Functional	100%	51	0.30			
33 kV VASANT VIHAR GRID	SVVHR111	11kV FDR O/G TO VASANT ENCLAVE NO.-1	550VVR-VVR182A	400	RESIDENTIAL	Functional	100%	1	0.08			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL110	11kV FDR MOTI BAGH	TI-RKZ154A-2	990	MIXED	Functional	100%	108	0.75	5.16	0.01	0.11%
33 kV VASANT VIHAR GRID	SVVHR104	11kV FDR O/G WEST END COLONY	TI-VVR028A-2	990	MIXED	Functional	100%	177	0.73			
33 kV VASANT VIHAR GRID	SVVHR105	11kV FDR O/G TO ANAND NIKETAN	TI-VVR026A-2	990	MIXED	Functional	100%	198	0.57			
33 kV VASANT VIHAR GRID	SVVHR104	11kV FDR O/G WEST END COLONY	TI-RKZ154A-3	990	MIXED	Functional	100%	297	0.50			
33 kV VASANT VIHAR GRID	SVVHR105	11kV FDR O/G TO ANAND NIKETAN	TI-VVR026A-1	990	MIXED	Functional	100%	235	0.50			
33 kV VASANT VIHAR GRID	SVVHR105	11kV FDR O/G TO ANAND NIKETAN	TX-VVR106A-1	990	MIXED	Functional	100%	210	0.49			
220/66/33/11 kV RIDGE VALLEY GRID	SRVAL136	11kV FDR VENKTESHWAR COLLEGE	TX-VVR129A-1	990	MIXED	Functional	100%	243	0.48			
33 kV VASANT VIHAR GRID	SVVHR104	11kV FDR O/G WEST END COLONY	TG-VVR173A-1	990	RESIDENTIAL	Functional	100%	70	0.42			
33 kV VASANT VIHAR GRID	SVVHR104	11kV FDR O/G WEST END COLONY	TI-VVR028A-1	990	MIXED	Functional	100%	148	0.31			
33 kV VASANT VIHAR GRID	SVVHR104	11kV FDR O/G WEST END COLONY	TX-VVR097A-1	990	MIXED	Functional	100%	110	0.24			
33 kV VASANT VIHAR GRID	SVVHR104	11kV FDR O/G WEST END COLONY	TI-RKZ154A-1	400	MIXED	Functional	100%	46	0.17			
33 kV BHIKAJI CAMA PLACE GRID	SBKCM103	11kV FDR PLOT NO.-25	TI-RKZ118A-1	630	COMMERCIAL	Functional	100%	1	0.17	0.55	0.01	1.54%
33 kV BHIKAJI CAMA PLACE GRID	SBKCM103	11kV FDR PLOT NO.-25	TI-RKZ105A-2	630	COMMERCIAL	Functional	100%	4	0.12			
33 kV BHIKAJI CAMA PLACE GRID	SBKCM103	11kV FDR PLOT NO.-25	TI-RKZ119A-2	630	COMMERCIAL	Functional	100%	5	0.11			
33 kV BHIKAJI CAMA PLACE GRID	SBKCM103	11kV FDR PLOT NO.-25	TI-RKZ105A-1	630	COMMERCIAL	Functional	100%	9	0.10			
33 kV BHIKAJI CAMA PLACE GRID	SBKCM103	11kV FDR PLOT NO.-25	TI-RKZ119A-1	630	COMMERCIAL	Functional	100%	17	0.04			
33 kV BHIKAJI CAMA PLACE GRID	SBKCM103	11kV FDR PLOT NO.-25	TI-RKZ118A-2	630	COMMERCIAL	Functional	100%	1	0.03			
33 kV R.K.PURAM - 2 GRID	SRKP2122	11kV FDR O/G S/S NO.-1, SECTOR-1, R.K PURAM	TI-RKZ045A-2	990	RESIDENTIAL	Functional	100%	1458	0.58	1.78	0.02	1.31%
33 kV R.K.PURAM - 1 GRID	SRKP1112	11kV FDR O/G SECTOR-2 R.K PURAM	TI-RKZ030A-1	990	RESIDENTIAL	Functional	100%	1055	0.28			
33 kV R.K.PURAM - 2 GRID	SRKP2122	11kV FDR O/G S/S NO.-1, SECTOR-1, R.K PURAM	TI-RKZ045A-1	990	RESIDENTIAL	Functional	100%	451	0.20			
33 kV R.K.PURAM - 1 GRID	SRKP1112	11kV FDR O/G SECTOR-2 R.K PURAM	TG-RKZ032A-1	400	RESIDENTIAL	Functional	100%	146	0.16			
33 kV R.K.PURAM - 1 GRID	SRKP1112	11kV FDR O/G SECTOR-2 R.K PURAM	TI-RKZ030A-2	630	RESIDENTIAL	Functional	100%	174	0.14			
33 kV R.K.PURAM - 2 GRID	SRKP2122	11kV FDR O/G S/S NO.-1, SECTOR-1, R.K PURAM	TI-RKZ045B-1	990	RESIDENTIAL	Functional	100%	0	0.13			
33 kV R.K.PURAM - 1 GRID	SRKP1110	11kV FDR O/G R.K PURAM EAST BLOCK	TG-RKZ160A-1	400	RESIDENTIAL	Functional	100%	2	0.11			
33 kV R.K.PURAM - 2 GRID	SRKP2129	11kV FDR 3W O/D RMU INSIDE GRID	TG-RKZ163A-2	990	RESIDENTIAL	AMR Functional	100%	93	0.09			
33 kV R.K.PURAM - 2 GRID	SRKP2129	11kV FDR 3W O/D RMU INSIDE GRID	TG-RKZ163A-3	990	RESIDENTIAL	AMR Functional	100%	49	0.06			
33 kV R.K.PURAM - 2 GRID	SRKP2129	11kV FDR 3W O/D RMU INSIDE GRID	TG-RKZ163A-1	990	RESIDENTIAL	AMR Functional	100%	66	0.06			
33 kV R.K.PURAM - 1 GRID	SRKP1108	11kV FDR O/G SCIENTIFIC HOSTEL	TI-VVR018A-1	630	MIXED	Functional	100%	48	0.16	0.71	0.10	12.86%
33 kV R.K.PURAM - 1 GRID	SRKP1108	11kV FDR O/G SCIENTIFIC HOSTEL	TI-VVR017A-2	630	MIXED	Functional	100%	52	0.13			
33 kV R.K.PURAM - 1 GRID	SRKP1108	11kV FDR O/G SCIENTIFIC HOSTEL	TI-VVR019A-1	630	MIXED	Functional	100%	133	0.13			
33 kV R.K.PURAM - 1 GRID	SRKP1108	11kV FDR O/G SCIENTIFIC HOSTEL	TI-VVR020A-1	630	MIXED	Functional	100%	25	0.11			
33 kV R.K.PURAM - 1 GRID	SRKP1108	11kV FDR O/G SCIENTIFIC HOSTEL	TI-VVR017A-1	630	MIXED	Functional	100%	47	0.07			
33 kV R.K.PURAM - 1 GRID	SRKP1108	11kV FDR O/G SCIENTIFIC HOSTEL	TI-VVR018A-2	630	MIXED	Functional	100%	98	0.07			

33 kv R.K.PURAM - 1 GRID	SRKP1108	11kv FDR O/G SCIENTIFIC HOSTEL	TI-VVR020A-2	630	MIXED		Functional	100%	56	0.07			
33 kv R.K.PURAM - 1 GRID	SRKP1108	11kv FDR O/G SCIENTIFIC HOSTEL	TI-VVR019A-2	630	MIXED		Functional	100%	0	0.07			
33 kv R.K.PURAM - 1 GRID	SRKP1106	11kv FDR O/G E-1 VASANT VIHAR	TX-VVR087A-1	990	RESIDENTIAL		Functional	100%	162	0.64	3.69	0.23	5.79%
33 kv VASANT VIHAR GRID	SVVHR108	11kv FDR O/G A-BLOCK VASANT VIHAR	TI-VVR054A-1	990	RESIDENTIAL		Functional	100%	159	0.63			
66 kv J.N.U GRID	SJNUG103	11kv FDR VASANT LOK	TG-VVR073A-1	990	RESIDENTIAL		Functional	100%	331	0.56			
33 kv VASANT VIHAR GRID	SVVHR108	11kv FDR O/G A-BLOCK VASANT VIHAR	TI-VVR054A-2	990	RESIDENTIAL		Functional	100%	192	0.54			
33 kv VASANT VIHAR GRID	SVVHR108	11kv FDR O/G A-BLOCK VASANT VIHAR	TI-VVR054A-3	990	RESIDENTIAL		Functional	100%	157	0.54			
66 kv J.N.U GRID	SJNUG103	11kv FDR VASANT LOK	TG-VVR073A-2	630	RESIDENTIAL		Functional	100%	278	0.49			
33 kv VASANT VIHAR GRID	SVVHR108	11kv FDR O/G A-BLOCK VASANT VIHAR	TX-VVR098A-1	990	RESIDENTIAL		Functional	100%	165	0.37			
33 kv R.K.PURAM - 2 GRID	SRKP2132	11 kv FDR CAR PARKING MUNIRKA	TI-RKZ007A-1	400	RESIDENTIAL		Functional	100%	48	0.15			
33 kv MASJID MOTH GRID	SMMOT111	11kv FDR B & C BLOCK PANCHSHEEL ENCL.	TG-HKS168A-2	990	RESIDENTIAL		Functional	100%	447	0.78	4.51	0.36	7.37%
33 kv MASJID MOTH GRID	SMMOT106	11kv FDR O/G SOAMI NAGAR	TG-HKS183A-1	630	RESIDENTIAL		Functional	100%	213	0.64			
33 kv MASJID MOTH GRID	SMMOT111	11kv FDR B & C BLOCK PANCHSHEEL ENCL.	TG-HKS168A-3	990	RESIDENTIAL		Functional	100%	0	0.48			
33 kv MASJID MOTH GRID	SMMOT111	11kv FDR B & C BLOCK PANCHSHEEL ENCL.	TX-HKS250A-1	990	RESIDENTIAL		Functional	100%	252	0.47			
33 kv MASJID MOTH GRID	SMMOT106	11kv FDR O/G SOAMI NAGAR	TK-HKS170A-1	990	RESIDENTIAL		Functional	100%	304	0.41			
33 kv MASJID MOTH GRID	SMMOT106	11kv FDR O/G SOAMI NAGAR	TK-HKS170A-2	990	RESIDENTIAL		Functional	100%	168	0.41			
33 kv MASJID MOTH GRID	SMMOT106	11kv FDR O/G SOAMI NAGAR	TG-HKS183A-2	630	RESIDENTIAL		Functional	100%	242	0.37			
33 kv MASJID MOTH GRID	SMMOT111	11kv FDR B & C BLOCK PANCHSHEEL ENCL.	TI-HKS167A-1	630	RESIDENTIAL		Functional	100%	145	0.27			
33 kv MASJID MOTH GRID	SMMOT120	11kv FDR O/G C-17 PANCH SHEEL PARK (RMU) NEAR FLY OVER	TG-HKS185A-1	630	COMMERCIAL	AMR	Functional	100%	167	0.25			
33 kv MASJID MOTH GRID	SMMOT111	11kv FDR B & C BLOCK PANCHSHEEL ENCL.	TG-HKS168A-1	630	RESIDENTIAL		Functional	100%	178	0.23			
33 kv MASJID MOTH GRID	SMMOT104	11kv FDR O/G DAKSHIN DEEP SADIQ NAGAR	TX-HKS184A-1	990	RESIDENTIAL		Functional	100%	116	0.22			
33 kv MASJID MOTH GRID	SMMOT111	11kv FDR B & C BLOCK PANCHSHEEL ENCL.	TI-HKS167A-2	630	RESIDENTIAL		Functional	100%	199	0.20			
33 kv MASJID MOTH GRID	SMMOT118	11kv STR 100kVA STATION TRF. NO.-1	HK-STC084A-1	100	COMMERCIAL		Functional	100%	1	0.02			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM108	11kv FDR B-5, S.J ENCLAVE	551GPK-HKS314A-	630	MIXED		Functional	100%	0	0.14			
33 kv SIRI FORT GRID	SSHRI112	11kv FDR PANCHSHEEL CLUB	TI-HKS164A-1	1000	RESIDENTIAL		Functional	100%	163	0.64	5.20	0.08	1.50%
33 kv SHIVALIK GRID	SSHIV123	11kv FDR O/G L-BLOCK HAUZ KHAS	TI-HKS155A-2	990	RESIDENTIAL		Functional	100%	136	0.47			
33 kv SHIVALIK GRID	SSHIV301	11kv FDR O/G TO MAYFAIR GARDEN	TX-HKS172A-1	990	RESIDENTIAL		Functional	100%	242	0.44			
33 kv SHIVALIK GRID	SSHIV301	11kv FDR O/G TO MAYFAIR GARDEN	TX-HKS173A-1	990	RESIDENTIAL		Functional	100%	173	0.44			
33 kv SIRI FORT GRID	SSHRI104	11kv FDR PHD HOUSE	TG-HKS175A-1	630	RESIDENTIAL		Functional	100%	401	0.43			
33 kv SHIVALIK GRID	SSHIV301	11kv FDR O/G TO MAYFAIR GARDEN	TI-HKS162A-2	630	RESIDENTIAL		Functional	100%	212	0.39			
33 kv SIRI FORT GRID	SSHRI112	11kv FDR PANCHSHEEL CLUB	TI-HKS164A-2	990	RESIDENTIAL		Functional	100%	3	0.34			
33 kv SHIVALIK GRID	SSHIV301	11kv FDR O/G TO MAYFAIR GARDEN	TI-HKS162A-1	630	RESIDENTIAL		Functional	100%	17	0.29			
33 kv SHIVALIK GRID	SSHIV301	11kv FDR O/G TO MAYFAIR GARDEN	TX-HKS254A-1	990	RESIDENTIAL		Functional	100%	122	0.28			
33 kv SHIVALIK GRID	SSHIV123	11kv FDR O/G L-BLOCK HAUZ KHAS	TI-HKS155A-1	990	RESIDENTIAL		Functional	100%	87	0.27			
33 kv SHIVALIK GRID	SSHIV123	11kv FDR O/G L-BLOCK HAUZ KHAS	TX-HKS174A-1	990	RESIDENTIAL		Functional	100%	75	0.27			
33 kv ADCHINI GRID	SADCN110	11kv FDR BHIM NAGRI (I.I.T S/S NO.-2	TI-HKS156A-1	630	RESIDENTIAL		Functional	100%	249	0.26			
33 kv SIRI FORT GRID	SSHRI104	11kv FDR PHD HOUSE	TG-HKS175A-2	630	RESIDENTIAL		Functional	100%	27	0.25			
33 kv SHIVALIK GRID	SSHIV123	11kv FDR O/G L-BLOCK HAUZ KHAS	TX-HKS186A-1	990	RESIDENTIAL		Functional	100%	131	0.19			
33 kv ADCHINI GRID	SADCN110	11kv FDR BHIM NAGRI (I.I.T S/S NO.-2	2551RBI-HKS305A-	990	RESIDENTIAL		Functional	100%	109	0.11			
33 kv SIRI FORT GRID	SSHRI125	11kv FDR O/G SHOPPING CENTER PANCHSHEEL	TX-HKS157A-1	630	RESIDENTIAL		Functional	100%	16	0.10			
33 kv ADCHINI GRID	SADCN110	11kv FDR BHIM NAGRI (I.I.T S/S NO.-2	TX-HKS158A-1	990	RESIDENTIAL		Functional	100%	12	0.09			
33 kv SIRI FORT GRID	SSHRI104	11kv FDR PHD HOUSE	TP-HKS222A-1	400	RESIDENTIAL		Functional	100%	30	0.02			
33 kv N.D.S.E.-2 GRID	SNDSE108	11kv FDR 11KV O/G ANDREWS GANJ POLICE STATION	TG-HKS119A-1	1600	RESIDENTIAL	AMR	Functional	100%	976	1.00	12.51	0.21	1.67%
33 kv SIRI FORT GRID	SSHRI120	11kv FDR O/G GULMOHAR ENCLAVE	TG-HKS135A-1	990	RESIDENTIAL		Functional	100%	344	0.86			
33 kv H.U.D.C.O GRID	SHUDC116	11kv FDR O/G HARDEV PURI HKS	TG-HKS137A-1	990	RESIDENTIAL	AMR	Functional	100%	885	0.83			
33 kv SIRI FORT GRID	SSHRI120	11kv FDR O/G GULMOHAR ENCLAVE	TG-HKS141A-1	990	RESIDENTIAL		Functional	100%	1292	0.73			
33 kv SIRI FORT GRID	SSHRI108	11kv FDR O/G GULMOHAR PARK	TG-HKS116A-1	990	RESIDENTIAL		Functional	100%	1085	0.68			
33 kv SIRI FORT GRID	SSHRI120	11kv FDR O/G GULMOHAR ENCLAVE	TG-HKS141A-2	990	RESIDENTIAL		Functional	100%	27	0.67			
33 kv H.U.D.C.O GRID	SHUDC116	11kv FDR O/G HARDEV PURI HKS	TG-HKS137A-2	990	RESIDENTIAL		Functional	100%	432	0.64			
33 kv SIRI FORT GRID	SSHRI108	11kv FDR O/G GULMOHAR PARK	TG-HKS116A-2	990	RESIDENTIAL		Functional	100%	500	0.62			

33/11 kv AIIMS MASJID MOTH GRID(AIIMS-2)	SAIIM005	11kv FDR AIIMS SURGICAL BLOCK-1	TP-HKS140A-1	990	RESIDENTIAL		Functional	100%	1244	0.58			
33/11 kv AIIMS MASJID MOTH GRID(AIIMS-2)	SAIIM005	11kv FDR AIIMS SURGICAL BLOCK-1	TG-HKS134A-2	990	RESIDENTIAL		Functional	100%	362	0.56			
33 kv H.U.D.C.O GRID	SHUDC107	11kv FDR A.I.I.M.S STAFF QUARTERS	TI-HKS102A-1	990	RESIDENTIAL		Functional	100%	131	0.52			
33 kv SIRI FORT GRID	SSHRI120	11kv FDR O/G GULMOHAR ENCLAVE	TI-HKS125A-1	990	RESIDENTIAL	AMR	Functional	100%	406	0.50			
33 kv H.U.D.C.O GRID	SHUDC112	11kv FDR YUSUF SARAI COMM. CENTER	TI-HKS145A-1	990	RESIDENTIAL		Functional	100%	205	0.50			
33 kv H.U.D.C.O GRID	SHUDC112	11kv FDR YUSUF SARAI COMM. CENTER	TI-HKS145A-3	990	RESIDENTIAL		Functional	100%	175	0.47			
33 kv H.U.D.C.O GRID	SHUDC112	11kv FDR YUSUF SARAI COMM. CENTER	TI-HKS145A-2	990	RESIDENTIAL		Functional	100%	246	0.47			
33/11 kv AIIMS MASJID MOTH GRID(AIIMS-2)	SAIIM005	11kv FDR AIIMS SURGICAL BLOCK-1	TG-HKS134A-1	630	RESIDENTIAL		Functional	100%	603	0.46			
33/11 kv AIIMS MASJID MOTH GRID(AIIMS-2)	SAIIM005	11kv FDR AIIMS SURGICAL BLOCK-1	TG-HKS140A-2	630	RESIDENTIAL		Functional	100%	0	0.45			
33 kv H.U.D.C.O GRID	SHUDC107	11kv FDR A.I.I.M.S STAFF QUARTERS	TG-HKS221A-1	990	RESIDENTIAL		Functional	100%	339	0.41			
33 kv SIRI FORT GRID	SSHRI120	11kv FDR O/G GULMOHAR ENCLAVE	TG-HKS134A-3	630	RESIDENTIAL		Functional	100%	0	0.37			
33 kv H.U.D.C.O GRID	SHUDC107	11kv FDR A.I.I.M.S STAFF QUARTERS	TI-HKS102A-2	630	RESIDENTIAL		Functional	100%	154	0.34			
33 kv H.U.D.C.O GRID	SHUDC105	11kv FDR O/G I.O.C BUILDING	551AGJ-HKS300A-	630	COMMERCIAL		Functional	100%	334	0.31			
33 kv SIRI FORT GRID	SSHRI120	11kv FDR O/G GULMOHAR ENCLAVE	TI-HKS125A-2	630	RESIDENTIAL		Functional	100%	255	0.27			
33 kv H.U.D.C.O GRID	SHUDC107	11kv FDR A.I.I.M.S STAFF QUARTERS	551AGJ-HKS302A-	630	RESIDENTIAL		Functional	100%	126	0.23			
33 kv H.U.D.C.O GRID	SHUDC107	11kv FDR A.I.I.M.S STAFF QUARTERS	TG-HKS299A-1	630	RESIDENTIAL		Functional	100%	156	0.20			
220 kv A.I.I.M.S TRAUMA CENTER	SSHRI121	AIIMS TRAUMA CENTER TO AIIMS-2 M.MOTH	551AGJ-STC134A-	400	COMMERCIAL		Functional	100%	0	0.04			
33 kv MASJID MOTH GRID	SMMOT104	11kv FDR O/G DAKSHIN DEEP SADIQ NAGAR	TI-HKS109A-2	990	COMMERCIAL		Functional	100%	728	0.51	5.44	0.09	1.59%
33 kv N.D.S.E.-2 GRID	SNDSE106	11kv O/G D-3 HTC NDSE-II ANDREWS GANJ MAIN	TI-HKS101A-2	990	INDUSTRIAL		Functional	100%	0	0.49			
33 kv MASJID MOTH GRID	SMMOT104	11kv FDR O/G DAKSHIN DEEP SADIQ NAGAR	TI-HKS108A-1	990	COMMERCIAL		Functional	100%	968	0.43			
33 kv MASJID MOTH GRID	SMMOT104	11kv FDR O/G DAKSHIN DEEP SADIQ NAGAR	TI-HKS109A-1	990	COMMERCIAL		Functional	100%	609	0.43			
33 kv MASJID MOTH GRID	SMMOT104	11kv FDR O/G DAKSHIN DEEP SADIQ NAGAR	TI-HKS107A-2	990	COMMERCIAL		Functional	100%	219	0.42			
33 kv H.U.D.C.O GRID	SHUDC104	11kv FDR O/G POLICE COLONY ANDREWS GANJ	TX-HKS136A-1	990	COMMERCIAL		Functional	100%	660	0.39			
33 kv MASJID MOTH GRID	SMMOT104	11kv FDR O/G DAKSHIN DEEP SADIQ NAGAR	TI-HKS107A-1	990	COMMERCIAL		Functional	100%	526	0.37			
33 kv MASJID MOTH GRID	SMMOT104	11kv FDR O/G DAKSHIN DEEP SADIQ NAGAR	TI-HKS108A-2	630	COMMERCIAL		Functional	100%	257	0.36			
33 kv N.D.S.E.-2 GRID	SNDSE105	11kv FDR 11KV O/G DJB PUMPING STATION HAZOORI LAL	TI-HKS126A-1	630	INDUSTRIAL	AMR	Functional	100%	177	0.30			
33 kv N.D.S.E.-2 GRID	SNDSE106	11kv O/G D-3 HTC NDSE-II ANDREWS GANJ MAIN	TI-HKS101A-1	990	INDUSTRIAL		Functional	100%	1098	0.22			
33 kv N.D.S.E.-2 GRID	SNDSE106	11kv O/G D-3 HTC NDSE-II ANDREWS GANJ MAIN	TI-HKS122A-2	630	INDUSTRIAL		Functional	100%	0	0.15			
33 kv MASJID MOTH GRID	SMMOT104	11kv FDR O/G DAKSHIN DEEP SADIQ NAGAR	551AGJ-HKS109A-	630	RESIDENTIAL		Functional	100%	0	0.15			
33 kv H.U.D.C.O GRID	SHUDC103	11kv FDR O/G HUDCO S/S NO.-6	TI-HKS212A-1	400	INDUSTRIAL	AMR	Functional	100%	183	0.09			
33 kv H.U.D.C.O GRID	SHUDC103	11kv FDR O/G HUDCO S/S NO.-6	TI-HKS142A-1	630	INDUSTRIAL		Functional	100%	43	0.09			
33 kv H.U.D.C.O GRID	SHUDC112	11kv FDR HUDCO S/S NO.-2 (OLD)	TI-HKS217A-1	630	INDUSTRIAL		Functional	100%	45	0.08			
33 kv N.D.S.E.-2 GRID	SNDSE106	11kv O/G D-3 HTC NDSE-II ANDREWS GANJ MAIN	TI-HKS122A-1	630	INDUSTRIAL		Functional	100%	354	0.08			
33 kv H.U.D.C.O GRID	SHUDC103	11kv FDR O/G HUDCO S/S NO.-6	TI-HKS219A-1	400	INDUSTRIAL		Functional	100%	83	0.08			
33 kv N.D.S.E.-2 GRID	SNDSE106	11kv O/G D-3 HTC NDSE-II ANDREWS GANJ MAIN	TI-HKS210A-2	400	INDUSTRIAL		Functional	100%	44	0.07			
33 kv H.U.D.C.O GRID	SHUDC103	11kv FDR O/G HUDCO S/S NO.-6	TI-HKS082A-2	400	INDUSTRIAL		Functional	100%	66	0.07			
33 kv H.U.D.C.O GRID	SHUDC103	11kv FDR O/G HUDCO S/S NO.-6	TI-HKS082A-1	400	INDUSTRIAL		Functional	100%	67	0.07			
33 kv H.U.D.C.O GRID	SHUDC103	11kv FDR O/G HUDCO S/S NO.-6	TI-HKS049A-1	630	INDUSTRIAL		Functional	100%	18	0.06			
33 kv H.U.D.C.O GRID	SHUDC103	11kv FDR O/G HUDCO S/S NO.-6	TI-HKS214A-2	400	INDUSTRIAL		Functional	100%	57	0.06			
33 kv H.U.D.C.O GRID	SHUDC103	11kv FDR O/G HUDCO S/S NO.-6	TI-HKS212A-2	400	INDUSTRIAL	AMR	Functional	100%	126	0.06			
33 kv H.U.D.C.O GRID	SHUDC103	11kv FDR O/G HUDCO S/S NO.-6	TI-HKS049A-2	630	INDUSTRIAL		Functional	100%	25	0.05			
33 kv H.U.D.C.O GRID	SHUDC103	11kv FDR O/G HUDCO S/S NO.-6	TI-HKS213A-1	400	INDUSTRIAL		Functional	100%	0	0.05			
33 kv N.D.S.E.-2 GRID	SNDSE106	11kv O/G D-3 HTC NDSE-II ANDREWS GANJ MAIN	TI-HKS221A-2	400	INDUSTRIAL		Functional	100%	63	0.05			
33 kv H.U.D.C.O GRID	SHUDC103	11kv FDR O/G HUDCO S/S NO.-6	TI-HKS052A-1	400	INDUSTRIAL		Functional	100%	21	0.04			
33 kv H.U.D.C.O GRID	SHUDC103	11kv FDR O/G HUDCO S/S NO.-6	TI-HKS214A-1	400	INDUSTRIAL		Functional	100%	46	0.04			
33 kv H.U.D.C.O GRID	SHUDC101	11kv FDR O/G HUDCO 4-PANEL BOARD	TI-HKS191A-1	400	COMMERCIAL		Functional	100%	1	0.04			
33 kv H.U.D.C.O GRID	SHUDC103	11kv FDR O/G HUDCO S/S NO.-6	TI-HKS052A-2	400	INDUSTRIAL		Functional	100%	54	0.04			
33 kv N.D.S.E.-2 GRID	SNDSE106	11kv O/G D-3 HTC NDSE-II ANDREWS GANJ MAIN	TI-HKS210A-1	400	INDUSTRIAL		Functional	100%	81	0.04			

33 kv N.D.S.E.-2 GRID	SNLSE106	11KV O/G D-3 HTC NDSE-II ANDREWS GANJ MAIN	TI-HKS211A-1	400	INDUSTRIAL		Functional	100%	119	0.04			
33 kv H.U.D.C.O GRID	SHUDC103	11kv FDR O/G HUDCO S/S NO.-6	TI-HKS213A-2	400	INDUSTRIAL		Functional	100%	200	0.03			
33 kv H.U.D.C.O GRID	SHUDC110	11kv STR 100kVA STATION TRF	HK-STC076A-1	100	COMMERCIAL		Functional	100%	1	0.03			
33 kv H.U.D.C.O GRID	SHUDC103	11kv FDR O/G HUDCO S/S NO.-6	TI-HKS219A-2	400	INDUSTRIAL		Functional	100%	28	0.02			
33 kv H.U.D.C.O GRID	SHUDC109	11kv FDR AYURVIGYAN NAGAR S/S NO.-2	TI-HKS099A-2	990	COMMERCIAL		Functional	100%	231	0.65	2.36	0.22	8.39%
33 kv H.U.D.C.O GRID	SHUDC109	11kv FDR AYURVIGYAN NAGAR S/S NO.-2	TI-HKS099A-1	990	COMMERCIAL		Functional	100%	229	0.48			
33 kv H.U.D.C.O GRID	SHUDC101	11KV FDR 200FLAT AYURVIGYAN NAGAR	551AGJ-HKS106A-	990	COMMERCIAL	AMR	Functional	100%	106	0.28			
33 kv H.U.D.C.O GRID	SHUDC109	11kv FDR AYURVIGYAN NAGAR S/S NO.-2	TI-HKS104A-1	630	COMMERCIAL		Functional	100%	323	0.24			
33 kv H.U.D.C.O GRID	SHUDC109	11kv FDR AYURVIGYAN NAGAR S/S NO.-2	551AGJ-HKS104A-	400	RESIDENTIAL		Functional	100%	0	0.18			
33 kv SIRI FORT GRID	SSHRI125	11kv FDR O/G SHOPPING CENTER PANCHSHEEL	TI-HKS098A-1	400	COMMERCIAL		Functional	100%	7	0.15			
33 kv H.U.D.C.O GRID	SHUDC101	11kv FDR 200FLAT AYURVIGYAN NAGAR	TI-HKS110A-2	400	COMMERCIAL	AMR	Functional	100%	60	0.11			
33 kv H.U.D.C.O GRID	SHUDC101	11kv FDR 200FLAT AYURVIGYAN NAGAR	TP-HKS112A-1	400	COMMERCIAL		Functional	100%	64	0.09			
33 kv MASJID MOTH GRID	SMMOT104	11kv FDR O/G DAKSHIN DEEP SADIQ NAGAR	551AGJ-HKS316A-	630	MIXED		Functional	100%	74	0.08			
33 kv H.U.D.C.O GRID	SHUDC109	11kv FDR AYURVIGYAN NAGAR S/S NO.-2	TI-HKS111A-2	400	COMMERCIAL		Functional	100%	89	0.07			
33 kv H.U.D.C.O GRID	SHUDC109	11kv FDR AYURVIGYAN NAGAR S/S NO.-2	TI-HKS111A-1	400	COMMERCIAL		Functional	100%	63	0.07			
33 kv SIRI FORT GRID	SSHRI125	11kv FDR O/G SHOPPING CENTER PANCHSHEEL	TI-HKS098A-2	400	COMMERCIAL		Functional	100%	13	0.04			
33 kv H.U.D.C.O GRID	SHUDC101	11kv FDR 200FLAT AYURVIGYAN NAGAR	TI-HKS105A-1	400	COMMERCIAL	AMR	Functional	100%	78	0.04			
33 kv H.U.D.C.O GRID	SHUDC101	11kv FDR 200FLAT AYURVIGYAN NAGAR	TI-HKS110A-1	400	COMMERCIAL		Functional	100%	199	0.03			
33 kv H.U.D.C.O GRID	SHUDC101	11kv FDR 200FLAT AYURVIGYAN NAGAR	TI-HKS105A-2	400	COMMERCIAL	AMR	Functional	100%	8	0.03			
33 kv H.U.D.C.O GRID	SHUDC101	11kv FDR 200FLAT AYURVIGYAN NAGAR	551AGJ-HKS106A-	400	COMMERCIAL	AMR	Functional	100%	66	0.03			
33 kv H.U.D.C.O GRID	SHUDC109	11kv FDR AYURVIGYAN NAGAR S/S NO.-2	TI-HKS144A-1	400	COMMERCIAL		Functional	100%	18	0.01			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM105	11kv FDR B-4, S.J ENCLAVE	TG-HKS271A-1	1600	INDUSTRIAL		Functional	100%	1444	0.97	23.52	0.90	3.70%
33 kv BHIKAJI CAMA PLACE GRID	SBKCM105	11kv FDR B-4, S.J ENCLAVE	TI-HKS071A-3	990	RESIDENTIAL		Functional	100%	5	0.74			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM116	11kv FDR B-3 JHANDU SINGH MARG	TX-HKS097A-1	990	RESIDENTIAL		Functional	100%	556	0.73			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM116	11kv FDR B-3 JHANDU SINGH MARG	TG-HKS269A-1	990	RESIDENTIAL		Functional	100%	1069	0.71			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM125	11kv FDR B-7, S.J ENCLAVE	TI-HKS080A-3	990	RESIDENTIAL		Functional	100%	0	0.71			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM110	11kv FDR A-1 S.J ENCLAVE	TI-HKS071A-4	990	RESIDENTIAL		Functional	100%	4	0.71			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM108	11kv FDR B-5, S.J ENCLAVE	TI-HKS031A-3	1000	RESIDENTIAL		Functional	100%	0	0.69			
33 kv R.K.PURAM - 2 GRID	SRKP2119	11kv FDR R.K KHANNA STADIUM	TI-HKS015A-2	990	RESIDENTIAL		Functional	100%	0	0.68			
33 kv R.K.PURAM - 2 GRID	SRKP2119	11kv FDR R.K KHANNA STADIUM	TG-HKS296A-1	990	RESIDENTIAL		Functional	100%	644	0.67			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM129	11kv FDR A2/15 PSS S.J ENCLAVE	TX-HKS091A-1	990	RESIDENTIAL		Functional	100%	571	0.66			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM125	11kv FDR B-7, S.J ENCLAVE	TI-HKS080A-2	990	RESIDENTIAL		Functional	100%	200	0.65			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM113	11kv FDR B-6, S.J ENCLAVE	TI-HKS081A-1	990	RESIDENTIAL		Functional	100%	1173	0.65			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM113	11kv FDR B-6, S.J ENCLAVE	TI-HKS081A-3	990	RESIDENTIAL		Functional	100%	0	0.65			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM110	11kv FDR A-1 S.J ENCLAVE	TX-HKS024A-1	990	RESIDENTIAL		Functional	100%	554	0.64			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM122	11kv FDR CREAMATION GROUND, I/D G.P EXTN.	TX-HKS086A-1	990	INDUSTRIAL		Functional	100%	1272	0.64			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM110	11kv FDR A-1 S.J ENCLAVE	TG-HKS036A-1	990	RESIDENTIAL		Functional	100%	1238	0.63			
33 kv R.K.PURAM - 2 GRID	SRKP2119	11kv FDR R.K KHANNA STADIUM	TG-HKS286A-1	990	RESIDENTIAL		Functional	100%	932	0.62			
33 kv R.K.PURAM - 2 GRID	SRKP2119	11kv FDR R.K KHANNA STADIUM	TG-HKS094A-2	990	RESIDENTIAL		Functional	100%	0	0.60			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM105	11kv FDR B-4, S.J ENCLAVE	TI-HKS071A-2	990	RESIDENTIAL		Functional	100%	534	0.59			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM108	11kv FDR B-5, S.J ENCLAVE	TI-HKS031A-1	1000	RESIDENTIAL		Functional	100%	927	0.57			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM124	11kv FDR RAJ NAGAR	TG-HKS085A-1	1000	RESIDENTIAL		Functional	100%	174	0.57			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM110	11kv FDR A-1 S.J ENCLAVE	TG-HKS036A-2	990	RESIDENTIAL		Functional	100%	0	0.56			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM125	11kv FDR B-7, S.J ENCLAVE	TI-HKS080A-1	990	RESIDENTIAL		Functional	100%	941	0.56			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM110	11kv FDR A-1 S.J ENCLAVE	TX-HKS024A-2	990	RESIDENTIAL		Functional	100%	0	0.55			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM124	11kv FDR RAJ NAGAR	TK-HKS074A-2	990	RESIDENTIAL		Functional	100%	171	0.53			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM110	11kv FDR A-1 S.J ENCLAVE	TX-HKS027A-1	990	RESIDENTIAL		Functional	100%	299	0.50			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM129	11kv FDR A2/15 PSS S.J ENCLAVE	TX-HKS095A-1	990	RESIDENTIAL		Functional	100%	246	0.50			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM113	11kv FDR B-6, S.J ENCLAVE	TI-HKS081A-2	990	RESIDENTIAL		Functional	100%	182	0.49			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM124	11kv FDR RAJ NAGAR	TI-HKS030A-1	990	RESIDENTIAL		Functional	100%	157	0.49			

33 kv BHIKAJI CAMA PLACE GRID	SBKCM116	11kv FDR B-3 JHANDU SINGH MARG	TK-HKS025A-1	990	RESIDENTIAL	Functional	100%	185	0.46			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM129	11kv FDR A2/15 PSS S.J.ENCLAVE	TX-HKS091A-2	990	RESIDENTIAL	Functional	100%	0	0.45			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM129	11kv FDR A2/15 PSS S.J.ENCLAVE	TI-HKS090A-2	990	RESIDENTIAL	Functional	100%	0	0.44			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM105	11kv FDR B-4, S.J ENCLAVE	TI-HKS071A-1	990	RESIDENTIAL	Functional	100%	1095	0.42			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM116	11kv FDR B-3 JHANDU SINGH MARG	TX-HKS233A-1	990	RESIDENTIAL	Functional	100%	622	0.41			
33 kv R.K.PURAM - 2 GRID	SRKP2119	11kv FDR R.K KHANNA STADIUM	TI-HKS015A-1	630	RESIDENTIAL	Functional	100%	1264	0.38			
33 kv R.K.PURAM - 2 GRID	SRKP2119	11kv FDR R.K KHANNA STADIUM	TI-HKS015A-3	630	RESIDENTIAL	Functional	100%	0	0.38			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM108	11kv FDR B-5, S.J ENCLAVE	TI-HKS031A-2	990	RESIDENTIAL	Functional	100%	308	0.37			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM124	11kv FDR RAJ NAGAR	TI-HKS030A-2	990	RESIDENTIAL	Functional	100%	67	0.35			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM116	11kv FDR B-3 JHANDU SINGH MARG	TK-HKS025A-2	990	RESIDENTIAL	Functional	100%	201	0.34			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM129	11kv FDR A2/15 PSS S.J.ENCLAVE	TI-HKS090A-1	990	RESIDENTIAL	Functional	100%	383	0.34			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM116	11kv FDR B-3 JHANDU SINGH MARG	TG-HKS269A-2	630	RESIDENTIAL	Functional	100%	0	0.33			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM124	11kv FDR RAJ NAGAR	TK-HKS074A-1	990	RESIDENTIAL	Functional	100%	299	0.32			
33 kv R.K.PURAM - 2 GRID	SRKP2119	11kv FDR R.K KHANNA STADIUM	TG-HKS094A-1	630	RESIDENTIAL	Functional	100%	503	0.31			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM108	11kv FDR B-5, S.J ENCLAVE	TX-HKS230A-1	990	RESIDENTIAL	Functional	100%	378	0.27			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM116	11kv FDR B-3 JHANDU SINGH MARG	551GPK-HKS301A-	990	RESIDENTIAL	Functional	100%	81	0.24			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM110	11kv FDR A-1 S.J ENCLAVE	TI-HKS138A-1	400	RESIDENTIAL	Functional	100%	3	0.17			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM110	11kv FDR A-1 S.J ENCLAVE	551GPK-HKS036A-	990	RESIDENTIAL	Functional	100%	0	0.15			
33 kv R.K.PURAM - 1 GRID	SRKP1111	11kv FDR O/G R.K.KHANNA STADIUM	551GPK-HKS026A-	990	MIXED	Functional	100%	111	0.00			
33 kv I.I.T. GRID	SIITG115	11kv FDR O/G TELEPHONE EXCHANGE S.D.A	TI-HKS076A-2	990	RESIDENTIAL	Functional	100%	204	0.61	6.60	0.10	1.54%
33 kv ADCHINI GRID	SADCN103	11kv FDR TIKONA PARK	TX-HKS093A-3	990	RESIDENTIAL	Functional	100%	0	0.61			
33 kv SHIVALIK GRID	SSHIV111	11kv FDR O/G TO C-1 TIKONA PARK S.D.A	TI-HKS073A-2	990	RESIDENTIAL	Functional	100%	0	0.59			
33 kv ADCHINI GRID	SADCN103	11kv FDR TIKONA PARK	TX-HKS093A-2	990	RESIDENTIAL	Functional	100%	93	0.50			
33 kv I.I.T. GRID	SIITG115	11kv FDR O/G TELEPHONE EXCHANGE S.D.A	TI-HKS076A-1	990	RESIDENTIAL	Functional	100%	281	0.47			
33 kv ADCHINI GRID	SADCN103	11kv FDR TIKONA PARK	TG-HKS276A-1	990	COMMERCIAL	Functional	100%	287	0.43			
33 kv ADCHINI GRID	SADCN103	11kv FDR TIKONA PARK	TX-HKS093A-1	990	RESIDENTIAL	Functional	100%	364	0.40			
33 kv ADCHINI GRID	SADCN110	11kv FDR BHIM NAGRI (I.I.T S/S NO.-2	TK-HKS075A-1	990	RESIDENTIAL	Functional	100%	330	0.38			
33 kv ADCHINI GRID	SADCN103	11kv FDR TIKONA PARK	TI-HKS073B-1	990	RESIDENTIAL	Functional	100%	0	0.37			
33 kv I.I.T. GRID	SIITG115	11kv FDR O/G TELEPHONE EXCHANGE S.D.A	TG-HKS088A-2	990	RESIDENTIAL	Functional	100%	163	0.37			
33 kv ADCHINI GRID	SADCN110	11kv FDR BHIM NAGRI (I.I.T S/S NO.-2	TK-HKS075A-2	630	RESIDENTIAL	Functional	100%	133	0.31			
33 kv SHIVALIK GRID	SSHIV110	11kv FDR O/G TO BHIM NAGRI S.D.A	TI-HKS077A-2	1000	RESIDENTIAL	Functional	100%	301	0.29			
33 kv I.I.T. GRID	SIITG115	11kv FDR O/G TELEPHONE EXCHANGE S.D.A	TG-HKS088A-1	990	RESIDENTIAL	Functional	100%	211	0.26			
33 kv SHIVALIK GRID	SSHIV110	11kv FDR O/G TO BHIM NAGRI S.D.A	TI-HKS077A-3	990	RESIDENTIAL	Functional	100%	0	0.24			
33 kv SHIVALIK GRID	SSHIV111	11kv FDR O/G TO C-1 TIKONA PARK S.D.A	TX-HKS035A-1	990	RESIDENTIAL	Functional	100%	253	0.22			
33 kv ADCHINI GRID	SADCN103	11kv FDR TIKONA PARK	TI-HKS073A-3	400	RESIDENTIAL	Functional	100%	0	0.19			
33 kv ADCHINI GRID	SADCN103	11kv FDR TIKONA PARK	TI-HKS073A-1	990	RESIDENTIAL	Functional	100%	448	0.16			
33 kv I.I.T. GRID	SIITG115	11kv FDR O/G TELEPHONE EXCHANGE S.D.A	TX-HKS089A-1	990	RESIDENTIAL	Functional	100%	112	0.16			
33 kv SHIVALIK GRID	SSHIV110	11kv FDR O/G TO BHIM NAGRI S.D.A	TI-HKS077A-1	630	RESIDENTIAL	Functional	100%	177	0.13			
33 kv I.I.T. GRID	SIITG115	11kv FDR O/G TELEPHONE EXCHANGE S.D.A	TP-HKS228A-1	400	RESIDENTIAL	Functional	100%	29	0.01			
33 kv ADCHINI GRID	SADCN103	11kv FDR TIKONA PARK	551GPK-HKS093A-	400	RESIDENTIAL	Functional	100%	0	0.00			
33 kv H.U.D.C.O GRID	SHUDC105	11kv FDR O/G I.O.C BUILDING	TI-HKS083A-2	990	INDUSTRIAL	Functional	100%	472	0.68	8.25	0.09	1.08%
33 kv H.U.D.C.O GRID	SHUDC105	11kv FDR O/G I.O.C BUILDING	TI-HKS072A-2	990	INDUSTRIAL	Functional	100%	181	0.65			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM125	11kv FDR B-7, S.J ENCLAVE	TG-HKS092A-1	990	INDUSTRIAL	Functional	100%	350	0.64			
33 kv H.U.D.C.O GRID	SHUDC105	11kv FDR O/G I.O.C BUILDING	TI-HKS072A-1	990	INDUSTRIAL	Functional	100%	311	0.60			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM125	11kv FDR B-7, S.J ENCLAVE	TG-HKS092A-2	990	INDUSTRIAL	Functional	100%	455	0.59			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM118	11kv FDR GREEN PARK EXTN.	TG-HKS084A-1	990	INDUSTRIAL	Functional	100%	791	0.58			
33 kv H.U.D.C.O GRID	SHUDC105	11kv FDR O/G I.O.C BUILDING	TI-HKS083A-3	990	INDUSTRIAL	Functional	100%	241	0.55			
33 kv ADCHINI GRID	SADCN103	11kv FDR TIKONA PARK	TI-HKS022A-1	990	RESIDENTIAL	Functional	100%	476	0.52			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM118	11kv FDR GREEN PARK EXTN.	TG-HKS084A-2	990	INDUSTRIAL	Functional	100%	62	0.49			
33 kv SIRI FORT GRID	SSHRI103	11kv FDR GREEN PARK MAIN	TX-HKS227A-1	990	INDUSTRIAL	Functional	100%	160	0.48			

33 kv SHIVALIK GRID	SSHIV111	11kv FDR O/G TO C-1 TIKONA PARK S.D.A	TI-HKS079A-1	990	INDUSTRIAL	Functional	100%	105	0.43			
33 kv SIRI FORT GRID	SSHRI103	11kv FDR GREEN PARK MAIN	TG-HKS023A-1	990	INDUSTRIAL	Functional	100%	169	0.43			
33 kv ADCHINI GRID	SADCN103	11kv FDR TIKONA PARK	TI-HKS022A-2	630	RESIDENTIAL	Functional	100%	0	0.33			
33 kv SIRI FORT GRID	SSHRI103	11kv FDR GREEN PARK MAIN	TI-HKS083A-1	990	INDUSTRIAL	Functional	100%	80	0.32			
33 kv SIRI FORT GRID	SSHRI103	11kv FDR GREEN PARK MAIN	TG-HKS023A-2	990	INDUSTRIAL	Functional	100%	43	0.31			
33 kv SHIVALIK GRID	SSHIV111	11kv FDR O/G TO C-1 TIKONA PARK S.D.A	TI-HKS079A-2	990	INDUSTRIAL	Functional	100%	44	0.23			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM125	11kv FDR B-7, S.J ENCLAVE	TG-HKS278A-1	630	COMMERCIAL	Functional	100%	158	0.21			
33 kv H.U.D.C.O GRID	SHUDC105	11kv FDR O/G I.O.C BUILDING	TP-HKS264A-1	400	COMMERCIAL	Functional	100%	30	0.18			
33 kv H.U.D.C.O GRID	SHUDC105	11kv FDR O/G I.O.C BUILDING	TG-HKS265A-1	630	INDUSTRIAL	Functional	100%	65	0.11			
33 kv R.K.PURAM - 2 GRID	SRKP2119	11kv FDR R.K KHANNA STADIUM	551GPK-HKS317A-	630	MIXED	Functional	100%	0	0.01			
33 kv N.D.S.E.-2 GRID	SNDS104	11kv FDR O/G GREEN PARK EXTENSION	TX-HKS096A-1	990	INDUSTRIAL	Functional	100%	298	0.73	5.12	0.34	6.19%
33 kv BHIKAJI CAMA PLACE GRID	SBKCM122	11kv FDR CREAMATION GROUND, I/D G.P EXTN.	TG-HKS028A-1	990	INDUSTRIAL	Functional	100%	128	0.67			
33 kv N.D.S.E.-2 GRID	SNDS104	11kv FDR O/G GREEN PARK EXTENSION	TI-HKS078A-3	990	INDUSTRIAL	Functional	100%	326	0.60			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM122	11kv FDR CREAMATION GROUND, I/D G.P EXTN.	TG-HKS028A-2	990	INDUSTRIAL	Functional	100%	344	0.57			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM118	11kv FDR GREEN PARK EXTN.	TI-HKS078A-2	990	RESIDENTIAL	Functional	100%	189	0.53			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM122	11kv FDR CREAMATION GROUND, I/D G.P EXTN.	TG-HKS029A-2	990	INDUSTRIAL	Functional	100%	188	0.52			
33 kv N.D.S.E.-2 GRID	SNDS104	11kv FDR O/G GREEN PARK EXTENSION	TX-HKS232A-1	990	INDUSTRIAL	Functional	100%	132	0.49			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM122	11kv FDR CREAMATION GROUND, I/D G.P EXTN.	TG-HKS029A-1	990	INDUSTRIAL	Functional	100%	319	0.47			
33 kv BHIKAJI CAMA PLACE GRID	SBKCM118	11kv FDR GREEN PARK EXTN.	TI-HKS078A-1	990	INDUSTRIAL	Functional	100%	84	0.42			
33 kv H.U.D.C.O GRID	SHUDC112	11kv FDR YUSUF SARAI COMM. CENTER	TP-HKS205A-1	630	COMMERCIAL	Functional	100%	67	0.30			
33 kv I.I.T. GRID	SIITG115	11KV FDR O/G TELEPHONE EXCHANGE S.D.A	551GPK-HKS308A-	630	COMMERCIAL	Functional	100%	2	0.15			
33 kv I.I.T. GRID	SIITG107	11kv FDR O/G TIFAC BUILDING	TX-HKS244A-1	990	RESIDENTIAL	Functional	100%	1668	0.72	5.72	0.27	4.54%
33 kv ADCHINI GRID	SADCN105	11kv FDR O/G KATWARIA SARAI (MULTI STORY) NO.-1	TG-HKS223A-1	990	RESIDENTIAL	Functional	100%	1806	0.65			
33 kv I.I.T. GRID	SIITG107	11kv FDR O/G TIFAC BUILDING	TI-HKS001A-2	990	RESIDENTIAL	Functional	100%	74	0.62			
33 kv I.I.T. GRID	SIITG109	11kv FDR O/G S.I.I.A NO.-5,KATWARIA SARAI	TI-HKS005A-1	990	RESIDENTIAL	Functional	100%	340	0.54			
33 kv I.I.T. GRID	SIITG109	11kv FDR O/G S.I.I.A NO.-5,KATWARIA SARAI	TI-HKS005A-2	990	RESIDENTIAL	Functional	100%	550	0.53			
33 kv I.I.T. GRID	SIITG107	11kv FDR O/G TIFAC BUILDING	TX-HKS244A-2	630	RESIDENTIAL	Functional	100%	0	0.52			
33 kv I.I.T. GRID	SIITG107	11kv FDR O/G TIFAC BUILDING	TI-HKS001A-1	630	RESIDENTIAL	Functional	100%	884	0.49			
33 kv ADCHINI GRID	SADCN105	11kv FDR O/G KATWARIA SARAI (MULTI STORY) NO.-1	TG-HKS223A-2	630	COMMERCIAL	Functional	100%	0	0.44			
33 kv I.I.T. GRID	SIITG104	11kv FDR S.I.I.A NO.-1	TI-HKS004A-1	630	RESIDENTIAL	Functional	100%	52	0.25			
33 kv ADCHINI GRID	SADCN108	11kv FDR S.I.I.A NO.-II	TI-HKS012A-2	990	COMMERCIAL	Functional	100%	32	0.21			
33 kv I.I.T. GRID	SIITG109	11kv FDR O/G S.I.I.A NO.-5,KATWARIA SARAI	TI-HKS002A-1	990	COMMERCIAL	Functional	100%	204	0.20			
33 kv ADCHINI GRID	SADCN108	11kv FDR S.I.I.A NO.-II	551KTS-HKS309A-	400	RESIDENTIAL	Functional	100%	2	0.16			
33 kv ADCHINI GRID	SADCN108	11kv FDR S.I.I.A NO.-II	TI-HKS012A-1	990	COMMERCIAL	Functional	100%	27	0.15			
33 kv I.I.T. GRID	SIITG104	11kv FDR S.I.I.A NO.-1	TI-HKS004A-2	630	RESIDENTIAL	Functional	100%	10	0.10			
33 kv ADCHINI GRID	SADCN105	11kv FDR O/G KATWARIA SARAI (MULTI STORY) NO.-1	TI-HKS006A-1	630	RESIDENTIAL	Functional	100%	50	0.09			
33 kv I.I.T. GRID	SIITG105	11kv FDR S.I.I.A NO.-4	TI-HKS010A-1	990	RESIDENTIAL	Functional	100%	7	0.08			
33 kv ADCHINI GRID	SADCN105	11kv FDR O/G KATWARIA SARAI (MULTI STORY) NO.-1	TI-HKS007A-1	630	RESIDENTIAL	Functional	100%	19	0.06			
33 kv I.I.T. GRID	SIITG109	11kv FDR O/G S.I.I.A NO.-5,KATWARIA SARAI	TI-HKS002A-2	400	COMMERCIAL	Functional	100%	188	0.06			
66 kv J.N.U GRID	SJNUG116	11kv STR 315KVA STATION TRANS.	VK-STC078A-1	400	RESIDENTIAL	Functional	100%	0	0.04			
33 kv ADCHINI GRID	SADCN108	11kv FDR S.I.I.A NO.-II	TP-HKS021A-1	400	COMMERCIAL	Functional	100%	13	0.04			
33 kv ADCHINI GRID	SADCN108	11kv FDR S.I.I.A NO.-II	TI-HKS011A-1	630	COMMERCIAL	Functional	100%	7	0.03			
33 kv ADCHINI GRID	SADCN121	11kv FDR ADCHINI CROSSING	TP-HKS020A-1	100	COMMERCIAL	Functional	100%	26	0.01			
33 kv SIRI FORT GRID	SSHRI106	11kv FDR O/G INSTITUTIONAL AREA HAUZ KHAS	TI-HKS159A-1	990	COMMERCIAL	Functional	100%	102	0.68	4.19	0.17	3.98%
33 kv SIRI FORT GRID	SSHRI102	11kv FDR O/G E-BLOCK HAUZ KHAS	TI-HKS154A-3	990	COMMERCIAL	Functional	100%	189	0.65			
33 kv SIRI FORT GRID	SSHRI104	11kv FDR PHD HOUSE	TX-HKS177A-1	990	COMMERCIAL	Functional	100%	384	0.46			
33 kv SIRI FORT GRID	SSHRI104	11kv FDR PHD HOUSE	TG-HKS176A-1	630	COMMERCIAL	Functional	100%	873	0.40			
33 kv SIRI FORT GRID	SSHRI102	11kv FDR O/G E-BLOCK HAUZ KHAS	TI-HKS154A-4	990	COMMERCIAL	Functional	100%	0	0.37			
33 kv SIRI FORT GRID	SSHRI104	11kv FDR PHD HOUSE	TG-HKS176A-2	990	COMMERCIAL	Functional	100%	62	0.31			
33 kv SIRI FORT GRID	SSHRI106	11kv FDR O/G INSTITUTIONAL AREA HAUZ KHAS	TI-HKS160A-2	400	COMMERCIAL	Functional	100%	0	0.29			

33 kv SIRI FORT GRID	SSHRI102	11kv FDR O/G E-BLOCK HAUZ KHAS	TI-HKS154A-1	630	COMMERCIAL		Functional	100%	0	0.29			
33 kv SIRI FORT GRID	SSHRI106	11kv FDR O/G INSTITUTIONAL AREA HAUZ KHAS	TI-HKS159A-2	990	COMMERCIAL		Functional	100%	146	0.29			
33 kv SIRI FORT GRID	SSHRI102	11kv FDR O/G E-BLOCK HAUZ KHAS	TI-HKS154A-2	990	COMMERCIAL		Functional	100%	261	0.27			
33 kv SIRI FORT GRID	SSHRI106	11kv FDR O/G INSTITUTIONAL AREA HAUZ KHAS	TI-HKS160A-1	990	COMMERCIAL		Functional	100%	363	0.26			
33 kv SIRI FORT GRID	SSHRI106	11kv FDR O/G INSTITUTIONAL AREA HAUZ KHAS	TI-HKS161A-2	400	COMMERCIAL		Functional	100%	0	0.04			
33 kv SIRI FORT GRID	SSHRI106	11kv FDR O/G INSTITUTIONAL AREA HAUZ KHAS	TI-HKS161A-1	630	COMMERCIAL		Functional	100%	13	0.04			
33 kv H.U.D.C.O GRID	SHUDC105	11kv FDR O/G I.O.C BUILDING	2551RBI-HKS303A-	630	RESIDENTIAL		Functional	100%	1	0.01			
33 kv I.I.T. GRID	SIITG106	11KV FDR CSMRS (DOUBLE CABLE)	TG-HKS013A-1	990	RESIDENTIAL	AMR	Functional	100%	431	0.67	3.84	0.06	1.50%
33 kv I.I.T. GRID	SIITG106	11KV FDR CSMRS (DOUBLE CABLE)	TI-HKS018A-2	990	RESIDENTIAL		Functional	100%	278	0.62			
33 kv I.I.T. GRID	SIITG106	11KV FDR CSMRS (DOUBLE CABLE)	TI-HKS003A-1	990	RESIDENTIAL		Functional	100%	688	0.39			
33 kv ADCHINI GRID	SADCN110	11kv FDR BHIM NAGRI (I.I.T S/S NO.-2	TI-HKS016A-1	990	COMMERCIAL	AMR	Functional	100%	578	0.37			
33 kv I.I.T. GRID	SIITG106	11KV FDR CSMRS (DOUBLE CABLE)	TG-HKS013A-2	630	RESIDENTIAL	AMR	Functional	100%	618	0.34			
33 kv I.I.T. GRID	SIITG106	11KV FDR CSMRS (DOUBLE CABLE)	TI-HKS018A-1	990	RESIDENTIAL		Functional	100%	541	0.33			
33 kv ADCHINI GRID	SADCN110	11kv FDR BHIM NAGRI (I.I.T S/S NO.-2	TI-HKS017A-1	990	COMMERCIAL	AMR	Functional	100%	595	0.31			
33 kv I.I.T. GRID	SIITG106	11KV FDR CSMRS (DOUBLE CABLE)	TI-HKS003A-2	400	RESIDENTIAL		Functional	100%	0	0.24			
33 kv I.I.T. GRID	SIITG116	11KV FDR O/G PROFESSOR FLATS I.I.T S/STN	TI-HKS143A-4	630	COMMERCIAL		Functional	100%	22	0.12			
33 kv I.I.T. GRID	SIITG116	11KV FDR O/G PROFESSOR FLATS I.I.T S/STN	TI-HKS143A-2	630	COMMERCIAL		Functional	100%	30	0.11			
33 kv I.I.T. GRID	SIITG116	11KV FDR O/G PROFESSOR FLATS I.I.T S/STN	TI-HKS143A-1	630	COMMERCIAL		Functional	100%	30	0.10			
33 kv I.I.T. GRID	SIITG110	11KV FDRO/G I.I.T MINI CAMPUS	TI-HKS009A-1	630	RESIDENTIAL		Functional	100%	3	0.09			
33 kv I.I.T. GRID	SIITG110	11kv FDRO/G I.I.T MINI CAMPUS	2551KTS-HKS008A-	630	MIXED		Functional	100%	90	0.08			
33 kv I.I.T. GRID	SIITG116	11KV FDR O/G PROFESSOR FLATS I.I.T S/STN	TG-HKS293A-1	630	RESIDENTIAL		Functional	100%	57	0.08			
33 kv I.I.T. GRID	SIITG108	11kv STR 100kVA STATION TRANSFORMER	HK-STC110A-1	100	COMMERCIAL		Functional	100%	1	0.01			
33 kv I.I.T. GRID	SIITG110	11kv FDRO/G I.I.T MINI CAMPUS	2551KTS-HKS008A-	400	MIXED		Functional	100%	74	0.01			
33 kv N.D.S.E.-2 GRID	SNDSE116	11KV OG AIIMS STAFF QTRS	TX-HKS225A-1	990	COMMERCIAL		Functional	100%	504	0.74	10.32	0.04	0.40%
33 kv N.D.S.E.-2 GRID	SNDSE107	11KV FDR 11KV O/G COMMUNITY CENTER, NDSE-II	TI-HKS129A-1	990	COMMERCIAL		Functional	100%	379	0.73			
33 kv N.D.S.E.-2 GRID	SNDSE107	11KV FDR 11KV O/G COMMUNITY CENTER, NDSE-II	TG-HKS128A-1	990	COMMERCIAL		Functional	100%	217	0.70			
33 kv H.U.D.C.O GRID	SHUDC104	11KV FDR O/G POLICE COLONY ANDREWS GANJ	TG-HKS131A-1	990	COMMERCIAL	AMR	Functional	100%	740	0.65			
33 kv H.U.D.C.O GRID	SHUDC104	11KV FDR O/G POLICE COLONY ANDREWS GANJ	TX-HKS133A-1	990	COMMERCIAL	AMR	Functional	100%	177	0.59			
33 kv N.D.S.E.-2 GRID	SNDSE107	11KV FDR 11KV O/G COMMUNITY CENTER, NDSE-II	TI-HKS147A-1	990	COMMERCIAL	AMR	Functional	100%	435	0.56			
33 kv N.D.S.E.-2 GRID	SNDSE109	11KV FDR 11KV TO O/G MEDICAL ENCLAVE RMU	TI-HKS120A-2	990	COMMERCIAL		Functional	100%	0	0.49			
33 kv N.D.S.E.-2 GRID	SNDSE101	11KV FDR 11KV O/G YES BANK NDSE-2	TG-HKS127A-1	990	COMMERCIAL		Functional	100%	78	0.47			
33 kv N.D.S.E.-2 GRID	SNDSE116	11KV OG AIIMS STAFF QTRS	TK-HKS117A-2	990	COMMERCIAL		Functional	100%	0	0.47			
33 kv H.U.D.C.O GRID	SHUDC104	11KV FDR O/G POLICE COLONY ANDREWS GANJ	TX-HKS132A-1	990	COMMERCIAL	AMR	Functional	100%	354	0.47			
33 kv N.D.S.E.-2 GRID	SNDSE116	11KV OG AIIMS STAFF QTRS	TK-HKS117A-1	990	COMMERCIAL		Functional	100%	963	0.47			
33 kv H.U.D.C.O GRID	SHUDC104	11KV FDR O/G POLICE COLONY ANDREWS GANJ	TG-HKS131A-2	630	COMMERCIAL		Functional	100%	0	0.46			
33 kv N.D.S.E.-2 GRID	SNDSE108	11KV FDR 11KV O/G ANDREWS GANJ POLICE STATION	TI-HKS100A-1	990	COMMERCIAL		Functional	100%	189	0.45			
33 kv N.D.S.E.-2 GRID	SNDSE116	11KV OG AIIMS STAFF QTRS	TX-HKS225A-2	630	COMMERCIAL	AMR	Functional	100%	1148	0.40			
33 kv H.U.D.C.O GRID	SHUDC106	11KV FDR N.D.S.E-2 (HUDCO SIDE)	TK-HKS216A-1	990	COMMERCIAL		Functional	100%	130	0.39			
33 kv N.D.S.E.-2 GRID	SNDSE107	11KV FDR 11KV O/G COMMUNITY CENTER, NDSE-II	TG-HKS128A-2	1600	COMMERCIAL		Functional	100%	274	0.39			
33 kv H.U.D.C.O GRID	SHUDC106	11KV FDR N.D.S.E-2 (HUDCO SIDE)	TK-HKS216A-2	990	COMMERCIAL		Functional	100%	24	0.39			
33 kv N.D.S.E.-2 GRID	SNDSE101	11KV FDR 11KV O/G YES BANK NDSE-2	TG-HKS130A-1	630	COMMERCIAL	AMR	Functional	100%	178	0.34			
33 kv N.D.S.E.-2 GRID	SNDSE109	11KV FDR 11KV TO O/G MEDICAL ENCLAVE RMU	TI-HKS120A-1	990	COMMERCIAL		Functional	100%	224	0.32			
33 kv N.D.S.E.-2 GRID	SNDSE101	11KV FDR 11KV O/G YES BANK NDSE-2	TG-HKS130A-2	990	COMMERCIAL		Functional	100%	11	0.32			
33 kv N.D.S.E.-2 GRID	SNDSE109	11KV FDR 11KV TO O/G MEDICAL ENCLAVE RMU	TI-HKS139A-1	630	COMMERCIAL		Functional	100%	35	0.30			
33 kv N.D.S.E.-2 GRID	SNDSE106	11KV O/G D-3 HTC NDSE-II ANDREWS GANJ MAIN	TX-HKS226A-1	990	COMMERCIAL		Functional	100%	19	0.24			
33 kv N.D.S.E.-2 GRID	SNDSE323	11kv STR 100kVA STATION TRANSFORMER	2551AGJ-STC087A-	100	COMMERCIAL	AMR	Functional	100%	1	0.02			
33 kv SIRI FORT GRID	SSHRI108	11kv FDR O/G GULMOHAR PARK	TG-HKS113A-1	990	RESIDENTIAL		Functional	100%	396	0.80	5.08	0.10	1.96%
33 kv SIRI FORT GRID	SSHRI101	11kv FDR NITI BAGH	TI-HKS123A-2	990	COMMERCIAL	AMR	Functional	100%	214	0.66			
33 kv SIRI FORT GRID	SSHRI108	11kv FDR O/G GULMOHAR PARK	TX-HKS114A-1	990	RESIDENTIAL		Functional	100%	267	0.57			
33 kv SIRI FORT GRID	SSHRI101	11kv FDR NITI BAGH	TI-HKS121A-1	990	RESIDENTIAL		Functional	100%	255	0.54			

33 kv SIRI FORT GRID	SSHRI108	11kv FDR O/G GULMOHAR PARK	TG-HKS113A-2	990	RESIDENTIAL		Functional	100%	208	0.53			
33 kv SIRI FORT GRID	SSHRI101	11kv FDR NITI BAGH	TX-HKS146A-1	990	RESIDENTIAL		Functional	100%	167	0.45			
33 kv SIRI FORT GRID	SSHRI101	11kv FDR NITI BAGH	TX-HKS115A-1	990	RESIDENTIAL		Functional	100%	279	0.43			
33 kv SIRI FORT GRID	SSHRI101	11kv FDR NITI BAGH	TX-HKS124A-1	990	COMMERCIAL	AMR	Functional	100%	167	0.42			
33 kv SIRI FORT GRID	SSHRI101	11kv FDR NITI BAGH	TI-HKS123A-1	990	COMMERCIAL	AMR	Functional	100%	324	0.35			
33 kv SIRI FORT GRID	SSHRI101	11kv FDR NITI BAGH	TI-HKS121B-2	990	RESIDENTIAL		Functional	100%	0	0.30			
33 kv SIRI FORT GRID	SSHRI101	11kv FDR NITI BAGH	TI-HKS121A-2	990	RESIDENTIAL		Functional	100%	177	0.12			
33 kv SIRI FORT GRID	SSHRI105	11kv FDR AGVC NO.-2	TI-HKS151A-1	990	RESIDENTIAL		Functional	100%	193	0.23	1.36	0.01	1.03%
33 kv SIRI FORT GRID	SSHRI118	11kv FDR AGVC S/STN. NO.-3	2551RBI-HKS152A-1	990	MIXED		Functional	100%	254	0.21			
33 kv SIRI FORT GRID	SSHRI105	11kv FDR AGVC NO.-2	TI-HKS151A-2	990	RESIDENTIAL		Functional	100%	70	0.19			
33 kv SIRI FORT GRID	SSHRI105	11kv FDR AGVC NO.-2	TI-HKS150A-1	990	COMMERCIAL		Functional	100%	68	0.18			
33 kv SIRI FORT GRID	SSHRI105	11kv FDR AGVC NO.-2	TI-HKS150A-2	990	COMMERCIAL		Functional	100%	130	0.15			
33 kv SIRI FORT GRID	SSHRI118	11kv FDR AGVC S/STN. NO.-3	2551RBI-HKS152A-1	990	MIXED		Functional	100%	40	0.15			
33 kv SIRI FORT GRID	SSHRI118	11kv FDR AGVC S/STN. NO.-3	TI-HKS153A-1	630	COMMERCIAL		Functional	100%	143	0.15			
33 kv SIRI FORT GRID	SSHRI118	11kv FDR AGVC S/STN. NO.-3	TI-HKS153A-2	630	COMMERCIAL		Functional	100%	78	0.12			
33 kv SIRI FORT GRID	SSHRI119	11kv FDR O/G 40-SAHPUR JAT	TI-HKS169A-2	990	COMMERCIAL		Functional	100%	184	0.86	11.73	0.57	4.66%
33 kv SIRI FORT GRID	SSHRI107	11kv FDR O/G N-98 PANCHSHEEL PARK	TG-HKS178A-2	990	COMMERCIAL		Functional	100%	856	0.76			
33 kv SIRI FORT GRID	SSHRI107	11kv FDR O/G N-98 PANCHSHEEL PARK	TG-HKS290A-1	990	RESIDENTIAL		Functional	100%	313	0.72			
33 kv SHIVALIK GRID	SSHIV106	11kv FDR 11kv O/G TO S-BLOCK PANCHSHEEL PARK	TK-HKS171A-1	990	COMMERCIAL		Functional	100%	163	0.62			
33 kv SIRI FORT GRID	SSHRI119	11kv FDR O/G 40-SAHPUR JAT	TI-HKS169A-1	630	COMMERCIAL		Functional	100%	643	0.61			
33 kv SIRI FORT GRID	SSHRI125	11kv FDR O/G SHOPPING CENTER PANCHSHEEL	TI-HKS163A-2	990	RESIDENTIAL		Functional	100%	0	0.61			
33 kv SIRI FORT GRID	SSHRI125	11kv FDR O/G SHOPPING CENTER PANCHSHEEL	TG-HKS289A-1	990	RESIDENTIAL		Functional	100%	339	0.59			
33 kv SIRI FORT GRID	SSHRI107	11kv FDR O/G N-98 PANCHSHEEL PARK	TX-HKS181A-1	990	COMMERCIAL		Functional	100%	310	0.54			
33 kv SIRI FORT GRID	SSHRI125	11kv FDR O/G SHOPPING CENTER PANCHSHEEL	TX-HKS180A-1	990	RESIDENTIAL		Functional	100%	313	0.54			
33 kv SHIVALIK GRID	SSHIV106	11kv FDR 11kv O/G TO S-BLOCK PANCHSHEEL PARK	TX-HKS181A-2	990	COMMERCIAL		Functional	100%	0	0.54			
33 kv SIRI FORT GRID	SSHRI119	11kv FDR O/G 40-SAHPUR JAT	TG-HKS179A-2	990	COMMERCIAL		Functional	100%	758	0.53			
33 kv SIRI FORT GRID	SSHRI112	11kv FDR PANCHSHEEL CLUB	TK-HKS220A-2	990	RESIDENTIAL		Functional	100%	79	0.50			
33 kv SIRI FORT GRID	SSHRI119	11kv FDR O/G 40-SAHPUR JAT	TG-HKS179A-3	630	RESIDENTIAL		Functional	100%	0	0.49			
33 kv SIRI FORT GRID	SSHRI125	11kv FDR O/G SHOPPING CENTER PANCHSHEEL	TI-HKS163A-1	990	RESIDENTIAL		Functional	100%	315	0.46			
33 kv SHIVALIK GRID	SSHIV106	11kv FDR 11kv O/G TO S-BLOCK PANCHSHEEL PARK	TG-HKS182A-1	1000	COMMERCIAL		Functional	100%	188	0.45			
33 kv SHIVALIK GRID	SSHIV106	11kv FDR 11kv O/G TO S-BLOCK PANCHSHEEL PARK	TI-HKS166A-2	990	COMMERCIAL		Functional	100%	0	0.43			
33 kv SHIVALIK GRID	SSHIV106	11kv FDR 11kv O/G TO S-BLOCK PANCHSHEEL PARK	TK-HKS171A-2	630	COMMERCIAL		Functional	100%	140	0.38			
33 kv SHIVALIK GRID	SSHIV106	11kv FDR 11kv O/G TO S-BLOCK PANCHSHEEL PARK	TI-HKS166A-1	630	COMMERCIAL		Functional	100%	432	0.38			
33 kv MASJID MOTH GRID	SMMOT106	11kv FDR O/G SOAMI NAGAR	TI-HKS165A-1	990	COMMERCIAL		Functional	100%	162	0.36			
33 kv MASJID MOTH GRID	SMMOT106	11kv FDR O/G SOAMI NAGAR	TI-HKS165A-2	990	COMMERCIAL		Functional	100%	123	0.36			
33 kv SIRI FORT GRID	SSHRI112	11kv FDR PANCHSHEEL CLUB	TK-HKS220A-1	630	COMMERCIAL		Functional	100%	244	0.30			
33 kv SIRI FORT GRID	SSHRI119	11kv FDR O/G 40-SAHPUR JAT	TG-HKS179A-1	990	COMMERCIAL		Functional	100%	492	0.30			
33 kv SIRI FORT GRID	SSHRI119	11kv FDR O/G 40-SAHPUR JAT	2551RBI-HKS179A-1	990	RESIDENTIAL		Functional	100%	0	0.24			
33 kv SIRI FORT GRID	SSHRI119	11kv FDR O/G 40-SAHPUR JAT	TG-HKS224A-1	630	COMMERCIAL		Functional	100%	523	0.22			
33 kv SHIVALIK GRID	SSHIV106	11kv FDR 11kv O/G TO S-BLOCK PANCHSHEEL PARK	TG-HKS275A-1	630	COMMERCIAL		Functional	100%	61	0.19			
33 kv SIRI FORT GRID	SSHRI119	11kv FDR O/G 40-SAHPUR JAT	TG-HKS224A-2	630	RESIDENTIAL		Functional	100%	0	0.17			
33 kv SIRI FORT GRID	SSHRI107	11kv FDR O/G N-98 PANCHSHEEL PARK	TG-HKS178A-1	630	COMMERCIAL		Functional	100%	260	0.10			
33 kv SIRI FORT GRID	SSHRI112	11kv FDR PANCHSHEEL CLUB	TI-HKS251A-1	400	COMMERCIAL		Functional	100%	4	0.05			
33 kv SIRI FORT GRID	SSHRI117	11kv STR 100kVA STATION TRF. NO.¿1	HK-STC100A-1	100	COMMERCIAL		Functional	100%	1	0.01			
66 kv PANKHA ROAD GRID	WPNRD112	11kv FDR A-4 JKP(ASALAT PUR)	TG-JAB005A-1	1600	RESIDENTIAL	AMR	Functional	100%	293	0.74	9.95	0.10	0.95%
33 kv D.C.JANAKPURI GRID	WJKPG110	11kv FDR PLOT NO-13 LIC BUILDING(DC)	TI-JAB001A-1	990	RESIDENTIAL	AMR	Functional	100%	422	0.66			
66 kv PANKHA ROAD GRID	WPNRD112	11kv FDR A-4 JKP(ASALAT PUR)	TG-JAB007A-1	990	RESIDENTIAL		Functional	100%	161	0.62			
33 kv D.C.JANAKPURI GRID	WJKPG110	11kv FDR PLOT NO-13 LIC BUILDING(DC)	TI-JAB001A-2	990	RESIDENTIAL	AMR	Functional	100%	251	0.62			
66 kv PANKHA ROAD GRID	WPNRD115	11kv FDR A-1 MOTHER DAIRY	TI-JAB003A-2	990	RESIDENTIAL	AMR	Functional	100%	213	0.57			

33 kv D.C.JANAKPURI GRID	WJKPG110	11kv FDR PLOT NO-13 LIC BUILDING(DC)	TG-JAB019A-2	990	RESIDENTIAL	AMR	Functional	100%	0	0.56			
66 kv PANKHA ROAD GRID	WPNRD115	11kv FDR A-1 MOTHER DAIRY	TG-JAB099A-1	630	RESIDENTIAL	AMR	Functional	100%	235	0.52			
33 kv D.C.JANAKPURI GRID	WJKPG110	11kv FDR PLOT NO-13 LIC BUILDING(DC)	TK-JAB004A-1	630	RESIDENTIAL	AMR	Functional	100%	583	0.44			
66 kv PANKHA ROAD GRID	WPNRD118	11kv FDR P&T QTRS (JKP)	TG-JAB009A-2	990	RESIDENTIAL	AMR	Functional	100%	0	0.41			
66 kv PANKHA ROAD GRID	WPNRD112	11kv FDR A-4 JKP(ASALAT PUR)	TG-JAB078A-1	630	RESIDENTIAL		Functional	100%	232	0.41			
66 kv PANKHA ROAD GRID	WPNRD115	11kv FDR A-1 MOTHER DAIRY	2610B1J-JAB104A-1	630	RESIDENTIAL		Functional	100%	17	0.39			
66 kv PANKHA ROAD GRID	WPNRD112	11kv FDR A-4 JKP(ASALAT PUR)	TK-JAB011A-1	990	RESIDENTIAL		Functional	100%	462	0.38			
66 kv PANKHA ROAD GRID	WPNRD118	11kv FDR P&T QTRS (JKP)	TG-JAB008A-2	630	RESIDENTIAL		Functional	100%	196	0.36			
66 kv PANKHA ROAD GRID	WPNRD112	11kv FDR A-4 JKP(ASALAT PUR)	TK-JAB011A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.35			
66 kv PANKHA ROAD GRID	WPNRD118	11kv FDR P&T QTRS (JKP)	TG-JAB009A-1	630	RESIDENTIAL	AMR	Functional	100%	316	0.33			
66 kv PANKHA ROAD GRID	WPNRD112	11kv FDR A-4 JKP(ASALAT PUR)	TI-JAB010A-2	990	RESIDENTIAL		Functional	100%	152	0.33			
33 kv D.C.JANAKPURI GRID	WJKPG110	11kv FDR PLOT NO-13 LIC BUILDING(DC)	TK-JAB019A-1	630	RESIDENTIAL	AMR	Functional	100%	259	0.32			
66 kv PANKHA ROAD GRID	WPNRD115	11kv FDR A-1 MOTHER DAIRY	TI-JAB003A-1	990	RESIDENTIAL	AMR	Functional	100%	381	0.32			
66 kv PANKHA ROAD GRID	WPNRD112	11kv FDR A-4 JKP(ASALAT PUR)	TI-JAB006A-2	630	RESIDENTIAL		Functional	100%	97	0.31			
33 kv D.C.JANAKPURI GRID	WJKPG110	11kv FDR PLOT NO-13 LIC BUILDING(DC)	TI-JAB002A-2	630	RESIDENTIAL	AMR	Functional	100%	263	0.30			
33 kv D.C.JANAKPURI GRID	WJKPG110	11kv FDR PLOT NO-13 LIC BUILDING(DC)	TI-JAB002A-1	630	RESIDENTIAL		Functional	100%	458	0.27			
33 kv D.C.JANAKPURI GRID	WJKPG110	11kv FDR PLOT NO-13 LIC BUILDING(DC)	2610B1J-JAB111A-1	630	MIXED		Functional	100%	0	0.21			
66 kv PANKHA ROAD GRID	WPNRD112	11kv FDR A-4 JKP(ASALAT PUR)	TI-JAB010A-1	990	RESIDENTIAL		Functional	100%	745	0.21			
66 kv PANKHA ROAD GRID	WPNRD115	11kv FDR A-1 MOTHER DAIRY	TI-JAB018A-1	630	RESIDENTIAL		Functional	100%	317	0.18			
66 kv PANKHA ROAD GRID	WPNRD112	11kv FDR A-4 JKP(ASALAT PUR)	TG-JAB007A-2	630	RESIDENTIAL		Functional	100%	0	0.15			
66 kv PANKHA ROAD GRID	WPNRD112	11kv FDR A-4 JKP(ASALAT PUR)	TI-JAB006A-1	630	RESIDENTIAL		Functional	100%	136	0.06			
66 kv PANKHA ROAD GRID	WPNRD116	11kv STR 400KVA STATION TRANSFORMER	TN-WTC016A-1	400	MIXED		Functional	100%	1	0.03			
33 kv D.C.JANAKPURI GRID	WJKPG109	11kv FDR PLOT NO-11 DISTT CENTER + BOOSTER PUMP JKP PT VIA RMU NO-2	TG-JAB013A-1	990	RESIDENTIAL	AMR	Functional	100%	141	0.80	4.61	0.06	1.25%
33 kv D.C.JANAKPURI GRID	WJKPG109	11kv FDR PLOT NO-11 DISTT CENTER + BOOSTER PUMP JKP PT VIA RMU NO-2	TK-JAB012A-2	1000	RESIDENTIAL		Functional	100%	379	0.76			
33 kv D.C.JANAKPURI GRID	WJKPG109	11kv FDR PLOT NO-11 DISTT CENTER + BOOSTER PUMP JKP PT VIA RMU NO-2	TK-JAB014A-1	990	RESIDENTIAL		Functional	100%	608	0.71			
33 kv D.C.JANAKPURI GRID	WJKPG109	11kv FDR PLOT NO-11 DISTT CENTER + BOOSTER PUMP JKP PT VIA RMU NO-2	TI-JAB016A-1	990	RESIDENTIAL	AMR	Functional	100%	630	0.43			
33 kv D.C.JANAKPURI GRID	WJKPG109	11kv FDR PLOT NO-11 DISTT CENTER + BOOSTER PUMP JKP PT VIA RMU NO-2	TK-JAB012A-1	630	RESIDENTIAL		Functional	100%	772	0.36			
66 kv PANKHA ROAD GRID	WPNRD118	11kv FDR P&T QTRS (JKP)	TP-JAB021A-1	630	RESIDENTIAL		Functional	100%	401	0.35			
66 kv PANKHA ROAD GRID	WPNRD118	11kv FDR P&T QTRS (JKP)	TI-JAB020A-2	630	RESIDENTIAL		Functional	100%	144	0.34			
66 kv PANKHA ROAD GRID	WPNRD112	11kv FDR A-4 JKP(ASALAT PUR)	TP-JAB022A-1	990	RESIDENTIAL		Functional	100%	316	0.24			
66 kv PANKHA ROAD GRID	WPNRD118	11kv FDR P&T QTRS (JKP)	TI-JAB020A-1	630	RESIDENTIAL		Functional	100%	53	0.20			
33 kv D.C.JANAKPURI GRID	WJKPG109	11kv FDR PLOT NO-11 DISTT CENTER + BOOSTER PUMP JKP PT VIA RMU NO-2	TI-JAB016A-2	990	RESIDENTIAL	AMR	Functional	100%	819	0.20			
66 kv PANKHA ROAD GRID	WPNRD112	11kv FDR A-4 JKP(ASALAT PUR)	TG-JAB022A-2	630	RESIDENTIAL		Functional	100%	0	0.17			
66 kv PANKHA ROAD GRID	WPNRD118	11kv FDR P&T QTRS (JKP)	TP-JAB017A-1	400	MIXED		Functional	100%	1	0.05			
33 kv D.C.JANAKPURI GRID	WJKPG109	11kv FDR PLOT NO-11 DISTT CENTER + BOOSTER PUMP JKP PT VIA RMU NO-2	TI-JAB015A-1	630	RESIDENTIAL	AMR	Functional	100%	156	0.03			
66 kv PANKHA ROAD GRID	WPNRD118	11kv FDR P&T QTRS (JKP)	TI-JAB015A-2	400	RESIDENTIAL	AMR	Functional	100%	24	0.02			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP122	11kv FDR CCRA SSTN JKP	TK-JCD040A-1	1600	RESIDENTIAL		Functional	100%	1223	1.02	6.62	0.00	0.07%
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP122	11kv FDR CCRA SSTN JKP	TK-JCD040A-2	990	RESIDENTIAL		Functional	100%	943	0.71			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP122	11kv FDR CCRA SSTN JKP	TK-JCD036A-1	990	RESIDENTIAL		Functional	100%	1117	0.59			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP118	11kv FDR D-1 SUB STN JKP	TG-JCD044A-1	990	RESIDENTIAL		Functional	100%	934	0.58			
33 kv MAYAPURI GRID	WMYPR112	11kv FDR TIHAR JAIL	TK-JCD043A-2	990	RESIDENTIAL		Functional	100%	302	0.57			

66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP118	11kv FDR D-1 SUB STN JKP	TI-JCD061A-2	990	RESIDENTIAL		Functional	100%	570	0.56			
33 kv MAYAPURI GRID	WMYPR112	11kv FDR TIHAR JAIL	TK-JCD043A-1	990	RESIDENTIAL		Functional	100%	611	0.48			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP122	11kv FDR CCRA SSTN JKP	TI-JCD042A-1	990	RESIDENTIAL		Functional	100%	399	0.45			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP122	11kv FDR CCRA SSTN JKP	TG-JCD037A-1	630	RESIDENTIAL		Functional	100%	702	0.43			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP122	11kv FDR CCRA SSTN JKP	TI-JCD042A-2	630	RESIDENTIAL		Functional	100%	318	0.39			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP118	11kv FDR D-1 SUB STN JKP	TI-JCD061A-1	630	RESIDENTIAL		Functional	100%	55	0.33			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP118	11kv FDR D-1 SUB STN JKP	TI-JCD041A-1	630	RESIDENTIAL		Functional	100%	241	0.25			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP118	11kv FDR D-1 SUB STN JKP	TI-JCD041A-2	630	RESIDENTIAL		Functional	100%	404	0.25			
66 kv HARI NAGAR GRID	WHRGN120	11kv FDR LIG-149	TG-MYP117A-1	1600	RESIDENTIAL		Functional	100%	351	0.68	7.98	0.02	0.27%
66 kv HARI NAGAR GRID	WHRGN130	11kv FDR GOPAL NAGAR	TI-MYP077A-2	990	RESIDENTIAL		Functional	100%	1101	0.68			
66 kv HARI NAGAR GRID	WHRGN130	11kv FDR GOPAL NAGAR	TG-MYP057A-1	990	RESIDENTIAL		Functional	100%	766	0.67			
66 kv HARI NAGAR GRID	WHRGN103	11kv FDR FATEH NAGAR	TG-MYP074A-1	990	RESIDENTIAL		Functional	100%	584	0.61			
66 kv HARI NAGAR GRID	WHRGN103	11kv FDR FATEH NAGAR	TG-MYP079A-1	990	RESIDENTIAL		Functional	100%	608	0.59			
66 kv HARI NAGAR GRID	WHRGN120	11kv FDR LIG-149	TG-MYP071A-2	1600	RESIDENTIAL		Functional	100%	657	0.57			
66 kv HARI NAGAR GRID	WHRGN120	11kv FDR LIG-149	TG-MYP071A-1	990	RESIDENTIAL		Functional	100%	423	0.52			
66 kv HARI NAGAR GRID	WHRGN130	11kv FDR GOPAL NAGAR	TI-MYP077A-3	1600	RESIDENTIAL		Functional	100%	932	0.51			
66 kv HARI NAGAR GRID	WHRGN103	11kv FDR FATEH NAGAR	610MP1-MYP074A	990	RESIDENTIAL		Functional	100%	531	0.49			
66 kv HARI NAGAR GRID	WHRGN130	11kv FDR GOPAL NAGAR	TG-MYP057A-2	630	RESIDENTIAL		Functional	100%	0	0.42			
66 kv HARI NAGAR GRID	WHRGN103	11kv FDR FATEH NAGAR	TI-MYP077A-1	990	RESIDENTIAL		Functional	100%	0	0.41			
66 kv HARI NAGAR GRID	WHRGN120	11kv FDR LIG-149	TG-MYP069A-1	630	RESIDENTIAL		Functional	100%	44	0.39			
66 kv HARI NAGAR GRID	WHRGN130	11kv FDR GOPAL NAGAR	TG-MYP076A-2	630	RESIDENTIAL		Functional	100%	0	0.35			
66 kv HARI NAGAR GRID	WHRGN120	11kv FDR LIG-149	TI-MYP067A-2	630	RESIDENTIAL		Functional	100%	178	0.32			
66 kv HARI NAGAR GRID	WHRGN103	11kv FDR FATEH NAGAR	TG-MYP116A-1	630	RESIDENTIAL		Functional	100%	319	0.31			
66 kv HARI NAGAR GRID	WHRGN120	11kv FDR LIG-149	TI-MYP067A-1	990	RESIDENTIAL		Functional	100%	0	0.22			
66 kv HARI NAGAR GRID	WHRGN130	11kv FDR GOPAL NAGAR	TG-MYP076A-1	630	RESIDENTIAL		Functional	100%	621	0.21			
66 kv HARI NAGAR GRID	WHRGN115	11kv STR 400KVA STATION TRANSFORMER	TG-WTC008A-1	400	RESIDENTIAL		Functional	100%	1	0.07			
33 kv MUKHERJEE PARK GRID	WMUKP109	11kv FDR AJANTA	TK-RJG005A-1	990	COMMERCIAL		Functional	100%	693	0.84	5.75	0.01	0.26%
66 kv HARI NAGAR GRID	WHRGN107	11kv FDR TIKONA PARK	TG-RJG004A-2	990	RESIDENTIAL		Functional	100%	0	0.72			
66 kv HARI NAGAR GRID	WHRGN107	11kv FDR TIKONA PARK	TG-RJG006A-1	990	COMMERCIAL		Functional	100%	847	0.66			
66 kv HARI NAGAR GRID	WHRGN107	11kv FDR TIKONA PARK	TK-RJG003A-1	990	RESIDENTIAL		Functional	100%	608	0.62			
66 kv HARI NAGAR GRID	WHRGN107	11kv FDR TIKONA PARK	TG-RJG006A-2	990	COMMERCIAL		Functional	100%	527	0.61			
66 kv HARI NAGAR GRID	WHRGN107	11kv FDR TIKONA PARK	TG-RJG004A-1	990	RESIDENTIAL		Functional	100%	1279	0.59			
33 kv MAYAPURI GRID	WMYPR113	11kv FDR KACHCHA TIHAR	TK-RJG002A-1	990	RESIDENTIAL		Functional	100%	1063	0.50			
33 kv MUKHERJEE PARK GRID	WMUKP109	11kv FDR AJANTA	TK-RJG005A-2	630	RESIDENTIAL		Functional	100%	0	0.48			
66 kv HARI NAGAR GRID	WHRGN107	11kv FDR TIKONA PARK	TG-RJG001A-1	630	RESIDENTIAL		Functional	100%	308	0.43			
66 kv HARI NAGAR GRID	WHRGN107	11kv FDR TIKONA PARK	TK-RJG003A-2	630	RESIDENTIAL		Functional	100%	343	0.32			
33 kv D.C.JANAKPURI GRID	WJKPG101	11kv FDR NANGLI ZALIB	TG-JAB093A-1	990	RESIDENTIAL	AMR	Functional	100%	296	0.72	10.29	0.14	1.37%
33 kv D.C.JANAKPURI GRID	WJKPG101	11kv FDR NANGLI ZALIB	TK-JAB039A-2	990	RESIDENTIAL		Functional	100%	413	0.70			
33 kv D.C.JANAKPURI GRID	WJKPG101	11kv FDR NANGLI ZALIB	TI-JAB038A-1	990	RESIDENTIAL	AMR	Functional	100%	577	0.69			
33 kv D.C.JANAKPURI GRID	WJKPG107	11kv FDR B-3 SS 3 JANAKPURI	TG-JAB044A-1	990	RESIDENTIAL		Functional	100%	394	0.65			
33 kv D.C.JANAKPURI GRID	WJKPG101	11kv FDR NANGLI ZALIB	TI-JAB038A-2	990	RESIDENTIAL		Functional	100%	494	0.61			
33 kv D.C.JANAKPURI GRID	WJKPG107	11kv FDR B-3 SS 3 JANAKPURI	TG-JAB046A-1	990	RESIDENTIAL		Functional	100%	612	0.58			
66 kv PANKHA ROAD GRID	WPNRD111	11kv FDR B2 JKP (CHANAN DEVI)	TG-JAB041A-2	630	RESIDENTIAL		Functional	100%	0	0.53			

33 kv D.C.JANAKPURI GRID	WJKPG107	11kv FDR B-3 SS 3 JANAKPURI	TI-JAB045A-2	990	RESIDENTIAL		Functional	100%	127	0.48			
66 kv PANKHA ROAD GRID	WPNRD111	11kv FDR B2 JKP (CHANAN DEVI)	TI-JAB040A-2	990	RESIDENTIAL		Functional	100%	458	0.47			
66 kv PANKHA ROAD GRID	WPNRD111	11kv FDR B2 JKP (CHANAN DEVI)	TP-JAB088A-1	990	RESIDENTIAL		Functional	100%	288	0.46			
33 kv D.C.JANAKPURI GRID	WJKPG101	11kv FDR NANGLI ZALIB	TK-JAB039A-1	990	RESIDENTIAL		Functional	100%	82	0.44			
33 kv D.C.JANAKPURI GRID	WJKPG107	11kv FDR B-3 SS 3 JANAKPURI	TI-JAB048A-1	990	RESIDENTIAL		Functional	100%	12	0.42			
66 kv PANKHA ROAD GRID	WPNRD111	11kv FDR B2 JKP (CHANAN DEVI)	TI-JAB040A-1	990	RESIDENTIAL		Functional	100%	681	0.39			
33 kv D.C.JANAKPURI GRID	WJKPG107	11kv FDR B-3 SS 3 JANAKPURI	TI-JAB048A-3	1000	RESIDENTIAL	AMR	Functional	100%	135	0.39			
66 kv PANKHA ROAD GRID	WPNRD111	11kv FDR B2 JKP (CHANAN DEVI)	TG-JAB042A-1	630	RESIDENTIAL		Functional	100%	617	0.38			
66 kv PANKHA ROAD GRID	WPNRD111	11kv FDR B2 JKP (CHANAN DEVI)	TG-JAB041A-1	990	RESIDENTIAL		Functional	100%	411	0.37			
66 kv PANKHA ROAD GRID	WPNRD111	11kv FDR B2 JKP (CHANAN DEVI)	2610B1J-JAB068A-1	990	RESIDENTIAL		Functional	100%	212	0.34			
33 kv D.C.JANAKPURI GRID	WJKPG107	11kv FDR B-3 SS 3 JANAKPURI	TP-JAB047A-1	630	RESIDENTIAL		Functional	100%	260	0.32			
33 kv D.C.JANAKPURI GRID	WJKPG107	11kv FDR B-3 SS 3 JANAKPURI	TI-JAB045A-1	630	RESIDENTIAL		Functional	100%	448	0.28			
66 kv PANKHA ROAD GRID	WPNRD111	11kv FDR B2 JKP (CHANAN DEVI)	2610B1J-JAB103A-1	990	RESIDENTIAL		Functional	100%	173	0.20			
33 kv D.C.JANAKPURI GRID	WJKPG101	11kv FDR NANGLI ZALIB	2610B1J-JAB039A-1	630	MIXED		Functional	100%	0	0.20			
33 kv MAYAPURI GRID	WMYPR115	11kv FDR SHIV NAGAR	2610B1J-JAB108A-1	630	RESIDENTIAL		Functional	100%	47	0.19			
33 kv D.C.JANAKPURI GRID	WJKPG101	11kv FDR NANGLI ZALIB	2610B1J-JAB110A-1	400	MIXED		Functional	100%	0	0.19			
33 kv D.C.JANAKPURI GRID	WJKPG109	11kv FDR PLOT NO-11 DISTT CENTER + BOOSTER PUMP JKP PT VIA RMU NO-2	2610C3J-JAB106A-1	990	RESIDENTIAL	AMR	Functional	100%	166	0.17			
33 kv D.C.JANAKPURI GRID	WJKPG107	11kv FDR B-3 SS 3 JANAKPURI	TI-JAB048A-2	630	RESIDENTIAL	AMR	Functional	100%	26	0.11			
66 kv PANKHA ROAD GRID	WPNRD111	11kv FDR B2 JKP CHANAN DEVI	2610B1J-JAB103B-1	990	RESIDENTIAL		Functional	100%	0	0.10			
33 kv D.C.JANAKPURI GRID	WJKPG110	11kv FDR PLOT NO-13 LIC BUILDING(DC)	2610B1J-JAB109A-1	630	MIXED		Functional	100%	0	0.07			
33 kv D.C.JANAKPURI GRID	WJKPG101	11kv FDR NANGLI ZALIB	TI-JAB050A-2	990	RESIDENTIAL	AMR	Functional	100%	246	0.70	5.17	0.11	2.16%
33 kv D.C.JANAKPURI GRID	WJKPG117	11kv FDR B6 INDOOR, CHOTI SABZI MANDI	TK-JAB058A-1	990	RESIDENTIAL		Functional	100%	653	0.68			
33 kv D.C.JANAKPURI GRID	WJKPG117	11kv FDR B6 INDOOR, CHOTI SABZI MANDI	TI-JAB056A-1	990	RESIDENTIAL	AMR	Functional	100%	503	0.66			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP121	11kv FDR B-2 BOOSTER PUMP B-2 JKP	TI-JAB049A-1	630	RESIDENTIAL		Functional	100%	0	0.49			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP121	11kv FDR B-2 BOOSTER PUMP B-2 JKP	TI-JAB049A-2	630	RESIDENTIAL		Functional	100%	90	0.48			
66 kv HARI NAGAR GRID	WHRGN127	11kv FDR SHIV NAGAR EXTN	TK-JAB051A-2	630	RESIDENTIAL		Functional	100%	0	0.47			
66 kv HARI NAGAR GRID	WHRGN127	11kv FDR SHIV NAGAR EXTN	TK-JAB051A-1	990	RESIDENTIAL	AMR	Functional	100%	376	0.38			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP121	11kv FDR B-2 BOOSTER PUMP B-2 JKP	TI-JAB053A-1	990	RESIDENTIAL	AMR	Functional	100%	449	0.32			
33 kv D.C.JANAKPURI GRID	WJKPG117	11kv FDR B6 INDOOR, CHOTI SABZI MANDI	TI-JAB056A-2	630	RESIDENTIAL	AMR	Functional	100%	90	0.30			
33 kv D.C.JANAKPURI GRID	WJKPG101	11kv FDR NANGLI ZALIB	TI-JAB050A-1	630	RESIDENTIAL		Functional	100%	15	0.29			
33 kv D.C.JANAKPURI GRID	WJKPG117	11kv FDR B6 INDOOR, CHOTI SABZI MANDI	TG-JAB059A-1	630	RESIDENTIAL		Functional	100%	308	0.25			
66 kv HARI NAGAR GRID	WHRGN127	11kv FDR SHIV NAGAR EXTN	TP-JAB052A-1	630	RESIDENTIAL		Functional	100%	649	0.25			
66 kv PANKHA ROAD GRID	WPNRD110	11kv FDR C-2 JKP	TI-JCD001A-2	990	RESIDENTIAL		Functional	100%	235	0.77	6.16	0.24	3.78%
66 kv PANKHA ROAD GRID	WPNRD114	11kv FDR RMU	TI-JCD002A-2	990	RESIDENTIAL		Functional	100%	398	0.57			
66 kv PANKHA ROAD GRID	WPNRD627	11kv FDR C-2 A	TG-JCD067A-1	1600	RESIDENTIAL		Functional	100%	419	0.55			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP106	11kv FDR C-4 JANAK PURI	TI-JCD068A-2	990	RESIDENTIAL		Functional	100%	41	0.54			
66 kv PANKHA ROAD GRID	WPNRD627	11kv FDR C-2 A	TG-JCD007A-1	990	RESIDENTIAL		Functional	100%	467	0.54			
66 kv PANKHA ROAD GRID	WPNRD110	11kv FDR C-2 JKP	TI-JCD005A-1	990	RESIDENTIAL		Functional	100%	344	0.52			
66 kv PANKHA ROAD GRID	WPNRD626	11 kv FDR C1A (AMROOD WALA) JKP	TG-JCD003A-1	630	RESIDENTIAL		Functional	100%	533	0.45			

66 KV PANKHA ROAD GRID	WPNRD110	11KV FDR C-2 JKP	TG-JCD006A-2	990	RESIDENTIAL		Functional	100%	363	0.43			
66 KV PANKHA ROAD GRID	WPNRD114	11KV FDR RMU	TG-JCD002A-3	630	RESIDENTIAL		Functional	100%	0	0.39			
66 KV PANKHA ROAD GRID	WPNRD110	11KV FDR C-2 JKP	TI-JCD001A-1	630	RESIDENTIAL		Functional	100%	219	0.35			
66 KV PANKHA ROAD GRID	WPNRD627	11KV FDR C-2 A	TI-JCD068A-1	990	RESIDENTIAL		Functional	100%	611	0.31			
66 KV PANKHA ROAD GRID	WPNRD110	11KV FDR C-2 JKP	TI-JCD005A-2	990	RESIDENTIAL		Functional	100%	124	0.28			
66 KV PANKHA ROAD GRID	WPNRD110	11KV FDR C-2 JKP	TG-JCD004A-1	630	RESIDENTIAL		Functional	100%	200	0.22			
66 KV PANKHA ROAD GRID	WPNRD114	11KV FDR RMU	2610C3J-JCD002A-3	630	MIXED		Functional	100%	0	0.14			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP106	11KV FDR C-4 JANAK PURI	2610C3J-JCD094A-3	630	MIXED		Functional	100%	0	0.13			
66 KV PANKHA ROAD GRID	WPNRD110	11KV FDR C-2 JKP	TG-JCD006A-1	400	RESIDENTIAL		Functional	100%	0	0.11			
66 KV PANKHA ROAD GRID	WPNRD114	11KV FDR RMU	2610C3J-JCD088A-3	400	RESIDENTIAL		Functional	100%	1	0.09			
66 KV PANKHA ROAD GRID	WPNRD626	11 KV FDR C1A (AMROOD WALA) JKP	TI-JCD013A-2	990	RESIDENTIAL		Functional	100%	468	0.83	8.55	0.31	3.54%
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP119	11KV FDR C-3 COMPLAINT CENTER JKP	TI-JCD009A-1	990	RESIDENTIAL		Functional	100%	284	0.82			
66 KV PANKHA ROAD GRID	WPNRD626	11 KV FDR C1A (AMROOD WALA) JKP	TG-JCD072A-1	990	RESIDENTIAL		Functional	100%	419	0.74			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP102	11KV FDR TIHAR JAIL NO-5	TK-JCD015A-1	990	RESIDENTIAL		Functional	100%	602	0.61			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP106	11KV FDR C-4 JANAK PURI	TG-JCD019A-1	990	RESIDENTIAL		Functional	100%	919	0.60			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP119	11KV FDR C-3 COMPLAINT CENTER JKP	TI-JCD009A-2	990	RESIDENTIAL		Functional	100%	485	0.56			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP102	11KV FDR TIHAR JAIL NO-5	TI-JCD020A-1	990	RESIDENTIAL		Functional	100%	419	0.55			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP102	11KV FDR TIHAR JAIL NO-5	TI-JCD020A-2	990	RESIDENTIAL		Functional	100%	192	0.52			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP106	11KV FDR C-4 JANAK PURI	TP-JCD018A-1	630	RESIDENTIAL		Functional	100%	327	0.41			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP108	11KV FDR MS BUILDING COMM CENTER- JKP	TG-JCD011A-1	990	RESIDENTIAL		Functional	100%	587	0.37			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP102	11KV FDR TIHAR JAIL NO-5	TP-JCD017A-1	630	RESIDENTIAL		Functional	100%	293	0.34			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP108	11KV FDR MS BULDING	TG-JCD011B-1	990	RESIDENTIAL		Functional	100%	0	0.31			
66 KV PANKHA ROAD GRID	WPNRD110	11KV FDR C-2 JKP	2610C3J-JCD089A-3	630	RESIDENTIAL		Functional	100%	236	0.29			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP102	11KV FDR TIHAR JAIL NO-5	TG-JCD016A-1	630	RESIDENTIAL		Functional	100%	581	0.29			
66 KV PANKHA ROAD GRID	WPNRD626	11 KV FDR C1A (AMROOD WALA) JKP	TI-JCD014A-1	630	RESIDENTIAL		Functional	100%	571	0.28			
33 KV MAYAPURI GRID	WMYPR123	11KV FDR DDU STAFF QUTRS	2610C3J-JCD091A-3	500	MIXED		Functional	100%	0	0.25			
66 KV PANKHA ROAD GRID	WPNRD626	11 KV FDR C1A (AMROOD WALA) JKP	TI-JCD013A-1	630	RESIDENTIAL		Functional	100%	196	0.24			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP119	11KV FDR C-3 COMPLAINT CENTER JKP	TG-JCD021A-1	630	RESIDENTIAL		Functional	100%	226	0.24			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP106	11KV FDR C-4 JANAK PURI	TI-JCD012A-1	990	RESIDENTIAL		Functional	100%	216	0.23			
66 KV PANKHA ROAD GRID	WPNRD626	11 KV FDR C1A (AMROOD WALA) JKP	TI-JCD014A-2	630	RESIDENTIAL		Functional	100%	1	0.19			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP106	11KV FDR C-4 JANAK PURI	TI-JCD012A-2	630	RESIDENTIAL		Functional	100%	50	0.17			
66 KV HARI NAGAR GRID	WHRGN121	11KV FDR DELHI HAAT	2610C3J-JCD085A-3	400	COMMERCIAL		Functional	100%	0	0.03			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP119	11KV FDR C-3 COMPLAINT CENTER JKP	TG-JCD025A-1	990	RESIDENTIAL		Functional	100%	636	0.56	2.88	0.04	1.22%
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP119	11KV FDR C-3 COMPLAINT CENTER JKP	TG-JCD022A-1	630	RESIDENTIAL		Functional	100%	885	0.32			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP108	11KV FDR MS BUILDING COMM CENTER- JKP	TI-JCD024A-1	990	RESIDENTIAL		Functional	100%	336	0.29			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP119	11KV FDR C-3 COMPLAINT CENTER JKP	TG-JCD022A-2	990	RESIDENTIAL		Functional	100%	176	0.29			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP108	11KV FDR MS BUILDING COMM CENTER- JKP	TI-JCD030A-1	990	RESIDENTIAL		Functional	100%	172	0.29			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP101	11KV FDR COMMUNITY CENTRE SSTN-1 (PETROL PUMP JKP)	TI-JCD029A-2	990	RESIDENTIAL		Functional	100%	109	0.26			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP108	11KV FDR MS BUILDING COMM CENTER- JKP	TI-JCD031A-1	990	RESIDENTIAL		Functional	100%	91	0.22			

66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP108	11KV FDR MS BUILDING COMM CENTER-JKP	TG-JCD023A-1	630	RESIDENTIAL		Functional	100%	505	0.22			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP108	11KV FDR MS BUILDING COMM CENTER-JKP	TI-JCD024A-2	990	RESIDENTIAL		Functional	100%	15	0.20			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP108	11KV FDR MS BUILDING COMM CENTER-JKP	TI-JCD030A-2	990	RESIDENTIAL		Functional	100%	77	0.14			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP101	11KV FDR COMMUNITY CENTRE SSTN-1 (PETROL PUMP JKP)	TI-JCD029A-1	630	RESIDENTIAL		Functional	100%	49	0.11			
33 KV MAYAPURI GRID	WMYPR121	11KV FDR POLICE CHOWKY	TI-MYP066A-2	990	RESIDENTIAL		Functional	100%	556	0.66	1.75	0.02	1.11%
33 KV MAYAPURI GRID	WMYPR121	11KV FDR POLICE CHOWKY	TI-MYP065A-2	990	RESIDENTIAL		Functional	100%	777	0.48			
33 KV MAYAPURI GRID	WMYPR121	11KV FDR POLICE CHOWKY	TI-MYP065A-1	990	RESIDENTIAL		Functional	100%	467	0.39			
33 KV MAYAPURI GRID	WMYPR121	11KV FDR POLICE CHOWKY	TI-MYP066A-1	990	RESIDENTIAL		Functional	100%	628	0.23			
33KV A-43 MAYAPURI GRID	WA43M134	11KV FDR Q.BLK RAJOURI GARDEN	TK-RJG058A-1	990	COMMERCIAL		Functional	100%	99	0.77	4.48	0.06	1.33%
33KV A-43 MAYAPURI GRID	WA43M134	11KV FDR Q.BLK RAJOURI GARDEN	TK-RJG057A-2	990	RESIDENTIAL		Functional	100%	831	0.59			
33 KV W.D.D.C (VISHAL) GRID	WVSHL116	11KV FDR F-BLK RAJOURI GARDEN	TK-RJG054A-1	990	RESIDENTIAL		Functional	100%	335	0.56			
66 KV HARI NAGAR GRID	WHRGN114	11KV FDR J-BLK C C RAJOURI	TK-RJG056A-1	990	RESIDENTIAL		Functional	100%	281	0.55			
66 KV HARI NAGAR GRID	WHRGN114	11KV FDR J-BLK C C RAJOURI	TI-RJG060A-2	630	RESIDENTIAL		Functional	100%	77	0.48			
66 KV HARI NAGAR GRID	WHRGN114	11KV FDR J-BLK C C RAJOURI	TK-RJG055A-1	400	RESIDENTIAL		Functional	100%	418	0.34			
66 KV HARI NAGAR GRID	WHRGN114	11KV FDR J-BLK C C RAJOURI	TK-RJG057A-1	630	RESIDENTIAL		Functional	100%	141	0.34			
33KV A-43 MAYAPURI GRID	WA43M134	11KV FDR Q.BLK RAJOURI GARDEN	TK-RJG058A-2	630	RESIDENTIAL		Functional	100%	241	0.32			
66 KV HARI NAGAR GRID	WHRGN114	11KV FDR J-BLK C C RAJOURI	TI-RJG060A-1	630	RESIDENTIAL		Functional	100%	72	0.30			
66 KV HARI NAGAR GRID	WHRGN114	11KV FDR J-BLK C C RAJOURI	TP-RJG055A-2	400	RESIDENTIAL		Functional	100%	0	0.29			
33 KV MAYAPURI GRID	WMYPR123	11KV FDR DDU STAFF QUTRS	TP-MYP070A-1	630	RESIDENTIAL		Functional	100%	1322	0.57	2.53	0.03	1.08%
33 KV MAYAPURI GRID	WMYPR123	11KV FDR DDU STAFF QUTRS	TI-MYP072A-1	630	RESIDENTIAL	AMR	Functional	100%	725	0.45			
33 KV MAYAPURI GRID	WMYPR123	11KV FDR DDU STAFF QUTRS	TI-MYP072A-2	990	RESIDENTIAL	AMR	Functional	100%	189	0.43			
33 KV MAYAPURI GRID	WMYPR105	11KV FDR DDU HOSPITAL	610MP1-MYP098B	990	RESIDENTIAL		Functional	100%	0	0.42			
33 KV MAYAPURI GRID	WMYPR105	11KV FDR DDU HOSPITAL	610MP1-MYP098A	990	RESIDENTIAL		Functional	100%	548	0.33			
33 KV MAYAPURI GRID	WMYPR123	11KV FDR DDU STAFF QUTRS	TG-MYP137A-1	400	RESIDENTIAL		Functional	100%	36	0.11			
33 KV MAYAPURI GRID	WMYPR109	11KV FDR AJANTA	TP-MYP120A-1	400	RESIDENTIAL		Functional	100%	1	0.11			
33 KV MAYAPURI GRID	WMYPR123	11KV FDR DDU STAFF QUTRS	TP-MYP131A-1	250	RESIDENTIAL		Functional	100%	1	0.10			
66 KV HARI NAGAR GRID	WHRGN111	11KV FDR SUB DISTT CENTER NO-2 HARI NAGAR	TI-MYP006A-1	100	INDUSTRIAL		Functional	100%	5	0.03			
33 KV D.C.JANAKPURI GRID	WJKPG115	11 KV FDR PLOT NO.-7A, D.C JANAKPURI	TI-JAB031A-1	400	COMMERCIAL		Functional	100%	99	0.17	1.45	0.02	1.35%
33 KV D.C.JANAKPURI GRID	WJKPG108	11KV FDR PLOT NO 5 DC JKP	TI-JAB029A-1	630	COMMERCIAL		Functional	100%	54	0.15			
33 KV D.C.JANAKPURI GRID	WJKPG108	11KV FDR PLOT NO 5 DC JKP	TI-JAB028A-1	990	COMMERCIAL		Functional	100%	90	0.13			
33 KV D.C.JANAKPURI GRID	WJKPG108	11KV FDR PLOT NO 5 DC JKP	TI-JAB026A-3	630	COMMERCIAL		Functional	100%	24	0.13			
33 KV D.C.JANAKPURI GRID	WJKPG108	11KV FDR PLOT NO 5 DC JKP	TI-JAB028A-2	1000	COMMERCIAL		Functional	100%	117	0.12			
33 KV D.C.JANAKPURI GRID	WJKPG115	11 KV FDR PLOT NO.-7A, D.C JANAKPURI	TI-JAB031A-2	400	COMMERCIAL		Functional	100%	99	0.11			
33 KV D.C.JANAKPURI GRID	WJKPG108	11KV FDR PLOT NO 5 DC JKP	TI-JAB027A-1	630	COMMERCIAL		Functional	100%	124	0.10			
33 KV D.C.JANAKPURI GRID	WJKPG108	11KV FDR PLOT NO 5 DC JKP	TI-JAB029A-2	630	COMMERCIAL		Functional	100%	37	0.10			
33 KV D.C.JANAKPURI GRID	WJKPG108	11KV FDR PLOT NO 5 DC JKP	TI-JAB027A-2	630	COMMERCIAL		Functional	100%	172	0.09			
33 KV D.C.JANAKPURI GRID	WJKPG115	11 KV FDR PLOT NO.-7A, D.C JANAKPURI	TI-JAB025A-3	630	COMMERCIAL		Functional	100%	60	0.08			
33 KV D.C.JANAKPURI GRID	WJKPG115	11 KV FDR PLOT NO.-7A, D.C JANAKPURI	TI-JAB025A-1	630	COMMERCIAL		Functional	100%	30	0.07			
33 KV D.C.JANAKPURI GRID	WJKPG115	11 KV FDR PLOT NO.-7A, D.C JANAKPURI	TI-JAB032A-1	630	COMMERCIAL		Functional	100%	45	0.06			
33 KV D.C.JANAKPURI GRID	WJKPG108	11KV FDR PLOT NO 5 DC JKP	TI-JAB026A-2	630	COMMERCIAL		Functional	100%	59	0.05			
33 KV D.C.JANAKPURI GRID	WJKPG108	11KV FDR PLOT NO 5 DC JKP	TI-JAB026A-1	630	COMMERCIAL		Functional	100%	36	0.05			

33 kv D.C.JANAKPURI GRID	WJKPG115	11 KV FDR PLOT NO.-7A, D.C JANAKPURI	TI-JAB025A-2	630	COMMERCIAL		Functional	100%	27	0.03			
33 kv D.C.JANAKPURI GRID	WJKPG115	11 KV FDR PLOT NO.-7A, D.C JANAKPURI	TI-JAB030A-1	630	COMMERCIAL		Functional	100%	324	0.03			
33 kv D.C.JANAKPURI GRID	WJKPG109	11kv FDR PLOT NO-11 DISTT CENTER + BOOSTER PUMP JKP PT VIA RMU NO-2	TI-JAB036A-2	1000	COMMERCIAL		Functional	100%	145	0.13	1.27	0.01	0.74%
33 kv D.C.JANAKPURI GRID	WJKPG104	11kv FDR JYOTI SHIKHAR PLOT NO 8 (RMU)	TI-JAB034A-1	630	COMMERCIAL		Functional	100%	78	0.13			
33 kv D.C.JANAKPURI GRID	WJKPG104	11kv FDR JYOTI SHIKHAR PLOT NO 8 (RMU)	TI-JAB034A-2	630	COMMERCIAL		Functional	100%	62	0.11			
33 kv D.C.JANAKPURI GRID	WJKPG111	11kv FDR DISTRICT SERVICE CENTRE	TI-JAB023A-1	400	RESIDENTIAL		Functional	100%	36	0.10			
33 kv D.C.JANAKPURI GRID	WJKPG109	11kv FDR PLOT NO-11 DISTT CENTER + BOOSTER PUMP JKP PT VIA RMU NO-2	TI-JAB036A-1	1000	COMMERCIAL		Functional	100%	199	0.09			
33 kv D.C.JANAKPURI GRID	WJKPG104	11kv FDR JYOTI SHIKHAR PLOT NO 8 (RMU)	TI-JAB033A-2	630	COMMERCIAL		Functional	100%	99	0.09			
33 kv D.C.JANAKPURI GRID	WJKPG109	11kv FDR PLOT NO-11 DISTT CENTER + BOOSTER PUMP JKP PT VIA RMU NO-2	TI-JAB037A-2	630	COMMERCIAL		Functional	100%	83	0.08			
33 kv D.C.JANAKPURI GRID	WJKPG104	11kv FDR JYOTI SHIKHAR PLOT NO 8 (RMU)	TI-JAB035A-2	630	COMMERCIAL		Functional	100%	84	0.07			
33 kv D.C.JANAKPURI GRID	WJKPG109	11kv FDR PLOT NO-11 DISTT CENTER + BOOSTER PUMP JKP PT VIA RMU NO-2	TI-JAB037A-1	630	COMMERCIAL		Functional	100%	131	0.07			
33 kv D.C.JANAKPURI GRID	WJKPG104	11kv FDR JYOTI SHIKHAR PLOT NO 8 (RMU)	TI-JAB035A-1	630	COMMERCIAL		Functional	100%	183	0.07			
33 kv D.C.JANAKPURI GRID	WJKPG104	11kv FDR JYOTI SHIKHAR PLOT NO 8 (RMU)	TI-JAB033A-1	630	COMMERCIAL		Functional	100%	65	0.07			
33 kv D.C.JANAKPURI GRID	WJKPG110	11kv FDR PLOT NO-13 LIC BUILDING(DC)	TI-JAB076A-2	630	INDUSTRIAL		Functional	100%	5	0.05			
33 kv D.C.JANAKPURI GRID	WJKPG104	11kv FDR JYOTI SHIKHAR PLOT NO 8 (RMU)	TI-JAB035A-3	630	COMMERCIAL		Functional	100%	74	0.05			
33 kv D.C.JANAKPURI GRID	WJKPG111	11kv FDR DISTRICT SERVICE CENTRE	TI-JAB024A-1	630	COMMERCIAL		Functional	100%	28	0.04			
33 kv D.C.JANAKPURI GRID	WJKPG116	11kv FDR CNG PUMP D. CENTER	TP-JAB081A-2	400	COMMERCIAL		Functional	100%	8	0.04			
33 kv D.C.JANAKPURI GRID	WJKPG110	11kv FDR PLOT NO-13 LIC BUILDING(DC)	TI-JAB076A-1	630	INDUSTRIAL		Functional	100%	1	0.03			
33 kv D.C.JANAKPURI GRID	WJKPG111	11kv FDR DISTRICT SERVICE CENTRE	TI-JAB024A-2	630	COMMERCIAL		Functional	100%	9	0.02			
33 kv D.C.JANAKPURI GRID	WJKPG112	11kv STR 100KVA STATION TRANSFORMER	JK-WTC005A-1	100	RESIDENTIAL		Functional	100%	3	0.02			
33 kv D.C.JANAKPURI GRID	WJKPG116	11kv FDR CNG PUMP D. CENTER	TP-JAB081A-1	400	COMMERCIAL		Functional	100%	23	0.01			
33 kv MAYAPURI GRID	WMYPR108	11kv FDR SFS NO-1	TI-MYP063A-1	990	RESIDENTIAL		Functional	100%	990	0.66	2.95	0.22	6.87%
33 kv MAYAPURI GRID	WMYPR108	11kv FDR SFS NO-1	TG-MYP062A-1	990	RESIDENTIAL		Functional	100%	505	0.60			
33 kv MAYAPURI GRID	WMYPR108	11kv FDR SFS NO-1	TI-MYP063A-3	990	RESIDENTIAL		Functional	100%	0	0.50			
33 kv MAYAPURI GRID	WMYPR108	11kv FDR SFS NO-1	TI-MYP063A-2	990	RESIDENTIAL		Functional	100%	311	0.47			
33 kv MAYAPURI GRID	WMYPR121	11kv FDR POLICE CHOWKY	TI-MYP064A-1	630	RESIDENTIAL		Functional	100%	409	0.44			
33 kv MAYAPURI GRID	WMYPR121	11kv FDR POLICE CHOWKY	TI-MYP064A-2	990	RESIDENTIAL		Functional	100%	465	0.32			
33 kv MAYAPURI GRID	WMYPR115	11kv FDR SHIV NAGAR	TI-MYP068A-1	400	RESIDENTIAL		Functional	100%	159	0.14			
33 kv MAYAPURI GRID	WMYPR121	11kv FDR POLICE CHOWKY	TG-MYP133A-1	400	RESIDENTIAL		Functional	100%	12	0.03			
33 kv W.D.D.C (VISHAL) GRID	WVSHL133	11kv FDR A-2 BANK QTR RAJOURI GARDEN	TP-RJG023A-2	1600	RESIDENTIAL		Functional	100%	141	0.95	12.73	0.26	1.99%
33kv A-43 MAYAPURI GRID	WA43M118	11kv FDR GILL HOUSE	TX-RJG051A-1	990	RESIDENTIAL		Functional	100%	103	0.84			
33 kv W.D.D.C (VISHAL) GRID	WVSHL116	11kv FDR F-BLK RAJOURI GARDEN	TG-RJG031A-1	990	RESIDENTIAL		Functional	100%	183	0.81			
33 kv W.D.D.C (VISHAL) GRID	WVSHL133	11kv FDR A-2 BANK QTR RAJOURI GARDEN	TP-RJG023A-1	990	RESIDENTIAL		Functional	100%	270	0.73			
33 kv W.D.D.C (VISHAL) GRID	WVSHL112	11kv FDR J-3 RAJOURI GDN	TK-RJG044A-3	990	RESIDENTIAL		Functional	100%	849	0.70			
33kv A-43 MAYAPURI GRID	WA43M134	11kv FDR Q BLK RAJOURI GARDEN	TP-RJG062A-1	990	RESIDENTIAL		Functional	100%	386	0.68			
33kv A-43 MAYAPURI GRID	WA43M118	11kv FDR GILL HOUSE	TK-RJG047A-1	990	RESIDENTIAL		Functional	100%	96	0.63			
33 kv W.D.D.C (VISHAL) GRID	WVSHL112	11kv FDR J-3 RAJOURI GDN	TK-RJG044A-1	990	RESIDENTIAL		Functional	100%	0	0.61			
33 kv W.D.D.C (VISHAL) GRID	WVSHL118	11kv FDR GURUDWARA RAJAURI GDN	TK-RJG065A-1	1600	RESIDENTIAL		Functional	100%	133	0.58			
33kv A-43 MAYAPURI GRID	WA43M118	11kv FDR GILL HOUSE	TK-RJG052A-2	990	RESIDENTIAL		Functional	100%	101	0.56			

33kV A-43 MAYAPURI GRID	WA43M118	11kV FDR GILL HOUSE	TK-RJG050A-2	630	RESIDENTIAL		Functional	100%	177	0.53			
33 kv W.D.D.C (VISHAL) GRID	WVSHL112	11kV FDR J-3 RAJOURI GDN	TK-RJG044A-2	990	RESIDENTIAL		Functional	100%	272	0.47			
33 kv W.D.D.C (VISHAL) GRID	WVSHL118	11kV FDR GURUDWARA RAJAURI GDN	TK-RJG065A-2	990	RESIDENTIAL		Functional	100%	101	0.42			
33kV A-43 MAYAPURI GRID	WA43M118	11kV FDR GILL HOUSE	TK-RJG052A-1	990	RESIDENTIAL		Functional	100%	101	0.41			
33 kv W.D.D.C (VISHAL) GRID	WVSHL133	11kV FDR A-2 BANK QTR RAJOURI GARDEN	TG-RJG043A-2	990	RESIDENTIAL		Functional	100%	137	0.40			
33 kv W.D.D.C (VISHAL) GRID	WVSHL116	11kV FDR F-BLK RAJOURI GARDEN	TX-RJG048A-1	990	COMMERCIAL		Functional	100%	176	0.40			
33 kv W.D.D.C (VISHAL) GRID	WVSHL133	11kV FDR A-2 BANK QTR RAJOURI GARDEN	TG-RJG043A-1	990	RESIDENTIAL		Functional	100%	312	0.39			
33kV A-43 MAYAPURI GRID	WA43M118	11kV FDR GILL HOUSE	TK-RJG047A-2	990	RESIDENTIAL		Functional	100%	370	0.37			
33 kv W.D.D.C (VISHAL) GRID	WVSHL116	11kV FDR F-BLK RAJOURI GARDEN	TI-RJG049A-2	630	RESIDENTIAL		Functional	100%	146	0.37			
33 kv W.D.D.C (VISHAL) GRID	WVSHL116	11kV FDR F-BLK RAJOURI GARDEN	TG-RJG071A-1	990	RESIDENTIAL		Functional	100%	522	0.36			
33 kv W.D.D.C (VISHAL) GRID	WVSHL133	11kV FDR A-2 BANK QTR RAJOURI GARDEN	TK-RJG041A-1	990	RESIDENTIAL		Functional	100%	250	0.32			
33 kv W.D.D.C (VISHAL) GRID	WVSHL116	11kV FDR F-BLK RAJOURI GARDEN	TI-RJG049A-1	630	RESIDENTIAL		Functional	100%	250	0.30			
33 kv W.D.D.C (VISHAL) GRID	WVSHL133	11kV FDR A-2 BANK QTR RAJOURI GARDEN	6105BN-RJG043A-	990	RESIDENTIAL		Functional	100%	0	0.26			
33kV A-43 MAYAPURI GRID	WA43M118	11kV FDR GILL HOUSE	TK-RJG050A-1	990	RESIDENTIAL		Functional	100%	26	0.21			
33 kv W.D.D.C (VISHAL) GRID	WVSHL118	11kV FDR GURUDWARA RAJAURI GDN	TK-RJG041B-1	990	RESIDENTIAL		Functional	100%	0	0.17			
33 kv W.D.D.C (VISHAL) GRID	WVSHL130	11kV FDR L.I.G RAJOURI GARDEN	TG-RJG081A-1	630	RESIDENTIAL		Functional	100%	2	0.17			
33 kv W.D.D.C (VISHAL) GRID	WVSHL116	11kV FDR F-BLK RAJOURI GARDEN	TG-RJG053A-1	630	RESIDENTIAL		Functional	100%	151	0.14			
33 kv W.D.D.C (VISHAL) GRID	WVSHL133	11kV FDR A-2 BANK QTR RAJOURI GARDEN	TK-RJG041A-2	630	RESIDENTIAL		Functional	100%	184	0.12			
JAFFARPUR GRID SSTN	WVSHL118	11kV RAWTA	TG-RJG041B-2	630	RESIDENTIAL		Functional	100%	0	0.09			
33 kv MAYAPURI GRID	WMYPR123	11kV FDR DDU STAFF QUTRS	TK-MYP094A-1	1600	INDUSTRIAL		Functional	100%	2862	1.27	6.70	0.16	2.32%
66 kv HARI NAGAR GRID	WHRGN108	11kV FDR RMU NO-2	TK-MYP080A-1	1600	INDUSTRIAL		Functional	100%	1005	0.98			
33kV A-43 MAYAPURI GRID	WA43M120	11kV FDR RAMPURA SSTN	TG-MYP084A-1	1600	INDUSTRIAL		Functional	100%	389	0.89			
66 kv HARI NAGAR GRID	WHRGN104	11kV FDR GANDHI PARK ID SSTN	TI-MYP061A-2	990	INDUSTRIAL		Functional	100%	768	0.89			
66 kv HARI NAGAR GRID	WHRGN108	11kV FDR RMU NO-2	TI-MYP061A-1	990	INDUSTRIAL		Functional	100%	954	0.80			
66 kv HARI NAGAR GRID	WHRGN104	11kV FDR GANDHI PARK ID SSTN	TI-MYP082A-1	990	RESIDENTIAL		Functional	100%	0	0.66			
66 kv HARI NAGAR GRID	WHRGN108	11kV FDR RMU NO-2	TG-MYP061A-3	990	RESIDENTIAL		Functional	100%	0	0.54			
66 kv HARI NAGAR GRID	WHRGN108	11kV FDR RMU NO-2	TK-MYP080A-2	990	RESIDENTIAL		Functional	100%	0	0.49			
66 kv HARI NAGAR GRID	WHRGN104	11kV FDR GANDHI PARK ID SSTN	TI-MYP082A-2	630	RESIDENTIAL		Functional	100%	1052	0.33			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP110	11kV FDR INSTITUTIONAL AREA JKP	TK-JCD054A-2	990	RESIDENTIAL		Functional	100%	1529	0.72	4.12	0.02	0.43%
66 kv PANKHA ROAD GRID	WPNRD117	11kV FDR RAGHU NAGAR (NEW)	TI-JCD056A-1	1000	RESIDENTIAL	AMR	Functional	100%	830	0.65			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP130	11kV FDR MOHAN NAGAR MANDIR WALA	TG-JCD049A-1	990	RESIDENTIAL		Functional	100%	728	0.50			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP105	11kV FDR I-BLOCK SAGARPUR	2610D2J-JCD092A-	630	RESIDENTIAL		Functional	100%	50	0.47			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP130	11kV FDR MOHAN NAGAR MANDIR WALA	TG-JCD049A-2	630	COMMERCIAL		Functional	100%	0	0.40			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP105	11kV FDR I-BLOCK SAGARPUR	TG-JCD084A-1	630	RESIDENTIAL	AMR	Functional	100%	618	0.39			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP110	11kV FDR INSTITUTIONAL AREA JKP	2610D2J-JCD093A-	630	RESIDENTIAL		Functional	100%	48	0.27			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP110	11kV FDR INSTITUTIONAL AREA JKP	TI-JCD033A-1	630	RESIDENTIAL		Functional	100%	0	0.20			
33 kv MAYAPURI GRID	WMYPR122	11kV FDR D-1 JKP(CNG PUMP)	TI-JCD034A-1	630	RESIDENTIAL		Functional	100%	5	0.11			
33 kv MAYAPURI GRID	WMYPR122	11kV FDR D-1 JKP(CNG PUMP)	TI-JCD034A-2	400	RESIDENTIAL		Functional	100%	20	0.08			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP110	11kV FDR INSTITUTIONAL AREA JKP	TI-JCD032A-1	400	RESIDENTIAL		Functional	100%	63	0.08			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP110	11kV FDR INSTITUTIONAL AREA JKP	TI-JCD032A-2	400	RESIDENTIAL		Functional	100%	0	0.06			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP110	11kV FDR INSTITUTIONAL AREA JKP	TK-JCD054A-1	400	RESIDENTIAL		Functional	100%	0	0.06			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP110	11kV FDR INSTITUTIONAL AREA JKP	TI-JCD033A-2	630	RESIDENTIAL		Functional	100%	63	0.05			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP118	11kV FDR D-1 SUB STN JKP	TI-JCD053A-2	630	RESIDENTIAL		Functional	100%	0	0.03			

66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP118	11kv FDR D-1 SUB STN JKP	TI-JCD053A-1	630	RESIDENTIAL	Functional	100%	88	0.03			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP124	11kv STR 400KVA STATION TRANSFORMER	JK-WTC020A-1	400	RESIDENTIAL	Functional	100%	1	0.03			
66 kv HARI NAGAR GRID	WHRGN117	11kv FDR LIG RAJOURI GADAN	TI-RJG037A-1	1600	RESIDENTIAL	Functional	100%	367	1.15	8.30	0.12	1.42%
33 kv W.D.D.C (VISHAL) GRID	WVSHL118	11kv FDR GURUDWARA RAJAURI GDN	TK-RJG040A-2	990	RESIDENTIAL	Functional	100%	220	0.70			
66 kv HARI NAGAR GRID	WHRGN117	11kv FDR LIG RAJOURI GADAN	TI-RJG037A-2	990	RESIDENTIAL	Functional	100%	146	0.61			
66 kv HARI NAGAR GRID	WHRGN106	11kv FDR GURUDWARA R GARDEN	TK-RJG042A-1	990	RESIDENTIAL	Functional	100%	234	0.59			
66 kv HARI NAGAR GRID	WHRGN117	11kv FDR LIG RAJOURI GADAN	TK-RJG061A-2	990	RESIDENTIAL	Functional	100%	582	0.56			
66 kv HARI NAGAR GRID	WHRGN106	11kv FDR GURUDWARA R GARDEN	TK-RJG039A-1	990	RESIDENTIAL	Functional	100%	511	0.51			
33 kv W.D.D.C (VISHAL) GRID	WVSHL130	11kv FDR L.I.G RAJOURI GARDEN	TK-RJG035A-1	990	RESIDENTIAL	Functional	100%	1297	0.49			
33 kv W.D.D.C (VISHAL) GRID	WVSHL130	11kv FDR L.I.G RAJOURI GARDEN	TG-RJG077A-1	990	RESIDENTIAL	Functional	100%	195	0.49			
33 kv W.D.D.C (VISHAL) GRID	WVSHL130	11kv FDR L.I.G RAJOURI GARDEN	TK-RJG059A-1	630	RESIDENTIAL	Functional	100%	271	0.48			
33 kv W.D.D.C (VISHAL) GRID	WVSHL130	11kv FDR L.I.G RAJOURI GARDEN	TK-RJG059A-2	990	RESIDENTIAL	Functional	100%	56	0.47			
66 kv HARI NAGAR GRID	WHRGN117	11kv FDR LIG RAJOURI GADAN	TK-RJG061A-1	990	RESIDENTIAL	Functional	100%	233	0.43			
66 kv HARI NAGAR GRID	WHRGN106	11kv FDR GURUDWARA RAJOURI GARDEN	610SBN-RJG036B-	990	RESIDENTIAL	Functional	100%	0	0.38			
33 kv W.D.D.C (VISHAL) GRID	WVSHL118	11kv FDR GURUDWARA RAJAURI GDN	TK-RJG040A-1	990	RESIDENTIAL	Functional	100%	222	0.35			
66 kv HARI NAGAR GRID	WHRGN106	11kv FDR GURUDWARA R GARDEN	TK-RJG046A-1	630	RESIDENTIAL	Functional	100%	0	0.29			
66 kv HARI NAGAR GRID	WHRGN106	11kv FDR GURUDWARA R GARDEN	TK-RJG046A-2	990	RESIDENTIAL	Functional	100%	113	0.27			
66 kv HARI NAGAR GRID	WHRGN106	11kv FDR GURUDWARA R GARDEN	TP-RJG042A-2	630	RESIDENTIAL	Functional	100%	0	0.25			
66 kv HARI NAGAR GRID	WHRGN106	11kv FDR GURUDWARA R GARDEN	610SBN-RJG036A-	990	RESIDENTIAL	Functional	100%	649	0.23			
66 kv HARI NAGAR GRID	WHRGN117	11kv FDR LIG RAJOURI GADAN	TI-RJG038A-1	400	RESIDENTIAL	Functional	100%	198	0.18			
33 kv MAYAPURI GRID	WMYPR113	11kv FDR KACHCHA TIHAR	TK-RJG007A-2	990	INDUSTRIAL	Functional	100%	3322	0.76	6.92	0.21	2.93%
33 kv MAYAPURI GRID	WMYPR113	11kv FDR KACHCHA TIHAR	TP-RJG008A-1	990	INDUSTRIAL	Functional	100%	633	0.74			
66 kv HARI NAGAR GRID	WHRGN110	11kv FDR AJANTA ID SSTN	TG-RJG010A-1	990	RESIDENTIAL	Functional	100%	600	0.70			
66 kv HARI NAGAR GRID	WHRGN129	11kv FDR ARJUN BAKERY MANAK VIHAR	TG-RJG011A-2	990	RESIDENTIAL	Functional	100%	0	0.63			
33 kv MAYAPURI GRID	WMYPR109	11kv FDR AJANTA	TG-RJG067A-1	990	INDUSTRIAL	Functional	100%	1442	0.61			
66 kv HARI NAGAR GRID	WHRGN129	11kv FDR ARJUN BAKERY MANAK VIHAR	610SBN-RJG009A-	990	RESIDENTIAL	Functional	100%	0	0.57			
66 kv HARI NAGAR GRID	WHRGN129	11kv FDR ARJUN BAKERY MANAK VIHAR	TI-RJG009A-1	990	INDUSTRIAL	Functional	100%	1018	0.53			
33 kv MAYAPURI GRID	WMYPR113	11kv FDR KACHCHA TIHAR	TK-RJG007A-1	990	INDUSTRIAL	Functional	100%	0	0.45			
33 kv MAYAPURI GRID	WMYPR113	11kv FDR KACHCHA TIHAR	TK-RJG007A-3	990	RESIDENTIAL	Functional	100%	0	0.45			
66 kv HARI NAGAR GRID	WHRGN110	11kv FDR AJANTA ID SSTN	TG-RJG010A-2	630	RESIDENTIAL	Functional	100%	0	0.44			
66 kv HARI NAGAR GRID	WHRGN129	11kv FDR ARJUN BAKERY MANAK VIHAR	TK-RJG013A-1	990	INDUSTRIAL	Functional	100%	582	0.39			
33 kv MAYAPURI GRID	WMYPR113	11kv FDR KACHCHA TIHAR	610SBN-RJG008A-	990	MIXED	Functional	100%	0	0.32			
33 kv MAYAPURI GRID	WMYPR113	11kv FDR KACHCHA TIHAR	TK-RJG007B-1	990	RESIDENTIAL	Functional	100%	0	0.29			
66 kv HARI NAGAR GRID	WHRGN129	11kv FDR ARJUN BAKERY MANAK VIHAR	TK-RJG011A-1	990	INDUSTRIAL	Functional	100%	476	0.24			
33kv A-43 MAYAPURI GRID	WA43M142	11kv FDR DTC MAYAPURI E-BUS CHARGING NO. 2	TP-MYP001A-2	990	INDUSTRIAL	Functional	100%	319	0.71	2.47	0.03	1.04%
33kv A-43 MAYAPURI GRID	WA43M142	11kv FDR DTC MAYAPURI E-BUS CHARGING NO. 2	TG-MYP002A-1	990	INDUSTRIAL	Functional	100%	32	0.39			
33kv A-43 MAYAPURI GRID	WA43M142	11kv FDR DTC MAYAPURI E-BUS CHARGING NO. 2	TP-MYP001A-1	990	MIXED	Functional	100%	240	0.37			
66 kv REWARI LINE GRID (NDPL)	NRVLN103	11kv FDR A-15 MAYAPURI	TP-MYP004A-1	990	INDUSTRIAL	Functional	100%	44	0.33			
66 kv REWARI LINE GRID (NDPL)	NRVLN103	11kv FDR A-15 MAYAPURI	TI-MYP005A-2	990	INDUSTRIAL	Functional	100%	117	0.29			
66 kv REWARI LINE GRID (NDPL)	WA43M142	11kv FDR A-43 MAYA PURI	TI-MYP005A-1	990	INDUSTRIAL	Functional	100%	90	0.21			
33kv A-43 MAYAPURI GRID	WA43M115	11kv FDR A-8 PH-1 MYP:PL	TK-MYP003A-1	630	INDUSTRIAL	Functional	100%	98	0.12			
33kv A-43 MAYAPURI GRID	WA43M115	11kv FDR A-8 PH-1 MYP:PL	610MP1-MYP003A	630	MIXED	Functional	100%	0	0.08			
33 kv MAYAPURI GRID	WMYPR114	11kv FDR C-88 MAYA PURI	TI-MYP023A-2	990	INDUSTRIAL	Functional	100%	74	0.70	4.14	0.10	2.32%
METAL FORGING GRID SSTN	WMEFO101	11kv FDR METAL FORGING	TI-MYP023A-1	990	INDUSTRIAL	Functional	100%	195	0.64			
33 kv MAYAPURI GRID	WMYPR114	11kv FDR C-88 MAYA PURI	TG-MYP031A-1	990	INDUSTRIAL	Functional	100%	176	0.55			
33 kv MAYAPURI GRID	WMYPR110	11kv FDR MAHARANI SS	610MP1-MYP029A	990	INDUSTRIAL	Functional	100%	325	0.50			
33 kv MAYAPURI GRID	WMYPR110	11kv FDR MAHARANI SS	TG-MYP022A-2	990	INDUSTRIAL	Functional	100%	32	0.44			
33 kv MAYAPURI GRID	WMYPR114	11kv FDR C-88 MAYA PURI	TI-MYP023A-3	990	INDUSTRIAL	Functional	100%	49	0.40			
33 kv MAYAPURI GRID	WMYPR110	11kv FDR MAHARANI SS	610MP1-MYP029A	630	INDUSTRIAL	Functional	100%	64	0.32			

33 KV MAYAPURI GRID	WMYPR110	11KV FDR MAHARANI SS	TG-MYP022A-1	630	INDUSTRIAL		Functional	100%	103	0.32			
33 KV MAYAPURI GRID	WMYPR110	11KV FDR MAHARANI SS	610MP1-MYP029B	990	RESIDENTIAL		Functional	100%	0	0.30			
33 KV MAYAPURI GRID	WMYPR110	11KV FDR MAHARANI SS	610MP1-MYP029A	990	INDUSTRIAL		Functional	100%	63	0.06			
33 KV MAYAPURI GRID	WMYPR103	11KV FDR F-BLK MAYAPURI	TG-MYP026A-1	990	INDUSTRIAL		Functional	100%	444	0.76	7.19	0.09	1.23%
33 KV MAYAPURI GRID	WMYPR114	11KV FDR C-88 MAYA PURI	TG-MYP020A-1	990	INDUSTRIAL		Functional	100%	79	0.74			
33 KV MAYAPURI GRID	WMYPR103	11KV FDR F-BLK MAYAPURI	TI-MYP027A-1	990	INDUSTRIAL		Functional	100%	187	0.62			
33 KV MAYAPURI GRID	WMYPR114	11KV FDR C-88 MAYA PURI	TG-MYP017A-1	990	INDUSTRIAL		Functional	100%	72	0.57			
33 KV MAYAPURI GRID	WMYPR103	11KV FDR F-BLK MAYAPURI	610MP1-MYP024A	630	RESIDENTIAL		Functional	100%	0	0.52			
33 KV MAYAPURI GRID	WMYPR122	11KV FDR D-1 JKP(CNG PUMP)	TK-MYP021A-2	990	INDUSTRIAL		Functional	100%	532	0.42			
33 KV MAYAPURI GRID	WMYPR103	11KV FDR F-BLK MAYAPURI	TI-MYP028A-3	990	INDUSTRIAL		Functional	100%	731	0.42			
33 KV MAYAPURI GRID	WMYPR122	11KV FDR D-1 JKP(CNG PUMP)	TI-MYP038A-1	990	INDUSTRIAL		Functional	100%	17	0.41			
33 KV MAYAPURI GRID	WMYPR103	11KV FDR F-BLK MAYAPURI	TI-MYP028A-1	990	INDUSTRIAL		Functional	100%	110	0.39			
33 KV MAYAPURI GRID	WMYPR103	11KV FDR F-BLK MAYAPURI	TI-MYP027A-3	990	INDUSTRIAL		Functional	100%	5	0.39			
33 KV MAYAPURI GRID	WMYPR103	11KV FDR F-BLK MAYAPURI	TI-MYP028A-2	630	INDUSTRIAL		Functional	100%	13	0.37			
33 KV MAYAPURI GRID	WMYPR103	11KV FDR F-BLK MAYAPURI	TI-MYP027A-2	630	INDUSTRIAL		Functional	100%	3	0.36			
33 KV MAYAPURI GRID	WMYPR110	11KV FDR MAHARANI SS	TP-MYP025A-1	630	INDUSTRIAL		Functional	100%	69	0.36			
33 KV MAYAPURI GRID	WMYPR122	11KV FDR D-1 JKP(CNG PUMP)	TK-MYP021A-1	630	INDUSTRIAL		Functional	100%	0	0.32			
33 KV MAYAPURI GRID	WMYPR103	11KV FDR F-BLK MAYAPURI	TK-MYP024A-1	990	INDUSTRIAL		Functional	100%	102	0.31			
66 KV PANKHA ROAD GRID	WPNRD626	11 KV FDR C1A (AMROOD WALA) JKP	TG-MYP024B-1	990	RESIDENTIAL		Functional	100%	0	0.19			
33KV A-43 MAYAPURI GRID	WA43M136	11KV FDR E-BLK MAYAPURI PH-2:ID	TG-MYP028A-4	630	RESIDENTIAL		Functional	100%	0	0.11			
33 KV MAYAPURI GRID	WMYPR117	11KV FDR FACILITY CENTRE	TI-MYP035A-1	990	INDUSTRIAL	AMR	Functional	100%	0	0.75	5.82	0.12	2.07%
33 KV MAYAPURI GRID	WMYPR111	11KV FDR D-BLK KHAJAN BASTI	TI-MYP034A-2	990	INDUSTRIAL		Functional	100%	83	0.74			
33 KV MAYAPURI GRID	WMYPR117	11KV FDR FACILITY CENTRE	TI-MYP035A-2	1000	INDUSTRIAL		Functional	100%	1567	0.69			
33 KV MAYAPURI GRID	WMYPR111	11KV FDR D-BLK KHAJAN BASTI	TI-MYP034A-3	990	INDUSTRIAL		Functional	100%	650	0.63			
33 KV MAYAPURI GRID	WMYPR117	11KV FDR FACILITY CENTRE	TG-MYP039A-1	990	INDUSTRIAL		Functional	100%	133	0.48			
33 KV MAYAPURI GRID	WMYPR117	11KV FDR FACILITY CENTRE	TG-MYP099A-1	990	INDUSTRIAL		Functional	100%	285	0.47			
33 KV MAYAPURI GRID	WMYPR111	11KV FDR D-BLK KHAJAN BASTI	TG-MYP032A-1	630	INDUSTRIAL		Functional	100%	169	0.46			
33 KV MAYAPURI GRID	WMYPR111	11KV FDR D-BLK KHAJAN BASTI	TI-MYP034A-1	990	INDUSTRIAL		Functional	100%	697	0.42			
33 KV MAYAPURI GRID	WMYPR117	11KV FDR FACILITY CENTRE	TG-MYP039A-2	630	RESIDENTIAL		Functional	100%	0	0.40			
33 KV MAYAPURI GRID	WMYPR111	11KV FDR D-BLK KHAJAN BASTI	TI-MYP033A-1	990	COMMERCIAL		Functional	100%	177	0.31			
33 KV MAYAPURI GRID	WMYPR117	11KV FDR FACILITY CENTRE	TI-MYP037A-2	630	INDUSTRIAL		Functional	100%	190	0.22			
33 KV MAYAPURI GRID	WMYPR117	11KV FDR FACILITY CENTRE	610MP1-MYP037A	630	MIXED		Functional	100%	0	0.16			
33 KV MAYAPURI GRID	WMYPR111	11KV FDR D-BLK KHAJAN BASTI	TI-MYP033A-2	630	INDUSTRIAL		Functional	100%	198	0.13			
33 KV MAYAPURI GRID	WMYPR117	11KV FDR FACILITY CENTRE	TI-MYP037A-1	630	INDUSTRIAL		Functional	100%	278	0.09			
METAL FORGING GRID SSTN	WMEFO101	11KV FDR METAL FORGING	TP-MYP132A-1	990	RESIDENTIAL		Functional	100%	59	0.72	6.52	0.24	3.58%
66 KV REWARI LINE GRID (NDPL)	NRVLN104	11KV FDR B-32 MAYAPURI	TI-MYP012A-2	990	INDUSTRIAL		Functional	100%	28	0.48			
33KV A-43 MAYAPURI GRID	WA43M133	11KV FDR B-125 PHASE-1	TK-MYP011A-1	990	INDUSTRIAL		Functional	100%	410	0.48			
METAL FORGING GRID SSTN	WMEFO101	11KV FDR METAL FORGING	TI-MYP015A-1	990	COMMERCIAL		Functional	100%	92	0.47			
66 KV REWARI LINE GRID (NDPL)	WA43M142	11KV FDR B-49 MAYAPURI	TG-MYP018A-1	990	INDUSTRIAL		Functional	100%	21	0.45			
66 KV REWARI LINE GRID (NDPL)	NRVLN103	11KV FDR A-15 MAYAPURI	TI-MYP009A-1	990	INDUSTRIAL		Functional	100%	43	0.44			
66 KV REWARI LINE GRID (NDPL)	NRVLN103	11KV FDR A-15 MAYAPURI	TK-MYP010A-2	630	RESIDENTIAL		Functional	100%	0	0.41			
66 KV REWARI LINE GRID (NDPL)	NRVLN103	11KV FDR A-15 MAYAPURI	610MP1-MYP157A	630	MIXED		Functional	100%	0	0.39			
66 KV REWARI LINE GRID (NDPL)	WA43M142	11KV FDR B-49 MAYAPURI	TI-MYP013A-1	990	INDUSTRIAL		Functional	100%	188	0.32			
66 KV REWARI LINE GRID (NDPL)	WA43M142	11KV FDR B-49 MAYAPURI	TI-MYP013A-2	990	INDUSTRIAL		Functional	100%	5	0.29			
33KV A-43 MAYAPURI GRID	WA43M135	11KV FDR POLICE STN MAYAPURI	TI-MYP085A-1	990	INDUSTRIAL		Functional	100%	37	0.29			
66 KV REWARI LINE GRID (NDPL)	NRVLN104	11KV FDR B-32 MAYAPURI	TI-MYP012A-3	990	INDUSTRIAL		Functional	100%	11	0.24			
33KV A-43 MAYAPURI GRID	WA43M119	11KV FDR B-32 MAYAPURI PH-1	TK-MYP011A-2	990	INDUSTRIAL		Functional	100%	73	0.23			
66 KV REWARI LINE GRID (NDPL)	WA43M142	11KV FDR A-43 MAYA PURI	TI-MYP008A-2	630	INDUSTRIAL		Functional	100%	6	0.23			
66 KV HARI NAGAR GRID	WHRGN104	11KV FDR GANDHI PARK ID SSTN	TI-MYP085A-2	990	RESIDENTIAL		Functional	100%	0	0.21			
33KV A-43 MAYAPURI GRID	WA43M119	11KV FDR B-32 MAYAPURI PH-1	TI-MYP012A-1	990	INDUSTRIAL		Functional	100%	322	0.20			

66 KV REWARI LINE GRID (NDPL)	NRVLN103	11KV FDR A-15 MAYAPURI	TK-MYP010A-1	990	INDUSTRIAL		Functional	100%	148	0.20			
REWARI LINE GRID (NDPL)	NRVLN103	11KV FDR A-15 MAYAPURI	TK-MYP010B-1	990	RESIDENTIAL		Functional	100%	0	0.16			
66 KV REWARI LINE GRID (NDPL)	NRVLN104	11KV FDR B-32 MAYAPURI	TP-MYP019A-1	400	INDUSTRIAL		Functional	100%	47	0.15			
METAL FORGING GRID SSTN	WMEFO101	11KV FDR METAL FORGING	610MP1-MYP132A	630	MIXED		Functional	100%	0	0.14			
METAL FORGING GRID SSTN	WMEFO101	11KV FDR COMMUNITY CENTER MAYAPURI PHASE-1	TI-MYP008A-1	990	INDUSTRIAL		Functional	100%	172	0.13			
66 KV REWARI LINE GRID (NDPL)	WA43M142	11KV FDR B-49 MAYAPURI	TI-MYP016A-1	990	INDUSTRIAL		Functional	100%	14	0.11			
66 KV HARI NAGAR GRID	WHRGN118	11KV FDR MIG RAJOURI GADAN	TG-RJG033A-2	990	RESIDENTIAL		Functional	100%	167	0.56	2.97	0.04	1.25%
66 KV HARI NAGAR GRID	WHRGN118	11KV FDR MIG RAJOURI GADAN	TI-RJG066A-1	990	RESIDENTIAL		Functional	100%	612	0.44			
66 KV HARI NAGAR GRID	WHRGN118	11KV FDR MIG RAJOURI GADAN	TG-RJG033A-1	990	RESIDENTIAL		Functional	100%	523	0.39			
33 KV MUKHERJEE PARK GRID	WMUKP102	11KV FDR RED MIG RAJOURI GARDEN	TG-RJG034A-1	630	RESIDENTIAL		Functional	100%	146	0.35			
33 KV MUKHERJEE PARK GRID	WMUKP102	11KV FDR RED MIG RAJOURI GARDEN	TG-RJG073A-1	630	RESIDENTIAL		Functional	100%	534	0.34			
33 KV MUKHERJEE PARK GRID	WMUKP109	11KV FDR AJANTA	TI-RJG032A-2	630	RESIDENTIAL		Functional	100%	42	0.24			
33 KV MUKHERJEE PARK GRID	WMUKP102	11KV FDR RED MIG RAJOURI GARDEN	TG-RJG072A-1	400	RESIDENTIAL		Functional	100%	164	0.23			
33 KV MUKHERJEE PARK GRID	WMUKP109	11KV FDR AJANTA	TI-RJG032A-1	630	RESIDENTIAL		Functional	100%	195	0.22			
33 KV MUKHERJEE PARK GRID	WMUKP102	11KV FDR RED MIG RAJOURI GARDEN	610SBN-RJG072A-	630	MIXED		Functional	100%	0	0.09			
33 KV W.D.D.C (VISHAL) GRID	WVSHL118	11KV FDR GURUDWARA RAJAURI GDN	610SBN-RJG090A-	630	MIXED		Functional	100%	0	0.08			
33 KV W.D.D.C (VISHAL) GRID	WVSHL112	11KV FDR J-3 RAJOURI GDN	610SBN-RJG091A-	250	MIXED		Functional	100%	0	0.07			
33KV A-43 MAYAPURI GRID	WA43M120	11KV FDR RAMPURA SSTN	TK-MYP045A-1	990	INDUSTRIAL		Functional	100%	625	0.84	4.07	0.24	5.60%
33KV A-43 MAYAPURI GRID	WA43M137	11KV FDR MOHAN MANDIR HARI NAGAR:K	TK-MYP046A-1	990	RESIDENTIAL		Functional	100%	1378	0.75			
33KV A-43 MAYAPURI GRID	WA43M120	11KV FDR RAMPURA SSTN	TP-MYP107A-1	990	INDUSTRIAL		Functional	100%	201	0.61			
33KV A-43 MAYAPURI GRID	WA43M137	11KV FDR MOHAN MANDIR HARI NAGAR:K	TK-MYP046A-2	990	INDUSTRIAL		Functional	100%	945	0.58			
66 KV HARI NAGAR GRID	WHRGN111	11KV FDR SUB DISTT CENTER NO-2 HARI NAGAR	TG-MYP106A-1	1600	INDUSTRIAL		Functional	100%	314	0.53			
METAL FORGING GRID SSTN	WMEFO101	11KV FDR COMMUNITY CENTER MAYAPURI PHASE-1	TK-MYP047A-1	630	INDUSTRIAL		Functional	100%	1121	0.51			
66 KV HARI NAGAR GRID	WHRGN111	11KV FDR SUB DISTT CENTER NO-2 HARI NAGAR	TG-MYP106A-2	630	RESIDENTIAL		Functional	100%	0	0.25			
33KV A-43 MAYAPURI GRID	WA43M120	11KV FDR RAMPURA SSTN	TK-MYP045A-2	990	INDUSTRIAL		Functional	100%	386	0.24			
33 KV MAYAPURI GRID	WMYPR118	11KV FDR PUMPING STN S ASRAM	TI-MYP048A-2	990	INDUSTRIAL		Functional	100%	233	0.62	4.61	0.03	0.64%
33 KV MAYAPURI GRID	WMYPR118	11KV FDR PUMPING STN S ASRAM	TI-MYP048A-1	990	INDUSTRIAL		Functional	100%	127	0.57			
METAL FORGING GRID SSTN	WMEFO101	11KV FDR COMMUNITY CENTER MAYAPURI PHASE-1	TP-MYP104A-1	630	RESIDENTIAL		Functional	100%	110	0.51			
33 KV MAYAPURI GRID	WMYPR118	11KV FDR PUMPING STN S ASRAM	TP-MYP050A-1	990	RESIDENTIAL		Functional	100%	1773	0.47			
METAL FORGING GRID SSTN	WMEFO101	11KV FDR COMMUNITY CENTER MAYAPURI PHASE-1	TI-MYP052A-2	990	INDUSTRIAL		Functional	100%	294	0.40			
METAL FORGING GRID SSTN	WMEFO101	11KV FDR COMMUNITY CENTER MAYAPURI PHASE-1	TI-MYP052A-1	630	INDUSTRIAL		Functional	100%	312	0.31			
33 KV MAYAPURI GRID	WMYPR118	11KV FDR PUMPING STN S ASRAM	TI-MYP049A-2	630	RESIDENTIAL	AMR	Functional	100%	446	0.25			
33 KV MAYAPURI GRID	WMYPR118	11KV FDR PUMPING STN S ASRAM	TI-MYP048A-3	630	RESIDENTIAL		Functional	100%	0	0.24			
33KV A-43 MAYAPURI GRID	WA43M142	11KV FDR DTC MAYAPURI E-BUS CHARGING NO. 2	TI-MYP054A-2	630	INDUSTRIAL	AMR	Functional	100%	229	0.23			
33KV A-43 MAYAPURI GRID	WA43M142	11KV FDR DTC MAYAPURI E-BUS CHARGING NO. 2	TI-MYP056A-2	630	RESIDENTIAL		Functional	100%	124	0.23			
33 KV MAYAPURI GRID	WMYPR118	11KV FDR PUMPING STN S ASRAM	TI-MYP049A-1	990	RESIDENTIAL	AMR	Functional	100%	0	0.23			
33KV A-43 MAYAPURI GRID	WA43M142	11KV FDR DTC MAYAPURI E-BUS CHARGING NO. 2	TI-MYP053A-1	630	RESIDENTIAL		Functional	100%	298	0.12			
33KV A-43 MAYAPURI GRID	WA43M142	11KV FDR DTC MAYAPURI E-BUS CHARGING NO. 2	TI-MYP053A-2	400	RESIDENTIAL		Functional	100%	153	0.11			
33KV A-43 MAYAPURI GRID	WA43M142	11KV FDR DTC MAYAPURI E-BUS CHARGING NO. 2	TI-MYP056A-1	400	RESIDENTIAL		Functional	100%	63	0.11			
33KV A-43 MAYAPURI GRID	WA43M142	11KV FDR DTC MAYAPURI E-BUS CHARGING NO. 2	TI-MYP055A-2	630	RESIDENTIAL		Functional	100%	170	0.11			
33KV A-43 MAYAPURI GRID	WA43M142	11KV FDR DTC MAYAPURI E-BUS CHARGING NO. 2	TI-MYP055A-1	400	RESIDENTIAL		Functional	100%	117	0.08			
33KV A-43 MAYAPURI GRID	WA43M142	11KV FDR DTC MAYAPURI E-BUS CHARGING NO. 2	TI-MYP054A-1	400	RESIDENTIAL	AMR	Functional	100%	43	0.03			
66 KV HARI NAGAR GRID	WHRGN113	11KV FDR CET PLANT MAYAPURI	TP-MYP149A-1	250	RESIDENTIAL		Functional	100%	1	0.02			
33 KV MAYAPURI GRID	WMYPR104	11KV FDR MIG RAJOURI GARDEN	TK-MYP058A-1	990	RESIDENTIAL		Functional	100%	1219	0.64	3.54	0.05	1.34%
66 KV HARI NAGAR GRID	WHRGN104	11KV FDR GANDHI PARK ID SSTN	TI-MYP059A-1	630	INDUSTRIAL		Functional	100%	841	0.42			
33 KV MAYAPURI GRID	WMYPR104	11KV FDR MIG RAJOURI GARDEN	TI-MYP043A-1	630	RESIDENTIAL		Functional	100%	207	0.29			
33 KV MAYAPURI GRID	WMYPR104	11KV FDR MIG RAJOURI GARDEN	TI-MYP043A-2	630	RESIDENTIAL		Functional	100%	348	0.28			
33 KV MAYAPURI GRID	WMYPR104	11KV FDR MIG RAJOURI GARDEN	TI-MYP081A-1	630	INDUSTRIAL		Functional	100%	43	0.26			
33 KV MAYAPURI GRID	WMYPR108	11KV FDR SFS NO-1	TI-MYP042A-2	630	RESIDENTIAL		Functional	100%	40	0.23			
33 KV MAYAPURI GRID	WMYPR104	11KV FDR MIG RAJOURI GARDEN	TI-MYP081A-2	630	INDUSTRIAL		Functional	100%	188	0.21			

33 kv MAYAPURI GRID	WMYPR104	11KV FDR MIG RAJOURI GARDEN	TI-MYP044A-1	630	RESIDENTIAL		Functional	100%	192	0.20			
33 kv MAYAPURI GRID	WMYPR108	11kv FDR SFS NO-1	TI-MYP041A-1	630	RESIDENTIAL		Functional	100%	65	0.19			
33 kv MAYAPURI GRID	WMYPR108	11kv FDR SFS NO-1	TI-MYP042A-1	630	RESIDENTIAL		Functional	100%	187	0.19			
33 kv MAYAPURI GRID	WMYPR104	11KV FDR MIG RAJOURI GARDEN	TG-MYP058A-2	630	RESIDENTIAL		Functional	100%	0	0.14			
33 kv MAYAPURI GRID	WMYPR108	11kv FDR SFS NO-1	TI-MYP041A-2	630	RESIDENTIAL		Functional	100%	213	0.14			
33 kv MAYAPURI GRID	WMYPR104	11KV FDR MIG RAJOURI GARDEN	TI-MYP044A-2	630	RESIDENTIAL		Functional	100%	120	0.13			
33 kv MAYAPURI GRID	WMYPR108	11kv FDR SFS NO-1	TI-MYP040A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.12			
33 kv MAYAPURI GRID	WMYPR104	11KV FDR MIG RAJOURI GARDEN	TI-MYP060A-2	630	RESIDENTIAL		Functional	100%	57	0.05			
33 kv MAYAPURI GRID	WMYPR104	11KV FDR MIG RAJOURI GARDEN	TI-MYP060A-1	630	RESIDENTIAL		Functional	100%	15	0.04			
33 kv MAYAPURI GRID	WMYPR108	11kv FDR SFS NO-1	TI-MYP040A-2	630	RESIDENTIAL	AMR	Functional	100%	102	0.03			
33 kv MAYAPURI GRID	WMYPR116	11kv STR 400KVA STATION TRANSFORMER	JK-WTC011A-1	400	RESIDENTIAL		Functional	100%	1	0.02			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP109	11kv FDR BOOSTER PUMP (DELHI CANTT)	TI-JCD055A-1	990	RESIDENTIAL		Functional	100%	564	0.76	6.64	0.00	0.03%
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP130	11kv FDR MOHAN NAGAR MANDIR WALA	TK-JCD047A-1	990	RESIDENTIAL		Functional	100%	1093	0.75			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP130	11kv FDR MOHAN NAGAR MANDIR WALA	TK-JCD045A-1	990	RESIDENTIAL		Functional	100%	504	0.73			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP109	11kv FDR BOOSTER PUMP (DELHI CANTT)	TI-JCD055A-2	990	RESIDENTIAL		Functional	100%	911	0.62			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP111	11kv FDR D-2 JKP	TI-JCD050A-2	990	RESIDENTIAL		Functional	100%	265	0.59			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP118	11kv FDR D-1 SUB STN JKP	TG-JCD051A-1	990	RESIDENTIAL		Functional	100%	318	0.53			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP130	11kv FDR MOHAN NAGAR MANDIR WALA	TK-JCD045A-2	990	RESIDENTIAL		Functional	100%	839	0.51			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP111	11kv FDR D-2 JKP	TP-JCD048A-2	990	RESIDENTIAL		Functional	100%	383	0.41			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP111	11kv FDR D-2 JKP	2610D2J-JCD046A-1	630	RESIDENTIAL		Functional	100%	0	0.40			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP118	11kv FDR D-1 SUB STN JKP	TI-JCD050A-1	990	RESIDENTIAL		Functional	100%	751	0.38			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP111	11kv FDR D-2 JKP	TP-JCD048A-1	630	RESIDENTIAL		Functional	100%	689	0.30			
33 kv MAYAPURI GRID	WMYPR115	11kv FDR SHIV NAGAR	TI-JCD058A-1	630	RESIDENTIAL		Functional	100%	2	0.25			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP130	11kv FDR MOHAN NAGAR MANDIR WALA	2610D2J-JCD047A-1	630	RESIDENTIAL		Functional	100%	0	0.21			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP111	11kv FDR D-2 JKP	TG-JCD046A-1	630	RESIDENTIAL		Functional	100%	899	0.19			
66 kv HARI NAGAR GRID	WHRGN109	11kv FDR 14-BLOCK SUBHASH NAGAR	TK-RJG019A-1	990	RESIDENTIAL		Functional	100%	718	0.77	5.91	0.09	1.52%
66 kv HARI NAGAR GRID	WHRGN114	11kv FDR J-BLK C C RAJOURI	TK-RJG069A-1	990	RESIDENTIAL		Functional	100%	716	0.67			
33kv A-43 MAYAPURI GRID	WA43M117	11kv FDR SSTN NO-2 SUBHASH NAGAR	TI-RJG030A-1	990	RESIDENTIAL		Functional	100%	722	0.63			
33kv A-43 MAYAPURI GRID	WA43M117	11kv FDR SSTN NO-2 SUBHASH NAGAR	TK-RJG021A-1	990	RESIDENTIAL		Functional	100%	1141	0.55			
66 kv HARI NAGAR GRID	WHRGN109	11kv FDR 14-BLOCK SUBHASH NAGAR	TK-RJG020A-2	990	RESIDENTIAL		Functional	100%	514	0.49			
66 kv HARI NAGAR GRID	WHRGN109	11kv FDR 14-BLOCK SUBHASH NAGAR	TK-RJG020A-1	990	RESIDENTIAL		Functional	100%	859	0.42			
66 kv HARI NAGAR GRID	WHRGN109	11kv FDR 14-BLOCK SUBHASH NAGAR	TG-RJG020A-3	630	RESIDENTIAL		Functional	100%	0	0.41			
33kv A-43 MAYAPURI GRID	WA43M117	11kv FDR SSTN NO-2 SUBHASH NAGAR	TI-RJG030A-2	990	RESIDENTIAL		Functional	100%	344	0.40			
33kv A-43 MAYAPURI GRID	WA43M117	11kv FDR SSTN NO-2 SUBHASH NAGAR	TK-RJG024A-2	990	RESIDENTIAL		Functional	100%	549	0.39			
33kv A-43 MAYAPURI GRID	WA43M117	11kv FDR SSTN NO-2 SUBHASH NAGAR	TP-RJG021A-2	990	RESIDENTIAL		Functional	100%	0	0.28			
33kv A-43 MAYAPURI GRID	WA43M117	11kv FDR SSTN NO-2 SUBHASH NAGAR	TG-RJG030A-3	630	RESIDENTIAL		Functional	100%	0	0.25			
66 kv HARI NAGAR GRID	WHRGN109	11kv FDR 14-BLOCK SUBHASH NAGAR	TP-RJG064A-1	400	RESIDENTIAL		Functional	100%	236	0.16			
JAFFARPUR GRID SSTN	NRVLN106	11kv RMU OUTSIDE GRID	TG-RJG021C-2	990	RESIDENTIAL		Functional	100%	0	0.15			
33kv A-43 MAYAPURI GRID	WA43M117	11kv FDR SSTN NO-2 SUBHASH NAGAR	TK-RJG024A-1	630	RESIDENTIAL		Functional	100%	0	0.15			
66 kv HARI NAGAR GRID	WHRGN109	11kv FDR 14-BLOCK SUBHASH NAGAR	610SBN-RJG064A-1	630	RESIDENTIAL		Functional	100%	0	0.12			
REWARI LINE GRID (NDPL)	NRVLN106	11kv FDR 11&12 BLK SUBHASH NAGAR	TG-RJG021B-2	990	RESIDENTIAL		Functional	100%	0	0.11			
33 kv W.D.D.C (VISHAL) GRID	WVSHL116	11kv FDR F-BLK RAJOURI GARDEN	610SBN-RJG092A-1	250	MIXED		Functional	100%	0	0.03			
33 kv MUKHERJEE PARK GRID	WMUKP104	11kv FDR SUBHASH NAGAR	TG-RJG029A-1	990	RESIDENTIAL		Functional	100%	1008	0.70	7.89	0.18	2.27%

33 kV MUKHERJEE PARK GRID	WMUKP104	11kV FDR SUBHASH NAGAR	TI-RJG018A-1	1500	RESIDENTIAL		Functional	100%	239	0.65			
33 kV MUKHERJEE PARK GRID	WMUKP104	11kV FDR SUBHASH NAGAR	TK-RJG028A-1	990	RESIDENTIAL		Functional	100%	394	0.63			
33 kV MUKHERJEE PARK GRID	WMUKP130	11kV FDR 6 BLK SUBASH NAGAR	TK-RJG017A-1	990	RESIDENTIAL		Functional	100%	826	0.61			
66 kV HARI NAGAR GRID	WHRGN128	11kV FDR SSTN NO-3 SUBASH NAGAR CHHATRIWALA	TG-RJG063A-1	990	RESIDENTIAL		Functional	100%	1193	0.58			
33 kV MUKHERJEE PARK GRID	WMUKP130	11kV FDR 6 BLK SUBASH NAGAR	TK-RJG014A-1	990	RESIDENTIAL		Functional	100%	1050	0.57			
66 kV HARI NAGAR GRID	WHRGN118	11kV FDR MIG RAJOURI GADAN	JK-HVD002A-1	990	RESIDENTIAL		Functional	100%	520	0.52			
33 kV MUKHERJEE PARK GRID	WMUKP130	11kV FDR 6 BLK SUBASH NAGAR	TK-RJG014A-2	630	RESIDENTIAL		Functional	100%	25	0.50			
66 kV HARI NAGAR GRID	WHRGN128	11kV FDR SSTN NO-3 SUBASH NAGAR CHHATRIWALA	TK-RJG012A-1	990	RESIDENTIAL		Functional	100%	142	0.48			
66 kV HARI NAGAR GRID	WHRGN118	11kV FDR MIG RAJOURI GADAN	TP-HVD001A-1	1250	RESIDENTIAL		Functional	100%	1321	0.43			
66 kV HARI NAGAR GRID	WHRGN118	11kV FDR MIG RAJOURI GADAN	JK-HVD003A-1	1150	RESIDENTIAL		Functional	100%	177	0.41			
33 kV MUKHERJEE PARK GRID	WMUKP130	11kV FDR 6 BLK SUBASH NAGAR	TK-RJG017A-2	990	RESIDENTIAL		Functional	100%	0	0.37			
33 kV MUKHERJEE PARK GRID	WMUKP104	11kV FDR SUBHASH NAGAR	TI-RJG018A-2	990	RESIDENTIAL		Functional	100%	104	0.36			
33 kV MUKHERJEE PARK GRID	WMUKP130	11kV FDR 6 BLK SUBASH NAGAR	610SBN-RJG015B-	990	RESIDENTIAL		Functional	100%	0	0.30			
66 kV HARI NAGAR GRID	WHRGN128	11kV FDR SSTN NO-3 SUBASH NAGAR CHHATRIWALA	TK-RJG012A-3	630	RESIDENTIAL		Functional	100%	0	0.30			
33 kV MUKHERJEE PARK GRID	WMUKP130	11kV FDR 6 BLK SUBASH NAGAR	610SBN-RJG014A-	630	RESIDENTIAL		Functional	100%	0	0.28			
66 kV HARI NAGAR GRID	WHRGN128	11kV FDR SSTN NO-3 SUBASH NAGAR CHHATRIWALA	TK-RJG012A-2	990	RESIDENTIAL		Functional	100%	677	0.24			
33 kV MUKHERJEE PARK GRID	WMUKP130	11kV FDR 6 BLK SUBASH NAGAR	610SBN-RJG015A-	990	RESIDENTIAL		Functional	100%	272	0.16			
66 kV HARI NAGAR GRID	WHRGN105	11kV FDR G-BLK HARI NAGAR	TG-JAB066A-2	1600	RESIDENTIAL	AMR	Functional	100%	736	1.06	11.37	0.15	1.30%
66 kV INST. AREA JKP (SAGARPUR) GRID	WSGRP121	11kV FDR B-2 BOOSTER PUMP B-2 JKP	TG-JAB067A-1	1000	RESIDENTIAL	AMR	Functional	100%	749	0.73			
33 kV D.C.JANAKPURI GRID	WJKPG106	11kV FDR BOOSTER PUMP JKP	TI-JAB055A-1	990	RESIDENTIAL	AMR	Functional	100%	225	0.71			
66 kV HARI NAGAR GRID	WHRGN105	11kV FDR G-BLK HARI NAGAR	TG-JAB063A-1	1600	RESIDENTIAL	AMR	Functional	100%	622	0.71			
66 kV INST. AREA JKP (SAGARPUR) GRID	WSGRP125	11kV FDR MUSICAL FOUNTAIN	TG-JAB061A-1	990	RESIDENTIAL	AMR	Functional	100%	499	0.68			
66 kV HARI NAGAR GRID	WHRGN105	11kV FDR G-BLK HARI NAGAR	TK-JAB057A-1	990	RESIDENTIAL	AMR	Functional	100%	1270	0.67			
33 kV D.C.JANAKPURI GRID	WJKPG106	11kV FDR BOOSTER PUMP JKP	TK-JAB065A-1	990	RESIDENTIAL	AMR	Functional	100%	407	0.67			
66 kV INST. AREA JKP (SAGARPUR) GRID	WSGRP125	11kV FDR MUSICAL FOUNTAIN	TG-JAB062A-1	990	RESIDENTIAL		Functional	100%	625	0.63			
33 kV MAYAPURI GRID	WMYPR115	11kV FDR SHIV NAGAR	TI-JAB060A-3	990	RESIDENTIAL		Functional	100%	647	0.56			
33 kV MAYAPURI GRID	WMYPR115	11kV FDR SHIV NAGAR	TI-JAB060A-2	630	RESIDENTIAL		Functional	100%	0	0.52			
33 kV D.C.JANAKPURI GRID	WJKPG106	11kV FDR BOOSTER PUMP JKP	TK-JAB043A-2	990	RESIDENTIAL	AMR	Functional	100%	253	0.52			
33 kV MAYAPURI GRID	WMYPR115	11kV FDR SHIV NAGAR	TI-JAB060A-1	990	RESIDENTIAL		Functional	100%	680	0.51			
66 kV INST. AREA JKP (SAGARPUR) GRID	WSGRP125	11kV FDR MUSICAL FOUNTAIN	TI-JAB054A-2	1000	RESIDENTIAL		Functional	100%	211	0.47			
66 kV INST. AREA JKP (SAGARPUR) GRID	WSGRP125	11kV FDR MUSICAL FOUNTAIN	TI-JAB054A-1	990	RESIDENTIAL	AMR	Functional	100%	339	0.44			
33 kV MAYAPURI GRID	WMYPR115	11kV FDR SHIV NAGAR	TG-JAB074A-1	990	RESIDENTIAL		Functional	100%	659	0.41			
33 kV D.C.JANAKPURI GRID	WJKPG106	11kV FDR BOOSTER PUMP JKP	TI-JAB055A-2	630	RESIDENTIAL	AMR	Functional	100%	243	0.38			
33 kV D.C.JANAKPURI GRID	WJKPG106	11kV FDR BOOSTER PUMP JKP	TK-JAB065A-2	990	RESIDENTIAL	AMR	Functional	100%	460	0.36			
66 kV INST. AREA JKP (SAGARPUR) GRID	WSGRP125	11kV FDR MUSICAL FOUNTAIN	TI-JAB054A-3	990	RESIDENTIAL		Functional	100%	102	0.32			
33 kV D.C.JANAKPURI GRID	WJKPG106	11kV FDR BOOSTER PUMP JKP	TK-JAB043A-1	630	RESIDENTIAL	AMR	Functional	100%	665	0.29			
66 kV HARI NAGAR GRID	WHRGN121	11kV FDR DELHI HAAT	2610B1J-JAB102A-	400	RESIDENTIAL	AMR	Functional	100%	245	0.26			
66 kV INST. AREA JKP (SAGARPUR) GRID	WSGRP121	11kV FDR B-2 BOOSTER PUMP B-2 JKP	2610B1J-JAB067A-	630	MIXED		Functional	100%	0	0.23			
66 kV HARI NAGAR GRID	WHRGN105	11kV FDR G-BLK HARI NAGAR	TP-JAB064A-1	400	RESIDENTIAL		Functional	100%	408	0.22			
66 kV HARI NAGAR GRID	WHRGN105	11kV FDR G-BLK HARI NAGAR	TG-JAB066A-1	400	RESIDENTIAL	AMR	Functional	100%	918	0.16			
33 kV MUKHERJEE PARK GRID	WMUKP131	11kV FDR FATEH NAGAR	TK-RJG025A-1	990	RESIDENTIAL		Functional	100%	680	1.43	3.77	0.20	5.11%
66 kV HARI NAGAR GRID	WHRGN110	11kV FDR AJANTA ID SSTN	TK-RJG027A-1	990	RESIDENTIAL		Functional	100%	525	0.64			
66 kV HARI NAGAR GRID	WHRGN110	11kV FDR AJANTA ID SSTN	TI-RJG026A-1	1000	RESIDENTIAL		Functional	100%	523	0.60			

33 kv MUKHERJEE PARK GRID	WMUKP109	11kv FDR AJANTA	TK-RJG022A-1	990	RESIDENTIAL		Functional	100%	473	0.51			
33 kv MUKHERJEE PARK GRID	WMUKP131	11kv FDR FATEH NAGAR	TP-RJG068A-1	990	RESIDENTIAL		Functional	100%	140	0.40			
33 kv MUKHERJEE PARK GRID	WMUKP109	11kv FDR AJANTA	TK-RJG075A-1	630	RESIDENTIAL		Functional	100%	77	0.39			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP118	11kv FDR D-1 SUB STN JKP	TG-JCD038A-1	990	INDUSTRIAL		Functional	100%	143	0.63	0.76	0.06	7.76%
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP118	11kv FDR D-1 SUB STN JKP	TG-JCD039A-1	630	INDUSTRIAL		Functional	100%	219	0.20			
33kv A-43 MAYAPURI GRID	WA43M141	11kv STR STATION TRANSFORMER NO-1	610MP1-WTC130A	400	RESIDENTIAL		Functional	100%	1	0.03	0.77	0.22	22.07%
33 kv MAYAPURI GRID	WMYPR122	11kv FDR D-1 JKP(CNG PUMP)	TI-JCD057A-2	630	RESIDENTIAL		Functional	100%	1	0.25			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP102	11kv FDR TIHAR JAIL NO-5	TI-JCD027A-1	400	RESIDENTIAL		Functional	100%	113	0.14			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP102	11kv FDR TIHAR JAIL NO-5	TI-JCD026A-1	400	COMMERCIAL		Functional	100%	366	0.12			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP102	11kv FDR TIHAR JAIL NO-5	TI-JCD026A-3	630	RESIDENTIAL		Functional	100%	0	0.10			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP101	11kv FDR COMMUNITY CENTER (PETROL PUMP)	2610C3J-JCD028B-1	990	RESIDENTIAL		Functional	100%	0	0.09			
33 kv MAYAPURI GRID	WMYPR112	11kv FDR TIHAR JAIL	TP-JCD074A-1	400	COMMERCIAL		Functional	100%	0	0.08			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP101	11kv FDR COMMUNITY CENTRE SSTN-1 (PETROL PUMP JKP)	2610C3J-JCD028A-1	630	RESIDENTIAL		Functional	100%	72	0.06			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP102	11kv FDR TIHAR JAIL NO-5	TI-JCD026A-2	630	RESIDENTIAL		Functional	100%	0	0.06			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP101	11kv FDR COMMUNITY CENTRE SSTN-1 (PETROL PUMP JKP)	2610C3J-JCD028A-1	990	RESIDENTIAL		Functional	100%	177	0.03			
33 kv MAYAPURI GRID	WMYPR112	11kv FDR TIHAR JAIL	TP-JCD066A-1	400	MIXED		Functional	100%	9	0.02			
66 kv I.O.C.BIJWASAN GRID	SBWSN104	11kv FDR BAMNAULI	620BTL-CWL533A	400	MIXED	AMR	Functional	100%	0	0.02	2.45	0.31	11.16%
66 kv G - 4 DWARKA GRID	WG4PN125	11kv FDR VILL.AMBERHAI	TG-CWL452A-1	630	RESIDENTIAL	AMR	Functional	100%	448	0.58			
66 kv G - 4 DWARKA GRID	WG4PN125	11kv FDR VILL.AMBERHAI	TG-CWL017A-2	630	RESIDENTIAL	AMR	Functional	100%	485	0.50			
66 kv G - 4 DWARKA GRID	WG4PN125	11kv FDR VILL.AMBERHAI	TG-CWL033A-1	630	RESIDENTIAL	AMR	Functional	100%	424	0.40			
66 kv G - 4 DWARKA GRID	WG4PN125	11kv FDR VILL.AMBERHAI	TG-CWL456A-1	630	RESIDENTIAL	AMR	Functional	100%	471	0.37			
66 kv G - 4 DWARKA GRID	WG4PN125	11kv FDR VILL.AMBERHAI	TG-CWL017A-1	400	RESIDENTIAL	AMR	Functional	100%	121	0.31			
66 kv G - 4 DWARKA GRID	WG4PN125	11kv FDR VILL.AMBERHAI	620BTL-CWL541A	630	MIXED		Functional	100%	182	0.25			
66 kv G - 4 DWARKA GRID	WG4PN125	11kv FDR VILL.AMBERHAI	TG-CWL388A-1	400	RESIDENTIAL	AMR	Functional	100%	196	0.24			
66 kv G - 4 DWARKA GRID	WG4PN125	11kv FDR VILL.AMBERHAI	620BTL-CWL538A	400	MIXED	AMR	Functional	100%	13	0.05			
66 kv G - 4 DWARKA GRID	WG4PN120	11kv FDR DHOOL SHIRAS	TP-CWL424A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.04			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	TP-NAJ248A-1	990	RESIDENTIAL	AMR	Functional	100%	355	0.42	2.02	0.18	8.08%
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	NF-HVD030A-1	1150	RESIDENTIAL		Functional	100%	726	0.35			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	NF-HVD023A-1	825	RESIDENTIAL		Functional	100%	428	0.30			
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	TP-NAJ250A-1	400	RESIDENTIAL	AMR	Functional	100%	251	0.29			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	TP-NAJ239A-1	400	RESIDENTIAL	AMR	Functional	100%	318	0.23			
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	620AJM-NAJ419A	630	MIXED		Functional	100%	0	0.19			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	TP-NAJ249A-1	400	RESIDENTIAL	AMR	Functional	100%	168	0.14			
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	TP-NAJ083A-1	400	RESIDENTIAL	AMR	Functional	100%	448	0.12			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	TG-NAJ047A-1	630	RESIDENTIAL	AMR	Functional	100%	39	0.06			
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	TP-NAJ146A-1	100	RESIDENTIAL		Functional	100%	6	0.03			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	TG-NAJ045A-1	630	RESIDENTIAL	AMR	Functional	100%	41	0.03			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	TG-NAJ046A-1	630	RESIDENTIAL	AMR	Functional	100%	45	0.02			
66 kv TIKRI KALAN GRID	WMUND116	11kv FDR DJB UGR DICHAN NO-1	620AJM-NAJ413A	100	MIXED		Functional	100%	0	0.01			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD123	11kv FDR ARJUN PARK	TP-NAJ012A-1	630	RESIDENTIAL	AMR	Functional	100%	933	0.70	4.63	0.41	8.16%
220kv NAJAFGARH GRID	TDNG107	11kv FDR RAMA PARK	NF-HVD092A-1	1775	RESIDENTIAL		Functional	100%	1436	0.58			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD123	11kv FDR ARJUN PARK	TP-NAJ010A-1	630	RESIDENTIAL	AMR	Functional	100%	619	0.57			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD123	11kv FDR ARJUN PARK	NF-HVD034A-1	1225	RESIDENTIAL		Functional	100%	1169	0.53			

66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD123	11kV FDR ARJUN PARK	TP-NAJ230A-1	630	RESIDENTIAL	AMR	Functional	100%	624	0.49			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD123	11kV FDR ARJUN PARK	TP-NAJ233A-1	630	RESIDENTIAL	AMR	Functional	100%	668	0.38			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD123	11kV FDR ARJUN PARK	620DLG-NAJ233A-	630	MIXED		Functional	100%	0	0.38			
220kV NAJAFGARH GRID	TDNG107	11kV FDR RAMA PARK	NF-HVD091A-1	800	RESIDENTIAL		Functional	100%	515	0.37			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD123	11kV FDR ARJUN PARK	TG-NAJ362A-1	630	RESIDENTIAL		Functional	100%	281	0.21			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD123	11kV FDR ARJUN PARK	TG-NAJ092A-1	630	RESIDENTIAL	AMR	Functional	100%	116	0.18			
220kV NAJAFGARH GRID	TDNG107	11kV FDR RAMA PARK	TG-NAJ077A-1	990	RESIDENTIAL	AMR	Functional	100%	1673	0.16			
220kV NAJAFGARH GRID	TDNG110	11kV FDR KAKROLA FEEDER	TP-NAJ269A-1	400	RESIDENTIAL	AMR	Functional	100%	153	0.13			
220kV NAJAFGARH GRID	TDNG107	11kV FDR RAMA PARK	620DLG-NAJ392A-	400	COMMERCIAL	AMR	Functional	100%	46	0.09			
220kV NAJAFGARH GRID	TDNG107	11kV FDR RAMA PARK	TP-NAJ247A-1	250	RESIDENTIAL	AMR	Functional	100%	58	0.07			
220kV NAJAFGARH GRID	TDNG107	11kV FDR RAMA PARK	620DLG-NAJ077A-	990	MIXED		Functional	100%	0	0.07			
220kV NAJAFGARH GRID	TDNG107	11kV FDR RAMA PARK	TP-NAJ089A-1	400	RESIDENTIAL	AMR	Functional	100%	169	0.07			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD123	11kV FDR ARJUN PARK	TP-NAJ211A-1	100	RESIDENTIAL	AMR	Functional	100%	73	0.05			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD123	11kV FDR ARJUN PARK	TP-NAJ098A-1	100	RESIDENTIAL		Functional	100%	19	0.00			
220kV NAJAFGARH GRID	TDNG107	11kV FDR RAMA PARK	TP-NAJ023A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kV FDR KANGAN HERI	TP-CWL021A-1	630	RESIDENTIAL		Functional	100%	688	0.40	0.56	0.22	28.43%
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kV FDR KANGAN HERI	TG-CWL408A-1	400	RESIDENTIAL		Functional	100%	183	0.38			
66 kV G - 4 DWARKA GRID	WG4PN120	11kV FDR DHOOL SHIRAS	TP-CWL047A-1	630	RESIDENTIAL	AMR	Functional	100%	359	0.55	3.41	0.28	7.56%
66 kV G - 4 DWARKA GRID	WG4PN120	11kV FDR DHOOL SHIRAS	TG-CWL427A-1	630	RESIDENTIAL		Functional	100%	173	0.51			
66 kV G - 4 DWARKA GRID	WG4PN120	11kV FDR DHOOL SHIRAS	TG-CWL014A-1	630	RESIDENTIAL	AMR	Functional	100%	568	0.46			
66 kV G - 4 DWARKA GRID	WG4PN120	11kV FDR DHOOL SHIRAS	620BTL-CWL045A-	630	COMMERCIAL	AMR	Functional	100%	315	0.40			
66 kV G - 4 DWARKA GRID	WG4PN120	11kV FDR DHOOL SHIRAS	620BTL-CWL218A-	630	COMMERCIAL	AMR	Functional	100%	0	0.33			
66 kV G - 4 DWARKA GRID	WG4PN120	11kV FDR DHOOL SHIRAS	620BTL-CWL218A-	400	RESIDENTIAL	AMR	Functional	100%	113	0.32			
66 kV G - 4 DWARKA GRID	WG4PN120	11kV FDR DHOOL SHIRAS	TP-CWL293A-1	400	RESIDENTIAL	AMR	Functional	100%	1527	0.26			
66 kV G - 4 DWARKA GRID	WG4PN120	11kV FDR DHOOL SHIRAS	620BTL-CWL293A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.23			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL120A-1	400	RESIDENTIAL	AMR	Functional	100%	128	0.15			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL214A-1	250	RESIDENTIAL	AMR	Functional	100%	133	0.12			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL119A-1	400	RESIDENTIAL	AMR	Functional	100%	18	0.10			
66 kV G - 4 DWARKA GRID	WG4PN120	11kV FDR DHOOL SHIRAS	620BTL-CWL531A-	630	RESIDENTIAL	AMR	Functional	100%	17	0.08			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL121A-1	100	RESIDENTIAL	AMR	Functional	100%	40	0.05			
66 kV G - 4 DWARKA GRID	WG4PN120	11kV FDR DHOOL SHIRAS	TP-CWL118A-1	400	RESIDENTIAL	AMR	Functional	100%	38	0.03			
66 kV I.O.C.BIJWASAN GRID	SBWSN111	11kV FDR B.S.F CHAWLA CAMP	TG-CWL085A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.03			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	620BTL-CWL517A-	100	RESIDENTIAL	AMR	Functional	100%	20	0.03			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL123A-1	100	RESIDENTIAL	AMR	Functional	100%	24	0.02			
66 kV G - 4 DWARKA GRID	WG4PN120	11kV FDR DHOOL SHIRAS	TP-CWL140A-1	400	RESIDENTIAL	AMR	Functional	100%	11	0.02			
66 kV I.O.C.BIJWASAN GRID	SBWSN101	11kV FDR BHARTHAL	TG-CWL012A-1	990	RESIDENTIAL	AMR	Functional	100%	567	0.49	3.32	1.11	25.07%
66 kV I.O.C.BIJWASAN GRID	SBWSN101	11kV FDR BHARTHAL	TG-CWL442A-1	630	RESIDENTIAL	AMR	Functional	100%	712	0.47			
66 kV I.O.C.BIJWASAN GRID	SBWSN101	11kV FDR BHARTHAL	TP-CWL236A-1	630	RESIDENTIAL	AMR	Functional	100%	187	0.45			
66 kV I.O.C.BIJWASAN GRID	SBWSN101	11kV FDR BHARTHAL	TG-CWL484A-1	630	RESIDENTIAL	AMR	Functional	100%	267	0.40			

66 kV I.O.C.BIJWASAN GRID	SBWSN101	11kV FDR BHARTHAL	620BTL-CWL133A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.38			
66 kV I.O.C.BIJWASAN GRID	SBWSN101	11kV FDR BHARTHAL	TP-CWL044A-1	400	RESIDENTIAL	AMR	Functional	100%	445	0.35			
66 kV I.O.C.BIJWASAN GRID	SBWSN101	11kV FDR BHARTHAL	620BTL-CWL133A-	400	RESIDENTIAL	AMR	Functional	100%	323	0.31			
66 kV I.O.C.BIJWASAN GRID	SBWSN101	11kV FDR BHARTHAL	TP-CWL031A-1	630	RESIDENTIAL	AMR	Functional	100%	367	0.27			
66 kV I.O.C.BIJWASAN GRID	SBWSN101	11kV FDR BHARTHAL	620BTL-CWL536A-	400	MIXED	AMR	Functional	100%	57	0.26			
66 kV I.O.C.BIJWASAN GRID	SBWSN101	11kV FDR BHARTHAL	TG-CWL012B-1	990	RESIDENTIAL	AMR	Functional	100%	0	0.24			
66 kV I.O.C.BIJWASAN GRID	SBWSN101	11kV FDR BHARTHAL	620BTL-CWL547A-	630	MIXED		Functional	100%	139	0.23			
66 kV I.O.C.BIJWASAN GRID	SBWSN101	11kV FDR BHARTHAL	TG-CWL130A-1	400	RESIDENTIAL	AMR	Functional	100%	287	0.15			
66 kV I.O.C.BIJWASAN GRID	SBWSN101	11kV FDR BHARTHAL	620BTL-CWL546A-	630	MIXED		Functional	100%	57	0.11			
66 kV G - 6 P.P.K GRID	WG6PN125	11kV FDR 810 DDA. FLATS SEC-26(DWK)	TP-CWL350A-2	630	RESIDENTIAL	AMR	Functional	100%	119	0.08			
66 kV G - 6 P.P.K GRID	WG6PN125	11kV FDR 810 DDA. FLATS SEC-26(DWK)	TG-CWL351A-2	630	RESIDENTIAL	AMR	Functional	100%	137	0.07			
66 kV G - 6 P.P.K GRID	WG6PN125	11kV FDR 810 DDA. FLATS SEC-26(DWK)	TG-CWL350A-1	630	RESIDENTIAL	AMR	Functional	100%	169	0.05			
66 kV G - 6 P.P.K GRID	WG6PN125	11kV FDR 810 DDA. FLATS SEC-26(DWK)	TG-CWL351A-1	630	RESIDENTIAL	AMR	Functional	100%	158	0.05			
66 kV I.O.C.BIJWASAN GRID	SBWSN101	11kV FDR BHARTHAL	TP-CWL474A-1	400	MIXED	AMR	Functional	100%	1	0.05			
66 kV G - 6 P.P.K GRID	WG6PN128	11kV FDR POCHAN PUR	620BTL-CWL545A-	400	MIXED		Functional	100%	20	0.05			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL201A-1	400	RESIDENTIAL	AMR	Functional	100%	334	0.38	1.53	0.05	2.91%
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL464A-1	400	RESIDENTIAL	AMR	Functional	100%	298	0.29			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL206A-1	400	RESIDENTIAL	AMR	Functional	100%	336	0.24			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TG-CWL137A-1	400	RESIDENTIAL	AMR	Functional	100%	158	0.24			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL206A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.13			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	620BTL-CWL516A-	630	RESIDENTIAL	AMR	Functional	100%	80	0.13			
66 kV I.O.C.BIJWASAN GRID	SBWSN111	11kV FDR B.S.F CHAWLA CAMP	TP-CWL175A-1	100	RESIDENTIAL	AMR	Functional	100%	34	0.07			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL136A-1	100	RESIDENTIAL	AMR	Functional	100%	28	0.07			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL343A-1	100	RESIDENTIAL		Functional	100%	4	0.02			
66 kV G - 4 DWARKA GRID	WG4PN121	11kV FDR CHHAWLA	TG-CWL009A-1	990	RESIDENTIAL	AMR	Functional	100%	805	0.76	3.56	2.26	38.84%
66 kV I.O.C.BIJWASAN GRID	SBWSN111	11kV FDR B.S.F CHAWLA CAMP	TG-CWL008A-1	990	RESIDENTIAL	AMR	Functional	100%	686	0.71			
66 kV G - 4 DWARKA GRID	WG4PN121	11kV FDR CHHAWLA	TP-CWL007A-1	630	RESIDENTIAL	AMR	Functional	100%	641	0.63			
66 kV I.O.C.BIJWASAN GRID	SBWSN111	11kV FDR B.S.F CHAWLA CAMP	620CWL-CWL243A	990	RESIDENTIAL	AMR	Functional	100%	0	0.63			
66 kV G - 4 DWARKA GRID	WG4PN121	11kV FDR CHHAWLA	TP-CWL139A-1	630	RESIDENTIAL	AMR	Functional	100%	193	0.59			
66 kV I.O.C.BIJWASAN GRID	SBWSN111	11kV FDR B.S.F CHAWLA CAMP	TG-CWL243A-1	630	RESIDENTIAL	AMR	Functional	100%	544	0.58			
66 kV I.O.C.BIJWASAN GRID	SBWSN111	11kV FDR B.S.F CHAWLA CAMP	TP-CWL414A-1	990	RESIDENTIAL	AMR	Functional	100%	406	0.57			
66 kV I.O.C.BIJWASAN GRID	SBWSN111	11kV FDR B.S.F CHAWLA CAMP	TG-CWL010A-1	630	RESIDENTIAL	AMR	Functional	100%	697	0.52			
66 kV I.O.C.BIJWASAN GRID	SBWSN111	11kV FDR B.S.F CHAWLA CAMP	620CWL-CWL008A	990	MIXED	AMR	Functional	100%	0	0.26			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL154A-1	100	RESIDENTIAL	AMR	Functional	100%	8	0.10			
66 kV G - 4 DWARKA GRID	WG4PN121	11kV FDR CHHAWLA	TP-CWL283A-1	400	RESIDENTIAL	AMR	Functional	100%	114	0.07			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kV FDR KANGAN HERI	TP-CWL149A-1	100	RESIDENTIAL	AMR	Functional	100%	63	0.06			

66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kv FDR KANGAN HERI	TP-CWL495A-1	400	RESIDENTIAL	AMR	Functional	100%	101	0.05			
66 KV G - 4 DWARKA GRID	WG4PN121	11kv FDR CHHAWLA	TP-CWL146A-1	100	RESIDENTIAL	AMR	Functional	100%	10	0.05			
66 KV I.O.C.BIJWASAN GRID	SBWSN104	11kv FDR BAMNAULI	TP-CWL143A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.05			
66 KV G - 4 DWARKA GRID	WG4PN128	11kv FDR QUTUB VIHAR PH-2	TP-CWL182A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.04			
66 KV G - 4 DWARKA GRID	WG4PN121	11kv FDR CHHAWLA	TP-CWL507A-1	100	MIXED	AMR	Functional	100%	4	0.03			
66 KV I.O.C.BIJWASAN GRID	SBWSN111	11kv FDR B.S.F CHAWLA CAMP	TP-CWL150A-1	100	RESIDENTIAL	AMR	Functional	100%	79	0.03			
66 KV G - 4 DWARKA GRID	WG4PN121	11kv FDR CHHAWLA	TP-CWL151A-1	100	RESIDENTIAL	AMR	Functional	100%	32	0.02			
66 KV G - 4 DWARKA GRID	WG4PN121	11kv FDR CHHAWLA	TP-CWL148A-1	100	RESIDENTIAL		Functional	100%	17	0.02			
66 KV I.O.C.BIJWASAN GRID	SBWSN104	11kv FDR BAMNAULI	TP-CWL001A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 KV G - 4 DWARKA GRID	WG4PN128	11kv FDR QUTUB VIHAR PH-2	TP-CWL141A-1	100	RESIDENTIAL	AMR	Functional	100%	6	0.01			
66 KV G - 4 DWARKA GRID	WG4PN101	11kv FDR GOYALA DAIRY	TG-CWL134A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 KV G - 4 DWARKA GRID	WG4PN121	11kv FDR CHHAWLA	TP-CWL486A-1	250	RESIDENTIAL	AMR	Functional	100%	93	0.01			
66 KV G - 4 DWARKA GRID	WG4PN121	11kv FDR CHHAWLA	TP-CWL285A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.00			
66 KV JAFFARPUR GRID	WZAFF110	11kv FDR DAULAT PUR	TP-CWL027A-1	630	RESIDENTIAL	AMR	Functional	100%	411	0.32	0.73	0.36	33.25%
66 KV JAFFARPUR GRID	WZAFF110	11kv FDR DAULAT PUR	TP-CWL028A-1	400	RESIDENTIAL	AMR	Functional	100%	250	0.24			
66 KV JAFFARPUR GRID	WZAFF110	11kv FDR DAULAT PUR	TP-NAJ364A-1	400	RESIDENTIAL	AMR	Functional	100%	143	0.24			
66 KV JAFFARPUR GRID	WZAFF110	11kv FDR DAULAT PUR	TP-CWL029A-1	400	RESIDENTIAL	AMR	Functional	100%	169	0.22			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL051A-1	100	RESIDENTIAL	AMR	Functional	100%	13	0.02			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL049A-1	100	RESIDENTIAL	AMR	Functional	100%	17	0.02			
66 KV JAFFARPUR GRID	WZAFF110	11kv FDR DAULAT PUR	TP-CWL078A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.01			
66 KV JAFFARPUR GRID	WZAFF110	11kv FDR DAULAT PUR	TP-CWL048A-1	100	RESIDENTIAL	AMR	Functional	100%	18	0.01			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	620DLP-NAJ407A-	100	INDUSTRIAL	AMR	Functional	100%	1	0.01			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	620DLP-NAJ403A-	100	RESIDENTIAL	AMR	Functional	100%	5	0.01			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL052A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.01			
66 KV JAFFARPUR GRID	WZAFF110	11kv FDR DAULAT PUR	TP-CWL063A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.00			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD129	11kv FDR G-BLOCK SHYAM VIHAR	NF-HVD009A-1	2500	RESIDENTIAL		Functional	100%	1189	0.92	3.13	0.17	5.15%
66 KV G - 4 DWARKA GRID	WG4PN129	11kv FDR SHYAM VIHAR PH-2	NF-HVD075A-1	2400	RESIDENTIAL		Functional	100%	1009	0.64			
220KV NAJAFGARH GRID	TDNG104	11kv FDR DEENPUR	TG-CWL003A-1	630	RESIDENTIAL	AMR	Functional	100%	564	0.47			
66/11 KV GRID SUBSTATION AT GOYLA KHURD	WGOYL008	11kv FDR SHYAM ENCLAVE	NF-HVD065A-1	1100	RESIDENTIAL		Functional	100%	536	0.40			
66/11 KV GRID SUBSTATION AT GOYLA KHURD	WGOYL008	11kv FDR SHYAM ENCLAVE	TG-CWL004A-1	630	RESIDENTIAL	AMR	Functional	100%	520	0.35			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD129	11kv FDR G-BLOCK SHYAM VIHAR	TP-CWL241A-1	400	RESIDENTIAL	AMR	Functional	100%	109	0.23			
66/11 KV GRID SUBSTATION AT GOYLA KHURD	WGOYL008	11kv FDR SHYAM ENCLAVE	TP-CWL301A-1	400	RESIDENTIAL	AMR	Functional	100%	167	0.17			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD129	11kv FDR G-BLOCK SHYAM VIHAR	TP-CWL207A-1	400	RESIDENTIAL	AMR	Functional	100%	121	0.12			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD129	11kv FDR G-BLOCK SHYAM VIHAR	TP-CWL113A-1	100	RESIDENTIAL		Functional	100%	7	0.01			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD102	11kv FDR ROSHAN PURA	NF-HVD011A-1	1750	RESIDENTIAL		Functional	100%	807	0.93	8.12	0.49	5.73%
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD107	11kv FDR PRASHANT SS-BD CWL	TI-NAJ056A-1	990	RESIDENTIAL	AMR	Functional	100%	1801	0.73			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD107	11kv FDR PRASHANT SS-BD CWL	TG-NAJ058A-1	990	RESIDENTIAL	AMR	Functional	100%	1045	0.70			
220KV NAJAFGARH GRID	TDNG105	11kv FDR DTL COLONY	TP-NAJ059A-1	630	RESIDENTIAL	AMR	Functional	100%	456	0.68			
220KV NAJAFGARH GRID	TDNG105	11kv FDR DTL COLONY	TG-NAJ017A-1	990	RESIDENTIAL	AMR	Functional	100%	323	0.66			
220KV PAPPAN KALAN 2 GRID	WPKL2105	11kv FDR DMRC STAFF QUARTERS	NF-HVD059A-1	1750	RESIDENTIAL		Functional	100%	1012	0.61			

66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD102	11kv FDR ROSHAN PURA	NF-HVD010A-1	1575	RESIDENTIAL		Functional	100%	1121	0.57			
220kv NAJAFGARH GRID	TDNG105	11kv FDR DTL COLONY	NF-HVD081A-2	1200	RESIDENTIAL		Functional	100%	667	0.55			
220kv NAJAFGARH GRID	TDNG105	11kv FDR DTL COLONY	TG-NAJ057A-1	630	RESIDENTIAL	AMR	Functional	100%	393	0.54			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD107	11kv FDR PRASHANT SS-BD CWL	TG-NAJ268A-1	630	RESIDENTIAL	AMR	Functional	100%	415	0.44			
220kv PAPPAN KALAN 2 GRID	WPKL2105	11kv FDR DMRC STAFF QUARTERS	NF-HVD015A-1	775	RESIDENTIAL		Functional	100%	381	0.36			
220kv NAJAFGARH GRID	TDNG105	11kv FDR DTL COLONY	TG-NAJ057A-2	990	RESIDENTIAL	AMR	Functional	100%	670	0.34			
220kv NAJAFGARH GRID	TDNG105	11kv FDR DTL COLONY	TP-NAJ236A-1	400	RESIDENTIAL	AMR	Functional	100%	600	0.33			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD102	11kv FDR ROSHAN PURA	TG-CWL372A-1	400	RESIDENTIAL		Functional	100%	249	0.27			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD107	11kv FDR PRASHANT SS-BD CWL	TI-NAJ056A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.27			
220kv PAPPAN KALAN 2 GRID	WPKL2112	11kv FDR 5-MGD PUMPING SS NO-2	TP-NAJ193A-1	400	RESIDENTIAL	AMR	Functional	100%	279	0.25			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD107	11kv FDR PRASHANT SS-BD CWL	TP-NAJ197A-1	400	RESIDENTIAL	AMR	Functional	100%	353	0.20			
220kv NAJAFGARH GRID	TDNG105	11kv FDR DTL COLONY	TP-NAJ073A-1	400	RESIDENTIAL		Functional	100%	201	0.14			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD118	11kv FDR DJB-1	TP-NAJ152A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.03			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kv FDR KANGAN HERI	TP-NAJ270A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.02			
220kv PAPPAN KALAN 2 GRID	WPKL2112	11kv FDR 5-MGD PUMPING SS NO-2	TP-CWL460A-1	100	COMMERCIAL	AMR	Functional	100%	4	0.01			
220kv PAPPAN KALAN 2 GRID	WPKL2112	11kv FDR 5-MGD PUMPING SS NO-2	620SYV-NAJ193A-	630	MIXED		Functional	100%	0	0.00			
66 kv G - 4 DWARKA GRID	WG4PN120	11kv FDR DHOOL SHIRAS	TG-CWL015A-1	630	RESIDENTIAL	AMR	Functional	100%	239	0.46	1.26	0.62	33.06%
66 kv G - 4 DWARKA GRID	WG4PN120	11kv FDR DHOOL SHIRAS	620BTL-CWL534A-	630	MIXED	AMR	Functional	100%	23	0.38			
66 kv G - 4 DWARKA GRID	WG4PN120	11kv FDR DHOOL SHIRAS	TP-CWL475A-1	400	RESIDENTIAL		Functional	100%	144	0.24			
66 kv G - 4 DWARKA GRID	WG4PN120	11kv FDR DHOOL SHIRAS	TP-CWL446A-1	400	RESIDENTIAL	AMR	Functional	100%	187	0.22			
66 kv G - 4 DWARKA GRID	WG4PN120	11kv FDR DHOOL SHIRAS	TG-CWL019A-1	630	RESIDENTIAL	AMR	Functional	100%	634	0.19			
66 kv G - 4 DWARKA GRID	WG4PN120	11kv FDR DHOOL SHIRAS	TP-CWL312A-1	400	RESIDENTIAL	AMR	Functional	100%	134	0.19			
66 kv G - 4 DWARKA GRID	WG4PN120	11kv FDR DHOOL SHIRAS	TP-CWL447A-1	400	RESIDENTIAL	AMR	Functional	100%	160	0.18			
66 kv G - 4 DWARKA GRID	WG4PN120	11kv FDR DHOOL SHIRAS	TP-CWL083A-1	100	RESIDENTIAL	AMR	Functional	100%	10	0.02			
66 kv G - 4 DWARKA GRID	WG4PN120	11kv FDR DHOOL SHIRAS	TP-CWL443A-1	250	RESIDENTIAL		Functional	100%	1	0.00			
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	TG-NAJ026A-1	990	RESIDENTIAL	AMR	Functional	100%	254	0.91	1.51	4.35	74.27%
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	TG-NAJ027A-1	990	RESIDENTIAL	AMR	Functional	100%	377	0.74			
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	TG-NAJ028A-1	990	RESIDENTIAL	AMR	Functional	100%	232	0.63			
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	TP-NAJ288A-1	630	RESIDENTIAL	AMR	Functional	100%	242	0.60			
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	620AJM-NAJ323A-	630	RESIDENTIAL	AMR	Functional	100%	222	0.58			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	TG-NAJ222A-1	990	RESIDENTIAL	AMR	Functional	100%	168	0.55			
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	620AJM-NAJ400A-	630	RESIDENTIAL	AMR	Functional	100%	271	0.43			
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	620AJM-NAJ138A-	630	RESIDENTIAL	AMR	Functional	100%	333	0.42			
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	TP-NAJ194A-1	400	RESIDENTIAL		Functional	100%	129	0.32			
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	620AJM-NAJ400A-	630	COMMERCIAL	AMR	Functional	100%	312	0.22			
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	TP-NAJ110A-1	400	RESIDENTIAL		Functional	100%	26	0.09			
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	TP-NAJ116A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.07			
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	TP-NAJ099A-1	100	RESIDENTIAL	AMR	Functional	100%	9	0.04			
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	TP-NAJ142A-1	100	RESIDENTIAL		Functional	100%	9	0.03			
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	TP-NAJ107A-1	100	RESIDENTIAL	AMR	Functional	100%	6	0.03			
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	TP-NAJ108A-1	100	RESIDENTIAL	AMR	Functional	100%	27	0.02			
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	TP-NAJ145A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.02			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	TP-NAJ113A-1	100	RESIDENTIAL	AMR	Functional	100%	14	0.02			
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	TP-NAJ260A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.02			
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	TP-NAJ123A-1	100	RESIDENTIAL	AMR	Functional	100%	27	0.02			
220kv NAJAFGARH GRID	TDNG102	11kv FDR DICHOAN	TP-NAJ106A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.02			

66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TP-NAJ141A-1	100	RESIDENTIAL	AMR	Functional	100%	10	0.01			
220kV NAJAFGARH GRID	TDNG102	11kV FDR DICHUAN	TP-NAJ122A-1	100	RESIDENTIAL	AMR	Functional	100%	15	0.01			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TP-NAJ115A-1	100	RESIDENTIAL	AMR	Functional	100%	21	0.01			
220kV NAJAFGARH GRID	TDNG102	11kV FDR DICHUAN	TP-NAJ126A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.01			
220kV NAJAFGARH GRID	TDNG111	11kV FDR ANAJ MANDI	TP-NAJ143A-1	100	RESIDENTIAL	AMR	Functional	100%	10	0.01			
220kV NAJAFGARH GRID	TDNG102	11kV FDR DICHUAN	TP-NAJ124A-1	100	RESIDENTIAL	AMR	Functional	100%	12	0.01			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TP-NAJ155A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.01			
220kV NAJAFGARH GRID	TDNG111	11kV FDR ANAJ MANDI	TP-NAJ154A-1	100	RESIDENTIAL		Functional	100%	3	0.00			
220kV NAJAFGARH GRID	TDNG104	11kV FDR DEENPUR	NF-HVD013A-1	1250	RESIDENTIAL		Functional	100%	1045	0.70	2.51	0.25	9.03%
220kV NAJAFGARH GRID	TDNG104	11kV FDR DEENPUR	NF-HVD014A-1	2475	RESIDENTIAL		Functional	100%	1068	0.37			
220kV NAJAFGARH GRID	TDNG104	11kV FDR DEENPUR	NF-HVD033A-1	750	RESIDENTIAL		Functional	100%	504	0.37			
220kV NAJAFGARH GRID	TDNG104	11kV FDR DEENPUR	TP-CWL002A-1	400	RESIDENTIAL	AMR	Functional	100%	190	0.29			
220kV NAJAFGARH GRID	TDNG104	11kV FDR DEENPUR	620JTM-NAJ410A-	630	RESIDENTIAL	AMR	Functional	100%	153	0.23			
220kV NAJAFGARH GRID	TDNG104	11kV FDR DEENPUR	NF-HVD062A-1	650	RESIDENTIAL		Functional	100%	200	0.22			
220kV NAJAFGARH GRID	TDNG104	11kV FDR DEENPUR	NF-HVD061A-1	525	RESIDENTIAL		Functional	100%	186	0.18			
220kV NAJAFGARH GRID	TDNG104	11kV FDR DEENPUR	TP-CWL313A-1	400	RESIDENTIAL	AMR	Functional	100%	177	0.14			
220kV NAJAFGARH GRID	TDNG104	11kV FDR DEENPUR	620JTM-NAJ398A-	630	RESIDENTIAL	AMR	Functional	100%	116	0.13			
220kV NAJAFGARH GRID	TDNG104	11kV FDR DEENPUR	NF-HVD094A-1	275	RESIDENTIAL		Functional	100%	145	0.10			
220kV NAJAFGARH GRID	TDNG104	11kV FDR DEENPUR	620JTM-HVD097A-	1125	RESIDENTIAL		Functional	100%	212	0.04			
220kV NAJAFGARH GRID	TDNG105	11kV FDR DTL COLONY	TG-NAJ279A-1	990	RESIDENTIAL	AMR	Functional	100%	490	0.84	2.80	0.26	8.59%
220kV NAJAFGARH GRID	TDNG105	11kV FDR DTL COLONY	NF-HVD036A-1	1500	RESIDENTIAL		Functional	100%	1997	0.80			
220kV NAJAFGARH GRID	TDNG105	11kV FDR DTL COLONY	NF-HVD036A-2	500	RESIDENTIAL		Functional	100%	0	0.48			
220kV NAJAFGARH GRID	TDNG105	11kV FDR DTL COLONY	TG-NAJ018A-1	400	RESIDENTIAL		Functional	100%	294	0.34			
220kV NAJAFGARH GRID	TDNG105	11kV FDR DTL COLONY	TG-NAJ014A-1	400	RESIDENTIAL	AMR	Functional	100%	482	0.27			
220kV NAJAFGARH GRID	TDNG105	11kV FDR DTL COLONY	TG-NAJ374A-1	400	RESIDENTIAL	AMR	Functional	100%	151	0.19			
220kV NAJAFGARH GRID	TDNG102	11kV FDR DICHUAN	TG-NAJ373A-1	400	RESIDENTIAL	AMR	Functional	100%	123	0.11			
220kV NAJAFGARH GRID	TDNG105	11kV FDR DTL COLONY	TG-NAJ016A-1	400	RESIDENTIAL	AMR	Functional	100%	26	0.04			
66 kV G - 4 DWARKA GRID	WG4PN101	11kV FDR GOYALA DAIRY	TP-CWL036A-1	630	RESIDENTIAL	AMR	Functional	100%	1248	0.49	2.33	0.10	3.94%
66 kV G - 4 DWARKA GRID	WG4PN105	11kV FDR HANUMAN CHOWK	NF-HVD020A-1	1050	RESIDENTIAL		Functional	100%	334	0.46			
66 kV G - 4 DWARKA GRID	WG4PN101	11kV FDR GOYALA DAIRY	NF-HVD021A-1	1050	RESIDENTIAL		Functional	100%	0	0.44			
66 kV G - 4 DWARKA GRID	WG4PN101	11kV FDR GOYALA DAIRY	TP-CWL204A-1	400	RESIDENTIAL	AMR	Functional	100%	369	0.30			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD108	11kV FDR GOYALA SCHOOL BD CWL	TG-CWL468A-2	630	RESIDENTIAL	AMR	Functional	100%	181	0.27			
66 kV G - 4 DWARKA GRID	WG4PN101	11kV FDR GOYALA DAIRY	TG-CWL254A-1	400	RESIDENTIAL	AMR	Functional	100%	200	0.19			
66 kV G - 4 DWARKA GRID	WG4PN105	11kV FDR HANUMAN CHOWK	TP-CWL235A-1	400	RESIDENTIAL	AMR	Functional	100%	274	0.15			
66 kV G - 4 DWARKA GRID	WG4PN101	11kV FDR GOYALA DAIRY	TP-CWL084A-1	400	RESIDENTIAL	AMR	Functional	100%	48	0.09			
66 kV G - 4 DWARKA GRID	WG4PN101	11kV FDR GOYALA DAIRY	TG-CWL087A-1	100	RESIDENTIAL		Functional	100%	18	0.04			
66 kV G - 4 DWARKA GRID	WG4PN105	11kV FDR HANUMAN CHOWK	TP-CWL253A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.01			
66 kV G - 4 DWARKA GRID	WG4PN101	11kV FDR GOYALA DAIRY	620CWL-HVD083A-	625	MIXED		Functional	100%	0	0.00			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TG-NAJ030A-1	990	RESIDENTIAL	AMR	Functional	100%	430	1.07	1.00	3.72	78.74%
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TG-NAJ305A-1	990	RESIDENTIAL	AMR	Functional	100%	171	0.96			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	620AJM-NAJ388A-	630	RESIDENTIAL	AMR	Functional	100%	291	0.71			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TG-NAJ029A-1	990	RESIDENTIAL	AMR	Functional	100%	501	0.52			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	620AJM-NAJ415A-	990	MIXED	AMR	Functional	100%	0	0.44			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TI-NAJ031A-1	990	RESIDENTIAL	AMR	Functional	100%	328	0.40			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	620AJM-NAJ401A-	630	COMMERCIAL	AMR	Functional	100%	357	0.35			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TP-NAJ135A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.05			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TP-NAJ128A-1	100	RESIDENTIAL		Functional	100%	8	0.04			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TP-NAJ133A-2	100	RESIDENTIAL	AMR	Functional	100%	13	0.04			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TP-NAJ131A-1	100	RESIDENTIAL	AMR	Functional	100%	12	0.03			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TP-NAJ132A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.03			

66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TP-NAJ134A-1	100	RESIDENTIAL	AMR	Functional	100%	51	0.02			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TP-NAJ133A-1	100	RESIDENTIAL		Functional	100%	0	0.02			
66 kV TIKRI KALAN GRID	WMUND605	11kV FDR JHARODA	620AJM-NAJ120A	100	COMMERCIAL	AMR	Functional	100%	1	0.01			
66 kV TIKRI KALAN GRID	WMUND605	11kV FDR JHARODA	620AJM-NAJ390A	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TP-NAJ136A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.01			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TP-NAJ129A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.01			
66 kV TIKRI KALAN GRID	WMUND605	11kV FDR JHARODA	TP-NAJ137A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.00			
66/11kV MITRAON GRID	WMITR108	11kV FDR BABA HARIDAS	TP-NAJ130A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.00			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kV FDR JHATIKARA MORE	TG-CWL011A-1	630	RESIDENTIAL	AMR	Functional	100%	508	0.40	0.52	0.36	40.78%
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kV FDR JHATIKARA MORE	TP-CWL060A-1	400	RESIDENTIAL	AMR	Functional	100%	176	0.24			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kV FDR JHATIKARA MORE	TG-NAJ330A-1	630	RESIDENTIAL	AMR	Functional	100%	81	0.22			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kV FDR JHATIKARA MORE	TP-NAJ340A-1	100	RESIDENTIAL		Functional	100%	12	0.02			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kV FDR JHATIKARA MORE	TP-CWL061A-1	100	RESIDENTIAL		Functional	100%	26	0.01			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kV FDR JHATIKARA MORE	TP-CWL062A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.00			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kV FDR JHATIKARA MORE	TP-CWL059A-1	100	RESIDENTIAL	AMR	Functional	100%	21	0.00			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kV FDR JHATIKARA MORE	TP-CWL279A-1	100	RESIDENTIAL		Functional	100%	5	0.00			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kV FDR KANGAN HERI	TG-CWL013A-1	630	RESIDENTIAL	AMR	Functional	100%	686	0.49	1.81	0.53	22.56%
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TG-CWL470A-1	630	RESIDENTIAL		Functional	100%	307	0.46			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kV FDR KANGAN HERI	TG-CWL018A-1	630	RESIDENTIAL	AMR	Functional	100%	474	0.46			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kV FDR KANGAN HERI	TP-CWL413A-1	400	RESIDENTIAL		Functional	100%	366	0.28			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kV FDR KANGAN HERI	TP-CWL220A-1	400	RESIDENTIAL	AMR	Functional	100%	356	0.14			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kV FDR KANGAN HERI	TP-CWL272A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.08			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kV FDR KANGAN HERI	TP-CWL115A-1	100	RESIDENTIAL	AMR	Functional	100%	35	0.08			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kV FDR KANGAN HERI	TP-CWL166A-1	100	RESIDENTIAL		Functional	100%	46	0.05			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL167A-1	100	RESIDENTIAL	AMR	Functional	100%	16	0.05			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL172A-1	100	RESIDENTIAL	AMR	Functional	100%	9	0.05			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kV FDR KANGAN HERI	620CWL-CWL529A	400	RESIDENTIAL		Functional	100%	22	0.04			
66 kV G - 4 DWARKA GRID	WG4PN121	11kV FDR CHHAWLA	TP-CWL153A-1	100	COMMERCIAL	AMR	Functional	100%	43	0.03			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL131A-1	100	MIXED	AMR	Functional	100%	1	0.03			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kV FDR KANGAN HERI	TP-CWL171A-1	100	RESIDENTIAL	AMR	Functional	100%	17	0.02			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	620CWL-CWL162A	100	RESIDENTIAL	AMR	Functional	100%	10	0.02			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kV FDR KANGAN HERI	TP-CWL054A-1	100	RESIDENTIAL	AMR	Functional	100%	25	0.01			
66 kV DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kV FDR KANGAN HERI	TP-CWL308A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL168A-1	100	RESIDENTIAL	AMR	Functional	100%	8	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL169A-1	100	RESIDENTIAL	AMR	Functional	100%	8	0.01			
66 kV I.O.C.BIJWASAN GRID	SBWSN104	11kV FDR BAMNAULI	TP-CWL174A-1	100	RESIDENTIAL	AMR	Functional	100%	14	0.01			

66 kv I.O.C.BJWASAN GRID	SBWSN104	11kv FDR BAMNAULI	TP-CWL170A-1	100	RESIDENTIAL	AMR	Functional	100%	8	0.01			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kv FDR KANGAN HERI	TP-CWL053A-1	100	RESIDENTIAL	AMR	Functional	100%	9	0.00			
66 kv JAFFARPUR GRID	WZAFF114	11kv FDR PANDWALA	TG-NAJ327A-1	630	RESIDENTIAL	AMR	Functional	100%	161	0.33	0.81	0.38	31.95%
66 kv JAFFARPUR GRID	WZAFF114	11kv FDR PANDWALA	TG-CWL242A-1	630	RESIDENTIAL	AMR	Functional	100%	363	0.29			
66 kv JAFFARPUR GRID	WZAFF110	11kv FDR DAULAT PUR	TP-CWL026A-1	400	RESIDENTIAL	AMR	Functional	100%	229	0.25			
66 kv JAFFARPUR GRID	WZAFF110	11kv FDR DAULAT PUR	TP-CWL276A-1	400	RESIDENTIAL	AMR	Functional	100%	185	0.24			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL278A-1	100	RESIDENTIAL		Functional	100%	10	0.05			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TG-CWL306A-2	100	RESIDENTIAL		Functional	100%	27	0.01			
66 kv JAFFARPUR GRID	WZAFF110	11kv FDR DAULAT PUR	TP-CWL076A-1	100	RESIDENTIAL	AMR	Functional	100%	11	0.01			
66 kv JAFFARPUR GRID	WZAFF110	11kv FDR DAULAT PUR	TP-CWL196A-1	100	MIXED	AMR	Functional	100%	2	0.01			
220kv NAJAFGARH GRID	TDNG110	11kv FDR KAKROLA FEEDER	620DLP-CWL075A-	100	MIXED		Functional	100%	0	0.00			
66 kv JAFFARPUR GRID	WZAFF110	11kv FDR DAULAT PUR	TP-CWL074A-1	100	RESIDENTIAL	AMR	Functional	100%	46	0.00			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD128	11KV FDR DELHI GATE	TG-NAJ019A-1	990	RESIDENTIAL	AMR	Functional	100%	886	2.05	7.21	0.05	0.72%
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD128	11KV FDR DELHI GATE	TG-NAJ021A-1	990	RESIDENTIAL		Functional	100%	1079	0.92			
220kv NAJAFGARH GRID	TDNG105	11kv FDR DTL COLONY	TG-NAJ267A-1	990	RESIDENTIAL	AMR	Functional	100%	703	0.69			
220kv NAJAFGARH GRID	TDNG105	11kv FDR DTL COLONY	TG-NAJ051A-1	990	RESIDENTIAL		Functional	100%	925	0.69			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD128	11KV FDR DELHI GATE	TG-NAJ021A-2	990	RESIDENTIAL	AMR	Functional	100%	634	0.65			
220kv NAJAFGARH GRID	TDNG105	11kv FDR DTL COLONY	TG-NAJ022A-1	630	RESIDENTIAL	AMR	Functional	100%	902	0.50			
220kv NAJAFGARH GRID	TDNG103	11kv FDR PUMPING STATION	TI-NAJ035A-2	990	RESIDENTIAL	AMR	Functional	100%	271	0.48			
220kv NAJAFGARH GRID	TDNG105	11kv FDR DTL COLONY	TG-NAJ022A-2	990	RESIDENTIAL	AMR	Functional	100%	462	0.42			
220kv NAJAFGARH GRID	TDNG103	11kv FDR PUMPING STATION	TP-NAJ035A-1	990	RESIDENTIAL	AMR	Functional	100%	285	0.28			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD128	11KV FDR DELHI GATE	TI-NAJ055A-1	990	RESIDENTIAL	AMR	Functional	100%	238	0.28			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD127	11kv FDR PREM NAGAR	620DLG-NAJ417A-	400	MIXED		Functional	100%	0	0.11			
220kv NAJAFGARH GRID	TDNG105	11kv FDR DTL COLONY	TI-NAJ055A-2	400	COMMERCIAL	AMR	Functional	100%	196	0.10			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD127	11kv FDR PREM NAGAR	TP-NAJ153A-1	100	RESIDENTIAL	AMR	Functional	100%	31	0.05			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD128	11kv FDR DELHI GATE	TP-NAJ271A-1	250	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD128	11kv FDR DELHI GATE	TP-NAJ096A-1	100	RESIDENTIAL	AMR	Functional	100%	53	0.01			
220kv NAJAFGARH GRID	TDNG106	11kv FDR TP KOTLA	TP-NAJ078A-1	990	RESIDENTIAL	AMR	Functional	100%	569	0.66	2.79	0.04	1.39%
220kv NAJAFGARH GRID	TDNG106	11kv FDR TP KOTLA	NF-HVD077A-1	1375	RESIDENTIAL		Functional	100%	791	0.60			
220kv NAJAFGARH GRID	TDNG106	11kv FDR TP KOTLA	NF-HVD032A-1	1100	RESIDENTIAL		Functional	100%	968	0.59			
220kv NAJAFGARH GRID	TDNG105	11kv FDR DTL COLONY	TP-NAJ263A-1	400	RESIDENTIAL	AMR	Functional	100%	233	0.34			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD128	11kv FDR DELHI GATE	TP-NAJ067A-1	400	RESIDENTIAL	AMR	Functional	100%	348	0.34			
220kv NAJAFGARH GRID	TDNG106	11kv FDR TP KOTLA	NF-HVD076A-1	575	RESIDENTIAL		Functional	100%	334	0.15			
220kv NAJAFGARH GRID	TDNG106	11kv FDR TP KOTLA	NF-HVD093A-1	250	RESIDENTIAL		Functional	100%	126	0.10			
220kv NAJAFGARH GRID	TDNG106	11kv FDR TP KOTLA	TP-NAJ093A-1	100	RESIDENTIAL	AMR	Functional	100%	36	0.05			
66 kv G - 6 P.P.K GRID	WG6PN128	11kv FDR POCHAN PUR	TP-CWL296A-1	990	RESIDENTIAL	AMR	Functional	100%	624	0.76	6.40	0.58	8.30%
66 kv G - 6 P.P.K GRID	WG6PN128	11kv FDR POCHAN PUR	NF-HVD082A-1	1525	RESIDENTIAL		Functional	100%	1212	0.54			
66 kv G - 6 P.P.K GRID	WG6PN128	11kv FDR POCHAN PUR	TP-CWL032A-1	630	RESIDENTIAL	AMR	Functional	100%	982	0.53			
66 kv G - 6 P.P.K GRID	WG6PN128	11kv FDR POCHAN PUR	TG-CWL337A-1	630	RESIDENTIAL	AMR	Functional	100%	426	0.50			
66 kv G - 6 P.P.K GRID	WG6PN128	11kv FDR POCHAN PUR	620BTL-CWL177A-	990	RESIDENTIAL	AMR	Functional	100%	310	0.49			
66 kv G - 6 P.P.K GRID	WG6PN128	11kv FDR POCHAN PUR	TG-CWL337A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.45			
66 kv G - 6 P.P.K GRID	WG6PN128	11kv FDR POCHAN PUR	TG-CWL016A-1	630	RESIDENTIAL	AMR	Functional	100%	776	0.42			
66 kv G - 6 P.P.K GRID	WG6PN128	11kv FDR POCHANPUR	620BTL-CWL451A-	750	RESIDENTIAL		Functional	100%	674	0.34			

66 kv G - 6 P.P.K GRID	WG6PN128	11kv FDR POCHAN PUR	TP-CWL483A-1	400	RESIDENTIAL	AMR	Functional	100%	241	0.32			
66 kv G - 6 P.P.K GRID	WG6PN128	11kv FDR POCHAN PUR	TG-CWL016A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.28			
66 kv G - 6 P.P.K GRID	WG6PN128	11kv FDR POCHAN PUR	TG-CWL451A-1	630	RESIDENTIAL	AMR	Functional	100%	91	0.25			
66 kv G - 6 P.P.K GRID	WG6PN125	11kv FDR 810 DDA. FLATS SEC-26(DWK)	TG-CWL176A-1	630	RESIDENTIAL	AMR	Functional	100%	215	0.24			
66 kv G - 6 P.P.K GRID	WG6PN128	11kv FDR POCHAN PUR	TP-CWL469A-1	630	RESIDENTIAL	AMR	Functional	100%	84	0.22			
66 kv G - 6 P.P.K GRID	WG6PN125	11kv FDR 810 DDA. FLATS SEC-26(DWK)	TG-CWL176A-2	630	RESIDENTIAL	AMR	Functional	100%	203	0.22			
66 kv G - 6 P.P.K GRID	WG6PN128	11kv FDR POCHAN PUR	TP-CWL093A-1	400	RESIDENTIAL	AMR	Functional	100%	505	0.22			
66 kv G - 6 P.P.K GRID	WG6PN128	11kv FDR POCHAN PUR	620BTL-CWL522A-	400	RESIDENTIAL	AMR	Functional	100%	195	0.22			
66 kv G - 6 P.P.K GRID	WG6PN125	11kv FDR 810 DDA. FLATS SEC-26(DWK)	TG-CWL132A-2	630	RESIDENTIAL	AMR	Functional	100%	552	0.21			
66 kv G - 6 P.P.K GRID	WG6PN125	11kv FDR 810 DDA. FLATS SEC-26(DWK)	TG-CWL132A-3	630	RESIDENTIAL	AMR	Functional	100%	244	0.20			
66 kv G - 6 P.P.K GRID	WG6PN125	11kv FDR 810 DDA. FLATS SEC-26(DWK)	TG-CWL132A-1	630	RESIDENTIAL	AMR	Functional	100%	183	0.17			
66 kv G - 4 DWARKA GRID	WG4PN625	11kv FDR DDA POCKET 9 DWARKA SEC-23B	620BTL-CWL499A-	630	RESIDENTIAL	AMR	Functional	100%	90	0.07			
66 kv G - 4 DWARKA GRID	WG4PN625	11kv FDR DDA POCKET 9 DWARKA SEC-23B	620BTL-CWL500A-	630	RESIDENTIAL	AMR	Functional	100%	132	0.05			
66 kv G - 4 DWARKA GRID	WG4PN625	11kv FDR DDA POCKET 9 DWARKA SEC-23B	620BTL-CWL499A-	630	RESIDENTIAL	AMR	Functional	100%	90	0.05			
66 kv G - 4 DWARKA GRID	WG4PN626	11kv FDR DDA POCKET 7 DWARKA SEC-23B	620BTL-CWL503A-	630	RESIDENTIAL	AMR	Functional	100%	94	0.04			
66 kv G - 4 DWARKA GRID	WG4PN626	11kv FDR DDA POCKET 7 DWARKA SEC-23B	620BTL-CWL503A-	630	RESIDENTIAL	AMR	Functional	100%	102	0.04			
66 kv G - 4 DWARKA GRID	WG4PN626	11kv FDR DDA POCKET 7 DWARKA SEC-23B	620BTL-CWL504A-	630	RESIDENTIAL	AMR	Functional	100%	137	0.04			
66 kv G - 4 DWARKA GRID	WG4PN626	11kv FDR DDA POCKET 7 DWARKA SEC-23B	620BTL-CWL504A-	630	RESIDENTIAL	AMR	Functional	100%	145	0.03			
66 kv G - 4 DWARKA GRID	WG4PN625	11kv FDR DDA POCKET 9 DWARKA SEC-23B	620BTL-CWL500A-	630	RESIDENTIAL		Functional	100%	76	0.02			
66 kv G - 4 DWARKA GRID	WG4PN627	11kv FDR DDA POCKET 4 DWARKA SEC-23B	620BTL-CWL505A-	630	RESIDENTIAL	AMR	Functional	100%	72	0.02			
66 kv G - 4 DWARKA GRID	WG4PN625	11kv FDR DDA POCKET 9 DWARKA SEC-23B	620BTL-CWL501A-	630	RESIDENTIAL	AMR	Functional	100%	10	0.02			
66 kv G - 4 DWARKA GRID	WG4PN627	11kv FDR DDA POCKET 4 DWARKA SEC-23B	620BTL-CWL506A-	630	RESIDENTIAL	AMR	Functional	100%	10	0.01			
66 kv G - 4 DWARKA GRID	WG4PN120	11kv FDR DHOOL SHIRAS	620BTL-CWL530A-	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kv G - 4 DWARKA GRID	WG4PN625	11kv FDR DDA POCKET 9 DWARKA SEC-23B	620BTL-CWL501A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.01			
66 kv G - 4 DWARKA GRID	WG4PN627	11kv FDR DDA POCKET 4 DWARKA SEC-23B	620BTL-CWL505A-	630	RESIDENTIAL		Functional	100%	0	0.01			
66 kv G - 4 DWARKA GRID	WG4PN625	11kv FDR DDA POCKET 9 DWARKA SEC-23B	620BTL-CWL502A-	630	RESIDENTIAL	AMR	Functional	100%	34	0.00			
66 kv G - 4 DWARKA GRID	WG4PN627	11kv FDR DDA POCKET 4 DWARKA SEC-23B	620BTL-CWL506A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.00			
66 kv G - 4 DWARKA GRID	WG4PN625	11kv FDR DDA POCKET 9 DWARKA SEC-23B	620BTL-CWL502A-	630	MIXED	AMR	Functional	100%	0	0.00			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL025A-1	630	RESIDENTIAL	AMR	Functional	100%	414	0.40	1.87	0.64	25.56%
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL023A-1	400	RESIDENTIAL	AMR	Functional	100%	390	0.36			
66 kv JAFFARPUR GRID	WZAFF114	11kv FDR PANDWALA	TP-CWL024A-1	630	RESIDENTIAL	AMR	Functional	100%	524	0.30			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TI-CWL284A-1	400	RESIDENTIAL	AMR	Functional	100%	117	0.29			
66 kv JAFFARPUR GRID	WZAFF114	11kv FDR PANDWALA	TP-CWL088A-1	400	RESIDENTIAL	AMR	Functional	100%	164	0.28			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL091A-1	400	RESIDENTIAL		Functional	100%	181	0.22			
66 kv JAFFARPUR GRID	WZAFF114	11kv FDR PANDWALA	TP-CWL219A-1	400	RESIDENTIAL	AMR	Functional	100%	197	0.19			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL091A-2	400	RESIDENTIAL		Functional	100%	17	0.12			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL055A-1	400	RESIDENTIAL	AMR	Functional	100%	52	0.09			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL100A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.04			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL096A-1	100	RESIDENTIAL		Functional	100%	5	0.04			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL305A-1	100	RESIDENTIAL	AMR	Functional	100%	29	0.04			
66 kv JAFFARPUR GRID	WZAFF114	11kv FDR PANDWALA	TP-CWL092A-1	100	RESIDENTIAL	AMR	Functional	100%	15	0.03			
66 kv JAFFARPUR GRID	WZAFF114	11kv FDR PANDWALA	TP-CWL089A-1	100	RESIDENTIAL	AMR	Functional	100%	13	0.03			
66 kv JAFFARPUR GRID	WZAFF114	11kv FDR PANDWALA	TP-CWL056A-1	100	RESIDENTIAL	AMR	Functional	100%	12	0.02			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL094A-1	100	RESIDENTIAL	AMR	Functional	100%	16	0.02			

66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL099A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.01			
66 kv JAFFARPUR GRID	WZAFF114	11kv FDR PANDWALA	TP-CWL090A-1	100	RESIDENTIAL	AMR	Functional	100%	10	0.01			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL186A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kv FDR KANGAN HERI	TP-CWL101A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.01			
66 kv JAFFARPUR GRID	WZAFF114	11kv FDR PANDWALA	TP-CWL081A-1	100	RESIDENTIAL	AMR	Functional	100%	6	0.00			
66 kv JAFFARPUR GRID	WZAFF114	11kv FDR PANDWALA	TP-CWL095A-1	100	RESIDENTIAL		Functional	100%	7	0.00			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD116	11kv FDR SHYAM VIHAR	620DLG-HVD089A-	1250	RESIDENTIAL		Functional	100%	971	0.84	11.46	0.64	5.32%
220kv NAJAFGARH GRID	TDTNG108	11kv FDR NANGLI SHAKRAWATI	TG-NAJ002A-1	990	RESIDENTIAL	AMR	Functional	100%	176	0.79			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD123	11kv FDR ARJUN PARK	TG-NAJ151A-1	630	RESIDENTIAL	AMR	Functional	100%	219	0.70			
220kv NAJAFGARH GRID	TDTNG108	11kv FDR NANGLI SHAKRAWATI	TP-NAJ005A-1	990	RESIDENTIAL	AMR	Functional	100%	273	0.65			
220kv NAJAFGARH GRID	TDTNG107	11kv FDR RAMA PARK	NF-HVD026A-1	1100	RESIDENTIAL		Functional	100%	777	0.61			
220kv NAJAFGARH GRID	TDTNG107	11kv FDR RAMA PARK	TP-HVD090A-1	1100	RESIDENTIAL		Functional	100%	573	0.61			
220kv NAJAFGARH GRID	TDTNG108	11kv FDR NANGLI SHAKRAWATI	TG-NAJ287A-1	630	RESIDENTIAL	AMR	Functional	100%	107	0.50			
220kv NAJAFGARH GRID	TDTNG108	11kv FDR NANGLI SHAKRAWATI	TG-NAJ004A-1	990	RESIDENTIAL	AMR	Functional	100%	152	0.47			
220kv NAJAFGARH GRID	TDTNG108	11kv FDR NANGLI SHAKRAWATI	TG-NAJ287A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.46			
220kv NAJAFGARH GRID	TDTNG107	11kv FDR RAMA PARK	TG-NAJ257A-1	400	RESIDENTIAL	AMR	Functional	100%	414	0.45			
220kv NAJAFGARH GRID	TDTNG106	11kv FDR TP KOTLA	620DLG-NAJ104A-	400	RESIDENTIAL	AMR	Functional	100%	53	0.45			
220kv NAJAFGARH GRID	TDTNG106	11kv FDR TP KOTLA	620DLG-NAJ109A-	400	RESIDENTIAL	AMR	Functional	100%	56	0.40			
220kv NAJAFGARH GRID	TDTNG108	11kv FDR NANGLI SHAKRAWATI	TG-NAJ003A-1	630	RESIDENTIAL		Functional	100%	127	0.37			
220kv NAJAFGARH GRID	TDTNG107	11kv FDR RAMA PARK	TP-NAJ244A-1	400	RESIDENTIAL	AMR	Functional	100%	680	0.36			
220kv NAJAFGARH GRID	TDTNG108	11kv FDR NANGLI SHAKRAWATI	620DLG-NAJ003A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.35			
220kv NAJAFGARH GRID	TDTNG106	11kv FDR TP KOTLA	620DLG-NAJ084A-	400	RESIDENTIAL	AMR	Functional	100%	40	0.34			
220kv NAJAFGARH GRID	TDTNG106	11kv FDR TP KOTLA	TP-NAJ007A-1	630	RESIDENTIAL	AMR	Functional	100%	140	0.30			
220kv NAJAFGARH GRID	TDTNG105	11kv FDR DTL COLONY	TG-NAJ274A-1	400	RESIDENTIAL	AMR	Functional	100%	370	0.29			
220kv NAJAFGARH GRID	TDTNG106	11kv FDR TP KOTLA	TP-NAJ358A-1	400	RESIDENTIAL		Functional	100%	48	0.28			
220kv NAJAFGARH GRID	TDTNG107	11kv FDR RAMA PARK	TP-NAJ361A-1	400	RESIDENTIAL	AMR	Functional	100%	355	0.25			
220kv NAJAFGARH GRID	TDTNG107	11kv FDR RAMA PARK	TP-NAJ011A-1	400	RESIDENTIAL	AMR	Functional	100%	584	0.24			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD123	11kv FDR ARJUN PARK	TG-NAJ006A-2	630	RESIDENTIAL		Functional	100%	28	0.23			
220kv NAJAFGARH GRID	TDTNG106	11kv FDR TP KOTLA	TP-NAJ350A-1	400	RESIDENTIAL	AMR	Functional	100%	30	0.21			
220kv NAJAFGARH GRID	TDTNG105	11kv FDR DTL COLONY	TP-NAJ049A-1	400	RESIDENTIAL		Functional	100%	98	0.21			
220kv NAJAFGARH GRID	TDTNG108	11kv FDR NANGLI SHAKRAWATI	TG-NAJ324A-1	630	RESIDENTIAL	AMR	Functional	100%	51	0.19			
220kv NAJAFGARH GRID	TDTNG109	11kv FDR 7 PANEL BOARD	TP-NAJ112A-1	400	RESIDENTIAL	AMR	Functional	100%	45	0.18			
220kv NAJAFGARH GRID	TDTNG108	11kv FDR NANGLI SHAKRAWATI	TP-NAJ278A-1	400	RESIDENTIAL	AMR	Functional	100%	33	0.18			
220kv NAJAFGARH GRID	TDTNG105	11kv FDR DTL COLONY	620DLG-NAJ402A-	630	RESIDENTIAL	AMR	Functional	100%	28	0.18			
220kv NAJAFGARH GRID	TDTNG106	11kv FDR TP KOTLA	620DLG-NAJ411A-	400	RESIDENTIAL	AMR	Functional	100%	14	0.17			
220kv NAJAFGARH GRID	TDTNG107	11kv FDR RAMA PARK	TP-NAJ245A-1	400	RESIDENTIAL	AMR	Functional	100%	567	0.17			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD123	11kv FDR ARJUN PARK	TP-NAJ360A-1	400	RESIDENTIAL	AMR	Functional	100%	191	0.14			
220kv NAJAFGARH GRID	TDTNG106	11kv FDR TP KOTLA	620DLG-NAJ395A-	400	RESIDENTIAL	AMR	Functional	100%	22	0.13			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD123	11kv FDR ARJUN PARK	TG-NAJ006A-1	630	RESIDENTIAL	AMR	Functional	100%	308	0.11			
220kv NAJAFGARH GRID	TDTNG106	11kv FDR TP KOTLA	TG-NAJ007A-2	400	RESIDENTIAL	AMR	Functional	100%	4	0.10			
220kv NAJAFGARH GRID	TDTNG108	11kv FDR NANGLI SHAKRAWATI	TG-NAJ226A-1	400	RESIDENTIAL	AMR	Functional	100%	122	0.07			
220kv NAJAFGARH GRID	TDTNG106	11kv FDR TP KOTLA	TP-NAJ357A-1	400	RESIDENTIAL		Functional	100%	28	0.05			
220kv NAJAFGARH GRID	TDTNG106	11kv FDR TP KOTLA	TP-NAJ352A-1	100	RESIDENTIAL	AMR	Functional	100%	16	0.04			
220kv NAJAFGARH GRID	TDTNG106	11kv FDR TP KOTLA	TP-NAJ359A-1	100	RESIDENTIAL		Functional	100%	27	0.01			
220kv NAJAFGARH GRID	TDTNG106	11kv FDR TP KOTLA	TP-NAJ351A-1	100	RESIDENTIAL		Functional	100%	24	0.01			
220kv NAJAFGARH GRID	TDTNG104	11kv FDR DEENPUR	TG-CWL269A-1	630	RESIDENTIAL	AMR	Functional	100%	476	0.44	1.77	0.34	16.34%

220KV NAJAFGARH GRID	TDTNG104	11KV FDR DEENPUR	TG-CWL006A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.33			
220KV NAJAFGARH GRID	TDTNG104	11KV FDR DEENPUR	TP-CWL292A-1	400	RESIDENTIAL	AMR	Functional	100%	544	0.26			
220KV NAJAFGARH GRID	TDTNG104	11KV FDR DEENPUR	TP-CWL270A-2	400	RESIDENTIAL	AMR	Functional	100%	78	0.26			
220KV NAJAFGARH GRID	TDTNG104	11KV FDR DEENPUR	TG-CWL006A-1	400	RESIDENTIAL	AMR	Functional	100%	671	0.22			
220KV NAJAFGARH GRID	TDTNG104	11KV FDR DEENPUR	TP-CWL292A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.20			
220KV NAJAFGARH GRID	TDTNG104	11KV FDR DEENPUR	TP-CWL270A-1	400	RESIDENTIAL	AMR	Functional	100%	339	0.14			
220KV NAJAFGARH GRID	TDTNG104	11KV FDR DEENPUR	TG-CWL108A-1	400	RESIDENTIAL	AMR	Functional	100%	196	0.13			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD115	11KV FDR ROSHAN PURA X-1	TG-CWL109A-1	400	RESIDENTIAL	AMR	Functional	100%	101	0.07			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD115	11KV FDR ROSHAN PURA X-1	TP-NAJ091A-1	100	RESIDENTIAL	AMR	Functional	100%	59	0.03			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD115	11KV FDR ROSHAN PURA X-1	620JTM-NAJ412A	630	MIXED	AMR	Functional	100%	185	0.03			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	TP-CWL110A-1	400	RESIDENTIAL	AMR	Functional	100%	23	0.04	0.14	0.08	37.48%
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	TP-CWL103A-1	100	RESIDENTIAL	AMR	Functional	100%	24	0.03			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	TP-CWL105A-1	100	RESIDENTIAL	AMR	Functional	100%	22	0.03			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	TP-CWL097A-1	100	RESIDENTIAL	AMR	Functional	100%	12	0.03			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	TP-NAJ082A-2	100	RESIDENTIAL		Functional	100%	7	0.02			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	TP-CWL111A-1	100	RESIDENTIAL	AMR	Functional	100%	13	0.02			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	TP-CWL107A-1	100	RESIDENTIAL	AMR	Functional	100%	12	0.02			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	TP-CWL438A-1	100	RESIDENTIAL	AMR	Functional	100%	16	0.01			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	TP-CWL437A-1	100	RESIDENTIAL	AMR	Functional	100%	20	0.01			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	TP-CWL106A-1	100	RESIDENTIAL	AMR	Functional	100%	6	0.01			
220KV NAJAFGARH GRID	TDTNG104	11KV FDR DEENPUR	TP-CWL114A-1	100	RESIDENTIAL	AMR	Functional	100%	21	0.01			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	TP-CWL430A-1	100	MIXED		Functional	100%	7	0.00			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	TP-CWL104A-1	100	RESIDENTIAL	AMR	Functional	100%	12	0.00			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	TP-NAJ298A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.00			
220KV NAJAFGARH GRID	TDTNG104	11KV FDR DEENPUR	TP-CWL116A-1	100	RESIDENTIAL	AMR	Functional	100%	18	0.00			
66 KV G - 4 DWARKA GRID	WG4PN105	11KV FDR HANUMAN CHOWK	NF-HVD058A-1	1050	RESIDENTIAL		Functional	100%	314	0.52	10.36	0.90	8.01%
66 KV G - 4 DWARKA GRID	WG4PN105	11KV FDR HANUMAN CHOWK	TG-CWL480A-1	630	RESIDENTIAL	AMR	Functional	100%	421	0.49			
66 KV G - 4 DWARKA GRID	WG4PN128	11KV FDR QUTUB VIHAR PH-2	620CWL-CWL526A	630	RESIDENTIAL	AMR	Functional	100%	391	0.45			
66 KV G - 4 DWARKA GRID	WG4PN127	11KV MCD SCHOOL QUTUB VIHAR	TP-CWL239A-1	400	RESIDENTIAL	AMR	Functional	100%	795	0.42			
66 KV G - 4 DWARKA GRID	WG4PN127	11KV MCD SCHOOL QUTUB VIHAR	TG-CWL259A-1	630	RESIDENTIAL	AMR	Functional	100%	256	0.40			
66 KV G - 4 DWARKA GRID	WG4PN105	11KV FDR HANUMAN CHOWK	TP-CWL246A-1	400	RESIDENTIAL	AMR	Functional	100%	598	0.40			
66 KV G - 4 DWARKA GRID	WG4PN105	11KV FDR HANUMAN CHOWK	TP-CWL248A-1	400	RESIDENTIAL	AMR	Functional	100%	684	0.39			
66 KV G - 4 DWARKA GRID	WG4PN127	11KV MCD SCHOOL QUTUB VIHAR	TP-CWL257A-1	400	RESIDENTIAL	AMR	Functional	100%	384	0.39			
66 KV G - 4 DWARKA GRID	WG4PN127	11KV MCD SCHOOL QUTUB VIHAR	TP-CWL267A-1	400	RESIDENTIAL	AMR	Functional	100%	614	0.39			
66 KV G - 4 DWARKA GRID	WG4PN127	11KV MCD SCHOOL QUTUB VIHAR	TP-CWL302A-1	400	RESIDENTIAL	AMR	Functional	100%	456	0.37			
66 KV G - 4 DWARKA GRID	WG4PN127	11KV MCD SCHOOL QUTUB VIHAR	TP-CWL265A-1	400	RESIDENTIAL	AMR	Functional	100%	413	0.35			
66 KV G - 4 DWARKA GRID	WG4PN127	11KV MCD SCHOOL QUTUB VIHAR	TG-CWL339A-1	400	RESIDENTIAL	AMR	Functional	100%	262	0.33			
66 KV G - 4 DWARKA GRID	WG4PN127	11KV MCD SCHOOL QUTUB VIHAR	TG-CWL255A-1	400	RESIDENTIAL	AMR	Functional	100%	236	0.31			
66 KV G - 4 DWARKA GRID	WG4PN128	11KV FDR QUTUB VIHAR PH-2	TG-CWL232A-1	400	RESIDENTIAL	AMR	Functional	100%	189	0.30			
66 KV G - 4 DWARKA GRID	WG4PN127	11KV MCD SCHOOL QUTUB VIHAR	TG-CWL303A-1	400	RESIDENTIAL		Functional	100%	633	0.29			
66 KV G - 4 DWARKA GRID	WG4PN128	11KV FDR QUTUB VIHAR PH-2	TP-CWL230A-1	400	RESIDENTIAL		Functional	100%	790	0.28			
66 KV G - 4 DWARKA GRID	WG4PN127	11KV MCD SCHOOL QUTUB VIHAR	TP-CWL238A-1	400	RESIDENTIAL	AMR	Functional	100%	423	0.28			

66 kv G - 4 DWARKA GRID	WG4PN129	11kv FDR SHYAM VIHAR PH-2	620CWL-CWL540A	400	MIXED	AMR	Functional	100%	0	0.27			
66 kv G - 4 DWARKA GRID	WG4PN128	11kv FDR QUTUB VIHAR PH-2	TP-CWL228A-1	400	RESIDENTIAL	AMR	Functional	100%	601	0.27			
66 kv G - 4 DWARKA GRID	WG4PN105	11kv FDR HANUMAN CHOWK	TG-CWL264A-1	400	RESIDENTIAL	AMR	Functional	100%	189	0.26			
66 kv G - 4 DWARKA GRID	WG4PN127	11kv MCD SCHOOL QUTUB VIHAR	TP-CWL260A-1	400	RESIDENTIAL	AMR	Functional	100%	384	0.26			
66 kv G - 4 DWARKA GRID	WG4PN105	11kv FDR HANUMAN CHOWK	TP-CWL042A-1	400	RESIDENTIAL		Functional	100%	415	0.25			
66 kv G - 4 DWARKA GRID	WG4PN105	11kv FDR HANUMAN CHOWK	TP-CWL227A-1	400	RESIDENTIAL	AMR	Functional	100%	454	0.24			
66 kv G - 4 DWARKA GRID	WG4PN127	11kv MCD SCHOOL QUTUB VIHAR	TP-CWL258A-1	400	RESIDENTIAL	AMR	Functional	100%	193	0.24			
66 kv G - 4 DWARKA GRID	WG4PN127	11kv MCD SCHOOL QUTUB VIHAR	TP-CWL266A-1	400	RESIDENTIAL		Functional	100%	524	0.24			
66 kv G - 4 DWARKA GRID	WG4PN128	11kv FDR QUTUB VIHAR PH-2	TP-CWL234A-1	400	RESIDENTIAL	AMR	Functional	100%	416	0.23			
66 kv G - 4 DWARKA GRID	WG4PN128	11kv FDR QUTUB VIHAR PH-2	TP-CWL250A-1	400	RESIDENTIAL	AMR	Functional	100%	193	0.23			
66 kv G - 4 DWARKA GRID	WG4PN105	11kv FDR HANUMAN CHOWK	TP-CWL252A-1	400	RESIDENTIAL	AMR	Functional	100%	189	0.22			
66 kv G - 4 DWARKA GRID	WG4PN127	11kv MCD SCHOOL QUTUB VIHAR	TG-CWL420A-1	400	RESIDENTIAL	AMR	Functional	100%	240	0.22			
66 kv G - 4 DWARKA GRID	WG4PN127	11kv MCD SCHOOL QUTUB VIHAR	TP-CWL244A-1	400	RESIDENTIAL	AMR	Functional	100%	301	0.21			
66 kv G - 4 DWARKA GRID	WG4PN105	11kv FDR HANUMAN CHOWK	TG-CWL263A-1	400	RESIDENTIAL	AMR	Functional	100%	328	0.21			
66 kv G - 4 DWARKA GRID	WG4PN127	11kv MCD SCHOOL QUTUB VIHAR	TP-CWL256A-1	400	RESIDENTIAL	AMR	Functional	100%	186	0.20			
66 kv G - 4 DWARKA GRID	WG4PN127	11kv MCD SCHOOL QUTUB VIHAR	TP-CWL268A-1	400	RESIDENTIAL	AMR	Functional	100%	198	0.19			
66 kv G - 4 DWARKA GRID	WG4PN105	11kv FDR HANUMAN CHOWK	TP-CWL226A-1	400	RESIDENTIAL	AMR	Functional	100%	427	0.17			
66 kv G - 4 DWARKA GRID	WG4PN127	11kv MCD SCHOOL QUTUB VIHAR	TP-CWL398A-1	400	RESIDENTIAL	AMR	Functional	100%	210	0.14			
66 kv G - 4 DWARKA GRID	WG4PN128	11kv FDR QUTUB VIHAR PH-2	TP-CWL231A-1	400	RESIDENTIAL	AMR	Functional	100%	607	0.14			
66 kv G - 4 DWARKA GRID	WG4PN127	11kv MCD SCHOOL QUTUB VIHAR	TP-CWL245A-1	400	RESIDENTIAL	AMR	Functional	100%	260	0.13			
66 kv G - 4 DWARKA GRID	WG4PN105	11kv FDR HANUMAN CHOWK	TP-CWL237A-1	400	RESIDENTIAL	AMR	Functional	100%	665	0.11			
66 kv G - 4 DWARKA GRID	WG4PN101	11kv FDR GOYALA DAIRY	TG-CWL348A-1	400	RESIDENTIAL	AMR	Functional	100%	67	0.11			
66 kv G - 4 DWARKA GRID	WG4PN128	11kv FDR QUTUB VIHAR PH-2	TP-CWL261A-1	400	RESIDENTIAL	AMR	Functional	100%	220	0.10			
66 kv G - 4 DWARKA GRID	WG4PN105	11kv FDR HANUMAN CHOWK	TP-CWL247A-1	400	RESIDENTIAL	AMR	Functional	100%	171	0.09			
66 kv G - 4 DWARKA GRID	WG4PN128	11kv FDR QUTUB VIHAR PH-2	620BTL-CWL537A	400	MIXED	AMR	Functional	100%	194	0.06			
66 kv G - 4 DWARKA GRID	WG4PN105	11kv FDR HANUMAN CHOWK	TP-CWL251A-1	400	RESIDENTIAL	AMR	Functional	100%	169	0.05			
66 kv G - 4 DWARKA GRID	WG4PN102	11kv FDR TAJPUR	TP-CWL467A-1	100	RESIDENTIAL	AMR	Functional	100%	155	0.04			
66 kv G - 4 DWARKA GRID	WG4PN105	11kv FDR HANUMAN CHOWK	TP-CWL205A-1	100	MIXED		Functional	100%	93	0.02			
66 kv G - 4 DWARKA GRID	WG4PN102	11kv FDR TAJPUR	620BTL-CWL524A	100	RESIDENTIAL	AMR	Functional	100%	3	0.02			
66 kv G - 4 DWARKA GRID	WG4PN102	11kv FDR TAJPUR	TP-CWL450A-1	100	RESIDENTIAL	AMR	Functional	100%	44	0.00			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kv FDR KANGAN HERI	TG-CWL022A-1	630	RESIDENTIAL	AMR	Functional	100%	487	0.33	0.85	0.13	13.51%
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kv FDR KANGAN HERI	NF-HVD072A-1	900	RESIDENTIAL		Functional	100%	359	0.31			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kv FDR KANGAN HERI	TG-CWL415A-1	400	RESIDENTIAL	AMR	Functional	100%	218	0.19			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kv FDR KANGAN HERI	TP-CWL098A-1	400	RESIDENTIAL	AMR	Functional	100%	87	0.13			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kv FDR KANGAN HERI	TP-CWL080A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.01			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kv FDR KANGAN HERI	TP-CWL102A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.01			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD127	11kv FDR PREM NAGAR	NF-HVD044A-1	3125	RESIDENTIAL		Functional	100%	1425	1.03	7.12	0.11	1.47%
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD115	11kv FDR ROSHAN PURA X-1	NF-HVD043A-1	3525	RESIDENTIAL		Functional	100%	818	0.80			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD127	11kv FDR PREM NAGAR	620JTM-HVD098A	625	MIXED		Functional	100%	943	0.48			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD115	11kv FDR ROSHAN PURA X-1	TP-CWL046A-1	630	RESIDENTIAL	AMR	Functional	100%	447	0.42			
220kv NAJAFGARH GRID	TDTNG103	11kv FDR PUMPING STATION	NF-HVD042A-1	1700	RESIDENTIAL		Functional	100%	1058	0.42			
220kv NAJAFGARH GRID	TDTNG103	11kv FDR PUMPING STATION	TG-NAJ034A-1	990	RESIDENTIAL	AMR	Functional	100%	575	0.39			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD127	11kv FDR PREM NAGAR	NF-HVD024A-1	375	RESIDENTIAL		Functional	100%	120	0.37			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD127	11kv FDR PREM NAGAR	NF-HVD087A-1	750	RESIDENTIAL		Functional	100%	395	0.36			

66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD127	11KV FDR PREM NAGAR	TI-NAJ033A-1	630	RESIDENTIAL	AMR	Functional	100%	546	0.35			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD115	11KV FDR ROSHAN PURA X-1	TP-CWL208A-1	630	RESIDENTIAL	AMR	Functional	100%	234	0.34			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD127	11KV FDR PREM NAGAR	620JTM-NAJ094A	400	RESIDENTIAL	AMR	Functional	100%	148	0.32			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD126	11KV FDR KHAIRA	TG-CWL297A-1	400	RESIDENTIAL	AMR	Functional	100%	197	0.27			
220KV NAJAFGARH GRID	TDNG103	11KV FDR PUMPING STATION	NF-HVD018A-1	600	RESIDENTIAL		Functional	100%	0	0.25			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD126	11KV FDR KHAIRA	620JTM-HVD100A	625	MIXED		Functional	100%	261	0.24			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD127	11KV FDR PREM NAGAR	NF-HVD080A-1	2150	RESIDENTIAL		Functional	100%	494	0.24			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD127	11KV FDR PREM NAGAR	NF-HVD085A-1	2300	RESIDENTIAL		Functional	100%	508	0.23			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD126	11KV FDR KHAIRA	TP-NAJ253A-1	400	RESIDENTIAL	AMR	Functional	100%	132	0.21			
220KV NAJAFGARH GRID	TDNG103	11KV FDR PUMPING STATION	NF-HVD073A-1	900	RESIDENTIAL		Functional	100%	579	0.17			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD126	11KV FDR KHAIRA	TG-CWL346A-1	400	RESIDENTIAL	AMR	Functional	100%	173	0.13			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD115	11KV FDR ROSHAN PURA X-1	TP-NAJ355A-1	250	RESIDENTIAL	AMR	Functional	100%	72	0.07			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD115	11KV FDR ROSHAN PURA X-1	620JTM-NAJ394A	100	RESIDENTIAL	AMR	Functional	100%	27	0.03			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD128	11KV FDR DELHI GATE	TP-NAJ159A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD115	11KV FDR ROSHAN PURA X-1	TP-NAJ354A-1	250	RESIDENTIAL	AMR	Functional	100%	175	0.02			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD127	11KV FDR PREM NAGAR	TP-NAJ321A-1	400	RESIDENTIAL	AMR	Functional	100%	8	0.02			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD115	11KV FDR ROSHAN PURA X-1	TG-NAJ041A-1	990	RESIDENTIAL	AMR	Functional	100%	568	0.56	4.98	0.24	4.66%
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD130	11KV FDR BDO OFFICE	TG-NAJ042A-1	990	RESIDENTIAL	AMR	Functional	100%	639	0.50			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD114	11KV FDR VARDHMAN VIHAR	NF-HVD053A-1	2250	RESIDENTIAL		Functional	100%	1220	0.45			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD114	11KV FDR VARDHMAN VIHAR	620JTM-HVD001A	625	RESIDENTIAL	AMR	Functional	100%	263	0.42			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD115	11KV FDR ROSHAN PURA X-1	NF-HVD074A-1	1225	RESIDENTIAL		Functional	100%	509	0.39			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD114	11KV FDR VARDHMAN VIHAR	620JTM-HVD099A	625	MIXED		Functional	100%	209	0.33			
220KV NAJAFGARH GRID	TDNG103	11KV FDR PUMPING STATION	TP-NAJ061A-1	400	RESIDENTIAL	AMR	Functional	100%	12	0.31			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD130	11KV FDR BDO OFFICE	TP-NAJ065A-2	630	RESIDENTIAL	AMR	Functional	100%	153	0.31			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD114	11KV FDR VARDHMAN VIHAR	TG-NAJ062A-2	400	RESIDENTIAL	AMR	Functional	100%	324	0.29			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD130	11KV FDR BDO OFFICE	TP-NAJ065A-1	400	RESIDENTIAL	AMR	Functional	100%	172	0.26			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD130	11KV FDR BDO OFFICE	TP-NAJ064A-1	630	RESIDENTIAL		Functional	100%	258	0.25			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD115	11KV FDR ROSHAN PURA X-1	TG-NAJ044A-1	630	RESIDENTIAL	AMR	Functional	100%	225	0.23			
220KV NAJAFGARH GRID	TDNG104	11KV FDR DEENPUR	NF-HVD008A-1	525	RESIDENTIAL		Functional	100%	146	0.22			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD115	11KV FDR ROSHAN PURA X-1	NF-HVD055A-1	2250	RESIDENTIAL		Functional	100%	515	0.16			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD115	11KV FDR ROSHAN PURA X-1	NF-HVD054A-1	500	RESIDENTIAL		Functional	100%	671	0.15			
220KV NAJAFGARH GRID	TDNG103	11KV FDR PUMPING STATION	NF-HVD0041A-1	375	RESIDENTIAL		Functional	100%	236	0.15			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD114	11KV FDR VARDHMAN VIHAR	NF-HVD027A-1	500	RESIDENTIAL		Functional	100%	145	0.13			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD114	11KV FDR VARDHMAN VIHAR	TP-NAJ063A-1	400	RESIDENTIAL		Functional	100%	184	0.09			
220KV NAJAFGARH GRID	TDNG104	11KV FDR DEENPUR	NF-HVD088A-1	225	RESIDENTIAL		Functional	100%	0	0.02			

220KV NAJAFGARH GRID	TDTNG110	11KV FDR KAKROLA FEEDER	NF-HVD049A-1	2575	RESIDENTIAL		Functional	100%	1787	1.24	6.98	0.54	7.20%			
220KV NAJAFGARH GRID	TDTNG110	11KV FDR KAKROLA FEEDER	NF-HVD048A-1	2825	RESIDENTIAL		Functional	100%	2103	1.22						
220KV NAJAFGARH GRID	TDTNG105	11KV FDR DTL COLONY	TG-NAJ015A-1	990	RESIDENTIAL	AMR	Functional	100%	355	0.70						
220KV NAJAFGARH GRID	TDTNG105	11KV FDR DTL COLONY	TG-NAJ052A-1	990	RESIDENTIAL	AMR	Functional	100%	998	0.67						
220KV NAJAFGARH GRID	TDTNG105	11KV FDR DTL COLONY	TP-NAJ080A-1	990	RESIDENTIAL	AMR	Functional	100%	653	0.64						
220KV NAJAFGARH GRID	TDTNG110	11KV FDR KAKROLA FEEDER	NF-HVD047A-1	1100	RESIDENTIAL		Functional	100%	625	0.50						
220KV PAPPAN KALAN 2 GRID	WPKL2105	11KV FDR DMRC STAFF QUARTERS	NF-HVD051A-1	1475	RESIDENTIAL		Functional	100%	702	0.47						
220KV NAJAFGARH GRID	TDTNG110	11KV FDR KAKROLA FEEDER	TP-NAJ238A-1	400	RESIDENTIAL	AMR	Functional	100%	764	0.26						
220KV NAJAFGARH GRID	TDTNG110	11KV FDR KAKROLA FEEDER	TP-NAJ090A-1	400	RESIDENTIAL	AMR	Functional	100%	107	0.25						
220KV NAJAFGARH GRID	TDTNG110	11KV FDR KAKROLA FEEDER	TG-CWL448A-1	400	RESIDENTIAL		Functional	100%	422	0.23						
220KV NAJAFGARH GRID	TDTNG110	11KV FDR KAKROLA FEEDER	TP-NAJ237A-1	400	RESIDENTIAL	AMR	Functional	100%	140	0.21						
220KV PAPPAN KALAN 2 GRID	WPKL2105	11KV FDR DMRC STAFF QUARTERS	NF-HVD052A-1	575	RESIDENTIAL		Functional	100%	194	0.20						
220KV PAPPAN KALAN 2 GRID	WPKL2105	11KV FDR DMRC STAFF QUARTERS	TI-NAJ266A-3	990	RESIDENTIAL	AMR	Functional	100%	0	0.16						
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD124	11KV FDR ROSHAN GARDEN S/S NO.-2	NF-HVD050A-1	200	RESIDENTIAL		Functional	100%	131	0.12						
220KV NAJAFGARH GRID	TDTNG110	11KV FDR KAKROLA FEEDER	620DLG-NAJ281A-	100	MIXED		Functional	100%	0	0.10						
220KV NAJAFGARH GRID	TDTNG110	11KV FDR KAKROLA FEEDER	620DLG-CWL539A-	630	MIXED		Functional	100%	27	0.10						
220KV NAJAFGARH GRID	TDTNG110	11KV FDR KAKROLA FEEDER	620DLG-CWL527A-	630	RESIDENTIAL	AMR	Functional	100%	112	0.09						
220KV PAPPAN KALAN 2 GRID	WPKL2105	11KV FDR DMRC STAFF QUARTERS	TI-NAJ266A-4	990	RESIDENTIAL	AMR	Functional	100%	0	0.05						
220KV PAPPAN KALAN 2 GRID	WPKL2105	11KV FDR DMRC STAFF QUARTERS	TP-CWL493A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.04						
220KV PAPPAN KALAN 2 GRID	WPKL2105	11KV FDR DMRC STAFF QUARTERS	TI-NAJ266A-1	990	RESIDENTIAL	AMR	Functional	100%	0	0.04						
220KV NAJAFGARH GRID	TDTNG110	11KV FDR KAKROLA FEEDER	TP-NAJ165A-1	100	RESIDENTIAL		Functional	100%	7	0.04						
220KV PAPPAN KALAN 2 GRID	WPKL2105	11KV FDR DMRC STAFF QUARTERS	TI-NAJ266A-2	990	RESIDENTIAL	AMR	Functional	100%	209	0.03						
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD109	11KV STR 400KVA STATION TRANSFORMER	TG-WTC028A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.03						
220KV NAJAFGARH GRID	TDTNG110	11KV FDR KAKROLA FEEDER	620DLG-CWL535A-	400	MIXED	AMR	Functional	100%	17	0.03						
220KV NAJAFGARH GRID	TDTNG110	11KV FDR KAKROLA FEEDER	TP-CWL454A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.03						
220KV PAPPAN KALAN 2 GRID	WPKL2105	11KV FDR DMRC STAFF QUARTERS	TI-NAJ265A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.02						
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD120	11KV FDR STAFF QUR 50 MGD NJF	TP-CWL195A-1	630	RESIDENTIAL	AMR	Functional	100%	20	0.02						
220KV PAPPAN KALAN 2 GRID	WPKL2105	11KV FDR DMRC STAFF QUARTERS	TI-NAJ265A-2	400	RESIDENTIAL	AMR	Functional	100%	57	0.02						
66 KV G - 4 DWARKA GRID	WG4PN101	11KV FDR GOYALA DAIRY	TP-CWL215A-1	400	RESIDENTIAL	AMR	Functional	100%	463	0.29				0.77	0.15	16.52%
66 KV G - 4 DWARKA GRID	WG4PN101	11KV FDR GOYALA DAIRY	TP-CWL034A-1	400	RESIDENTIAL	AMR	Functional	100%	169	0.28						
66 KV G - 4 DWARKA GRID	WG4PN105	11KV FDR HANUMAN CHOWK	TP-CWL249A-1	400	RESIDENTIAL	AMR	Functional	100%	288	0.23						
66 KV G - 4 DWARKA GRID	WG4PN101	11KV FDR GOYALA DAIRY	620CWL-CWL215A-	400	MIXED		Functional	100%	0	0.10						
66 KV G - 4 DWARKA GRID	WG4PN128	11KV FDR QUTUB VIHAR PH-2	TP-CWL158A-1	100	RESIDENTIAL	AMR	Functional	100%	79	0.02						
66 KV G - 4 DWARKA GRID	WG4PN105	11KV FDR HANUMAN CHOWK	TP-CWL155A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.01						
66 KV JAFFARPUR GRID	WZAFF110	11KV FDR DAULAT PUR	TP-CWL282A-1	400	RESIDENTIAL	AMR	Functional	100%	306	0.37						
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	TP-CWL030A-1	400	RESIDENTIAL	AMR	Functional	100%	355	0.34	0.73	0.45	37.89%			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	TG-NAJ322A-1	630	RESIDENTIAL	AMR	Functional	100%	177	0.27						
66 KV JAFFARPUR GRID	WZAFF110	11KV FDR DAULAT PUR	620DLP-NAJ389A-	400	RESIDENTIAL	AMR	Functional	100%	113	0.18						
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	620DLP-CWL079A-	100	RESIDENTIAL	AMR	Functional	100%	0	0.01						
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11KV FDR JHATIKARA MORE	620DLP-CWL079A-	100	RESIDENTIAL	AMR	Functional	100%	21	0.00						
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD102	11KV FDR ROSHAN PURA	NF-HVD084A-1	1675	RESIDENTIAL		Functional	100%	929	0.91						
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD118	11KV FDR DJB-1	NF-HVD078A-1	2150	RESIDENTIAL		Functional	100%	1028	0.74						
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD107	11KV FDR PRASHANT SS-BD CWL	TG-NAJ039A-1	990	RESIDENTIAL	AMR	Functional	100%	886	0.65	6.39	0.25	3.71%			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD118	11KV FDR DJB-1	NF-HVD038A-1	1425	RESIDENTIAL		Functional	100%	783	0.58						

66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD107	11KV FDR PRASHANT SS-BD CWL	TG-NAJ025A-1	990	RESIDENTIAL	AMR	Functional	100%	502	0.57			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD118	11KV FDR DJB-1	TG-NAJ062A-1	630	RESIDENTIAL	AMR	Functional	100%	432	0.49			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD118	11KV FDR DJB-1	NF-HVD039A-1	1150	RESIDENTIAL		Functional	100%	578	0.48			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD102	11KV FDR ROSHAN PURA	TG-CWL421A-1	630	RESIDENTIAL	AMR	Functional	100%	471	0.41			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD102	11KV FDR ROSHAN PURA	TG-NAJ038A-1	630	RESIDENTIAL	AMR	Functional	100%	757	0.41			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD118	11KV FDR DJB-1	TG-NAJ037A-1	990	RESIDENTIAL	AMR	Functional	100%	359	0.37			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD107	11KV FDR PRASHANT SS-BD CWL	TG-NAJ024A-1	630	RESIDENTIAL	AMR	Functional	100%	823	0.29			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD102	11KV FDR ROSHAN PURA	NF-HVD006A-2	525	RESIDENTIAL		Functional	100%	336	0.24			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD102	11KV FDR ROSHAN PURA	TG-NAJ040A-1	630	RESIDENTIAL	AMR	Functional	100%	553	0.23			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD118	11KV FDR DJB-1	NF-HVD045A-1	425	RESIDENTIAL		Functional	100%	193	0.14			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD118	11KV FDR DJB-1	TP-NAJ264A-2	400	RESIDENTIAL	AMR	Functional	100%	190	0.13			
66/11 KV GRID SUBSTATION AT GOYLA KHURD	WGOYL008	11KV FDR SHYAM ENCLAVE	NF-HVD068A-1	2875	RESIDENTIAL		Functional	100%	2232	1.19	8.59	0.13	1.54%
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD116	11KV FDR SHYAM VIHAR	CL-HVD002A-1	2225	RESIDENTIAL		Functional	100%	1878	0.91			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD108	11KV FDR GOYALA SCHOOL BD CWL	CL-HVD003A-1	2750	RESIDENTIAL		Functional	100%	2331	0.84			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD116	11KV FDR SHYAM VIHAR	CL-HVD004A-1	2075	RESIDENTIAL		Functional	100%	1355	0.84			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD116	11KV FDR SHYAM VIHAR	NF-HVD066A-1	1875	RESIDENTIAL		Functional	100%	696	0.81			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD116	11KV FDR SHYAM VIHAR	TP-CWL209A-1	990	RESIDENTIAL	AMR	Functional	100%	753	0.74			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD129	11KV FDR G-BLOCK SHYAM VIHAR	NF-HVD005A-2	1300	RESIDENTIAL		Functional	100%	531	0.54			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD118	11KV FDR DJB-1	TP-CWL445A-1	990	RESIDENTIAL		Functional	100%	381	0.44			
66/11 KV GRID SUBSTATION AT GOYLA KHURD	WGOYL008	11KV FDR SHYAM ENCLAVE	CL-HVD001A-1	850	RESIDENTIAL		Functional	100%	599	0.33			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD116	11KV FDR SHYAM VIHAR	TG-CWL288A-1	400	RESIDENTIAL	AMR	Functional	100%	419	0.30			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD108	11KV FDR GOYALA SCHOOL BD CWL	TG-CWL035A-1	630	RESIDENTIAL		Functional	100%	287	0.29			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD129	11KV FDR G-BLOCK SHYAM VIHAR	TP-CWL212A-1	400	RESIDENTIAL	AMR	Functional	100%	292	0.27			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD116	11KV FDR SHYAM VIHAR	620SYV-CWL479A-	630	RESIDENTIAL	AMR	Functional	100%	636	0.23			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD108	11KV FDR GOYALA SCHOOL BD CWL	620SYV-CWL515A-	630	RESIDENTIAL	AMR	Functional	100%	303	0.20			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD118	11KV FDR DJB-1	TP-CWL117A-1	400	RESIDENTIAL	AMR	Functional	100%	95	0.14			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD108	11KV FDR GOYALA SCHOOL BD CWL	TG-CWL498A-1	400	RESIDENTIAL	AMR	Functional	100%	182	0.12			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD129	11KV FDR G-BLOCK SHYAM VIHAR	620SYV-CWL550A-	630	MIXED		Functional	100%	0	0.11			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD118	11KV FDR DJB-1	TG-CWL389A-1	400	RESIDENTIAL	AMR	Functional	100%	170	0.10			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD108	11KV FDR GOYALA SCHOOL BD CWL	TP-CWL497A-1	400	RESIDENTIAL	AMR	Functional	100%	50	0.10			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD116	11KV FDR SHYAM VIHAR	TP-CWL479A-1	250	RESIDENTIAL	AMR	Functional	100%	30	0.09			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD108	11KV FDR GOYALA SCHOOL BD CWL	620DLG-CWL521A-	400	RESIDENTIAL	AMR	Functional	100%	120	0.05			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD108	11KV FDR GOYALA SCHOOL BD CWL	620SYV-CWL037A-	100	COMMERCIAL	AMR	Functional	100%	8	0.03			

66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD118	11kv FDR DJB-1	TP-NAJ085A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD108	11kv FDR GOYALA SCHOOL BD CWL	TG-CWL035A-2	100	RESIDENTIAL	AMR	Functional	100%	0	0.02			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD116	11kv FDR SHYAM VIHAR	TP-CWL112A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.01			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD118	11kv FDR DJB-1	TP-NAJ086A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.01			
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	NF-HVD057A-1	1775	RESIDENTIAL		Functional	100%	1326	0.70	2.72	0.24	8.07%
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	TG-NAJ075A-1	630	RESIDENTIAL	AMR	Functional	100%	734	0.47			
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	TP-NAJ072A-1	400	RESIDENTIAL	AMR	Functional	100%	542	0.40			
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	TP-NAJ100A-1	400	RESIDENTIAL	AMR	Functional	100%	349	0.39			
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	TP-NAJ371A-1	630	RESIDENTIAL	AMR	Functional	100%	364	0.30			
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	TG-NAJ183A-1	400	RESIDENTIAL	AMR	Functional	100%	300	0.22			
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	TG-NAJ050A-1	400	RESIDENTIAL	AMR	Functional	100%	256	0.19			
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	NF-HVD095A-1	425	RESIDENTIAL		Functional	100%	238	0.16			
220kv NAJAFGARH GRID	TDNG111	11kv FDR ANAJ MANDI	TP-NAJ076A-1	400	RESIDENTIAL	AMR	Functional	100%	260	0.12			
66/11kv MITRAON GRID	WMITR105	11kv FDR SAINIK ENCLAVE FEEDER	TP-NAJ370A-1	100	COMMERCIAL	AMR	Functional	100%	35	0.02			
220kv NAJAFGARH GRID	TDNG112	11kv FDR CHAWLA TANK	NF-HVD046A-1	1875	RESIDENTIAL		Functional	100%	1107	0.93	3.20	0.18	5.23%
220kv NAJAFGARH GRID	TDNG112	11kv FDR CHAWLA TANK	TP-NAJ069A-1	630	RESIDENTIAL	AMR	Functional	100%	546	0.44			
220kv NAJAFGARH GRID	TDNG112	11kv FDR CHAWLA TANK	NF-HVD037A-1	1050	RESIDENTIAL		Functional	100%	584	0.42			
220kv NAJAFGARH GRID	TDNG112	11kv FDR CHAWLA TANK	NF-HVD064A-1	850	RESIDENTIAL		Functional	100%	495	0.41			
220kv NAJAFGARH GRID	TDNG112	11kv FDR CHAWLA TANK	TP-NAJ068A-1	400	RESIDENTIAL	AMR	Functional	100%	358	0.30			
220kv NAJAFGARH GRID	TDNG112	11kv FDR CHAWLA TANK	NF-HVD063A-1	1450	RESIDENTIAL		Functional	100%	456	0.27			
220kv NAJAFGARH GRID	TDNG112	11kv FDR CHAWLA TANK	TP-NAJ235A-1	400	RESIDENTIAL	AMR	Functional	100%	238	0.23			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	620AJM-NAJ391A	400	RESIDENTIAL	AMR	Functional	100%	14	0.17			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	NF-HVD070A-1	475	RESIDENTIAL		Functional	100%	267	0.08			
220kv NAJAFGARH GRID	TDNG112	11kv FDR CHAWLA TANK	TP-NAJ275A-1	400	RESIDENTIAL	AMR	Functional	100%	169	0.07			
220kv NAJAFGARH GRID	TDNG112	11kv FDR CHAWLA TANK	TP-NAJ346A-1	100	RESIDENTIAL	AMR	Functional	100%	63	0.06			
66/11kv MITRAON GRID	WMITR104	11kv FDR CHAUHAN ENCLAVE	NF-HVD029A-1	1925	RESIDENTIAL		Functional	100%	1065	0.62	3.44	0.36	9.53%
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD126	11kv FDR KHAIRA	TP-CWL295A-1	630	RESIDENTIAL	AMR	Functional	100%	884	0.41			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD126	11kv FDR KHAIRA	TG-NAJ326A-1	990	RESIDENTIAL	AMR	Functional	100%	244	0.40			
66/11kv MITRAON GRID	WMITR104	11kv FDR CHAUHAN ENCLAVE	NF-HVD022A-1	975	RESIDENTIAL		Functional	100%	587	0.39			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD126	11kv FDR KHAIRA	TP-NAJ331A-1	400	RESIDENTIAL	AMR	Functional	100%	332	0.25			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD126	11kv FDR KHAIRA	620JTM-NAJ414A	630	MIXED	AMR	Functional	100%	184	0.25			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD126	11kv FDR KHAIRA	620JTM-NAJ397A	630	RESIDENTIAL	AMR	Functional	100%	128	0.23			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD126	11kv FDR KHAIRA	TP-CWL298A-1	400	RESIDENTIAL	AMR	Functional	100%	379	0.23			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD126	11kv FDR KHAIRA	TP-NAJ009A-1	400	RESIDENTIAL	AMR	Functional	100%	465	0.23			
66/11kv MITRAON GRID	WMITR104	11kv FDR CHAUHAN ENCLAVE	TP-NAJ329A-1	400	COMMERCIAL	AMR	Functional	100%	1	0.22			
66/11kv MITRAON GRID	WMITR104	11kv FDR CHAUHAN ENCLAVE	TP-NAJ356A-1	400	RESIDENTIAL	AMR	Functional	100%	136	0.22			
66/11kv MITRAON GRID	WMITR104	11kv FDR CHAUHAN ENCLAVE	NF-HVD067A-1	425	RESIDENTIAL		Functional	100%	121	0.14			
66/11kv MITRAON GRID	WMITR104	11kv FDR CHAUHAN ENCLAVE	NF-HVD007A-1	350	RESIDENTIAL		Functional	100%	158	0.12			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD126	11kv FDR KHAIRA	TP-CWL314A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.02			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD126	11kv FDR KHAIRA	TP-CWL300A-1	100	RESIDENTIAL	AMR	Functional	100%	33	0.00			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	620SYV-MOB001A	630	RESIDENTIAL		Functional	100%	0	0.09			
66 kv G - 4 DWARKA GRID	WG4PN121	11kv FDR CHHAWLA	TG-CWL457A-1	630	RESIDENTIAL	AMR	Functional	100%	570	0.42	1.12	0.37	25.01%
66 kv G - 4 DWARKA GRID	WG4PN121	11kv FDR CHHAWLA	TP-CWL210A-1	400	RESIDENTIAL	AMR	Functional	100%	503	0.35			

66 kv G - 4 DWARKA GRID	WG4PN121	11kv FDR CHHAWLA	NF-HVD069A-1	950	RESIDENTIAL		Functional	100%	320	0.31			
66 kv G - 4 DWARKA GRID	WG4PN121	11kv FDR CHHAWLA	TP-CWL152A-1	400	RESIDENTIAL	AMR	Functional	100%	274	0.20			
66 kv I.O.C.BIJWASAN GRID	SBWSN111	11kv FDR B.S.F CHAWLA CAMP	TP-CWL304A-1	400	RESIDENTIAL	AMR	Functional	100%	170	0.20			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL213A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	TP-NAJ241A-1	990	RESIDENTIAL	AMR	Functional	100%	724	0.57	1.63	0.02	1.17%
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	NF-HVD012A-1	1275	RESIDENTIAL		Functional	100%	747	0.32			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	TG-NAJ289A-1	400	RESIDENTIAL	AMR	Functional	100%	262	0.28			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	TG-NAJ363A-1	630	RESIDENTIAL	AMR	Functional	100%	234	0.20			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	TP-NAJ242A-1	400	RESIDENTIAL	AMR	Functional	100%	355	0.17			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	TP-NAJ345A-1	100	RESIDENTIAL	AMR	Functional	100%	62	0.04			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	TP-NAJ252A-1	100	RESIDENTIAL	AMR	Functional	100%	27	0.03			
220kv NAJAFGARH GRID	TDNG109	11kv FDR 7 PANEL BOARD	TP-NAJ161A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kv JAFFARPUR GRID	WZAFF110	11kv FDR DAULAT PUR	620DLP-CWL073A-	100	RESIDENTIAL		Functional	100%	0	0.02	0.06	0.05	43.57%
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL067A-1	100	RESIDENTIAL	AMR	Functional	100%	33	0.01			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL072A-1	100	RESIDENTIAL	AMR	Functional	100%	48	0.01			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL071A-1	100	RESIDENTIAL	AMR	Functional	100%	22	0.01			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-NAJ309A-1	100	COMMERCIAL	AMR	Functional	100%	25	0.01			
66 kv JAFFARPUR GRID	WZAFF110	11kv FDR DAULAT PUR	TP-CWL064A-1	100	RESIDENTIAL	AMR	Functional	100%	24	0.01			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL280A-1	100	RESIDENTIAL	AMR	Functional	100%	20	0.01			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-NAJ325A-1	100	RESIDENTIAL	AMR	Functional	100%	21	0.01			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL082A-1	100	RESIDENTIAL	AMR	Functional	100%	22	0.01			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL068A-1	100	COMMERCIAL	AMR	Functional	100%	34	0.01			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL369A-1	100	RESIDENTIAL		Functional	100%	30	0.00			
66 kv JAFFARPUR GRID	WZAFF110	11kv FDR DAULAT PUR	620DLP-CWL073A-	100	RESIDENTIAL	AMR	Functional	100%	38	0.00			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL069A-1	100	RESIDENTIAL		Functional	100%	14	0.00			
66 kv JAFFARPUR GRID	WZAFF129	11kv FDR GHUMANHERA MORE	TP-CWL281A-1	100	RESIDENTIAL		Functional	100%	0	0.00			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-NAJ319A-1	100	RESIDENTIAL	AMR	Functional	100%	12	0.00			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD125	11kv FDR JHATIKARA MORE	TP-CWL066A-1	100	RESIDENTIAL	AMR	Functional	100%	13	0.00			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kv FDR KANGAN HERI	TP-CWL057A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.05	0.06	0.01	13.16%
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD101	11kv FDR KANGAN HERI	TP-CWL160A-1	100	RESIDENTIAL	AMR	Functional	100%	28	0.02			
66 kv TIKRI KALAN GRID	WMUND605	11kv FDR JHARODA	TP-NAJ184A-1	400	RESIDENTIAL	AMR	Functional	100%	770	0.32	0.56	0.09	14.38%
66 kv TIKRI KALAN GRID	WMUND605	11kv FDR JHARODA	620AJM-NAJ404A-	400	RESIDENTIAL	AMR	Functional	100%	3	0.17			
66 kv TIKRI KALAN GRID	WMUND605	11kv FDR JHARODA	TP-NAJ184A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.15			
66 kv TIKRI KALAN GRID	WMUND605	11kv FDR JHARODA	620DLG-NAJ375A-	100	RESIDENTIAL	AMR	Functional	100%	17	0.02			
66 kv I.O.C.BIJWASAN GRID	SBWSN104	11kv FDR BAMNAULI	TG-CWL453A-1	630	RESIDENTIAL	AMR	Functional	100%	322	0.27	0.34	0.22	39.21%
66 kv I.O.C.BIJWASAN GRID	SBWSN104	11kv FDR BAMNAULI	TI-CWL020A-1	400	RESIDENTIAL		Functional	100%	225	0.23			
66 kv I.O.C.BIJWASAN GRID	SBWSN104	11kv FDR BAMNAULI	TP-CWL161A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.03			
66 kv I.O.C.BIJWASAN GRID	SBWSN111	11kv FDR B.S.F CHAWLA CAMP	TP-CWL286A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.02			
66 kv I.O.C.BIJWASAN GRID	SBWSN104	11kv FDR BAMNAULI	TP-CWL135A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			

66 kv I.O.C.BIJWASAN GRID	SBWSN104	11kv FDR BAMNAULI	TP-CWL386A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.00			
66 kv I.O.C.BIJWASAN GRID	SBWSN104	11kv FDR BAMNAULI	TG-CWL165A-1	400	RESIDENTIAL		Functional	100%	88	0.12	0.09	0.09	49.95%
66 kv I.O.C.BIJWASAN GRID	SBWSN104	11kv FDR BAMNAULI	TP-CWL164A-1	100	RESIDENTIAL	AMR	Functional	100%	18	0.05			
66 kv I.O.C.BIJWASAN GRID	SBWSN104	11kv FDR BAMNAULI	TG-CWL163A-1	100	RESIDENTIAL	AMR	Functional	100%	10	0.01			
66 kv JAFFARPUR GRID	WZAFF120	11kv FDR JHUL JHULI	621GMH-JFR032A-	400	RESIDENTIAL		Functional	100%	167	0.47	0.13	0.64	82.83%
66 kv JAFFARPUR GRID	WZAFF120	11kv FDR JHUL JHULI	621GMH-JFR137A-	400	RESIDENTIAL		Functional	100%	145	0.27			
66 kv JAFFARPUR GRID	WZAFF120	11kv FDR JHUL JHULI	621GMH-JFR138A-	100	MIXED		Functional	100%	0	0.03			
66/11kv MITRAON GRID	WMITR116	11kv FDR SURAKHPUR ROAD GOPAL NAGAR	TP-JFR310A-1	400	RESIDENTIAL	AMR	Functional	100%	471	0.40	1.22	0.04	3.53%
66/11kv MITRAON GRID	WMITR105	11kv FDR SAINIK ENCLAVE FEEDER	TG-JFR008A-1	400	RESIDENTIAL	AMR	Functional	100%	537	0.33			
66/11kv MITRAON GRID	WMITR116	11kv FDR SURAKHPUR ROAD GOPAL NAGAR	621CRP-HVD007A-	625	RESIDENTIAL		Functional	100%	416	0.25			
66/11kv MITRAON GRID	WMITR116	11kv FDR SURAKHPUR ROAD GOPAL NAGAR	621CRP-HVD013A-	675	RESIDENTIAL		Functional	100%	334	0.23			
66/11kv MITRAON GRID	WMITR106	11kv FDR NETAJI LANE	TP-JFR199A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.02			
66/11kv MITRAON GRID	WMITR116	11kv FDR SURAKHPUR ROAD GOPAL NAGAR	TP-JFR301A-1	100	RESIDENTIAL	AMR	Functional	100%	22	0.02			
66/11kv MITRAON GRID	WMITR105	11kv FDR SAINIK ENCLAVE FEEDER	TP-JFR302A-1	100	RESIDENTIAL	AMR	Functional	100%	9	0.01			
66/11kv MITRAON GRID	WMITR116	11kv FDR SURAKHPUR ROAD GOPAL NAGAR	621CRP-JFR626A-	630	MIXED		Functional	100%	0	0.03	1.17	0.28	19.53%
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	621MTR-JFR071A-	630	RESIDENTIAL	AMR	Functional	100%	841	0.48			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	621MTR-HVD012A-	900	RESIDENTIAL		Functional	100%	417	0.41			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	621MTR-JFR181A-	630	RESIDENTIAL	AMR	Functional	100%	317	0.24			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	TP-JFR550A-1	400	MIXED	AMR	Functional	100%	3	0.20			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	621MTR-JFR184A-	100	RESIDENTIAL		Functional	100%	8	0.02			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	621MTR-JFR182A-	100	RESIDENTIAL	AMR	Functional	100%	11	0.02			
66 kv JAFFARPUR GRID	WZAFF101	11kv FDR R.T.R.M. HOSPITAL	621MTR-JFR595A-	100	RESIDENTIAL		Functional	100%	1	0.02			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	621MTR-JFR183A-	100	RESIDENTIAL	AMR	Functional	100%	16	0.01			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	621MTR-JFR432A-	100	RESIDENTIAL		Functional	100%	1	0.01			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	621MTR-JFR197A-	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			
66/11kv MITRAON GRID	WMITR105	11kv FDR SAINIK ENCLAVE FEEDER	TG-JFR007A-1	400	RESIDENTIAL	AMR	Functional	100%	634	0.46	1.27	0.02	1.40%
66/11kv MITRAON GRID	WMITR105	11kv FDR SAINIK ENCLAVE FEEDER	TP-JFR026A-1	990	RESIDENTIAL	AMR	Functional	100%	872	0.45			
66/11kv MITRAON GRID	WMITR105	11kv FDR SAINIK ENCLAVE FEEDER	621CRP-JFR025A-	400	RESIDENTIAL	AMR	Functional	100%	509	0.37			
66 kv JAFFARPUR GRID	WZAFF128	11kv FDR RAWTA	TP-JFR029A-1	630	RESIDENTIAL		Functional	100%	310	0.38	0.60	0.54	47.22%
66 kv JAFFARPUR GRID	WZAFF128	11kv FDR RAWTA	621GMH-JFR030A-	630	RESIDENTIAL		Functional	100%	591	0.34			
66 kv JAFFARPUR GRID	WZAFF128	11kv FDR RAWTA	TP-JFR517A-1	400	RESIDENTIAL		Functional	100%	130	0.32			
66 kv JAFFARPUR GRID	WZAFF128	11kv FDR RAWTA	TP-JFR448A-1	100	RESIDENTIAL		Functional	100%	4	0.05			
66 kv JAFFARPUR GRID	WZAFF128	11kv FDR RAWTA	621GMH-JFR140A-	100	RESIDENTIAL		Functional	100%	10	0.02			
66 kv JAFFARPUR GRID	WZAFF128	11kv FDR RAWTA	621GMH-JFR136A-	100	RESIDENTIAL		Functional	100%	9	0.02			
66 kv JAFFARPUR GRID	WZAFF128	11kv FDR RAWTA	621GMH-JFR148A-	100	RESIDENTIAL		Functional	100%	9	0.01			
66 kv JAFFARPUR GRID	WZAFF128	11kv FDR RAWTA	621GMH-JFR133A-	100	RESIDENTIAL		Functional	100%	13	0.00			
66 kv JAFFARPUR GRID	WZAFF128	11kv FDR RAWTA	TP-JFR446A-1	100	MIXED		Functional	100%	7	0.00			
66 kv JAFFARPUR GRID	WZAFF106	11kv FDR MALIK PUR	621UJW-JFR006A-	400	RESIDENTIAL		Functional	100%	198	0.47	0.60	1.41	70.36%
66 kv JAFFARPUR GRID	WZAFF106	11kv FDR MALIK PUR	TP-JFR576A-1	630	RESIDENTIAL		Functional	100%	159	0.39			
66 kv JAFFARPUR GRID	WZAFF105	11kv FDR JAFFAR PUR	621UJW-JFR039A-	400	RESIDENTIAL		Functional	100%	379	0.36			
66 kv JAFFARPUR GRID	WZAFF105	11kv FDR JAFFAR PUR	621UJW-JFR621A-	630	MIXED	AMR	Functional	100%	0	0.33			
66 kv JAFFARPUR GRID	WZAFF106	11kv FDR MALIK PUR	621UJW-JFR040A-	400	RESIDENTIAL		Functional	100%	206	0.29			
66 kv JAFFARPUR GRID	WZAFF109	11kv FDR DHANSA	621UJW-JFR120A-	100	RESIDENTIAL		Functional	100%	4	0.07			
66 kv JAFFARPUR GRID	WZAFF106	11kv FDR MALIK PUR	621UJW-JFR157A-	100	RESIDENTIAL		Functional	100%	13	0.07			
66 kv JAFFARPUR GRID	WZAFF106	11kv FDR MALIK PUR	621UJW-JFR162A-	100	RESIDENTIAL	AMR	Functional	100%	11	0.02			
66 kv JAFFARPUR GRID	WZAFF130	11kv FDR SUREHRA VILLAGE	621MTR-JFR053A-	400	RESIDENTIAL	AMR	Functional	100%	399	0.34	0.82	0.14	14.83%
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	621MTR-JFR060A-	630	RESIDENTIAL		Functional	100%	777	0.31			
66 kv JAFFARPUR GRID	WZAFF130	11kv FDR SUREHRA VILLAGE	621MTR-JFR052A-	400	RESIDENTIAL	AMR	Functional	100%	215	0.17			

66 KV JAFFARPUR GRID	WZAFF130	11KV FDR SUREHRA VILLAGE	621MTR-JFR187A-	100	RESIDENTIAL	AMR	Functional	100%	88	0.05			
66 KV JAFFARPUR GRID	WZAFF107	11KV FDR KHERA DABAR	TP-JFR220A-1	100	RESIDENTIAL		Functional	100%	23	0.03			
66 KV JAFFARPUR GRID	WZAFF107	11KV FDR KHERA DABAR	621MTR-JFR186A-	100	RESIDENTIAL		Functional	100%	9	0.02			
66 KV JAFFARPUR GRID	WZAFF130	11KV FDR SUREHRA VILLAGE	621MTR-JFR188A-	100	RESIDENTIAL	AMR	Functional	100%	13	0.02			
66 KV JAFFARPUR GRID	WZAFF102	11KV FDR MITRAON	621MTR-JFR191A-	100	RESIDENTIAL	AMR	Functional	100%	8	0.01			
66/11KV MITRAON GRID	WMITR107	11KV FDR NEW MITRAON	621MTR-JFR189A-	100	RESIDENTIAL	AMR	Functional	100%	6	0.01			
66 KV JAFFARPUR GRID	WZAFF107	11KV FDR KHERA DABAR	621MTR-JFR192A-	100	RESIDENTIAL		Functional	100%	4	0.00			
66/11KV MITRAON GRID	WMITR107	11KV FDR NEW MITRAON	621MTR-JFR190A-	100	RESIDENTIAL	AMR	Functional	100%	11	0.00			
66 KV JAFFARPUR GRID	WZAFF105	11KV FDR JAFFAR PUR	TP-JFR334A-1	630	RESIDENTIAL		Functional	100%	353	0.37	0.55	0.15	21.53%
66 KV JAFFARPUR GRID	WZAFF105	11KV FDR JAFFAR PUR	TP-JFR035A-1	400	RESIDENTIAL		Functional	100%	369	0.31			
66 KV JAFFARPUR GRID	WZAFF105	11KV FDR JAFFAR PUR	621UJW-JFR177A-	100	RESIDENTIAL		Functional	100%	10	0.01			
66 KV JAFFARPUR GRID	WZAFF128	11KV FDR RAWTA	621UJW-JFR176A-	100	RESIDENTIAL		Functional	100%	15	0.01			
66 KV JAFFARPUR GRID	WZAFF128	11KV FDR RAWTA	621UJW-JFR175A-	100	RESIDENTIAL		Functional	100%	14	0.00			
66 KV JAFFARPUR GRID	WZAFF128	11KV FDR RAWTA	TP-JFR174A-1	100	RESIDENTIAL		Functional	100%	3	0.00			
66 KV JAFFARPUR GRID	WZAFF105	11KV FDR JAFFAR PUR	621UJW-JFR617A-	400	MIXED		Functional	100%	0	0.00			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	TP-JFR349A-1	630	RESIDENTIAL		Functional	100%	351	0.46	1.31	1.45	52.55%
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	TP-JFR559A-1	400	RESIDENTIAL		Functional	100%	194	0.39			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	621GMH-JFR027A-	400	RESIDENTIAL		Functional	100%	302	0.37			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	TP-JFR333A-1	400	RESIDENTIAL		Functional	100%	173	0.33			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	621GMH-JFR178A-	400	RESIDENTIAL		Functional	100%	193	0.27			
66 KV JAFFARPUR GRID	WZAFF128	11KV FDR RAWTA	621GMH-JFR614A-	630	MIXED		Functional	100%	0	0.26			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	TP-JFR295A-1	400	RESIDENTIAL		Functional	100%	336	0.21			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	621GMH-JFR600A-	630	RESIDENTIAL		Functional	100%	2	0.10			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	TG-JFR473A-1	400	COMMERCIAL		Functional	100%	32	0.08			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	TP-JFR351A-1	100	RESIDENTIAL		Functional	100%	1	0.06			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	TP-JFR223A-1	100	RESIDENTIAL		Functional	100%	13	0.04			
66 KV JAFFARPUR GRID	WZAFF128	11KV FDR RAWTA	621GMH-JFR609A-	100	RESIDENTIAL		Functional	100%	9	0.04			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	TP-JFR450A-1	250	MIXED		Functional	100%	2	0.03			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	621GMH-JFR147A-	400	RESIDENTIAL		Functional	100%	43	0.03			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	TP-JFR141A-1	100	RESIDENTIAL		Functional	100%	8	0.02			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	TP-JFR255A-1	250	RESIDENTIAL		Functional	100%	2	0.02			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	621GMH-JFR145A-	100	RESIDENTIAL		Functional	100%	27	0.01			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	621GMH-JFR179A-	100	RESIDENTIAL		Functional	100%	6	0.01			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	TP-JFR222A-1	100	RESIDENTIAL		Functional	100%	14	0.01			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	621GMH-JFR146A-	100	RESIDENTIAL		Functional	100%	14	0.01			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	TP-JFR440A-1	100	RESIDENTIAL		Functional	100%	18	0.00			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	TP-JFR339A-1	100	RESIDENTIAL		Functional	100%	4	0.00			
66 KV JAFFARPUR GRID	WZAFF129	11KV FDR GHUMANHERA MORE	621GMH-JFR632A-	100	MIXED	AMR	Functional	100%	0	0.00			
66 KV JAFFARPUR GRID	WZAFF107	11KV FDR KHERA DABAR	621MTR-JFR185A-	100	RESIDENTIAL		Functional	100%	0	0.00	0.25	0.24	49.26%
66 KV JAFFARPUR GRID	WZAFF105	11KV FDR JAFFAR PUR	621UJW-JFR629A-	100	MIXED		Functional	100%	0	0.00			
66 KV JAFFARPUR GRID	WZAFF107	11KV FDR KHERA DABAR	TP-JFR282A-1	630	RESIDENTIAL		Functional	100%	347	0.47			
66 KV JAFFARPUR GRID	WZAFF114	11KV FDR PANDWALA	621UJW-JFR015A-	100	RESIDENTIAL		Functional	100%	12	0.01			
66 KV JAFFARPUR GRID	WZAFF106	11KV FDR MALIK PUR	TP-JFR037A-1	630	RESIDENTIAL	AMR	Functional	100%	396	0.35	0.57	0.71	55.32%
66 KV JAFFARPUR GRID	WZAFF106	11KV FDR MALIK PUR	TP-JFR036A-1	630	RESIDENTIAL		Functional	100%	384	0.31			
66 KV JAFFARPUR GRID	WZAFF106	11KV FDR MALIK PUR	621UJW-JFR620A-	630	MIXED	AMR	Functional	100%	0	0.29			
66 KV JAFFARPUR GRID	WZAFF106	11KV FDR MALIK PUR	TP-JFR309A-1	400	RESIDENTIAL	AMR	Functional	100%	267	0.27			
66 KV JAFFARPUR GRID	WZAFF106	11KV FDR MALIK PUR	TP-JFR352A-1	100	RESIDENTIAL	AMR	Functional	100%	18	0.03			
66 KV JAFFARPUR GRID	WZAFF105	11KV FDR JAFFAR PUR	621UJW-JFR154A-	100	RESIDENTIAL		Functional	100%	3	0.03			
66 KV JAFFARPUR GRID	WZAFF106	11KV FDR MALIK PUR	621UJW-JFR005A-	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 KV JAFFARPUR GRID	WZAFF105	11KV FDR JAFFAR PUR	621UJW-JFR171A-	100	RESIDENTIAL		Functional	100%	9	0.01			

66 KV JAFFARPUR GRID	WZAFF105	11KV FDR JAFFAR PUR	TP-JFR227A-1	100	MIXED		Functional	100%	9	0.00			
66 KV JAFFARPUR GRID	WZAFF120	11KV FDR JHUL JHULI	621UJW-JFR173A-	100	RESIDENTIAL		Functional	100%	13	0.00			
66/11KV MITRAON GRID	WMITR107	11KV FDR NEW MITRAON	621MTR-JFR061A-	630	RESIDENTIAL	AMR	Functional	100%	281	0.57	2.04	2.56	55.69%
66/11KV MITRAON GRID	WMITR107	11KV FDR NEW MITRAON	621MTR-JFR044A-	630	RESIDENTIAL	AMR	Functional	100%	572	0.57			
66/11KV MITRAON GRID	WMITR107	11KV FDR NEW MITRAON	621MTR-JFR043A-	630	RESIDENTIAL	AMR	Functional	100%	436	0.48			
66/11KV MITRAON GRID	WMITR107	11KV FDR NEW MITRAON	TG-JFR291A-1	630	RESIDENTIAL	AMR	Functional	100%	447	0.45			
66/11KV MITRAON GRID	WMITR107	11KV FDR NEW MITRAON	TG-JFR284A-1	630	RESIDENTIAL	AMR	Functional	100%	55	0.42			
66 KV JAFFARPUR GRID	WZAFF125	11KV FDR RAIL MASTER	TI-JFR323A-1	400	RESIDENTIAL	AMR	Functional	100%	238	0.36			
66 KV JAFFARPUR GRID	WZAFF107	11KV FDR KHERA DABAR	621MTR-JFR618A-	630	MIXED		Functional	100%	0	0.34			
66 KV JAFFARPUR GRID	WZAFF107	11KV FDR KHERA DABAR	621MTR-JFR618A-	630	MIXED		Functional	100%	0	0.34			
66/11KV MITRAON GRID	WMITR103	11KV FDR GANGOTRI	621MTR-JFR598A-	630	RESIDENTIAL	AMR	Functional	100%	1	0.28			
66/11KV MITRAON GRID	WMITR107	11KV FDR NEW MITRAON	TP-JFR207A-1	400	RESIDENTIAL		Functional	100%	255	0.28			
66 KV JAFFARPUR GRID	WZAFF125	11KV FDR RAIL MASTER	621CRP-JFR603A-	250	COMMERCIAL	AMR	Functional	100%	0	0.16			
66 KV JAFFARPUR GRID	WZAFF130	11KV FDR SUREHRA VILLAGE	621MTR-JFR605A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.16			
66 KV JAFFARPUR GRID	WZAFF102	11KV FDR MITRAON	621MTR-JFR206A-	100	RESIDENTIAL	AMR	Functional	100%	19	0.04			
66/11KV MITRAON GRID	WMITR102	11KV STR 400KVA STATION TRANSFORMER	621MTR-WTC131A	400	MIXED	AMR	Functional	100%	1	0.04			
66/11KV MITRAON GRID	WMITR107	11KV FDR NEW MITRAON	621MTR-JFR205A-	100	RESIDENTIAL	AMR	Functional	100%	18	0.04			
66/11KV MITRAON GRID	WMITR107	11KV FDR NEW MITRAON	TP-JFR268A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02			
66 KV JAFFARPUR GRID	WZAFF107	11KV FDR KHERA DABAR	TP-JFR216A-1	100	INDUSTRIAL	AMR	Functional	100%	13	0.02			
66 KV JAFFARPUR GRID	WZAFF125	11KV FDR RAIL MASTER	621MTR-JFR131A-	100	COMMERCIAL	AMR	Functional	100%	1	0.02			
66/11KV MITRAON GRID	WMITR107	11KV FDR NEW MITRAON	621MDL-JFR196A-	100	RESIDENTIAL	AMR	Functional	100%	6	0.01			
66 KV JAFFARPUR GRID	WZAFF115	11KV FDR NEW C. R. P. F.	TP-JFR509A-1	100	RESIDENTIAL		Functional	100%	0	0.01			
66 KV JAFFARPUR GRID	WZAFF125	11KV FDR RAIL MASTER	621MTR-JFR602A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.01			
66/11KV MITRAON GRID	WMITR107	11KV FDR NEW MITRAON	TP-JFR208A-1	100	RESIDENTIAL		Functional	100%	11	0.00			
66 KV JAFFARPUR GRID	WZAFF105	11KV FDR JAFFAR PUR	621UJW-JFR059A-	990	RESIDENTIAL		Functional	100%	796	0.67	1.26	1.15	47.65%
66 KV JAFFARPUR GRID	WZAFF110	11KV FDR DAULAT PUR	621UJW-JFR038A-	630	RESIDENTIAL	AMR	Functional	100%	341	0.46			
66 KV JAFFARPUR GRID	WZAFF105	11KV FDR JAFFAR PUR	621UJW-JFR150A-	630	RESIDENTIAL		Functional	100%	410	0.45			
66 KV JAFFARPUR GRID	WZAFF105	11KV FDR JAFFAR PUR	621UJW-JFR592A-	630	RESIDENTIAL		Functional	100%	247	0.40			
66 KV JAFFARPUR GRID	WZAFF101	11KV FDR R. T. R. M. HOSPITAL	TP-JFR575A-1	400	RESIDENTIAL		Functional	100%	24	0.36			
66 KV JAFFARPUR GRID	WZAFF101	11KV FDR R. T. R. M. HOSPITAL	621UJW-JFR591A-	100	RESIDENTIAL		Functional	100%	6	0.04			
66 KV JAFFARPUR GRID	WZAFF101	11KV FDR R. T. R. M. HOSPITAL	TP-JFR155A-1	100	RESIDENTIAL		Functional	100%	9	0.01			
66 KV JAFFARPUR GRID	WZAFF101	11KV FDR R. T. R. M. HOSPITAL	621UJW-JFR153A-	100	RESIDENTIAL		Functional	100%	10	0.00			
66 KV JAFFARPUR GRID	WZAFF105	11KV FDR JAFFAR PUR	TP-JFR226A-1	100	RESIDENTIAL		Functional	100%	2	0.00			
66 KV JAFFARPUR GRID	WZAFF105	11KV FDR JAFFAR PUR	621UJW-JFR601A-	100	RESIDENTIAL		Functional	100%	10	0.00			
66 KV JAFFARPUR GRID	WZAFF105	11KV FDR JAFFAR PUR	621UJW-JFR156A-	100	RESIDENTIAL		Functional	100%	10	0.00			
66 KV JAFFARPUR GRID	WZAFF101	11KV FDR R. T. R. M. HOSPITAL	621UJW-JFR149A-	100	RESIDENTIAL		Functional	100%	6	0.00			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	TG-JFR556A-1	630	RESIDENTIAL	AMR	Functional	100%	292	0.53	1.46	1.47	50.15%
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	TG-JFR063A-1	630	RESIDENTIAL	AMR	Functional	100%	476	0.51			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR062A-	630	RESIDENTIAL		Functional	100%	431	0.44			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR089A-	400	RESIDENTIAL		Functional	100%	258	0.41			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	TP-JFR557A-1	400	RESIDENTIAL		Functional	100%	226	0.38			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR046A-	400	RESIDENTIAL	AMR	Functional	100%	488	0.29			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR077A-	100	RESIDENTIAL		Functional	100%	9	0.05			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR075A-	100	RESIDENTIAL		Functional	100%	53	0.05			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR085A-	100	RESIDENTIAL	AMR	Functional	100%	34	0.03			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR081A-	100	RESIDENTIAL		Functional	100%	16	0.03			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR074A-	100	RESIDENTIAL	AMR	Functional	100%	19	0.03			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR016A-	100	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR627A-	100	MIXED		Functional	100%	0	0.02			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR084A-	100	RESIDENTIAL	AMR	Functional	100%	18	0.02			

66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	TP-JFR344A-1	100	RESIDENTIAL		Functional	100%	5	0.01			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR046A-	100	RESIDENTIAL	AMR	Functional	100%	25	0.01			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	TP-JFR224A-1	100	RESIDENTIAL	AMR	Functional	100%	13	0.01			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR087A-	100	RESIDENTIAL		Functional	100%	8	0.01			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR076A-	100	RESIDENTIAL		Functional	100%	10	0.01			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR072A-	100	RESIDENTIAL		Functional	100%	14	0.01			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR599A-	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR083A-	100	RESIDENTIAL	AMR	Functional	100%	6	0.01			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	TP-JFR539A-1	100	RESIDENTIAL		Functional	100%	20	0.00			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	TP-JFR512A-1	100	RESIDENTIAL		Functional	100%	12	0.00			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	TP-JFR262A-1	100	RESIDENTIAL		Functional	100%	14	0.00			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR085A-	100	RESIDENTIAL	AMR	Functional	100%	25	0.00			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR073A-	100	RESIDENTIAL		Functional	100%	10	0.00			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	TP-JFR533A-1	100	RESIDENTIAL		Functional	100%	10	0.00			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR082A-	100	RESIDENTIAL		Functional	100%	7	0.00			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR079A-	100	RESIDENTIAL	AMR	Functional	100%	6	0.00			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR088A-	100	RESIDENTIAL	AMR	Functional	100%	11	0.00			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR628A-	100	MIXED		Functional	100%	0	0.00			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	621DNS-JFR090A-	630	RESIDENTIAL		Functional	100%	446	0.52	0.90	1.75	65.99%
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	621DNS-JFR047A-	630	RESIDENTIAL	AMR	Functional	100%	293	0.51			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	621DNS-JFR048A-	630	RESIDENTIAL	AMR	Functional	100%	240	0.41			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	TG-JFR064A-1	630	RESIDENTIAL	AMR	Functional	100%	401	0.39			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	621DNS-JFR613A-	630	MIXED		Functional	100%	0	0.39			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	621DNS-JFR607A-	630	RESIDENTIAL	AMR	Functional	100%	203	0.24			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	621DNS-JFR096A-	100	RESIDENTIAL		Functional	100%	13	0.06			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	621DNS-JFR092A-	100	RESIDENTIAL		Functional	100%	6	0.04			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	TP-JFR355A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	TP-JFR232A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.03			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	TP-JFR091A-1	100	RESIDENTIAL	AMR	Functional	100%	18	0.01			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	621DNS-JFR095A-	100	RESIDENTIAL	AMR	Functional	100%	7	0.01			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR094A-	100	RESIDENTIAL		Functional	100%	11	0.00			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	621DNS-JFR097A-	100	RESIDENTIAL		Functional	100%	17	0.00			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	621DNS-JFR615A-	100	MIXED	AMR	Functional	100%	0	0.00			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	TP-JFR098A-1	100	RESIDENTIAL	AMR	Functional	100%	15	0.00			
66 KV JAFFARPUR GRID	WZAFF120	11KV FDR JHUL JHULI	621GMH-JFR019A-	400	RESIDENTIAL		Functional	100%	226	0.21	0.41	0.19	32.00%
66 KV JAFFARPUR GRID	WZAFF120	11KV FDR JHUL JHULI	621MTR-JFR128A-	400	RESIDENTIAL		Functional	100%	181	0.21			
66 KV JAFFARPUR GRID	WZAFF120	11KV FDR JHUL JHULI	TP-JFR034A-1	400	RESIDENTIAL		Functional	100%	194	0.18			
66 KV JAFFARPUR GRID	WZAFF120	11KV FDR JHUL JHULI	TP-JFR382A-1	100	RESIDENTIAL		Functional	100%	20	0.01			
66/11KV MITRAON GRID	WMITR134	11KV FDR KAIR VILLAGE	621MDL-JFR051A-	630	RESIDENTIAL	AMR	Functional	100%	424	0.37	0.80	0.62	43.82%
66/11KV MITRAON GRID	WMITR134	11KV FDR KAIR VILLAGE	TG-JFR582A-1	630	RESIDENTIAL		Functional	100%	317	0.35			
66/11KV MITRAON GRID	WMITR134	11KV FDR KAIR VILLAGE	621MDL-JFR195A-	400	RESIDENTIAL	AMR	Functional	100%	181	0.31			
66/11KV MITRAON GRID	WMITR134	11KV FDR KAIR VILLAGE	621MDL-JFR065A-	630	RESIDENTIAL		Functional	100%	623	0.24			
66/11KV MITRAON GRID	WMITR134	11KV FDR KAIR VILLAGE	TP-JFR235A-1	400	RESIDENTIAL	AMR	Functional	100%	8	0.08			
66/11KV MITRAON GRID	WMITR134	11KV FDR KAIR VILLAGE	621MDL-JFR194A-	100	RESIDENTIAL		Functional	100%	32	0.04			
66/11KV MITRAON GRID	WMITR134	11KV FDR KAIR VILLAGE	TP-JFR024A-1	100	RESIDENTIAL		Functional	100%	5	0.01			
66/11KV MITRAON GRID	WMITR134	11KV FDR KAIR VILLAGE	TP-JFR482A-1	100	RESIDENTIAL		Functional	100%	14	0.01			
66 KV JAFFARPUR GRID	WZAFF104	11KV FDR DABAR ENCLAVE	621MDL-JFR608A-	100	RESIDENTIAL		Functional	100%	13	0.00			
66/11KV MITRAON GRID	WMITR134	11KV FDR KAIR VILLAGE	TP-JFR472A-1	100	MIXED		Functional	100%	0	0.00			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	621DNS-JFR045A-	400	RESIDENTIAL	AMR	Functional	100%	282	0.26	0.36	0.07	16.62%
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	621DNS-JFR594A-	630	RESIDENTIAL	AMR	Functional	100%	229	0.15			

66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	TP-JFR303A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.01			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR123A-	100	RESIDENTIAL	AMR	Functional	100%	10	0.01			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	621DNS-JFR099A-	100	RESIDENTIAL	AMR	Functional	100%	15	0.00			
66 KV JAFFARPUR GRID	WZAFF109	11KV FDR DHANSA	621DNS-JFR494A-	100	RESIDENTIAL	AMR	Functional	100%	2	0.00			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	621MDL-JFR606A-	100	RESIDENTIAL		Functional	100%	0	0.06	1.68	0.04	2.50%
66 KV JAFFARPUR GRID	WZAFF130	11KV FDR SUREHRA VILLAGE	621MDL-JFR619A-	400	MIXED	AMR	Functional	100%	0	0.01			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	621MDL-JFR402A-	100	RESIDENTIAL		Functional	100%	0	0.00			
66/11KV MITRAON GRID	WMITR105	11KV FDR SAINIK ENCLAVE FEEDER	JF-HVD022A-2	2550	RESIDENTIAL		Functional	100%	1280	0.69			
66/11KV MITRAON GRID	WMITR105	11KV FDR SAINIK ENCLAVE FEEDER	TP-JFR277A-1	630	RESIDENTIAL		Functional	100%	565	0.42			
66/11KV MITRAON GRID	WMITR105	11KV FDR SAINIK ENCLAVE FEEDER	TP-JFR279A-1	400	RESIDENTIAL	AMR	Functional	100%	439	0.33			
66/11KV MITRAON GRID	WMITR106	11KV FDR NETAJI LANE	621CRP-JFR168A-	400	RESIDENTIAL	AMR	Functional	100%	241	0.13			
66/11KV MITRAON GRID	WMITR105	11KV FDR SAINIK ENCLAVE FEEDER	TG-JFR023A-2	100	RESIDENTIAL	AMR	Functional	100%	140	0.07			
66 KV JAFFARPUR GRID	WZAFF120	11KV FDR JHUL JHULI	621GMH-JFR033A-	630	RESIDENTIAL		Functional	100%	353	0.31	0.27	0.26	49.85%
66 KV JAFFARPUR GRID	WZAFF120	11KV FDR JHUL JHULI	TG-JFR553A-1	400	RESIDENTIAL		Functional	100%	113	0.18			
66 KV JAFFARPUR GRID	WZAFF120	11KV FDR JHUL JHULI	621GMH-JFR124A-	100	AGRICULTURE		Functional	100%	7	0.02			
66 KV JAFFARPUR GRID	WZAFF120	11KV FDR JHUL JHULI	621GMH-JFR127A-	100	RESIDENTIAL		Functional	100%	1	0.01			
66 KV JAFFARPUR GRID	WZAFF120	11KV FDR JHUL JHULI	621GMH-JFR126A-	100	RESIDENTIAL		Functional	100%	25	0.01			
66/11KV MITRAON GRID	WMITR110	11KV FDR NEW THANA	621MTR-HVD016A	1800	RESIDENTIAL		Functional	100%	1268	0.83	4.29	0.07	1.54%
66/11KV MITRAON GRID	WMITR110	11KV FDR NEW THANA	JF-HVD005A-3	1050	RESIDENTIAL		Functional	100%	973	0.78			
66/11KV MITRAON GRID	WMITR110	11KV FDR NEW THANA	621MTR-HVD003A	2300	RESIDENTIAL		Functional	100%	1238	0.63			
66/11KV MITRAON GRID	WMITR110	11KV FDR NEW THANA	621MTR-HVD003A	2300	RESIDENTIAL		Functional	100%	1067	0.50			
66 KV JAFFARPUR GRID	WZAFF125	11KV FDR RAIL MASTER	621MTR-HVD018A	1550	RESIDENTIAL		Functional	100%	664	0.40			
66/11KV MITRAON GRID	WMITR110	11KV FDR NEW THANA	TG-JFR274A-1	400	RESIDENTIAL		Functional	100%	233	0.29			
66/11KV MITRAON GRID	WMITR110	11KV FDR NEW THANA	621MTR-HVD020A	625	RESIDENTIAL		Functional	100%	341	0.22			
66/11KV MITRAON GRID	WMITR110	11KV FDR NEW THANA	TG-JFR285A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.22			
66/11KV MITRAON GRID	WMITR110	11KV FDR NEW THANA	TP-JFR285A-1	400	RESIDENTIAL	AMR	Functional	100%	589	0.16			
66/11KV MITRAON GRID	WMITR110	11KV FDR NEW THANA	TP-JFR538A-1	100	RESIDENTIAL	AMR	Functional	100%	116	0.13			
66/11KV MITRAON GRID	WMITR110	11KV FDR NEW THANA	621MTR-HVD017A	150	RESIDENTIAL		Functional	100%	64	0.10			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD126	11KV FDR KHAIRA	TG-JFR350A-1	100	RESIDENTIAL	AMR	Functional	100%	26	0.08			
66/11KV MITRAON GRID	WMITR110	11KV FDR NEW THANA	TP-JFR218A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66/11KV MITRAON GRID	WMITR109	11KV FDR P-BLOCK GOPAL NAGAR FEEDER	621CRP-JFR165A-	100	RESIDENTIAL		Functional	100%	1	0.01			
66/11KV MITRAON GRID	WMITR109	11KV FDR P-BLOCK GOPAL NAGAR FEEDER	621CRP-JFR003A-	630	RESIDENTIAL	AMR	Functional	100%	484	0.51	5.20	0.24	4.40%
66/11KV MITRAON GRID	WMITR109	11KV FDR P-BLOCK GOPAL NAGAR FEEDER	621CRP-JFR020A-	400	RESIDENTIAL	AMR	Functional	100%	599	0.47			
66/11KV MITRAON GRID	WMITR109	11KV FDR P-BLOCK GOPAL NAGAR FEEDER	621CRP-HVD011A-	2750	RESIDENTIAL		Functional	100%	1462	0.45			
66/11KV MITRAON GRID	WMITR116	11KV FDR SURAKHPUR ROAD GOPAL NAGAR	TP-JFR278A-1	630	RESIDENTIAL	AMR	Functional	100%	735	0.41			
66/11KV MITRAON GRID	WMITR103	11KV FDR GANGOTRI	TP-JFR022A-1	400	RESIDENTIAL	AMR	Functional	100%	341	0.34			
66/11KV MITRAON GRID	WMITR116	11KV FDR SURAKHPUR ROAD GOPAL NAGAR	TP-JFR311A-1	630	RESIDENTIAL	AMR	Functional	100%	341	0.33			
66/11KV MITRAON GRID	WMITR103	11KV FDR GANGOTRI	TP-JFR563A-1	400	RESIDENTIAL	AMR	Functional	100%	344	0.32			
66/11KV MITRAON GRID	WMITR109	11KV FDR P-BLOCK GOPAL NAGAR FEEDER	TP-JFR562A-1	400	RESIDENTIAL		Functional	100%	371	0.30			
66/11KV MITRAON GRID	WMITR116	11KV FDR SURAKHPUR ROAD GOPAL NAGAR	TP-JFR548A-1	400	RESIDENTIAL	AMR	Functional	100%	414	0.26			
66/11KV MITRAON GRID	WMITR103	11KV FDR GANGOTRI	621CRP-JFR021A-	400	RESIDENTIAL	AMR	Functional	100%	218	0.24			
66/11KV MITRAON GRID	WMITR109	11KV FDR P-BLOCK GOPAL NAGAR FEEDER	621CRP-HVD004A-	1000	RESIDENTIAL		Functional	100%	431	0.24			
66/11KV MITRAON GRID	WMITR109	11KV FDR P-BLOCK GOPAL NAGAR FEEDER	621CRP-JFR004A-	400	RESIDENTIAL	AMR	Functional	100%	376	0.23			
66/11KV MITRAON GRID	WMITR109	11KV FDR P-BLOCK GOPAL NAGAR FEEDER	621CRP-JFR003A-	400	RESIDENTIAL	AMR	Functional	100%	740	0.23			
66/11KV MITRAON GRID	WMITR109	11KV FDR P-BLOCK GOPAL NAGAR FEEDER	TP-JFR280A-1	400	RESIDENTIAL	AMR	Functional	100%	364	0.22			
66/11KV MITRAON GRID	WMITR103	11KV FDR GANGOTRI	621CRP-HVD001A-	1500	RESIDENTIAL		Functional	100%	763	0.21			
66/11KV MITRAON GRID	WMITR113	11KV FDR ARADHNA ENCLAVE	621CRP-HVD009A-	725	RESIDENTIAL		Functional	100%	204	0.18			
66/11KV MITRAON GRID	WMITR103	11KV FDR GANGOTRI	621CRP-JFR058A-	400	RESIDENTIAL		Functional	100%	223	0.15			
66/11KV MITRAON GRID	WMITR103	11KV FDR GANGOTRI	TP-JFR313A-1	250	RESIDENTIAL	AMR	Functional	100%	1	0.12			
66/11KV MITRAON GRID	WMITR103	11KV FDR GANGOTRI	TP-JFR347A-1	250	RESIDENTIAL	AMR	Functional	100%	1	0.11			

66/11kv MITRAON GRID	WMITR103	11kv FDR GANGOTRI	TP-JFR312A-1	400	RESIDENTIAL	AMR	Functional	100%	55	0.10			
66/11kv MITRAON GRID	WMITR103	11kv FDR GANGOTRI	621CRP-JFR200A-	100	RESIDENTIAL	AMR	Functional	100%	7	0.02			
66 kv JAFFARPUR GRID	WZAFF103	11kv FDR ISSAPUR	621DNS-JFR049A-	400	RESIDENTIAL		Functional	100%	237	0.31	0.17	0.23	56.96%
66 kv JAFFARPUR GRID	WZAFF103	11kv FDR ISSAPUR	TP-JFR505A-1	100	RESIDENTIAL	AMR	Functional	100%	13	0.03			
66 kv JAFFARPUR GRID	WZAFF103	11kv FDR ISSAPUR	621DNS-JFR119A-	100	RESIDENTIAL	AMR	Functional	100%	7	0.02			
66 kv JAFFARPUR GRID	WZAFF103	11kv FDR ISSAPUR	TP-JFR443A-2	100	RESIDENTIAL		Functional	100%	2	0.02			
66 kv JAFFARPUR GRID	WZAFF103	11kv FDR ISSAPUR	621DNS-JFR101A-	100	RESIDENTIAL	AMR	Functional	100%	9	0.01			
66 kv JAFFARPUR GRID	WZAFF109	11kv FDR DHANSA	621DNS-JFR122A-	100	RESIDENTIAL		Functional	100%	2	0.01			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	TP-JFR551A-1	400	MIXED		Functional	100%	1	0.19	0.45	0.12	21.46%
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	621MTR-JFR057A-	630	RESIDENTIAL	AMR	Functional	100%	450	0.17			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	TP-JFR211A-1	100	RESIDENTIAL		Functional	100%	137	0.09			
66 kv JAFFARPUR GRID	WZAFF114	11kv FDR PANDWALA	TP-JFR477A-1	100	MIXED		Functional	100%	4	0.03			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	TP-JFR210A-1	100	RESIDENTIAL	AMR	Functional	100%	6	0.02			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	621MTR-JFR017A-	100	RESIDENTIAL	AMR	Functional	100%	4	0.02			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	TP-JFR212A-1	100	RESIDENTIAL	AMR	Functional	100%	12	0.02			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	TP-JFR458A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.01			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	TP-JFR508A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.01			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	TP-JFR213A-1	100	RESIDENTIAL		Functional	100%	11	0.00			
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	TP-JFR214A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.00			
66 kv JAFFARPUR GRID	WZAFF105	11kv FDR JAFFAR PUR	621UJW-JFR070A-	630	RESIDENTIAL	AMR	Functional	100%	677	0.59	0.86	0.26	23.27%
66 kv JAFFARPUR GRID	WZAFF107	11kv FDR KHERA DABAR	621UJW-JFR054A-	630	RESIDENTIAL		Functional	100%	251	0.27			
66 kv JAFFARPUR GRID	WZAFF105	11kv FDR JAFFAR PUR	TP-JFR296A-1	400	RESIDENTIAL		Functional	100%	150	0.13			
66 kv JAFFARPUR GRID	WZAFF102	11kv FDR MITRAON	621UJW-JFR164A-	100	RESIDENTIAL		Functional	100%	31	0.05			
66 kv JAFFARPUR GRID	WZAFF105	11kv FDR JAFFAR PUR	621UJW-JFR170A-	100	RESIDENTIAL		Functional	100%	29	0.04			
66 kv JAFFARPUR GRID	WZAFF101	11kv FDR R.T.R.M. HOSPITAL	TP-JFR320A-1	100	RESIDENTIAL		Functional	100%	4	0.03			
66 kv JAFFARPUR GRID	WZAFF105	11kv FDR JAFFAR PUR	TP-JFR445A-1	100	RESIDENTIAL		Functional	100%	15	0.02			
66/11kv MITRAON GRID	WMITR113	11kv FDR ARADHNA ENCLAVE	621CRP-HVD008A-	1575	RESIDENTIAL		Functional	100%	1221	0.74	2.28	0.04	1.66%
66/11kv MITRAON GRID	WMITR113	11kv FDR ARADHNA ENCLAVE	621CRP-JFR028A-	400	RESIDENTIAL	AMR	Functional	100%	658	0.49			
66/11kv MITRAON GRID	WMITR113	11kv FDR ARADHNA ENCLAVE	621CRP-JFR068A-	400	RESIDENTIAL	AMR	Functional	100%	566	0.35			
66/11kv MITRAON GRID	WMITR113	11kv FDR ARADHNA ENCLAVE	TP-JFR547A-1	990	RESIDENTIAL	AMR	Functional	100%	527	0.34			
66/11kv MITRAON GRID	WMITR113	11kv FDR ARADHNA ENCLAVE	621CRP-JFR068A-	400	RESIDENTIAL	AMR	Functional	100%	600	0.28			
66 kv JAFFARPUR GRID	WZAFF115	11kv FDR NEW C.R.P.F.	TP-JFR050A-1	400	RESIDENTIAL		Functional	100%	256	0.11			
66/11kv MITRAON GRID	WMITR105	11kv FDR SAINIK ENCLAVE FEEDER	TP-JFR281A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.00			
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	621MDL-JFR067A-	630	RESIDENTIAL	AMR	Functional	100%	397	0.41	0.46	0.51	52.53%
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	TG-JFR273A-1	630	RESIDENTIAL	AMR	Functional	100%	460	0.40			
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	621MDL-JFR105A-	100	RESIDENTIAL		Functional	100%	16	0.04			
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	621MDL-JFR400A-	100	RESIDENTIAL		Functional	100%	10	0.03			
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	TP-JFR013A-1	100	RESIDENTIAL	AMR	Functional	100%	6	0.02			
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	621MDL-JFR104A-	100	RESIDENTIAL		Functional	100%	21	0.02			
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	TP-JFR239A-1	100	RESIDENTIAL		Functional	100%	1	0.01			
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	621MDL-JFR103A-	100	RESIDENTIAL		Functional	100%	12	0.01			
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	TP-JFR462A-1	100	RESIDENTIAL		Functional	100%	3	0.01			
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	621MDL-JFR115A-	100	RESIDENTIAL		Functional	100%	18	0.01			
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	TP-JFR363A-1	100	RESIDENTIAL		Functional	100%	1	0.00			
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	TP-JFR289A-1	100	RESIDENTIAL		Functional	100%	2	0.00			
66/11kv MITRAON GRID	WMITR134	11kv FDR KAIR VILLAGE	621MDL-JFR604A-	400	MIXED		Functional	100%	0	0.00			
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	621MDL-JFR066A-	630	RESIDENTIAL	AMR	Functional	100%	322	0.42	0.60	0.76	52.66%
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	TP-JFR577A-1	400	RESIDENTIAL		Functional	100%	285	0.35			
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	621MDL-JFR066A-	400	RESIDENTIAL	AMR	Functional	100%	191	0.27			
66 kv JAFFARPUR GRID	WZAFF121	11kv FDR NEW MUNDHELA	621MDL-JFR114A-	400	RESIDENTIAL	AMR	Functional	100%	242	0.11			

66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	621MDL-JFR110A-	100	RESIDENTIAL		Functional	100%	15	0.04			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	TP-JFR233A-1	100	RESIDENTIAL		Functional	100%	2	0.03			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	TP-JFR215A-1	100	RESIDENTIAL		Functional	100%	9	0.03			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	TP-JFR471A-1	100	RESIDENTIAL		Functional	100%	6	0.02			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	621MDL-JFR116A-	100	RESIDENTIAL		Functional	100%	9	0.02			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	621MDL-JFR113A-	100	RESIDENTIAL		Functional	100%	2	0.01			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	TP-JFR488A-1	100	MIXED		Functional	100%	6	0.01			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	621MDL-JFR106A-	100	RESIDENTIAL		Functional	100%	10	0.01			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	TP-JFR357A-1	100	RESIDENTIAL		Functional	100%	8	0.01			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	TP-JFR560A-1	100	RESIDENTIAL		Functional	100%	13	0.01			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	TP-JFR304A-1	100	RESIDENTIAL		Functional	100%	13	0.01			
66 KV JAFFARPUR GRID	WZAFF103	11KV FDR ISSAPUR	621MDL-JFR109A-	100	RESIDENTIAL		Functional	100%	7	0.01			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	621DNS-JFR118A-	100	RESIDENTIAL		Functional	100%	9	0.00			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	TP-JFR485A-1	100	RESIDENTIAL		Functional	100%	9	0.00			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	TP-JFR514A-1	100	RESIDENTIAL		Functional	100%	1	0.00			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	621MDL-JFR112A-	100	RESIDENTIAL		Functional	100%	8	0.00			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	621MDL-JFR117A-	100	RESIDENTIAL		Functional	100%	3	0.00			
66 KV JAFFARPUR GRID	WZAFF104	11KV FDR DABAR ENCLAVE	621UJW-HVD019A	3750	RESIDENTIAL		Functional	100%	1373	0.60	1.15	0.01	1.17%
66 KV JAFFARPUR GRID	WZAFF101	11KV FDR R.T.R.M. HOSPITAL	621MDL-JFR587A-	400	RESIDENTIAL		Functional	100%	320	0.19			
66 KV JAFFARPUR GRID	WZAFF101	11KV FDR R.T.R.M. HOSPITAL	621UJW-JFR014A-	400	RESIDENTIAL		Functional	100%	318	0.18			
66 KV JAFFARPUR GRID	WZAFF101	11KV FDR R.T.R.M. HOSPITAL	TG-JFR318A-1	630	RESIDENTIAL		Functional	100%	0	0.04			
66 KV JAFFARPUR GRID	WZAFF101	11KV FDR R.T.R.M. HOSPITAL	621UJW-JFR169A-	100	RESIDENTIAL		Functional	100%	2	0.04			
66 KV JAFFARPUR GRID	WZAFF101	11KV FDR R.T.R.M. HOSPITAL	TG-JFR318A-2	630	RESIDENTIAL		Functional	100%	2	0.04			
66 KV JAFFARPUR GRID	WZAFF101	11KV FDR R.T.R.M. HOSPITAL	TP-JFR225A-1	100	RESIDENTIAL		Functional	100%	2	0.03			
66 KV JAFFARPUR GRID	WZAFF107	11KV FDR KHERA DABAR	TP-JFR298A-1	100	RESIDENTIAL		Functional	100%	4	0.02			
66 KV JAFFARPUR GRID	WZAFF111	11KV STR 400KVA STATION TRANSFORMER	JF-WTC009A-1	400	RESIDENTIAL		Functional	100%	1	0.01			
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	621MDL-HVD024A	750	RESIDENTIAL		Functional	100%	337	0.23	0.23	0.00	0.15%
66 KV JAFFARPUR GRID	WZAFF121	11KV FDR NEW MUNDHELA	TP-JFR343A-1	100	RESIDENTIAL		Functional	100%	7	0.00			
66 KV JAFFARPUR GRID	WZAFF128	11KV FDR RAWTA	621GMH-JFR031A-	400	RESIDENTIAL		Functional	100%	175	0.14	0.12	0.04	22.82%
66 KV JAFFARPUR GRID	WZAFF128	11KV FDR RAWTA	TP-JFR240A-1	100	RESIDENTIAL		Functional	100%	7	0.00			
66 KV JAFFARPUR GRID	WZAFF128	11KV FDR RAWTA	621GMH-JFR139A-	100	RESIDENTIAL		Functional	100%	9	0.00			
66/11KV MITRAON GRID	WMITR134	11KV FDR KAIR VILLAGE	TP-JFR574A-1	100	RESIDENTIAL		Functional	100%	6	0.01			
66 KV JAFFARPUR GRID	WZAFF104	11KV FDR DABAR ENCLAVE	621CRP-MOB001A	630	MIXED		Functional	100%	0	0.00			
66KV NILOTHI GRID	WNILO113	11KV FDR BAPROLA NO2 (UG)	TG-NAG070A-1	990	RESIDENTIAL		Functional	100%	1204	0.95	3.95	0.48	10.89%
66KV NILOTHI GRID	WNILO112	11KV FDR RAJIV RATAN-3	TP-NAG117A-1	990	RESIDENTIAL		Functional	100%	1122	0.77			
66KV NILOTHI GRID	WNILO112	11KV FDR RAJIV RATAN-3	TP-NAG116A-1	1600	RESIDENTIAL		Functional	100%	1173	0.64			
66KV NILOTHI GRID	WNILO113	11KV FDR BAPROLA NO-2 (UG)	630BPR-NAG069B-	990	RESIDENTIAL		Functional	100%	0	0.48			
66KV NILOTHI GRID	WNILO105	11KV FDR RAJIV RATAN-2	TP-NAG018A-1	400	RESIDENTIAL		Functional	100%	529	0.46			
66KV NILOTHI GRID	WNILO105	11KV FDR RAJIV RATAN-2	TG-NAG119A-1	630	RESIDENTIAL		Functional	100%	757	0.44			
66KV NILOTHI GRID	WNILO113	11KV FDR BAPROLA NO2 (UG)	630BPR-NAG069A-	990	RESIDENTIAL		Functional	100%	1077	0.32			
66KV NILOTHI GRID	WNILO105	11KV FDR RAJIV RATAN-2	TP-NAG168A-1	400	RESIDENTIAL		Functional	100%	275	0.19			
66KV NILOTHI GRID	WNILO111	11KV FDR BAPROLA OLD O/H	630BPR-NAG238A-	400	MIXED		Functional	100%	0	0.15			
66KV NILOTHI GRID	WNILO105	11KV FDR RAJIV RATAN-2	TP-NAG049A-1	100	RESIDENTIAL		Functional	100%	1	0.03			
66 KV NANGLOI GRID	WNNG107	11KV FDR JAWALAPURI CAMP NO.4	630UNR-PEG056A-	990	RESIDENTIAL		Functional	100%	1683	0.68	5.71	0.09	1.49%
66 KV NANGLOI GRID	WNNG107	11KV FDR JAWALAPURI CAMP NO.4	630UNR-PEG057A-	630	RESIDENTIAL		Functional	100%	476	0.66			
66 KV NANGLOI GRID	WNNG116	11KV FDR P.V.C. MKT.JAWALA PURI (R&BLOCK)	630UNR-PEG054A-	990	RESIDENTIAL		Functional	100%	646	0.63			
66 KV NANGLOI GRID	WNNG107	11KV FDR JAWALAPURI CAMP NO.4	630UNR-PEG058A-	630	RESIDENTIAL		Functional	100%	800	0.63			
66 KV NANGLOI GRID	WNNG107	11KV FDR JAWALAPURI CAMP NO.4	TG-PEG059A-1	990	RESIDENTIAL		Functional	100%	414	0.45			
66 KV NANGLOI GRID	WNNG116	11KV FDR P.V.C. MKT.JAWALA PURI (R&BLOCK)	630UNR-PEG055A-	990	RESIDENTIAL		Functional	100%	569	0.45			
66 KV NANGLOI GRID	WNNG107	11KV FDR JAWALAPURI CAMP NO.4	630UNR-PEG056A-	630	RESIDENTIAL		Functional	100%	0	0.36			

66 kv PASCHIM VIHAR GRID	WPSCV119	11kv FDR 1140 SFS FLATS	TG-PEG210A-1	630	RESIDENTIAL	AMR	Functional	100%	199	0.33			
66 kv NANGLOI GRID	WNNGL116	11kv FDR P.V.C. MKT.JAWALA PURI (R2BLOCK)	TG-PEG209A-1	630	RESIDENTIAL		Functional	100%	162	0.33			
66 kv NANGLOI GRID	WNNGL107	11kv FDR JAWALAPURI CAMP NO.4	630UNR-PEG061A	630	INDUSTRIAL		Functional	100%	382	0.29			
66 kv NANGLOI GRID	WNNGL116	11kv FDR P.V.C. MKT.JAWALA PURI (R2BLOCK)	630UNR-PEG054A	630	RESIDENTIAL		Functional	100%	368	0.29			
66 kv NANGLOI GRID	WNNGL116	11kv FDR P.V.C. MKT.JAWALA PURI (R2BLOCK)	630UNR-PEG060A	630	RESIDENTIAL		Functional	100%	313	0.22			
66 kv NANGLOI GRID	WNNGL107	11kv FDR JAWALAPURI CAMP NO.4	630UNR-PEG062A	400	INDUSTRIAL		Functional	100%	0	0.20			
66 kv NANGLOI GRID	WNNGL107	11kv FDR JAWALAPURI CAMP NO.4	630UNR-PEG061A	630	INDUSTRIAL		Functional	100%	45	0.18			
66 kv NANGLOI GRID	WNNGL107	11kv FDR JAWALAPURI CAMP NO.4	630UNR-PEG062A	400	MIXED		Functional	100%	517	0.08			
66 kv NANGLOI GRID	WNNGL125	11kv STR 400KVA STATION TRANSFORMER	TG-WTC014A-1	400	RESIDENTIAL		Functional	100%	1	0.03			
66 kv PASCHIM VIHAR GRID	WPSCV129	11kv FDR CHANDER VIHAR	NG-HVD008A-1	2825	RESIDENTIAL		Functional	100%	1795	1.33	7.47	0.36	4.58%
66 kv PASCHIM VIHAR GRID	WPSCV115	11kv FDR NILOTHI	NG-HVD011A-1	2025	RESIDENTIAL		Functional	100%	1614	1.23			
66 kv PASCHIM VIHAR GRID	WPSCV129	11kv FDR CHANDER VIHAR	NG-HVD003A-1	2525	RESIDENTIAL		Functional	100%	2211	1.18			
66 kv PASCHIM VIHAR GRID	WPSCV129	11kv FDR CHANDER VIHAR	TP-NAG077A-1	990	RESIDENTIAL		Functional	100%	1345	0.87			
66 kv BODELLA - 2 GRID	WBDL2103	11kv FDR GRAMSABHA NILOTHI	TP-NAG213A-1	990	RESIDENTIAL		Functional	100%	1214	0.82			
66 kv PASCHIM VIHAR GRID	WPSCV131	11kv FDR UDAY VIHAR	TP-NAG198A-1	990	RESIDENTIAL		Functional	100%	966	0.77			
66 kv PASCHIM VIHAR GRID	WPSCV131	11kv FDR UDAY VIHAR	TG-NAG082A-1	990	RESIDENTIAL		Functional	100%	1023	0.74			
66 kv PASCHIM VIHAR GRID	WPSCV131	11kv FDR UDAY VIHAR	TG-NAG200A-1	630	RESIDENTIAL		Functional	100%	790	0.64			
66 kv PASCHIM VIHAR GRID	WPSCV129	11kv FDR CHANDER VIHAR	TP-NAG078A-1	630	RESIDENTIAL		Functional	100%	584	0.26			
66 kv PASCHIM VIHAR GRID	WPSCV131	11kv FDR UDAY VIHAR	TP-NAG123A-1	990	RESIDENTIAL		Functional	100%	1125	0.82	5.46	0.07	1.27%
66 kv PASCHIM VIHAR GRID	WPSCV115	11kv FDR NILOTHI	TP-NAG079A-1	630	RESIDENTIAL		Functional	100%	942	0.82			
66 kv PASCHIM VIHAR GRID	WPSCV115	11kv FDR NILOTHI	TG-NAG080A-1	630	RESIDENTIAL		Functional	100%	1172	0.82			
66 kv PASCHIM VIHAR GRID	WPSCV115	11kv FDR NILOTHI	TP-NAG081A-1	990	RESIDENTIAL		Functional	100%	1283	0.74			
66kv NILOTHI GRID	WNILO139	11kv FDR DEEPAK VIHAR	TG-NAG207A-1	630	RESIDENTIAL		Functional	100%	807	0.71			
66 kv PASCHIM VIHAR GRID	WPSCV115	11kv FDR NILOTHI	TP-NAG124A-1	630	RESIDENTIAL		Functional	100%	791	0.69			
66kv NILOTHI GRID	WNILO139	11kv FDR DEEPAK VIHAR	TG-NAG127A-2	630	RESIDENTIAL		Functional	100%	41	0.60			
66kv NILOTHI GRID	WNILO139	11kv FDR DEEPAK VIHAR	TG-NAG127A-1	400	RESIDENTIAL		Functional	100%	1158	0.32			
66 kv PASCHIM VIHAR GRID	WPSCV133	11kv FDR GH-14	630UNR-PEG067A	630	RESIDENTIAL		Functional	100%	255	0.48	2.20	0.07	3.27%
66 kv PASCHIM VIHAR GRID	WPSCV133	11kv FDR GH-14	630UNR-PEG067A	630	RESIDENTIAL		Functional	100%	197	0.23			
66 kv PASCHIM VIHAR GRID	WPSCV133	11kv FDR GH-14	630UNR-PEG068A	630	RESIDENTIAL		Functional	100%	276	0.17			
66 kv PASCHIM VIHAR GRID	WPSCV133	11kv FDR GH-14	630UNR-PEG072A	630	RESIDENTIAL		Functional	100%	233	0.17			
66 kv PASCHIM VIHAR GRID	WPSCV133	11kv FDR GH-14	630UNR-PEG069A	630	RESIDENTIAL		Functional	100%	87	0.15			
66 kv PASCHIM VIHAR GRID	WPSCV133	11kv FDR GH-14	630UNR-PEG072A	630	RESIDENTIAL		Functional	100%	0	0.14			
66 kv PASCHIM VIHAR GRID	WPSCV133	11kv FDR GH-14	TI-PEG070A-2	630	RESIDENTIAL		Functional	100%	107	0.12			
66 kv PASCHIM VIHAR GRID	WPSCV133	11kv FDR GH-14	630UNR-PEG066A	400	RESIDENTIAL		Functional	100%	0	0.12			
66 kv PASCHIM VIHAR GRID	WPSCV133	11kv FDR GH-14	TI-PEG070A-1	630	RESIDENTIAL		Functional	100%	86	0.11			
66 kv PASCHIM VIHAR GRID	WPSCV133	11kv FDR GH-14	630UNR-PEG068A	630	RESIDENTIAL		Functional	100%	0	0.11			
66 kv PASCHIM VIHAR GRID	WPSCV133	11kv FDR GH-14	TI-PEG066A-2	400	RESIDENTIAL		Functional	100%	150	0.09			
66 kv PASCHIM VIHAR GRID	WPSCV133	11kv FDR GH-14	630UNR-PEG071A	630	RESIDENTIAL		Functional	100%	63	0.07			
66 kv PASCHIM VIHAR GRID	WPSCV133	11kv FDR GH-14	630UNR-PEG069A	630	RESIDENTIAL		Functional	100%	90	0.07			
66 kv NANGLOI GRID	WNNGL116	11kv FDR P.V.C. MKT.JAWALA PURI (R2BLOCK)	TP-PEG121A-1	400	RESIDENTIAL		Functional	100%	37	0.05			
66 kv NANGLOI GRID	WNNGL116	11kv FDR P.V.C. MKT.JAWALA PURI (R2BLOCK)	630UNR-PEG073A	630	RESIDENTIAL		Functional	100%	0	0.05			
66 kv NANGLOI GRID	WNNGL116	11kv FDR P.V.C. MKT.JAWALA PURI (R2BLOCK)	630UNR-PEG074A	400	RESIDENTIAL		Functional	100%	42	0.05			
66 kv NANGLOI GRID	WNNGL116	11kv FDR P.V.C. MKT.JAWALA PURI (R2BLOCK)	630UNR-PEG073A	630	RESIDENTIAL		Functional	100%	81	0.05			
66 kv PASCHIM VIHAR GRID	WPSCV133	11kv FDR GH-14	TI-PEG071A-2	630	RESIDENTIAL		Functional	100%	6	0.04			
33 kv UDYOG NAGAR GRID	WUDNR103	11kv FDR F-BLOCK D.S.I.D.C	TG-PEG106A-3	990	RESIDENTIAL		Functional	100%	0	1.13	10.79	0.96	8.20%
33 kv UDYOG NAGAR GRID	WUDNR103	11kv FDR F-BLOCK D.S.I.D.C	TI-PEG106A-2	990	INDUSTRIAL		Functional	100%	56	0.92			
33 kv UDYOG NAGAR GRID	WUDNR110	11kv FDR H-BLOCK DSIDC ID SSTN	TG-PEG105A-1	990	RESIDENTIAL		Functional	100%	28	0.73			
66 kv NANGLOI GRID	WNNGL109	11kv FDR D.S.I.D.C	TI-PEG110A-2	990	INDUSTRIAL		Functional	100%	28	0.65			
66 kv NANGLOI GRID	WNNGL122	11kv FDR UDYOG NAGAR NO.1	TI-PEG104A-2	990	INDUSTRIAL		Functional	100%	0	0.62			
66 kv NANGLOI GRID	WNNGL122	11kv FDR UDYOG NAGAR NO.1	TG-PEG104A-3	990	RESIDENTIAL		Functional	100%	0	0.62			

66 kV NANGLOI GRID	WNNGL113	11kV FDR UDYOG NAGAR NO-2	TG-PEG214A-1	630	MIXED		Functional	100%	12	0.60			
33 kV UDYOG NAGAR GRID	WUDNR110	11kV FDR H-BLOCK DSIDC ID SSTN	TI-PEG108A-1	990	INDUSTRIAL		Functional	100%	59	0.59			
66 kV NANGLOI GRID	WNNGL109	11kV FDR D.S.I.D.C	TI-PEG103A-2	990	INDUSTRIAL		Functional	100%	22	0.59			
66 kV NANGLOI GRID	WNNGL109	11kV FDR D.S.I.D.C	TI-PEG111A-1	990	INDUSTRIAL		Functional	100%	8	0.59			
33 kV UDYOG NAGAR GRID	WUDNR103	11kV FDR F-BLOCK D.S.I.D.C	TI-PEG106A-1	990	INDUSTRIAL		Functional	100%	20	0.57			
33 kV UDYOG NAGAR GRID	WUDNR110	11kV FDR H-BLOCK DSIDC ID SSTN	TI-PEG104A-1	990	RESIDENTIAL		Functional	100%	51	0.50			
66 kV NANGLOI GRID	WNNGL113	11kV FDR UDYOG NAGAR NO-2	TP-PEG109A-1	1600	INDUSTRIAL		Functional	100%	15	0.49			
66 kV NANGLOI GRID	WNNGL109	11kV FDR D.S.I.D.C	TI-PEG111A-2	990	INDUSTRIAL		Functional	100%	18	0.49			
33 kV UDYOG NAGAR GRID	WUDNR105	11kV FDR S/STN,NO¿1 UDYOG NAGAR	TG-PEG112A-2	630	RESIDENTIAL		Functional	100%	0	0.48			
66 kV NANGLOI GRID	WNNGL109	11kV FDR D.S.I.D.C	TI-PEG103A-1	990	INDUSTRIAL		Functional	100%	11	0.43			
66 kV NANGLOI GRID	WNNGL109	11kV FDR D.S.I.D.C	TG-PEG132A-1	630	MIXED		Functional	100%	973	0.43			
33 kV UDYOG NAGAR GRID	WUDNR105	11kV FDR S/STN,NO¿1 UDYOG NAGAR	TG-PEG112A-1	630	RESIDENTIAL		Functional	100%	52	0.42			
66 kV NANGLOI GRID	WNNGL109	11kV FDR D.S.I.D.C	TP-PEG103A-3	630	RESIDENTIAL		Functional	100%	0	0.36			
66 kV NANGLOI GRID	WNNGL109	11kV FDR D.S.I.D.C	TG-PEG110A-3	990	COMMERCIAL		Functional	100%	0	0.26			
66 kV NANGLOI GRID	WNNGL109	11kV FDR D.S.I.D.C	TI-PEG110A-1	630	RESIDENTIAL		Functional	100%	26	0.21			
33 kV UDYOG NAGAR GRID	WUDNR110	11kV FDR H-BLOCK DSIDC ID SSTN	TI-PEG108A-2	990	INDUSTRIAL		Functional	100%	4	0.09			
66 kV PASCHIM VIHAR GRID	WPSCV134	11kV FDR SUNDER VIHAR	630GH9-PEG038A	990	RESIDENTIAL		Functional	100%	282	0.75	3.52	0.08	2.29%
33 kV PASCHIM PURI GRID	WPSCP104	11kV FDR SUNDER VIHAR	630GH9-PEG037A	990	RESIDENTIAL		Functional	100%	280	0.60			
33 kV PASCHIM PURI GRID	WPSCP104	11kV FDR SUNDER VIHAR	630GH9-PEG036A	990	RESIDENTIAL		Functional	100%	29	0.38			
33 kV PASCHIM PURI GRID	WPSCP104	11kV FDR SUNDER VIHAR	TI-PEG035A-2	990	RESIDENTIAL		Functional	100%	346	0.38			
33 kV PASCHIM PURI GRID	WPSCP104	11kV FDR SUNDER VIHAR	630GH9-PEG036A	990	RESIDENTIAL		Functional	100%	343	0.26			
33 kV PASCHIM PURI GRID	WPSCP104	11kV FDR SUNDER VIHAR	630GH9-PEG035B	990	RESIDENTIAL		Functional	100%	0	0.26			
33 kV PASCHIM PURI GRID	WPSCP104	11kV FDR SUNDER VIHAR	630GH9-PEG079A	630	RESIDENTIAL		Functional	100%	856	0.25			
33 kV PASCHIM PURI GRID	WPSCP104	11kV FDR SUNDER VIHAR	630GH9-PEG079A	630	RESIDENTIAL		Functional	100%	204	0.23			
33 kV PASCHIM PURI GRID	WPSCP104	11kV FDR SUNDER VIHAR	630GH9-PEG080A	630	RESIDENTIAL		Functional	100%	137	0.22			
33 kV PASCHIM PURI GRID	WPSCP104	11kV FDR SUNDER VIHAR	630GH9-PEG080A	630	RESIDENTIAL		Functional	100%	83	0.14			
66 kV PASCHIM VIHAR GRID	WPSCV120	11kV FDR 656 MIG FLATS	TP-PEG094A-1	400	RESIDENTIAL		Functional	100%	4	0.10			
33 kV PASCHIM PURI GRID	WPSCP104	11kV FDR SUNDER VIHAR	630GH9-PEG035A	990	RESIDENTIAL		Functional	100%	134	0.02			
33 kV PASCHIM PURI GRID	WPSCP104	11kV FDR SUNDER VIHAR	TP-PEG123A-1	100	RESIDENTIAL		Functional	100%	2	0.02			
66 kV PASCHIM VIHAR GRID	WPSCV135	11kV FDR AMBICA VIHAR	TI-PEG092A-2	990	RESIDENTIAL		Functional	100%	409	0.63	3.16	0.04	1.27%
66 kV PASCHIM VIHAR GRID	WPSCV135	11kV FDR AMBICA VIHAR	TI-PEG092A-1	990	RESIDENTIAL		Functional	100%	169	0.48			
66 kV PASCHIM VIHAR GRID	WPSCV135	11kV FDR AMBICA VIHAR	TP-PEG093A-1	990	RESIDENTIAL		Functional	100%	199	0.33			
66 kV PASCHIM VIHAR GRID	WPSCV119	11kV FDR 1140 SFS FLATS	TI-PEG090A-2	630	RESIDENTIAL		Functional	100%	63	0.24			
66 kV PASCHIM VIHAR GRID	WPSCV119	11kV FDR 1140 SFS FLATS	TI-PEG088A-2	630	RESIDENTIAL		Functional	100%	258	0.20			
66 kV PASCHIM VIHAR GRID	WPSCV119	11kV FDR 1140 SFS FLATS	TI-PEG089A-2	630	RESIDENTIAL		Functional	100%	77	0.15			
66 kV PASCHIM VIHAR GRID	WPSCV119	11kV FDR 1140 SFS FLATS	630GH9-PEG052A	400	RESIDENTIAL		Functional	100%	126	0.15			
66 kV PASCHIM VIHAR GRID	WPSCV119	11kV FDR 1140 SFS FLATS	630GH9-PEG087A	630	RESIDENTIAL		Functional	100%	101	0.14			
66 kV PASCHIM VIHAR GRID	WPSCV119	11kV FDR 1140 SFS FLATS	630GH9-PEG087A	630	RESIDENTIAL		Functional	100%	163	0.14			
66 kV PASCHIM VIHAR GRID	WPSCV119	11kV FDR 1140 SFS FLATS	TI-PEG088A-1	630	RESIDENTIAL		Functional	100%	145	0.14			
66 kV PASCHIM VIHAR GRID	WPSCV119	11kV FDR 1140 SFS FLATS	TI-PEG090A-1	630	COMMERCIAL		Functional	100%	0	0.13			
66 kV PASCHIM VIHAR GRID	WPSCV119	11kV FDR 1140 SFS FLATS	TI-PEG089A-1	630	RESIDENTIAL		Functional	100%	41	0.12			
66 kV PASCHIM VIHAR GRID	WPSCV119	11kV FDR 1140 SFS FLATS	630GH9-PEG086A	400	RESIDENTIAL		Functional	100%	241	0.11			
66 kV PASCHIM VIHAR GRID	WPSCV119	11kV FDR 1140 SFS FLATS	630GH9-PEG086A	400	RESIDENTIAL		Functional	100%	197	0.09			
66 kV PASCHIM VIHAR GRID	WPSCV119	11kV FDR 1140 SFS FLATS	630GH9-PEG053A	400	RESIDENTIAL		Functional	100%	0	0.07			
66 kV PASCHIM VIHAR GRID	WPSCV119	11kV FDR 1140 SFS FLATS	630GH9-PEG053A	400	RESIDENTIAL		Functional	100%	187	0.07			
66 kV PASCHIM VIHAR GRID	WPSCV116	11kV FDR 1200 M.I.G. FLATS.	630GH9-PEG083A	630	RESIDENTIAL		Functional	100%	255	0.34	1.77	0.24	11.91%
66 kV PASCHIM VIHAR GRID	WPSCV116	11kV FDR 1200 M.I.G. FLATS.	TI-PEG082A-2	630	RESIDENTIAL		Functional	100%	291	0.30			
66 kV PASCHIM VIHAR GRID	WPSCV116	11kV FDR 1200 M.I.G. FLATS.	TI-PEG082A-1	630	RESIDENTIAL		Functional	100%	152	0.22			
66 kV PASCHIM VIHAR GRID	WPSCV116	11kV FDR 1200 M.I.G. FLATS.	630GH9-PEG085A	630	RESIDENTIAL		Functional	100%	0	0.20			
66 kV PASCHIM VIHAR GRID	WPSCV116	11kV FDR 1200 M.I.G. FLATS.	630GH9-PEG084A	400	RESIDENTIAL		Functional	100%	57	0.19			

66 kv PASCHIM VIHAR GRID	WPSCV116	11kv FDR 1200 M.I.G. FLATS.	630GH9-PEG085A-	630	RESIDENTIAL	Functional	100%	146	0.17			
66 kv PASCHIM VIHAR GRID	WPSCV135	11kv FDR AMBICA VIHAR	TI-PEG091A-1	630	RESIDENTIAL	Functional	100%	161	0.15			
66 kv PASCHIM VIHAR GRID	WPSCV116	11kv FDR 1200 M.I.G. FLATS.	630GH9-PEG084A-	630	RESIDENTIAL	Functional	100%	144	0.11			
33 kv PASCHIM PURI GRID	WPSCP125	11kv FDR MTNL NO-2	TG-PEG116A-1	400	COMMERCIAL	Functional	100%	2	0.11			
66 kv PASCHIM VIHAR GRID	WPSCV116	11kv FDR 1200 M.I.G. FLATS.	630GH9-PEG083A-	630	RESIDENTIAL	Functional	100%	108	0.09			
66 kv PASCHIM VIHAR GRID	WPSCV135	11kv FDR AMBICA VIHAR	TI-PEG081A-2	630	RESIDENTIAL	Functional	100%	39	0.07			
66 kv PASCHIM VIHAR GRID	WPSCV135	11kv FDR AMBICA VIHAR	TI-PEG081A-1	630	RESIDENTIAL	Functional	100%	38	0.06			
66 kv PASCHIM VIHAR GRID	WPSCV114	11kv FDR 688 LIG FLATS(GH-8)	630GH9-PEG039A-	630	RESIDENTIAL	Functional	100%	479	0.44	1.79	0.19	9.81%
66 kv PASCHIM VIHAR GRID	WPSCV112	11kv FDR 1312 LIG FLATS	630GH9-PEG040A-	630	RESIDENTIAL	Functional	100%	217	0.42			
66 kv PASCHIM VIHAR GRID	WPSCV114	11kv FDR 688 LIG FLATS(GH-8)	630GH9-PEG050A-	400	RESIDENTIAL	Functional	100%	257	0.24			
66 kv PASCHIM VIHAR GRID	WPSCV114	11kv FDR 688 LIG FLATS(GH-8)	630GH9-PEG042A-	400	MIXED	Functional	100%	159	0.22			
66 kv PASCHIM VIHAR GRID	WPSCV114	11kv FDR 688 LIG FLATS(GH-8)	630GH9-PEG051A-	630	RESIDENTIAL	Functional	100%	181	0.18			
66 kv PASCHIM VIHAR GRID	WPSCV112	11kv FDR 1312 LIG FLATS	630GH9-PEG041A-	400	RESIDENTIAL	Functional	100%	257	0.17			
66 kv PASCHIM VIHAR GRID	WPSCV114	11kv FDR 688 LIG FLATS(GH-8)	630GH9-PEG051A-	630	RESIDENTIAL	Functional	100%	186	0.16			
66 kv PASCHIM VIHAR GRID	WPSCV114	11kv FDR 688 LIG FLATS(GH-8)	630GH9-PEG050A-	400	RESIDENTIAL	Functional	100%	181	0.15			
33 kv PASCHIM PURI GRID	WPSCP108	11kv FDR UDYOG NAGAR NO-1 (BHERA ENCLAVE)	630GH9-PEG045A-	1600	RESIDENTIAL	Functional	100%	170	0.80	6.72	0.20	2.87%
33 kv PASCHIM PURI GRID	WPSCP108	11kv FDR UDYOG NAGAR NO-1 (BHERA ENCLAVE)	630GH9-PEG044A-	990	RESIDENTIAL	Functional	100%	356	0.71			
33 kv PASCHIM PURI GRID	WPSCP108	11kv FDR UDYOG NAGAR NO-1 (BHERA ENCLAVE)	630GH9-PEG043A-	990	RESIDENTIAL	Functional	100%	401	0.65			
66 kv NANGLOI GRID	WNNG110	11kv FDR HINDUSTAN SOCIETY	TG-PEG097A-1	990	RESIDENTIAL	Functional	100%	365	0.62			
33 kv PASCHIM PURI GRID	WPSCP108	11kv FDR UDYOG NAGAR NO-1 (BHERA ENCLAVE)	630GH9-PEG043A-	630	RESIDENTIAL	Functional	100%	0	0.56			
33 kv PASCHIM PURI GRID	WPSCP108	11kv FDR UDYOG NAGAR NO-1 (BHERA ENCLAVE)	630GH9-PEG043A-	990	RESIDENTIAL	Functional	100%	697	0.48			
66 kv NANGLOI GRID	WNNG110	11kv FDR HINDUSTAN SOCIETY	TG-PEG200A-1	990	RESIDENTIAL	Functional	100%	232	0.47			
66 kv NANGLOI GRID	WNNG110	11kv FDR HINDUSTAN SOCIETY	TI-PEG095A-3	990	RESIDENTIAL	Functional	100%	0	0.42			
66 kv NANGLOI GRID	WNNG110	11kv FDR HINDUSTAN SOCIETY	TI-PEG096A-2	630	RESIDENTIAL	Functional	100%	199	0.41			
66 kv NANGLOI GRID	WNNG110	11kv FDR HINDUSTAN SOCIETY	TI-PEG095A-1	990	RESIDENTIAL	Functional	100%	71	0.37			
66 kv PASCHIM VIHAR GRID	WPSCV119	11kv FDR 1140 SFS FLATS	TG-PEG098A-2	630	RESIDENTIAL	Functional	100%	275	0.36			
66 kv NANGLOI GRID	WNNG110	11kv FDR HINDUSTAN SOCIETY	TI-PEG096A-1	630	RESIDENTIAL	Functional	100%	384	0.33			
66 kv NANGLOI GRID	WNNG110	11kv FDR HINDUSTAN SOCIETY	TI-PEG095A-2	990	RESIDENTIAL	Functional	100%	320	0.33			
66 kv NANGLOI GRID	WNNG110	11kv FDR HINDUSTAN SOCIETY	TP-PEG211A-1	400	COMMERCIAL	Functional	100%	139	0.24			
66 kv PASCHIM VIHAR GRID	WPSCV119	11kv FDR 1140 SFS FLATS	TG-PEG098A-1	630	RESIDENTIAL	Functional	100%	0	0.16			
33 kv UDYOG NAGAR GRID	WUDNR113	11kv FDR UDYOG NAGAR SS-4 NEW	630UNR-PEG004A-	990	INDUSTRIAL	Functional	100%	9	0.61	9.29	0.01	0.11%
33 kv UDYOG NAGAR GRID	WUDNR113	11kv FDR UDYOG NAGAR SS-4 NEW	630UNR-PEG016A-	990	INDUSTRIAL	Functional	100%	66	0.50			
33 kv UDYOG NAGAR GRID	WUDNR113	11kv FDR UDYOG NAGAR SS-4 NEW	TG-PEG008A-1	990	INDUSTRIAL	Functional	100%	14	0.48			
66 kv NANGLOI GRID	WNNG113	11kv FDR UDYOG NAGAR NO-2	630UNR-PEG002A-	1000	INDUSTRIAL	Functional	100%	45	0.48			
33 kv UDYOG NAGAR GRID	WUDNR120	11kv FDR SSTN-5 VIA K-25	630UNR-PEG010A-	630	INDUSTRIAL	Functional	100%	4	0.48			
33 kv UDYOG NAGAR GRID	WUDNR120	11kv FDR SSTN-5 VIA K-25	630UNR-PEG005A-	990	INDUSTRIAL	Functional	100%	0	0.37			
33 kv UDYOG NAGAR GRID	WUDNR104	11kv FDR S/STN, NO23 UDYOG NGR (OLD)	TP-PEG119A-1	990	INDUSTRIAL	Functional	100%	20	0.37			
33 kv UDYOG NAGAR GRID	WUDNR105	11kv FDR S/STN, NO21 UDYOG NAGAR	630UNR-PEG007A-	630	INDUSTRIAL	Functional	100%	9	0.35			
33 kv UDYOG NAGAR GRID	WUDNR105	11kv FDR S/STN, NO21 UDYOG NAGAR	630UNR-PEG009A-	990	INDUSTRIAL	Functional	100%	10	0.34			
33 kv UDYOG NAGAR GRID	WUDNR105	11kv FDR S/STN, NO21 UDYOG NAGAR	630UNR-PEG001A-	990	INDUSTRIAL	Functional	100%	0	0.34			
33 kv UDYOG NAGAR GRID	WUDNR120	11kv FDR SSTN-5 VIA K-25	TG-PEG124A-1	990	INDUSTRIAL	Functional	100%	78	0.33			
33 kv UDYOG NAGAR GRID	WUDNR120	11kv FDR SSTN-5 VIA K-25	TP-PEG127A-1	400	INDUSTRIAL	Functional	100%	38	0.32			
33 kv UDYOG NAGAR GRID	WUDNR105	11kv FDR O/G S/STN, NO-1 UDYOG NGR	630UNR-PEG009B-	990	RESIDENTIAL	Functional	100%	0	0.29			
33 kv UDYOG NAGAR GRID	WUDNR104	11kv FDR S/STN, NO23 UDYOG NGR (OLD)	630UNR-PEG003A-	990	INDUSTRIAL	Functional	100%	45	0.25			
33 kv UDYOG NAGAR GRID	WUDNR120	11kv FDR SSTN-5 VIA K-25	630UNR-PEG006A-	990	INDUSTRIAL	Functional	100%	34	0.25			
66 kv NANGLOI GRID	WNNG113	11kv FDR UDYOG NAGAR NO-2	630UNR-PEG013A-	630	INDUSTRIAL	Functional	100%	6	0.24			
33 kv UDYOG NAGAR GRID	WUDNR113	11kv FDR UDYOG NAGAR SS-4 NEW	TP-PEG120A-1	400	INDUSTRIAL	Functional	100%	16	0.23			
33 kv UDYOG NAGAR GRID	WUDNR113	11kv FDR UDYOG NAGAR SS-4 NEW	630UNR-PEG004A-	630	RESIDENTIAL	Functional	100%	54	0.22			
33 kv UDYOG NAGAR GRID	WUDNR109	11kv FDR UDYOG NAGAR SSTN NO-3 (NEW)	630UNR-PEG011A-	630	INDUSTRIAL	Functional	100%	8	0.22			
33 kv UDYOG NAGAR GRID	WUDNR105	11kv FDR S/STN, NO21 UDYOG NAGAR	TI-PEG126A-1	400	INDUSTRIAL	Functional	100%	38	0.21			

33 kV UDYOG NAGAR GRID	WUDNR109	11kV FDR UDYOG NAGAR SSTN NO-3 (NEW)	TP-PEG131A-1	400	MIXED		Functional	100%	192	0.20			
33 kV UDYOG NAGAR GRID	WUDNR113	11kV FDR UDYOG NAGAR SS-4 NEW	TG-PEG125A-1	990	INDUSTRIAL		Functional	100%	12	0.19			
33 kV UDYOG NAGAR GRID	WUDNR120	11kV FDR SSTN-5 VIA K-25	630UNR-PEG005B	990	INDUSTRIAL		Functional	100%	0	0.18			
33 kV UDYOG NAGAR GRID	WUDNR105	11kV FDR S/STN,NO21 UDYOG NAGAR	630UNR-PEG001A	990	RESIDENTIAL		Functional	100%	892	0.17			
33 kV UDYOG NAGAR GRID	WUDNR120	11kV FDR SSTN-5 VIA K-25	TP-PEG128A-1	400	INDUSTRIAL		Functional	100%	185	0.17			
66 kV NANGLOI GRID	WNNGL113	11kV FDR UDYOG NAGAR NO-2	630UNR-PEG014A	630	INDUSTRIAL		Functional	100%	24	0.16			
33 kV UDYOG NAGAR GRID	WUDNR120	11kV FDR SSTN-5 VIA K-25	TG-PEG005A-3	630	RESIDENTIAL		Functional	100%	15	0.16			
33 kV UDYOG NAGAR GRID	WUDNR113	11kV FDR UDYOG NAGAR SS-4 NEW	630UNR-PEG015A	630	INDUSTRIAL		Functional	100%	34	0.15			
33 kV UDYOG NAGAR GRID	WUDNR120	11kV FDR SSTN-5 VIA K-25	630UNR-PEG005A	990	INDUSTRIAL		Functional	100%	29	0.15			
33 kV UDYOG NAGAR GRID	WUDNR120	11kV FDR SSTN-5 VIA K-25	630UNR-PEG224A	400	RESIDENTIAL		Functional	100%	1	0.14			
33 kV UDYOG NAGAR GRID	WUDNR108	11kV FDR S/STN,NO22 UDYOG NAGAR	630UNR-PEG002A	630	INDUSTRIAL		Functional	100%	25	0.13			
33 kV UDYOG NAGAR GRID	WUDNR104	11kV FDR S/STN, NO23 UDYOG NGR (OLD)	630UNR-PEG003A	630	INDUSTRIAL		Functional	100%	101	0.12			
33 kV UDYOG NAGAR GRID	WUDNR106	11kV FDR UDYOG NGR S/STN NO-4 (OLD)	TP-PEG129A-1	400	COMMERCIAL		Functional	100%	185	0.11			
33 kV UDYOG NAGAR GRID	WUDNR104	11kV FDR S/STN, NO23 UDYOG NGR (OLD)	TP-PEG118A-1	400	INDUSTRIAL		Functional	100%	6	0.11			
33 kV UDYOG NAGAR GRID	WUDNR104	11kV FDR S/STN, NO23 UDYOG NGR (OLD)	630UNR-PEG017A	990	INDUSTRIAL		Functional	100%	8	0.11			
33 kV UDYOG NAGAR GRID	WUDNR120	11kV FDR SSTN-5 VIA K-25	TP-PEG006A-2	400	COMMERCIAL		Functional	100%	0	0.05			
33 kV UDYOG NAGAR GRID	WUDNR105	11kV FDR S/STN,NO21 UDYOG NAGAR	630UNR-PEG007A	630	RESIDENTIAL		Functional	100%	0	0.03			
33 kV UDYOG NAGAR GRID	WUDNR108	11kV FDR S/STN,NO22 UDYOG NAGAR	630UNR-PEG002A	400	RESIDENTIAL		Functional	100%	0	0.03			
33 kV UDYOG NAGAR GRID	WUDNR109	11kV FDR UDYOG NAGAR SSTN NO-3 (NEW)	630UNR-PEG012A	400	INDUSTRIAL		Functional	100%	4	0.02			
33 kV UDYOG NAGAR GRID	WUDNR109	11kV FDR UDYOG NAGAR SSTN NO-3 (NEW)	630UNR-PEG003A	990	INDUSTRIAL		Functional	100%	4	0.02			
33 kV UDYOG NAGAR GRID	WUDNR102	11kV STR 100KVA STATION TRANSFORMER	TP-WTC021A-1	100	RESIDENTIAL		Functional	100%	1	0.02			
33 kV UDYOG NAGAR GRID	WUDNR104	11kV FDR O/G S/STN.NO-3 UDYOG NGR(OLD)	630UNR-PEG003B	990	INDUSTRIAL		Functional	100%	0	0.02			
66 kV NANGLOI GRID	WNNGL112	11kV FDR NANGLOI NO 22	TG-NAG002A-1	630	RESIDENTIAL		Functional	100%	728	0.68	2.78	0.27	9.01%
66 kV NANGLOI GRID	WNNGL112	11kV FDR NANGLOI NO 22	TG-NAG001A-1	990	RESIDENTIAL		Functional	100%	855	0.68			
66 kV NANGLOI GRID	WNNGL112	11kV FDR NANGLOI NO 22	TG-NAG004A-1	990	RESIDENTIAL		Functional	100%	985	0.63			
66 kV NANGLOI GRID	WNNGL112	11kV FDR NANGLOI NO 22	TG-NAG003A-1	990	RESIDENTIAL		Functional	100%	833	0.56			
66 kV NANGLOI GRID	WNNGL112	11kV FDR NANGLOI NO 22	TG-NAG001A-2	990	RESIDENTIAL		Functional	100%	479	0.50			
66kV NILOTHI GRID	WNILO105	11kV FDR RAJIV RATAN-2	TP-NAG046A-1	990	RESIDENTIAL		Functional	100%	1745	1.06	7.20	0.23	3.14%
66kV NILOTHI GRID	WNILO105	11kV FDR RAJIV RATAN-2	TP-NAG156A-1	990	RESIDENTIAL		Functional	100%	1618	0.88			
66kV NILOTHI GRID	WNILO111	11kV FDR BAPROLA OLD O/H	TP-NAG155A-1	990	RESIDENTIAL		Functional	100%	1326	0.81			
66kV NILOTHI GRID	WNILO108	11kV FDR AMBEDKAR CHOWK	TP-NAG154A-1	990	RESIDENTIAL		Functional	100%	1377	0.66			
66kV NILOTHI GRID	WNILO111	11kV FDR BAPROLA OLD O/H	TP-NAG073A-1	630	RESIDENTIAL		Functional	100%	1146	0.61			
66kV NILOTHI GRID	WNILO111	11kV FDR BAPROLA OLD O/H	TG-NAG072A-1	630	RESIDENTIAL		Functional	100%	1144	0.56			
66kV NILOTHI GRID	WNILO108	11kV FDR AMBEDKAR CHOWK	TG-NAG150A-1	990	RESIDENTIAL		Functional	100%	734	0.44			
66kV NILOTHI GRID	WNILO105	11kV FDR RAJIV RATAN-2	TG-NAG153A-1	400	RESIDENTIAL		Functional	100%	810	0.44			
66kV NILOTHI GRID	WNILO105	11kV FDR RAJIV RATAN-2	TP-NAG047A-1	630	RESIDENTIAL		Functional	100%	870	0.39			
66kV NILOTHI GRID	WNILO111	11kV FDR BAPROLA OLD O/H	TP-NAG152A-1	630	RESIDENTIAL		Functional	100%	581	0.37			
66kV NILOTHI GRID	WNILO111	11kV FDR BAPROLA OLD O/H	TP-NAG151A-1	400	RESIDENTIAL		Functional	100%	589	0.36			
66kV NILOTHI GRID	WNILO105	11kV FDR RAJIV RATAN-2	TP-NAG047A-2	400	RESIDENTIAL		Functional	100%	152	0.29			
66kV NILOTHI GRID	WNILO105	11kV FDR RAJIV RATAN-2	TP-NAG118A-1	400	RESIDENTIAL		Functional	100%	417	0.26			
66kV NILOTHI GRID	WNILO105	11kV FDR RAJIV RATAN-2	630BPR-NAG236A	990	MIXED		Functional	100%	0	0.20			
66kV NILOTHI GRID	WNILO105	11kV FDR RAJIV RATAN-2	630BPR-NAG224A	400	RESIDENTIAL		Functional	100%	76	0.05			
66kV NILOTHI GRID	WNILO105	11kV FDR RAJIV RATAN-2	630BPR-NAG226A	400	RESIDENTIAL		Functional	100%	14	0.03			
66kV NILOTHI GRID	WNILO111	11kV FDR BAPROLA OLD O/H	630BPR-NAG230A	100	MIXED		Functional	100%	0	0.02			
66 kV NANGLOI W.W GRID	WNNWW112	11kV FDR SAINI MOHALLA	TG-NAG033A-1	1600	RESIDENTIAL		Functional	100%	1508	1.26	6.49	0.05	0.77%
66kV NILOTHI GRID	WNILO117	11kV FDR LAXMI PARK NO22	TP-NAG105A-2	990	RESIDENTIAL		Functional	100%	580	1.26			
66kV NILOTHI GRID	WNILO117	11kV FDR LAXMI PARK NO22	TP-NAG035A-2	990	RESIDENTIAL		Functional	100%	1596	1.01			
66kV NILOTHI GRID	WNILO117	11kV FDR LAXMI PARK NO22	TP-NAG196A-1	990	RESIDENTIAL		Functional	100%	231	0.67			
66kV NILOTHI GRID	WNILO117	11kV FDR LAXMI PARK NO22	TI-NAG034A-3	630	RESIDENTIAL		Functional	100%	2358	0.56			
66kV NILOTHI GRID	WNILO117	11kV FDR LAXMI PARK NO22	TI-NAG034A-2	990	RESIDENTIAL		Functional	100%	1089	0.53			

66kV NILOTHI GRID	WNILO117	11kV FDR LAXMI PARK NO2	TP-NAG035A-1	630	RESIDENTIAL	Functional	100%	96	0.51			
66 kV NANGLOI GRID	WNNGL120	11kV FDR NANGLOI2	TP-NAG029A-2	630	RESIDENTIAL	Functional	100%	92	0.31			
66 kV NANGLOI GRID	WNNGL120	11kV FDR NANGLOI2	TP-NAG029A-1	630	RESIDENTIAL	Functional	100%	108	0.29			
66kV NILOTHI GRID	WNILO117	11kV FDR LAXMI PARK NO2	TP-NAG144A-1	630	RESIDENTIAL	Functional	100%	1140	0.16			
33 kV UDYOG NAGAR GRID	WUDNR107	11kV FDR S/STN NO22 MIANWALI NGR (NEW)	630GH9-PEG065A	990	RESIDENTIAL	Functional	100%	74	0.69	4.46	0.49	9.86%
33 kV UDYOG NAGAR GRID	WUDNR107	11kV FDR S/STN NO22 MIANWALI NGR (NEW)	630GH9-PEG064A	990	RESIDENTIAL	Functional	100%	174	0.57			
33 kV UDYOG NAGAR GRID	WUDNR107	11kV FDR S/STN NO22 MIANWALI NGR (NEW)	TG-PEG122A-1	630	RESIDENTIAL	Functional	100%	133	0.55			
33 kV UDYOG NAGAR GRID	WUDNR116	11kV FDR S/STN NO21 MIANWALI NAGAR	630GH9-PEG063A	630	RESIDENTIAL	Functional	100%	145	0.52			
33 kV UDYOG NAGAR GRID	WUDNR107	11kV FDR S/STN NO22 MIANWALI NGR (NEW)	630GH9-PEG064A	630	RESIDENTIAL	Functional	100%	510	0.48			
33 kV UDYOG NAGAR GRID	WUDNR107	11kV FDR S/STN NO22 MIANWALI NGR (NEW)	630GH9-PEG065A	630	RESIDENTIAL	Functional	100%	0	0.47			
33 kV UDYOG NAGAR GRID	WUDNR116	11kV FDR S/STN NO21 MIANWALI NAGAR	630GH9-PEG063A	630	RESIDENTIAL	Functional	100%	175	0.43			
66 kV NANGLOI GRID	WNNGL114	11kV FDR SHANKAR GARDEN	630GH9-PEG031A	630	RESIDENTIAL	Functional	100%	362	0.41			
33 kV UDYOG NAGAR GRID	WUDNR107	11kV FDR S/STN NO22 MIANWALI NGR (NEW)	630GH9-PEG064A	630	RESIDENTIAL	Functional	100%	0	0.31			
66 kV NANGLOI GRID	WNNGL114	11kV FDR SHANKAR GARDEN	630GH9-PEG031A	630	RESIDENTIAL	Functional	100%	0	0.25			
33 kV UDYOG NAGAR GRID	WUDNR107	11kV FDR S/STN NO22 MIANWALI NGR (NEW)	630GH9-PEG065A	990	RESIDENTIAL	Functional	100%	735	0.24			
33 kV UDYOG NAGAR GRID	WUDNR107	11kV FDR S/STN NO22 MIANWALI NGR (NEW)	TP-PEG117A-1	400	RESIDENTIAL	Functional	100%	10	0.03			
66kV NILOTHI GRID	WNILO106	11kV FDR RAJIV RATAN-1	TP-NAG110A-1	400	RESIDENTIAL	Functional	100%	745	0.63	2.94	0.05	1.58%
66kV NILOTHI GRID	WNILO106	11kV FDR RAJIV RATAN-1	TP-NAG109A-1	990	RESIDENTIAL	Functional	100%	832	0.46			
66kV NILOTHI GRID	WNILO106	11kV FDR RAJIV RATAN-1	TP-NAG113A-1	400	RESIDENTIAL	Functional	100%	442	0.35			
66kV NILOTHI GRID	WNILO106	11kV FDR RAJIV RATAN-1	TP-NAG115A-1	400	RESIDENTIAL	Functional	100%	531	0.34			
66kV NILOTHI GRID	WNILO106	11kV FDR RAJIV RATAN-1	TP-NAG111A-1	400	RESIDENTIAL	Functional	100%	531	0.34			
66kV NILOTHI GRID	WNILO106	11kV FDR RAJIV RATAN-1	TP-NAG107A-1	400	RESIDENTIAL	Functional	100%	558	0.31			
66kV NILOTHI GRID	WNILO106	11kV FDR RAJIV RATAN-1	TP-NAG114A-1	400	RESIDENTIAL	Functional	100%	295	0.30			
66kV NILOTHI GRID	WNILO106	11kV FDR RAJIV RATAN-1	TP-NAG112A-1	400	RESIDENTIAL	Functional	100%	555	0.25			
66 kV NANGLOI W.W GRID	WNNWW124	11kV FDR HARIJAN BASTI	TI-NAG180A-1	1600	INDUSTRIAL	Functional	100%	126	1.54	6.83	1.02	13.02%
66 kV NANGLOI W.W GRID	WNNWW112	11kV FDR SAINI MOHALLA	TG-NAG020A-1	1600	RESIDENTIAL	Functional	100%	0	1.37			
66 kV NANGLOI GRID	WNNGL115	11kV FDR JAT MOHALLA	TG-NAG021A-1	990	INDUSTRIAL	Functional	100%	1436	0.96			
66 kV NANGLOI W.W GRID	WNNWW124	11kV FDR HARIJAN BASTI	TG-NAG020A-2	990	INDUSTRIAL	Functional	100%	245	0.78			
66kV NILOTHI GRID	WNILO138	11kV FDR AMANPURI HVDS	TI-NAG140A-1	990	INDUSTRIAL	Functional	100%	136	0.76			
66 kV NANGLOI W.W GRID	WNNWW124	11kV FDR HARIJAN BASTI	TI-NAG136A-1	990	COMMERCIAL	Functional	100%	87	0.72			
66 kV NANGLOI W.W GRID	WNNWW124	11kV FDR HARIJAN BASTI	630NGL-NAG227A	630	RESIDENTIAL	Functional	100%	27	0.61			
66 kV NANGLOI W.W GRID	WNNWW124	11kV FDR HARIJAN BASTI	630NGL-NAG235A	630	MIXED	Functional	100%	0	0.47			
66 kV NANGLOI W.W GRID	WNNWW124	11kV FDR HARIJAN BASTI	TG-NAG134A-1	630	RESIDENTIAL	Functional	100%	17	0.31			
66kV NILOTHI GRID	WNILO138	11kV FDR AMANPURI HVDS	TG-NAG140A-2	630	RESIDENTIAL	Functional	100%	0	0.29			
66 kV NANGLOI W.W GRID	WNNWW112	11kV FDR SAINI MOHALLA	TP-NAG063A-1	100	RESIDENTIAL	Functional	100%	4	0.03			
66 kV NANGLOI W.W GRID	WNNWW112	11kV FDR SAINI MOHALLA	TP-NAG135A-1	100	COMMERCIAL	Functional	100%	1	0.02			
66 kV PASCHIM VIHAR GRID	WPSCV117	11kV FDR HANUMAN MANDIR	TP-NAG043A-1	990	RESIDENTIAL	Functional	100%	902	1.16	5.89	0.25	4.09%
66 kV PASCHIM VIHAR GRID	WPSCV136	11kV FDR SHIVRAM PARK	TP-NAG166A-1	990	RESIDENTIAL	Functional	100%	773	1.01			
66 kV PASCHIM VIHAR GRID	WPSCV117	11kV FDR HANUMAN MANDIR	TP-NAG039A-2	990	RESIDENTIAL	Functional	100%	480	1.00			
66 kV PASCHIM VIHAR GRID	WPSCV117	11kV FDR HANUMAN MANDIR	TG-NAG167A-1	630	RESIDENTIAL	Functional	100%	1177	0.66			
66 kV PASCHIM VIHAR GRID	WPSCV117	11kV FDR HANUMAN MANDIR	TP-NAG106A-1	630	RESIDENTIAL	Functional	100%	1080	0.64			
66 kV PASCHIM VIHAR GRID	WPSCV117	11kV FDR HANUMAN MANDIR	TP-NAG039A-1	630	RESIDENTIAL	Functional	100%	3154	0.63			
66 kV PASCHIM VIHAR GRID	WPSCV117	11kV FDR HANUMAN MANDIR	630NGL-NAG167A	990	RESIDENTIAL	Functional	100%	0	0.59			
66 kV PASCHIM VIHAR GRID	WPSCV117	11kV FDR HANUMAN MANDIR	TP-NAG132A-1	400	RESIDENTIAL	Functional	100%	533	0.44			
66 kV PASCHIM VIHAR GRID	WPSCV128	11kV FDR NIHAL VIHAR	TG-NAG038A-1	1600	RESIDENTIAL	Functional	100%	1725	0.97	9.19	0.11	1.20%
66 kV PASCHIM VIHAR GRID	WPSCV128	11kV FDR NIHAL VIHAR	TG-NAG037A-1	990	RESIDENTIAL	Functional	100%	1291	0.86			
66 kV PASCHIM VIHAR GRID	WPSCV117	11kV FDR HANUMAN MANDIR	TP-NAG190A-1	630	RESIDENTIAL	Functional	100%	124	0.84			
66 kV PASCHIM VIHAR GRID	WPSCV117	11kV FDR HANUMAN MANDIR	TP-NAG044A-2	990	RESIDENTIAL	Functional	100%	1772	0.79			
66 kV PASCHIM VIHAR GRID	WPSCV127	11kV FDR E-BLOCK NIHAL VIHAR	TG-NAG085A-1	990	RESIDENTIAL	Functional	100%	957	0.73			
66 kV PASCHIM VIHAR GRID	WPSCV117	11kV FDR HANUMAN MANDIR	TP-NAG190A-2	630	RESIDENTIAL	Functional	100%	0	0.72			

66kV NILOTHI GRID	WNILO117	11kV FDR LAXMI PARK NO2	TP-NAG007A-1	990	RESIDENTIAL		Functional	100%	936	0.71			
66 kV PASCHIM VIHAR GRID	WPSCV130	11kV FDR A BLK NIHAL VIHAR	630NGL-NAG228A	630	RESIDENTIAL		Functional	100%	383	0.69			
66 kV PASCHIM VIHAR GRID	WPSCV127	11kV FDR E-BLOCK NIHAL VIHAR	TG-NAG040A-1	990	RESIDENTIAL		Functional	100%	2042	0.68			
66 kV PASCHIM VIHAR GRID	WPSCV128	11kV FDR NIHAL VIHAR	TG-NAG036B-2	990	RESIDENTIAL		Functional	100%	0	0.64			
66 kV PASCHIM VIHAR GRID	WPSCV128	11kV FDR NIHAL VIHAR	TG-NAG036A-1	990	RESIDENTIAL		Functional	100%	492	0.51			
66 kV PASCHIM VIHAR GRID	WPSCV127	11kV FDR E-BLOCK NIHAL VIHAR	630NGL-NAG040A	630	RESIDENTIAL		Functional	100%	0	0.44			
66 kV PASCHIM VIHAR GRID	WPSCV128	11kV FDR NIHAL VIHAR	TG-NAG036A-2	990	RESIDENTIAL		Functional	100%	1949	0.31			
66 kV PASCHIM VIHAR GRID	WPSCV117	11kV FDR HANUMAN MANDIR	630NGL-NAG190A	630	RESIDENTIAL		Functional	100%	0	0.29			
66 kV PASCHIM VIHAR GRID	WPSCV117	11kV FDR HANUMAN MANDIR	TP-NAG044A-1	630	RESIDENTIAL		Functional	100%	0	0.13			
66 kV PASCHIM VIHAR GRID	WPSCV127	11kV FDR E-BLOCK NIHAL VIHAR	TP-NAG130A-2	990	RESIDENTIAL		Functional	100%	2678	1.15	6.70	1.03	13.37%
66 kV PASCHIM VIHAR GRID	WPSCV132	11kV FDR F & S BLOCK NIHAL VIHAR	TP-NAG087A-1	990	RESIDENTIAL		Functional	100%	666	0.90			
66 kV PASCHIM VIHAR GRID	WPSCV127	11kV FDR E-BLOCK NIHAL VIHAR	TP-NAG160A-1	990	RESIDENTIAL		Functional	100%	687	0.76			
66 kV NANGLOI W.W GRID	WNNWW125	11kV FDR RAJEEV RATAN NO21	TP-NAG131A-1	400	RESIDENTIAL		Functional	100%	490	0.73			
66kV NILOTHI GRID	WNILO117	11kV FDR LAXMI PARK NO2	TP-NAG042A-1	990	RESIDENTIAL		Functional	100%	773	0.70			
66 kV PASCHIM VIHAR GRID	WPSCV132	11kV FDR F & S BLOCK NIHAL VIHAR	TP-NAG161A-1	630	RESIDENTIAL		Functional	100%	196	0.61			
66 kV PASCHIM VIHAR GRID	WPSCV127	11kV FDR E-BLOCK NIHAL VIHAR	TP-NAG130A-1	630	RESIDENTIAL		Functional	100%	670	0.59			
66 kV PASCHIM VIHAR GRID	WPSCV132	11kV FDR F & S BLOCK NIHAL VIHAR	TP-NAG008A-1	400	RESIDENTIAL		Functional	100%	175	0.48			
66 kV PASCHIM VIHAR GRID	WPSCV132	11kV FDR F & S BLOCK NIHAL VIHAR	TP-NAG162A-1	990	RESIDENTIAL		Functional	100%	977	0.38			
66 kV PASCHIM VIHAR GRID	WPSCV132	11kV FDR F & S BLOCK NIHAL VIHAR	TG-NAG103A-1	400	RESIDENTIAL		Functional	100%	380	0.34			
66 kV PASCHIM VIHAR GRID	WPSCV132	11kV FDR F & S BLOCK NIHAL VIHAR	TP-NAG041A-1	400	RESIDENTIAL		Functional	100%	379	0.34			
66 kV PASCHIM VIHAR GRID	WPSCV132	11kV FDR F & S BLOCK NIHAL VIHAR	TP-NAG088A-1	400	RESIDENTIAL		Functional	100%	944	0.28			
66 kV PASCHIM VIHAR GRID	WPSCV115	11kV FDR NILOTHI	TP-NAG139A-1	400	RESIDENTIAL		Functional	100%	365	0.26			
66 kV PASCHIM VIHAR GRID	WPSCV132	11kV FDR F & S BLOCK NIHAL VIHAR	TP-NAG164A-1	400	RESIDENTIAL		Functional	100%	36	0.21			
66 kV PASCHIM VIHAR GRID	WPSCV118	11kV FDR STP NILOTHI(SHIV VIHAR)	TG-NAG158A-1	630	MIXED		Functional	100%	1095	0.86	3.48	0.21	5.71%
66 kV PASCHIM VIHAR GRID	WPSCV118	11kV FDR STP NILOTHI(SHIV VIHAR)	TG-NAG159A-1	630	MIXED		Functional	100%	800	0.78			
66kV NILOTHI GRID	WNILO139	11kV FDR DEEPAK VIHAR	TP-NAG054A-1	630	RESIDENTIAL		Functional	100%	425	0.49			
66kV NILOTHI GRID	WNILO128	11kV FDR DJB SPS NILOTHI NO.-2	TP-NAG052A-1	400	RESIDENTIAL		Functional	100%	283	0.36			
66kV NILOTHI GRID	WNILO128	11kV FDR DJB SPS NILOTHI NO.-2	TG-NAG053A-1	630	RESIDENTIAL		Functional	100%	311	0.35			
66 kV PASCHIM VIHAR GRID	WPSCV118	11kV FDR STP NILOTHI(SHIV VIHAR)	630BPR-HVD018A	450	RESIDENTIAL	AMR	Functional	100%	513	0.30			
66 kV PASCHIM VIHAR GRID	WPSCV118	11kV FDR STP NILOTHI(SHIV VIHAR)	NG-HVD007A-1	350	RESIDENTIAL		Functional	100%	297	0.22			
66kV NILOTHI GRID	WNILO128	11kV FDR DJB SPS NILOTHI NO.-2	TG-NAG206A-1	630	RESIDENTIAL		Functional	100%	169	0.20			
66kV NILOTHI GRID	WNILO128	11kV FDR DJB SPS NILOTHI NO.-2	TP-NAG083A-1	400	RESIDENTIAL		Functional	100%	189	0.11			
66kV NILOTHI GRID	WNILO128	11kV FDR DJB SPS NILOTHI NO.-2	TP-NAG012A-1	100	RESIDENTIAL		Functional	100%	0	0.02			
33 kV PASCHIM PURI GRID	WPSCP123	11kV FDR PEERAGRAHI S/STN NO27	630GH9-PEG025A	990	MIXED		Functional	100%	280	0.62	6.49	0.63	8.84%
33 kV PASCHIM PURI GRID	WPSCP123	11kV FDR PEERAGRAHI S/STN NO27	630GH9-PEG022A	990	MIXED		Functional	100%	348	0.61			
33 kV PASCHIM PURI GRID	WPSCP109	11kV FDR PEERA GARHI SS NO-3	630GH9-PEG027A	990	MIXED		Functional	100%	232	0.55			
33 kV PASCHIM PURI GRID	WPSCP125	11kV FDR MTNL NO-2	630GH9-PEG023A	990	MIXED		Functional	100%	378	0.55			
33 kV PASCHIM PURI GRID	WPSCP125	11kV FDR MTNL NO-2	630GH9-PEG029A	990	MIXED		Functional	100%	188	0.50			
66 kV NANGLOI GRID	WNNGL114	11kV FDR SHANKAR GARDEN	630GH9-PEG030A	990	RESIDENTIAL		Functional	100%	360	0.50			
33 kV PASCHIM PURI GRID	WPSCP109	11kV FDR PEERA GARHI SS NO-3	630GH9-PEG020A	990	MIXED		Functional	100%	163	0.49			
33 kV PASCHIM PURI GRID	WPSCP123	11kV FDR PEERAGRAHI S/STN NO27	630GH9-PEG018A	990	RESIDENTIAL		Functional	100%	237	0.43			
33 kV PASCHIM PURI GRID	WPSCP109	11kV FDR PEERA GARHI SS NO-3	630GH9-PEG021A	990	MIXED		Functional	100%	208	0.42			
33 kV PASCHIM PURI GRID	WPSCP123	11kV FDR PEERAGRAHI S/STN NO27	630GH9-PEG019A	990	MIXED		Functional	100%	119	0.31			
33 kV PASCHIM PURI GRID	WPSCP123	11kV FDR PEERAGRAHI S/STN NO27	630GH9-PEG024A	990	MIXED		Functional	100%	163	0.31			
33 kV PASCHIM PURI GRID	WPSCP125	11kV FDR MTNL NO-2	630GH9-PEG026A	990	MIXED		Functional	100%	101	0.27			
66 kV NANGLOI GRID	WNNGL114	11kV FDR SHANKAR GARDEN	TG-PEG201A-1	630	RESIDENTIAL		Functional	100%	115	0.23			
33 kV PASCHIM PURI GRID	WPSCP108	11kV FDR UDYOG NAGAR NO-1 (BHERA ENCLAVE)	TI-PEG101A-1	630	RESIDENTIAL		Functional	100%	159	0.23			
33 kV PASCHIM PURI GRID	WPSCP123	11kV FDR PEERAGRAHI S/STN NO27	TI-PEG100A-1	630	RESIDENTIAL		Functional	100%	92	0.23			
33 kV PASCHIM PURI GRID	WPSCP125	11kV FDR MTNL NO-2	630GH9-PEG028A	630	MIXED		Functional	100%	109	0.22			
33 kV PASCHIM PURI GRID	WPSCP123	11kV FDR PEERAGRAHI SS-7	630GH9-PEG024B	990	MIXED		Functional	100%	0	0.20			

66 kv NANGLOI GRID	WNNG114	11kv FDR SHANKAR GARDEN	TI-PEG099A-1	630	RESIDENTIAL	Functional	100%	182	0.18			
33 kv PASCHIM PURI GRID	WPSCP109	11kv FDR PEERA GARHI SS NO-3	TI-PEG102A-1	630	RESIDENTIAL	Functional	100%	80	0.17			
66 kv NANGLOI GRID	WNNG114	11kv FDR SHANKAR GARDEN	TI-PEG099A-2	400	RESIDENTIAL	Functional	100%	47	0.10			
66 kv NANGLOI W.W GRID	WNNW109	11kv FDR SHIV RAM PARK	NG-HVD002A-1	3400	RESIDENTIAL	Functional	100%	1864	1.88	9.92	0.10	0.95%
66kv NILOTHI GRID	WNILO124	11kv FDR ADHYAPAK NAGAR	TG-NAG055A-1	1600	RESIDENTIAL	Functional	100%	1089	1.12			
66 kv NANGLOI W.W GRID	WNNW103	11kv FDR RAJEEV RATAN NO2	NG-HVD012A-1	1875	RESIDENTIAL	Functional	100%	2531	1.00			
66 kv NANGLOI W.W GRID	WNNW103	11kv FDR RAJEEV RATAN NO2	630NGL-HVD016A-	2025	COMMERCIAL	Functional	100%	488	0.89			
66 kv PASCHIM VIHAR GRID	WPSCV118	11kv FDR STP NILOTHI(SHIV VIHAR)	NG-HVD009A-1	1375	RESIDENTIAL	Functional	100%	1091	0.78			
66kv NILOTHI GRID	WNILO138	11kv FDR AMANPURI HVDS	NG-HVD001A-1	1325	MIXED	Functional	100%	253	0.78			
66kv NILOTHI GRID	WNILO124	11kv FDR ADHYAPAK NAGAR	TG-NAG128A-1	990	RESIDENTIAL	Functional	100%	684	0.74			
66kv NILOTHI GRID	WNILO124	11kv FDR ADHYAPAK NAGAR	TP-NAG060A-1	990	RESIDENTIAL	Functional	100%	1293	0.71			
66 kv NANGLOI W.W GRID	WNNW125	11kv FDR RAJEEV RATAN NO21	TG-NAG057A-1	990	RESIDENTIAL	Functional	100%	905	0.64			
66 kv NANGLOI W.W GRID	WNNW125	11kv FDR RAJEEV RATAN NO21	TP-NAG129A-1	630	RESIDENTIAL	Functional	100%	978	0.58			
66 kv NANGLOI W.W GRID	WNNW125	11kv FDR RAJEEV RATAN NO21	TP-NAG058A-1	630	RESIDENTIAL	Functional	100%	1632	0.44			
66 kv NANGLOI W.W GRID	WNNW125	11kv FDR RAJEEV RATAN NO21	630NGL-HVD019A-	1475	MIXED	Functional	100%	0	0.36			
66kv NILOTHI GRID	WNILO138	11kv FDR AMANPURI HVDS	630NGL-HVD001A-	100	MIXED	Functional	100%	0	0.05			
66 kv NANGLOI W.W GRID	WNNW109	11kv FDR SHIV RAM PARK	TP-NAG194A-1	100	COMMERCIAL	Functional	100%	92	0.02			
66 kv NANGLOI W.W GRID	WNNW109	11kv FDR SHIV RAM PARK	630NGL-HVD015A-	250	RESIDENTIAL	Functional	100%	1	0.02			
66 kv PASCHIM VIHAR GRID	WPSCP109	11kv FDR LIC COLONY	TP-PEG076A-1	990	RESIDENTIAL	Functional	100%	327	0.75	1.95	0.16	7.40%
66 kv PASCHIM VIHAR GRID	WPSCV120	11kv FDR 656 MIG FLATS	630GH9-PEG077A-	630	RESIDENTIAL	Functional	100%	270	0.27			
66 kv PASCHIM VIHAR GRID	WPSCP109	11kv FDR LIC COLONY	630GH9-PEG075A-	630	RESIDENTIAL	Functional	100%	186	0.25			
66 kv PASCHIM VIHAR GRID	WPSCV120	11kv FDR 656 MIG FLATS	630GH9-PEG077A-	630	RESIDENTIAL	Functional	100%	102	0.21			
66 kv PASCHIM VIHAR GRID	WPSCV120	11kv FDR 656 MIG FLATS	630GH9-PEG078A-	630	RESIDENTIAL	Functional	100%	71	0.19			
66 kv PASCHIM VIHAR GRID	WPSCV120	11kv FDR 656 MIG FLATS	630GH9-PEG078A-	630	RESIDENTIAL	Functional	100%	293	0.17			
66 kv PASCHIM VIHAR GRID	WPSCP109	11kv FDR LIC COLONY	630GH9-PEG075A-	630	RESIDENTIAL	Functional	100%	186	0.16			
33 kv PASCHIM PURI GRID	WPSCP125	11kv FDR MTNL NO-2	TI-PEG114A-1	630	RESIDENTIAL	Functional	100%	42	0.04			
33 kv PASCHIM PURI GRID	WPSCP125	11kv FDR MTNL NO-2	TI-PEG114A-2	630	RESIDENTIAL	Functional	100%	25	0.03			
33 kv PASCHIM PURI GRID	WPSCP125	11kv FDR MTNL NO-2	TI-PEG115A-1	630	RESIDENTIAL	Functional	100%	23	0.02			
33 kv PASCHIM PURI GRID	WPSCP125	11kv FDR MTNL NO-2	TI-PEG115A-2	630	RESIDENTIAL	Functional	100%	4	0.01			
66 kv NANGLOI GRID	WNNG115	11kv FDR JAT MOHALLA	TG-NAG019A-1	1600	RESIDENTIAL	Functional	100%	504	1.11	3.17	0.05	1.50%
66 kv NANGLOI W.W GRID	WNNW112	11kv FDR SAINI MOHALLA	TG-NAG025A-1	990	RESIDENTIAL	Functional	100%	1813	0.69			
66 kv NANGLOI GRID	WNNG115	11kv FDR JAT MOHALLA	TG-NAG165A-1	990	RESIDENTIAL	Functional	100%	153	0.56			
66 kv NANGLOI GRID	WNNG120	11kv FDR NANGLOI2	TP-NAG028A-1	400	MIXED	Functional	100%	63	0.47			
66 kv NANGLOI GRID	WNNG115	11kv FDR JAT MOHALLA	TG-NAG019A-2	990	RESIDENTIAL	Functional	100%	401	0.38			
66kv NILOTHI GRID	WNILO112	11kv FDR RAJIV RATAN-3	TI-NAG094A-2	630	RESIDENTIAL	Functional	100%	169	0.19	0.68	0.01	1.45%
66kv NILOTHI GRID	WNILO112	11kv FDR RAJIV RATAN-3	TI-NAG068A-2	630	RESIDENTIAL	Functional	100%	434	0.18			
66kv NILOTHI GRID	WNILO106	11kv FDR RAJIV RATAN-1	TI-NAG064A-2	630	RESIDENTIAL	Functional	100%	18	0.08			
66kv NILOTHI GRID	WNILO112	11kv FDR RAJIV RATAN-3	TI-NAG068A-1	630	RESIDENTIAL	Functional	100%	122	0.08			
66kv NILOTHI GRID	WNILO112	11kv FDR RAJIV RATAN-3	TI-NAG089A-1	630	COMMERCIAL	Functional	100%	19	0.04			
66kv NILOTHI GRID	WNILO106	11kv FDR RAJIV RATAN-1	TI-NAG064A-1	630	RESIDENTIAL	Functional	100%	202	0.04			
66kv NILOTHI GRID	WNILO112	11kv FDR RAJIV RATAN-3	TI-NAG089A-2	630	RESIDENTIAL	Functional	100%	222	0.04			
66kv NILOTHI GRID	WNILO112	11kv FDR RAJIV RATAN-3	TI-NAG094A-1	630	RESIDENTIAL	Functional	100%	272	0.03			
66kv NILOTHI GRID	WNILO105	11kv FDR RAJIV RATAN-2	TI-NAG023A-1	630	RESIDENTIAL	Functional	100%	1	0.01			
66kv NILOTHI GRID	WNILO105	11kv FDR RAJIV RATAN-2	TP-NAG006A-1	100	COMMERCIAL	Functional	100%	0	0.00			
66 kv NANGLOI W.W GRID	WNNW125	11kv FDR RAJEEV RATAN NO21	630NGL-HVD005A-	925	MIXED	Functional	100%	2058	0.60	4.80	0.93	16.18%
66 kv NANGLOI GRID	WNNG108	11kv FDR LAXMI PARK	TP-NAG032A-1	990	RESIDENTIAL	Functional	100%	722	1.23			
66 kv NANGLOI GRID	WNNG108	11kv FDR LAXMI PARK	NG-HVD013A-1	1425	RESIDENTIAL	Functional	100%	1315	1.21			
66 kv NANGLOI GRID	WNNG108	11kv FDR LAXMI PARK	630NGL-HVD017A-	2125	RESIDENTIAL	Functional	100%	360	0.77			
66 kv NANGLOI GRID	WNNG108	11kv FDR LAXMI PARK	NG-HVD010A-1	1575	RESIDENTIAL	Functional	100%	1634	0.74			
66 kv NANGLOI GRID	WNNG108	11kv FDR LAXMI PARK	NG-HVD004A-1	3450	RESIDENTIAL	Functional	100%	1761	0.69			

66 kV NANGLOI GRID	WNNG108	11kV FDR LAXMI PARK	NG-HVD014A-1	2900	RESIDENTIAL		Functional	100%	518	0.51			
66kV NILOTHI GRID	WNILO107	11kV FDR TP KOTLA	TG-NAG157A-1	990	RESIDENTIAL		Functional	100%	1410	1.08	2.90	0.31	9.68%
66kV NILOTHI GRID	WNILO111	11kV FDR BAPROLA OLD O/H	TP-NAG120A-1	400	RESIDENTIAL		Functional	100%	440	0.45			
66kV NILOTHI GRID	WNILO107	11kV FDR TP KOTLA	TP-NAG065A-1	630	RESIDENTIAL		Functional	100%	514	0.39			
66kV NILOTHI GRID	WNILO107	11kV FDR TP KOTLA	TG-NAG193A-1	630	RESIDENTIAL		Functional	100%	512	0.34			
66kV NILOTHI GRID	WNILO107	11kV FDR TP KOTLA	TP-NAG067A-1	400	RESIDENTIAL		Functional	100%	242	0.27			
66kV NILOTHI GRID	WNILO107	11kV FDR TP KOTLA	TG-NAG066B-1	990	RESIDENTIAL		Functional	100%	0	0.26			
66kV NILOTHI GRID	WNILO107	11kV FDR TP KOTLA	TG-NAG005A-1	400	RESIDENTIAL		Functional	100%	192	0.22			
66kV NILOTHI GRID	WNILO107	11kV FDR TP KOTLA	TG-NAG066A-1	990	RESIDENTIAL		Functional	100%	479	0.20			
66kV NILOTHI GRID	WNILO107	11kV FDR TP KOTLA	TP-NAG074A-1	990	RESIDENTIAL		Functional	100%	1106	0.78	3.47	0.27	7.22%
66kV NILOTHI GRID	WNILO111	11kV FDR BAPROLA OLD O/H	TP-NAG121A-1	990	RESIDENTIAL		Functional	100%	150	0.72			
66kV NILOTHI GRID	WNILO107	11kV FDR TP KOTLA	TP-NAG178A-1	630	RESIDENTIAL		Functional	100%	787	0.69			
66kV NILOTHI GRID	WNILO107	11kV FDR TP KOTLA	TP-NAG148A-1	630	RESIDENTIAL		Functional	100%	734	0.59			
66kV NILOTHI GRID	WNILO107	11kV FDR TP KOTLA	TG-NAG009A-1	630	RESIDENTIAL		Functional	100%	182	0.45			
66kV NILOTHI GRID	WNILO107	11kV FDR TP KOTLA	TP-NAG179A-1	400	RESIDENTIAL		Functional	100%	169	0.22			
66kV NILOTHI GRID	WNILO107	11kV FDR TP KOTLA	TP-NAG122A-1	400	RESIDENTIAL		Functional	100%	194	0.16			
66kV NILOTHI GRID	WNILO108	11kV FDR AMBEDKAR CHOWK	TP-NAG133A-2	400	RESIDENTIAL		Functional	100%	3	0.09			
66kV NILOTHI GRID	WNILO110	11kV STR 400KVA STATION TRANSFORMER	TG-WTC019A-1	400	RESIDENTIAL		Functional	100%	1	0.04			
66 kV BODELLA - 2 GRID	WBDL2103	11kV FDR GRAMSABHA NILOTHI	TP-NAG084A-1	990	RESIDENTIAL		Functional	100%	1306	1.12	3.15	0.24	7.14%
66 kV BODELLA - 2 GRID	WBDL2103	11kV FDR GRAMSABHA NILOTHI	TP-NAG126A-1	990	RESIDENTIAL		Functional	100%	636	0.59			
66kV NILOTHI GRID	WNILO139	11kV FDR DEEPAK VIHAR	TP-NAG125A-1	400	COMMERCIAL		Functional	100%	608	0.50			
66 kV BODELLA - 2 GRID	WBDL2103	11kV FDR GRAMSABHA NILOTHI	NG-HVD006A-1	1100	RESIDENTIAL		Functional	100%	633	0.47			
66 kV BODELLA - 2 GRID	WBDL2103	11kV FDR GRAMSABHA NILOTHI	TP-NAG146A-1	400	RESIDENTIAL		Functional	100%	449	0.36			
66 kV BODELLA - 2 GRID	WBDL2103	11kV FDR GRAMSABHA NILOTHI	TP-NAG145A-1	400	RESIDENTIAL		Functional	100%	356	0.35			
66kV NILOTHI GRID	WNILO108	11kV FDR AMBEDKAR CHOWK	TP-NAG142A-2	990	RESIDENTIAL		Functional	100%	1698	1.03	4.57	0.16	3.36%
66kV NILOTHI GRID	WNILO112	11kV FDR RAJIV RATAN-3	TP-NAG086A-2	990	RESIDENTIAL		Functional	100%	1795	0.98			
66kV NILOTHI GRID	WNILO108	11kV FDR AMBEDKAR CHOWK	TP-NAG137A-1	990	RESIDENTIAL		Functional	100%	1886	0.80			
66kV NILOTHI GRID	WNILO108	11kV FDR AMBEDKAR CHOWK	630BPR-NAG108A	630	RESIDENTIAL		Functional	100%	0	0.51			
66kV NILOTHI GRID	WNILO112	11kV FDR RAJIV RATAN-3	TP-NAG149A-1	990	RESIDENTIAL		Functional	100%	1121	0.47			
66kV NILOTHI GRID	WNILO108	11kV FDR AMBEDKAR CHOWK	630BPR-NAG137A	400	RESIDENTIAL		Functional	100%	0	0.32			
66kV NILOTHI GRID	WNILO112	11kV FDR RAJIV RATAN-3	TP-NAG086A-1	400	RESIDENTIAL		Functional	100%	585	0.31			
66kV NILOTHI GRID	WNILO108	11kV FDR AMBEDKAR CHOWK	TP-NAG108A-1	630	RESIDENTIAL		Functional	100%	926	0.30			
66 kV PASCHIM VIHAR GRID	WPSCV126	11kV FDR MEERA BAGH	630GH9-PEG032A	990	RESIDENTIAL		Functional	100%	147	0.70	4.04	0.21	4.91%
66 kV PASCHIM VIHAR GRID	WPSCV126	11kV FDR MEERA BAGH	630GH9-PEG032A	990	RESIDENTIAL		Functional	100%	729	0.66			
66 kV PASCHIM VIHAR GRID	WPSCV112	11kV FDR 1312 LIG FLATS	630GH9-PEG049A	990	RESIDENTIAL		Functional	100%	13	0.55			
66 kV PASCHIM VIHAR GRID	WPSCV126	11kV FDR MEERA BAGH	630GH9-PEG033A	990	RESIDENTIAL		Functional	100%	0	0.48			
66 kV PASCHIM VIHAR GRID	WPSCV126	11kV FDR MEERA BAGH	630GH9-PEG033A	990	RESIDENTIAL		Functional	100%	330	0.37			
66 kV PASCHIM VIHAR GRID	WPSCV112	11kV FDR 1312 LIG FLATS	630GH9-PEG048A	630	RESIDENTIAL		Functional	100%	427	0.31			
66 kV PASCHIM VIHAR GRID	WPSCV112	11kV FDR 1312 LIG FLATS	630GH9-PEG046A	400	RESIDENTIAL		Functional	100%	176	0.29			
66 kV PASCHIM VIHAR GRID	WPSCV112	11kV FDR 1312 LIG FLATS	630GH9-PEG047A	630	RESIDENTIAL		Functional	100%	281	0.24			
66 kV PASCHIM VIHAR GRID	WPSCV126	11kV FDR MEERA BAGH	630GH9-PEG034A	400	RESIDENTIAL		Functional	100%	110	0.18			
66 kV PASCHIM VIHAR GRID	WPSCV112	11kV FDR 1312 LIG FLATS	630GH9-PEG047A	630	RESIDENTIAL		Functional	100%	75	0.17			
66 kV PASCHIM VIHAR GRID	WPSCV112	11kV FDR 1312 LIG FLATS	630GH9-PEG046A	630	RESIDENTIAL		Functional	100%	436	0.13			
66 kV PASCHIM VIHAR GRID	WPSCV112	11kV FDR 1312 LIG FLATS	TI-PEG048A-2	630	RESIDENTIAL		Functional	100%	474	0.12			
66 kV PASCHIM VIHAR GRID	WPSCV108	11kV STR 400KVA STATION TRANSFORMER	PB-WTC018A-1	400	MIXED		Functional	100%	1	0.03			
66 kV NANGLOI GRID	WNNG120	11kV FDR NANGLOI $\frac{1}{2}$	TG-NAG027A-1	990	RESIDENTIAL		Functional	100%	777	1.06	2.87	0.39	11.97%
66 kV NANGLOI GRID	WNNG113	11kV FDR RAIL NEER PLANT	TG-NAG076A-1	990	MIXED		Functional	100%	1401	0.73			
66 kV NANGLOI GRID	WNNG120	11kV FDR NANGLOI $\frac{1}{2}$	TG-NAG026A-1	630	MIXED		Functional	100%	337	0.55			
66 kV NANGLOI GRID	WNNG113	11kV FDR RAIL NEER PLANT	TG-NAG076A-3	630	RESIDENTIAL		Functional	100%	0	0.50			
66 kV NANGLOI GRID	WNNG113	11kV FDR RAIL NEER PLANT	TG-NAG076A-2	630	RESIDENTIAL		Functional	100%	0	0.41			

66 kv TIKRI KALAN GRID	WMUND107	11kv FDR BABA HARIDAS	631TIK-MDK549A-	400	MIXED	AMR	Functional	100%	1	0.45	3.77	0.03	0.92%
66 kv TIKRI KALAN GRID	WMUND118	11kv FDR SUB STATION NO-5	TP-MDK058A-1	990	RESIDENTIAL	AMR	Functional	100%	432	0.71			
66 kv TIKRI KALAN GRID	WMUND109	11kv FDR BULBUL VATIKA	TP-MDK042A-1	630	RESIDENTIAL	AMR	Functional	100%	695	0.64			
66 kv TIKRI KALAN GRID	WMUND109	11kv FDR BULBUL VATIKA	TP-MDK041A-1	990	RESIDENTIAL		Functional	100%	289	0.52			
66 kv TIKRI KALAN GRID	WMUND109	11kv FDR BULBUL VATIKA	TP-MDK244A-1	990	RESIDENTIAL	AMR	Functional	100%	56	0.32			
66 kv TIKRI KALAN GRID	WMUND109	11kv FDR BULBUL VATIKA	TG-MDK383A-1	630	MIXED	AMR	Functional	100%	81	0.29			
66 kv TIKRI KALAN GRID	WMUND109	11kv FDR BULBUL VATIKA	TG-MDK339A-2	630	RESIDENTIAL		Functional	100%	0	0.26			
66 kv TIKRI KALAN GRID	WMUND118	11kv FDR SUB STATION NO-5	TG-MDK058A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.20			
66 kv NANGLOI W.W GRID	WNNWW119	11kv FDR TIKRI VILLAGE	TP-MDK526A-1	400	RESIDENTIAL	AMR	Functional	100%	54	0.19			
66 kv TIKRI KALAN GRID	WMUND109	11kv FDR BULBUL VATIKA	TP-MDK339A-1	400	MIXED	AMR	Functional	100%	120	0.11			
66 kv TIKRI KALAN GRID	WMUND109	11kv FDR BULBUL VATIKA	TI-MDK169A-1	630	MIXED	AMR	Functional	100%	190	0.09			
66 kv TIKRI KALAN GRID	WMUND109	11kv FDR BULBUL VATIKA	TI-MDK169A-2	630	MIXED	AMR	Functional	100%	0	0.03			
66 kv TIKRI KALAN GRID	WMUND107	11kv FDR BABA HARIDAS	TP-MDK387A-1	100	RESIDENTIAL	AMR	Functional	100%	90	0.01			
66 kv NANGLOI W.W GRID	WNNWW110	11kv FDR ARVIND ENCLAVE S/S ₂ 3	TI-MDK031A-2	990	RESIDENTIAL	AMR	Functional	100%	1086	0.75			
66 kv NANGLOI W.W GRID	WNNWW110	11kv FDR ARVIND ENCLAVE S/S ₂ 3	631SPK-MDK032A-	990	RESIDENTIAL	AMR	Functional	100%	1277	0.72			
66 kv NANGLOI W.W GRID	WNNWW110	11kv FDR ARVIND ENCLAVE S/S ₂ 3	TI-MDK036A-1	990	RESIDENTIAL	AMR	Functional	100%	808	0.64			
66 kv NANGLOI W.W GRID	WNNWW110	11kv FDR ARVIND ENCLAVE S/S ₂ 3	631SPK-MDK032A-	990	RESIDENTIAL	AMR	Functional	100%	588	0.45			
66 kv NANGLOI W.W GRID	WNNWW110	11kv FDR ARVIND ENCLAVE S/S ₂ 3	TI-MDK033A-2	630	RESIDENTIAL	AMR	Functional	100%	1219	0.44			
66 kv NANGLOI W.W GRID	WNNWW110	11kv FDR ARVIND ENCLAVE S/S ₂ 3	TI-MDK033A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.43			
66 kv NANGLOI W.W GRID	WNNWW110	11kv FDR ARVIND ENCLAVE S/S ₂ 3	TP-MDK221A-1	400	INDUSTRIAL	AMR	Functional	100%	306	0.38			
66 kv NANGLOI GRID	WNNGL117	11kv FDR BAKKAR WALA	TG-MDK050A-1	630	RESIDENTIAL		Functional	100%	193	0.31			
66 kv NANGLOI W.W GRID	WNNWW110	11kv FDR ARVIND ENCLAVE S/S ₂ 3	TP-MDK009A-1	400	RESIDENTIAL		Functional	100%	281	0.29			
66 kv NANGLOI W.W GRID	WNNWW110	11kv FDR ARVIND ENCL SS-3	631SPK-MDK032B-	990	RESIDENTIAL	AMR	Functional	100%	0	0.22			
66 kv NANGLOI W.W GRID	WNNWW110	11kv FDR ARVIND ENCLAVE S/S ₂ 3	TI-MDK031A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.17			
66 kv NANGLOI GRID	WNNGL117	11kv FDR BAKKAR WALA	TP-MDK230A-1	400	COMMERCIAL	AMR	Functional	100%	56	0.09			
66 kv NANGLOI W.W GRID	WNNWW113	11kv FDR YADAV PARK EXT	TI-MDK017A-1	630	RESIDENTIAL	AMR	Functional	100%	522	0.60			
66 kv NANGLOI W.W GRID	WNNWW113	11kv FDR YADAV PARK EXT	TP-MDK272A-1	400	RESIDENTIAL	AMR	Functional	100%	424	0.57			
66 kv NANGLOI W.W GRID	WNNWW113	11kv FDR YADAV PARK EXT	TP-MDK274A-1	630	RESIDENTIAL	AMR	Functional	100%	829	0.55			
66 kv NANGLOI GRID	WNNGL117	11kv FDR BAKKAR WALA	MD-HVD022A-1	2705	RESIDENTIAL		Functional	100%	962	0.43	0.46	0.18	27.57%
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	MD-HVD001A-1	925	RESIDENTIAL		Functional	100%	713	0.15			
66 kv NANGLOI GRID	WNNGL117	11kv FDR BAKKAR WALA	MD-HVD002A-1	1380	RESIDENTIAL		Functional	100%	508	0.06	4.45	0.43	8.73%
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	TG-MDK039A-1	990	COMMERCIAL	AMR	Functional	100%	709	0.84			
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	TG-MDK038A-1	990	RESIDENTIAL	AMR	Functional	100%	512	0.66			
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	TP-MDK511A-1	990	RESIDENTIAL		Functional	100%	949	0.51			
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	631SPK-MDK338A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.45			
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	TG-MDK040A-2	630	RESIDENTIAL	AMR	Functional	100%	1283	0.45			
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	631SPK-MDK516A-	990	MIXED		Functional	100%	0	0.73			
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	TG-MDK040A-1	400	COMMERCIAL		Functional	100%	0	0.36			
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	TP-MDK231A-1	400	COMMERCIAL	AMR	Functional	100%	38	0.25			
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	TP-MDK104A-1	400	MIXED		Functional	100%	112	0.22			
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	TG-MDK020A-1	400	COMMERCIAL	AMR	Functional	100%	120	0.17			
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	TP-MDK338A-1	400	COMMERCIAL	AMR	Functional	100%	272	0.12			
66 kv NANGLOI W.W GRID	WNNWW114	11kv FDR DDA. FLATS	TP-MDK130A-1	100	MIXED		Functional	100%	17	0.08			
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	TP-MDK516B-1	990	MIXED		Functional	100%	1132	0.03			
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	TP-MDK105A-1	100	COMMERCIAL		Functional	100%	14	0.01			
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	TP-MDK461A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.00			
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	TP-MDK106A-1	100	INDUSTRIAL	AMR	Functional	100%	1	0.00			
66 kv NANGLOI W.W GRID	WNNWW128	11kv FDR BAKKARWALA JJ COLONY	TP-MDK461A-1	400	RESIDENTIAL	AMR	Functional	100%	448	0.00			
66 kv TIKRI KALAN GRID	WMUND112	11kv FDR RANI KHERA MORE	TP-MDK167A-1	630	INDUSTRIAL	AMR	Functional	100%	17	1.00	4.68	1.41	23.16%
66 kv TIKRI KALAN GRID	WMUND108	11kv FDR HIRAN KUDNA	TP-MDK078A-1	990	RESIDENTIAL		Functional	100%	6	0.50			

66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK166A-1	630	MIXED	AMR	Functional	100%	9	0.39
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK107A-1	630	RESIDENTIAL	AMR	Functional	100%	79	0.36
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TG-MDK528A-1	400	RESIDENTIAL	AMR	Functional	100%	22	0.35
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TG-MDK034A-1	630	MIXED	AMR	Functional	100%	23	0.32
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK439A-1	400	RESIDENTIAL	AMR	Functional	100%	38	0.32
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK185A-1	630	INDUSTRIAL	AMR	Functional	100%	20	0.30
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK145A-1	400	RESIDENTIAL		Functional	100%	10	0.26
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK346A-1	400	MIXED	AMR	Functional	100%	5	0.21
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK183A-1	400	RESIDENTIAL	AMR	Functional	100%	14	0.20
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	631TIK-MDK565A-	250	RESIDENTIAL		Functional	100%	0	0.17
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK443A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.15
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	631TIK-MDK561A-	400	MIXED	AMR	Functional	100%	0	0.14
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK101A-1	400	MIXED	AMR	Functional	100%	8	0.13
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	631TIK-MDK540A-	400	RESIDENTIAL	AMR	Functional	100%	24	0.12
66 kV TIKRI KALAN GRID	WMUND102	11kV FDR GHEVERA MORE	TP-MDK295A-1	400	MIXED	AMR	Functional	100%	3	0.12
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK115A-1	400	RESIDENTIAL		Functional	100%	5	0.09
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	631TIK-MDK584A-	250	MIXED	AMR	Functional	100%	0	0.08
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK132A-1	400	RESIDENTIAL	AMR	Functional	100%	7	0.07
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK336A-1	400	INDUSTRIAL	AMR	Functional	100%	2	0.07
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK307A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.06
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK450A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.06
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK437A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.05
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK449A-1	400	INDUSTRIAL	AMR	Functional	100%	10	0.05
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK347A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.05
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK348A-1	100	MIXED	AMR	Functional	100%	1	0.05
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK341A-1	100	MIXED	AMR	Functional	100%	1	0.04
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK085A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.04
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK441A-1	400	RESIDENTIAL	AMR	Functional	100%	9	0.04
66 kV TIKRI KALAN GRID	WMUND102	11kV FDR GHEVERA MORE	TP-MDK283A-1	100	MIXED	AMR	Functional	100%	46	0.03
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	631TIK-MDK566A-	100	MIXED	AMR	Functional	100%	0	0.03
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK292A-1	100	MIXED	AMR	Functional	100%	1	0.03
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK306A-1	100	MIXED	AMR	Functional	100%	2	0.02
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK349A-1	100	MIXED	AMR	Functional	100%	25	0.02
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK438A-1	400	RESIDENTIAL	AMR	Functional	100%	36	0.02
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK189A-1	100	INDUSTRIAL	AMR	Functional	100%	7	0.02
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK285A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TG-MDK173A-1	100	MIXED	AMR	Functional	100%	1	0.02
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK485A-1	100	RESIDENTIAL		Functional	100%	1	0.01
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK342A-1	100	MIXED		Functional	100%	1	0.01
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK440A-1	100	RESIDENTIAL	AMR	Functional	100%	24	0.01
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK436A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.01
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK109A-2	100	RESIDENTIAL	AMR	Functional	100%	4	0.01
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK305A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.01
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK291A-1	100	MIXED	AMR	Functional	100%	2	0.01
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK181A-1	100	INDUSTRIAL		Functional	100%	2	0.01
66 kV TIKRI KALAN GRID	WMUND102	11kV FDR GHEVERA MORE	TP-MDK100A-1	100	MIXED		Functional	100%	2	0.01
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK237A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.00
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK444A-1	100	RESIDENTIAL		Functional	100%	3	0.00
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK343A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK469A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.00

66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK187A-1	100	INDUSTRIAL	AMR	Functional	100%	2	0.00			
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK468A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.00			
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	TP-MDK302A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.00			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TG-MDK201A-1	630	MIXED	AMR	Functional	100%	0	0.13	1.95	0.02	0.87%
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK208A-1	630	MIXED	AMR	Functional	100%	0	0.12			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TG-MDK206A-1	630	MIXED		Functional	100%	0	0.10			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK194A-1	630	MIXED	AMR	Functional	100%	60	0.10			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK198A-2	400	MIXED	AMR	Functional	100%	162	0.08			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TG-MDK190A-2	630	MIXED	AMR	Functional	100%	79	0.08			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK202A-2	630	MIXED		Functional	100%	275	0.08			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK184A-1	630	MIXED	AMR	Functional	100%	129	0.06			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TG-MDK180A-1	630	MIXED	AMR	Functional	100%	0	0.06			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TG-MDK192A-1	630	MIXED	AMR	Functional	100%	81	0.06			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK176A-1	630	MIXED	AMR	Functional	100%	67	0.06			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TG-MDK210A-2	400	MIXED	AMR	Functional	100%	150	0.05			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK196A-2	400	MIXED	AMR	Functional	100%	165	0.05			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK186A-1	630	RESIDENTIAL	AMR	Functional	100%	49	0.05			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK184A-2	630	RESIDENTIAL		Functional	100%	154	0.05			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK186A-2	630	MIXED	AMR	Functional	100%	75	0.05			
66 kV TIKRI KALAN GRID	WMUND609	11KV FDR NO-1 821,DDA FLATS,BAKKARWALA,MDK	631SPK-MDK596A	630	MIXED		Functional	100%	0	0.04			
66 kV TIKRI KALAN GRID	WMUND609	11KV FDR NO-1 821,DDA FLATS,BAKKARWALA,MDK	631SPK-MDK594A	630	MIXED		Functional	100%	0	0.04			
66 kV TIKRI KALAN GRID	WMUND609	11KV FDR NO-1 821,DDA FLATS,BAKKARWALA,MDK	631SPK-MDK594A	630	MIXED		Functional	100%	0	0.04			
66 kV TIKRI KALAN GRID	WMUND609	11KV FDR NO-1 821,DDA FLATS,BAKKARWALA,MDK	631SPK-MDK595A	630	MIXED		Functional	100%	0	0.04			
66 kV TIKRI KALAN GRID	WMUND609	11KV FDR NO-1 821,DDA FLATS,BAKKARWALA,MDK	631SPK-MDK595A	630	MIXED		Functional	100%	0	0.04			
66 kV TIKRI KALAN GRID	WMUND609	11KV FDR NO-1 821,DDA FLATS,BAKKARWALA,MDK	631SPK-MDK596A	630	MIXED		Functional	100%	0	0.04			
66 kV TIKRI KALAN GRID	WMUND609	11KV FDR NO-1 821,DDA FLATS,BAKKARWALA,MDK	631SPK-MDK593A	630	MIXED		Functional	100%	0	0.04			
66 kV TIKRI KALAN GRID	WMUND609	11KV FDR NO-1 821,DDA FLATS,BAKKARWALA,MDK	631SPK-MDK593A	630	MIXED		Functional	100%	0	0.04			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK204A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.04			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK204A-2	400	RESIDENTIAL	AMR	Functional	100%	170	0.04			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TG-MDK188A-1	630	MIXED	AMR	Functional	100%	182	0.04			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK182A-2	630	RESIDENTIAL		Functional	100%	37	0.04			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TG-MDK188A-2	630	MIXED	AMR	Functional	100%	47	0.03			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK202A-1	630	MIXED		Functional	100%	0	0.03			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TG-MDK180A-2	630	RESIDENTIAL		Functional	100%	155	0.03			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK182A-1	630	RESIDENTIAL		Functional	100%	71	0.03			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TG-MDK206A-2	630	RESIDENTIAL		Functional	100%	168	0.03			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TG-MDK190A-1	630	MIXED		Functional	100%	95	0.03			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TG-MDK192A-2	630	MIXED		Functional	100%	28	0.03			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK194A-2	630	MIXED		Functional	100%	91	0.03			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK176A-2	630	MIXED		Functional	100%	72	0.03			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK178A-2	630	MIXED	AMR	Functional	100%	123	0.03			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK178A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.02			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TP-MDK464A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TG-MDK210A-1	400	MIXED		Functional	100%	14	0.02			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK198A-1	400	MIXED		Functional	100%	0	0.02			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK196A-1	400	MIXED	AMR	Functional	100%	0	0.00			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TI-MDK208A-2	630	MIXED	AMR	Functional	100%	253	0.00			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TG-MDK201A-2	630	MIXED		Functional	100%	221	0.00			
66 kV NANGLOI GRID	WNNGL119	11kV FDR J.J COLONEY NO.2	TI-MDK005A-1	990	RESIDENTIAL	AMR	Functional	100%	519	0.89	3.54	0.06	1.54%
66 kV NANGLOI GRID	WNNGL119	11kV FDR J.J COLONEY NO.2	TI-MDK006A-1	990	RESIDENTIAL	AMR	Functional	100%	1173	0.70			

66 kV NANGLOI GRID	WNNG119	11kV FDR J.J COLONEY NO.2	TI-MDK006A-3	630	RESIDENTIAL		Functional	100%	611	0.61			
66 kV NANGLOI GRID	WNNG119	11kV FDR J.J COLONEY NO.2	TG-MDK007A-1	1600	RESIDENTIAL		Functional	100%	1767	0.55			
66 kV NANGLOI GRID	WNNG119	11kV FDR J.J COLONEY NO.2	TG-MDK008A-1	990	RESIDENTIAL	AMR	Functional	100%	1523	0.53			
66 kV NANGLOI GRID	WNNG119	11kV FDR J.J COLONEY NO.2	TI-MDK006A-2	990	RESIDENTIAL	AMR	Functional	100%	854	0.32			
66kV NILOTHI GRID	WNILO131	11kV FDR CHANCHAL PARK	TG-MDK229A-1	990	RESIDENTIAL	AMR	Functional	100%	1363	0.73	3.97	0.52	11.64%
66kV NILOTHI GRID	WNILO131	11kV FDR CHANCHAL PARK	TP-MDK367A-1	630	RESIDENTIAL	AMR	Functional	100%	717	0.55			
66kV NILOTHI GRID	WNILO131	11kV FDR CHANCHAL PARK	TG-MDK451A-1	630	COMMERCIAL	AMR	Functional	100%	889	0.52			
66 kV NANGLOI W.W GRID	WNNWW123	11kV FDR JAI VIHAR	631DSI-MDK545A-	630	RESIDENTIAL		Functional	100%	544	0.49			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	TP-MDK023A-1	400	RESIDENTIAL	AMR	Functional	100%	696	0.49			
66kV NILOTHI GRID	WNILO131	11kV FDR CHANCHAL PARK	631DSI-MDK552A-	990	RESIDENTIAL	AMR	Functional	100%	448	0.43			
66 kV NANGLOI W.W GRID	WNNWW123	11kV FDR JAI VIHAR	TG-MDK242A-1	630	RESIDENTIAL	AMR	Functional	100%	448	0.40			
66kV NILOTHI GRID	WNILO131	11kV FDR CHANCHAL PARK	TG-MDK135A-1	630	RESIDENTIAL	AMR	Functional	100%	513	0.35			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	631DSI-MDK560A-	630	COMMERCIAL	AMR	Functional	100%	191	0.22			
66 kV NANGLOI W.W GRID	WNNWW123	11kV FDR JAI VIHAR	TP-MDK129A-1	400	RESIDENTIAL	AMR	Functional	100%	138	0.19			
66kV NILOTHI GRID	WNILO131	11kV FDR CHANCHAL PARK	TG-MDK373A-1	400	RESIDENTIAL		Functional	100%	63	0.05			
66 kV NANGLOI W.W GRID	WNNWW123	11kV FDR JAI VIHAR	631DSI-MDK513A-	100	RESIDENTIAL	AMR	Functional	100%	30	0.03			
66kV NILOTHI GRID	WNILO131	11kV FDR CHANCHAL PARK	631DSI-MDK562A-	400	RESIDENTIAL	AMR	Functional	100%	34	0.02			
66kV NILOTHI GRID	WNILO131	11kV FDR CHANCHAL PARK	TP-MDK514A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02			
66 kV NANGLOI GRID	WNNG117	11kV FDR BAKKAR WALA	TP-MDK476A-1	990	RESIDENTIAL	AMR	Functional	100%	918	0.87	5.05	0.87	14.71%
66kV NILOTHI GRID	WNILO140	11kV FDR COMMUNITY CENTRE	TG-MDK027A-1	990	RESIDENTIAL		Functional	100%	592	0.77			
66kV NILOTHI GRID	WNILO140	11kV FDR COMMUNITY CENTRE	TG-MDK013A-1	990	RESIDENTIAL	AMR	Functional	100%	566	0.54			
66 kV NANGLOI GRID	WNNG111	11kV FDR RAJENDERA PARK	631SPK-MDK402A-	630	RESIDENTIAL	AMR	Functional	100%	454	0.42			
66 kV NANGLOI GRID	WNNG118	11kV FDR POLICE QUATERS	TI-MDK012A-2	990	RESIDENTIAL	AMR	Functional	100%	616	0.41			
66 kV NANGLOI GRID	WNNG111	11kV FDR RAJENDERA PARK	631DSI-MDK551A-	630	RESIDENTIAL	AMR	Functional	100%	9	0.39			
66 kV NANGLOI GRID	WNNG118	11kV FDR POLICE QUATERS	TI-MDK012A-3	630	RESIDENTIAL		Functional	100%	0	0.36			
66 kV NANGLOI GRID	WNNG118	11kV FDR POLICE QUATERS	TI-MDK012A-1	990	RESIDENTIAL	AMR	Functional	100%	449	0.36			
66 kV NANGLOI W.W GRID	WNNWW113	11kV FDR YADAV PARK EXT	TP-MDK010A-1	400	RESIDENTIAL	AMR	Functional	100%	778	0.35			
66 kV NANGLOI W.W GRID	WNNWW113	11kV FDR YADAV PARK EXT	TP-MDK366A-1	990	RESIDENTIAL	AMR	Functional	100%	83	0.34			
66 kV NANGLOI GRID	WNNG111	11kV FDR RAJENDERA PARK	631DSI-MDK067A-	630	MIXED		Functional	100%	0	0.34			
66 kV NANGLOI GRID	WNNG118	11kV FDR POLICE QUATERS	TI-MDK012A-4	630	RESIDENTIAL	AMR	Functional	100%	32	0.32			
66kV NILOTHI GRID	WNILO140	11kV FDR COMMUNITY CENTRE	TP-MDK015A-1	630	RESIDENTIAL		Functional	100%	256	0.28			
66 kV NANGLOI GRID	WNNG111	11kV FDR RAJENDERA PARK	TI-MDK067A-1	400	RESIDENTIAL	AMR	Functional	100%	276	0.16			
66 kV NANGLOI GRID	WNNG123	11kV FDR MUNDKA	631DSI-MDK406A-	990	MIXED		Functional	100%	0	0.00			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	TP-MDK309A-1	990	RESIDENTIAL		Functional	100%	41	0.68	1.29	0.14	9.98%
66 kV NANGLOI GRID	WNNG124	11kV FDR I.O.C	TG-MDK323A-1	400	COMMERCIAL	AMR	Functional	100%	46	0.22			
66 kV NANGLOI GRID	WNNG124	11kV FDR I.O.C	TP-MDK320A-1	400	COMMERCIAL	AMR	Functional	100%	380	0.18			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	631SPK-MDK309A-	400	MIXED	AMR	Functional	100%	0	0.14			
66 kV NANGLOI GRID	WNNG124	11kV FDR I.O.C	TP-MDK322A-1	400	COMMERCIAL	AMR	Functional	100%	78	0.12			
66 kV NANGLOI GRID	WNNG124	11kV FDR I.O.C	TP-MDK321A-1	400	COMMERCIAL		Functional	100%	285	0.11			
66 kV TIKRI KALAN GRID	WMUND111	11kV FDR SUBASH VIHAR-1	TG-MDK139A-1	630	RESIDENTIAL	AMR	Functional	100%	1611	0.97	3.08	0.54	15.01%
66 kV TIKRI KALAN GRID	WMUND111	11kV FDR SUBASH VIHAR-1	TG-MDK139A-2	630	RESIDENTIAL	AMR	Functional	100%	439	0.53			
66 kV TIKRI KALAN GRID	WMUND111	11kV FDR SUBASH VIHAR-1	TG-MDK527A-1	630	RESIDENTIAL		Functional	100%	113	0.48			
66 kV TIKRI KALAN GRID	WMUND111	11kV FDR SUBASH VIHAR-1	TG-MDK531A-1	630	RESIDENTIAL	AMR	Functional	100%	47	0.24			
66 kV TIKRI KALAN GRID	WMUND107	11kV FDR BABA HARIDAS	TP-MDK092A-1	400	MIXED	AMR	Functional	100%	132	0.22			
66 kV TIKRI KALAN GRID	WMUND101	11kV FDR NEEL WALL	631TIK-MDK591A-	990	MIXED		Functional	100%	0	0.22			
66 kV TIKRI KALAN GRID	WMUND105	11kV FDR PVC MARKET-II	631SPK-MDK575A-	250	MIXED	AMR	Functional	100%	0	0.21			
66 kV TIKRI KALAN GRID	WMUND111	11kV FDR SUBASH VIHAR-1	TP-MDK505A-1	400	RESIDENTIAL	AMR	Functional	100%	2	0.18			
66 kV TIKRI KALAN GRID	WMUND111	11kV FDR SUBASH VIHAR-1	TP-MDK473A-1	250	RESIDENTIAL	AMR	Functional	100%	75	0.16			
66 kV TIKRI KALAN GRID	WMUND107	11kV FDR BABA HARIDAS	TG-MDK066A-1	400	RESIDENTIAL	AMR	Functional	100%	10	0.14			
66 kV TIKRI KALAN GRID	WMUND111	11kV FDR SUBASH VIHAR-1	TP-MDK289A-1	100	RESIDENTIAL	AMR	Functional	100%	90	0.12			

66 kV TIKRI KALAN GRID	WMUND111	11kV FDR SUBASH VIHAR-1	TP-MDK088A-1	400	MIXED	AMR	Functional	100%	63	0.10			
66 kV TIKRI KALAN GRID	WMUND107	11kV FDR BABA HARIDAS	631TIK-MDK550A-	400	RESIDENTIAL	AMR	Functional	100%	0	0.03			
66 kV TIKRI KALAN GRID	WMUND107	11kV FDR BABA HARIDAS	TG-MDK037A-1	400	MIXED	AMR	Functional	100%	26	0.01			
66 kV TIKRI KALAN GRID	WMUND111	11kV FDR SUBASH VIHAR-1	TP-MDK288A-1	100	RESIDENTIAL	AMR	Functional	100%	52	0.01			
66 kV TIKRI KALAN GRID	WMUND107	11kV FDR BABA HARIDAS	TP-MDK404A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK474A-1	630	RESIDENTIAL		Functional	100%	46	0.44	1.27	0.39	23.50%
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	631TIK-MDK580A-	400	MIXED	AMR	Functional	100%	0	0.28			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK472A-1	250	RESIDENTIAL	AMR	Functional	100%	5	0.20			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK426A-1	100	INDUSTRIAL	AMR	Functional	100%	30	0.11			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK099A-1	400	INDUSTRIAL	AMR	Functional	100%	17	0.08			
66 kV TIKRI KALAN GRID	WMUND107	11kV FDR BABA HARIDAS	TG-MDK114A-1	400	RESIDENTIAL	AMR	Functional	100%	14	0.08			
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK096A-1	100	INDUSTRIAL	AMR	Functional	100%	67	0.05			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK416A-1	100	INDUSTRIAL	AMR	Functional	100%	54	0.05			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK427A-1	100	INDUSTRIAL	AMR	Functional	100%	25	0.04			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK419A-1	100	INDUSTRIAL		Functional	100%	49	0.04			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK520A-1	100	RESIDENTIAL		Functional	100%	11	0.04			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK340A-1	100	INDUSTRIAL	AMR	Functional	100%	18	0.04			
66 kV TIKRI KALAN GRID	WMUND107	11kV FDR BABA HARIDAS	TP-MDK482A-1	100	RESIDENTIAL	AMR	Functional	100%	19	0.03			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK417A-1	100	INDUSTRIAL	AMR	Functional	100%	31	0.03			
66 kV TIKRI KALAN GRID	WMUND102	11kV FDR GHEVERA MORE	TP-MDK097A-1	100	INDUSTRIAL	AMR	Functional	100%	30	0.02			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK430A-1	100	INDUSTRIAL	AMR	Functional	100%	17	0.02			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK420A-1	100	INDUSTRIAL		Functional	100%	18	0.02			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK418A-1	100	INDUSTRIAL	AMR	Functional	100%	17	0.02			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK429A-1	100	INDUSTRIAL	AMR	Functional	100%	14	0.01			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK428A-1	100	INDUSTRIAL	AMR	Functional	100%	4	0.01			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK422A-1	100	INDUSTRIAL	AMR	Functional	100%	10	0.01			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK421A-1	100	INDUSTRIAL	AMR	Functional	100%	2	0.01			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK423A-1	100	INDUSTRIAL	AMR	Functional	100%	12	0.01			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK424A-1	100	INDUSTRIAL	AMR	Functional	100%	5	0.01			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK098A-1	100	INDUSTRIAL	AMR	Functional	100%	2	0.01			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK425A-1	100	INDUSTRIAL	AMR	Functional	100%	9	0.01			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK344A-1	100	MIXED	AMR	Functional	100%	1	0.00			
66 kV TIKRI KALAN GRID	WMUND101	11kV FDR NEEL WALL	TP-MDK061A-1	630	RESIDENTIAL	AMR	Functional	100%	383	0.50	1.03	0.17	14.12%
66 kV TIKRI KALAN GRID	WMUND101	11kV FDR NEEL WALL	TP-MDK062A-1	630	RESIDENTIAL	AMR	Functional	100%	473	0.47			
66 kV TIKRI KALAN GRID	WMUND101	11kV FDR NEEL WALL	631TIK-MDK558A-	630	RESIDENTIAL	AMR	Functional	100%	63	0.09			
66 kV TIKRI KALAN GRID	WMUND101	11kV FDR NEEL WALL	TP-MDK095A-1	100	RESIDENTIAL	AMR	Functional	100%	6	0.04			
66 kV TIKRI KALAN GRID	WMUND101	11kV FDR NEEL WALL	TP-MDK093A-1	100	RESIDENTIAL		Functional	100%	6	0.04			
66 kV TIKRI KALAN GRID	WMUND111	11kV FDR SUBASH VIHAR-1	TP-MDK298A-1	100	RESIDENTIAL	AMR	Functional	100%	24	0.03			
66 kV TIKRI KALAN GRID	WMUND101	11kV FDR NEEL WALL	TP-MDK094A-1	100	RESIDENTIAL	AMR	Functional	100%	15	0.02			
66 kV TIKRI KALAN GRID	WMUND102	11kV FDR GHEVERA MORE	TP-MDK284A-1	400	MIXED		Functional	100%	10	0.00			
66 kV TIKRI KALAN GRID	WMUND101	11kV FDR NEEL WALL	631TIK-MDK554A-	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			
66 kV TIKRI KALAN GRID	WMUND101	11kV FDR NEEL WALL	631TIK-MDK555A-	100	MIXED	AMR	Functional	100%	0	0.00			
66 kV TIKRI KALAN GRID	WMUND102	11kV FDR GHEVERA MORE	TG-MDK045A-1	990	MIXED	AMR	Functional	100%	609	0.83	1.61	1.19	42.59%
66 kV TIKRI KALAN GRID	WMUND102	11kV FDR GHEVERA MORE	TG-MDK044A-1	990	MIXED	AMR	Functional	100%	440	0.74			
66 kV TIKRI KALAN GRID	WMUND102	11kV FDR GHEVERA MORE	TP-MDK121A-1	400	RESIDENTIAL	AMR	Functional	100%	17	0.42			
66 kV TIKRI KALAN GRID	WMUND102	11kV FDR GHEVERA MORE	TP-MDK484A-1	400	RESIDENTIAL	AMR	Functional	100%	82	0.35			
66 kV TIKRI KALAN GRID	WMUND102	11kV FDR GHEVERA MORE	631TIK-MDK557A-	630	RESIDENTIAL	AMR	Functional	100%	8	0.20			
66 kV TIKRI KALAN GRID	WMUND102	11kV FDR GHEVERA MORE	TP-MDK504A-1	400	RESIDENTIAL	AMR	Functional	100%	21	0.19			
66 kV TIKRI KALAN GRID	WMUND102	11kV FDR GHEVERA MORE	631TIK-MDK588A-	630	MIXED		Functional	100%	0	0.05			
66 kV TIKRI KALAN GRID	WMUND102	11kV FDR GHEVERA MORE	TP-MDK287A-1	100	MIXED		Functional	100%	10	0.02			

66 kV TIKRI KALAN GRID	WMUND102	11kV FDR GHEVERA MORE	TP-MDK475A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.01	3.27	3.18	49.29%
66 kV NANGLOI W.W GRID	WNNWW113	11kV FDR YADAV PARK EXT	TG-MDK047A-1	990	RESIDENTIAL	AMR	Functional	100%	590	1.33			
66 kV NANGLOI W.W GRID	WNNWW111	11kV FDR KAMRUDEEN NGR.	TG-MDK046A-1	990	RESIDENTIAL	AMR	Functional	100%	498	1.08			
66 kV NANGLOI W.W GRID	WNNWW113	11kV FDR YADAV PARK EXT	TG-MDK486A-1	630	RESIDENTIAL	AMR	Functional	100%	129	0.81			
66 kV NANGLOI W.W GRID	WNNWW111	11kV FDR KAMRUDEEN NGR.	TG-MDK048A-1	990	RESIDENTIAL	AMR	Functional	100%	559	0.70			
66 kV NANGLOI W.W GRID	WNNWW113	11kV FDR YADAV PARK EXT	TP-MDK399A-1	400	RESIDENTIAL	AMR	Functional	100%	222	0.61			
66 kV NANGLOI W.W GRID	WNNWW113	11kV FDR YADAV PARK EXT	TG-MDK049A-1	630	RESIDENTIAL		Functional	100%	513	0.45			
66 kV NANGLOI W.W GRID	WNNWW111	11kV FDR KAMRUDEEN NGR.	TP-MDK374A-1	400	RESIDENTIAL	AMR	Functional	100%	197	0.38			
66 kV NANGLOI W.W GRID	WNNWW111	11kV FDR KAMRUDEEN NGR.	TI-MDK081A-1	630	RESIDENTIAL	AMR	Functional	100%	199	0.37			
66 kV NANGLOI W.W GRID	WNNWW111	11kV FDR KAMRUDEEN NGR.	TP-MDK082A-1	400	RESIDENTIAL	AMR	Functional	100%	180	0.36			
66 kV NANGLOI GRID	WNNGL111	11kV FDR RAJENDERA PARK	TI-MDK233A-1	400	RESIDENTIAL	AMR	Functional	100%	183	0.22			
66 kV TIKRI KALAN GRID	WMUND118	11kV FDR SUB STATION NO-5	631DSI-MDK570A-	400	MIXED		Functional	100%	0	0.12			
66 kV NANGLOI W.W GRID	WNNWW127	11kV STR 400KVA STATION TRANSFORMER	TG-WTC015A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.03			
66 kV NANGLOI W.W GRID	WNNWW111	11kV FDR KAMRUDEEN NGR.	TP-MDK400A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kV NANGLOI W.W GRID	WNNWW115	11kV FDR KUWAR SINGH NAGAR	TI-MDK018A-1	630	RESIDENTIAL		Functional	100%	1103	0.64	5.15	0.46	8.20%
66 kV NANGLOI W.W GRID	WNNWW107	11kV FDR HANUMAN MANDIR	TP-MDK142A-1	990	RESIDENTIAL	AMR	Functional	100%	1235	0.48			
66 kV NANGLOI W.W GRID	WNNWW115	11kV FDR KUWAR SINGH NAGAR	631DSI-MDK019A-	630	INDUSTRIAL	AMR	Functional	100%	0	0.45			
66 kV NANGLOI W.W GRID	WNNWW107	11kV FDR HANUMAN MANDIR	TP-MDK276A-1	400	RESIDENTIAL	AMR	Functional	100%	525	0.45			
66 kV NANGLOI W.W GRID	WNNWW115	11kV FDR KUWAR SINGH NAGAR	TP-MDK227A-1	400	RESIDENTIAL	AMR	Functional	100%	652	0.44			
66 kV NANGLOI W.W GRID	WNNWW106	11kV FDR SWARN PARK	631DSI-MDK564A-	630	RESIDENTIAL	AMR	Functional	100%	491	0.44			
66 kV NANGLOI W.W GRID	WNNWW107	11kV FDR HANUMAN MANDIR	TP-MDK512A-1	630	RESIDENTIAL	AMR	Functional	100%	215	0.44			
66 kV NANGLOI W.W GRID	WNNWW107	11kV FDR HANUMAN MANDIR	TP-MDK141A-1	630	RESIDENTIAL		Functional	100%	606	0.38			
66 kV NANGLOI W.W GRID	WNNWW115	11kV FDR KUWAR SINGH NAGAR	TP-MDK235A-1	990	RESIDENTIAL	AMR	Functional	100%	676	0.35			
66 kV NANGLOI W.W GRID	WNNWW115	11kV FDR KUWAR SINGH NAGAR	TI-MDK019A-1	990	RESIDENTIAL	AMR	Functional	100%	1281	0.33			
66 kV NANGLOI W.W GRID	WNNWW115	11kV FDR KUWAR SINGH NAGAR	TP-MDK228A-1	400	RESIDENTIAL	AMR	Functional	100%	742	0.31			
66 kV NANGLOI W.W GRID	WNNWW115	11kV FDR KUWAR SINGH NAGAR	TG-MDK028A-1	630	RESIDENTIAL		Functional	100%	98	0.26			
66 kV NANGLOI W.W GRID	WNNWW115	11kV FDR KUWAR SINGH NAGAR	TI-MDK018A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.23			
66 kV NANGLOI W.W GRID	WNNWW107	11kV FDR HANUMAN MANDIR	TP-MDK140A-1	400	RESIDENTIAL	AMR	Functional	100%	441	0.22			
66 kV NANGLOI W.W GRID	WNNWW123	11kV FDR JAI VIHAR	631DSI-MDK574A-	400	MIXED	AMR	Functional	100%	1	0.20			
66 kV TIKRI KALAN GRID	WMUND106	11kV FDR SUBASH VIHAR-2	TG-MDK076A-1	990	RESIDENTIAL	AMR	Functional	100%	942	0.96	3.83	1.10	22.30%
66 kV TIKRI KALAN GRID	WMUND105	11kV FDR PVC MARKET-II	TG-MDK077A-1	990	RESIDENTIAL	AMR	Functional	100%	561	0.87			
66 kV TIKRI KALAN GRID	WMUND105	11kV FDR PVC MARKET-II	TG-MDK073A-1	990	RESIDENTIAL	AMR	Functional	100%	414	0.67			
66 kV TIKRI KALAN GRID	WMUND106	11kV FDR SUBASH VIHAR-2	TG-MDK074A-1	630	RESIDENTIAL	AMR	Functional	100%	446	0.58			
66 kV TIKRI KALAN GRID	WMUND105	11kV FDR PVC MARKET-II	TG-MDK435A-1	400	RESIDENTIAL	AMR	Functional	100%	199	0.44			
66 kV TIKRI KALAN GRID	WMUND106	11kV FDR SUBASH VIHAR-2	TG-MDK072A-1	630	RESIDENTIAL	AMR	Functional	100%	495	0.34			
66 kV TIKRI KALAN GRID	WMUND105	11kV FDR PVC MARKET-II	TP-MDK075A-1	400	RESIDENTIAL	AMR	Functional	100%	664	0.32			
66 kV TIKRI KALAN GRID	WMUND107	11kV FDR BABA HARIDAS	2631TIK-MDK582A-1	630	MIXED	AMR	Functional	100%	0	0.29			
66 kV TIKRI KALAN GRID	WMUND106	11kV FDR SUBASH VIHAR-2	TG-MDK232A-1	400	RESIDENTIAL	AMR	Functional	100%	245	0.21			
66 kV TIKRI KALAN GRID	WMUND105	11kV FDR PVC MARKET-II	631TIK-MDK578A-	400	MIXED	AMR	Functional	100%	203	0.16			
66 kV TIKRI KALAN GRID	WMUND101	11kV FDR NEEL WALL	631TIK-MDK583A-	400	MIXED	AMR	Functional	100%	0	0.06			
66 kV TIKRI KALAN GRID	WMUND112	11kV FDR RANI KHERA MORE	631TIK-MDK542A-	100	RESIDENTIAL	AMR	Functional	100%	3	0.02			
66 kV TIKRI KALAN GRID	WMUND105	11kV FDR PVC MARKET-II	TP-MDK091A-1	100	MIXED	AMR	Functional	100%	27	0.01			
66 kV TIKRI KALAN GRID	WMUND106	11kV FDR SUBASH VIHAR-2	TP-MDK345A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV NANGLOI W.W GRID	WNNWW121	11kV FDR RAJDHANI PARK	TG-MDK069A-1	990	COMMERCIAL		Functional	100%	662	0.81	6.35	0.60	8.64%
66 kV NANGLOI W.W GRID	WNNWW106	11kV FDR SWARN PARK	TG-MDK530A-1	630	RESIDENTIAL	AMR	Functional	100%	145	0.63			
66 kV NANGLOI W.W GRID	WNNWW121	11kV FDR RAJDHANI PARK	TI-MDK068A-1	990	COMMERCIAL	AMR	Functional	100%	630	0.63			
66 kV NANGLOI W.W GRID	WNNWW121	11kV FDR RAJDHANI PARK	TP-MDK500A-1	630	RESIDENTIAL		Functional	100%	4	0.61			
66 kV NANGLOI W.W GRID	WNNWW118	11kV FDR VRINDAVAN VATIKA	TP-MDK234A-1	630	RESIDENTIAL	AMR	Functional	100%	359	0.52			
66 kV NANGLOI W.W GRID	WNNWW106	11kV FDR SWARN PARK	631SPK-MDK544A-	630	RESIDENTIAL	AMR	Functional	100%	39	0.42			
66 kV NANGLOI W.W GRID	WNNWW118	11kV FDR VRINDAVAN VATIKA	631SPK-MDK553A-	990	RESIDENTIAL	AMR	Functional	100%	289	0.42			

66 kv NANGLOI W.W GRID	WNNWW121	11kv FDR RAJDHANI PARK	TP-MDK391A-1	400	COMMERCIAL		Functional	100%	441	0.35			
66 kv NANGLOI W.W GRID	WNNWW121	11kv FDR RAJDHANI PARK	TG-MDK070A-1	990	COMMERCIAL	AMR	Functional	100%	182	0.30			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TP-MDK238A-1	400	COMMERCIAL		Functional	100%	272	0.29			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TP-MDK496A-1	400	RESIDENTIAL	AMR	Functional	100%	22	0.29			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TG-MDK442A-1	400	RESIDENTIAL	AMR	Functional	100%	90	0.24			
66 kv NANGLOI W.W GRID	WNNWW117	11kv FDR INDIAN OIL	TG-MDK308A-1	990	RESIDENTIAL	AMR	Functional	100%	235	0.24			
66 kv NANGLOI W.W GRID	WNNWW117	11kv FDR INDIAN OIL	631SPK-MDK541A	630	RESIDENTIAL	AMR	Functional	100%	39	0.23			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TG-MDK134A-1	630	COMMERCIAL	AMR	Functional	100%	132	0.16			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TP-MDK239A-1	400	COMMERCIAL		Functional	100%	60	0.16			
66 kv NANGLOI W.W GRID	WNNWW117	11kv FDR INDIAN OIL	TP-MDK518A-1	400	RESIDENTIAL	AMR	Functional	100%	21	0.12			
66 kv NANGLOI W.W GRID	WNNWW106	11kv FDR SWARN PARK	TG-MDK243A-1	400	COMMERCIAL	AMR	Functional	100%	17	0.10			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TP-MDK501A-1	400	RESIDENTIAL	AMR	Functional	100%	193	0.09			
66 kv NANGLOI W.W GRID	WNNWW117	11kv FDR INDIAN OIL	TP-MDK517A-1	400	RESIDENTIAL	AMR	Functional	100%	174	0.08			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TP-MDK481A-1	400	RESIDENTIAL	AMR	Functional	100%	2	0.07			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TP-MDK325A-1	400	COMMERCIAL	AMR	Functional	100%	63	0.07			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	631SPK-MDK548A	990	MIXED		Functional	100%	0	0.06			
66 kv NANGLOI W.W GRID	WNNWW106	11kv FDR SWARN PARK	631SPK-MDK567A	400	RESIDENTIAL	AMR	Functional	100%	2	0.02			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TP-MDK389A-1	400	COMMERCIAL	AMR	Functional	100%	241	0.02			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TP-MDK218A-1	100	COMMERCIAL	AMR	Functional	100%	25	0.01			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TP-MDK324A-1	100	COMMERCIAL	AMR	Functional	100%	66	0.01			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TP-MDK240A-1	100	COMMERCIAL	AMR	Functional	100%	118	0.00			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TP-MDK388A-1	100	COMMERCIAL	AMR	Functional	100%	35	0.00			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK002A-1	630	INDUSTRIAL	AMR	Functional	100%	16	0.55	3.71	0.23	5.83%
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK223A-1	630	INDUSTRIAL	AMR	Functional	100%	32	0.46			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK211A-1	630	INDUSTRIAL	AMR	Functional	100%	29	0.45			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK108A-1	400	RESIDENTIAL	AMR	Functional	100%	12	0.39			
66 kv TIKRI KALAN GRID	WMUND118	11kv FDR SUB STATION NO-5	631SPK-MDK572A	990	RESIDENTIAL	AMR	Functional	100%	266	0.33			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK001A-1	630	INDUSTRIAL		Functional	100%	42	0.27			
66 kv TIKRI KALAN GRID	WMUND109	11kv FDR BULBUL VATIKA	TP-MDK197A-1	400	MIXED	AMR	Functional	100%	30	0.24			
66 kv TIKRI KALAN GRID	WMUND109	11kv FDR BULBUL VATIKA	TP-MDK168A-1	400	MIXED		Functional	100%	12	0.22			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK205A-1	400	MIXED	AMR	Functional	100%	12	0.21			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK225A-1	400	INDUSTRIAL	AMR	Functional	100%	6	0.15			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK226A-1	400	RESIDENTIAL	AMR	Functional	100%	21	0.13			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK110A-1	400	INDUSTRIAL	AMR	Functional	100%	1	0.12			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK224A-1	400	INDUSTRIAL	AMR	Functional	100%	23	0.11			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK503A-1	400	RESIDENTIAL	AMR	Functional	100%	21	0.08			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK177A-1	100	INDUSTRIAL	AMR	Functional	100%	9	0.05			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK191A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TG-MDK203A-1	100	RESIDENTIAL	AMR	Functional	100%	13	0.02			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK219A-1	100	INDUSTRIAL	AMR	Functional	100%	2	0.02			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK209A-1	100	MIXED	AMR	Functional	100%	18	0.02			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK014A-1	100	RESIDENTIAL	AMR	Functional	100%	18	0.02			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK220A-1	100	INDUSTRIAL		Functional	100%	0	0.01			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK207A-1	100	MIXED	AMR	Functional	100%	19	0.01			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK390A-1	400	INDUSTRIAL	AMR	Functional	100%	2	0.01			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK319A-1	100	INDUSTRIAL	AMR	Functional	100%	1	0.01			
66 kv TIKRI KALAN GRID	WMUND119	11kv FDR ABHINANDAN VATIKA	TP-MDK199A-1	100	MIXED		Functional	100%	21	0.00			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	631SPK-MDK569A	400	MIXED		Functional	100%	0	0.00			
66 kv NANGLOI W.W GRID	WNNWW121	11kv FDR RAJDHANI PARK	TG-MDK051A-1	990	RESIDENTIAL	AMR	Functional	100%	323	1.22	11.00	0.16	1.47%
66 kv TIKRI KALAN GRID	WMUND120	11kv FDR BOOSTER PUMP MUNDKA GOAN	TG-MDK053A-2	990	RESIDENTIAL	AMR	Functional	100%	990	0.73			

66 kv TIKRI KALAN GRID	WMUND118	11kv FDR SUB STATION NO-5	TG-MDK052A-1	990	RESIDENTIAL	AMR	Functional	100%	518	0.72			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TP-MDK386A-1	990	RESIDENTIAL	AMR	Functional	100%	167	0.71			
66 kv NANGLOI W.W GRID	WNNWW106	11kv FDR SWARN PARK	TP-MDK112A-1	630	MIXED		Functional	100%	202	0.70			
66 kv NANGLOI W.W GRID	WNNWW121	11kv FDR RAJDHANI PARK	TG-MDK059A-2	990	RESIDENTIAL	AMR	Functional	100%	956	0.70			
66 kv NANGLOI W.W GRID	WNNWW121	11kv FDR RAJDHANI PARK	631SPK-MDK059A	630	RESIDENTIAL	AMR	Functional	100%	0	0.68			
66 kv TIKRI KALAN GRID	WMUND120	11kv FDR BOOSTER PUMP MUNDKA GOAN	TG-MDK053A-1	990	RESIDENTIAL	AMR	Functional	100%	657	0.68			
66 kv TIKRI KALAN GRID	WMUND120	11kv FDR BOOSTER PUMP MUNDKA GOAN	TP-MDK111A-1	500	RESIDENTIAL	AMR	Functional	100%	105	0.66			
66 kv TIKRI KALAN GRID	WMUND118	11kv FDR SUB STATION NO-5	TG-MDK054A-1	990	RESIDENTIAL	AMR	Functional	100%	946	0.62			
66 kv TIKRI KALAN GRID	WMUND120	11kv FDR BOOSTER PUMP MUNDKA GOAN	TP-MDK060A-1	630	RESIDENTIAL	AMR	Functional	100%	498	0.59			
66 kv TIKRI KALAN GRID	WMUND120	11kv FDR BOOSTER PUMP MUNDKA GOAN	631SPK-MDK053A	630	RESIDENTIAL	AMR	Functional	100%	0	0.57			
66 kv NANGLOI GRID	WNNGL124	11kv FDR I.O.C	TG-MDK056A-1	990	RESIDENTIAL	AMR	Functional	100%	599	0.45			
66 kv NANGLOI W.W GRID	WNNWW121	11kv FDR RAJDHANI PARK	TG-MDK059A-1	990	RESIDENTIAL	AMR	Functional	100%	0	0.45			
66 kv NANGLOI W.W GRID	WNNWW121	11kv FDR RAJDHANI PARK	TG-MDK529A-1	990	RESIDENTIAL		Functional	100%	119	0.40			
66 kv TIKRI KALAN GRID	WMUND118	11kv FDR SUB STATION NO-5	TG-MDK054A-2	990	RESIDENTIAL	AMR	Functional	100%	403	0.32			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TG-MDK300A-1	400	RESIDENTIAL		Functional	100%	52	0.28			
66 kv TIKRI KALAN GRID	WMUND109	11kv FDR BULBUL VATIKA	TG-MDK294A-1	630	MIXED	AMR	Functional	100%	424	0.26			
66 kv NANGLOI GRID	WNNGL124	11kv FDR I.O.C	TP-MDK490A-1	400	COMMERCIAL	AMR	Functional	100%	64	0.25			
66 kv NANGLOI W.W GRID	WNNWW118	11kv FDR VRINDAVAN VATIKA	TP-MDK493A-1	400	RESIDENTIAL	AMR	Functional	100%	85	0.18			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK507A-1	630	RESIDENTIAL	AMR	Functional	100%	477	0.64	2.26	0.60	21.05%
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK245A-1	400	RESIDENTIAL	AMR	Functional	100%	149	0.37			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK282A-1	400	MIXED	AMR	Functional	100%	466	0.34			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK508A-1	400	RESIDENTIAL	AMR	Functional	100%	258	0.29			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	631TIK-MDK563A	630	RESIDENTIAL	AMR	Functional	100%	46	0.29			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK352A-1	400	INDUSTRIAL	AMR	Functional	100%	158	0.15			
66 kv TIKRI KALAN GRID	WMUND105	11kv FDR PVC MARKET-II	631TIK-MDK556A	630	RESIDENTIAL	AMR	Functional	100%	5	0.12			
66 kv TIKRI KALAN GRID	WMUND110	11kv FDR PVC MARKET-I	TG-MDK455A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.10			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK356A-1	400	RESIDENTIAL	AMR	Functional	100%	82	0.08			
66 kv TIKRI KALAN GRID	WMUND110	11kv FDR PVC MARKET-I	631TIK-MDK456A	400	RESIDENTIAL	AMR	Functional	100%	80	0.08			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	631TIK-MDK507A	400	MIXED	AMR	Functional	100%	0	0.08			
66 kv TIKRI KALAN GRID	WMUND110	11kv FDR PVC MARKET-I	TG-MDK458A-1	630	RESIDENTIAL	AMR	Functional	100%	48	0.05			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK278A-1	400	MIXED	AMR	Functional	100%	31	0.04			
66 kv TIKRI KALAN GRID	WMUND110	11kv FDR PVC MARKET-I	TG-MDK457A-1	630	RESIDENTIAL		Functional	100%	85	0.04			
66 kv TIKRI KALAN GRID	WMUND110	11kv FDR PVC MARKET-I	TG-MDK455A-1	630	RESIDENTIAL	AMR	Functional	100%	143	0.03			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK090A-1	100	MIXED		Functional	100%	1	0.03			
66 kv TIKRI KALAN GRID	WMUND110	11kv FDR PVC MARKET-I	TG-MDK459A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.03			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK126A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kv TIKRI KALAN GRID	WMUND110	11kv FDR PVC MARKET-I	TG-MDK459A-1	630	RESIDENTIAL	AMR	Functional	100%	59	0.01			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK357A-1	100	MIXED	AMR	Functional	100%	40	0.01			
66 kv TIKRI KALAN GRID	WMUND110	11kv FDR PVC MARKET-I	TG-MDK458A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.01			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK354A-1	100	MIXED		Functional	100%	61	0.01			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK355A-1	100	MIXED		Functional	100%	61	0.01			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK358A-1	100	MIXED		Functional	100%	67	0.01			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK359A-1	100	MIXED		Functional	100%	209	0.01			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK351A-1	100	MIXED		Functional	100%	72	0.01			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK360A-1	100	MIXED		Functional	100%	36	0.01			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK353A-1	100	MIXED		Functional	100%	60	0.01			
66 kv TIKRI KALAN GRID	WMUND111	11kv FDR SUBASH VIHAR-1	TP-MDK371A-1	100	RESIDENTIAL	AMR	Functional	100%	5	0.00			
66 kv TIKRI KALAN GRID	WMUND606	11kv FDR AZAD HIND GRAM	TP-MDK264A-1	400	COMMERCIAL	AMR	Functional	100%	72	0.22	0.62	0.14	18.96%
66 kv TIKRI KALAN GRID	WMUND101	11kv FDR NEEL WALL	TP-MDK144A-1	100	RESIDENTIAL	AMR	Functional	100%	16	0.08			
66 kv TIKRI KALAN GRID	WMUND108	11kv FDR HIRAN KUDNA	TP-MDK247A-1	400	COMMERCIAL	AMR	Functional	100%	25	0.08			

66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK258A-1	400	COMMERCIAL	AMR	Functional	100%	43	0.08			
66 kV TIKRI KALAN GRID	WMUND109	11kV FDR BULBUL VATIKA	TP-MDK497A-1	400	RESIDENTIAL	AMR	Functional	100%	62	0.07			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK259A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.05			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK253A-1	100	COMMERCIAL	AMR	Functional	100%	13	0.03			
66 kV TIKRI KALAN GRID	WMUND114	11kV STR 400KVA STATION TRANSFORMER	TP-WTC026A-1	400	COMMERCIAL	AMR	Functional	100%	1	0.02			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK251A-1	100	COMMERCIAL	AMR	Functional	100%	10	0.02			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK260A-1	100	COMMERCIAL		Functional	100%	3	0.02			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK254A-1	100	COMMERCIAL		Functional	100%	4	0.02			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK261A-1	100	COMMERCIAL	AMR	Functional	100%	10	0.02			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK256A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.01			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK252A-1	100	MIXED		Functional	100%	0	0.01			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK255A-1	100	MIXED		Functional	100%	0	0.01			
66 kV TIKRI KALAN GRID	WMUND108	11kV FDR HIRAN KUDNA	TP-MDK246A-1	100	COMMERCIAL		Functional	100%	0	0.01			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK249A-1	100	MIXED		Functional	100%	0	0.01			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK270A-1	100	COMMERCIAL		Functional	100%	0	0.01			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK267A-1	100	COMMERCIAL	AMR	Functional	100%	2	0.01			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK250A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.00			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK265A-1	100	COMMERCIAL	AMR	Functional	100%	0	0.00			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK266A-1	100	COMMERCIAL	AMR	Functional	100%	0	0.00			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK263A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.00			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK257A-1	400	COMMERCIAL	AMR	Functional	100%	5	0.00			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK248A-1	100	COMMERCIAL	AMR	Functional	100%	0	0.00			
66 kV TIKRI KALAN GRID	WMUND606	11kV FDR AZAD HIND GRAM	TP-MDK269A-1	100	MIXED		Functional	100%	0	0.00			
66 kV NANGLOI GRID	WNNG121	11kV FDR PUNJABI BASTI	TG-MDK024A-1	990	RESIDENTIAL		Functional	100%	1121	0.77	2.60	0.17	6.19%
66 kV NANGLOI GRID	WNNG121	11kV FDR PUNJABI BASTI	TG-MDK004A-1	630	RESIDENTIAL	AMR	Functional	100%	493	0.64			
66 kV NANGLOI GRID	WNNG121	11kV FDR PUNJABI BASTI	TG-MDK004A-2	630	RESIDENTIAL	AMR	Functional	100%	725	0.48			
66 kV NANGLOI GRID	WNNG121	11kV FDR PUNJABI BASTI	TG-MDK003A-2	990	RESIDENTIAL	AMR	Functional	100%	144	0.38			
66 kV NANGLOI GRID	WNNG119	11kV FDR J.J. COLONEY NO. 2	TG-MDK003A-1	630	RESIDENTIAL		Functional	100%	489	0.27			
66 kV NANGLOI GRID	WNNG121	11kV FDR PUNJABI BASTI	TI-MDK275A-1	630	RESIDENTIAL	AMR	Functional	100%	181	0.17			
66 kV NANGLOI GRID	WNNG121	11kV FDR PUNJABI BASTI	631SPK-MDK571A	400	MIXED		Functional	100%	0	0.05			
66 kV NANGLOI GRID	WNNG117	11kV FDR BAKKAR WALA	TI-MDK080A-1	990	RESIDENTIAL	AMR	Functional	100%	979	0.79	4.35	0.29	6.14%
66 kV NANGLOI GRID	WNNG111	11kV FDR RAJENDERA PARK	TI-MDK065A-1	630	RESIDENTIAL	AMR	Functional	100%	458	0.73			
66 kV NANGLOI GRID	WNNG117	11kV FDR BAKKAR WALA	TI-MDK043A-2	990	RESIDENTIAL	AMR	Functional	100%	484	0.62			
66 kV NANGLOI GRID	WNNG117	11kV FDR BAKKAR WALA	TI-MDK064A-1	630	RESIDENTIAL		Functional	100%	599	0.53			
66 kV NANGLOI GRID	WNNG117	11kV FDR BAKKAR WALA	631SPK-MDK063A	630	RESIDENTIAL		Functional	100%	0	0.51			
66 kV NANGLOI GRID	WNNG117	11kV FDR BAKKAR WALA	TI-MDK043A-1	990	RESIDENTIAL	AMR	Functional	100%	0	0.51			
66 kV NANGLOI GRID	WNNG117	11kV FDR BAKKAR WALA	TI-MDK063A-1	630	RESIDENTIAL		Functional	100%	778	0.41			
66 kV NANGLOI GRID	WNNG111	11kV FDR RAJENDERA PARK	TG-MDK079A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.27			
66 kV NANGLOI GRID	WNNG111	11kV FDR RAJENDERA PARK	TI-MDK079A-1	630	RESIDENTIAL	AMR	Functional	100%	1328	0.27			
66 kV NANGLOI W.W GRID	WNNWW123	11kV FDR JAI VIHAR	TG-MDK273A-1	990	RESIDENTIAL	AMR	Functional	100%	480	1.16	6.40	0.84	11.56%
66 kV NANGLOI W.W GRID	WNNWW123	11kV FDR JAI VIHAR	TG-MDK022A-1	990	RESIDENTIAL	AMR	Functional	100%	225	0.89			
66kV NILOTHI GRID	WNILO133	11kV FDR MEERA ENCLAVE	TP-MDK071A-1	630	RESIDENTIAL	AMR	Functional	100%	197	0.77			
66kV NILOTHI GRID	WNILO133	11kV FDR MEERA ENCLAVE	TG-MDK409A-1	990	RESIDENTIAL	AMR	Functional	100%	460	0.71			
66kV NILOTHI GRID	WNILO133	11kV FDR MEERA ENCLAVE	TP-MDK143A-1	990	RESIDENTIAL	AMR	Functional	100%	280	0.63			
66kV NILOTHI GRID	WNILO133	11kV FDR MEERA ENCLAVE	TG-MDK409A-3	630	RESIDENTIAL	AMR	Functional	100%	0	0.61			
66 kV NANGLOI W.W GRID	WNNWW107	11kV FDR HANUMAN MANDIR	TP-MDK369A-1	630	RESIDENTIAL	AMR	Functional	100%	632	0.51			
66 kV NANGLOI W.W GRID	WNNWW123	11kV FDR JAI VIHAR	TP-MDK241A-1	630	RESIDENTIAL	AMR	Functional	100%	620	0.45			
66 kV NANGLOI W.W GRID	WNNWW107	11kV FDR HANUMAN MANDIR	TP-MDK368A-1	630	RESIDENTIAL		Functional	100%	304	0.42			
66kV NILOTHI GRID	WNILO133	11kV FDR MEERA ENCLAVE	TG-MDK409A-2	990	RESIDENTIAL	AMR	Functional	100%	461	0.38			
66 kV NANGLOI W.W GRID	WNNWW123	11kV FDR JAI VIHAR	631DSI-MDK559A	630	RESIDENTIAL	AMR	Functional	100%	165	0.33			

66kV NILOTHI GRID	WNLO133	11kV FDR MEERA ENCLAVE	TP-MDK410A-1	630	RESIDENTIAL	AMR	Functional	100%	185	0.23			
66 kV NANGLOI W.W GRID	WNNWW123	11kV FDR JAI VIHAR	TP-MDK506A-1	400	RESIDENTIAL	AMR	Functional	100%	196	0.08			
66 kV NANGLOI W.W GRID	WNNWW107	11kV FDR HANUMAN MANDIR	631DSI-MDK568A	400	RESIDENTIAL	AMR	Functional	100%	368	0.05			
66 kV NANGLOI W.W GRID	WNNWW107	11kV FDR HANUMAN MANDIR	TP-MDK411A-1	100	RESIDENTIAL	AMR	Functional	100%	25	0.03			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	TP-MDK153A-1	630	INDUSTRIAL	AMR	Functional	100%	16	0.54	4.37	0.23	4.97%
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK314A-1	630	RESIDENTIAL	AMR	Functional	100%	8	0.41			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	TP-MDK326A-1	400	INDUSTRIAL	AMR	Functional	100%	46	0.35			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	TP-MDK310A-1	630	RESIDENTIAL	AMR	Functional	100%	10	0.29			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	TG-MDK334A-1	990	INDUSTRIAL	AMR	Functional	100%	47	0.26			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	TP-MDK327A-1	400	INDUSTRIAL	AMR	Functional	100%	113	0.24			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK147A-1	630	INDUSTRIAL	AMR	Functional	100%	11	0.22			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK149A-1	400	INDUSTRIAL	AMR	Functional	100%	11	0.20			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK156A-1	400	INDUSTRIAL		Functional	100%	19	0.19			
66 kV NANGLOI W.W GRID	WNNWW118	11kV FDR VRINDAVAN VATIKA	631SPK-MDK576A	630	MIXED	AMR	Functional	100%	0	0.19			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	TP-MDK311A-1	400	INDUSTRIAL	AMR	Functional	100%	41	0.15			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK217A-1	400	INDUSTRIAL	AMR	Functional	100%	14	0.15			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK315A-1	400	INDUSTRIAL	AMR	Functional	100%	13	0.15			
66 kV NANGLOI W.W GRID	WNNWW118	11kV FDR VRINDAVAN VATIKA	631SPK-MDK573A	630	RESIDENTIAL	AMR	Functional	100%	154	0.13			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	TP-MDK331A-1	990	INDUSTRIAL	AMR	Functional	100%	14	0.12			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK154A-1	400	RESIDENTIAL	AMR	Functional	100%	25	0.12			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK337A-1	100	INDUSTRIAL	AMR	Functional	100%	1	0.10			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	TP-MDK317A-1	400	INDUSTRIAL	AMR	Functional	100%	5	0.10			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	TP-MDK312A-1	400	INDUSTRIAL	AMR	Functional	100%	9	0.10			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	TP-MDK151A-1	400	INDUSTRIAL	AMR	Functional	100%	16	0.09			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK155A-1	400	INDUSTRIAL	AMR	Functional	100%	6	0.08			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK148A-1	400	INDUSTRIAL	AMR	Functional	100%	8	0.08			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	TP-MDK335A-1	400	RESIDENTIAL		Functional	100%	90	0.08			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK328A-1	400	INDUSTRIAL		Functional	100%	57	0.05			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TG-MDK216A-1	400	INDUSTRIAL	AMR	Functional	100%	8	0.05			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	TP-MDK313A-1	400	INDUSTRIAL	AMR	Functional	100%	8	0.05			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK150A-1	100	INDUSTRIAL	AMR	Functional	100%	12	0.04			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK316A-1	100	INDUSTRIAL	AMR	Functional	100%	13	0.02			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK398A-1	100	INDUSTRIAL	AMR	Functional	100%	2	0.01			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	TP-MDK396A-1	100	INDUSTRIAL	AMR	Functional	100%	3	0.01			
66 kV TIKRI KALAN GRID	WMUND117	11kV FDR SHIVA GARDEN	TP-MDK152A-1	100	INDUSTRIAL	AMR	Functional	100%	37	0.00			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK158A-1	630	RESIDENTIAL	AMR	Functional	100%	25	0.45	3.08	0.53	14.78%
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TG-MDK021A-1	400	RESIDENTIAL	AMR	Functional	100%	9	0.45			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK332A-1	630	INDUSTRIAL		Functional	100%	85	0.40			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK333A-1	400	INDUSTRIAL	AMR	Functional	100%	38	0.28			
66 kV NANGLOI W.W GRID	WNNWW118	11kV FDR VRINDAVAN VATIKA	631SPK-MDK543A	400	RESIDENTIAL	AMR	Functional	100%	16	0.25			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK163A-1	400	INDUSTRIAL	AMR	Functional	100%	80	0.24			
66 kV NANGLOI GRID	WNNGL124	11kV FDR I.O.C	TP-MDK165A-1	400	INDUSTRIAL		Functional	100%	22	0.21			
66 kV NANGLOI GRID	WNNGL124	11kV FDR I.O.C	TP-MDK214A-1	630	RESIDENTIAL		Functional	100%	14	0.20			
66 kV TIKRI KALAN GRID	WMUND609	11KV FDR NO-1 821,DDA FLATS,BAKKARWALA,MDK	631SPK-MDK592A	630	MIXED		Functional	100%	0	0.19			
66 kV TIKRI KALAN GRID	WMUND609	11KV FDR NO-1 821,DDA FLATS,BAKKARWALA,MDK	631SPK-MDK592A	630	MIXED		Functional	100%	0	0.19			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK161A-1	400	INDUSTRIAL	AMR	Functional	100%	26	0.18			
66 kV NANGLOI GRID	WNNGL124	11kV FDR I.O.C	TP-MDK162A-1	400	RESIDENTIAL	AMR	Functional	100%	9	0.14			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK159A-1	400	INDUSTRIAL	AMR	Functional	100%	36	0.11			
66 kV NANGLOI GRID	WNNGL124	11kV FDR I.O.C	TP-MDK215A-1	400	INDUSTRIAL	AMR	Functional	100%	7	0.09			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK146A-1	400	INDUSTRIAL	AMR	Functional	100%	9	0.04			

66 kV NANGLOI GRID	WNNGL124	11kV FDR I.O.C	TP-MDK213A-1	100	INDUSTRIAL		Functional	100%	2	0.04			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK179A-1	100	INDUSTRIAL	AMR	Functional	100%	38	0.04			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK160A-1	400	INDUSTRIAL	AMR	Functional	100%	21	0.03			
66 kV NANGLOI GRID	WNNGL124	11kV FDR I.O.C	TP-MDK329A-1	100	INDUSTRIAL		Functional	100%	69	0.02			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK157A-1	400	INDUSTRIAL	AMR	Functional	100%	12	0.02			
66 kV NANGLOI GRID	WNNGL124	11kV FDR I.O.C	TP-MDK164A-1	100	INDUSTRIAL	AMR	Functional	100%	41	0.01			
66 kV NANGLOI W.W GRID	WNNWW122	11kV FDR MUNDKA LT LESS	TP-MDK330A-1	100	INDUSTRIAL	AMR	Functional	100%	95	0.01			
66 kV NANGLOI GRID	WNNGL118	11kV FDR POLICE QUATERS	MD-HVD007A-1	3925	RESIDENTIAL		Functional	100%	2485	2.16	6.24	0.56	8.24%
66 kV NANGLOI W.W GRID	WNNWW113	11kV FDR YADAV PARK EXT	MD-HVD013A-1	2375	RESIDENTIAL		Functional	100%	1686	1.28			
66 kV NANGLOI GRID	WNNGL111	11kV FDR RAJENDERA PARK	MD-HVD015A-1	2525	RESIDENTIAL		Functional	100%	1722	1.10			
66 kV NANGLOI GRID	WNNGL111	11kV FDR RAJENDERA PARK	MD-HVD017A-1	1925	RESIDENTIAL		Functional	100%	1028	0.82			
66kV NILOTHI GRID	WNILO131	11kV FDR CHANCHAL PARK	MD-HVD027A-1	1050	RESIDENTIAL		Functional	100%	681	0.34			
66kV NILOTHI GRID	WNILO131	11kV FDR CHANCHAL PARK	MD-HVD023A-1	675	RESIDENTIAL		Functional	100%	571	0.27			
66 kV NANGLOI W.W GRID	WNNWW113	11kV FDR YADAV PARK EXT	MD-HVD011A-1	600	RESIDENTIAL		Functional	100%	113	0.25			
66 kV NANGLOI W.W GRID	WNNWW105	11kV FDR RANHOLLA	MD-HVD020A-1	500	RESIDENTIAL		Functional	100%	307	0.24			
66 kV NANGLOI W.W GRID	WNNWW114	11kV FDR DDA. FLATS	MD-HVD025A-1	425	RESIDENTIAL		Functional	100%	181	0.16			
66kV NILOTHI GRID	WNILO131	11kV FDR CHANCHAL PARK	MD-HVD008A-1	700	RESIDENTIAL		Functional	100%	254	0.15			
66 kV NANGLOI W.W GRID	WNNWW123	11kV FDR JAI VIHAR	MD-HVD003A-1	125	RESIDENTIAL		Functional	100%	39	0.04			
33 kV PASCHIM PURI GRID	WPSCP107	11kV STR 100KVA STATION TRANSFORMER	TG-WTC017A-1	100	RESIDENTIAL		Functional	100%	3	0.02	4.40	0.21	4.49%
33 kV S.B.MILL GRID	WSBML115	11kV STR 100KVA STATION TRANSFORMER	TG-WTC127A-1	100	RESIDENTIAL		Functional	100%	2	0.01			
33 kV PASCHIM PURI GRID	WPSCP338	11kV FDR A-1 JANTA SS PASCHIM VIHAR	640BPV-PAS019A-	990	RESIDENTIAL		Functional	100%	346	0.67			
33 kV PASCHIM PURI GRID	WPSCP106	11kV FDR M.I.G MILANSAR APPARTMENT	640BPV-PAS023A-	990	RESIDENTIAL		Functional	100%	352	0.55			
33 kV PASCHIM PURI GRID	WPSCP338	11kV FDR A-1 JANTA SS PASCHIM VIHAR	640BPV-PAS104A-	630	RESIDENTIAL		Functional	100%	137	0.44			
33 kV PASCHIM PURI GRID	WPSCP121	11kV FDR D.T.C DEPOT	640BPV-PAS024A-	990	RESIDENTIAL		Functional	100%	62	0.42			
33 kV PASCHIM PURI GRID	WPSCP121	11kV FDR D.T.C DEPOT	640BPV-PAS022A-	990	RESIDENTIAL		Functional	100%	461	0.38			
33 kV PASCHIM PURI GRID	WPSCP121	11kV FDR D.T.C DEPOT	640BPV-PAS021A-	630	RESIDENTIAL		Functional	100%	191	0.36			
33 kV PASCHIM PURI GRID	WPSCP338	11kV FDR A-1 JANTA SS PASCHIM VIHAR	640BPV-PAS019A-	990	RESIDENTIAL		Functional	100%	448	0.33			
33 kV PASCHIM PURI GRID	WPSCP121	11kV FDR D.T.C DEPOT	640BPV-PAS022A-	630	RESIDENTIAL		Functional	100%	187	0.28			
33 kV PASCHIM PURI GRID	WPSCP106	11kV FDR M.I.G MILANSAR APPARTMENT	640BPV-PAS023A-	630	RESIDENTIAL		Functional	100%	299	0.25			
33 kV PASCHIM PURI GRID	WPSCP121	11kV FDR D.T.C DEPOT	640BPV-PAS020A-	630	RESIDENTIAL		Functional	100%	41	0.21			
33 kV PASCHIM PURI GRID	WPSCP121	11kV FDR D.T.C DEPOT	640BPV-PAS020A-	990	RESIDENTIAL		Functional	100%	358	0.20			
33 kV PASCHIM PURI GRID	WPSCP121	11kV FDR D.T.C DEPOT	640BPV-PAS116A-	400	MIXED		Functional	100%	0	0.10			
33 kV PASCHIM PURI GRID	WPSCP106	11kV FDR M.I.G MILANSAR APPARTMENT	640BPV-PAS083A-	630	RESIDENTIAL		Functional	100%	14	0.09			
33 kV PASCHIM PURI GRID	WPSCP106	11kV FDR M.I.G MILANSAR APPARTMENT	640BPV-PAS083A-	630	RESIDENTIAL		Functional	100%	286	0.09			
33 kV PASCHIM PURI GRID	WPSCP106	11kV FDR M.I.G MILANSAR APPARTMENT	640BPV-PAS084A-	630	RESIDENTIAL		Functional	100%	230	0.08			
33 kV PASCHIM PURI GRID	WPSCP106	11kV FDR M.I.G MILANSAR APPARTMENT	640BPV-PAS084A-	630	RESIDENTIAL		Functional	100%	22	0.08			
33 kV PASCHIM PURI GRID	WPSCP121	11kV FDR D.T.C DEPOT	640BPV-PAS100A-	400	INDUSTRIAL		Functional	100%	8	0.03			
33 kV PASCHIM PURI GRID	WPSCP115	11kV FDR A-6 PASCHIM VIHAR	640BPV-PAS074A-	1000	RESIDENTIAL		Functional	100%	513	0.62	1.76	0.04	2.31%
33 kV PASCHIM PURI GRID	WPSCP115	11kV FDR A-6 PASCHIM VIHAR	640BPV-PAS075A-	630	RESIDENTIAL		Functional	100%	616	0.36			
66 kV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH116	11kV FDR CAPITAL MALL PASCHIM VIHAR	640BPV-PAS112A-	400	MIXED		Functional	100%	317	0.35			
33 kV PASCHIM PURI GRID	WPSCP115	11kV FDR A-6 PASCHIM VIHAR	640BPV-PAS072A-	630	RESIDENTIAL		Functional	100%	140	0.19			
33 kV PASCHIM PURI GRID	WPSCP115	11kV FDR A-6 PASCHIM VIHAR	640BPV-PAS072A-	400	RESIDENTIAL		Functional	100%	191	0.16			
33 kV PASCHIM PURI GRID	WPSCP115	11kV FDR A-6 PASCHIM VIHAR	640BPV-PAS073A-	630	RESIDENTIAL		Functional	100%	75	0.09			
33 kV PASCHIM PURI GRID	WPSCP122	11kV FDR A-2 COMMUNITY CENTER	640BPV-PAS043A-	630	RESIDENTIAL		Functional	100%	22	0.04			
33 kV PASCHIM PURI GRID	WPSCP121	11kV FDR D.T.C DEPOT	640BPV-PAS026A-	990	INDUSTRIAL		Functional	100%	0	0.74	1.08	0.24	18.01%
33 kV PASCHIM PURI GRID	WPSCP121	11kV FDR D.T.C DEPOT	640BPV-PAS111A-	400	RESIDENTIAL		Functional	100%	1778	0.21			
33 kV PASCHIM PURI GRID	WPSCP121	11kV FDR D.T.C DEPOT	640BPV-PAS115A-	400	RESIDENTIAL		Functional	100%	0	0.19			
33 kV PASCHIM PURI GRID	WPSCP121	11kV FDR D.T.C DEPOT	640BPV-PAS089A-	400	INDUSTRIAL		Functional	100%	176	0.17			
33 kV PASCHIM PURI GRID	WPSCP110	11kV FDR A-2 SSTN.	640BPV-PAS016A-	990	RESIDENTIAL		Functional	100%	404	0.60	3.33	0.19	5.44%

33 kv PASCHIM PURI GRID	WPSCP110	11kv FDR A-2 SSTN.	640BPV-PAS017A-	990	RESIDENTIAL	Functional	100%	343	0.53			
33 kv PASCHIM PURI GRID	WPSCP110	11kv FDR A-2 SSTN.	640BPV-PAS014A-	990	RESIDENTIAL	Functional	100%	352	0.48			
33 kv PASCHIM PURI GRID	WPSCP110	11kv FDR A-2 SSTN.	640BPV-PAS014A-	990	RESIDENTIAL	Functional	100%	226	0.33			
33 kv PASCHIM PURI GRID	WPSCP122	11kv FDR A-2 COMMUNITY CENTER	640BPV-PAS053A-	630	RESIDENTIAL	Functional	100%	192	0.33			
33 kv PASCHIM PURI GRID	WPSCP110	11kv FDR A-2 SSTN.	640BPV-PAS016A-	630	RESIDENTIAL	Functional	100%	226	0.28			
33 kv PASCHIM PURI GRID	WPSCP122	11kv FDR A-2 COMMUNITY CENTER	640BPV-PAS052A-	630	RESIDENTIAL	Functional	100%	173	0.28			
33 kv PASCHIM PURI GRID	WPSCP338	11kv FDR A-1 JANTA SS PASCHIM VIHAR	640BPV-PAS018A-	630	RESIDENTIAL	Functional	100%	193	0.27			
33 kv PASCHIM PURI GRID	WPSCP122	11kv FDR A-2 COMMUNITY CENTER	640BPV-PAS015A-	630	RESIDENTIAL	Functional	100%	111	0.17			
33 kv PASCHIM PURI GRID	WPSCP122	11kv FDR A-2 COMMUNITY CENTER	640BPV-PAS015A-	400	RESIDENTIAL	Functional	100%	138	0.09			
33 kv PASCHIM PURI GRID	WPSCP122	11kv FDR A-2 COMMUNITY CENTER	640BPV-PAS052A-	400	RESIDENTIAL	Functional	100%	137	0.09			
33 kv PASCHIM PURI GRID	WPSCP110	11kv FDR A-2 SSTN.	640BPV-PAS016A-	630	RESIDENTIAL	Functional	100%	64	0.07			
33 kv PASCHIM PURI GRID	WPSCP113	11kv FDR B-3 PASCHIM VIHAR	640BPV-PAS113A-	630	MIXED	Functional	100%	0	0.00			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV106	11kv FDR COTTEGE ENCLAVE	640BPV-PAS058A-	990	RESIDENTIAL	Functional	100%	344	0.62	2.99	0.11	3.53%
33 kv PASCHIM PURI GRID	WPSCP115	11kv FDR A-6 PASCHIM VIHAR	640BPV-PAS095A-	630	RESIDENTIAL	Functional	100%	165	0.40			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV106	11kv FDR COTTEGE ENCLAVE	640BPV-PAS058A-	990	RESIDENTIAL	Functional	100%	295	0.36			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV106	11kv FDR COTTEGE ENCLAVE	640BPV-PAS068A-	630	RESIDENTIAL	Functional	100%	138	0.30			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV103	11kv FDR SITE-7	640BPV-PAS069A-	630	RESIDENTIAL	Functional	100%	158	0.25			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV106	11kv FDR COTTEGE ENCLAVE	640BPV-PAS068A-	400	RESIDENTIAL	Functional	100%	170	0.19			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV103	11kv FDR SITE-7	640BPV-PAS071A-	1000	RESIDENTIAL	Functional	100%	64	0.19			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV103	11kv FDR SITE-7	640BPV-PAS069A-	990	RESIDENTIAL	Functional	100%	282	0.18			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV106	11kv FDR COTTEGE ENCLAVE	640BPV-PAS097A-	990	RESIDENTIAL	Functional	100%	77	0.17			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV106	11kv FDR COTTEGE ENCLAVE	640BPV-PAS097A-	630	RESIDENTIAL	Functional	100%	177	0.14			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV103	11kv FDR SITE-7	640BPV-PAS063A-	990	RESIDENTIAL	Functional	100%	61	0.10			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV103	11kv FDR SITE-7	640BPV-PAS063A-	630	RESIDENTIAL	Functional	100%	43	0.09			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV103	11kv FDR SITE-7	640BPV-PAS071A-	630	RESIDENTIAL	Functional	100%	112	0.09			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV109	11kv STR 100KVA STATION TRANSFORMER-2	TG-WTC115A-2	100	MIXED	Functional	100%	0	0.03			
33 kv PASCHIM PURI GRID	WPSCP102	11kv FDR PEERA GARHI BOOSTER PUMP	640BPV-PAS038A-	990	RESIDENTIAL	Functional	100%	460	0.83	4.89	0.47	8.78%
66 kv PASCHIM VIHAR GRID	WPSCV113	11kv FDR PEERAGARHI BOOSTER PUMP	640BPV-PAS077A-	990	RESIDENTIAL	Functional	100%	615	0.62			
33 kv PASCHIM PURI GRID	WPSCP113	11kv FDR B-3 PASCHIM VIHAR	640BPV-PAS027A-	990	RESIDENTIAL	Functional	100%	831	0.49			
33 kv PASCHIM PURI GRID	WPSCP102	11kv FDR PEERA GARHI BOOSTER PUMP	640BPV-PAS012A-	630	RESIDENTIAL	Functional	100%	304	0.48			
33 kv PASCHIM PURI GRID	WPSCP113	11kv FDR B-3 PASCHIM VIHAR	640BPV-PAS027A-	990	RESIDENTIAL	Functional	100%	197	0.48			
66 kv PASCHIM VIHAR GRID	WPSCV113	11kv FDR PEERAGARHI BOOSTER PUMP	640BPV-PAS041A-	990	RESIDENTIAL	Functional	100%	280	0.47			
66 kv PASCHIM VIHAR GRID	WPSCV113	11kv FDR PEERAGARHI BOOSTER PUMP	640BPV-PAS012A-	630	RESIDENTIAL	Functional	100%	139	0.34			
33 kv PASCHIM PURI GRID	WPSCP102	11kv FDR PEERA GARHI BOOSTER PUMP	640BPV-PAS039A-	990	RESIDENTIAL	Functional	100%	274	0.33			
33 kv PASCHIM PURI GRID	WPSCP102	11kv FDR PEERA GARHI BOOSTER PUMP	640BPV-PAS013A-	630	RESIDENTIAL	Functional	100%	551	0.27			
66 kv PASCHIM VIHAR GRID	WPSCV113	11kv FDR PEERAGARHI BOOSTER PUMP	640BPV-PAS042A-	400	RESIDENTIAL	Functional	100%	191	0.24			
66 kv PASCHIM VIHAR GRID	WPSCV113	11kv FDR PEERAGARHI BOOSTER PUMP	640BPV-PAS001A-	630	RESIDENTIAL	Functional	100%	192	0.21			
66 kv PASCHIM VIHAR GRID	WPSCV113	11kv FDR PEERAGARHI BOOSTER PUMP	640BPV-PAS001A-	630	RESIDENTIAL	Functional	100%	346	0.21			
33 kv PASCHIM PURI GRID	WPSCP102	11kv FDR PEERA GARHI BOOSTER PUMP	640BPV-PAS039A-	400	COMMERCIAL	Functional	100%	94	0.19			
66 kv PASCHIM VIHAR GRID	WPSCV113	11kv FDR PEERAGARHI BOOSTER PUMP	640BPV-PAS108A-	400	RESIDENTIAL	Functional	100%	105	0.19			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV105	11kv FDR MULTAN NAGAR (C-BLOCK)	640BPV-PAS114A-	400	MIXED	Functional	100%	0	0.00			
33 kv PASCHIM PURI GRID	WPSCP113	11kv FDR B-3 PASCHIM VIHAR	640BPV-PAS028A-	990	RESIDENTIAL	Functional	100%	607	0.68	4.28	0.18	3.93%

33 kv A - 4 PASCHIM VIHAR GRID	WA4PV111	11kv FDR B.G-3	640BPV-PAS032A-	630	RESIDENTIAL		Functional	100%	185	0.57			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV111	11kv FDR B.G-3	640BPV-PAS030A-	990	RESIDENTIAL		Functional	100%	573	0.55			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV111	11kv FDR B.G-3	640BPV-PAS029A-	630	RESIDENTIAL		Functional	100%	564	0.46			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV111	11kv FDR B.G-3	640BPV-PAS031A-	630	RESIDENTIAL		Functional	100%	332	0.43			
33 kv PASCHIM PURI GRID	WPSCP113	11kv FDR B-3 PASCHIM VIHAR	640BPV-PAS028A-	990	RESIDENTIAL		Functional	100%	291	0.34			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV111	11kv FDR B.G-3	640BPV-PAS031A-	990	RESIDENTIAL		Functional	100%	122	0.34			
33 kv PASCHIM PURI GRID	WPSCP113	11kv FDR B-3 PASCHIM VIHAR	640BPV-PAS078A-	990	RESIDENTIAL		Functional	100%	392	0.31			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV111	11kv FDR B.G-3	640BPV-PAS033A-	630	RESIDENTIAL		Functional	100%	281	0.27			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH116	11kv FDR CAPITAL MALL PASCHIM VIHAR	640BPV-PAS033A-	630	RESIDENTIAL		Functional	100%	210	0.24			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV111	11kv FDR B.G-3	640BPV-PAS030A-	630	RESIDENTIAL		Functional	100%	151	0.17			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV103	11kv FDR SITE-7	640BPV-PAS110A-	400	RESIDENTIAL		Functional	100%	138	0.11			
33 kv PASCHIM PURI GRID	WPSCP112	11kv FDR B-2 SSTN.	640BPV-PAS037A-	990	RESIDENTIAL		Functional	100%	258	0.65	3.47	0.04	1.19%
33 kv PASCHIM PURI GRID	WPSCP112	11kv FDR B-2 SSTN.	640BPV-PAS036A-	990	RESIDENTIAL		Functional	100%	313	0.57			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH116	11kv FDR CAPITAL MALL PASCHIM VIHAR	640BPV-PAS034A-	1000	RESIDENTIAL		Functional	100%	187	0.48			
33 kv PASCHIM PURI GRID	WPSCP112	11kv FDR B-2 SSTN.	640BPV-PAS037A-	990	RESIDENTIAL		Functional	100%	659	0.47			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH116	11kv FDR CAPITAL MALL PASCHIM VIHAR	640BPV-PAS034A-	990	RESIDENTIAL		Functional	100%	54	0.44			
33 kv PASCHIM PURI GRID	WPSCP112	11kv FDR B-2 SSTN.	640BPV-PAS035A-	630	RESIDENTIAL		Functional	100%	263	0.41			
33 kv PASCHIM PURI GRID	WPSCP112	11kv FDR B-2 SSTN.	640BPV-PAS035A-	630	RESIDENTIAL		Functional	100%	170	0.36			
33 kv PASCHIM PURI GRID	WPSCP112	11kv FDR B-2 SSTN.	640BPV-PAS037A-	630	RESIDENTIAL		Functional	100%	0	0.15			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV123	11kv FDR HANSRAJ MODEL SCHOOL	640R41-PBG051A-	990	RESIDENTIAL		Functional	100%	578	0.80	4.82	0.07	1.49%
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV123	11kv FDR HANSRAJ MODEL SCHOOL	640R41-PBG048A-	630	RESIDENTIAL		Functional	100%	122	0.71			
33 kv MADIPUR GRID	WM DPR102	11kv FDR PAL MOHAN APART.	640R41-PBG049A-	990	RESIDENTIAL		Functional	100%	99	0.47			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV115	11kv FDR ADRSH BHAWAN	640R41-PBG053A-	990	RESIDENTIAL		Functional	100%	288	0.46			
33 kv MADIPUR GRID	WM DPR111	11kv FDR ADARSH BHAWAN	640R41-PBG052A-	990	RESIDENTIAL		Functional	100%	108	0.44			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV123	11kv FDR HANSRAJ MODEL SCHOOL	640R41-PBG050A-	990	RESIDENTIAL		Functional	100%	132	0.37			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV123	11kv FDR HANSRAJ MODEL SCHOOL	640R41-PBG014A-	990	RESIDENTIAL		Functional	100%	0	0.36			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV115	11kv FDR ADRSH BHAWAN	640R41-PBG052A-	990	RESIDENTIAL		Functional	100%	182	0.35			
33 kv MADIPUR GRID	WM DPR102	11kv FDR PAL MOHAN APART.	640R41-PBG049A-	990	RESIDENTIAL		Functional	100%	90	0.32			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV123	11kv FDR HANSRAJ MODEL SCHOOL	640R41-PBG014A-	990	RESIDENTIAL		Functional	100%	602	0.27			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV115	11kv FDR ADRSH BHAWAN	640R41-PBG061A-	630	RESIDENTIAL		Functional	100%	173	0.21			
33 kv MADIPUR GRID	WM DPR102	11kv FDR PAL MOHAN APART.	640R41-PBG049A-	990	RESIDENTIAL		Functional	100%	88	0.14			
33 kv S.B.MILL GRID	WSBML106	11kv FDR J.J CLUSTER SHIVA NAND SCHOOL	640KRP-KAM001A-	990	RESIDENTIAL		Functional	100%	561	0.62	4.28	0.03	0.76%
33 kv NDPL ROHTAK ROAD	NRHTK103	11kv FDR BHAGWAN DAS NAGAR	640KRP-KAM030A-	990	RESIDENTIAL		Functional	100%	159	0.60			
33 kv NDPL ROHTAK ROAD	NRHTK107	11kv FDR JAIDEV PARK	640KRP-KAM034A-	630	COMMERCIAL		Functional	100%	445	0.40			
33 kv NDPL ROHTAK ROAD	NRHTK107	11kv FDR JAIDEV PARK	640KRP-KAM032A-	990	RESIDENTIAL		Functional	100%	327	0.39			
33 kv NDPL ROHTAK ROAD	NRHTK107	11kv FDR JAIDEV PARK	640KRP-KAM032A-	630	RESIDENTIAL		Functional	100%	235	0.35			
33 kv S.B.MILL GRID	WSBML106	11kv FDR J.J CLUSTER SHIVA NAND SCHOOL	640KRP-KAM030A-	630	RESIDENTIAL		Functional	100%	172	0.32			
33 kv NDPL ROHTAK ROAD	NRHTK107	11kv FDR JAIDEV PARK	640KRP-KAM033A-	400	RESIDENTIAL		Functional	100%	156	0.31			
33 kv S.B.MILL GRID	WSBML106	11kv FDR J.J CLUSTER SHIVA NAND SCHOOL	640KRP-KAM049A-	990	RESIDENTIAL		Functional	100%	237	0.31			

33 kv S.B.MILL GRID	WSBML106	11KV FDR J.J CLUSTER SHIVA NAND SCHOOL	640KRP-KAM001A	630	RESIDENTIAL	Functional	100%	346	0.30			
33 kv S.B.MILL GRID	WSBML106	11KV FDR J.J CLUSTER SHIVA NAND SCHOOL	640KRP-KAM002A	990	RESIDENTIAL	Functional	100%	361	0.23			
33 kv S.B.MILL GRID	WSBML106	11KV FDR J.J CLUSTER SHIVA NAND SCHOOL	640KRP-KAM035A	990	COMMERCIAL	Functional	100%	112	0.19			
33 kv S.B.MILL GRID	WSBML106	11KV FDR J.J CLUSTER SHIVA NAND SCHOOL	640KRP-KAM004A	400	RESIDENTIAL	Functional	100%	185	0.19			
33 kv S.B.MILL GRID	WSBML106	11KV FDR J.J CLUSTER SHIVA NAND SCHOOL	640KRP-KAM047A	400	COMMERCIAL	Functional	100%	55	0.11			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV114	11KV FDR SWAYAM SIDHA	640R41-PBG007A	990	RESIDENTIAL	Functional	100%	768	0.95	4.84	0.29	5.70%
33 kv W.D.D.C (VISHAL) GRID	WVSHL107	11KV FDR PUNJABI BAGH BOOSTER PUMP	640R41-PBG047A	990	RESIDENTIAL	Functional	100%	240	0.87			
33 kv W.D.D.C (VISHAL) GRID	WVSHL107	11KV FDR PUNJABI BAGH BOOSTER PUMP	640R41-PBG001A	1600	RESIDENTIAL	Functional	100%	220	0.77			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV114	11KV FDR SWAYAM SIDHA	640R41-PBG008A	990	RESIDENTIAL	Functional	100%	125	0.67			
33 kv W.D.D.C (VISHAL) GRID	WVSHL107	11KV FDR PUNJABI BAGH BOOSTER PUMP	640R41-PBG002A	990	RESIDENTIAL	Functional	100%	265	0.49			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV114	11KV FDR SHWAYAM SIDHA	640R41-PBG008B	990	RESIDENTIAL	Functional	100%	0	0.40			
33 kv W.D.D.C (VISHAL) GRID	WVSHL107	11KV FDR PUNJABI BAGH BOOSTER PUMP	640R41-PBG047A	630	RESIDENTIAL	Functional	100%	354	0.38			
33 kv MADIPUR GRID	WMDPR107	11KV FDR 240 MIG FLATS (208 SFS) MADIPUR	640R41-PBG009A	630	RESIDENTIAL	Functional	100%	418	0.38			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV114	11KV FDR SWAYAM SIDHA	640R41-PBG008A	990	RESIDENTIAL	Functional	100%	388	0.17			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV114	11KV FDR SWAYAM SIDHA	640R41-PBG007A	400	RESIDENTIAL	Functional	100%	100	0.05			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV121	11KV FDR C-BLK MADIPUR	640R41-PBG031A	1600	RESIDENTIAL	Functional	100%	792	1.45	3.97	0.32	7.57%
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV102	11KV FDR PASCHIM VIHAR EXT.	640R41-PBG030A	990	RESIDENTIAL	Functional	100%	1425	0.73			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV102	11KV FDR PASCHIM VIHAR EXT.	640R41-PBG031A	990	RESIDENTIAL	Functional	100%	850	0.65			
33 kv MADIPUR GRID	WMDPR112	11KV FDR 6 MILE STONE MADIPUR GATE	640R41-PBG057A	990	RESIDENTIAL	Functional	100%	339	0.57			
33 kv MADIPUR GRID	WMDPR107	11KV FDR 240 MIG FLATS (208 SFS) MADIPUR	640R41-PBG058A	990	RESIDENTIAL	Functional	100%	1401	0.46			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV102	11KV FDR PASCHIM VIHAR EXT.	640R41-PBG031A	990	RESIDENTIAL	Functional	100%	505	0.24			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV102	11KV FDR PASCHIM VIHAR EXT.	TG-PBG030A-2	400	RESIDENTIAL	Functional	100%	361	0.12			
33 kv MADIPUR GRID	WMDPR112	11KV FDR 6 MILE STONE MADIPUR GATE	640R41-PBG104A	400	MIXED	Functional	100%	0	0.07			
33 kv NDPL ROHTAK ROAD	NRHTK104	11KV FDR A-BLOCK KARAMPURA	640KRP-KAM023A	1600	RESIDENTIAL	Functional	100%	741	0.84	8.65	0.02	0.20%
33 kv S.B.MILL GRID	WSBML105	11KV FDR COMMUNITY CENTER KARAMPURA	640KRP-KAM021A	990	RESIDENTIAL	Functional	100%	928	0.80			
33 kv S.B.MILL GRID	WSBML105	11KV FDR COMMUNITY CENTER KARAMPURA	640KRP-KAM021A	990	RESIDENTIAL	Functional	100%	512	0.68			
33 kv S.B.MILL GRID	WSBML105	11KV FDR COMMUNITY CENTER KARAMPURA	640KRP-KAM020A	990	RESIDENTIAL	Functional	100%	706	0.67			
33 kv NDPL ROHTAK ROAD	NRHTK104	11KV FDR A-BLOCK KARAMPURA	640KRP-KAM016A	990	RESIDENTIAL	Functional	100%	765	0.65			
33 kv NDPL ROHTAK ROAD	NRHTK104	11KV FDR A-BLOCK KARAMPURA	640KRP-KAM017A	990	RESIDENTIAL	Functional	100%	710	0.56			
33 kv S.B.MILL GRID	WSBML105	11KV FDR COMMUNITY CENTER KARAMPURA	640KRP-KAM014A	990	RESIDENTIAL	Functional	100%	438	0.49			
33 kv NDPL ROHTAK ROAD	NRHTK104	11KV FDR A-BLOCK KARAMPURA	640KRP-KAM022A	990	RESIDENTIAL	Functional	100%	264	0.48			
33 kv S.B.MILL GRID	WSBML105	11KV FDR COMMUNITY CENTER KARAMPURA	640KRP-KAM018A	630	RESIDENTIAL	Functional	100%	857	0.45			
33 kv NDPL ROHTAK ROAD	NRHTK104	11KV FDR A-BLOCK KARAMPURA	640KRP-KAM045A	630	RESIDENTIAL	Functional	100%	515	0.39			
33 kv S.B.MILL GRID	WSBML103	11KV FDR CHARKHI GATE	640KRP-KAM008A	630	RESIDENTIAL	Functional	100%	556	0.38			
33 kv NDPL ROHTAK ROAD	NRHTK104	11KV FDR A-BLOCK KARAMPURA	640KRP-KAM017A	630	RESIDENTIAL	Functional	100%	258	0.37			
33 kv NDPL ROHTAK ROAD	NRHTK104	11KV FDR A-BLOCK KARAMPURA	640KRP-KAM022A	630	RESIDENTIAL	Functional	100%	479	0.36			
33 kv NDPL ROHTAK ROAD	NRHTK104	11KV FDR A-BLOCK KARAMPURA	640KRP-KAM019A	990	RESIDENTIAL	Functional	100%	149	0.35			
33 kv S.B.MILL GRID	WSBML105	11KV FDR COMMUNITY CENTER KARAMPURA	640KRP-KAM019A	990	RESIDENTIAL	Functional	100%	312	0.32			
33 kv S.B.MILL GRID	WSBML105	11KV FDR COMMUNITY CENTER KARAMPURA	640KRP-KAM014A	990	RESIDENTIAL	Functional	100%	348	0.26			
33 kv NDPL ROHTAK ROAD	NRHTK104	11KV FDR A-BLOCK KARAMPURA	640KRP-KAM022A	400	RESIDENTIAL	Functional	100%	350	0.25			
33 kv NDPL ROHTAK ROAD	NRHTK104	11KV FDR A-BLOCK KARAMPURA	640KRP-KAM013A	400	RESIDENTIAL	Functional	100%	226	0.25			
33 kv S.B.MILL GRID	WSBML103	11KV FDR CHARKHI GATE	640KRP-KAM008A	400	RESIDENTIAL	Functional	100%	333	0.12			
33 kv NDPL ROHTAK ROAD	NRHTK102	11KV FDR TRANSPORT CENTER (PJB BAGH)	640KRP-KAM056A	400	MIXED	Functional	100%	0	0.00			
33 kv MADIPUR GRID	WMDPR103	11KV FDR B-G-3 PRAGATI APPT. PASCHIM VIHAR	640R41-PBG022A	990	RESIDENTIAL	Functional	100%	875	0.80	6.06	0.18	2.88%
33 kv MADIPUR GRID	WMDPR103	11KV FDR B-G-3 PRAGATI APPT. PASCHIM VIHAR	640R41-PBG021A	990	RESIDENTIAL	Functional	100%	673	0.70			

33 kv A - 4 PASCHIM VIHAR GRID	WA4PV112	11kv FDR PRAGATI APPARTMENT S/STN NO-2	640R41-PBG020A-	1600	RESIDENTIAL		Functional	100%	1065	0.67			
33 kv MADIPUR GRID	WM DPR113	11kv FDR SLUM TREATMENT	640R41-PBG024A-	630	RESIDENTIAL		Functional	100%	497	0.51			
33 kv MADIPUR GRID	WM DPR103	11kv FDR B-G-3 PRAGATI APPT. PASCHIM VIHAR	640R41-PBG022A-	990	RESIDENTIAL		Functional	100%	847	0.44			
33 kv MADIPUR GRID	WM DPR113	11kv FDR SLUM TREATMENT	640R41-PBG023A-	630	RESIDENTIAL		Functional	100%	203	0.42			
33 kv MADIPUR GRID	WM DPR113	11kv FDR SLUM TREATMENT	640R41-PBG023A-	990	RESIDENTIAL		Functional	100%	466	0.38			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV112	11kv FDR PRAGATI APPARTMENT S/STN NO-2	TP-PBG096A-1	400	RESIDENTIAL		Functional	100%	341	0.37			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV110	11kv FDR 1212 JANTA QTRS. (C- BLK MADIPUR)	640R41-PBG110A-	400	MIXED		Functional	100%	0	0.32			
33 kv MADIPUR GRID	WM DPR113	11kv FDR SLUM TREATMENT	640R41-PBG060A-	400	MIXED		Functional	100%	0	0.31			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV112	11kv FDR PRAGATI APPARTMENT S/STN NO-2	640R41-PBG018A-	400	RESIDENTIAL		Functional	100%	196	0.21			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV112	11kv FDR PRAGATI APPARTMENT S/STN NO-2	640R41-PBG018A-	400	RESIDENTIAL		Functional	100%	359	0.21			
33 kv MADIPUR GRID	WM DPR113	11kv FDR SLUM TREATMENT	640R41-PBG024A-	400	RESIDENTIAL		Functional	100%	413	0.20			
33 kv MADIPUR GRID	WM DPR103	11kv FDR B-G-3 PRAGATI APPT. PASCHIM VIHAR	640R41-PBG021A-	630	RESIDENTIAL		Functional	100%	655	0.17			
33 kv MADIPUR GRID	WM DPR103	11kv FDR B-G-3 PRAGATI APPT. PASCHIM VIHAR	640R41-PBG107A-	400	MIXED		Functional	100%	0	0.16			
33 kv MADIPUR GRID	WM DPR103	11kv FDR B-G-3 PRAGATI APPT. PASCHIM VIHAR	640R41-PBG019A-	630	RESIDENTIAL		Functional	100%	95	0.13			
33 kv MADIPUR GRID	WM DPR113	11kv FDR SLUM TREATMENT	640R41-PBG023A-	630	RESIDENTIAL		Functional	100%	633	0.13			
33 kv MADIPUR GRID	WM DPR103	11kv FDR B-G-3 PRAGATI APPT. PASCHIM VIHAR	640R41-PBG019A-	630	RESIDENTIAL		Functional	100%	101	0.07			
33 kv MADIPUR GRID	WM DPR113	11kv FDR SLUM TREATMENT	640R41-PBG060A-	400	RESIDENTIAL		Functional	100%	69	0.04			
33 kv MADIPUR GRID	WM DPR109	11kv FDR PJB C. CENTER NO.-1	640R41-PBG004A-	990	RESIDENTIAL		Functional	100%	194	0.78	7.06	0.22	3.08%
33 kv MADIPUR GRID	WM DPR113	11kv FDR SLUM TREATMENT	640R41-PBG006A-	990	COMMERCIAL		Functional	100%	317	0.71			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV114	11kv FDR SWAYAM SIDHA	640R41-PBG005A-	990	RESIDENTIAL		Functional	100%	410	0.66			
33 kv MADIPUR GRID	WM DPR109	11kv FDR PJB C. CENTER NO.-1	640R41-PBG054A-	990	COMMERCIAL		Functional	100%	467	0.66			
33 kv MADIPUR GRID	WM DPR111	11kv FDR ADASRSH BHAWAN	640R41-PBG055A-	990	COMMERCIAL		Functional	100%	79	0.65			
33 kv MADIPUR GRID	WM DPR111	11kv FDR ADASRSH BHAWAN	640R41-PBG055A-	990	COMMERCIAL		Functional	100%	190	0.63			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV114	11kv FDR SWAYAM SIDHA	640R41-PBG003A-	630	RESIDENTIAL		Functional	100%	182	0.58			
33 kv MADIPUR GRID	WM DPR102	11kv FDR PAL MOHAN APART.	640R41-PBG012A-	630	COMMERCIAL		Functional	100%	133	0.42			
33 kv MADIPUR GRID	WM DPR109	11kv FDR PJB C. CENTER NO.-1	640R41-PBG097A-	630	RESIDENTIAL		Functional	100%	46	0.42			
33 kv MADIPUR GRID	WM DPR111	11kv FDR ADASRSH BHAWAN	640R41-PBG056A-	630	COMMERCIAL		Functional	100%	171	0.41			
33 kv MADIPUR GRID	WM DPR113	11kv FDR SLUM TREATMENT	640R41-PBG006A-	990	RESIDENTIAL		Functional	100%	162	0.41			
33 kv MADIPUR GRID	WM DPR102	11kv FDR PAL MOHAN APART.	640R41-PBG011A-	990	COMMERCIAL		Functional	100%	225	0.35			
33 kv MADIPUR GRID	WM DPR109	11kv FDR PJB C. CENTER NO.-1	TG-PBG054A-2	990	RESIDENTIAL		Functional	100%	0	0.35			
33 kv MADIPUR GRID	WM DPR111	11kv FDR ADASRSH BHAWAN	TG-PBG056A-2	630	RESIDENTIAL		Functional	100%	0	0.20			
33 kv MADIPUR GRID	WM DPR102	11kv FDR PAL MOHAN APART.	640R41-PBG012A-	400	COMMERCIAL		Functional	100%	75	0.05			
33 kv NDPL ROHTAK ROAD	NRHTK106	11kv FDR PUNJABI BAGH-1	TG-PBG043A-2	990	RESIDENTIAL		Functional	100%	0	0.63	4.65	0.20	4.17%
33 kv NDPL ROHTAK ROAD	NRHTK106	11kv FDR PUNJABI BAGH-1	640R41-PBG040A-	990	RESIDENTIAL		Functional	100%	171	0.62			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV120	11kv FDR POLICE STATION & QUATERS(PJB)	640R41-PBG042A-	990	RESIDENTIAL		Functional	100%	407	0.61			
33 kv MADIPUR GRID	WM DPR114	11kv FDR SHIV MANDIR	640R41-PBG046A-	990	RESIDENTIAL		Functional	100%	196	0.61			
33 kv NDPL ROHTAK ROAD	NRHTK106	11kv FDR PUNJABI BAGH-1	640R41-PBG043A-	990	RESIDENTIAL		Functional	100%	815	0.54			
33 kv MADIPUR GRID	WM DPR114	11kv FDR SHIV MANDIR	640R41-PBG045A-	990	RESIDENTIAL		Functional	100%	95	0.47			
33 kv MADIPUR GRID	WM DPR114	11kv FDR SHIV MANDIR	640R41-PBG045A-	990	RESIDENTIAL		Functional	100%	42	0.45			
33 kv MADIPUR GRID	WM DPR101	11kv FDR BOOSTER PUMP PUNJABI BAGH	640R41-PBG044A-	630	RESIDENTIAL		Functional	100%	78	0.33			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV120	11kv FDR POLICE STATION & QUATERS(PJB)	640R41-PBG041A-	630	RESIDENTIAL		Functional	100%	108	0.20			
33 kv NDPL ROHTAK ROAD	NRHTK106	11kv FDR PUNJABI BAGH-1	640R41-PBG044A-	990	RESIDENTIAL		Functional	100%	174	0.18			
33 kv MADIPUR GRID	WM DPR114	11kv FDR SHIV MANDIR	640R41-PBG045A-	630	RESIDENTIAL		Functional	100%	64	0.11			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV120	11kv FDR POLICE STATION & QUATERS(PJB)	640R41-PBG069A-	630	RESIDENTIAL		Functional	100%	20	0.09			
33 kv NDPL ROHTAK ROAD	NRHTK106	11kv FDR PUNJABI BAGH-1	640R41-PBG086A-	100	RESIDENTIAL		Functional	100%	13	0.01			

33 KV NDPL ROHTAK ROAD	NRHTK101	11KV FDR A F O (DIST EAST PUNJABI BAGH)	640KRP-KAM026A	990	RESIDENTIAL	Functional	100%	351	0.71	6.05	0.12	1.97%			
33 KV NDPL ROHTAK ROAD	NRHTK105	11KV FDR PUNJABI BAGH NO-2	640KRP-KAM025A	990	COMMERCIAL	Functional	100%	430	0.64						
33 KV NDPL ROHTAK ROAD	NRHTK101	11KV FDR A F O (DIST EAST PUNJABI BAGH)	640KRP-KAM012A	990	RESIDENTIAL	Functional	100%	175	0.55						
33 KV NDPL ROHTAK ROAD	NRHTK105	11KV FDR PUNJABI BAGH NO-2	640KRP-KAM024A	630	RESIDENTIAL	Functional	100%	268	0.54						
33 KV NDPL ROHTAK ROAD	NRHTK105	11KV FDR PUNJABI BAGH NO-2	640KRP-KAM026A	990	RESIDENTIAL	Functional	100%	145	0.54						
33 KV NDPL ROHTAK ROAD	NRHTK105	11KV FDR PUNJABI BAGH NO-2	640KRP-KAM031A	990	COMMERCIAL	Functional	100%	188	0.44						
33 KV NDPL ROHTAK ROAD	NRHTK105	11KV FDR PUNJABI BAGH NO-2	640KRP-KAM027A	990	RESIDENTIAL	Functional	100%	200	0.42						
33 KV NDPL ROHTAK ROAD	NRHTK101	11KV FDR A F O (DIST EAST PUNJABI BAGH)	640KRP-KAM011A	630	RESIDENTIAL	Functional	100%	375	0.41						
33 KV NDPL ROHTAK ROAD	NRHTK105	11KV FDR PUNJABI BAGH NO-2	640KRP-KAM027A	400	RESIDENTIAL	Functional	100%	51	0.39						
33 KV NDPL ROHTAK ROAD	NRHTK105	11KV FDR PUNJABI BAGH NO-2	640KRP-KAM029A	630	COMMERCIAL	Functional	100%	144	0.38						
33 KV NDPL ROHTAK ROAD	NRHTK105	11KV FDR PUNJABI BAGH NO-2	640KRP-KAM029A	630	COMMERCIAL	Functional	100%	287	0.35						
33 kv S.B.MILL GRID	WSBML106	11KV FDR J.J CLUSTER SHIVA NAND SCHOOL	640KRP-KAM048A	630	RESIDENTIAL	Functional	100%	230	0.31						
33 KV NDPL ROHTAK ROAD	NRHTK105	11KV FDR PUNJABI BAGH NO-2	640KRP-KAM024A	630	RESIDENTIAL	Functional	100%	182	0.28						
33 KV NDPL ROHTAK ROAD	NRHTK104	11KV FDR A-BLOCK KARAMPURA	640KRP-KAM057A	400	RESIDENTIAL	Functional	100%	0	0.12						
33 KV NDPL ROHTAK ROAD	NRHTK105	11KV FDR PUNJABI BAGH NO-2	640KRP-KAM050A	400	RESIDENTIAL	Functional	100%	16	0.07						
33 kv PASCHIM PURI GRID	WPSCP337	11KV FDR RBI COLONY WATER TANK	640BPV-PAS011A	990	RESIDENTIAL	Functional	100%	609	0.87	5.94	0.08	1.35%			
33 kv PASCHIM PURI GRID	WPSCP111	11KV FDR G BLOCK PUSHKAR VIHAR	640BPV-PAS005A	990	RESIDENTIAL	Functional	100%	295	0.63						
66 kv PASCHIM VIHAR GRID	WPSCV110	11KV FDR STATE BANK NAGAR	640BPV-PAS006A	630	RESIDENTIAL	Functional	100%	411	0.57						
33 kv PASCHIM PURI GRID	WPSCP111	11KV FDR G BLOCK PUSHKAR VIHAR	640BPV-PAS007A	990	RESIDENTIAL	Functional	100%	644	0.52						
33 kv PASCHIM PURI GRID	WPSCP111	11KV FDR G BLOCK PUSHKAR VIHAR	640BPV-PAS008A	630	RESIDENTIAL	Functional	100%	555	0.48						
66 kv PASCHIM VIHAR GRID	WPSCV110	11KV FDR STATE BANK NAGAR	640BPV-PAS006A	990	RESIDENTIAL	Functional	100%	279	0.46						
66 kv PASCHIM VIHAR GRID	WPSCV110	11KV FDR STATE BANK NAGAR	640BPV-PAS010A	630	RESIDENTIAL	Functional	100%	101	0.46						
33 kv PASCHIM PURI GRID	WPSCP337	11KV FDR RBI COLONY WATER TANK	640BPV-PAS011A	990	RESIDENTIAL	Functional	100%	275	0.45						
33 kv PASCHIM PURI GRID	WPSCP111	11KV FDR G BLOCK PUSHKAR VIHAR	640BPV-PAS007A	630	RESIDENTIAL	Functional	100%	457	0.37						
33 kv PASCHIM PURI GRID	WPSCP337	11KV FDR RBI COLONY WATER TANK	640BPV-PAS011A	630	RESIDENTIAL	Functional	100%	201	0.30						
33 kv PASCHIM PURI GRID	WPSCP111	11KV FDR G BLOCK PUSHKAR VIHAR	640BPV-PAS004A	630	RESIDENTIAL	Functional	100%	163	0.19						
66 kv PASCHIM VIHAR GRID	WPSCV110	11KV FDR STATE BANK NAGAR	640BPV-PAS090A	400	RESIDENTIAL	Functional	100%	52	0.18						
66 kv PASCHIM VIHAR GRID	WPSCV110	11KV FDR STATE BANK NAGAR	640BPV-PAS009A	630	RESIDENTIAL	Functional	100%	66	0.12						
66 kv PASCHIM VIHAR GRID	WPSCV110	11KV FDR STATE BANK NAGAR	640BPV-PAS010A	630	RESIDENTIAL	Functional	100%	103	0.12						
66 kv PASCHIM VIHAR GRID	WPSCV110	11KV FDR STATE BANK NAGAR	640BPV-PAS092A	400	RESIDENTIAL	Functional	100%	167	0.07						
66 kv PASCHIM VIHAR GRID	WPSCV110	11KV FDR STATE BANK NAGAR	640BPV-PAS009A	630	RESIDENTIAL	Functional	100%	176	0.07						
66 kv PASCHIM VIHAR GRID	WPSCV110	11KV FDR STATE BANK NAGAR	640BPV-PAS092A	400	RESIDENTIAL	Functional	100%	39	0.07						
33 kv PASCHIM PURI GRID	WPSCP111	11KV FDR G BLOCK PUSHKAR VIHAR	640BPV-PAS003A	400	RESIDENTIAL	Functional	100%	125	0.06						
33 kv PASCHIM PURI GRID	WPSCP111	11KV FDR G BLOCK PUSHKAR VIHAR	640BPV-PAS003A	400	RESIDENTIAL	Functional	100%	105	0.05						
33 kv MADIPUR GRID	WMDPR101	11KV FDR BOOSTER PUMP PUNJABI BAGH	640R41-PBG064A	990	RESIDENTIAL	Functional	100%	202	0.77				3.35	0.11	3.10%
33 kv MADIPUR GRID	WMDPR109	11KV FDR PJB C. CENTER NO.-1	640R41-PBG036A	990	RESIDENTIAL	Functional	100%	261	0.57						
33 kv MADIPUR GRID	WMDPR101	11KV FDR BOOSTER PUMP PUNJABI BAGH	640R41-PBG039A	630	RESIDENTIAL	Functional	100%	247	0.50						
33 kv MADIPUR GRID	WMDPR109	11KV FDR PJB C. CENTER NO.-1	640R41-PBG036A	990	RESIDENTIAL	Functional	100%	175	0.43						
33 kv MADIPUR GRID	WMDPR101	11KV FDR BOOSTER PUMP PUNJABI BAGH	640R41-PBG039A	630	RESIDENTIAL	Functional	100%	74	0.31						
33 kv MADIPUR GRID	WMDPR101	11KV FDR BOOSTER PUMP PUNJABI BAGH	640R41-PBG062A	630	RESIDENTIAL	Functional	100%	143	0.24						
33 KV NDPL ROHTAK ROAD	NRHTK106	11KV FDR PUNJABI BAGH-1	640R41-PBG106A	630	RESIDENTIAL	Functional	100%	0	0.21						
33 kv MADIPUR GRID	WMDPR101	11KV FDR BOOSTER PUMP PUNJABI BAGH	640R41-PBG037A	400	RESIDENTIAL	Functional	100%	74	0.17						
33 kv MADIPUR GRID	WMDPR113	11KV FDR SLUM TREATMENT	640R41-PBG112A	630	MIXED	Functional	100%	0	0.13						
33 KV NDPL ROHTAK ROAD	NRHTK106	11KV FDR PUNJABI BAGH-1	640R41-PBG105A	630	RESIDENTIAL	Functional	100%	0	0.13						
33 kv PASCHIM PURI GRID	WPSCP103	11KV FDR SHAKTI SOCIETY S/SNO-4	640BPV-PAS079A	630	RESIDENTIAL	Functional	100%	59	0.35	2.06	0.17	7.79%			
33 kv PASCHIM PURI GRID	WPSCP337	11KV FDR RBI COLONY WATER TANK	640BPV-PAS002A	630	RESIDENTIAL	Functional	100%	330	0.34						
33 kv PASCHIM PURI GRID	WPSCP103	11KV FDR SHAKTI SOCIETY S/SNO-4	640BPV-PAS080A	630	RESIDENTIAL	Functional	100%	47	0.29						
33 kv PASCHIM PURI GRID	WPSCP337	11KV FDR RBI COLONY WATER TANK	640BPV-PAS002A	630	RESIDENTIAL	Functional	100%	174	0.28						
33 kv PASCHIM PURI GRID	WPSCP103	11KV FDR SHAKTI SOCIETY S/SNO-4	640BPV-PAS082A	630	RESIDENTIAL	Functional	100%	93	0.23						
33 kv PASCHIM PURI GRID	WPSCP103	11KV FDR SHAKTI SOCIETY S/SNO-4	640BPV-PAS082A	630	RESIDENTIAL	Functional	100%	9	0.22						

33 kv PASCHIM PURI GRID	WPSCP103	11kv FDR SHAKTI SOCIETY S/SNO-4	640BPV-PAS080A-	630	RESIDENTIAL	Functional	100%	294	0.20			
33 kv PASCHIM PURI GRID	WPSCP103	11kv FDR SHAKTI SOCIETY S/SNO-4	640BPV-PAS081A-	400	RESIDENTIAL	Functional	100%	33	0.20			
33 kv PASCHIM PURI GRID	WPSCP103	11kv FDR SHAKTI SOCIETY S/SNO-4	640BPV-PAS081A-	400	RESIDENTIAL	Functional	100%	124	0.10			
33 kv PASCHIM PURI GRID	WPSCP337	11kv FDR RBI COLONY WATER TANK	640BPV-PAS091A-	100	RESIDENTIAL	Functional	100%	2	0.02			
33 kv PASCHIM PURI GRID	WPSCP114	11kv FDR A-3 DISPENSARY	640BPV-PAS094A-	990	RESIDENTIAL	Functional	100%	327	0.47	2.94	0.01	0.44%
33 kv PASCHIM PURI GRID	WPSCP114	11kv FDR A-3 DISPENSARY	640BPV-PAS046A-	990	RESIDENTIAL	Functional	100%	292	0.46			
33 kv PASCHIM PURI GRID	WPSCP114	11kv FDR A-3 DISPENSARY	640BPV-PAS046A-	990	RESIDENTIAL	Functional	100%	248	0.44			
33 kv PASCHIM PURI GRID	WPSCP114	11kv FDR A-3 DISPENSARY	640BPV-PAS054A-	990	RESIDENTIAL	Functional	100%	163	0.40			
33 kv PASCHIM PURI GRID	WPSCP122	11kv FDR A-2 COMMUNITY CENTER	640BPV-PAS047A-	630	RESIDENTIAL	Functional	100%	382	0.37			
33 kv PASCHIM PURI GRID	WPSCP114	11kv FDR A-3 DISPENSARY	640BPV-PAS049A-	630	RESIDENTIAL	Functional	100%	38	0.19			
33 kv PASCHIM PURI GRID	WPSCP114	11kv FDR A-3 DISPENSARY	640BPV-PAS076A-	990	RESIDENTIAL	Functional	100%	109	0.17			
33 kv PASCHIM PURI GRID	WPSCP122	11kv FDR A-2 COMMUNITY CENTER	640BPV-PAS051A-	630	RESIDENTIAL	Functional	100%	49	0.12			
33 kv PASCHIM PURI GRID	WPSCP122	11kv FDR A-2 COMMUNITY CENTER	640BPV-PAS050A-	400	RESIDENTIAL	Functional	100%	58	0.11			
33 kv PASCHIM PURI GRID	WPSCP122	11kv FDR A-2 COMMUNITY CENTER	640BPV-PAS050A-	630	RESIDENTIAL	Functional	100%	82	0.09			
33 kv PASCHIM PURI GRID	WPSCP115	11kv FDR A-6 PASCHIM VIHAR	640BPV-PAS049A-	400	RESIDENTIAL	Functional	100%	29	0.07			
33 kv PASCHIM PURI GRID	WPSCP122	11kv FDR A-2 COMMUNITY CENTER	640BPV-PAS051A-	630	RESIDENTIAL	Functional	100%	85	0.06			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV105	11kv FDR MULTAN NAGAR (C-BLOCK)	640BPV-PAS061A-	630	RESIDENTIAL	Functional	100%	238	0.70	2.84	0.15	5.10%
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV105	11kv FDR MULTAN NAGAR (C-BLOCK)	640BPV-PAS062A-	990	RESIDENTIAL	Functional	100%	492	0.55			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV105	11kv FDR MULTAN NAGAR (C-BLOCK)	640BPV-PAS060A-	990	RESIDENTIAL	Functional	100%	205	0.53			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV105	11kv FDR MULTAN NAGAR (C-BLOCK)	640BPV-PAS059A-	990	RESIDENTIAL	Functional	100%	241	0.50			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV105	11kv FDR MULTAN NAGAR (C-BLOCK)	640BPV-PAS060A-	990	RESIDENTIAL	Functional	100%	494	0.39			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV105	11kv FDR MULTAN NAGAR (C-BLOCK)	640BPV-PAS103A-	630	RESIDENTIAL	Functional	100%	230	0.33			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV104	11kv FDR A-4 CASH OFFICE	640BPV-PAS065A-	990	RESIDENTIAL	Functional	100%	252	0.62	2.76	0.09	3.03%
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV104	11kv FDR A-4 CASH OFFICE	640BPV-PAS064A-	990	RESIDENTIAL	Functional	100%	584	0.62			
33 kv PASCHIM PURI GRID	WPSCP115	11kv FDR A-6 PASCHIM VIHAR	640BPV-PAS048A-	630	RESIDENTIAL	Functional	100%	787	0.45			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV104	11kv FDR A-4 CASH OFFICE	640BPV-PAS065A-	630	RESIDENTIAL	Functional	100%	301	0.38			
33 kv PASCHIM PURI GRID	WPSCP115	11kv FDR A-6 PASCHIM VIHAR	640BPV-PAS048A-	630	RESIDENTIAL	Functional	100%	76	0.24			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV104	11kv FDR A-4 CASH OFFICE	640BPV-PAS067A-	990	RESIDENTIAL	Functional	100%	93	0.18			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV104	11kv FDR A-4 CASH OFFICE	640BPV-PAS066A-	990	RESIDENTIAL	Functional	100%	93	0.15			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV104	11kv FDR A-4 CASH OFFICE	640BPV-PAS067A-	630	RESIDENTIAL	Functional	100%	391	0.13			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV104	11kv FDR A-4 CASH OFFICE	640BPV-PAS066A-	630	RESIDENTIAL	Functional	100%	58	0.08			
33 kv S.B.MILL GRID	WSBML104	11kv FDR TULSI RAM DHARAMSALA	640KRP-KAM009A-	990	RESIDENTIAL	Functional	100%	30	0.44	1.23	0.07	5.17%
33 kv S.B.MILL GRID	WSBML104	11kv FDR TULSI RAM DHARAMSALA	640KRP-KAM010A-	400	RESIDENTIAL	Functional	100%	125	0.28			
33 kv S.B.MILL GRID	WSBML104	11kv FDR TULSI RAM DHARAMSALA	640KRP-KAM007A-	630	RESIDENTIAL	Functional	100%	11	0.25			
33 kv S.B.MILL GRID	WSBML104	11kv FDR TULSI RAM DHARAMSALA	640KRP-KAM015A-	400	RESIDENTIAL	Functional	100%	68	0.24			
33 kv S.B.MILL GRID	WSBML104	11kv FDR TULSI RAM DHARAMSALA	640KRP-KAM043A-	400	RESIDENTIAL	Functional	100%	9	0.08			
33 kv NDPL ROHTAK ROAD	NRHTK102	11kv FDR TRANSPORT CENTER (PJB BAGH)	640KRP-KAM028A-	990	COMMERCIAL	Functional	100%	166	0.52	1.56	0.07	4.12%
33 kv S.B.MILL GRID	WSBML106	11kv FDR J J CLUSTER SHIVA NAND SCHOOL	640KRP-KAM003A-	630	COMMERCIAL	Functional	100%	477	0.40			
33 kv NDPL ROHTAK ROAD	NRHTK103	11kv FDR BHAGWAN DAS NAGAR	640KRP-KAM044A-	400	COMMERCIAL	Functional	100%	730	0.33			
33 kv NDPL ROHTAK ROAD	NRHTK102	11kv FDR TRANSPORT CENTER (PJB BAGH)	640KRP-KAM028A-	630	COMMERCIAL	Functional	100%	216	0.25			
33 kv NDPL ROHTAK ROAD	NRHTK102	11kv FDR TRANSPORT CENTER (PJB BAGH)	640KRP-KAM042A-	400	COMMERCIAL	Functional	100%	61	0.14			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV113	11kv FDR 208 SFS QTRS.	640R41-PBG026A-	990	RESIDENTIAL	Functional	100%	529	0.73	5.50	0.07	1.32%

33 kv A - 4 PASCHIM VIHAR GRID	WA4PV113	11kv FDR 208 SFS QTRS.	640R41-PBG059A-	990	RESIDENTIAL	Functional	100%	487	0.72			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV113	11kv FDR 208 SFS QTRS.	640R41-PBG026A-	990	RESIDENTIAL	Functional	100%	1144	0.68			
33 kv MADIPUR GRID	WMDPR107	11kv FDR 240 MIG FLATS (208 SFS) MADIPUR	640R41-PBG028A-	990	RESIDENTIAL	Functional	100%	450	0.61			
33 kv MADIPUR GRID	WMDPR107	11kv FDR 240 MIG FLATS (208 SFS) MADIPUR	640R41-PBG076A-	990	RESIDENTIAL	Functional	100%	210	0.47			
33 kv MADIPUR GRID	WMDPR114	11kv FDR SHIV MANDIR	640R41-PBG010A-	630	RESIDENTIAL	Functional	100%	0	0.43			
33 kv MADIPUR GRID	WMDPR107	11kv FDR 240 MIG FLATS (208 SFS) MADIPUR	640R41-PBG028A-	630	RESIDENTIAL	Functional	100%	286	0.42			
33 kv MADIPUR GRID	WMDPR114	11kv FDR SHIV MANDIR	640R41-PBG010A-	990	RESIDENTIAL	Functional	100%	436	0.41			
33 kv MADIPUR GRID	WMDPR107	11kv FDR 240 MIG FLATS (208 SFS) MADIPUR	640R41-PBG029A-	630	RESIDENTIAL	Functional	100%	701	0.34			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV113	11kv FDR 208 SFS QTRS.	640R41-PBG087A-	400	RESIDENTIAL	Functional	100%	197	0.29			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV113	11kv FDR 208 SFS QTRS.	640R41-PBG025A-	990	RESIDENTIAL	Functional	100%	196	0.20			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV113	11kv FDR 208 SFS QTRS.	640R41-PBG025A-	990	RESIDENTIAL	Functional	100%	24	0.11			
33 kv MADIPUR GRID	WMDPR107	11kv FDR 240 MIG FLATS (208 SFS) MADIPUR	640R41-PBG077A-	400	RESIDENTIAL	Functional	100%	89	0.08			
33 kv MADIPUR GRID	WMDPR107	11kv FDR 240 MIG FLATS (208 SFS) MADIPUR	640R41-PBG077A-	400	RESIDENTIAL	Functional	100%	59	0.07			
33 kv MADIPUR GRID	WMDPR106	11kv STR 100KVA STATION TRANSFORMER	PB-WTC010A-1	100	RESIDENTIAL	Functional	100%	1	0.01			
33 kv MADIPUR GRID	WMDPR112	11kv FDR 6 MILE STONE MADIPUR GATE	640R41-PBG080A-	400	RESIDENTIAL	Functional	100%	745	0.44	0.77	0.18	18.68%
33 kv MADIPUR GRID	WMDPR112	11kv FDR 6 MILE STONE MADIPUR GATE	TP-PBG075A-1	400	RESIDENTIAL	Functional	100%	488	0.22			
33 kv MADIPUR GRID	WMDPR112	11kv FDR 6 MILE STONE MADIPUR GATE	640R41-PBG081A-	400	RESIDENTIAL	Functional	100%	445	0.21			
33 kv MADIPUR GRID	WMDPR112	11kv FDR 6 MILE STONE MADIPUR GATE	640R41-PBG100A-	400	COMMERCIAL	Functional	100%	74	0.08			
33 kv MADIPUR GRID	WMDPR112	11kv FDR 6 MILE STONE MADIPUR GATE	TP-PBG072A-1	100	RESIDENTIAL	Functional	100%	14	0.00			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV110	11kv FDR 1212 JANTA QTRS. (C- BLK MADIPUR)	640R41-PBG016A-	990	RESIDENTIAL	Functional	100%	1069	0.56	1.67	0.18	9.75%
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV110	11kv FDR 1212 JANTA QTRS. (C- BLK MADIPUR)	640R41-PBG015A-	990	RESIDENTIAL	Functional	100%	540	0.54			
33 kv MADIPUR GRID	WMDPR103	11kv FDR B-G-3 PRAGATI APPT. PASCHIM VIHAR	640R41-PBG065A-	630	RESIDENTIAL	Functional	100%	76	0.44			
33 kv MADIPUR GRID	WMDPR108	11kv FDR 1212-JANTA FLATS	640R41-PBG015A-	1600	RESIDENTIAL	Functional	100%	1070	0.27			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV110	11kv FDR 1212 JANTA QTRS. (C- BLK MADIPUR)	640R41-PBG017A-	400	RESIDENTIAL	Functional	100%	199	0.03			
33 kv PASCHIM PURI GRID	WPSCP106	11kv FDR M.I.G MILANSAR APPARTMENT	640BPV-PAS055A-	990	RESIDENTIAL	Functional	100%	467	0.64	1.91	0.08	4.22%
33 kv PASCHIM PURI GRID	WPSCP106	11kv FDR M.I.G MILANSAR APPARTMENT	640BPV-PAS056A-	630	RESIDENTIAL	Functional	100%	269	0.41			
33 kv PASCHIM PURI GRID	WPSCP106	11kv FDR M.I.G MILANSAR APPARTMENT	640BPV-PAS025A-	630	RESIDENTIAL	Functional	100%	267	0.31			
33 kv PASCHIM PURI GRID	WPSCP106	11kv FDR M.I.G MILANSAR APPARTMENT	640BPV-PAS025A-	630	RESIDENTIAL	Functional	100%	343	0.27			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV106	11kv FDR COTTEGE ENCLAVE	640BPV-PAS057A-	990	RESIDENTIAL	Functional	100%	542	0.24			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV106	11kv FDR COTTAGE ENCLAVE	640BPV-PAS057B-	990	RESIDENTIAL	Functional	100%	0	0.13			
33 kv MADIPUR GRID	WMDPR108	11kv FDR 1212-JANTA FLATS	640R41-PBG033A-	1600	RESIDENTIAL	Functional	100%	1382	0.86	4.38	0.78	15.05%
33 kv MADIPUR GRID	WMDPR108	11kv FDR 1212-JANTA FLATS	640R41-PBG063A-	990	RESIDENTIAL	Functional	100%	783	0.82			
33 kv MADIPUR GRID	WMDPR108	11kv FDR 1212-JANTA FLATS	640R41-PBG034A-	630	RESIDENTIAL	Functional	100%	406	0.78			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV121	11kv FDR C-BLK MADIPUR	640R41-PBG032A-	990	RESIDENTIAL	Functional	100%	204	0.77			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV121	11kv FDR C-BLK MADIPUR	640R41-PBG032A-	990	RESIDENTIAL	Functional	100%	1624	0.71			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV110	11kv FDR 1212 JANTA QTRS. (C- BLK MADIPUR)	640R41-PBG035A-	990	RESIDENTIAL	Functional	100%	912	0.55			
33 kv A - 4 PASCHIM VIHAR GRID	WA4PV110	11kv FDR 1212 JANTA QTRS. (C- BLK MADIPUR)	640R41-PBG035A-	990	RESIDENTIAL	Functional	100%	689	0.41			
33 kv MADIPUR GRID	WMDPR108	11kv FDR 1212-JANTA FLATS	640R41-PBG034A-	400	RESIDENTIAL	Functional	100%	539	0.25			
33 kv CHOUKHANDI GRID	WCHAK105	11kv FDR RZ-BLOCK, VISHNU GDN	TK-TGN162A-2	990	RESIDENTIAL	Functional	100%	802	1.16	11.48	3.36	22.62%
33 kv CHOUKHANDI GRID	WCHAK110	11kv FDR EXT.5C VISHNU GARDEN	TK-TGN164A-2	990	INDUSTRIAL	Functional	100%	849	0.99			
33 kv CHOUKHANDI GRID	WCHAK124	11kv FDR E BLOCK KHYALA	TI-TGN171A-2	1500	INDUSTRIAL	Functional	100%	671	0.94			

33 kv CHOUKHANDI GRID	WCHAK105	11kv FDR RZ-BLOCK, VISHNU GDN	TK-TGN162A-3	990	RESIDENTIAL		Functional	100%	311	0.92			
33 kv CHOUKHANDI GRID	WCHAK110	11kv FDR EXT.5C VISHNU GARDEN	TG-TGN180A-2	990	INDUSTRIAL		Functional	100%	1103	0.87			
33 kv CHOUKHANDI GRID	WCHAK110	11kv FDR EXT.5C VISHNU GARDEN	TG-TGN180A-1	990	INDUSTRIAL		Functional	100%	257	0.85			
33 kv CHOUKHANDI GRID	WCHAK124	11kv FDR E BLOCK KHYALA	TI-TGN171A-3	990	RESIDENTIAL		Functional	100%	894	0.83			
33 kv CHOUKHANDI GRID	WCHAK124	11kv FDR E BLOCK KHYALA	TI-TGN171A-1	1500	INDUSTRIAL		Functional	100%	259	0.83			
33 kv CHOUKHANDI GRID	WCHAK120	11kv FDR RAVI NAGAR GURUDWARA	TG-TGN184A-2	990	RESIDENTIAL		Functional	100%	532	0.79			
33 kv CHOUKHANDI GRID	WCHAK119	11kv FDR C&D BLK VISHNU GARDEN	TG-TGN170A-1	990	INDUSTRIAL		Functional	100%	528	0.77			
33 kv CHOUKHANDI GRID	WCHAK110	11kv FDR EXT.5C VISHNU GARDEN	TK-TGN164A-1	990	INDUSTRIAL		Functional	100%	1384	0.73			
33 kv CHOUKHANDI GRID	WCHAK109	11kv FDR B-1/283 VISHNU GDN (PHADIYA WALA)	TK-TGN179A-1	990	INDUSTRIAL		Functional	100%	1024	0.73			
33 kv CHOUKHANDI GRID	WCHAK119	11kv FDR C&D BLK VISHNU GARDEN	TK-TGN163A-2	990	INDUSTRIAL		Functional	100%	1046	0.71			
33 kv CHOUKHANDI GRID	WCHAK120	11kv FDR RAVI NAGAR GURUDWARA	TI-TGN166A-2	990	RESIDENTIAL		Functional	100%	536	0.70			
33 kv CHOUKHANDI GRID	WCHAK120	11kv FDR RAVI NAGAR GURUDWARA	TG-TGN184A-1	990	INDUSTRIAL		Functional	100%	268	0.67			
33 kv CHOUKHANDI GRID	WCHAK119	11kv FDR C&D BLK VISHNU GARDEN	TK-TGN163A-1	990	INDUSTRIAL		Functional	100%	1259	0.60			
33 kv CHOUKHANDI GRID	WCHAK105	11kv FDR RZ-BLOCK, VISHNU GDN	TK-TGN162A-1	990	RESIDENTIAL		Functional	100%	327	0.50			
33 kv CHOUKHANDI GRID	WCHAK119	11kv FDR C&D BLK VISHNU GARDEN	TK-TGN163A-3	630	RESIDENTIAL		Functional	100%	0	0.47			
33 kv CHOUKHANDI GRID	WCHAK120	11kv FDR RAVI NAGAR GURUDWARA	TI-TGN166A-1	990	INDUSTRIAL		Functional	100%	181	0.40			
33 kv CHOUKHANDI GRID	WCHAK110	11kv FDR EXT.5C VISHNU GARDEN	TP-TGN165A-1	400	INDUSTRIAL		Functional	100%	409	0.39			
33 kv PASCHIM PURI GRID	WPSCP105	11kv FDR NURSING GARDEN	TI-TGN152A-1	1600	RESIDENTIAL		Functional	100%	393	1.44	3.71	1.85	33.30%
33 kv PASCHIM PURI GRID	WPSCP105	11kv FDR NURSING GARDEN	TG-TGN151A-1	990	RESIDENTIAL		Functional	100%	340	0.74			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH110	11kv FDR NW-BLOCK VISHNU GARDEN	TI-TGN196A-1	990	INDUSTRIAL		Functional	100%	689	0.74			
33 kv PASCHIM PURI GRID	WPSCP105	11kv FDR NURSING GARDEN	TG-TGN151A-2	990	RESIDENTIAL		Functional	100%	0	0.68			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH110	11kv FDR NW-BLOCK VISHNU GARDEN	TK-TGN198A-1	990	INDUSTRIAL		Functional	100%	680	0.67			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH110	11kv FDR NW-BLOCK VISHNU GARDEN	TG-TGN196A-2	630	RESIDENTIAL		Functional	100%	0	0.52			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH110	11kv FDR NW-BLOCK VISHNU GARDEN	TG-TGN197A-1	990	INDUSTRIAL		Functional	100%	234	0.45			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH105	11kv FDR NW-BLOCK, CHOWK RMU (TGN)	TP-TGN150A-1	400	RESIDENTIAL		Functional	100%	227	0.34			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH113	11kv FDR S-BLK VISHNU GDN	TG-TGN169A-1	990	INDUSTRIAL		Functional	100%	1445	1.13	2.98	1.01	25.26%
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH113	11kv FDR S-BLK VISHNU GDN	TK-TGN191A-1	1600	INDUSTRIAL		Functional	100%	1058	1.08			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH113	11kv FDR S-BLK VISHNU GDN	TG-TGN169A-2	990	RESIDENTIAL		Functional	100%	0	0.75			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH113	11kv FDR S-BLK VISHNU GDN	TK-TGN191A-2	990	INDUSTRIAL		Functional	100%	314	0.72			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH113	11kv FDR S-BLK VISHNU GDN	TP-TGN202A-1	400	INDUSTRIAL		Functional	100%	537	0.31			
33 kv MUKHERJEE PARK GRID	WMUKP129	11kv FDR MOTHER DIARY SHYAM NGR	TG-TGN154A-1	1600	RESIDENTIAL		Functional	100%	1416	1.06	10.44	0.45	4.11%

33 kV MUKHERJEE PARK GRID	WMUKP113	11kV FDR CHAND NAGAR	TK-TGN160A-3	990	RESIDENTIAL		Functional	100%	0	0.77			
33 kV CHOUKHANDI GRID	WCHAK123	11kV FDR AB-BLOCK KHYALA	TI-TGN176A-1	990	RESIDENTIAL		Functional	100%	1349	0.76			
33 kV CHOUKHANDI GRID	WCHAK109	11kV FDR B-1/283 VISHNU GDN (PHADIYA WALA)	TG-TGN177A-1	990	RESIDENTIAL		Functional	100%	288	0.70			
33 kV MUKHERJEE PARK GRID	WMUKP105	11kV FDR B-BLOCK J.J COLONEY CHAUKHANDI	TG-TGN147A-1	990	RESIDENTIAL		Functional	100%	1289	0.70			
33 kV CHOUKHANDI GRID	WCHAK112	11kV FDR CHAND NAGAR (KHADDE WALA)	TK-TGN153A-2	990	COMMERCIAL		Functional	100%	1467	0.69			
33 kV MUKHERJEE PARK GRID	WMUKP110	11kV FDR CHAUKHANDI	TG-TGN174A-1	990	COMMERCIAL		Functional	100%	679	0.69			
33 kV CHOUKHANDI GRID	WCHAK123	11kV FDR AB-BLOCK KHYALA	TI-TGN176A-2	990	COMMERCIAL		Functional	100%	680	0.66			
33 kV CHOUKHANDI GRID	WCHAK123	11kV FDR AB-BLOCK KHYALA	TG-TGN173A-1	990	COMMERCIAL		Functional	100%	1051	0.62			
33 kV MUKHERJEE PARK GRID	WMUKP113	11kV FDR CHAND NAGAR	TK-TGN160A-2	990	COMMERCIAL		Functional	100%	639	0.55			
33 kV MUKHERJEE PARK GRID	WMUKP113	11kV FDR CHAND NAGAR	TG-TGN160B-1	990	RESIDENTIAL		Functional	100%	0	0.52			
33 kV CHOUKHANDI GRID	WCHAK112	11kV FDR CHAND NAGAR (KHADDE WALA)	TG-TGN153A-3	990	MIXED		Functional	100%	0	0.46			
33 kV CHOUKHANDI GRID	WCHAK123	11kV FDR AB-BLOCK KHYALA	TK-TGN161A-1	990	RESIDENTIAL		Functional	100%	483	0.45			
33 kV CHOUKHANDI GRID	WCHAK112	11kV FDR CHAND NAGAR (KHADDE WALA)	TK-TGN153A-1	1600	COMMERCIAL		Functional	100%	1018	0.44			
33 kV MUKHERJEE PARK GRID	WMUKP105	11kV FDR B-BLOCK J.J COLONEY CHAUKHANDI	TG-TGN147A-2	630	RESIDENTIAL		Functional	100%	0	0.41			
33 kV CHOUKHANDI GRID	WCHAK123	11kV FDR AB-BLOCK KHYALA	TI-TGN173A-2	990	COMMERCIAL		Functional	100%	843	0.39			
33 kV MUKHERJEE PARK GRID	WMUKP113	11kV FDR CHAND NAGAR	TK-TGN160A-1	990	COMMERCIAL		Functional	100%	1862	0.29			
33 kV CHOUKHANDI GRID	WCHAK123	11kV FDR AB-BLOCK KHYALA	TG-TGN236A-1	630	RESIDENTIAL		Functional	100%	499	0.29			
33 kV CHOUKHANDI GRID	WCHAK123	11kV FDR AB-BLOCK KHYALA	641MPK-TGN176A	630	COMMERCIAL		Functional	100%	0	0.24			
33 kV CHOUKHANDI GRID	WCHAK109	11kV FDR B-1/283 VISHNU GDN (PHADIYA WALA)	TG-TGN177A-2	630	RESIDENTIAL		Functional	100%	939	0.21			
33 kV MUKHERJEE PARK GRID	WMUKP113	11kV FDR CHAND NAGAR	641MPK-TGN160A	630	MIXED		Functional	100%	0	0.00			
33 kV MUKHERJEE PARK GRID	WMUKP113	11kV FDR CHAND NAGAR	TG-TGN159A-1	1600	MIXED		Functional	100%	1334	1.16	8.14	0.47	5.48%
66 kV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH119	11kV FDR F-BLK KHATTE VISHNU GARDEN	TK-TGN032A-1	990	INDUSTRIAL		Functional	100%	1011	0.84			
33 kV MUKHERJEE PARK GRID	WMUKP118	11kV FDR MUKHERJEE PARK FEEDER NO.-1	TG-TGN158A-1	990	RESIDENTIAL		Functional	100%	1284	0.82			
33 kV MUKHERJEE PARK GRID	WMUKP112	11kV FDR SHYAM NAGAR	641MPK-TGN190A	990	RESIDENTIAL		Functional	100%	0	0.78			
33 kV MUKHERJEE PARK GRID	WMUKP113	11kV FDR CHAND NAGAR	TP-TGN175A-1	990	RESIDENTIAL	AMR	Functional	100%	486	0.69			
66 kV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH119	11kV FDR F-BLK KHATTE VISHNU GARDEN	TG-TGN032A-3	990	RESIDENTIAL		Functional	100%	578	0.68			
33 kV MUKHERJEE PARK GRID	WMUKP112	11kV FDR SHYAM NAGAR	641MPK-TGN190A	990	RESIDENTIAL		Functional	100%	979	0.62			
33 kV MUKHERJEE PARK GRID	WMUKP106	11kV FDR MUKHERJEE PARK FEEDER NO.-2	TK-TGN155A-1	990	RESIDENTIAL		Functional	100%	709	0.52			
33 kV MUKHERJEE PARK GRID	WMUKP112	11kV FDR SHYAM NAGAR	641MPK-TGN190A	990	RESIDENTIAL		Functional	100%	1024	0.51			
33 kV MUKHERJEE PARK GRID	WMUKP118	11kV FDR MUKHERJEE PARK FEEDER NO.-1	TG-TGN238A-1	990	RESIDENTIAL		Functional	100%	470	0.45			
33 kV MUKHERJEE PARK GRID	WMUKP129	11kV FDR MOTHER DIARY SHYAM NGR	TG-TGN156A-1	990	RESIDENTIAL		Functional	100%	776	0.42			
33 kV MUKHERJEE PARK GRID	WMUKP129	11kV FDR MOTHER DIARY SHYAM NGR	TP-TGN157A-1	400	RESIDENTIAL		Functional	100%	471	0.31			
33 kV MUKHERJEE PARK GRID	WMUKP118	11kV FDR MUKHERJEE PARK FEEDER NO.-1	TG-TGN158A-2	990	RESIDENTIAL		Functional	100%	0	0.29			
33 kV MUKHERJEE PARK GRID	WMUKP106	11kV FDR MUKHERJEE PARK FEEDER NO.-2	TG-TGN155A-2	630	RESIDENTIAL		Functional	100%	0	0.27			
33 kV MUKHERJEE PARK GRID	WMUKP118	11kV FDR MUKHERJEE PARK FEEDER NO.-1	TP-TGN209A-1	400	RESIDENTIAL		Functional	100%	459	0.26			
33 kV CHOUKHANDI GRID	WCHAK118	11kV FDR CHAND NGR SCHOOL WALA	TK-TGN146A-1	990	COMMERCIAL		Functional	100%	833	0.81	3.67	0.48	11.62%
33 kV MUKHERJEE PARK GRID	WMUKP125	11kV FDR MUKHERJEE PARK SCHOOL WALA	TG-TGN186A-1	990	RESIDENTIAL		Functional	100%	944	0.73			
33 kV MUKHERJEE PARK GRID	WMUKP128	11kV FDR GANGA RAM VATIKA	TK-TGN187A-1	990	COMMERCIAL		Functional	100%	518	0.53			
33 kV MUKHERJEE PARK GRID	WMUKP112	11kV FDR SHYAM NAGAR	TG-TGN189A-1	990	COMMERCIAL		Functional	100%	517	0.49			
33 kV MUKHERJEE PARK GRID	WMUKP106	11kV FDR MUKHERJEE PARK FEEDER NO.-2	TG-TGN145A-1	1500	RESIDENTIAL		Functional	100%	446	0.43			
33 kV MUKHERJEE PARK GRID	WMUKP125	11kV FDR MUKHERJEE PARK SCHOOL WALA	TG-TGN186A-2	990	RESIDENTIAL		Functional	100%	0	0.43			

33 kv MUKHERJEE PARK GRID	WMUKP128	11kv FDR GANGA RAM VATIKA	TK-TGN187A-2	990	COMMERCIAL		Functional	100%	199	0.32			
33 kv MUKHERJEE PARK GRID	WMUKP118	11kv FDR MUKHERJEE PARK FEEDER NO.-1	641MPK-TGN145A	990	RESIDENTIAL		Functional	100%	0	0.15			
33 kv CHOUKHANDI GRID	WCHAK118	11kv FDR CHAND NGR SCHOOL WALA	TG-TGN188A-1	990	COMMERCIAL		Functional	100%	574	0.14			
33 kv CHOUKHANDI GRID	WCHAK118	11kv FDR CHAND NGR SCHOOL WALA	TG-TGN188A-2	630	RESIDENTIAL		Functional	100%	0	0.13			
33 kv MUKHERJEE PARK GRID	WMUKP111	11kv STR 100KVA STATION TRANSFORMER	TG-WTC126A-1	100	RESIDENTIAL		Functional	100%	1	0.02			
33 kv CHOUKHANDI GRID	WCHAK121	11kv FDR RAM NAGAR TALWAR WALA	TG-TGN141A-2	990	RESIDENTIAL		Functional	100%	723	0.71	3.79	0.53	12.20%
33 kv CHOUKHANDI GRID	WCHAK103	11kv FDR RAM NAGAR EXTENTION	TP-TGN137A-1	990	RESIDENTIAL		Functional	100%	650	0.70			
33 kv MUKHERJEE PARK GRID	WMUKP128	11kv FDR GANGA RAM VATIKA	TG-TGN142A-1	990	RESIDENTIAL		Functional	100%	566	0.62			
33 kv CHOUKHANDI GRID	WCHAK103	11kv FDR RAM NAGAR EXTENTION	TK-TGN182A-2	630	RESIDENTIAL		Functional	100%	400	0.52			
33 kv CHOUKHANDI GRID	WCHAK121	11kv FDR RAM NAGAR TALWAR WALA	TG-TGN144A-1	630	RESIDENTIAL		Functional	100%	341	0.48			
33 kv MUKHERJEE PARK GRID	WMUKP128	11kv FDR GANGA RAM VATIKA	TG-TGN142A-2	990	RESIDENTIAL		Functional	100%	566	0.47			
33 kv CHOUKHANDI GRID	WCHAK121	11kv FDR RAM NAGAR TALWAR WALA	TG-TGN141A-1	630	RESIDENTIAL		Functional	100%	282	0.33			
33 kv MUKHERJEE PARK GRID	WMUKP125	11kv FDR MUKHERJEE PARK SCHOOL WALA	TG-TGN143A-1	630	RESIDENTIAL		Functional	100%	320	0.29			
33 kv CHOUKHANDI GRID	WCHAK103	11kv FDR RAM NAGAR EXTENTION	TK-TGN182A-1	990	RESIDENTIAL		Functional	100%	467	0.20			
33 kv CHOUKHANDI GRID	WCHAK104	11kv FDR D.D.A CHAUKHANDI	TG-TGN138A-2	1600	RESIDENTIAL		Functional	100%	0	0.92	5.29	0.07	1.32%
33 kv MUKHERJEE PARK GRID	WMUKP110	11kv FDR CHAUKHANDI	TI-TGN135A-1	990	RESIDENTIAL		Functional	100%	1597	0.75			
33 kv CHOUKHANDI GRID	WCHAK103	11kv FDR RAM NAGAR EXTENTION	TG-TGN140A-1	990	RESIDENTIAL		Functional	100%	600	0.62			
33 kv CHOUKHANDI GRID	WCHAK104	11kv FDR D.D.A CHAUKHANDI	TG-TGN139A-1	630	RESIDENTIAL		Functional	100%	634	0.47			
33 kv CHOUKHANDI GRID	WCHAK104	11kv FDR D.D.A CHAUKHANDI	TG-TGN207A-2	630	RESIDENTIAL		Functional	100%	231	0.43			
33 kv MUKHERJEE PARK GRID	WMUKP105	11kv FDR B-BLOCK J.J COLONEY CHAUKHANDI	TK-TGN199A-1	630	RESIDENTIAL		Functional	100%	359	0.42			
33 kv MUKHERJEE PARK GRID	WMUKP110	11kv FDR CHAUKHANDI	TI-TGN135A-2	990	RESIDENTIAL		Functional	100%	331	0.33			
33 kv CHOUKHANDI GRID	WCHAK104	11kv FDR D.D.A CHAUKHANDI	TG-TGN138A-1	990	RESIDENTIAL		Functional	100%	1273	0.31			
33 kv MUKHERJEE PARK GRID	WMUKP105	11kv FDR B-BLOCK J.J COLONEY CHAUKHANDI	TG-TGN136A-1	630	RESIDENTIAL		Functional	100%	502	0.29			
33 kv MUKHERJEE PARK GRID	WMUKP105	11kv FDR B-BLOCK J.J COLONEY CHAUKHANDI	TK-TGN199A-2	630	RESIDENTIAL		Functional	100%	686	0.27			
33 kv CHOUKHANDI GRID	WCHAK104	11kv FDR D.D.A CHAUKHANDI	TI-TGN208A-1	630	RESIDENTIAL		Functional	100%	189	0.20			
33 kv CHOUKHANDI GRID	WCHAK104	11kv FDR D.D.A CHAUKHANDI	TI-TGN208A-2	630	RESIDENTIAL		Functional	100%	41	0.18			
33 kv CHOUKHANDI GRID	WCHAK104	11kv FDR D.D.A CHAUKHANDI	TI-TGN207A-1	630	MIXED		Functional	100%	34	0.14			
33 kv CHOUKHANDI GRID	WCHAK101	11kv STR 100KVA STATION TRANSFORMER	TN-WTC004A-1	100	MIXED		Functional	100%	1	0.02			
33 kv MUKHERJEE PARK GRID	WMUKP101	11kv FDR IND. AREA TILAK NAGAR	TG-TGN132A-1	990	COMMERCIAL	AMR	Functional	100%	177	0.76	5.52	0.32	5.40%
66 kv BODELLA - 1 GRID	WBDL1106	11kv FDR 224 SFS FLATS TAGORE GARDEN	TP-TGN083A-1	990	RESIDENTIAL		Functional	100%	658	0.61			
33 kv MUKHERJEE PARK GRID	WMUKP101	11kv FDR IND. AREA TILAK NAGAR	TK-TGN077A-1	990	COMMERCIAL		Functional	100%	558	0.49			
33 kv MUKHERJEE PARK GRID	WMUKP101	11kv FDR IND. AREA TILAK NAGAR	TG-TGN076A-2	990	COMMERCIAL		Functional	100%	170	0.42			
33 kv MUKHERJEE PARK GRID	WMUKP101	11kv FDR IND. AREA TILAK NAGAR	TK-TGN076A-1	990	COMMERCIAL		Functional	100%	45	0.42			
33 kv MUKHERJEE PARK GRID	WMUKP101	11kv FDR IND. AREA TILAK NAGAR	TP-TGN078A-1	990	COMMERCIAL		Functional	100%	200	0.42			
33 kv MUKHERJEE PARK GRID	WMUKP101	11kv FDR IND. AREA TILAK NAGAR	TK-TGN081A-2	990	COMMERCIAL		Functional	100%	263	0.40			
33 kv MUKHERJEE PARK GRID	WMUKP101	11kv FDR IND. AREA TILAK NAGAR	TK-TGN081A-1	990	COMMERCIAL		Functional	100%	203	0.39			
33 kv MUKHERJEE PARK GRID	WMUKP101	11kv FDR IND. AREA TILAK NAGAR	TG-TGN079A-1	990	RESIDENTIAL		Functional	100%	201	0.38			
66 kv BODELLA - 1 GRID	WBDL1106	11kv FDR 224 SFS FLATS TAGORE GARDEN	641TNR-TGN252A	630	MIXED		Functional	100%	0	0.37			
33 kv CHOUKHANDI GRID	WCHAK122	11kv FDR 288 PUNARWAS COLONY	TI-TGN082A-2	630	COMMERCIAL		Functional	100%	189	0.28			
33 kv MUKHERJEE PARK GRID	WMUKP110	11kv FDR WATER TANK TILAK NAGAR	TI-TGN131A-1	630	COMMERCIAL		Functional	100%	127	0.27			
33 kv MUKHERJEE PARK GRID	WMUKP110	11kv FDR WATER TANK TILAK NAGAR	TG-TGN080A-1	630	COMMERCIAL		Functional	100%	84	0.23			

33 kV MUKHERJEE PARK GRID	WMUKP101	11kV FDR IND. AREA TILAK NAGAR	TI-TGN063A-1	400	COMMERCIAL		Functional	100%	145	0.11			
33 kV MUKHERJEE PARK GRID	WMUKP101	11kV FDR IND. AREA TILAK NAGAR	TP-TGN204A-1	400	COMMERCIAL		Functional	100%	89	0.09			
33 kV MUKHERJEE PARK GRID	WMUKP101	11kV FDR IND. AREA TILAK NAGAR	641TNR-TGN077A	630	RESIDENTIAL		Functional	100%	0	0.09			
33 kV CHOUKHANDI GRID	WCHAK122	11kV FDR 288 PUNARWAS COLONY	TI-TGN082A-1	400	COMMERCIAL		Functional	100%	192	0.08			
66 kV BODELLA - 1 GRID	WBDL1117	11kV FDR 72-SFS NO-2 T.GDN	641TNR-TGN245A	400	MIXED		Functional	100%	0	0.02			
33 kV MUKHERJEE PARK GRID	WMUKP114	11kV FDR TELEPHONE EXCHANGE	TI-TGN007A-1	630	COMMERCIAL		Functional	100%	82	0.25	0.74	0.09	10.57%
33 kV MUKHERJEE PARK GRID	WMUKP114	11kV FDR TELEPHONE EXCHANGE	TI-TGN007A-2	630	RESIDENTIAL		Functional	100%	0	0.24			
33 kV W.D.D.C (VISHAL) GRID	WVSHL119	11kV FDR INTERCONNECTOR NO-1	TP-TGN008A-1	400	COMMERCIAL		Functional	100%	24	0.17			
33 kV W.D.D.C (VISHAL) GRID	WVSHL119	11kV FDR INTERCONNECTOR NO-1	641ABT-TGN008A	630	RESIDENTIAL		Functional	100%	0	0.09			
33 kV W.D.D.C (VISHAL) GRID	WVSHL119	11kV FDR INTERCONNECTOR NO-1	TP-TGN185A-1	400	COMMERCIAL		Functional	100%	8	0.04			
33 kV W.D.D.C (VISHAL) GRID	WVSHL119	11kV FDR INTERCONNECTOR NO-1	TP-TGN066A-1	100	COMMERCIAL		Functional	100%	6	0.03			
33 kV W.D.D.C (VISHAL) GRID	WVSHL102	11kV STR 400KVA STATION TRANSFORMER	TG-WTC128A-1	400	RESIDENTIAL		Functional	100%	1	0.02			
66 kV BODELLA - 2 GRID	WBDL2113	11kV FDR MBS NAGAR	TG-TGN102A-1	990	RESIDENTIAL		Functional	100%	1005	0.85	7.40	0.26	3.34%
33 kV CHOUKHANDI GRID	WCHAK108	11kV FDR KESHOPUR F&V MKT.1	TI-TGN105A-2	990	RESIDENTIAL		Functional	100%	1232	0.79			
33 kV CHOUKHANDI GRID	WCHAK108	11kV FDR KESHOPUR F&V MKT.1	TI-TGN105A-1	990	RESIDENTIAL		Functional	100%	1881	0.79			
66 kV BODELLA - 2 GRID	WBDL2113	11kV FDR MBS NAGAR	TG-TGN104A-2	990	RESIDENTIAL		Functional	100%	170	0.78			
33 kV CHOUKHANDI GRID	WCHAK108	11kV FDR KESHOPUR F&V MKT.1	TG-TGN105A-3	1600	RESIDENTIAL		Functional	100%	0	0.77			
33 kV CHOUKHANDI GRID	WCHAK107	11kV FDR TILAK VIHAR	TG-TGN117A-2	990	RESIDENTIAL		Functional	100%	0	0.69			
66 kV BODELLA - 2 GRID	WBDL2113	11kV FDR MBS NAGAR	TG-TGN101A-2	990	RESIDENTIAL		Functional	100%	0	0.64			
66 kV BODELLA - 2 GRID	WBDL2113	11kV FDR MBS NAGAR	TG-TGN104A-1	990	RESIDENTIAL		Functional	100%	1897	0.57			
66 kV BODELLA - 2 GRID	WBDL2113	11kV FDR MBS NAGAR	TG-TGN101A-1	990	RESIDENTIAL		Functional	100%	1702	0.49			
33 kV CHOUKHANDI GRID	WCHAK107	11kV FDR TILAK VIHAR	TG-TGN117A-1	990	RESIDENTIAL		Functional	100%	1421	0.39			
33 kV CHOUKHANDI GRID	WCHAK106	11kV FDR 224-SFS QTS	TP-TGN129A-1	630	RESIDENTIAL		Functional	100%	517	0.34			
66 kV BODELLA - 2 GRID	WBDL2113	11kV FDR MBS NAGAR	641TNR-TGN104A	630	MIXED		Functional	100%	0	0.24			
66 kV BODELLA - 1 GRID	WBDL1106	11kV FDR 224 SFS FLATS TAGORE GARDEN	TI-TGN100A-1	400	RESIDENTIAL		Functional	100%	187	0.20			
66 kV BODELLA - 1 GRID	WBDL1106	11kV FDR 224 SFS FLATS TAGORE GARDEN	TI-TGN100A-2	400	RESIDENTIAL	AMR	Functional	100%	106	0.12			
66 kV BODELLA - 1 GRID	WBDL1118	11kV FDR 20-BLOCK TILAK NAGAR	TK-TGN097A-1	1600	RESIDENTIAL	AMR	Functional	100%	1095	1.18	9.26	0.32	3.29%
66 kV BODELLA - 1 GRID	WBDL1118	11kV FDR 20-BLOCK TILAK NAGAR	TK-TGN096A-2	1600	COMMERCIAL		Functional	100%	940	0.84			
66 kV BODELLA - 1 GRID	WBDL1116	11kV FDR I-BLOCK TILAK NAGAR	TG-TGN127A-1	990	COMMERCIAL		Functional	100%	300	0.79			
66 kV BODELLA - 1 GRID	WBDL1106	11kV FDR 224 SFS FLATS TAGORE GARDEN	TK-TGN110A-1	990	COMMERCIAL		Functional	100%	808	0.72			
66 kV BODELLA - 1 GRID	WBDL1117	11kV FDR 72-SFS NO-2 T.GDN	TI-TGN094A-1	1500	COMMERCIAL		Functional	100%	530	0.68			
66 kV BODELLA - 1 GRID	WBDL1106	11kV FDR 224 SFS FLATS TAGORE GARDEN	TG-TGN084A-1	990	COMMERCIAL		Functional	100%	601	0.61			
33 kV MUKHERJEE PARK GRID	WMUKP110	11kV FDR WATER TANK TILAK NAGAR	TG-TGN095B-1	990	RESIDENTIAL		Functional	100%	0	0.56			
66 kV BODELLA - 1 GRID	WBDL1116	11kV FDR I-BLOCK TILAK NAGAR	TI-TGN107A-1	990	COMMERCIAL		Functional	100%	388	0.53			
66 kV BODELLA - 1 GRID	WBDL1117	11kV FDR 72-SFS NO-2 T.GDN	TI-TGN094A-2	1500	COMMERCIAL		Functional	100%	590	0.51			
33 kV MUKHERJEE PARK GRID	WMUKP110	11kV FDR WATER TANK TILAK NAGAR	TG-TGN095A-3	990	RESIDENTIAL		Functional	100%	0	0.46			
66 kV BODELLA - 1 GRID	WBDL1118	11kV FDR 20-BLOCK TILAK NAGAR	TK-TGN096A-1	990	COMMERCIAL		Functional	100%	504	0.42			
66 kV BODELLA - 1 GRID	WBDL1116	11kV FDR I-BLOCK TILAK NAGAR	TG-TGN109A-1	630	RESIDENTIAL		Functional	100%	182	0.37			
66 kV BODELLA - 1 GRID	WBDL1116	11kV FDR I-BLOCK TILAK NAGAR	TK-TGN122A-1	990	COMMERCIAL		Functional	100%	454	0.33			
33 kV CHOUKHANDI GRID	WCHAK106	11kV FDR 224-SFS QTS	TG-TGN098A-1	630	COMMERCIAL		Functional	100%	481	0.30			
66 kV BODELLA - 1 GRID	WBDL1116	11kV FDR I-BLOCK TILAK NAGAR	TG-TGN122A-2	630	RESIDENTIAL		Functional	100%	0	0.24			
66 kV BODELLA - 1 GRID	WBDL1106	11kV FDR 224 SFS FLATS TAGORE GARDEN	TG-TGN110A-2	630	RESIDENTIAL		Functional	100%	0	0.22			
33 kV CHOUKHANDI GRID	WCHAK106	11kV FDR 224-SFS QTS	TG-TGN098A-2	630	RESIDENTIAL		Functional	100%	0	0.22			
33 kV MUKHERJEE PARK GRID	WMUKP110	11kV FDR WATER TANK TILAK NAGAR	TG-TGN119A-2	630	RESIDENTIAL		Functional	100%	0	0.21			
33 kV MUKHERJEE PARK GRID	WMUKP110	11kV FDR WATER TANK TILAK NAGAR	TG-TGN095A-1	990	COMMERCIAL		Functional	100%	999	0.19			

66 kV BODELLA - 1 GRID	WBDL1106	11kV FDR 224 SFS FLATS TAGORE GARDEN	TG-TGN123A-1	400	RESIDENTIAL		Functional	100%	143	0.16			
33 kV MUKHERJEE PARK GRID	WMUKP110	11kV FDR WATER TANK TILAK NAGAR	TP-TGN119A-1	400	COMMERCIAL		Functional	100%	192	0.06			
33 kV CHOUKHANDI GRID	WCHAK107	11kV FDR TILAK VIHAR	TG-TGN106A-2	990	RESIDENTIAL		Functional	100%	0	0.83	2.85	0.37	11.58%
33 kV CHOUKHANDI GRID	WCHAK107	11kV FDR TILAK VIHAR	TG-TGN118A-1	990	RESIDENTIAL		Functional	100%	1077	0.63			
66 kV BODELLA - 2 GRID	WBDL2113	11kV FDR MBS NAGAR	TP-TGN203A-1	100	RESIDENTIAL		Functional	100%	86	0.63			
33 kV CHOUKHANDI GRID	WCHAK107	11kV FDR TILAK VIHAR	TG-TGN106A-1	990	RESIDENTIAL		Functional	100%	1795	0.36			
33 kV CHOUKHANDI GRID	WCHAK107	11kV FDR TILAK VIHAR	641TNR-TGN106A	630	RESIDENTIAL		Functional	100%	0	0.30			
33 kV CHOUKHANDI GRID	WCHAK107	11kV FDR TILAK VIHAR	641TNR-TGN118A	630	RESIDENTIAL		Functional	100%	0	0.22			
33 kV CHOUKHANDI GRID	WCHAK102	11kV FDR F & V MRKT-2 / VIA - RMU OUT SIDE CHAN. GRID GATE	TI-TGN134A-1	400	RESIDENTIAL		Functional	100%	150	0.09			
33 kV CHOUKHANDI GRID	WCHAK108	11kV FDR KESHOPUR F&V MKT.1	TI-TGN133A-2	400	RESIDENTIAL		Functional	100%	102	0.07			
33 kV CHOUKHANDI GRID	WCHAK108	11kV FDR KESHOPUR F&V MKT.1	TI-TGN133A-1	400	RESIDENTIAL		Functional	100%	0	0.05			
33 kV CHOUKHANDI GRID	WCHAK102	11kV FDR F & V MRKT-2 / VIA - RMU OUT SIDE CHAN. GRID GATE	TI-TGN134A-2	400	RESIDENTIAL		Functional	100%	28	0.04			
66 kV BODELLA - 1 GRID	WBDL1113	11kV FDR 320-MIG FLATS VKP	TG-TGN124A-1	1600	AGRICULTURE		Functional	100%	1549	1.15	3.31	0.28	7.85%
66 kV BODELLA - 1 GRID	WBDL1113	11kV FDR 320-MIG FLATS VKP	TG-TGN125A-1	1600	RESIDENTIAL		Functional	100%	1088	1.12			
66 kV BODELLA - 1 GRID	WBDL1113	11kV FDR 320-MIG FLATS VKP	TP-TGN126A-1	990	RESIDENTIAL		Functional	100%	768	0.57			
66 kV BODELLA - 1 GRID	WBDL1113	11kV FDR 320-MIG FLATS VKP	TI-TGN099A-1	990	RESIDENTIAL		Functional	100%	679	0.37			
33 kV CHOUKHANDI GRID	WCHAK111	11kV FDR 320-MIG FLATS	TI-TGN099A-2	630	RESIDENTIAL		Functional	100%	120	0.37			
66 kV BODELLA - 1 GRID	WBDL1126	11kV FDR KALI MATA MANDIR GANESH NAGAR	TK-TGN093A-1	1600	RESIDENTIAL		Functional	100%	1092	1.06	12.34	0.19	1.53%
66 kV BODELLA - 1 GRID	WBDL1118	11kV FDR 20-BLOCK TILAK NAGAR	TX-TGN121A-1	990	RESIDENTIAL		Functional	100%	1036	0.83			
66 kV BODELLA - 1 GRID	WBDL1126	11kV FDR KALI MATA MANDIR GANESH NAGAR	TK-TGN128A-1	990	RESIDENTIAL		Functional	100%	822	0.77			
66 kV BODELLA - 1 GRID	WBDL1127	11kV FDR GALI NO 8 MAHAVIR NAGAR	TK-TGN089A-2	1600	RESIDENTIAL		Functional	100%	840	0.77			
66 kV BODELLA - 1 GRID	WBDL1127	11kV FDR GALI NO 8 MAHAVIR NAGAR	TG-TGN090A-1	990	RESIDENTIAL		Functional	100%	1191	0.76			
66 kV BODELLA - 1 GRID	WBDL1107	11kV FDR K-BLK KRISHNA PARK	TK-TGN130A-1	990	RESIDENTIAL		Functional	100%	1352	0.69			
66 kV BODELLA - 1 GRID	WBDL1107	11kV FDR K-BLK KRISHNA PARK	TP-TGN088A-1	1600	RESIDENTIAL		Functional	100%	773	0.68			
66 kV BODELLA - 1 GRID	WBDL1117	11kV FDR 72-SFS NO-2 T. GDN	TI-TGN075A-2	990	RESIDENTIAL		Functional	100%	1407	0.66			
66 kV BODELLA - 1 GRID	WBDL1107	11kV FDR K-BLK KRISHNA PARK	TG-TGN111A-1	990	RESIDENTIAL		Functional	100%	698	0.65			
66 kV BODELLA - 1 GRID	WBDL1110	11kV FDR 72 SFS NO-1 T GDN	TX-TGN112A-2	990	RESIDENTIAL		Functional	100%	0	0.60			
66 kV BODELLA - 1 GRID	WBDL1110	11kV FDR 72 SFS NO-1 T GDN	TX-TGN091A-1	990	RESIDENTIAL		Functional	100%	684	0.59			
66 kV BODELLA - 1 GRID	WBDL1126	11kV FDR KALI MATA MANDIR GANESH NAGAR	TK-TGN128A-2	990	RESIDENTIAL		Functional	100%	751	0.56			
66 kV BODELLA - 1 GRID	WBDL1110	11kV FDR 72 SFS NO-1 T GDN	TG-TGN112A-1	990	RESIDENTIAL		Functional	100%	994	0.56			
66 kV BODELLA - 1 GRID	WBDL1110	11kV FDR 72 SFS NO-1 T GDN	TI-TGN075A-1	990	RESIDENTIAL		Functional	100%	0	0.48			
66 kV BODELLA - 1 GRID	WBDL1110	11kV FDR 72 SFS NO-1 T GDN	TP-TGN092A-1	990	RESIDENTIAL		Functional	100%	406	0.46			
66 kV BODELLA - 1 GRID	WBDL1127	11kV FDR GALI NO 8 MAHAVIR NAGAR	TG-TGN120A-1	630	RESIDENTIAL		Functional	100%	928	0.45			
66 kV BODELLA - 1 GRID	WBDL1110	11kV FDR 72 SFS NO-1 T GDN	TP-TGN113A-1	630	RESIDENTIAL		Functional	100%	445	0.43			
66 kV BODELLA - 1 GRID	WBDL1127	11kV FDR GALI NO 8 MAHAVIR NAGAR	TG-TGN120A-2	630	RESIDENTIAL		Functional	100%	0	0.35			
66 kV BODELLA - 1 GRID	WBDL1107	11kV FDR K-BLK KRISHNA PARK	TG-TGN130A-2	630	RESIDENTIAL		Functional	100%	0	0.30			
66 kV BODELLA - 1 GRID	WBDL1110	11kV FDR 72 SFS NO-1 T GDN	641TNR-TGN112A	630	MIXED		Functional	100%	0	0.24			
66 kV BODELLA - 1 GRID	WBDL1127	11kV FDR GALI NO 8 MAHAVIR NAGAR	TK-TGN089A-1	400	RESIDENTIAL		Functional	100%	402	0.24			
66 kV BODELLA - 1 GRID	WBDL1107	11kV FDR K-BLK KRISHNA PARK	641TNR-TGN130A	630	RESIDENTIAL		Functional	100%	0	0.19			
66 kV BODELLA - 1 GRID	WBDL1110	11kV FDR 72 SFS NO-1 T GDN	TP-TGN193A-1	400	RESIDENTIAL		Functional	100%	272	0.19			
33 kV CHOUKHANDI GRID	WCHAK117	11kV FDR C-BLK TILAK VIHAR	TI-TGN086A-1	990	MIXED		Functional	100%	578	0.85	4.88	0.26	5.15%
33 kV CHOUKHANDI GRID	WCHAK106	11kV FDR 224-SFS QTS	TG-TGN108A-1	990	COMMERCIAL		Functional	100%	1489	0.70			
33 kV CHOUKHANDI GRID	WCHAK111	11kV FDR 320-MIG FLATS	TI-TGN087A-2	990	MIXED		Functional	100%	759	0.64			

33 kv CHOUKHANDI GRID	WCHAK111	11kv FDR 320-MIG FLATS	TG-TGN114A-1	990	RESIDENTIAL		Functional	100%	578	0.62			
66 kv BODELLA - 1 GRID	WBDL1106	11kv FDR 224 SFS FLATS TAGORE GARDEN	TK-TGN085A-1	990	COMMERCIAL		Functional	100%	675	0.51			
33 kv CHOUKHANDI GRID	WCHAK117	11kv FDR C-BLK TILAK VIHAR	TI-TGN086A-2	990	RESIDENTIAL		Functional	100%	373	0.48			
33 kv CHOUKHANDI GRID	WCHAK111	11kv FDR 320-MIG FLATS	TI-TGN087A-1	400	COMMERCIAL		Functional	100%	341	0.29			
33 kv CHOUKHANDI GRID	WCHAK106	11kv FDR 224-SFS QTS	TG-TGN108A-2	630	RESIDENTIAL		Functional	100%	7	0.26			
66 kv BODELLA - 1 GRID	WBDL1106	11kv FDR 224 SFS FLATS TAGORE GARDEN	TG-TGN085A-2	630	RESIDENTIAL		Functional	100%	0	0.25			
33 kv CHOUKHANDI GRID	WCHAK111	11kv FDR 320-MIG FLATS	TI-TGN103A-1	630	COMMERCIAL		Functional	100%	72	0.22			
33 kv CHOUKHANDI GRID	WCHAK111	11kv FDR 320-MIG FLATS	TI-TGN103A-2	630	COMMERCIAL		Functional	100%	194	0.17			
33 kv CHOUKHANDI GRID	WCHAK106	11kv FDR 224-SFS QTS	641TNR-TGN244A-	630	RESIDENTIAL		Functional	100%	124	0.16			
33 kv W.D.D.C (VISHAL) GRID	WVSHL105	11kv FDR S-BLOCK VISHNU GARDEN VI WORK CENTER	TG-TGN025A-1	990	RESIDENTIAL		Functional	100%	1290	0.80	6.89	0.10	1.49%
33 kv W.D.D.C (VISHAL) GRID	WVSHL105	11kv FDR S-BLOCK VISHNU GARDEN VI WORK CENTER	TX-TGN024A-1	990	RESIDENTIAL		Functional	100%	634	0.67			
33 kv MUKHERJEE PARK GRID	WMUKP117	11kv FDR RAGHUBIR NAGAR D-BLOCK	TK-TGN054A-1	990	RESIDENTIAL		Functional	100%	483	0.66			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH104	11kv FDR NEW F-BLOCK TAGORE GARDEN	TG-TGN027A-1	630	COMMERCIAL		Functional	100%	872	0.64			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH104	11kv FDR NEW F-BLOCK TAGORE GARDEN	TG-TGN028A-1	990	COMMERCIAL		Functional	100%	593	0.64			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH104	11kv FDR NEW F-BLOCK TAGORE GARDEN	TG-TGN028A-3	990	RESIDENTIAL		Functional	100%	0	0.52			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH107	11kv FDR 608 JANTA FLAT	TI-TGN051A-2	990	RESIDENTIAL		Functional	100%	574	0.50			
33 kv MUKHERJEE PARK GRID	WMUKP117	11kv FDR RAGHUBIR NAGAR D-BLOCK	TI-TGN051A-1	630	RESIDENTIAL		Functional	100%	473	0.49			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH107	11kv FDR 608 JANTA FLAT	TI-TGN052A-2	630	RESIDENTIAL		Functional	100%	323	0.43			
33 kv W.D.D.C (VISHAL) GRID	WVSHL117	11kv FDR TAGORE GARDEN	TP-TGN220A-1	630	RESIDENTIAL		Functional	100%	372	0.41			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH104	11kv FDR NEW F-BLOCK TAGORE GARDEN	TG-TGN028A-2	630	COMMERCIAL		Functional	100%	1589	0.36			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH107	11kv FDR 608 JANTA FLAT	TG-TGN050A-1	630	RESIDENTIAL		Functional	100%	393	0.31			
33 kv W.D.D.C (VISHAL) GRID	WVSHL105	11kv FDR S-BLOCK VISHNU GARDEN VI WORK CENTER	TG-TGN067A-2	630	RESIDENTIAL		Functional	100%	0	0.29			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH107	11kv FDR 608 JANTA FLAT	TI-TGN052A-1	990	RESIDENTIAL		Functional	100%	382	0.23			
33 kv W.D.D.C (VISHAL) GRID	WVSHL105	11kv FDR S-BLOCK VISHNU GARDEN VI WORK CENTER	TG-TGN067A-1	400	RESIDENTIAL		Functional	100%	392	0.02			
33 kv W.D.D.C (VISHAL) GRID	WVSHL105	11kv FDR S-BLOCK VISHNU GARDEN VI WORK CENTER	TP-TGN222A-1	100	RESIDENTIAL		Functional	100%	19	0.02			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH107	11kv FDR 608 JANTA FLAT	TI-TGN031A-1	990	RESIDENTIAL		Functional	100%	1138	0.84	4.19	0.02	0.48%
33 kv MUKHERJEE PARK GRID	WMUKP117	11kv FDR RAGHUBIR NAGAR D-BLOCK	TP-TGN036A-1	990	COMMERCIAL		Functional	100%	637	0.56			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH119	11kv FDR F-BLK KHATTE VISHNU GARDEN	TG-TGN227A-1	990	RESIDENTIAL		Functional	100%	853	0.55			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH107	11kv FDR 608 JANTA FLAT	TI-TGN031A-2	990	RESIDENTIAL		Functional	100%	1128	0.53			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH107	11kv FDR 608 JANTA FLAT	TK-TGN029A-1	630	RESIDENTIAL		Functional	100%	650	0.52			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH107	11kv FDR 608 JANTA FLAT	641ABT-TGN030A-	630	RESIDENTIAL		Functional	100%	0	0.43			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH107	11kv FDR 608 JANTA FLAT	TG-TGN030A-1	630	RESIDENTIAL		Functional	100%	1023	0.39			

66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH107	11KV FDR 608 JANTA FLAT	TK-TGN029A-2	630	RESIDENTIAL	Functional	100%	497	0.28	8.41	0.15	1.72%			
33 kv W.D.D.C (VISHAL) GRID	WVSHL120	11KV FDR D-BLOCK RAGHUBIR NAGAR	641ABT-TGN253A-	400	MIXED	Functional	100%	0	0.11						
33 kv MUKHERJEE PARK GRID	WMUKP114	11KV FDR TELEPHONE EXCHANGE	641ABT-TGN249A-	250	MIXED	Functional	100%	0	0.00						
33 kv W.D.D.C (VISHAL) GRID	WVSHL120	11KV FDR D-BLOCK RAGHUBIR NAGAR	TG-TGN019A-1	990	RESIDENTIAL	Functional	100%	1555	0.82						
33 kv W.D.D.C (VISHAL) GRID	WVSHL132	11KV FDR F-BLOCK SHIVAJI ENCLAVE	TI-TGN061A-1	990	RESIDENTIAL	Functional	100%	886	0.75						
33 kv W.D.D.C (VISHAL) GRID	WVSHL120	11KV FDR D-BLOCK RAGHUBIR NAGAR	TG-TGN065A-1	990	RESIDENTIAL	Functional	100%	1134	0.74						
33 kv W.D.D.C (VISHAL) GRID	WVSHL132	11KV FDR F-BLOCK SHIVAJI ENCLAVE	TI-TGN061A-2	990	RESIDENTIAL	Functional	100%	1746	0.71						
33 kv W.D.D.C (VISHAL) GRID	WVSHL132	11KV FDR F-BLOCK SHIVAJI ENCLAVE	TG-TGN060A-1	630	RESIDENTIAL	Functional	100%	640	0.61						
33 kv W.D.D.C (VISHAL) GRID	WVSHL120	11KV FDR D-BLOCK RAGHUBIR NAGAR	TI-TGN062A-1	630	RESIDENTIAL	Functional	100%	384	0.61						
66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH108	11KV FDR G-BLOCK SHIVAJEE ENCLAVE	TG-TGN018A-2	990	RESIDENTIAL	Functional	100%	816	0.54						
33 kv W.D.D.C (VISHAL) GRID	WVSHL120	11KV FDR D-BLOCK RAGHUBIR NAGAR	TG-TGN057A-1	630	RESIDENTIAL	Functional	100%	596	0.52						
66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH109	11KV FDR M-BLK RAGHUBIR NAGAR	TG-TGN058A-2	630	RESIDENTIAL	Functional	100%	0	0.46						
66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH108	11KV FDR G-BLOCK SHIVAJEE ENCLAVE	TG-TGN018A-1	990	RESIDENTIAL	Functional	100%	180	0.44						
33 kv W.D.D.C (VISHAL) GRID	WVSHL120	11KV FDR D-BLOCK RAGHUBIR NAGAR	TP-TGN232A-1	630	RESIDENTIAL	Functional	100%	801	0.41						
66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH108	11KV FDR G-BLOCK SHIVAJEE ENCLAVE	TK-TGN017A-1	630	RESIDENTIAL	Functional	100%	195	0.36						
66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH108	11KV FDR G-BLOCK SHIVAJEE ENCLAVE	TK-TGN017A-2	400	RESIDENTIAL	Functional	100%	550	0.34						
33 kv W.D.D.C (VISHAL) GRID	WVSHL120	11KV FDR D-BLOCK RAGHUBIR NAGAR	TI-TGN062A-2	630	RESIDENTIAL	Functional	100%	1005	0.31						
33 kv W.D.D.C (VISHAL) GRID	WVSHL132	11KV FDR F-BLOCK SHIVAJI ENCLAVE	TG-TGN061A-3	400	RESIDENTIAL	Functional	100%	0	0.27						
33 kv W.D.D.C (VISHAL) GRID	WVSHL132	11KV FDR F-BLOCK SHIVAJI ENCLAVE	641ABT-TGN058A-	630	MIXED	Functional	100%	0	0.27						
33 kv W.D.D.C (VISHAL) GRID	WVSHL120	11KV FDR D-BLOCK RAGHUBIR NAGAR	TP-TGN231A-1	400	RESIDENTIAL	Functional	100%	89	0.26						
66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH109	11KV FDR M-BLK RAGHUBIR NAGAR	TK-TGN058A-1	630	RESIDENTIAL	Functional	100%	1306	0.08						
33 kv W.D.D.C (VISHAL) GRID	WVSHL120	11KV FDR D-BLOCK RAGHUBIR NAGAR	TP-TGN225A-1	100	RESIDENTIAL	Functional	100%	68	0.03						
33 kv W.D.D.C (VISHAL) GRID	WVSHL120	11KV FDR D-BLOCK RAGHUBIR NAGAR	TP-TGN168A-1	100	RESIDENTIAL	Functional	100%	87	0.02						
66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH108	11KV FDR G-BLOCK SHIVAJEE ENCLAVE	TK-TGN020A-1	630	RESIDENTIAL	Functional	100%	519	0.60				4.26	0.15	3.35%
33 kv W.D.D.C (VISHAL) GRID	WVSHL109	11KV FDR 748-JANTA FLATS	641ABT-TGN011A-	990	RESIDENTIAL	Functional	100%	175	0.59						
66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH108	11KV FDR G-BLOCK SHIVAJEE ENCLAVE	TI-TGN053A-1	990	RESIDENTIAL	Functional	100%	614	0.50						
33 kv W.D.D.C (VISHAL) GRID	WVSHL110	11KV FDR 1040 JANTA COLONY	TI-TGN010A-1	630	RESIDENTIAL	Functional	100%	180	0.45						
33 kv W.D.D.C (VISHAL) GRID	WVSHL109	11KV FDR 748-JANTA FLATS	641ABT-TGN011A-	990	RESIDENTIAL	Functional	100%	1079	0.44						
33 kv W.D.D.C (VISHAL) GRID	WVSHL110	11KV FDR 1040 JANTA COLONY	TI-TGN010A-2	990	RESIDENTIAL	Functional	100%	407	0.41						
33 kv W.D.D.C (VISHAL) GRID	WVSHL109	11KV FDR 748-JANTA FLATS	TP-TGN012A-1	630	RESIDENTIAL	Functional	100%	71	0.38						
33 kv W.D.D.C (VISHAL) GRID	WVSHL109	11KV FDR 748-JANTA FLATS	641ABT-TGN011B-	990	RESIDENTIAL	Functional	100%	0	0.26						
66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH108	11KV FDR G-BLOCK SHIVAJEE ENCLAVE	TI-TGN053A-3	400	RESIDENTIAL	Functional	100%	40	0.17						
33 kv W.D.D.C (VISHAL) GRID	WVSHL132	11KV FDR F-BLOCK SHIVAJI ENCLAVE	TI-TGN053A-2	400	RESIDENTIAL	Functional	100%	34	0.16						
33 kv W.D.D.C (VISHAL) GRID	WVSHL109	11KV FDR 748-JANTA FLATS	TI-TGN013A-1	400	RESIDENTIAL	Functional	100%	34	0.14						
33 kv W.D.D.C (VISHAL) GRID	WVSHL109	11KV FDR 748-JANTA FLATS	TI-TGN013A-2	400	RESIDENTIAL	Functional	100%	420	0.13						
33 kv W.D.D.C (VISHAL) GRID	WVSHL109	11KV FDR 748-JANTA FLATS	TI-TGN014A-2	400	RESIDENTIAL	Functional	100%	385	0.12						
33 kv W.D.D.C (VISHAL) GRID	WVSHL109	11KV FDR 748-JANTA FLATS	TI-TGN014A-1	400	RESIDENTIAL	Functional	100%	89	0.05						
33 kv MUKHERJEE PARK GRID	WMUKP117	11KV FDR RAGHUBIR NAGAR D-BLOCK	TG-TGN033A-1	990	RESIDENTIAL	Functional	100%	478	0.61	5.82	0.41	6.58%			
33 kv MUKHERJEE PARK GRID	WMUKP117	11KV FDR RAGHUBIR NAGAR D-BLOCK	TI-TGN043A-1	990	RESIDENTIAL	Functional	100%	486	0.56						
33 kv W.D.D.C (VISHAL) GRID	WVSHL117	11KV FDR TAGORE GARDEN	TG-TGN042A-1	990	RESIDENTIAL	Functional	100%	609	0.44						

33 kv MUKHERJEE PARK GRID	WMUKP107	11kv FDR TAGORE GARDEN	TG-TGN038A-1	630	RESIDENTIAL		Functional	100%	644	0.44			
33 kv MUKHERJEE PARK GRID	WMUKP107	11kv FDR TAGORE GARDEN	TK-TGN035A-2	990	RESIDENTIAL		Functional	100%	167	0.43			
33 kv MUKHERJEE PARK GRID	WMUKP107	11kv FDR TAGORE GARDEN	TK-TGN040A-1	990	RESIDENTIAL		Functional	100%	296	0.40			
33 kv MUKHERJEE PARK GRID	WMUKP114	11kv FDR TELEPHONE EXCHANGE	TG-TGN038A-2	990	RESIDENTIAL		Functional	100%	377	0.40			
33 kv MUKHERJEE PARK GRID	WMUKP107	11kv FDR TAGORE GARDEN	TP-TGN041A-1	630	RESIDENTIAL		Functional	100%	226	0.39			
33 kv W.D.D.C (VISHAL) GRID	WVSHL117	11kv FDR TAGORE GARDEN	TG-TGN034A-1	630	RESIDENTIAL		Functional	100%	368	0.37			
33 kv W.D.D.C (VISHAL) GRID	WVSHL117	11kv FDR TAGORE GARDEN	TG-TGN042A-2	630	RESIDENTIAL		Functional	100%	0	0.36			
33 kv MUKHERJEE PARK GRID	WMUKP107	11kv FDR TAGORE GARDEN	TK-TGN035A-1	630	RESIDENTIAL		Functional	100%	455	0.36			
33 kv MUKHERJEE PARK GRID	WMUKP107	11kv FDR TAGORE GARDEN	TI-TGN039A-2	990	RESIDENTIAL		Functional	100%	195	0.29			
33 kv W.D.D.C (VISHAL) GRID	WVSHL117	11kv FDR TAGORE GARDEN	TI-TGN039A-1	990	RESIDENTIAL		Functional	100%	293	0.28			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH106	11kv FDR C-BLK BREAK DOWN OFFICE	TG-TGN022A-2	400	RESIDENTIAL		Functional	100%	0	0.26			
33 kv MUKHERJEE PARK GRID	WMUKP117	11kv FDR RAGHUBIR NAGAR D-BLOCK	TK-TGN043A-2	630	RESIDENTIAL		Functional	100%	182	0.26			
33 kv W.D.D.C (VISHAL) GRID	WVSHL117	11kv FDR TAGORE GARDEN	TG-TGN044A-1	400	RESIDENTIAL		Functional	100%	163	0.24			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH106	11kv FDR C-BLK BREAK DOWN OFFICE	TI-TGN022A-1	630	RESIDENTIAL		Functional	100%	393	0.16			
33 kv MADIPUR GRID	WMDPR110	11kv FDR R-G BLOCK RAGHUBIR NAGAR	TG-TGN048A-1	990	INDUSTRIAL		Functional	100%	907	0.78	7.18	0.20	2.78%
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH109	11kv FDR M-BLK RAGHUBIR NAGAR	TK-TGN059A-1	1600	INDUSTRIAL		Functional	100%	1210	0.77			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH109	11kv FDR M-BLK RAGHUBIR NAGAR	TK-TGN047A-1	990	INDUSTRIAL		Functional	100%	75	0.73			
33 kv W.D.D.C (VISHAL) GRID	WVSHL101	11kv FDR KHAYALA PUMPING STATION	TI-TGN046A-1	630	INDUSTRIAL		Functional	100%	202	0.71			
33 kv W.D.D.C (VISHAL) GRID	WVSHL101	11kv FDR KHAYALA PUMPING STATION	TG-TGN045A-1	630	INDUSTRIAL		Functional	100%	986	0.59			
33 kv W.D.D.C (VISHAL) GRID	WVSHL101	11kv FDR KHAYALA PUMPING STATION	TI-TGN046A-2	630	INDUSTRIAL		Functional	100%	1617	0.41			
33 kv MADIPUR GRID	WMDPR110	11kv FDR R-G BLOCK RAGHUBIR NAGAR	TI-TGN055A-1	630	INDUSTRIAL		Functional	100%	188	0.41			
33 kv MADIPUR GRID	WMDPR110	11kv FDR R-G BLOCK RAGHUBIR NAGAR	TG-TGN056A-1	630	INDUSTRIAL		Functional	100%	640	0.39			
33 kv MADIPUR GRID	WMDPR110	11kv FDR R-G BLOCK RAGHUBIR NAGAR	TP-TGN015A-1	400	INDUSTRIAL		Functional	100%	576	0.35			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH109	11kv FDR M-BLK RAGHUBIR NAGAR	TG-TGN064A-1	400	INDUSTRIAL		Functional	100%	468	0.34			
33 kv W.D.D.C (VISHAL) GRID	WVSHL101	11kv FDR KHAYALA PUMPING STATION	TG-TGN049A-1	630	INDUSTRIAL		Functional	100%	539	0.34			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH109	11kv FDR M-BLK RAGHUBIR NAGAR	TK-TGN047A-2	630	INDUSTRIAL		Functional	100%	1503	0.33			
33 kv W.D.D.C (VISHAL) GRID	WVSHL101	11kv FDR KHAYALA PUMPING STATION	TG-TGN046A-3	630	RESIDENTIAL		Functional	100%	0	0.28			
33 kv MADIPUR GRID	WMDPR110	11kv FDR R-G BLOCK RAGHUBIR NAGAR	641ABT-TGN246A	630	RESIDENTIAL		Functional	100%	4	0.26			
33 kv MADIPUR GRID	WMDPR110	11kv FDR R-G BLOCK RAGHUBIR NAGAR	TG-TGN212A-1	630	INDUSTRIAL		Functional	100%	599	0.23			
33 kv MADIPUR GRID	WMDPR110	11kv FDR R-G BLOCK RAGHUBIR NAGAR	TI-TGN055A-2	630	INDUSTRIAL		Functional	100%	521	0.17			
33 kv MADIPUR GRID	WMDPR110	11kv FDR R-G BLOCK RAGHUBIR NAGAR	TP-TGN015A-2	400	RESIDENTIAL		Functional	100%	0	0.17			
33 kv W.D.D.C (VISHAL) GRID	WVSHL105	11kv FDR S-BLOCK VISHNU GARDEN VI WORK CENTER	TI-TGN037A-1	400	COMMERCIAL		Functional	100%	69	0.06			
66 kv GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH103	11kv STR 400KVA STATION TRANSFORMER	TG-WTC123A-1	400	RESIDENTIAL		Functional	100%	1	0.03			
33 kv W.D.D.C (VISHAL) GRID	WVSHL101	11kv FDR KHAYALA PUMPING STATION	TP-TGN224A-1	100	RESIDENTIAL		Functional	100%	60	0.02			
33 kv W.D.D.C (VISHAL) GRID	WVSHL101	11kv FDR KHAYALA PUMPING STATION	TP-TGN172A-1	100	RESIDENTIAL		Functional	100%	47	0.02			
33 kv W.D.D.C (VISHAL) GRID	WVSHL114	11kv FDR A-BLK TAGORE GDN FDR	TI-TGN001A-1	990	COMMERCIAL		Functional	100%	727	0.65	6.84	0.21	3.00%
33 kv W.D.D.C (VISHAL) GRID	WVSHL114	11kv FDR A-BLK TAGORE GDN FDR	TI-TGN001A-2	990	COMMERCIAL		Functional	100%	441	0.65			
33 kv MUKHERJEE PARK GRID	WMUKP114	11kv FDR TELEPHONE EXCHANGE	TI-TGN023A-2	990	RESIDENTIAL		Functional	100%	380	0.62			
33 kv W.D.D.C (VISHAL) GRID	WVSHL119	11kv FDR INTERCONNECTOR NO-1	TK-TGN005A-2	990	COMMERCIAL		Functional	100%	191	0.52			
33 kv MUKHERJEE PARK GRID	WMUKP114	11kv FDR TELEPHONE EXCHANGE	TI-TGN023A-1	990	RESIDENTIAL		Functional	100%	674	0.52			
33 kv W.D.D.C (VISHAL) GRID	WVSHL119	11kv FDR INTERCONNECTOR NO-1	TK-TGN004A-1	990	COMMERCIAL		Functional	100%	56	0.50			
33 kv MUKHERJEE PARK GRID	WMUKP107	11kv FDR TAGORE GARDEN	TG-TGN181A-1	630	RESIDENTIAL		Functional	100%	155	0.48			
33 kv MUKHERJEE PARK GRID	WMUKP114	11kv FDR TELEPHONE EXCHANGE	TK-TGN009A-1	630	COMMERCIAL		Functional	100%	215	0.46			

66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH106	11kv FDR C-BLK BREAK DOWN OFFICE	TG-TGN021A-1	990	RESIDENTIAL		Functional	100%	418	0.46			
33 kv W.D.D.C (VISHAL) GRID	WVSHL114	11kv FDR A-BLK TAGORE GDN FDR	TK-TGN003A-2	990	COMMERCIAL		Functional	100%	233	0.41			
33 kv W.D.D.C (VISHAL) GRID	WVSHL119	11kv FDR INTERCONNECTOR NO-1	TG-TGN002A-1	630	COMMERCIAL		Functional	100%	403	0.38			
33 kv W.D.D.C (VISHAL) GRID	WVSHL114	11kv FDR A-BLK TAGORE GDN FDR	TK-TGN003A-1	990	COMMERCIAL		Functional	100%	358	0.34			
33 kv MUKHERJEE PARK GRID	WMUKP114	11kv FDR TELEPHONE EXCHANGE	TK-TGN009A-2	990	COMMERCIAL		Functional	100%	191	0.34			
33 kv W.D.D.C (VISHAL) GRID	WVSHL119	11kv FDR INTERCONNECTOR NO-1	TK-TGN004A-2	990	COMMERCIAL		Functional	100%	98	0.31			
33 kv W.D.D.C (VISHAL) GRID	WVSHL119	11kv FDR INTERCONNECTOR NO-1	TK-TGN005A-1	990	COMMERCIAL		Functional	100%	189	0.23			
33 kv W.D.D.C (VISHAL) GRID	WVSHL119	11kv FDR INTERCONNECTOR NO-1	TP-TGN006A-1	400	COMMERCIAL		Functional	100%	104	0.16			
66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH105	11kv FDR NW-BLOCK, CHOWK RMU (TGN)	TG-TGN149A-2	990	RESIDENTIAL		Functional	100%	0	1.29	5.06	3.05	37.61%
33 kv PASCHIM PURI GRID	WPSCP105	11kv FDR NURSING GARDEN	TG-TGN167A-2	990	RESIDENTIAL		Functional	100%	343	1.14			
33 kv MUKHERJEE PARK GRID	WMUKP119	11kv FDR B-1/283 VISHNU GARDEN	TG-TGN194A-1	990	RESIDENTIAL		Functional	100%	844	1.11			
33 kv PASCHIM PURI GRID	WPSCP105	11kv FDR NURSING GARDEN	TG-TGN167A-1	990	RESIDENTIAL		Functional	100%	262	1.05			
66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH105	11kv FDR NW-BLOCK, CHOWK RMU (TGN)	TG-TGN149A-1	990	RESIDENTIAL		Functional	100%	640	0.89			
33 kv CHOUKHANDI GRID	WCHAK105	11kv FDR RZ-BLOCK, VISHNU GDN	TG-TGN201A-1	990	RESIDENTIAL	AMR	Functional	100%	407	0.61			
66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH118	11kv FDR PLOT NO-.23 SHIVAJI PLACE NO-.1	TG-TGN195A-1	630	RESIDENTIAL		Functional	100%	511	0.61			
33 kv PASCHIM PURI GRID	WPSCP105	11kv FDR NURSING GARDEN	641MPK-TGN239A	630	RESIDENTIAL		Functional	100%	178	0.59			
66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH118	11kv FDR PLOT NO-.23 SHIVAJI PLACE NO-.1	TG-TGN195A-2	990	RESIDENTIAL		Functional	100%	0	0.56			
33 kv PASCHIM PURI GRID	WPSCP105	11kv FDR NURSING GARDEN	TG-TGN239A-1	990	RESIDENTIAL		Functional	100%	0	0.19			
66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH105	11kv FDR NW-BLOCK, CHOWK RMU (TGN)	TP-TGN205A-1	100	MIXED		Functional	100%	19	0.03			
66 KV GURU G.S.HOSP.(RAGHUBIR NGR) GRID	WGGSH105	11kv FDR NW-BLOCK, CHOWK RMU (TGN)	TP-TGN206A-1	100	RESIDENTIAL		Functional	100%	1	0.03			
33 kv MUKHERJEE PARK GRID	WMUKP123	11kv FDR S-BLOCK WORK CENTER VISHNU GARDEN	TG-TGN148A-3	990	INDUSTRIAL		Functional	100%	732	1.66	4.00	3.48	46.49%
33 kv MUKHERJEE PARK GRID	WMUKP123	11kv FDR S-BLOCK WORK CENTER VISHNU GARDEN	TG-TGN148A-2	990	RESIDENTIAL		Functional	100%	942	1.37			
33 kv MUKHERJEE PARK GRID	WMUKP123	11kv FDR S-BLOCK WORK CENTER VISHNU GARDEN	TG-TGN148A-1	990	INDUSTRIAL		Functional	100%	370	1.32			
33 kv MUKHERJEE PARK GRID	WMUKP119	11kv FDR B-1/283 VISHNU GARDEN	TG-TGN192A-2	990	INDUSTRIAL		Functional	100%	1085	1.08			
33 kv MUKHERJEE PARK GRID	WMUKP119	11kv FDR B-1/283 VISHNU GARDEN	TG-TGN192A-1	990	INDUSTRIAL		Functional	100%	805	0.89			
33 kv MUKHERJEE PARK GRID	WMUKP123	11kv FDR S-BLOCK WORK CENTER VISHNU GARDEN	TI-TGN026A-1	990	RESIDENTIAL		Functional	100%	409	0.66			
33 kv MUKHERJEE PARK GRID	WMUKP119	11kv FDR B-1/283 VISHNU GARDEN	641MPK-TGN192A	630	MIXED		Functional	100%	0	0.50			
66 kv HASTSAL GRID	WHAST103	11kv FDR LIG MOTHER DAIRY	TI-VIK076A-1	990	RESIDENTIAL		Functional	100%	732	0.61	2.89	0.05	1.54%
66 kv BODELLA - 2 GRID	WBDL2130	11kv FDR LIG COMPLAINT CENTER	TI-VIK077A-1	990	RESIDENTIAL		Functional	100%	199	0.44			
66 kv BODELLA - 2 GRID	WBDL2130	11kv FDR LIG COMPLAINT CENTER	TI-VIK077A-2	630	RESIDENTIAL		Functional	100%	666	0.35			
66 kv BODELLA - 2 GRID	WBDL2131	11kv FDR LIG MOTHER DAIRY	TI-VIK075A-1	630	RESIDENTIAL		Functional	100%	205	0.34			
66 kv BODELLA - 2 GRID	WBDL2131	11kv FDR LIG MOTHER DAIRY	TI-VIK075A-2	630	RESIDENTIAL		Functional	100%	777	0.34			
66 kv HASTSAL GRID	WHAST103	11kv FDR LIG MOTHER DAIRY	TI-VIK073A-1	400	RESIDENTIAL		Functional	100%	0	0.32			
66 kv HASTSAL GRID	WHAST103	11kv FDR LIG MOTHER DAIRY	TI-VIK073A-2	630	RESIDENTIAL		Functional	100%	909	0.27			
66 kv HASTSAL GRID	WHAST103	11kv FDR LIG MOTHER DAIRY	TG-VIK076A-2	630	RESIDENTIAL		Functional	100%	0	0.25			
66 kv HASTSAL GRID	WHAST111	11kv FDR UTTAM NAG TERM	TG-HAS043A-1	990	COMMERCIAL	AMR	Functional	100%	1340	0.91	6.67	0.09	1.36%
66 kv HASTSAL GRID	WHAST123	11kv FDR GURUDWARA HASTAL ROAD	TG-HAS012A-1	990	COMMERCIAL		Functional	100%	866	0.83			
66 kv HASTSAL GRID	WHAST104	11kv FDR C2BLK J.J COLONY	TI-HAS008A-3	990	RESIDENTIAL		Functional	100%	544	0.72			
66 kv HASTSAL GRID	WHAST123	11kv FDR GURUDWARA HASTAL ROAD	TG-HAS038A-2	990	COMMERCIAL		Functional	100%	2777	0.71			
66 kv HASTSAL GRID	WHAST111	11kv FDR UTTAM NAG TERM	TK-HAS009A-2	630	RESIDENTIAL		Functional	100%	0	0.60			
66 kv HASTSAL GRID	WHAST111	11kv FDR UTTAM NAG TERM	TK-HAS009A-1	630	COMMERCIAL		Functional	100%	501	0.60			
66 kv HASTSAL GRID	WHAST104	11kv FDR C2BLK J.J COLONY	TG-HAS008A-1	990	COMMERCIAL		Functional	100%	2257	0.55			
66 kv HASTSAL GRID	WHAST111	11kv FDR UTTAM NAG TERM	TG-HAS038A-3	990	RESIDENTIAL		Functional	100%	0	0.49			

66 kV HASTSAL GRID	WHAST104	11kV FDR C-BLOCK JJ COLONY	TG-HAS008B-1	990	RESIDENTIAL		Functional	100%	0	0.48			
66 kV HASTSAL GRID	WHAST123	11kV FDR GURUDWARA HASTAL ROAD	TG-HAS012A-2	1000	COMMERCIAL		Functional	100%	234	0.40			
66 kV HASTSAL GRID	WHAST123	11kV FDR GURUDWARA HASTAL ROAD	TG-HAS038A-1	400	COMMERCIAL		Functional	100%	542	0.38			
66 kV HASTSAL GRID	WHAST111	11kV FDR UTTAM NAG TERM	TG-HAS170A-1	400	RESIDENTIAL		Functional	100%	2	0.07			
66 kV HASTSAL GRID	WHAST109	11kV STR 400KVA STATION TRANSFORMER	TG-WTC029A-1	400	RESIDENTIAL		Functional	100%	1	0.02			
66 kV BODELLA - 2 GRID	WBDL2138	11kV FDR BHARAT GHAR	TG-HAS053A-2	990	RESIDENTIAL		Functional	100%	1934	1.22	9.38	0.94	9.09%
66 kV BODELLA - 2 GRID	WBDL2102	11kV FDR HOLY CONVENT(SCHOOL VIKASPURI)	TP-HAS105A-1	990	RESIDENTIAL		Functional	100%	813	1.13			
66 kV BODELLA - 2 GRID	WBDL2102	11kV FDR HOLY CONVENT(SCHOOL VIKASPURI)	TP-HAS104A-1	990	RESIDENTIAL		Functional	100%	896	0.85			
66 kV BODELLA - 2 GRID	WBDL2129	11kV FDR SHIV VIHAR	TG-HAS077A-1	990	RESIDENTIAL		Functional	100%	3631	0.82			
66 kV BODELLA - 2 GRID	WBDL2129	11kV FDR SHIV VIHAR	TG-HAS125A-1	630	RESIDENTIAL		Functional	100%	659	0.71			
66 kV BODELLA - 2 GRID	WBDL2129	11kV FDR SHIV VIHAR	VP-HVD045A-1	1250	RESIDENTIAL		Functional	100%	926	0.70			
66kV NILOTHI GRID	WNILO130	11kV FDR PARDHAN CHOWK	TP-HAS139A-1	990	RESIDENTIAL		Functional	100%	483	0.66			
66 kV BODELLA - 2 GRID	WBDL2138	11kV FDR BHARAT GHAR	TP-HAS079A-1	630	RESIDENTIAL		Functional	100%	1041	0.65			
66kV NILOTHI GRID	WNILO130	11kV FDR PARDHAN CHOWK	TP-HAS123A-1	990	RESIDENTIAL		Functional	100%	886	0.65			
66kV NILOTHI GRID	WNILO130	11kV FDR PARDHAN CHOWK	TP-HAS085A-1	990	RESIDENTIAL		Functional	100%	889	0.50			
66kV NILOTHI GRID	WNILO130	11kV FDR PARDHAN CHOWK	TP-HAS123A-2	630	RESIDENTIAL		Functional	100%	1179	0.49			
66 kV BODELLA - 2 GRID	WBDL2138	11kV FDR BHARAT GHAR	TG-HAS053A-1	400	RESIDENTIAL		Functional	100%	387	0.45			
66 kV HASTSAL GRID	WHAST115	11kV FDR RAJHANS VIHAR	TP-HAS050A-1	630	RESIDENTIAL		Functional	100%	759	0.38			
66 kV BODELLA - 2 GRID	WBDL2129	11kV FDR SHIV VIHAR	TI-HAS109A-2	400	RESIDENTIAL		Functional	100%	0	0.38			
66 kV BODELLA - 2 GRID	WBDL2129	11kV FDR SHIV VIHAR	TP-HAS109A-1	400	RESIDENTIAL		Functional	100%	561	0.29			
66 kV BODELLA - 2 GRID	WBDL2129	11kV FDR SHIV VIHAR	TP-HAS052A-1	400	RESIDENTIAL		Functional	100%	24	0.27			
66kV NILOTHI GRID	WNILO130	11kV FDR PARDHAN CHOWK	TG-HAS152A-1	630	RESIDENTIAL		Functional	100%	11	0.16			
66 kV BODELLA - 1 GRID	WBDL1114	11kV FDR C BLOCK VIKASPURI	TG-VIK026A-1	990	RESIDENTIAL		Functional	100%	1345	1.01	8.78	0.10	1.12%
66 kV BODELLA - 2 GRID	WBDL2116	11kV FDR DG23 VKP	TI-VIK047A-1	990	RESIDENTIAL		Functional	100%	553	0.63			
66 kV BODELLA - 2 GRID	WBDL2116	11kV FDR DG23 VKP	TI-VIK045A-2	990	RESIDENTIAL		Functional	100%	181	0.63			
66 kV BODELLA - 2 GRID	WBDL2112	11kV FDR NAVYUG APPTT21	TG-VIK025A-1	990	RESIDENTIAL		Functional	100%	493	0.61			
66 kV BODELLA - 1 GRID	WBDL1114	11kV FDR C BLOCK VIKASPURI	TI-VIK030A-2	990	RESIDENTIAL		Functional	100%	697	0.56			
66 kV BODELLA - 2 GRID	WBDL2112	11kV FDR NAVYUG APPTT21	TI-VIK052A-1	990	RESIDENTIAL		Functional	100%	776	0.56			
66 kV BODELLA - 1 GRID	WBDL1105	11kV FDR D2BLOCK2VKP	TI-VIK044A-2	990	RESIDENTIAL	AMR	Functional	100%	188	0.53			
66 kV BODELLA - 1 GRID	WBDL1114	11kV FDR C BLOCK VIKASPURI	TG-VIK028A-1	990	RESIDENTIAL		Functional	100%	334	0.51			
66 kV BODELLA - 1 GRID	WBDL1105	11kV FDR D2BLOCK2VKP	TI-VIK042A-2	990	RESIDENTIAL		Functional	100%	309	0.48			
66 kV BODELLA - 1 GRID	WBDL1114	11kV FDR C BLOCK VIKASPURI	TI-VIK030A-1	990	RESIDENTIAL		Functional	100%	156	0.44			
66 kV BODELLA - 1 GRID	WBDL1114	11kV FDR C BLOCK VIKASPURI	TG-VIK029A-1	990	RESIDENTIAL		Functional	100%	625	0.44			
66 kV BODELLA - 1 GRID	WBDL1105	11kV FDR D2BLOCK2VKP	TI-VIK043A-2	630	RESIDENTIAL		Functional	100%	42	0.41			
66 kV BODELLA - 2 GRID	WBDL2119	11kV FDR G-1/3 SUB SATION	TG-VIK124A-1	630	RESIDENTIAL		Functional	100%	258	0.39			
66 kV BODELLA - 2 GRID	WBDL2116	11kV FDR DG23 VKP	TI-VIK045A-1	630	RESIDENTIAL		Functional	100%	165	0.35			
66 kV BODELLA - 2 GRID	WBDL2116	11kV FDR DG23 VKP	TI-VIK046A-1	630	RESIDENTIAL		Functional	100%	775	0.29			
66 kV BODELLA - 1 GRID	WBDL1105	11kV FDR D2BLOCK2VKP	TI-VIK044A-1	630	RESIDENTIAL	AMR	Functional	100%	415	0.23			
66 kV BODELLA - 1 GRID	WBDL1114	11kV FDR C BLOCK VIKASPURI	TI-VIK027A-2	630	RESIDENTIAL		Functional	100%	263	0.21			
66 kV BODELLA - 1 GRID	WBDL1105	11kV FDR D2BLOCK2VKP	TI-VIK043A-1	630	RESIDENTIAL		Functional	100%	199	0.17			
66 kV BODELLA - 2 GRID	WBDL2119	11kV FDR G-1/3 SUB SATION	2650CBV-VIK124A-	630	RESIDENTIAL		Functional	100%	0	0.16			
66 kV BODELLA - 1 GRID	WBDL1105	11kV FDR D2BLOCK2VKP	TI-VIK042A-1	630	RESIDENTIAL		Functional	100%	102	0.15			
66 kV BODELLA - 1 GRID	WBDL1114	11kV FDR C BLOCK VIKASPURI	TI-VIK027A-1	630	RESIDENTIAL		Functional	100%	44	0.12			
66 kV HASTSAL GRID	WHAST102	11kV FDR KALI BASTI	TI-HAS031A-2	990	RESIDENTIAL	AMR	Functional	100%	1404	0.78	4.76	0.25	4.99%
66 kV HASTSAL GRID	WHAST102	11kV FDR KALI BASTI	TI-HAS031A-1	990	RESIDENTIAL	AMR	Functional	100%	809	0.77			
66 kV HASTSAL GRID	WHAST108	11kV FDR HASTAL VIHAR	TI-HAS026A-1	990	RESIDENTIAL		Functional	100%	1721	0.76			
66 kV HASTSAL GRID	WHAST131	11kV FDR VIDHYA VIHAR	TP-HAS002A-1	990	RESIDENTIAL		Functional	100%	270	0.67			
66 kV HASTSAL GRID	WHAST111	11kV FDR UTTAM NAG TERM	TG-HAS039A-1	990	RESIDENTIAL	AMR	Functional	100%	528	0.63			
66 kV HASTSAL GRID	WHAST131	11kV FDR VIDHYA VIHAR	TG-HAS020A-2	630	RESIDENTIAL		Functional	100%	0	0.47			
66 kV HASTSAL GRID	WHAST108	11kV FDR HASTAL VIHAR	TP-HAS026A-2	400	RESIDENTIAL		Functional	100%	0	0.33			

66 kV HASTSAL GRID	WHAST131	11kV FDR VIDHYA VIHAR	TP-HAS020A-1	630	RESIDENTIAL		Functional	100%	1047	0.33			
66 kV HASTSAL GRID	WHAST131	11kV FDR VIDHYA VIHAR	TP-HAS020A-3	400	RESIDENTIAL		Functional	100%	0	0.16			
66 kV HASTSAL GRID	WHAST131	11kV FDR VIDHYA VIHAR	TP-HAS020A-4	400	RESIDENTIAL		Functional	100%	0	0.10			
66 kV BODELLA - 1 GRID	WBDL1111	11kV FDR HIMGIRI LIONS	TG-VIK054A-1	630	RESIDENTIAL		Functional	100%	331	0.60	4.96	0.49	9.02%
66 kV BODELLA - 2 GRID	WBDL2119	11kV FDR G-1/3 SUB SATION	TG-VIK125A-1	630	RESIDENTIAL		Functional	100%	309	0.58			
66 kV BODELLA - 1 GRID	WBDL1108	11kV FDR GUJRANWALA SOCIETY	TI-VIK064A-1	990	RESIDENTIAL		Functional	100%	306	0.52			
66 kV BODELLA - 2 GRID	WBDL2115	11kV FDR F2BLK I/D SSTN VKP	TI-VIK032A-1	990	RESIDENTIAL	AMR	Functional	100%	372	0.52			
66 kV BODELLA - 2 GRID	WBDL2115	11kV FDR F2BLK I/D SSTN VKP	TI-VIK032A-2	630	RESIDENTIAL	AMR	Functional	100%	354	0.46			
66 kV BODELLA - 2 GRID	WBDL2119	11kV FDR G-1/3 SUB SATION	TI-VIK070A-1	990	RESIDENTIAL		Functional	100%	225	0.33			
66 kV BODELLA - 2 GRID	WBDL2106	11kV FDR G21 SSTN21 SONIA	TI-VIK069A-2	630	RESIDENTIAL		Functional	100%	305	0.31			
66 kV BODELLA - 2 GRID	WBDL2107	11kV FDR GANGOTRI SOCIETY	TG-VIK033A-1	990	RESIDENTIAL		Functional	100%	474	0.31			
66 kV BODELLA - 2 GRID	WBDL2106	11kV FDR G21 SSTN21 SONIA	TP-VIK111A-1	630	RESIDENTIAL		Functional	100%	332	0.29			
66 kV BODELLA - 2 GRID	WBDL2115	11kV FDR F2BLK I/D SSTN VKP	TP-VIK144A-1	630	RESIDENTIAL		Functional	100%	137	0.26			
66 kV BODELLA - 2 GRID	WBDL2119	11kV FDR G-1/3 SUB SATION	TI-VIK068A-2	630	RESIDENTIAL		Functional	100%	38	0.26			
66 kV BODELLA - 2 GRID	WBDL2119	11kV FDR G-1/3 SUB SATION	TI-VIK067A-1	630	RESIDENTIAL		Functional	100%	45	0.25			
66 kV BODELLA - 2 GRID	WBDL2119	11kV FDR G-1/3 SUB SATION	TI-VIK070A-2	630	RESIDENTIAL		Functional	100%	451	0.22			
66 kV BODELLA - 2 GRID	WBDL2119	11kV FDR G-1/3 SUB SATION	TI-VIK068A-1	990	RESIDENTIAL		Functional	100%	39	0.19			
66 kV BODELLA - 2 GRID	WBDL2106	11kV FDR G21 SSTN21 SONIA	TI-VIK069A-1	990	RESIDENTIAL		Functional	100%	339	0.15			
66 kV BODELLA - 2 GRID	WBDL2106	11kV FDR G21 SSTN21 SONIA	TI-VIK069A-3	630	RESIDENTIAL		Functional	100%	180	0.13			
66 kV BODELLA - 2 GRID	WBDL2119	11kV FDR G-1/3 SUB SATION	TI-VIK067A-2	400	RESIDENTIAL		Functional	100%	204	0.05			
66 kV BODELLA - 2 GRID	WBDL2107	11kV FDR GANGOTRI SOCIETY	TI-VIK120A-1	400	RESIDENTIAL		Functional	100%	3	0.03			
66 kV BODELLA - 1 GRID	WBDL1103	11kV FDR KANGRA NIKETAN	TG-VIK101A-1	990	RESIDENTIAL		Functional	100%	425	0.49	1.93	0.02	1.27%
66 kV BODELLA - 1 GRID	WBDL1103	11kV FDR KANGRA NIKETAN	TG-VIK101A-2	630	RESIDENTIAL		Functional	100%	0	0.35			
66 kV BODELLA - 1 GRID	WBDL1108	11kV FDR GUJRANWALA SOCIETY	TI-VIK100A-1	990	RESIDENTIAL		Functional	100%	292	0.34			
66 kV BODELLA - 1 GRID	WBDL1108	11kV FDR GUJRANWALA SOCIETY	TI-VIK065A-1	400	RESIDENTIAL		Functional	100%	111	0.23			
66 kV BODELLA - 1 GRID	WBDL1108	11kV FDR GUJRANWALA SOCIETY	TI-VIK065A-2	630	RESIDENTIAL		Functional	100%	184	0.23			
66 kV BODELLA - 1 GRID	WBDL1108	11kV FDR GUJRANWALA SOCIETY	TI-VIK100A-2	630	RESIDENTIAL		Functional	100%	226	0.11			
66 kV BODELLA - 1 GRID	WBDL1108	11kV FDR GUJRANWALA SOCIETY	TI-VIK031A-1	630	RESIDENTIAL		Functional	100%	0	0.10			
66 kV BODELLA - 1 GRID	WBDL1108	11kV FDR GUJRANWALA SOCIETY	TI-VIK031A-2	400	RESIDENTIAL		Functional	100%	167	0.08			
66 kV BODELLA - 2 GRID	WBDL2114	11kV FDR RMU NO- 1	TI-VIK040A-2	630	RESIDENTIAL		Functional	100%	330	0.52	3.60	0.04	1.22%
66 kV BODELLA - 2 GRID	WBDL2115	11kV FDR F2BLK I/D SSTN VKP	TG-VIK037A-1	630	RESIDENTIAL		Functional	100%	440	0.49			
66 kV BODELLA - 1 GRID	WBDL1125	11kV FDR H2BLOCK STORE I/D VKP	TI-VIK039A-1	990	RESIDENTIAL	AMR	Functional	100%	341	0.37			
66 kV BODELLA - 2 GRID	WBDL2114	11kV FDR RMU NO- 1	TG-VIK036A-1	990	RESIDENTIAL		Functional	100%	487	0.37			
66 kV BODELLA - 2 GRID	WBDL2115	11kV FDR F2BLK I/D SSTN VKP	TG-VIK038A-1	630	RESIDENTIAL	AMR	Functional	100%	167	0.36			
66 kV BODELLA - 1 GRID	WBDL1125	11kV FDR H2BLOCK STORE I/D VKP	TI-VIK039A-2	990	RESIDENTIAL	AMR	Functional	100%	258	0.33			
66 kV BODELLA - 2 GRID	WBDL2107	11kV FDR GANGOTRI SOCIETY	TG-VIK035A-1	630	COMMERCIAL		Functional	100%	168	0.33			
66 kV BODELLA - 2 GRID	WBDL2128	11kV FDR SBI SOCIETY	TP-VIK126A-1	630	RESIDENTIAL		Functional	100%	403	0.30			
66 kV BODELLA - 2 GRID	WBDL2114	11kV FDR RMU NO- 1	TG-VIK036A-2	630	RESIDENTIAL		Functional	100%	0	0.26			
66 kV BODELLA - 2 GRID	WBDL2128	11kV FDR SBI SOCIETY	TG-VIK126A-2	630	RESIDENTIAL		Functional	100%	0	0.17			
66 kV BODELLA - 2 GRID	WBDL2114	11kV FDR RMU NO- 1	TI-VIK040A-1	400	RESIDENTIAL		Functional	100%	213	0.15			
66 kV HASTSAL GRID	WHAST101	11kV FDR DAAL MILL	TG-HAS017A-2	990	RESIDENTIAL	AMR	Functional	100%	609	1.08	6.02	0.12	1.89%
66 kV HASTSAL GRID	WHAST101	11kV FDR DAAL MILL	TG-HAS017A-1	990	RESIDENTIAL	AMR	Functional	100%	249	0.98			
66 kV HASTSAL GRID	WHAST116	11kV FDR HASTAL SOCIETY	TK-HAS014A-1	990	RESIDENTIAL		Functional	100%	358	0.80			
66 kV HASTSAL GRID	WHAST116	11kV FDR HASTAL SOCIETY	TK-HAS014A-2	990	RESIDENTIAL		Functional	100%	1165	0.80			
66 kV BODELLA - 2 GRID	WBDL2101	11kV FDR PANCHWATI SOCIETY 1	TP-HAS019A-1	990	RESIDENTIAL		Functional	100%	580	0.71			
66 kV BODELLA - 2 GRID	WBDL2110	11kV FDR HASTAL SOCIETY	TP-HAS155A-1	630	RESIDENTIAL		Functional	100%	334	0.52			
66 kV HASTSAL GRID	WHAST101	11kV FDR DAAL MILL	TG-HAS158A-1	630	RESIDENTIAL		Functional	100%	5	0.37			
66 kV HASTSAL GRID	WHAST101	11kV FDR DAAL MILL	TP-HAS018A-1	630	RESIDENTIAL		Functional	100%	143	0.34			
66 kV HASTSAL GRID	WHAST101	11kV FDR DAAL MILL	TG-HAS158A-2	630	RESIDENTIAL		Functional	100%	14	0.30			
66 kV HASTSAL GRID	WHAST116	11kV FDR HASTAL SOCIETY	TP-HAS014A-3	400	RESIDENTIAL		Functional	100%	0	0.23			

66 kV BODELLA - 2 GRID	WBDL2109	11kV FDR UJJAWAL APPT	TG-VIK041A-1	990	RESIDENTIAL		Functional	100%	598	0.66	4.75	0.45	8.57%
66 kV BODELLA - 1 GRID	WBDL1108	11kV FDR GUJRANWALA SOCIETY	TP-VIK122A-1	990	RESIDENTIAL		Functional	100%	525	0.65			
66 kV BODELLA - 1 GRID	WBDL1125	11kV FDR H2BLOCK STORE I/D VKP	TI-VIK060A-1	990	RESIDENTIAL		Functional	100%	1257	0.63			
66 kV BODELLA - 1 GRID	WBDL1111	11kV FDR HIMGIRI LIONS	TG-VIK056A-1	630	RESIDENTIAL		Functional	100%	294	0.42			
66 kV BODELLA - 1 GRID	WBDL1111	11kV FDR HIMGIRI LIONS	TI-VIK062A-2	630	RESIDENTIAL		Functional	100%	139	0.38			
66 kV BODELLA - 1 GRID	WBDL1111	11kV FDR HIMGIRI LIONS	TP-VIK128A-1	400	RESIDENTIAL		Functional	100%	183	0.37			
66 kV BODELLA - 2 GRID	WBDL2109	11kV FDR UJJAWAL APPT	TG-VIK055A-1	630	RESIDENTIAL		Functional	100%	563	0.37			
66 kV BODELLA - 1 GRID	WBDL1125	11kV FDR H2BLOCK STORE I/D VKP	TI-VIK060A-2	630	RESIDENTIAL		Functional	100%	309	0.35			
66 kV BODELLA - 2 GRID	WBDL2109	11kV FDR UJJAWAL APPT	TP-VIK057A-1	630	RESIDENTIAL		Functional	100%	274	0.34			
66 kV BODELLA - 1 GRID	WBDL1111	11kV FDR HIMGIRI LIONS	TG-VIK063A-1	630	RESIDENTIAL		Functional	100%	84	0.26			
66 kV BODELLA - 1 GRID	WBDL1111	11kV FDR HIMGIRI LIONS	TI-VIK062A-1	630	RESIDENTIAL		Functional	100%	401	0.25			
66 kV BODELLA - 2 GRID	WBDL2109	11kV FDR UJJAWAL APPT	TP-VIK058A-1	400	RESIDENTIAL		Functional	100%	218	0.21			
66 kV BODELLA - 1 GRID	WBDL1111	11kV FDR HIMGIRI LIONS	TI-VIK061A-2	630	RESIDENTIAL		Functional	100%	103	0.12			
66 kV BODELLA - 1 GRID	WBDL1111	11kV FDR HIMGIRI LIONS	TI-VIK061A-1	630	RESIDENTIAL		Functional	100%	98	0.09			
66 kV BODELLA - 1 GRID	WBDL1112	11kV FDR KESHOPUR	TI-VIK092A-1	630	RESIDENTIAL		Functional	100%	187	0.09			
66 kV BODELLA - 2 GRID	WBDL2136	11kV FDR A-BLK MANDIR WALA VIKASPURI	TI-VIK049A-1	630	RESIDENTIAL		Functional	100%	160	0.22	1.03	0.07	6.21%
66 kV BODELLA - 2 GRID	WBDL2136	11kV FDR A-BLK MANDIR WALA VIKASPURI	TI-VIK019A-2	990	RESIDENTIAL		Functional	100%	199	0.15			
66 kV BODELLA - 2 GRID	WBDL2118	11kV FDR LOK VIHAR VKP	TI-VIK080A-1	630	RESIDENTIAL		Functional	100%	96	0.11			
66 kV BODELLA - 2 GRID	WBDL2118	11kV FDR LOK VIHAR VKP	TI-VIK079A-2	630	RESIDENTIAL		Functional	100%	116	0.10			
66 kV BODELLA - 2 GRID	WBDL2118	11kV FDR LOK VIHAR VKP	TI-VIK079A-1	630	RESIDENTIAL		Functional	100%	67	0.10			
66 kV BODELLA - 2 GRID	WBDL2118	11kV FDR LOK VIHAR VKP	TI-VIK080A-2	630	RESIDENTIAL		Functional	100%	54	0.09			
66 kV BODELLA - 2 GRID	WBDL2118	11kV FDR LOK VIHAR VKP	TI-VIK059A-1	630	RESIDENTIAL		Functional	100%	74	0.08			
66 kV BODELLA - 2 GRID	WBDL2118	11kV FDR LOK VIHAR VKP	TI-VIK112A-2	400	RESIDENTIAL		Functional	100%	0	0.07			
66 kV BODELLA - 2 GRID	WBDL2118	11kV FDR LOK VIHAR VKP	TI-VIK078A-2	400	RESIDENTIAL		Functional	100%	60	0.07			
66 kV BODELLA - 2 GRID	WBDL2118	11kV FDR LOK VIHAR VKP	TI-VIK078A-1	400	RESIDENTIAL	AMR	Functional	100%	45	0.05			
66 kV BODELLA - 2 GRID	WBDL2136	11kV FDR A-BLK MANDIR WALA VIKASPURI	TI-VIK019A-1	990	RESIDENTIAL		Functional	100%	155	0.04			
66 kV BODELLA - 2 GRID	WBDL2118	11kV FDR LOK VIHAR VKP	TI-VIK112A-1	400	RESIDENTIAL		Functional	100%	99	0.04			
66 kV BODELLA - 2 GRID	WBDL2115	11kV FDR F2BLK I/D SSTN VKP	TI-VIK123A-1	630	RESIDENTIAL		Functional	100%	154	0.18			
66 kV BODELLA - 2 GRID	WBDL2107	11kV FDR GANGOTRI SOCIETY	TI-VIK071A-1	990	RESIDENTIAL		Functional	100%	0	0.16			
66 kV BODELLA - 2 GRID	WBDL2107	11kV FDR GANGOTRI SOCIETY	TI-VIK071A-2	630	RESIDENTIAL		Functional	100%	219	0.15			
66 kV BODELLA - 2 GRID	WBDL2115	11kV FDR F2BLK I/D SSTN VKP	TI-VIK087A-1	400	RESIDENTIAL		Functional	100%	88	0.14			
66 kV BODELLA - 2 GRID	WBDL2115	11kV FDR F2BLK I/D SSTN VKP	TI-VIK087A-2	630	RESIDENTIAL		Functional	100%	83	0.09			
66 kV BODELLA - 2 GRID	WBDL2115	11kV FDR F2BLK I/D SSTN VKP	TI-VIK086A-2	630	RESIDENTIAL		Functional	100%	122	0.08			
66 kV BODELLA - 2 GRID	WBDL2115	11kV FDR F2BLK I/D SSTN VKP	TI-VIK086A-1	400	RESIDENTIAL		Functional	100%	43	0.07			
66 kV BODELLA - 2 GRID	WBDL2108	11kV FDR ARUNODYA S/S NO.-1	TI-VIK034A-1	400	RESIDENTIAL		Functional	100%	87	0.07			
66 kV BODELLA - 2 GRID	WBDL2108	11kV FDR ARUNODYA S/S NO.-1	TI-VIK034A-2	400	RESIDENTIAL		Functional	100%	90	0.06			
66 kV BODELLA - 2 GRID	WBDL2115	11kV FDR F2BLK I/D SSTN VKP	TI-VIK085A-1	400	RESIDENTIAL		Functional	100%	66	0.06			
66 kV BODELLA - 2 GRID	WBDL2108	11kV FDR ARUNODYA S/S NO.-1	TP-VIK110A-1	400	RESIDENTIAL		Functional	100%	34	0.05			
66 kV BODELLA - 2 GRID	WBDL2108	11kV FDR ARUNODYA S/S NO.-1	TI-VIK001A-1	990	COMMERCIAL		Functional	100%	93	0.13	1.49	0.03	2.03%
66 kV BODELLA - 2 GRID	WBDL2112	11kV FDR NAVYUG APPTT21	TI-VIK102A-2	400	COMMERCIAL		Functional	100%	88	0.12			
66 kV BODELLA - 2 GRID	WBDL2108	11kV FDR ARUNODYA S/S NO.-1	TI-VIK089A-1	630	COMMERCIAL		Functional	100%	119	0.12			
66 kV BODELLA - 2 GRID	WBDL2108	11kV FDR ARUNODYA S/S NO.-1	TI-VIK001A-2	990	COMMERCIAL		Functional	100%	127	0.12			
66 kV BODELLA - 2 GRID	WBDL2108	11kV FDR ARUNODYA S/S NO.-1	TI-VIK022A-1	400	COMMERCIAL		Functional	100%	125	0.11			
66 kV BODELLA - 2 GRID	WBDL2112	11kV FDR NAVYUG APPTT21	TI-VIK091A-1	990	COMMERCIAL		Functional	100%	141	0.10			
66 kV BODELLA - 2 GRID	WBDL2112	11kV FDR NAVYUG APPTT21	TI-VIK102A-1	400	COMMERCIAL		Functional	100%	60	0.10			
66 kV BODELLA - 2 GRID	WBDL2108	11kV FDR ARUNODYA S/S NO.-1	TI-VIK121A-1	630	COMMERCIAL		Functional	100%	69	0.10			
66 kV BODELLA - 2 GRID	WBDL2108	11kV FDR ARUNODYA S/S NO.-1	TI-VIK121A-2	630	COMMERCIAL		Functional	100%	72	0.09			
66 kV BODELLA - 2 GRID	WBDL2108	11kV FDR ARUNODYA S/S NO.-1	TI-VIK023A-1	400	COMMERCIAL		Functional	100%	31	0.09			
66 kV BODELLA - 2 GRID	WBDL2108	11kV FDR ARUNODYA S/S NO.-1	TI-VIK088A-1	630	COMMERCIAL		Functional	100%	56	0.09			
66 kV BODELLA - 2 GRID	WBDL2112	11kV FDR NAVYUG APPTT21	TI-VIK090A-1	400	COMMERCIAL		Functional	100%	0	0.08			

66 kV BODELLA - 2 GRID	WBDL2112	11kV FDR NAVYUG APPTTz1	TI-VIK091A-2	400	COMMERCIAL		Functional	100%	0	0.08			
66 kV BODELLA - 2 GRID	WBDL2108	11kV FDR ARUNODYA S/S NO.-1	TI-VIK023A-2	400	COMMERCIAL		Functional	100%	111	0.07			
66 kV BODELLA - 2 GRID	WBDL2112	11kV FDR NAVYUG APPTTz1	TI-VIK090A-2	400	COMMERCIAL		Functional	100%	151	0.06			
66 kV BODELLA - 2 GRID	WBDL2108	11kV FDR ARUNODYA S/S NO.-1	TI-VIK088A-2	630	COMMERCIAL		Functional	100%	74	0.06			
66 kV BODELLA - 2 GRID	WBDL2108	11kV FDR ARUNODYA S/S NO.-1	TP-VIK146A-1	400	RESIDENTIAL		Functional	100%	1	0.01			
66 kV BODELLA - 2 GRID	WBDL2116	11kV FDR DGz3 VKP	TI-VIK048A-2	630	RESIDENTIAL		Functional	100%	349	0.23	2.45	0.05	2.13%
66 kV BODELLA - 2 GRID	WBDL2118	11kV FDR LOK VIHAR VKP	TI-VIK050A-2	400	RESIDENTIAL	AMR	Functional	100%	217	0.20			
66 kV BODELLA - 2 GRID	WBDL2116	11kV FDR DGz3 VKP	TI-VIK048A-1	630	RESIDENTIAL	AMR	Functional	100%	100	0.15			
66 kV BODELLA - 2 GRID	WBDL2107	11kV FDR GANGOTRI SOCIETY	TI-VIK084A-1	630	RESIDENTIAL		Functional	100%	102	0.14			
66 kV BODELLA - 2 GRID	WBDL2112	11kV FDR NAVYUG APPTTz1	TI-VIK021A-2	630	RESIDENTIAL		Functional	100%	94	0.13			
66 kV BODELLA - 2 GRID	WBDL2107	11kV FDR GANGOTRI SOCIETY	TI-VIK020A-2	630	RESIDENTIAL	AMR	Functional	100%	64	0.12			
66 kV BODELLA - 2 GRID	WBDL2118	11kV FDR LOK VIHAR VKP	TI-VIK083A-1	990	RESIDENTIAL		Functional	100%	76	0.11			
66 kV BODELLA - 2 GRID	WBDL2116	11kV FDR DGz3 VKP	TI-VIK114A-1	400	RESIDENTIAL		Functional	100%	50	0.10			
66 kV BODELLA - 2 GRID	WBDL2118	11kV FDR LOK VIHAR VKP	TI-VIK051A-1	400	RESIDENTIAL	AMR	Functional	100%	117	0.10			
66 kV BODELLA - 2 GRID	WBDL2118	11kV FDR LOK VIHAR VKP	TI-VIK050A-1	400	RESIDENTIAL	AMR	Functional	100%	19	0.09			
66 kV BODELLA - 2 GRID	WBDL2116	11kV FDR DGz3 VKP	TI-VIK109A-2	630	RESIDENTIAL		Functional	100%	60	0.09			
66 kV BODELLA - 2 GRID	WBDL2107	11kV FDR GANGOTRI SOCIETY	TI-VIK113A-1	400	RESIDENTIAL		Functional	100%	143	0.09			
66 kV BODELLA - 2 GRID	WBDL2118	11kV FDR LOK VIHAR VKP	TI-VIK083A-2	630	RESIDENTIAL		Functional	100%	98	0.09			
66 kV BODELLA - 2 GRID	WBDL2107	11kV FDR GANGOTRI SOCIETY	TI-VIK072A-2	630	RESIDENTIAL		Functional	100%	94	0.09			
66 kV BODELLA - 2 GRID	WBDL2116	11kV FDR DGz3 VKP	TI-VIK114A-2	400	RESIDENTIAL		Functional	100%	84	0.08			
66 kV BODELLA - 2 GRID	WBDL2107	11kV FDR GANGOTRI SOCIETY	TI-VIK082A-1	400	RESIDENTIAL		Functional	100%	114	0.08			
66 kV BODELLA - 2 GRID	WBDL2107	11kV FDR GANGOTRI SOCIETY	TI-VIK020A-1	630	RESIDENTIAL	AMR	Functional	100%	128	0.08			
66 kV BODELLA - 2 GRID	WBDL2107	11kV FDR GANGOTRI SOCIETY	TI-VIK082A-2	400	RESIDENTIAL		Functional	100%	10	0.08			
66 kV BODELLA - 2 GRID	WBDL2118	11kV FDR LOK VIHAR VKP	TI-VIK051A-2	400	RESIDENTIAL	AMR	Functional	100%	42	0.08			
66 kV BODELLA - 2 GRID	WBDL2116	11kV FDR DGz3 VKP	TI-VIK109A-1	990	RESIDENTIAL		Functional	100%	64	0.07			
66 kV BODELLA - 2 GRID	WBDL2112	11kV FDR NAVYUG APPTTz1	TI-VIK115A-1	400	RESIDENTIAL		Functional	100%	69	0.07			
66 kV BODELLA - 2 GRID	WBDL2107	11kV FDR GANGOTRI SOCIETY	TI-VIK072A-1	630	COMMERCIAL		Functional	100%	45	0.06			
66 kV BODELLA - 2 GRID	WBDL2107	11kV FDR GANGOTRI SOCIETY	TI-VIK074A-2	400	RESIDENTIAL	AMR	Functional	100%	80	0.05			
66 kV BODELLA - 2 GRID	WBDL2112	11kV FDR NAVYUG APPTTz1	TI-VIK021A-1	630	RESIDENTIAL		Functional	100%	85	0.05			
66 kV BODELLA - 2 GRID	WBDL2107	11kV FDR GANGOTRI SOCIETY	TI-VIK074A-1	400	RESIDENTIAL		Functional	100%	0	0.05			
66 kV BODELLA - 2 GRID	WBDL2104	11kV FDR 1616 JANTA HASTSAL	TP-VIK137A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV BODELLA - 1 GRID	WBDL1105	11kV FDR DzBLOCKzVKP	TG-VIK004A-1	990	RESIDENTIAL		Functional	100%	868	0.85	7.09	0.32	4.30%
33 kV D.C.JANAKPURI GRID	WJKPG102	11kV FDR RMU NO-3 SIMENCE SSTN BODELLA(VKP)	TI-VIK013A-1	990	RESIDENTIAL		Functional	100%	261	0.68			
33 kV D.C.JANAKPURI GRID	WJKPG102	11kV FDR RMU NO-3 SIMENCE SSTN BODELLA(VKP)	TI-VIK012A-1	630	RESIDENTIAL		Functional	100%	408	0.66			
66 kV BODELLA - 2 GRID	WBDL2136	11kV FDR A-BLK MANDIR WALA VIKASPURI	TI-VIK017A-1	990	RESIDENTIAL		Functional	100%	190	0.65			
66 kV BODELLA - 1 GRID	WBDL1105	11kV FDR DzBLOCKzVKP	TG-VIK014A-1	990	RESIDENTIAL		Functional	100%	246	0.58			
66 kV BODELLA - 2 GRID	WBDL2136	11kV FDR A-BLK MANDIR WALA VIKASPURI	TI-VIK017A-2	990	RESIDENTIAL		Functional	100%	456	0.55			
66 kV BODELLA - 1 GRID	WBDL1115	11kV FDR NEW KRISHNA PARK OH	TG-VIK006A-1	990	RESIDENTIAL		Functional	100%	174	0.48			
66 kV BODELLA - 1 GRID	WBDL1115	11kV FDR NEW KRISHNA PARK OH	TI-VIK093A-2	990	RESIDENTIAL		Functional	100%	46	0.45			
66 kV BODELLA - 1 GRID	WBDL1115	11kV FDR NEW KRISHNA PARK OH	TI-VIK093A-1	630	RESIDENTIAL		Functional	100%	382	0.38			
66 kV BODELLA - 1 GRID	WBDL1105	11kV FDR DzBLOCKzVKP	TG-VIK003A-1	630	RESIDENTIAL		Functional	100%	216	0.33			
33 kV D.C.JANAKPURI GRID	WJKPG102	11kV FDR RMU NO-3 SIMENCE SSTN BODELLA(VKP)	TI-VIK012A-2	630	RESIDENTIAL		Functional	100%	558	0.30			
66 kV BODELLA - 1 GRID	WBDL1124	11kV FDR RELIANCE MALL A-BLK VIKASPURI	TI-VIK018A-1	630	RESIDENTIAL		Functional	100%	242	0.30			
66 kV BODELLA - 1 GRID	WBDL1105	11kV FDR DzBLOCKzVKP	TG-VIK005A-1	630	RESIDENTIAL		Functional	100%	507	0.29			
66 kV BODELLA - 2 GRID	WBDL2136	11kV FDR A-BLK MANDIR WALA VIKASPURI	TI-VIK015A-2	630	RESIDENTIAL		Functional	100%	291	0.26			
66 kV BODELLA - 2 GRID	WBDL2136	11kV FDR A-BLK MANDIR WALA VIKASPURI	TI-VIK016A-1	630	RESIDENTIAL		Functional	100%	146	0.25			
66 kV BODELLA - 2 GRID	WBDL2136	11kV FDR A-BLK MANDIR WALA VIKASPURI	TI-VIK015A-1	630	RESIDENTIAL		Functional	100%	154	0.21			
66 kV BODELLA - 2 GRID	WBDL2136	11kV FDR A-BLK MANDIR WALA VIKASPURI	TI-VIK016A-2	630	RESIDENTIAL		Functional	100%	218	0.19			
66 kV HASTSAL GRID	WHAST115	11kV FDR RAJHANS VIHAR	TG-HAS049A-1	990	RESIDENTIAL		Functional	100%	1248	1.17	8.98	0.24	2.59%

66 kV HASTSAL GRID	WHAST129	11kV FDR PRESS ENCLAVE	650SHR-HVD028A-	3000	RESIDENTIAL		Functional	100%	1576	1.02			
66 kV BODELLA - 2 GRID	WBDL2143	11kV FDR RAJDHANI GALIWALA	VP-HVD047A-1	2125	RESIDENTIAL		Functional	100%	2689	0.97			
66 kV BODELLA - 2 GRID	WBDL2110	11kV FDR HASTAL SOCIETY	TG-HAS048A-1	990	RESIDENTIAL		Functional	100%	1338	0.92			
66 kV BODELLA - 2 GRID	WBDL2143	11kV FDR RAJDHANI GALIWALA	TP-HAS070A-1	990	RESIDENTIAL		Functional	100%	742	0.92			
66 kV BODELLA - 2 GRID	WBDL2125	11kV FDR DDA TC-1	VP-HVD057A-1	1325	RESIDENTIAL		Functional	100%	988	0.62			
66kV NILOTHI GRID	WNILO121	11kV FDR VIKRANT CHOWK	650SHR-HAS187A-	990	MIXED		Functional	100%	0	0.62			
66 kV BODELLA - 2 GRID	WBDL2135	11kV FDR RP WORLD SCHOOL	TG-HAS163A-1	630	COMMERCIAL		Functional	100%	441	0.61			
66 kV BODELLA - 2 GRID	WBDL2110	11kV FDR HASTAL SOCIETY	TG-HAS107A-1	990	RESIDENTIAL		Functional	100%	1475	0.53			
66 kV BODELLA - 2 GRID	WBDL2125	11kV FDR DDA TC-1	TP-HAS051A-1	400	RESIDENTIAL		Functional	100%	687	0.50			
66 kV BODELLA - 2 GRID	WBDL2135	11kV FDR RP WORLD SCHOOL	650SHR-HAS186A-	630	MIXED		Functional	100%	0	0.48			
66 kV HASTSAL GRID	WHAST129	11kV FDR PRESS ENCLAVE	VP-HVD033A-1	600	RESIDENTIAL		Functional	100%	465	0.24			
66 kV BODELLA - 2 GRID	WBDL2110	11kV FDR HASTAL SOCIETY	TP-HAS033A-2	990	RESIDENTIAL		Functional	100%	0	0.23			
66 kV BODELLA - 2 GRID	WBDL2110	11kV FDR HASTAL SOCIETY	TP-HAS033A-1	400	RESIDENTIAL		Functional	100%	2130	0.14			
66 kV BODELLA - 2 GRID	WBDL2135	11kV FDR RP WORLD SCHOOL	650SHR-HAS181A-	630	RESIDENTIAL		Functional	100%	69	0.13			
66 kV BODELLA - 2 GRID	WBDL2143	11kV FDR RAJDHANI GALIWALA	650SHR-HAS177A-	400	RESIDENTIAL		Functional	100%	50	0.05			
66 kV HASTSAL GRID	WHAST129	11kV FDR PRESS ENCLAVE	TG-HAS167A-2	630	RESIDENTIAL		Functional	100%	0	0.04			
66 kV HASTSAL GRID	WHAST129	11kV FDR PRESS ENCLAVE	TG-HAS167A-1	630	RESIDENTIAL		Functional	100%	67	0.01			
66 kV BODELLA - 2 GRID	WBDL2110	11kV FDR HASTAL SOCIETY	TP-HAS143A-1	100	RESIDENTIAL		Functional	100%	12	0.00			
66 kV HASTSAL GRID	WHAST115	11kV FDR RAJHANS VIHAR	TP-HAS103A-1	100	RESIDENTIAL		Functional	100%	8	0.00			
66 kV BODELLA - 2 GRID	WBDL2114	11kV FDR RMU NO- 1	TI-VIK053A-1	630	RESIDENTIAL		Functional	100%	141	0.18	1.49	0.01	0.87%
66 kV BODELLA - 2 GRID	WBDL2128	11kV FDR SBI SOCIETY	TI-VIK024A-2	630	RESIDENTIAL		Functional	100%	86	0.16			
66 kV BODELLA - 2 GRID	WBDL2114	11kV FDR RMU NO- 1	TI-VIK104A-1	630	RESIDENTIAL		Functional	100%	116	0.14			
66 kV BODELLA - 2 GRID	WBDL2109	11kV FDR UJJAWAL APPT	TI-VIK105A-1	630	RESIDENTIAL		Functional	100%	107	0.12			
66 kV BODELLA - 2 GRID	WBDL2128	11kV FDR SBI SOCIETY	TI-VIK106A-1	630	RESIDENTIAL		Functional	100%	86	0.11			
66 kV BODELLA - 2 GRID	WBDL2128	11kV FDR SBI SOCIETY	TI-VIK024A-1	990	RESIDENTIAL		Functional	100%	94	0.10			
66 kV BODELLA - 2 GRID	WBDL2128	11kV FDR SBI SOCIETY	TI-VIK103A-1	400	RESIDENTIAL		Functional	100%	83	0.09			
66 kV BODELLA - 2 GRID	WBDL2109	11kV FDR UJJAWAL APPT	TI-VIK108A-1	400	RESIDENTIAL		Functional	100%	95	0.09			
66 kV BODELLA - 2 GRID	WBDL2114	11kV FDR RMU NO- 1	TI-VIK053A-2	630	RESIDENTIAL		Functional	100%	79	0.09			
66 kV BODELLA - 2 GRID	WBDL2128	11kV FDR SBI SOCIETY	TI-VIK107A-2	630	MIXED		Functional	100%	10	0.09			
66 kV BODELLA - 2 GRID	WBDL2128	11kV FDR SBI SOCIETY	TI-VIK106A-2	630	RESIDENTIAL		Functional	100%	55	0.07			
66 kV BODELLA - 2 GRID	WBDL2109	11kV FDR UJJAWAL APPT	TI-VIK002A-2	400	RESIDENTIAL		Functional	100%	18	0.07			
66 kV BODELLA - 2 GRID	WBDL2128	11kV FDR SBI SOCIETY	TI-VIK107A-1	630	RESIDENTIAL		Functional	100%	101	0.06			
66 kV BODELLA - 2 GRID	WBDL2128	11kV FDR SBI SOCIETY	TP-VIK130A-1	400	RESIDENTIAL		Functional	100%	7	0.05			
66 kV BODELLA - 2 GRID	WBDL2109	11kV FDR UJJAWAL APPT	TI-VIK002A-1	400	RESIDENTIAL		Functional	100%	82	0.05			
66 kV BODELLA - 2 GRID	WBDL2105	11kV STR 400KVA STATION TRANSFORMER	VP-WTC003A-1	400	RESIDENTIAL		Functional	100%	1	0.02			
66 kV BODELLA - 1 GRID	WBDL1103	11kV FDR KANGRA NIKETAN	TG-VIK095A-1	990	RESIDENTIAL		Functional	100%	653	0.61	2.86	0.29	9.09%
66 kV BODELLA - 1 GRID	WBDL1103	11kV FDR KANGRA NIKETAN	TI-VIK097A-2	990	RESIDENTIAL		Functional	100%	50	0.61			
66 kV BODELLA - 1 GRID	WBDL1103	11kV FDR KANGRA NIKETAN	TI-VIK096A-1	990	RESIDENTIAL		Functional	100%	346	0.47			
33 kV D.C.JANAKPURI GRID	WJKPG102	11kV FDR RMU NO-3 SIMENCE SSTN BODELLA(VKP)	TG-VIK011A-1	630	RESIDENTIAL		Functional	100%	347	0.37			
33 kV D.C.JANAKPURI GRID	WJKPG105	11kV FDR NEW KRISHNA PARK (VKP)	TI-VIK094A-1	400	RESIDENTIAL		Functional	100%	72	0.31			
66 kV BODELLA - 1 GRID	WBDL1103	11kV FDR KANGRA NIKETAN	TI-VIK098A-2	630	RESIDENTIAL		Functional	100%	438	0.27			
66 kV BODELLA - 1 GRID	WBDL1103	11kV FDR KANGRA NIKETAN	TI-VIK098A-1	630	RESIDENTIAL		Functional	100%	154	0.19			
33 kV D.C.JANAKPURI GRID	WJKPG105	11kV FDR NEW KRISHNA PARK (VKP)	TI-VIK094A-2	630	RESIDENTIAL		Functional	100%	458	0.15			
66 kV BODELLA - 1 GRID	WBDL1103	11kV FDR KANGRA NIKETAN	TI-VIK097A-1	630	RESIDENTIAL		Functional	100%	316	0.15			
66 kV BODELLA - 2 GRID	WBDL2143	11kV FDR RAJDHANI GALIWALA	650CBV-HAS150A-	100	RESIDENTIAL		Functional	100%	2	0.01			
66 kV HASTSAL GRID	WHAST108	11kV FDR HASTAL VIHAR	TP-HVD074A-1	1400	RESIDENTIAL		Functional	100%	571	0.83	5.04	0.08	1.54%
66 kV HASTSAL GRID	WHAST108	11kV FDR HASTAL VIHAR	TI-HAS015A-2	990	RESIDENTIAL		Functional	100%	0	0.70			
66 kV HASTSAL GRID	WHAST108	11kV FDR HASTAL VIHAR	VP-HVD072A-1	2200	RESIDENTIAL		Functional	100%	1806	0.68			
66 kV HASTSAL GRID	WHAST102	11kV FDR KALI BASTI	TP-HAS086A-1	630	RESIDENTIAL		Functional	100%	934	0.57			

66 KV HASTSAL GRID	WHAST108	11KV FDR HASTAL VIHAR	TI-HAS015A-1	630	RESIDENTIAL	Functional	100%	1349	0.48			
66 KV HASTSAL GRID	WHAST102	11KV FDR KALI BASTI	650LHL-HAS099B-	990	MIXED	Functional	100%	0	0.42			
66 KV HASTSAL GRID	WHAST131	11KV FDR VIDHYA VIHAR	VP-HVD016A-1	800	RESIDENTIAL	Functional	100%	1586	0.41			
66 KV HASTSAL GRID	WHAST116	11KV FDR HASTAL SOCIETY	650LHL-HAS188A-	630	MIXED	Functional	100%	0	0.37			
66 KV HASTSAL GRID	WHAST102	11KV FDR KALI BASTI	TP-HAS099A-1	990	RESIDENTIAL	Functional	100%	967	0.34			
66 KV HASTSAL GRID	WHAST131	11KV FDR VIDHYA VIHAR	TP-HAS098A-1	400	RESIDENTIAL	Functional	100%	35	0.16			
66 KV HASTSAL GRID	WHAST131	11KV FDR VIDHYA VIHAR	VP-HVD071A-1	250	RESIDENTIAL	Functional	100%	174	0.14			
66 KV BODELLA - 2 GRID	WBDL2128	11KV FDR SBI SOCIETY	TI-VIK066A-2	630	RESIDENTIAL	Functional	100%	1	0.33	0.59	0.01	0.96%
66 KV BODELLA - 2 GRID	WBDL2128	11KV FDR SBI SOCIETY	TG-VIK119A-2	630	RESIDENTIAL	Functional	100%	20	0.10			
66 KV BODELLA - 2 GRID	WBDL2128	11KV FDR SBI SOCIETY	TG-VIK081A-2	400	RESIDENTIAL	Functional	100%	25	0.08			
66 KV BODELLA - 2 GRID	WBDL2128	11KV FDR SBI SOCIETY	TI-VIK066A-1	630	RESIDENTIAL	Functional	100%	68	0.04			
66 KV BODELLA - 2 GRID	WBDL2128	11KV FDR SBI SOCIETY	TG-VIK119A-1	630	RESIDENTIAL	Functional	100%	23	0.03			
66 KV BODELLA - 2 GRID	WBDL2128	11KV FDR SBI SOCIETY	TG-VIK081A-1	630	RESIDENTIAL	Functional	100%	20	0.02			
66 KV BODELLA - 2 GRID	WBDL2128	11KV FDR SBI SOCIETY	TG-VIK143A-1	630	RESIDENTIAL	Functional	100%	0	0.00			
66 KV BODELLA - 2 GRID	WBDL2128	11KV FDR SBI SOCIETY	TG-VIK143A-2	630	RESIDENTIAL	Functional	100%	0	0.00			
66 KV BODELLA - 2 GRID	WBDL2117	11KV FDR SHIVA ENCLAVE	VP-HVD059A-1	5050	RESIDENTIAL	Functional	100%	2633	1.83	6.08	0.04	0.65%
66 KV HASTSAL GRID	WHAST115	11KV FDR RAJHANS VIHAR	VP-HVD056A-1	2950	RESIDENTIAL	Functional	100%	325	1.06			
66 KV BODELLA - 2 GRID	WBDL2117	11KV FDR SHIVA ENCLAVE	VP-HVD046A-1	1900	RESIDENTIAL	Functional	100%	2136	0.87			
66 KV BODELLA - 2 GRID	WBDL2125	11KV FDR DDA TC-1	VP-HVD060A-1	2500	RESIDENTIAL	Functional	100%	1154	0.74			
66 KV BODELLA - 2 GRID	WBDL2102	11KV FDR HOLY CONVENT(SCHOOL VIKASPURI)	VP-HVD058A-1	1325	RESIDENTIAL	Functional	100%	924	0.60			
66 KV BODELLA - 2 GRID	WBDL2102	11KV FDR HOLY CONVENT(SCHOOL VIKASPURI)	TP-HAS074A-1	990	RESIDENTIAL	Functional	100%	1936	0.43			
66 KV BODELLA - 2 GRID	WBDL2102	11KV FDR HOLY CONVENT(SCHOOL VIKASPURI)	TG-HAS074A-2	630	RESIDENTIAL	Functional	100%	0	0.35			
66 KV BODELLA - 2 GRID	WBDL2102	11KV FDR HOLY CONVENT(SCHOOL VIKASPURI)	VP-HVD055A-1	1450	RESIDENTIAL	Functional	100%	139	0.24			
66 KV BODELLA - 2 GRID	WBDL2129	11KV FDR SHIV VIHAR	VP-HVD048A-1	2450	RESIDENTIAL	Functional	100%	775	0.87	4.30	0.29	6.26%
66 KV HASTSAL GRID	WHAST115	11KV FDR RAJHANS VIHAR	TG-HAS111A-1	630	RESIDENTIAL	Functional	100%	586	0.81			
66 KV HASTSAL GRID	WHAST115	11KV FDR RAJHANS VIHAR	TP-HAS142A-1	630	RESIDENTIAL	Functional	100%	775	0.77			
66 KV BODELLA - 2 GRID	WBDL2122	11KV FDR DDA TRAN. CAMP&2 HASTSAL	TG-HAS168A-1	630	RESIDENTIAL	Functional	100%	729	0.42			
66 KV BODELLA - 2 GRID	WBDL2122	11KV FDR DDA TRAN. CAMP&2 HASTSAL	TG-HAS141A-1	630	RESIDENTIAL	Functional	100%	918	0.39			
66 KV BODELLA - 2 GRID	WBDL2122	11KV FDR DDA TRAN. CAMP&2 HASTSAL	650SHR-HAS176A-	630	RESIDENTIAL	Functional	100%	1190	0.27			
66 KV BODELLA - 2 GRID	WBDL2122	11KV FDR DDA TRAN. CAMP&2 HASTSAL	VP-HVD038A-1	1925	RESIDENTIAL	Functional	100%	68	0.27			
66 KV HASTSAL GRID	WHAST115	11KV FDR RAJHANS VIHAR	650SHR-HAS142A-	400	INDUSTRIAL	Functional	100%	0	0.22			
66 KV BODELLA - 2 GRID	WBDL2122	11KV FDR DDA TRAN. CAMP&2 HASTSAL	VP-HVD077A-1	2025	RESIDENTIAL	Functional	100%	2329	0.22			
66 KV BODELLA - 2 GRID	WBDL2122	11KV FDR DDA TRAN. CAMP&2 HASTSAL	TG-HAS168A-2	630	RESIDENTIAL	Functional	100%	0	0.20			
66 KV BODELLA - 2 GRID	WBDL2122	11KV FDR DDA TRAN. CAMP&2 HASTSAL	TP-HAS141A-2	630	RESIDENTIAL	Functional	100%	0	0.13			
66 KV BODELLA - 2 GRID	WBDL2122	11KV FDR DDA TRAN. CAMP&2 HASTSAL	TP-HAS147A-1	100	RESIDENTIAL	Functional	100%	8	0.01			
66 KV BODELLA - 1 GRID	WBDL1101	11KV FDR VIKAS KUNJ	TI-VIK009A-1	990	RESIDENTIAL	Functional	100%	253	0.37	1.76	0.05	2.81%
66 KV BODELLA - 1 GRID	WBDL1101	11KV FDR VIKAS KUNJ	TI-VIK010A-1	990	RESIDENTIAL	Functional	100%	175	0.22			
66 KV BODELLA - 1 GRID	WBDL1103	11KV FDR KANGRA NIKETAN	TI-VIK099A-1	630	RESIDENTIAL	Functional	100%	115	0.20			
66 KV BODELLA - 1 GRID	WBDL1101	11KV FDR VIKAS KUNJ	TI-VIK009A-2	630	RESIDENTIAL	Functional	100%	107	0.19			
66 KV BODELLA - 1 GRID	WBDL1101	11KV FDR VIKAS KUNJ	TI-VIK010A-2	630	RESIDENTIAL	Functional	100%	90	0.18			
66 KV BODELLA - 1 GRID	WBDL1103	11KV FDR KANGRA NIKETAN	TI-VIK099A-2	630	RESIDENTIAL	Functional	100%	169	0.15			
66 KV BODELLA - 1 GRID	WBDL1101	11KV FDR VIKAS KUNJ	TI-VIK007A-1	630	RESIDENTIAL	Functional	100%	118	0.14			
66 KV BODELLA - 1 GRID	WBDL1101	11KV FDR VIKAS KUNJ	TI-VIK007A-2	630	RESIDENTIAL	Functional	100%	51	0.13			
66 KV BODELLA - 1 GRID	WBDL1101	11KV FDR VIKAS KUNJ	TI-VIK008A-2	630	RESIDENTIAL	Functional	100%	154	0.10			
66 KV BODELLA - 1 GRID	WBDL1101	11KV FDR VIKAS KUNJ	TI-VIK008A-1	630	RESIDENTIAL	Functional	100%	188	0.10			
66 KV BODELLA - 1 GRID	WBDL1104	11KV STR 100KVA STATION TRANSFORMER	VP-WTC002A-1	100	RESIDENTIAL	Functional	100%	1	0.04			
66KV NILOTHI GRID	WNILO121	11KV FDR VIKRANT CHOWK	VP-HVD064A-1	3225	RESIDENTIAL	Functional	100%	2255	1.71	8.34	0.90	9.76%
66 KV BODELLA - 2 GRID	WBDL2135	11KV FDR RP WORLD SCHOOL	TP-HAS076A-1	990	RESIDENTIAL	Functional	100%	4853	1.40			
66 KV BODELLA - 2 GRID	WBDL2135	11KV FDR RP WORLD SCHOOL	VP-HVD053A-1	2200	RESIDENTIAL	Functional	100%	995	0.90			
66 KV BODELLA - 2 GRID	WBDL2111	11KV FDR LIG&2 HASTAL	650SHR-HVD076A-	2425	RESIDENTIAL	Functional	100%	0	0.80			

66 KV BODELLA - 2 GRID	WBDL2111	11KV FDR LIG22 HASTAL	VP-HVD040A-1	3075	RESIDENTIAL		Functional	100%	4011	0.69			
66 KV BODELLA - 2 GRID	WBDL2104	11KV FDR 1616 JANTA HASTSAL	TG-HAS057A-2	990	RESIDENTIAL		Functional	100%	1948	0.69			
66 KV BODELLA - 2 GRID	WBDL2135	11KV FDR RP WORLD SCHOOL	TP-HAS046A-1	630	RESIDENTIAL		Functional	100%	2235	0.66			
66 KV BODELLA - 2 GRID	WBDL2104	11KV FDR 1616 JANTA HASTSAL	TG-HAS169A-2	630	RESIDENTIAL		Functional	100%	0	0.65			
66 KV BODELLA - 2 GRID	WBDL2104	11KV FDR 1616 JANTA HASTSAL	TG-HAS169A-1	630	RESIDENTIAL		Functional	100%	494	0.59			
66 KV BODELLA - 2 GRID	WBDL2104	11KV FDR 1616-JANTA FLATS HASTSAL	TG-HAS057B-2	990	RESIDENTIAL		Functional	100%	0	0.48			
66 KV BODELLA - 2 GRID	WBDL2135	11KV FDR RP WORLD SCHOOL	650SHR-HVD083A	1050	RESIDENTIAL		Functional	100%	0	0.37			
66 KV BODELLA - 2 GRID	WBDL2104	11KV FDR 1616 JANTA HASTSAL	TG-HAS057A-1	630	RESIDENTIAL		Functional	100%	0	0.28			
66KV NILOTHI GRID	WNILO121	11KV FDR VIKRANT CHOWK	TP-HAS166A-2	100	COMMERCIAL		Functional	100%	7	0.02			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP125	11KV FDR ADARSH NAGR	651CPE-CNK017A	990	RESIDENTIAL	AMR	Functional	100%	0	0.79	1.58	0.11	6.27%
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP105	11KV FDR R & S BLOCK CHANAKYA PLACE	TI-CNK007A-1	630	RESIDENTIAL	AMR	Functional	100%	757	0.59			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP125	11KV FDR ADARSH NAGR	TP-CNK017A-1	1600	RESIDENTIAL		Functional	100%	1195	0.31			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP127	11KV FDR VISHU VIHAR	TI-BND018A-2	1600	RESIDENTIAL	AMR	Functional	100%	1007	1.02	3.43	0.21	5.78%
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP127	11KV FDR VISHU VIHAR	TI-BND015A-1	990	RESIDENTIAL	AMR	Functional	100%	941	0.72			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP108	11KV FDR O-BLOCK UTTAM NAGAR	TI-BND021A-2	1600	RESIDENTIAL	AMR	Functional	100%	440	0.68			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP108	11KV FDR O-BLOCK UTTAM NAGAR	TI-BND021A-1	990	RESIDENTIAL	AMR	Functional	100%	2385	0.61			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP127	11KV FDR VISHU VIHAR	TI-BND018A-1	990	RESIDENTIAL	AMR	Functional	100%	477	0.60			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP104	11KV FDR S/S. NO-5	TI-BND013A-1	1600	RESIDENTIAL	AMR	Functional	100%	1977	0.94	4.12	0.36	8.03%
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP104	11KV FDR S/S. NO-5	TI-BND013A-2	990	RESIDENTIAL	AMR	Functional	100%	627	0.84			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP121	11KV FDR NAIWALA PKT-4,BINDAPUR	TI-BND019A-1	990	RESIDENTIAL		Functional	100%	738	0.83			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP123	11KV FDR B-BLOCK BINDAPUR	TI-BND026A-1	630	RESIDENTIAL	AMR	Functional	100%	1110	0.65			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP121	11KV FDR NAIWALA PKT-4,BINDAPUR	TI-BND020A-1	630	RESIDENTIAL	AMR	Functional	100%	1068	0.39			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP121	11KV FDR NAIWALA PKT-4,BINDAPUR	TI-BND023A-1	630	RESIDENTIAL		Functional	100%	1012	0.36			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP121	11KV FDR NAIWALA PKT-4,BINDAPUR	TI-BND023A-2	630	RESIDENTIAL		Functional	100%	0	0.31			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP116	11KV FDR BINDAPUR SCHOOL WALA	TI-BND020A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.16			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP116	11KV FDR BINDAPUR SCHOOL WALA	TG-BND004A-1	990	RESIDENTIAL		Functional	100%	244	0.96	2.94	0.29	9.04%
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP127	11KV FDR VISHU VIHAR	TG-BND014A-1	990	RESIDENTIAL	AMR	Functional	100%	1002	0.81			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP116	11KV FDR BINDAPUR SCHOOL WALA	TK-BND003A-2	990	RESIDENTIAL		Functional	100%	448	0.51			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP127	11KV FDR VISHU VIHAR	UG-HVD001A-1	750	RESIDENTIAL		Functional	100%	850	0.46			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP116	11KV FDR BINDAPUR SCHOOL WALA	651BPR-BND028A	990	MIXED		Functional	100%	0	0.27			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP116	11KV FDR BINDAPUR SCHOOL WALA	TK-BND003A-1	630	RESIDENTIAL		Functional	100%	327	0.23			
66 KV PANKHA ROAD GRID	WPNRD105	11KV FDR CHANAKYA PLACE	TP-CNK013A-1	990	RESIDENTIAL	AMR	Functional	100%	1198	1.34	11.73	0.07	0.59%
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP121	11KV FDR CHANAKYA PLACE I/D SSTN NO-1	UG-HVD004A-1	1050	RESIDENTIAL		Functional	100%	614	1.26			
66 KV PANKHA ROAD GRID	WPNRD105	11KV FDR CHANAKYA PLACE	TI-CNK009A-1	990	COMMERCIAL	AMR	Functional	100%	1425	1.13			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP121	11KV FDR CHANAKYA PLACE I/D SSTN NO-1	TI-CNK008A-1	990	COMMERCIAL	AMR	Functional	100%	1188	0.80			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP105	11KV FDR R & S BLOCK CHANAKYA PLACE	UG-HVD003A-1	1325	RESIDENTIAL		Functional	100%	518	0.74			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP121	11KV FDR CHANAKYA PLACE I/D SSTN NO-1	TI-CNK011A-1	990	COMMERCIAL	AMR	Functional	100%	1487	0.67			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP121	11KV FDR CHANAKYA PLACE I/D SSTN NO-1	TI-CNK011A-2	990	COMMERCIAL	AMR	Functional	100%	605	0.67			
66 KV PANKHA ROAD GRID	WPNRD105	11KV FDR CHANAKYA PLACE	651CPE-CNK024A	990	MIXED		Functional	100%	0	0.67			
66 KV PANKHA ROAD GRID	WPNRD105	11KV FDR CHANAKYA PLACE	TI-CNK010A-2	990	COMMERCIAL	AMR	Functional	100%	671	0.60			
66 KV PANKHA ROAD GRID	WPNRD105	11KV FDR CHANAKYA PLACE	TI-CNK010A-1	990	COMMERCIAL	AMR	Functional	100%	258	0.54			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP105	11KV FDR R & S BLOCK CHANAKYA PLACE	TG-CNK014A-1	630	RESIDENTIAL		Functional	100%	1684	0.53			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP121	11KV FDR CHANAKYA PLACE I/D SSTN NO-1	UG-HVD009A-1	1275	RESIDENTIAL		Functional	100%	106	0.50			
66 KV PANKHA ROAD GRID	WPNRD105	11KV FDR CHANAKYA PLACE	TP-CNK022A-1	400	RESIDENTIAL	AMR	Functional	100%	369	0.42			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP121	11KV FDR CHANAKYA PLACE I/D SSTN NO-1	TI-CNK008A-2	990	COMMERCIAL	AMR	Functional	100%	1135	0.41			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP105	11KV FDR R & S BLOCK CHANAKYA PLACE	TP-HVD003A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.40			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP125	11KV FDR ADARSH NAGR	651CPE-CNK030A	630	MIXED		Functional	100%	0	0.37			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP121	11KV FDR CHANAKYA PLACE I/D SSTN NO-1	TI-CNK012A-1	630	RESIDENTIAL	AMR	Functional	100%	255	0.34			
66 KV PANKHA ROAD GRID	WPNRD105	11KV FDR CHANAKYA PLACE	TP-CNK024A-1	990	RESIDENTIAL		Functional	100%	623	0.17			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP105	11KV FDR R & S BLOCK CHANAKYA PLACE	651CPE-CNK014A	990	MIXED		Functional	100%	0	0.17			

66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP121	11KV FDR CHANAKYA PLACE I/D SSTN NO-1	TP-CNK028A-1	250	RESIDENTIAL		Functional	100%	1	0.05	3.26	0.28	7.88%			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP123	11KV FDR B-BLOCK BINDAPUR	651BPR-BND027A	630	MIXED		Functional	100%	0	0.47						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP604	11KV FDR DDA S/STN NO-1 BINDAPUR	TG-BND012A-1	990	RESIDENTIAL	AMR	Functional	100%	322	0.45						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP113	11KV FDR S/S NO.-4	TI-BND007A-1	630	RESIDENTIAL	AMR	Functional	100%	435	0.39						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP113	11KV FDR S/S NO.-4	TI-BND008A-1	630	RESIDENTIAL	AMR	Functional	100%	560	0.37						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP604	11KV FDR DDA S/STN NO-1 BINDAPUR	TI-BND005A-1	630	RESIDENTIAL	AMR	Functional	100%	402	0.30						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP113	11KV FDR S/S NO.-4	TI-BND006A-1	630	RESIDENTIAL	AMR	Functional	100%	715	0.29						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP104	11KV FDR S/S. NO-5	TI-BND009A-1	630	RESIDENTIAL	AMR	Functional	100%	523	0.23						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP104	11KV FDR S/S. NO-5	651BPR-BND009A	400	MIXED		Functional	100%	0	0.23						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP104	11KV FDR S/S. NO-5	TP-BND011A-1	400	RESIDENTIAL	AMR	Functional	100%	483	0.19						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP113	11KV FDR S/S NO.-4	651BPR-BND008A	630	MIXED		Functional	100%	0	0.17						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP113	11KV FDR S/S NO.-4	651BPR-BND006A	630	MIXED	AMR	Functional	100%	0	0.15						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP104	11KV FDR S/S. NO-5	651BPR-BND011A	400	MIXED		Functional	100%	0	0.15						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP104	11KV FDR S/S. NO-5	TI-BND010A-1	400	RESIDENTIAL	AMR	Functional	100%	1058	0.12						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP120	11KV STR 400KVA STATION TRANSFORMER	UG-WTC001A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.03						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP106	11KV FDR VISHWAS PARK	TP-BND024A-1	250	RESIDENTIAL	AMR	Functional	100%	1	0.00						
66 KV PANKHA ROAD GRID	WPNRD106	11KV FDR MAHINDRA PARK	TI-CNK018A-2	1600	RESIDENTIAL	AMR	Functional	100%	1062	1.10				9.10	0.63	6.52%
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP125	11KV FDR ADARSH NAGR	TI-CNK015A-3	1600	RESIDENTIAL		Functional	100%	1741	0.97						
66 KV PANKHA ROAD GRID	WPNRD109	11KV FDR UTTAM NAGAR	TI-CNK019A-1	990	RESIDENTIAL	AMR	Functional	100%	366	0.94						
66 KV PANKHA ROAD GRID	WPNRD106	11KV FDR MAHINDRA PARK	TI-CNK018A-1	990	RESIDENTIAL	AMR	Functional	100%	414	0.84						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP608	11KV FDR JEEWAN PARK SOM BAZAR ROAD	TG-CNK015A-4	990	COMMERCIAL		Functional	100%	0	0.73						
66 KV PANKHA ROAD GRID	WPNRD107	11KV FDR JEEVAN PARK	TP-CNK016A-2	990	RESIDENTIAL	AMR	Functional	100%	2200	0.66						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP608	11KV FDR JEEWAN PARK SOM BAZAR ROAD	TI-CNK015A-1	990	RESIDENTIAL		Functional	100%	0	0.66						
66 KV PANKHA ROAD GRID	WPNRD109	11KV FDR UTTAM NAGAR	TG-CNK027A-1	990	RESIDENTIAL	AMR	Functional	100%	385	0.61						
66 KV PANKHA ROAD GRID	WPNRD107	11KV FDR JEEVAN PARK	TP-CNK025A-1	990	RESIDENTIAL		Functional	100%	607	0.60						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP608	11KV FDR JEEWAN PARK SOM BAZAR ROAD	TI-CNK015A-2	990	RESIDENTIAL		Functional	100%	3506	0.54						
66 KV PANKHA ROAD GRID	WPNRD109	11KV FDR UTTAM NAGAR	TP-CNK023A-1	990	RESIDENTIAL	AMR	Functional	100%	885	0.47						
66 KV PANKHA ROAD GRID	WPNRD109	11KV FDR UTTAM NAGAR	TI-CNK019A-2	990	RESIDENTIAL	AMR	Functional	100%	1150	0.45						
66 KV PANKHA ROAD GRID	WPNRD109	11KV FDR UTTAM NAGAR	TG-CNK027A-2	990	RESIDENTIAL	AMR	Functional	100%	0	0.44						
66 KV PANKHA ROAD GRID	WPNRD107	11KV FDR JEEVAN PARK	TP-CNK016A-1	990	RESIDENTIAL	AMR	Functional	100%	0	0.40						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP125	11KV FDR ADARSH NAGR	TI-CNK005A-1	990	RESIDENTIAL	AMR	Functional	100%	916	0.32						
66 KV PANKHA ROAD GRID	WPNRD109	11KV FDR UTTAM NAGAR	651CPE-HVD008A	100	MIXED		Functional	100%	0	0.01						
66 KV PANKHA ROAD GRID	WPNRD109	11KV FDR UTTAM NAGAR	UG-HVD008A-1	525	RESIDENTIAL		Functional	100%	409	0.00						
66 KV PANKHA ROAD GRID	WPNRD123	11KV FDR EAST UTTAM NAGAR	TK-MLP015A-1	1600	RESIDENTIAL	AMR	Functional	100%	0	1.32	11.82	0.28	2.31%			
33 kv D.C.JANAKPURI GRID	WJKPG103	11KV FDR MILAP NGR	TG-MLP020A-1	1600	RESIDENTIAL		Functional	100%	1470	1.26						
33 kv D.C.JANAKPURI GRID	WJKPG103	11KV FDR MILAP NGR	TI-MLP004A-2	1600	RESIDENTIAL	AMR	Functional	100%	1521	1.20						
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP132	11KV FDR O-BLOCK GEETA ENCLAVE	TI-MLP004A-1	1500	RESIDENTIAL	AMR	Functional	100%	487	1.09						
66 KV PANKHA ROAD GRID	WPNRD123	11KV FDR EAST UTTAM NAGAR	551MNR-MLP015A	1600	RESIDENTIAL	AMR	Functional	100%	984	1.05						
66 KV BODELLA - 1 GRID	WBDL1109	11KV FDR B-BLOCK UTTAM NAGAR U/G	TI-MLP017A-2	990	RESIDENTIAL	AMR	Functional	100%	122	1.00						
66 KV BODELLA - 1 GRID	WBDL1109	11KV FDR B-BLOCK UTTAM NAGAR U/G	TI-MLP017A-1	990	RESIDENTIAL		Functional	100%	3227	0.76						
66 KV HASTSAL GRID	WHAST127	11KV FDR J.J COLONY MACHHI MKT	TG-MLP013A-1	1600	RESIDENTIAL		Functional	100%	1141	0.75						
66 KV HASTSAL GRID	WHAST113	11KV FDR RAM DUTT ENCLAVE	TG-MLP012A-2	990	RESIDENTIAL	AMR	Functional	100%	0	0.63						
66 KV PANKHA ROAD GRID	WPNRD123	11KV FDR EAST UTTAM NAGAR	TK-MLP015A-2	1600	RESIDENTIAL	AMR	Functional	100%	1772	0.54						
66 KV HASTSAL GRID	WHAST113	11KV FDR RAM DUTT ENCLAVE	TG-MLP012A-1	990	RESIDENTIAL		Functional	100%	1551	0.54						
33 kv D.C.JANAKPURI GRID	WJKPG103	11KV FDR MILAP NGR	TG-MLP004A-3	630	RESIDENTIAL	AMR	Functional	100%	0	0.45						
66 KV HASTSAL GRID	WHAST127	11KV FDR J.J COLONY MACHHI MKT	TG-MLP013A-2	990	RESIDENTIAL		Functional	100%	419	0.43						
66 KV HASTSAL GRID	WHAST127	11KV FDR J.J COLONY MACHHI MKT	TG-MLP013B-2	990	RESIDENTIAL		Functional	100%	0	0.42						
66 KV BODELLA - 1 GRID	WBDL1109	11KV FDR B-BLOCK UTTAM NAGAR U/G	TI-MLP017A-3	990	RESIDENTIAL	AMR	Functional	100%	0	0.41						
66 KV PANKHA ROAD GRID	WPNRD109	11KV FDR UTTAM NAGAR	TP-MLP021A-1	400	RESIDENTIAL		Functional	100%	204	0.26						

66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP117	11KV FDR PRAJAPATI I/D S/S NO.-1	551MNR-MLP009A	990	RESIDENTIAL	AMR	Functional	100%	2326	0.95	2.72	0.01	0.53%
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP117	11KV FDR PRAJAPATI I/D S/S NO.-1	TG-MLP006A-1	990	RESIDENTIAL	AMR	Functional	100%	1460	0.77			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP117	11KV FDR PRAJAPATI I/D S/S NO.-1	TP-MLP026A-1	990	RESIDENTIAL	AMR	Functional	100%	37	0.60			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP117	11KV FDR PRAJAPATI I/D S/S NO.-1	TG-MLP006A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.42			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP128	11KV FDR SANJAY ENCLAVE	TG-BND016A-1	1600	RESIDENTIAL	AMR	Functional	100%	2072	1.24	5.23	0.35	6.21%
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP106	11KV FDR VISHWAS PARK	UG-HVD002A-2	1600	RESIDENTIAL		Functional	100%	1023	1.21			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP604	11KV FDR DDA S/STN NO-1 BINDAPUR	TG-BND017A-1	1600	RESIDENTIAL	AMR	Functional	100%	1376	1.05			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP108	11KV FDR O-BLOCK UTTAM NAGAR	TI-BND022A-1	990	RESIDENTIAL		Functional	100%	2361	0.76			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP108	11KV FDR O-BLOCK UTTAM NAGAR	TI-BND022A-2	990	RESIDENTIAL	AMR	Functional	100%	0	0.70			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP128	11KV FDR SANJAY ENCLAVE	TG-BND025A-1	1600	RESIDENTIAL	AMR	Functional	100%	1310	0.49			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP106	11KV FDR VISHWAS PARK	UG-HVD002A-1	1000	RESIDENTIAL		Functional	100%	0	0.13			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA130	11KV FDR KIRAN GARDEN	TI-MLP002A-1	1600	RESIDENTIAL		Functional	100%	0	1.47	18.90	0.20	1.03%
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA108	11KV FDR KIRAN GARDEN PM (NEAR MAHINDRU HOSPITAL)	TI-MLP003A-1	1600	RESIDENTIAL		Functional	100%	1868	1.32			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP112	11KV FDR IJL BLOCK UTTAM NAGAR	TG-MLP018A-1	1600	RESIDENTIAL		Functional	100%	1352	1.23			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA140	11KV FDR TIKONA PARK	TK-MLP007A-1	1600	RESIDENTIAL	AMR	Functional	100%	1194	1.22			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP112	11KV FDR IJL BLOCK UTTAM NAGAR	TG-MLP005A-1	1600	RESIDENTIAL		Functional	100%	1599	1.21			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP106	11KV FDR VISHWAS PARK	TG-MLP010A-1	1600	RESIDENTIAL		Functional	100%	1597	1.13			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP112	11KV FDR IJL BLOCK UTTAM NAGAR	TG-MLP019A-1	1500	RESIDENTIAL		Functional	100%	1267	1.02			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA108	11KV FDR KIRAN GARDEN PM (NEAR MAHINDRU HOSPITAL)	TG-MLP029A-1	1600	RESIDENTIAL	AMR	Functional	100%	358	0.97			
66 KV PANKHA ROAD GRID	WPNRD124	11KV FDR PREM NAGAR	TG-MLP011A-1	1600	RESIDENTIAL		Functional	100%	874	0.89			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA140	11KV FDR TIKONA PARK	TK-MLP007A-2	1600	RESIDENTIAL	AMR	Functional	100%	1012	0.87			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA106	11KV FDR DVBMP,TA-BLOCK	TG-MLP022A-1	1600	RESIDENTIAL	AMR	Functional	100%	1209	0.80			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA106	11KV FDR DVBMP,TA-BLOCK	TG-MLP033A-1	990	RESIDENTIAL		Functional	100%	455	0.78			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP606	11KV FDR T&B BLOCK KHADDAY WALA	TI-MLP016A-1	990	RESIDENTIAL	AMR	Functional	100%	151	0.76			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP606	11KV FDR T&B BLOCK KHADDAY WALA	TI-MLP016A-2	990	RESIDENTIAL	AMR	Functional	100%	2712	0.76			
66 KV HASTSAL GRID	WHAST114	11KV FDR B-BOCK UTTAM NAGAR (OLD)	TG-MLP019A-2	1500	RESIDENTIAL		Functional	100%	933	0.73			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA106	11KV FDR DVBMP,TA-BLOCK	TP-MLP027A-1	990	RESIDENTIAL	AMR	Functional	100%	852	0.66			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA140	11KV FDR TIKONA PARK	TI-MLP008A-1	990	RESIDENTIAL		Functional	100%	1360	0.60			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA140	11KV FDR TIKONA PARK	TI-MLP008A-2	990	RESIDENTIAL		Functional	100%	1144	0.58			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA130	11KV FDR KIRAN GARDEN	TI-MLP002A-2	990	RESIDENTIAL		Functional	100%	2783	0.51			
66 KV PANKHA ROAD GRID	WPNRD109	11KV FDR UTTAM NAGAR	TG-MLP032A-1	630	COMMERCIAL		Functional	100%	295	0.44			
66 KV PANKHA ROAD GRID	WPNRD124	11KV FDR PREM NAGAR	UG-HVD005A-1	475	RESIDENTIAL		Functional	100%	273	0.38			
66 KV PANKHA ROAD GRID	WPNRD124	11KV FDR PREM NAGAR	TI-MLP008A-4	630	RESIDENTIAL		Functional	100%	0	0.37			
66 KV PANKHA ROAD GRID	WPNRD124	11KV FDR PREM NAGAR	551MNR-HVD005A	400	RESIDENTIAL	AMR	Functional	100%	0	0.29			
66 KV PANKHA ROAD GRID	WPNRD124	11KV FDR PREM NAGAR	TI-MLP008A-3	400	RESIDENTIAL		Functional	100%	0	0.08			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP605	11KV FDR VANI VIHAR (PARK)	TG-MLP024A-1	1600	RESIDENTIAL		Functional	100%	77	1.43	6.46	0.34	5.07%
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP132	11KV FDR O-BLOCK GEETA ENCLAVE	TI-MLP025A-1	1600	RESIDENTIAL		Functional	100%	2084	1.08			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP132	11KV FDR O-BLOCK GEETA ENCLAVE	TI-MLP014A-1	1600	RESIDENTIAL	AMR	Functional	100%	2013	1.08			
66 KV HASTSAL GRID	WHAST110	11KV FDR B-BLOCK UTTAM NAGAR	TK-MLP023A-1	990	RESIDENTIAL		Functional	100%	1199	0.93			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP108	11KV FDR O-BLOCK UTTAM NAGAR	551MNR-MLP014A	1600	RESIDENTIAL	AMR	Functional	100%	0	0.88			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP605	11KV FDR VANI VIHAR (PARK)	TG-MLP024A-2	1600	RESIDENTIAL		Functional	100%	2070	0.75			
66 KV HASTSAL GRID	WHAST110	11KV FDR B-BLOCK UTTAM NAGAR	TK-MLP023A-2	990	RESIDENTIAL		Functional	100%	312	0.65			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA139	11KV FDR NAWADA	652AVR-HVD013A-	2050	RESIDENTIAL		Functional	100%	1504	1.17	5.35	0.66	10.93%
66/11 KV G-1 DWARKA GRID	WG1PN610	11KV FDR JAILDAR ENC	652AVR-AVH001A-	1600	RESIDENTIAL	AMR	Functional	100%	1074	0.72			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA112	11KV FDR NSIT NO-2	TP-AVH021A-1	1600	RESIDENTIAL		Functional	100%	1336	0.66			
66 KV HASTSAL GRID	WHAST119	11KV FDR A-BLOCK MANDIRWALA	652AVR-AVH040A-	630	RESIDENTIAL		Functional	100%	571	0.64			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA139	11KV FDR NAWADA	652AVR-HVD008A-	950	RESIDENTIAL		Functional	100%	688	0.58			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA112	11KV FDR NSIT NO-2	TP-AVH021A-2	1600	RESIDENTIAL		Functional	100%	304	0.58			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA146	11KV FDR C AND D BLK MOHAN GARDEN RMU NO-2	652AVR-HVD005A-	500	RESIDENTIAL		Functional	100%	244	0.42			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA139	11KV FDR NAWADA	652AVR-AVH051A-	990	RESIDENTIAL		Functional	100%	57	0.39			

66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD104	11KV FDR RANA ENCLAVE+RAMA PARK	652AVR-SPK070A-	990	MIXED		Functional	100%	0	0.23			
66 KV HASTSAL GRID	WHAST119	11KV FDR A-BLOCK MANDIRWALA	652AVR-AVH049A-	630	RESIDENTIAL		Functional	100%	0	0.21			
66 KV HASTSAL GRID	WHAST126	11KV FDR RAHUL COWK	652AVR-VGN051A-	990	MIXED		Functional	100%	0	0.19			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD104	11KV FDR RANA ENCLAVE+RAMA PARK	652AVR-SPK069A-	400	MIXED		Functional	100%	0	0.18			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA139	11KV FDR NAWADA	652AVR-AVH022A-	100	RESIDENTIAL	AMR	Functional	100%	2	0.04			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA139	11KV FDR NAWADA	652AVR-AVH043A-	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA146	11KV FDR C AND D BLK MOHAN GARDEN RMU NO-2	652AVR-HVD004A-	2500	RESIDENTIAL		Functional	100%	2182	1.37	6.98	0.42	5.70%
66/11 KV G-1 DWARKA GRID	WG1PN610	11KV FDR JAILDAR ENC	652AVR-HVD010A-	1425	RESIDENTIAL		Functional	100%	2639	1.05			
66/11 KV G-1 DWARKA GRID	WG1PN610	11KV FDR JAILDAR ENC	652AVR-HVD014A-	1750	RESIDENTIAL		Functional	100%	1462	0.87			
66 KV HASTSAL GRID	WHAST119	11KV FDR A-BLOCK MANDIRWALA	652AVR-AVH018A-	990	RESIDENTIAL	AMR	Functional	100%	37	0.66			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA144	11KV FDR RMU NO.-1 (M-BLOCK SHYAM PARK)	652AVR-AVH050A-	990	RESIDENTIAL		Functional	100%	150	0.56			
66 KV HASTSAL GRID	WHAST107	11KV FDR JHANDA CHOWK OM VIHAR	652AVR-AVH039A-	990	MIXED		Functional	100%	0	0.50			
66 KV HASTSAL GRID	WHAST125	11KV FDR NAWADA USTREWALA	652AVR-AVH054A-	990	MIXED		Functional	100%	0	0.50			
66 KV HASTSAL GRID	WHAST107	11KV FDR JHANDA CHOWK OM VIHAR	652AVR-AVH039A-	630	RESIDENTIAL		Functional	100%	201	0.42			
66 KV HASTSAL GRID	WHAST119	11KV FDR A-BLOCK MANDIRWALA	652AVR-AVH018A-	990	RESIDENTIAL	AMR	Functional	100%	22	0.39			
66/11 KV G-1 DWARKA GRID	WG1PN610	11KV FDR JAILDAR ENC	TG-AVH017A-2	630	RESIDENTIAL		Functional	100%	0	0.37			
66/11 KV G-1 DWARKA GRID	WG1PN610	11KV FDR JAILDAR ENC	652AVR-AVH044A-	990	RESIDENTIAL	AMR	Functional	100%	516	0.35			
66 KV HASTSAL GRID	WHAST119	11KV FDR A-BLOCK MANDIRWALA	652AVR-AVH052A-	990	MIXED		Functional	100%	0	0.31			
66/11 KV G-1 DWARKA GRID	WG1PN610	11KV FDR JAILDAR ENC	TP-AVH017A-1	400	RESIDENTIAL	AMR	Functional	100%	34	0.03			
66/11 KV G-1 DWARKA GRID	WG1PN610	11KV FDR JAILDAR ENC	652AVR-AVH015A-	100	RESIDENTIAL	AMR	Functional	100%	12	0.01			
66/11 KV G-1 DWARKA GRID	WG1PN610	11KV FDR JAILDAR ENC	652AVR-HVD009A-	1500	RESIDENTIAL		Functional	100%	1530	0.00			
66 KV HASTSAL GRID	WHAST125	11KV FDR NAWADA USTREWALA	652AVR-AVH005A-	990	RESIDENTIAL	AMR	Functional	100%	1128	0.94	5.49	0.18	3.15%
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA144	11KV FDR RMU NO.-1 (M-BLOCK SHYAM PARK)	652AVR-AVH002A-	990	RESIDENTIAL		Functional	100%	551	0.89			
66 KV HASTSAL GRID	WHAST107	11KV FDR JHANDA CHOWK OM VIHAR	652AVR-AVH003A-	990	RESIDENTIAL		Functional	100%	550	0.79			
66 KV DELHI JAL BOARD NAJAFGARH GRID	WDJBD122	11KV FDR GANDHI CHOWK	652AVR-SPK068A-	990	MIXED		Functional	100%	0	0.68			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA144	11KV FDR RMU NO.-1 (M-BLOCK SHYAM PARK)	652AVR-AVH011A-	990	RESIDENTIAL	AMR	Functional	100%	1133	0.65			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA144	11KV FDR RMU NO.-1 (M-BLOCK SHYAM PARK)	652AVR-AVH011A-	990	RESIDENTIAL	AMR	Functional	100%	0	0.50			
66 KV HASTSAL GRID	WHAST125	11KV FDR NAWADA USTREWALA	652AVR-AVH004A-	990	RESIDENTIAL	AMR	Functional	100%	497	0.44			
66KV NILOTHI GRID	WNILO116	11KV FDR UGR MOHAN GARDEN	652AVR-VGN049A-	990	MIXED		Functional	100%	0	0.29			
66 KV HASTSAL GRID	WHAST107	11KV FDR JHANDA CHOWK OM VIHAR	652AVR-AVH003A-	630	RESIDENTIAL		Functional	100%	470	0.28			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA144	11KV FDR RMU NO.-1 (M-BLOCK SHYAM PARK)	652AVR-HVD003A-	525	RESIDENTIAL		Functional	100%	183	0.21			
66 KV HASTSAL GRID	WHAST119	11KV FDR A-BLOCK MANDIRWALA	652AVR-AVH009A-	990	RESIDENTIAL		Functional	100%	1553	1.04	8.49	0.64	7.01%
66 KV HASTSAL GRID	WHAST124	11KV FDR MINI BUS STAND	652AVR-HVD001A-	1375	RESIDENTIAL		Functional	100%	1139	0.84			
66 KV HASTSAL GRID	WHAST130	11KV FDR OM VIHAR PHASE-2	652AVR-AVH007A-	630	RESIDENTIAL		Functional	100%	396	0.70			
66 KV HASTSAL GRID	WHAST125	11KV FDR NAWADA USTREWALA	652AVR-AVH008A-	990	RESIDENTIAL	AMR	Functional	100%	788	0.68			
66 KV HASTSAL GRID	WHAST124	11KV FDR MINI BUS STAND	652AVR-HVD006A-	1000	RESIDENTIAL		Functional	100%	1047	0.65			
66 KV HASTSAL GRID	WHAST124	11KV FDR MINI BUS STAND	652AVR-AVH014A-	990	RESIDENTIAL		Functional	100%	1634	0.61			
66 KV HASTSAL GRID	WHAST125	11KV FDR NAWADA USTREWALA	652AVR-AVH006A-	1600	RESIDENTIAL		Functional	100%	1223	0.51			
66 KV HASTSAL GRID	WHAST124	11KV FDR MINI BUS STAND	652AVR-AVH014A-	630	RESIDENTIAL		Functional	100%	882	0.50			
66 KV HASTSAL GRID	WHAST124	11KV FDR MINI BUS STAND	TP-AVH019A-1	400	RESIDENTIAL		Functional	100%	197	0.48			
66 KV HASTSAL GRID	WHAST130	11KV FDR OM VIHAR PHASE-2	652AVR-HVD002A-	1750	RESIDENTIAL		Functional	100%	1431	0.47			
66 KV HASTSAL GRID	WHAST125	11KV FDR NAWADA USTREWALA	652AVR-AVH006A-	990	RESIDENTIAL		Functional	100%	0	0.46			
66 KV HASTSAL GRID	WHAST130	11KV FDR OM VIHAR PHASE-2	652AVR-HVD015A-	1425	RESIDENTIAL		Functional	100%	0	0.45			
66 KV HASTSAL GRID	WHAST130	11KV FDR OM VIHAR PHASE-2	TG-AVH007A-2	630	RESIDENTIAL		Functional	100%	0	0.36			
66 KV HASTSAL GRID	WHAST112	11KV FEEDER OM VIHAR PHASE-5	TG-AVH009A-2	630	RESIDENTIAL	AMR	Functional	100%	179	0.36			
66 KV HASTSAL GRID	WHAST125	11KV FDR NAWADA USTREWALA	652AVR-AVH045A-	990	RESIDENTIAL	AMR	Functional	100%	172	0.35			
66 KV HASTSAL GRID	WHAST130	11KV FDR OM VIHAR PHASE-2	652AVR-AVH048A-	630	RESIDENTIAL	AMR	Functional	100%	689	0.29			
66 KV HASTSAL GRID	WHAST119	11KV FDR A-BLOCK MANDIRWALA	652AVR-AVH053A-	990	MIXED		Functional	100%	0	0.19			
66 KV HASTSAL GRID	WHAST130	11KV FDR OM VIHAR PHASE-2	652AVR-AVH048A-	630	RESIDENTIAL	AMR	Functional	100%	22	0.14			

66 kv HASTSAL GRID	WHAST124	11kv FDR MINI BUS STAND	652AVR-AVH016A	100	RESIDENTIAL	AMR	Functional	100%	39	0.04	5.66	0.06	1.11%
66 kv HASTSAL GRID	WHAST107	11kv FDR JHANDA CHOWK OM VIHAR	652AVR-AVH012A	1600	RESIDENTIAL	AMR	Functional	100%	3853	1.28			
66 kv HASTSAL GRID	WHAST112	11kv FEEDER OM VIHAR PHASE-5	652AVR-AVH013A	1600	RESIDENTIAL	AMR	Functional	100%	0	1.10			
66 kv HASTSAL GRID	WHAST112	11kv FEEDER OM VIHAR PHASE-5	652AVR-AVH013A	990	RESIDENTIAL	AMR	Functional	100%	2310	0.84			
66 kv HASTSAL GRID	WHAST119	11kv FDR A-BLOCK MANDIRWALA	652AVR-HVD007A	1875	RESIDENTIAL		Functional	100%	2153	0.74			
66 kv HASTSAL GRID	WHAST119	11kv FDR A-BLOCK MANDIRWALA	652AVR-AVH038A	630	RESIDENTIAL		Functional	100%	619	0.48			
66 kv HASTSAL GRID	WHAST107	11kv FDR JHANDA CHOWK OM VIHAR	652AVR-AVH012A	990	RESIDENTIAL		Functional	100%	1364	0.47			
66 kv HASTSAL GRID	WHAST119	11kv FDR A-BLOCK MANDIRWALA	652AVR-AVH038A	990	RESIDENTIAL		Functional	100%	1055	0.43			
66 kv HASTSAL GRID	WHAST107	11kv FDR JHANDA CHOWK OM VIHAR	652AVR-AVH047A	990	RESIDENTIAL	AMR	Functional	100%	1010	0.37			
66/11 kv G-1 DWARKA GRID	WG1PN111	11kv FDR BHAGWATI GARDEN COMPLEX	652SPK-HVD026A	2000	RESIDENTIAL		Functional	100%	929	1.48			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA135	11kv FDR LAXMI VIHAR	652SPK-HVD027A	1425	RESIDENTIAL		Functional	100%	1442	1.33			
66/11 kv G-1 DWARKA GRID	WG1PN120	11kv FDR MOHAN GARDEN	652SPK-SPK011A	1600	RESIDENTIAL	AMR	Functional	100%	2295	1.15			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA135	11kv FDR LAXMI VIHAR	652SPK-HVD020A	1650	RESIDENTIAL		Functional	100%	1565	1.05			
66/11 kv G-1 DWARKA GRID	WG1PN119	11kv FDR PP-2 (MGN)	652SPK-SPK003A	1600	RESIDENTIAL		Functional	100%	1346	0.96			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD122	11kv FDR GANDHI CHOWK	652SPK-SPK013A	1600	RESIDENTIAL	AMR	Functional	100%	2019	0.85			
66/11 kv G-1 DWARKA GRID	WG1PN119	11kv FDR PP-2 (MGN)	652SPK-HVD021A	990	RESIDENTIAL	AMR	Functional	100%	1012	0.76			
220kv PAPPAN KALAN 2 GRID	WPKL2108	11 kv FDR KUMAR DAIRY	TG-SPK002A-2	990	RESIDENTIAL	AMR	Functional	100%	0	0.73			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD122	11kv FDR GANDHI CHOWK	TP-VGN005A-2	990	RESIDENTIAL	AMR	Functional	100%	0	0.71			
220kv PAPPAN KALAN 2 GRID	WPKL2108	11 kv FDR KUMAR DAIRY	652SPK-SPK002A	990	RESIDENTIAL		Functional	100%	1643	0.67			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD122	11kv FDR GANDHI CHOWK	TP-VGN005A-1	630	RESIDENTIAL		Functional	100%	205	0.35			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD104	11kv FDR RANA ENCLAVE+RAMA PARK	652SPK-SPK065A	990	RESIDENTIAL	AMR	Functional	100%	198	0.30			
66/11 kv G-1 DWARKA GRID	WG1PN119	11kv FDR PP-2 (MGN)	TG-SPK003A-2	990	RESIDENTIAL		Functional	100%	0	0.25			
66/11 kv G-1 DWARKA GRID	WG1PN120	11kv FDR MOHAN GARDEN	652SPK-SPK066A	990	COMMERCIAL		Functional	100%	26	0.23			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD122	11kv FDR GANDHI CHOWK	TP-SPK039A-1	990	RESIDENTIAL		Functional	100%	1206	0.19			
66/11 kv G-1 DWARKA GRID	WG1PN119	11kv FDR PP-2 (MGN)	652SPK-SPK001A	400	RESIDENTIAL	AMR	Functional	100%	407	0.16			
66/11 kv G-1 DWARKA GRID	WG1PN120	11kv FDR MOHAN GARDEN	652SPK-HVD019A	1425	RESIDENTIAL		Functional	100%	1396	0.15			
66/11 kv G-1 DWARKA GRID	WG1PN120	11kv FDR MOHAN GARDEN	MG-HVD028A-1	225	RESIDENTIAL		Functional	100%	200	0.13			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD122	11kv FDR GANDHI CHOWK	TP-SPK039A-2	630	RESIDENTIAL		Functional	100%	753	0.12			
66/11 kv G-1 DWARKA GRID	WG1PN608	11kv FDR VIPIN GDN GALI NO 38	652SPK-SPK039A	630	MIXED		Functional	100%	0	0.10			
66/11 kv G-1 DWARKA GRID	WG1PN113	11kv FDR RAMA PARK	652SPK-HVD018A	2125	RESIDENTIAL		Functional	100%	1188	1.71	8.96	0.11	1.25%
220kv PAPPAN KALAN 2 GRID	WPKL2108	11 kv FDR KUMAR DAIRY	652SPK-HVD022A	2625	RESIDENTIAL		Functional	100%	3318	1.44			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD122	11kv FDR GANDHI CHOWK	652SPK-HVD023A	2025	RESIDENTIAL		Functional	100%	2981	1.15			
66/11 kv G-1 DWARKA GRID	WG1PN121	11kv FDR DMRC SHOPPING COMPLEX	TG-SPK008A-2	990	RESIDENTIAL	AMR	Functional	100%	497	0.95			
66/11 kv G-1 DWARKA GRID	WG1PN121	11kv FDR DMRC SHOPPING COMPLEX	652SPK-SPK008A	990	RESIDENTIAL		Functional	100%	1018	0.71			
220kv PAPPAN KALAN 2 GRID	WPKL2108	11 kv FDR KUMAR DAIRY	652SPK-HVD051A	1125	RESIDENTIAL		Functional	100%	949	0.70			
66/11 kv G-1 DWARKA GRID	WG1PN121	11kv FDR DMRC SHOPPING COMPLEX	TG-SPK007A-2	990	RESIDENTIAL		Functional	100%	0	0.67			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD122	11kv FDR GANDHI CHOWK	652SPK-HVD023A	990	RESIDENTIAL	AMR	Functional	100%	0	0.53			
66/11 kv G-1 DWARKA GRID	WG1PN112	11kv FDR LEXT MOHAN GARDEN	652SPK-HVD024A	2875	RESIDENTIAL		Functional	100%	1238	0.52			
66/11 kv G-1 DWARKA GRID	WG1PN121	11kv FDR DMRC SHOPPING COMPLEX	652SPK-SPK007A	990	RESIDENTIAL	AMR	Functional	100%	1867	0.44			
66/11 kv G-1 DWARKA GRID	WG1PN112	11kv FDR LEXT MOHAN GARDEN	MG-HVD023A-3	990	RESIDENTIAL	AMR	Functional	100%	0	0.21			
66/11 kv G-1 DWARKA GRID	WG1PN113	11kv FDR RAMA PARK	652SPK-SPK021A	100	RESIDENTIAL		Functional	100%	0	0.03			
66/11 kv G-1 DWARKA GRID	WG1PN128	11kv FDR WIINTER HILL SOCIETY DWARKA MOR NO-2	652SPK-SPK004A	1600	RESIDENTIAL	AMR	Functional	100%	1309	1.11	6.15	0.16	2.58%
66/11 kv G-1 DWARKA GRID	WG1PN116	11kv FDR WINTER HILL SOCIETY DWARKA MOR NO-1	652SPK-SPK010A	990	RESIDENTIAL	AMR	Functional	100%	937	0.75			
66/11 kv G-1 DWARKA GRID	WG1PN114	11kv FDR SEWAK PARK	TX-SPK056A-1	990	RESIDENTIAL		Functional	100%	302	0.60			
66/11 kv G-1 DWARKA GRID	WG1PN114	11kv FDR SEWAK PARK	652SPK-SPK009A	990	RESIDENTIAL		Functional	100%	922	0.48			
66/11 kv G-1 DWARKA GRID	WG1PN114	11kv FDR SEWAK PARK	TG-SPK062A-1	630	RESIDENTIAL		Functional	100%	602	0.38			

66/11 kv G-1 DWARKA GRID	WG1PN114	11kv FDR SEWAK PARK	2652SPK-SPK009A-	990	RESIDENTIAL		Functional	100%	0	0.35			
66/11 kv G-1 DWARKA GRID	WG1PN121	11kv FDR DMRC SHOPPING COMPLEX	TI-SPK025A-2	990	MIXED		Functional	100%	0	0.35			
66/11 kv G-1 DWARKA GRID	WG1PN121	11kv FDR DMRC SHOPPING COMPLEX	TG-SPK025A-1	990	MIXED		Functional	100%	656	0.35			
66/11 kv G-1 DWARKA GRID	WG1PN114	11kv FDR SEWAK PARK	MG-HVD049A-1	500	RESIDENTIAL		Functional	100%	299	0.34			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA135	11kv FDR LAXMI VIHAR	2652SPK-SPK009B-	990	RESIDENTIAL		Functional	100%	0	0.34			
66/11 kv G-1 DWARKA GRID	WG1PN114	11kv FDR SEWAK PARK	2652SPK-SPK023A-	990	RESIDENTIAL	AMR	Functional	100%	83	0.33			
66/11 kv G-1 DWARKA GRID	WG1PN114	11kv FDR SEWAK PARK	TK-SPK057A-1	990	RESIDENTIAL	AMR	Functional	100%	575	0.32			
66/11 kv G-1 DWARKA GRID	WG1PN128	11kv FDR WIINTER HILL SOCIETY DWARKA MOR NO-2	2652SPK-SPK020A-	400	RESIDENTIAL	AMR	Functional	100%	211	0.22			
66/11 kv G-1 DWARKA GRID	WG1PN116	11kv FDR WINTER HILL SOCIETY DWARKA MOR NO-1	652SPK-HVD017A-	1350	RESIDENTIAL		Functional	100%	825	0.15			
66/11 kv G-1 DWARKA GRID	WG1PN114	11kv FDR SEWAK PARK	2652SPK-SPK067A-	400	COMMERCIAL		Functional	100%	155	0.15			
66/11 kv G-1 DWARKA GRID	WG1PN116	11kv FDR WINTER HILL SOCIETY DWARKA MOR NO-1	TG-SPK037A-1	630	RESIDENTIAL		Functional	100%	223	0.10			
66/11 kv G-1 DWARKA GRID	WG1PN122	11kv FDR LAXMAN PURI	2652SPK-SPK014A-	990	RESIDENTIAL		Functional	100%	1235	0.83	9.44	0.17	1.82%
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA141	11kv FDR NAWADA HOUSING COMPLEX	TG-SPK031A-1	990	RESIDENTIAL		Functional	100%	1526	0.71			
66/11 kv G-1 DWARKA GRID	WG1PN122	11kv FDR LAXMAN PURI	2652SPK-SPK015A-	990	RESIDENTIAL		Functional	100%	951	0.64			
66/11 kv G-1 DWARKA GRID	WG1PN122	11kv FDR LAXMAN PURI	TG-SPK024A-1	990	RESIDENTIAL	AMR	Functional	100%	350	0.62			
66/11 kv G-1 DWARKA GRID	WG1PN122	11kv FDR LAXMAN PURI	2652SPK-SPK022A-	990	RESIDENTIAL		Functional	100%	801	0.62			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD122	11kv FDR GANDHI CHOWK	652SPK-HVD025A-	1350	RESIDENTIAL		Functional	100%	1120	0.55			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA141	11kv FDR NAWADA HOUSING COMPLEX	TG-SPK031A-2	990	RESIDENTIAL		Functional	100%	29	0.50			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD104	11kv FDR RANA ENCLAVE+RAMA PARK	2652SPK-SPK016A-	630	RESIDENTIAL		Functional	100%	1425	0.45			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD104	11kv FDR RANA ENCLAVE+RAMA PARK	2652SPK-SPK017A-	630	RESIDENTIAL		Functional	100%	597	0.42			
66/11 kv G-1 DWARKA GRID	WG1PN608	11kv FDR VIPIN GDN GALI NO 38	TG-SPK058A-1	990	RESIDENTIAL	AMR	Functional	100%	1008	0.41			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA141	11kv FDR NAWADA HOUSING COMPLEX	TI-SPK030A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.40			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD104	11kv FDR RANA ENCLAVE+RAMA PARK	TG-SPK054A-1	630	RESIDENTIAL	AMR	Functional	100%	609	0.39			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD122	11kv FDR GANDHI CHOWK	2652SPK-SPK047A-	630	MIXED		Functional	100%	0	0.35			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD104	11kv FDR RANA ENCLAVE+RAMA PARK	TG-SPK028A-1	400	RESIDENTIAL		Functional	100%	1113	0.34			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD104	11kv FDR RANA ENCLAVE+RAMA PARK	TG-SPK028A-2	630	RESIDENTIAL		Functional	100%	0	0.33			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD104	11kv FDR RANA ENCLAVE+RAMA PARK	2652SPK-SPK016A-	630	RESIDENTIAL	AMR	Functional	100%	0	0.33			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD104	11kv FDR RANA ENCLAVE+RAMA PARK	2652SPK-SPK034A-	630	RESIDENTIAL		Functional	100%	0	0.30			
66/11 kv G-1 DWARKA GRID	WG1PN122	11kv FDR LAXMAN PURI	TG-SPK024A-2	630	RESIDENTIAL		Functional	100%	1117	0.28			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD122	11kv FDR GANDHI CHOWK	TG-SPK047A-1	630	RESIDENTIAL	AMR	Functional	100%	667	0.26			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD104	11kv FDR RANA ENCLAVE+RAMA PARK	2652SPK-SPK017A-	400	RESIDENTIAL		Functional	100%	0	0.23			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD122	11kv FDR GANDHI CHOWK	2652SPK-SPK012A-	400	RESIDENTIAL		Functional	100%	287	0.20			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA141	11kv FDR NAWADA HOUSING COMPLEX	TI-SPK030A-1	400	RESIDENTIAL	AMR	Functional	100%	524	0.15			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD104	11kv FDR RANA ENCLAVE+RAMA PARK	TP-SPK034A-1	400	RESIDENTIAL		Functional	100%	721	0.13			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD104	11kv FDR RANA ENCLAVE+RAMA PARK	2652SPK-SPK016A-	630	RESIDENTIAL		Functional	100%	0	0.10			
66 kv DELHI JAL BOARD NAJAFGARH GRID	WDJBD104	11kv FDR RANA ENCLAVE+RAMA PARK	2652SPK-SPK064A-	630	RESIDENTIAL		Functional	100%	375	0.08			
66kv NILOTHI GRID	WNILO116	11kv FDR UGR MOHAN GARDEN	652VGN-HVD038A	1700	RESIDENTIAL		Functional	100%	1745	0.85	4.34	0.07	1.62%
66/11 kv G-1 DWARKA GRID	WG1PN609	11kv FDR P BLK M GDN	652VGN-HVD038A	1400	RESIDENTIAL		Functional	100%	620	0.62			
66kv NILOTHI GRID	WNILO127	11kv FDR TIRANGA CHOWK	652AVR-HVD051A-	1425	RESIDENTIAL		Functional	100%	1156	0.61			
66kv NILOTHI GRID	WNILO127	11kv FDR TIRANGA CHOWK	TP-VGN015A-1	990	RESIDENTIAL	AMR	Functional	100%	1377	0.55			
66/11 kv G-1 DWARKA GRID	WG1PN609	11kv FDR P BLK M GDN	652VGN-HVD034A	1750	RESIDENTIAL		Functional	100%	1194	0.52			
66/11 kv G-1 DWARKA GRID	WG1PN609	11kv FDR P BLK M GDN	652VGN-HVD034A	625	MIXED		Functional	100%	0	0.49			

66kV NILOTHI GRID	WNILO127	11kV FDR TIRANGA CHOWK	652VGN-HVD032A	1025	RESIDENTIAL		Functional	100%	366	0.31			
66kV NILOTHI GRID	WNILO116	11kV FDR UGR MOHAN GARDEN	652VGN-VGN047A	630	COMMERCIAL	AMR	Functional	100%	71	0.26			
66kV NILOTHI GRID	WNILO116	11kV FDR UGR MOHAN GARDEN	652VGN-VGN047A	630	COMMERCIAL	AMR	Functional	100%	73	0.17			
66kV NILOTHI GRID	WNILO116	11kV FDR UGR MOHAN GARDEN	TP-VGN003A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02			
66kV NILOTHI GRID	WNILO116	11kV FDR UGR MOHAN GARDEN	TP-VGN009A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kV HASTSAL GRID	WHAST126	11kV FDR RAHUL COWK	652VGN-HVD037A	2400	RESIDENTIAL		Functional	100%	1598	1.22	8.37	0.12	1.37%
66kV NILOTHI GRID	WNILO126	11kV FDR DEFENCE ENCLAVE	MG-HVD042A-1	2000	RESIDENTIAL		Functional	100%	1830	1.15			
66 kV HASTSAL GRID	WHAST126	11kV FDR RAHUL COWK	652VGN-HVD043A	1675	RESIDENTIAL		Functional	100%	781	0.95			
66 kV HASTSAL GRID	WHAST126	11kV FDR RAHUL COWK	652VGN-HVD043A	1425	RESIDENTIAL		Functional	100%	2150	0.91			
66 kV HASTSAL GRID	WHAST126	11kV FDR RAHUL COWK	652VGN-HVD036A	1475	RESIDENTIAL		Functional	100%	1808	0.71			
66 kV HASTSAL GRID	WHAST120	11kV FDR VIKAS KUNJ SCHOOL WALA	TP-VGN039A-1	990	RESIDENTIAL	AMR	Functional	100%	935	0.70			
66kV NILOTHI GRID	WNILO126	11kV FDR DEFENCE ENCLAVE	652VGN-HVD030A	1500	RESIDENTIAL	AMR	Functional	100%	1015	0.66			
66 kV HASTSAL GRID	WHAST120	11kV FDR VIKAS KUNJ SCHOOL WALA	652VGN-HVD031A	1025	RESIDENTIAL	AMR	Functional	100%	461	0.63			
66kV NILOTHI GRID	WNILO126	11kV FDR DEFENCE ENCLAVE	652VGN-HVD033A	1175	RESIDENTIAL		Functional	100%	599	0.63			
66 kV HASTSAL GRID	WHAST120	11kV FDR VIKAS KUNJ SCHOOL WALA	652VGN-HVD039A	1675	RESIDENTIAL	AMR	Functional	100%	909	0.54			
66 kV HASTSAL GRID	WHAST120	11kV FDR VIKAS KUNJ SCHOOL WALA	MG-HVD041A-1	750	RESIDENTIAL		Functional	100%	551	0.39			
66kV NILOTHI GRID	WNILO127	11kV FDR TIRANGA CHOWK	MG-HVD044A-1	1225	RESIDENTIAL		Functional	100%	1388	0.62	2.68	0.03	0.96%
220kV PAPPAN KALAN 2 GRID	WPKL2109	11kV FDR SAINIK ENCLAVE	652VGN-HVD050A	875	RESIDENTIAL		Functional	100%	686	0.57			
66kV NILOTHI GRID	WNILO116	11kV FDR UGR MOHAN GARDEN	MG-HVD048A-1	800	RESIDENTIAL		Functional	100%	693	0.50			
220kV PAPPAN KALAN 2 GRID	WPKL2109	11kV FDR SAINIK ENCLAVE	TP-VGN002A-1	400	RESIDENTIAL	AMR	Functional	100%	685	0.42			
66kV NILOTHI GRID	WNILO116	11kV FDR UGR MOHAN GARDEN	TG-VGN019A-1	630	RESIDENTIAL	AMR	Functional	100%	640	0.30			
66kV NILOTHI GRID	WNILO116	11kV FDR UGR MOHAN GARDEN	652VGN-VGN019A	400	RESIDENTIAL	AMR	Functional	100%	8	0.28			
66kV NILOTHI GRID	WNILO116	11kV FDR UGR MOHAN GARDEN	TP-VGN018A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kV HASTSAL GRID	WHAST121	11kV FDR RAKSHA ENCLAVE	652VGN-HVD049A	2625	RESIDENTIAL		Functional	100%	1540	0.95	6.52	0.10	1.56%
66kV NILOTHI GRID	WNILO127	11kV FDR TIRANGA CHOWK	652VGN-HVD047A	1975	RESIDENTIAL		Functional	100%	1119	0.88			
220kV PAPPAN KALAN 2 GRID	WPKL2109	11kV FDR SAINIK ENCLAVE	652VGN-HVD045A	1925	RESIDENTIAL		Functional	100%	2136	0.78			
66 kV HASTSAL GRID	WHAST121	11kV FDR RAKSHA ENCLAVE	MG-HVD046A-1	1850	RESIDENTIAL		Functional	100%	811	0.65			
66 kV HASTSAL GRID	WHAST121	11kV FDR RAKSHA ENCLAVE	652VGN-HVD035A	1300	RESIDENTIAL		Functional	100%	475	0.43			
66 kV HASTSAL GRID	WHAST121	11kV FDR RAKSHA ENCLAVE	652VGN-HVD040A	1375	RESIDENTIAL		Functional	100%	490	0.38			
66 kV HASTSAL GRID	WHAST121	11kV FDR RAKSHA ENCLAVE	TG-VGN006A-2	630	RESIDENTIAL	AMR	Functional	100%	98	0.36			
66 kV HASTSAL GRID	WHAST121	11kV FDR RAKSHA ENCLAVE	TP-VGN007A-2	400	RESIDENTIAL		Functional	100%	193	0.35			
220kV PAPPAN KALAN 2 GRID	WPKL2109	11kV FDR SAINIK ENCLAVE	TG-VGN013A-2	630	RESIDENTIAL	AMR	Functional	100%	338	0.32			
66 kV HASTSAL GRID	WHAST121	11kV FDR RAKSHA ENCLAVE	TG-VGN006A-1	400	RESIDENTIAL	AMR	Functional	100%	170	0.30			
66 kV HASTSAL GRID	WHAST121	11kV FDR RAKSHA ENCLAVE	652VGN-HVD035A	850	RESIDENTIAL		Functional	100%	966	0.24			
220kV PAPPAN KALAN 2 GRID	WPKL2109	11kV FDR SAINIK ENCLAVE	TG-VGN042A-2	630	RESIDENTIAL	AMR	Functional	100%	307	0.17			
220kV PAPPAN KALAN 2 GRID	WPKL2109	11kV FDR SAINIK ENCLAVE	TG-VGN013A-1	400	RESIDENTIAL		Functional	100%	28	0.16			
220kV PAPPAN KALAN 2 GRID	WPKL2109	11kV FDR SAINIK ENCLAVE	TG-VGN042A-1	630	RESIDENTIAL	AMR	Functional	100%	191	0.16			
66 kV HASTSAL GRID	WHAST121	11kV FDR RAKSHA ENCLAVE	TP-VGN007A-1	400	RESIDENTIAL		Functional	100%	686	0.15			
66 kV HASTSAL GRID	WHAST121	11kV FDR RAKSHA ENCLAVE	TG-VGN043A-1	630	RESIDENTIAL	AMR	Functional	100%	168	0.11			
66 kV HASTSAL GRID	WHAST121	11kV FDR RAKSHA ENCLAVE	TG-VGN043A-2	630	RESIDENTIAL	AMR	Functional	100%	107	0.06			
66 kV HASTSAL GRID	WHAST119	11kV FDR A-BLOCK MANDIRWALA	652SPK-MOB002A	990	MIXED		Functional	100%	0	0.19			
G-7 DWARKA GRID	WG7PN114	11kV FDR HARIJAN BASTI NEW GADDEWALA	660MLP-DWR082A	315	RESIDENTIAL		Functional	100%	0	0.06	6.39	1.24	16.27%
G-7 DWARKA GRID	WG7PN114	11kV FDR HARIJAN BASTI NEW GADDEWALA	660MLP-DWR082A	315	MIXED		Functional	100%	0	0.05			
66 kV G - 6 P.P.K GRID	WG6PN112	11kV FDR EPFO SEC-23	660S09-DWR135A	400	RESIDENTIAL		Functional	100%	0	0.33			
66 kV G - 6 P.P.K GRID	WG6PN112	11kV FDR EPFO SEC-23	660S09-DWR135A	400	INDUSTRIAL		Functional	100%	0	0.17			
66 kV G - 6 P.P.K GRID	WG6PN103	11kV FDR CAMMAND TANK-4, SECTOR-20	660S09-DWR168A	400	MIXED		Functional	100%	0	0.08			
66 kV G - 6 P.P.K GRID	WG6PN103	11kV FDR CAMMAND TANK-4, SECTOR-20	660S09-DWR168A	400	MIXED		Functional	100%	0	0.08			
66 kV G - 6 P.P.K GRID	WG6PN123	11kV FDR AWHO, SEC-22	TK-MNP063A-1	990	RESIDENTIAL		Functional	100%	1180	0.70			
66 kV G - 6 P.P.K GRID	WG6PN107	11kV FDR SEC-8 DP + 11kV FDR SEC-9 PKT-2	TG-DWR033A-1	630	RESIDENTIAL		Functional	100%	130	0.61			
66 kV G - 6 P.P.K GRID	WG6PN118	11kV FDR RAJ NAGAR	TG-DWR156A-1	630	RESIDENTIAL		Functional	100%	273	0.52			

G-7 DWARKA GRID	WG7PN108	11kV FDR DTC DEPOT	TG-DWR020A-1	500	RESIDENTIAL		Functional	100%	226	0.41			
66 kV G - 6 P.P.K GRID	WG6PN107	11kV FDR SEC-8 DP + 11kV FDR SEC-9 PKT-2	TG-DWR056A-2	630	RESIDENTIAL		Functional	100%	474	0.38			
66 kV G - 6 P.P.K GRID	WG6PN123	11kV FDR AWHO, SEC-22	TG-MNP062A-2	630	RESIDENTIAL		Functional	100%	0	0.38			
G-7 DWARKA GRID	WG7PN116	11kV FDR SPG SEC-8	TG-DWR032A-1	630	RESIDENTIAL		Functional	100%	178	0.36			
66 kV G - 6 P.P.K GRID	WG6PN123	11kV FDR AWHO, SEC-22	TG-MNP062A-1	630	RESIDENTIAL		Functional	100%	1203	0.34			
66 kV G - 6 P.P.K GRID	WG6PN107	11kV FDR SEC-8 DP + 11kV FDR SEC-9 PKT-2	TI-DWR131A-2	400	RESIDENTIAL		Functional	100%	88	0.25			
G-7 DWARKA GRID	WG7PN116	11kV FDR SPG SEC-8	TI-DWR068A-1	630	RESIDENTIAL		Functional	100%	127	0.24			
G-7 DWARKA GRID	WG7PN116	11kV FDR SPG SEC-8	TG-DWR019A-1	630	RESIDENTIAL		Functional	100%	175	0.23			
66 kV G - 6 P.P.K GRID	WG6PN107	11kV FDR SEC-8 DP + 11kV FDR SEC-9 PKT-2	TI-DWR027A-2	630	RESIDENTIAL		Functional	100%	188	0.21			
66 kV G - 6 P.P.K GRID	WG6PN123	11kV FDR AWHO, SEC-22	660S09-MNP063A	630	RESIDENTIAL		Functional	100%	0	0.20			
G-7 DWARKA GRID	WG7PN116	11kV FDR SPG SEC-8	TP-DWR153A-1	400	RESIDENTIAL		Functional	100%	142	0.19			
66 kV G - 6 P.P.K GRID	WG6PN107	11kV FDR SEC-8 DP + 11kV FDR SEC-9 PKT-2	TG-DWR033A-2	630	RESIDENTIAL		Functional	100%	195	0.19			
66 kV G - 6 P.P.K GRID	WG6PN107	11kV FDR SEC-8 DP + 11kV FDR SEC-9 PKT-2	TG-DWR056A-1	400	RESIDENTIAL		Functional	100%	0	0.18			
G-7 DWARKA GRID	WG7PN116	11kV FDR SPG SEC-8	660S09-DWR064A	400	RESIDENTIAL		Functional	100%	67	0.17			
66 kV G - 6 P.P.K GRID	WG6PN107	11kV FDR SEC-8 DP + 11kV FDR SEC-9 PKT-2	TI-DWR027A-1	500	RESIDENTIAL		Functional	100%	275	0.15			
G-7 DWARKA GRID	WG7PN116	11kV FDR SPG SEC-8	TI-DWR154A-1	400	RESIDENTIAL		Functional	100%	130	0.10			
G-7 DWARKA GRID	WG7PN116	11kV FDR SPG SEC-8	660S09-DWR064A	400	RESIDENTIAL		Functional	100%	72	0.07			
G-7 DWARKA GRID	WG7PN116	11kV FDR SPG SEC-8	TI-DWR155A-1	400	RESIDENTIAL		Functional	100%	102	0.06			
66 kV G - 6 P.P.K GRID	WG6PN107	11kV FDR SEC-8 DP + 11kV FDR SEC-9 PKT-2	TI-DWR131A-1	400	RESIDENTIAL		Functional	100%	61	0.03			
66 kV G - 6 P.P.K GRID	WG6PN123	11kV FDR AWHO, SEC-22	660S09-DWR197A	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP112	11kV FDR MADANPURI HANS PARK	660S09-MOB001A	630	RESIDENTIAL	AMR	Functional	100%	0	0.49			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP112	11kV FDR MADANPURI HANS PARK	660S09-MOB001A	990	MIXED		Functional	100%	0	0.29			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP112	11kV FDR MADANPURI HANS PARK	660S09-MOB001A	990	MIXED		Functional	100%	0	0.06			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP112	11kV FDR MADANPURI HANS PARK	660S09-MOB001A	990	MIXED		Functional	100%	0	0.06			
66 KV INST. AREA JKP (SAGARPUR) GRID	WSGRP112	11kV FDR MADANPURI HANS PARK	660S09-MOB002A	990	MIXED		Functional	100%	0	0.01			
G-7 DWARKA GRID	WG7PN130	11kV FDR SPG COMPLEX SEC-21 NO-3	TI-MNP070A-1	630	RESIDENTIAL	AMR	Functional	100%	268	0.16	1.39	0.18	11.31%
G-7 DWARKA GRID	WG7PN130	11kV FDR SPG COMPLEX SEC-21 NO-3	TI-MNP068A-1	630	RESIDENTIAL	AMR	Functional	100%	370	0.16			
G-7 DWARKA GRID	WG7PN130	11kV FDR SPG COMPLEX SEC-21 NO-3	TI-MNP066A-1	630	RESIDENTIAL	AMR	Functional	100%	434	0.14			
G-7 DWARKA GRID	WG7PN123	11kV FDR SPG COMPLEX DWK-21 NO-2	660S09-DWR239A	1250	RESIDENTIAL	AMR	Functional	100%	70	0.13			
G-7 DWARKA GRID	WG7PN123	11kV FDR SPG COMPLEX DWK-21 NO-2	660S09-DWR241A	1250	RESIDENTIAL	AMR	Functional	100%	58	0.12			
G-7 DWARKA GRID	WG7PN130	11kV FDR SPG COMPLEX SEC-21 NO-3	TI-MNP065A-1	400	RESIDENTIAL	AMR	Functional	100%	277	0.11			
G-7 DWARKA GRID	WG7PN123	11kV FDR SPG COMPLEX DWK-21 NO-2	660S09-DWR240A	1250	RESIDENTIAL	AMR	Functional	100%	137	0.11			
G-7 DWARKA GRID	WG7PN123	11kV FDR SPG COMPLEX DWK-21 NO-2	660S09-DWR242A	1250	RESIDENTIAL	AMR	Functional	100%	55	0.10			
G-7 DWARKA GRID	WG7PN123	11kV FDR SPG COMPLEX DWK-21 NO-2	660S09-DWR238A	1250	RESIDENTIAL	AMR	Functional	100%	113	0.10			
G-7 DWARKA GRID	WG7PN130	11kV FDR SPG COMPLEX SEC-21 NO-3	TI-MNP069A-1	630	RESIDENTIAL	AMR	Functional	100%	367	0.09			
G-7 DWARKA GRID	WG7PN123	11kV FDR SPG COMPLEX DWK-21 NO-2	660S09-DWR238A	1250	RESIDENTIAL	AMR	Functional	100%	113	0.09			
G-7 DWARKA GRID	WG7PN130	11kV FDR SPG COMPLEX SEC-21 NO-3	TI-MNP071A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.07			
G-7 DWARKA GRID	WG7PN123	11kV FDR SPG COMPLEX DWK-21 NO-2	660S09-DWR239A	1250	RESIDENTIAL		Functional	100%	149	0.06			
G-7 DWARKA GRID	WG7PN130	11kV FDR SPG COMPLEX SEC-21 NO-3	TI-MNP067A-1	630	RESIDENTIAL	AMR	Functional	100%	314	0.05			
G-7 DWARKA GRID	WG7PN130	11kV FDR SPG COMPLEX SEC-21 NO-3	TI-MNP071A-1	630	RESIDENTIAL	AMR	Functional	100%	316	0.05			
G-7 DWARKA GRID	WG7PN123	11kV FDR SPG COMPLEX DWK-21 NO-2	660S09-DWR241A	1250	RESIDENTIAL	AMR	Functional	100%	114	0.04			
G-7 DWARKA GRID	WG7PN110	11kV FDR SEC-8 S/STN.-5	TG-MNP035A-3	1600	RESIDENTIAL		Functional	100%	0	1.29	28.73	0.61	2.08%
66 kV G - 6 P.P.K GRID	WG6PN132	11kV FDR INTELLIGENCE BUREAU, SEC-9 + GALI NO-11 RAJ NAGAR	TG-MNP040A-1	1600	RESIDENTIAL		Functional	100%	1828	1.11			
66 kV G - 6 P.P.K GRID	WG6PN132	11kV FDR INTELLIGENCE BUREAU, SEC-9 + GALI NO-11 RAJ NAGAR	TG-MNP039A-2	1600	COMMERCIAL		Functional	100%	0	1.06			
G-7 DWARKA GRID	WG7PN115	11kV FDR STORE SEC-8	TI-MNP038A-1	1600	COMMERCIAL	AMR	Functional	100%	1759	1.00			
66 kV G - 6 P.P.K GRID	WG6PN129	11kV FDR OLD G-BLOCK RAJ NAGAR	660S09-MNP036A	1600	RESIDENTIAL		Functional	100%	2365	0.95			
G-7 DWARKA GRID	WG7PN128	11kV FDR MANGLAPURI NO-2 VIA RAMPHAL CHOWK	TG-MNP043A-1	1600	RESIDENTIAL		Functional	100%	0	0.95			

G-7 DWARKA GRID	WG7PN110	11kV FDR SEC-8 S/STN.-5	TI-MNP035A-1	1600	RESIDENTIAL		Functional	100%	1852	0.95			
66 kV G - 6 P.P.K GRID	WG6PN133	11kV FDR BHATT WALA	TI-MNP037A-1	990	RESIDENTIAL		Functional	100%	2551	0.93			
G-7 DWARKA GRID	WG7PN128	11kV FDR MANGLAPURI NO-2 VIA RAMPHAL CHOWK	TG-MNP042A-2	990	RESIDENTIAL		Functional	100%	0	0.88			
66 kV G - 6 P.P.K GRID	WG6PN129	11kV FDR OLD G-BLOCK RAJ NAGAR	TI-MNP034A-2	1600	RESIDENTIAL		Functional	100%	2054	0.88			
66 kV G - 2 P.P.K (NASEERPUR) GRID	WG2PN108	11kV FDR DADA CHHATRI MARG	TG-MNP048A-1	990	RESIDENTIAL		Functional	100%	1959	0.87			
G-7 DWARKA GRID	WG7PN124	11kV FDR SHASTRI MARG RAJ NAGAR	TI-MNP064A-1	1600	RESIDENTIAL		Functional	100%	0	0.86			
G-7 DWARKA GRID	WG7PN109	11kV FDR MAHADEVA	TG-MNP047A-1	990	RESIDENTIAL		Functional	100%	1413	0.83			
G-7 DWARKA GRID	WG7PN109	11kV FDR MAHADEVA	TI-MNP033A-1	990	RESIDENTIAL	AMR	Functional	100%	1654	0.83			
66 kV G - 6 P.P.K GRID	WG6PN129	11kV FDR OLD G-BLOCK RAJ NAGAR	TI-MNP034A-1	1600	RESIDENTIAL		Functional	100%	1710	0.81			
G-7 DWARKA GRID	WG7PN124	11kV FDR SHASTRI MARG RAJ NAGAR	TI-MNP064A-2	990	INDUSTRIAL		Functional	100%	1650	0.80			
G-7 DWARKA GRID	WG7PN110	11kV FDR SEC-8 S/STN.-5	TI-MNP035A-2	990	RESIDENTIAL		Functional	100%	2209	0.78			
G-7 DWARKA GRID	WG7PN128	11kV FDR MANGLAPURI NO-2 VIA RAMPHAL CHOWK	TK-MNP042A-1	990	RESIDENTIAL		Functional	100%	1540	0.77			
66 kV G - 6 P.P.K GRID	WG6PN118	11kV FDR RAJ NAGAR	TG-MNP046A-2	990	RESIDENTIAL		Functional	100%	0	0.75			
66 kV G - 2 P.P.K (NASEERPUR) GRID	WG2PN108	11kV FDR DADA CHHATRI MARG	TG-MNP048A-2	990	RESIDENTIAL		Functional	100%	0	0.68			
66 kV G - 6 P.P.K GRID	WG6PN133	11kV FDR BHATT WALA	TI-MNP037A-2	990	RESIDENTIAL		Functional	100%	15	0.68			
G-7 DWARKA GRID	WG7PN115	11kV FDR STORE SEC-8	TG-MNP039A-1	1600	RESIDENTIAL	AMR	Functional	100%	2094	0.66			
G-7 DWARKA GRID	WG7PN109	11kV FDR MAHADEVA	660S09-MNP045A	990	MIXED		Functional	100%	1460	0.65			
G-7 DWARKA GRID	WG7PN128	11kV FDR MANGLAPURI NO-2 VIA RAMPHAL CHOWK	TG-MNP043A-2	1600	RESIDENTIAL		Functional	100%	2133	0.65			
G-7 DWARKA GRID	WG7PN124	11kV FDR SHASTRI MARG RAJ NAGAR	660S09-DWR252A	990	RESIDENTIAL		Functional	100%	181	0.64			
66 kV G - 6 P.P.K GRID	WG6PN118	11kV FDR RAJ NAGAR	TG-MNP046A-3	1600	RESIDENTIAL		Functional	100%	0	0.61			
G-7 DWARKA GRID	WG7PN109	11kV FDR MAHADEVA	TG-MNP046A-1	630	RESIDENTIAL		Functional	100%	2636	0.60			
G-7 DWARKA GRID	WG7PN115	11kV FDR STORE SEC-8	TG-MNP058A-1	990	RESIDENTIAL		Functional	100%	1310	0.56			
66 kV G - 6 P.P.K GRID	WG6PN115	11kV FDR NBE SEC-9 FDR	660S09-HVD014A	728	RESIDENTIAL		Functional	100%	123	0.52			
66 kV G - 6 P.P.K GRID	WG6PN129	11kV FDR OLD G-BLOCK RAJ NAGAR	660S09-MNP036A	630	RESIDENTIAL		Functional	100%	0	0.51			
G-7 DWARKA GRID	WG7PN124	11kV FDR SHASTRI MARG RAJ NAGAR	TP-DWR115A-2	990	RESIDENTIAL		Functional	100%	0	0.48			
G-7 DWARKA GRID	WG7PN115	11kV FDR STORE SEC-8	660S09-MNP038A	990	MIXED		Functional	100%	0	0.47			
66 kV G - 6 P.P.K GRID	WG6PN132	11kV FDR INTELLIGENCE BUREAU, SEC-9 + GALI NO-11 RAJ NAGAR	660S09-MNP040A	630	MIXED		Functional	100%	0	0.46			
66 kV G - 2 P.P.K (NASEERPUR) GRID	WG2PN110	11kV FDR DDA OFFICE MANGLAPURI	660S09-DWR254A	990	RESIDENTIAL		Functional	100%	112	0.43			
G-7 DWARKA GRID	WG7PN110	11kV FDR SEC-8 S/STN.-5	TG-DWR121A-1	990	RESIDENTIAL		Functional	100%	509	0.42			
G-7 DWARKA GRID	WG7PN115	11kV FDR STORE SEC-8	660S09-MNP058A	990	MIXED		Functional	100%	0	0.37			
G-7 DWARKA GRID	WG7PN124	11kV FDR SHASTRI MARG RAJ NAGAR	TG-DWR115A-1	400	RESIDENTIAL		Functional	100%	375	0.35			
G-7 DWARKA GRID	WG7PN124	11kV FDR SHASTRI MARG RAJ NAGAR	660S09-DWR235A	630	RESIDENTIAL		Functional	100%	158	0.29			
66 kV G - 6 P.P.K GRID	WG6PN118	11kV FDR RAJ NAGAR	660S09-DWR256A	400	RESIDENTIAL		Functional	100%	276	0.26			
66 kV G - 6 P.P.K GRID	WG6PN115	11kV FDR NBE SEC-9 FDR	PM-HVD013A-1	1657	RESIDENTIAL		Functional	100%	1787	0.25			
G-7 DWARKA GRID	WG7PN124	11kV FDR SHASTRI MARG RAJ NAGAR	660S09-DWR235A	630	RESIDENTIAL		Functional	100%	63	0.24			
66 kV G - 6 P.P.K GRID	WG6PN132	11kV FDR INTELLIGENCE BUREAU, SEC-9 + GALI NO-11 RAJ NAGAR	TP-MNP041A-1	400	RESIDENTIAL		Functional	100%	821	0.24			
G-7 DWARKA GRID	WG7PN110	11kV FDR SEC-8 S/STN.-5	TG-DWR121A-2	990	RESIDENTIAL		Functional	100%	0	0.24			
G-7 DWARKA GRID	WG7PN110	11kV FDR SEC-8 S/STN.-5	PM-HVD012A-1	489	RESIDENTIAL		Functional	100%	381	0.25			
G-7 DWARKA GRID	WG7PN109	11kV FDR MAHADEVA	TG-MNP047A-2	630	RESIDENTIAL		Functional	100%	0	0.18			
66 kV G - 6 P.P.K GRID	WG6PN118	11kV FDR RAJ NAGAR	660S09-DWR260A	250	RESIDENTIAL		Functional	100%	0	0.09			
66 kV G - 6 P.P.K GRID	WG6PN115	11kV FDR NBE SEC-9 FDR	660S09-HVD014A	400	RESIDENTIAL		Functional	100%	115	0.09			
66 kV G - 6 P.P.K GRID	WG6PN115	11kV FDR NBE SEC-9 FDR	TG-MNP059A-1	100	RESIDENTIAL		Functional	100%	8	0.06			
66 kV G - 6 P.P.K GRID	WG6PN115	11kV FDR NBE SEC-9 FDR	660S09-HVD014A	400	RESIDENTIAL		Functional	100%	102	0.05			
66 kV G - 6 P.P.K GRID	WG6PN123	11kV FDR AWHO, SEC-22	TI-DWR037A-1	100	RESIDENTIAL		Functional	100%	10	0.01			
66 kV G - 6 P.P.K GRID	WG6PN107	11kV FDR SEC-8 DP + 11kV FDR SEC-9 PKT-2	TP-DWR120A-1	100	RESIDENTIAL		Functional	100%	3	0.01			
66 kV G - 6 P.P.K GRID	WG6PN132	11kV FDR INTELLIGENCE BUREAU, SEC-9 + GALI NO-11 RAJ NAGAR	660S09-DWR237A	100	RESIDENTIAL	AMR	Functional	100%	7	0.00			
66 kV G - 6 P.P.K GRID	WG6PN119	11kV FDR ARMY QTRS. SEC-21	TI-DWR003A-1	630	COMMERCIAL		Functional	100%	90	0.20	0.67	0.06	7.62%
66 kV G - 6 P.P.K GRID	WG6PN119	11kV FDR ARMY QTRS. SEC-21	TI-DWR004A-1	630	COMMERCIAL		Functional	100%	104	0.10			
66 kV G - 6 P.P.K GRID	WG6PN102	11kV FDR SEC-23, POLICE STATION	660S09-DWR198A	250	RESIDENTIAL		Functional	100%	1	0.09			

G-7 DWARKA GRID	WG7PN121	11kV FDR S/STN NO-1 MARBEL MARKET SECTOR 20 DWK	660509-DWR224A	630	RESIDENTIAL		Functional	100%	2	0.06			
66 kV G - 6 P.P.K GRID	WG6PN102	11kV FDR SEC-23, POLICE STATION	TP-DWR052A-1	400	COMMERCIAL	AMR	Functional	100%	1	0.05			
66 kV G - 6 P.P.K GRID	WG6PN119	11kV FDR ARMY QTRS. SEC-21	TG-DWR157A-1	400	COMMERCIAL	AMR	Functional	100%	6	0.04			
66 kV G - 6 P.P.K GRID	WG6PN119	11kV FDR ARMY QTRS. SEC-21	TP-DWR071A-1	400	RESIDENTIAL	AMR	Functional	100%	2	0.03			
G-7 DWARKA GRID	WG7PN121	11kV FDR S/STN NO-1 MARBEL MARKET SECTOR 20 DWK	660509-DWR225A	630	RESIDENTIAL		Functional	100%	9	0.03			
G-7 DWARKA GRID	WG7PN121	11kV FDR S/STN NO-1 MARBEL MARKET SECTOR 20 DWK	TG-DWR211A-2	630	RESIDENTIAL		Functional	100%	0	0.03			
G-7 DWARKA GRID	WG7PN121	11kV FDR S/STN NO-1 MARBEL MARKET SECTOR 20 DWK	TG-DWR211A-1	630	RESIDENTIAL		Functional	100%	17	0.03			
66 kV G - 6 P.P.K GRID	WG6PN102	11kV FDR SEC-23, POLICE STATION	TP-DWR209A-1	100	RESIDENTIAL		Functional	100%	1	0.03			
66 kV G - 6 P.P.K GRID	WG6PN119	11kV FDR ARMY QTRS. SEC-21	TP-DWR011A-1	400	COMMERCIAL	AMR	Functional	100%	12	0.02			
G-7 DWARKA GRID	WG7PN121	11kV FDR S/STN NO-1 MARBEL MARKET SECTOR 20 DWK	660509-DWR225A	630	RESIDENTIAL		Functional	100%	16	0.02			
G-7 DWARKA GRID	WG7PN121	11kV FDR S/STN NO-1 MARBEL MARKET SECTOR 20 DWK	660509-DWR222A	630	RESIDENTIAL		Functional	100%	2	0.01			
G-7 DWARKA GRID	WG7PN121	11kV FDR S/STN NO-1 MARBEL MARKET SECTOR 20 DWK	660509-DWR222A	630	RESIDENTIAL		Functional	100%	1	0.00			
G-7 DWARKA GRID	WG7PN121	11kV FDR S/STN NO-1 MARBEL MARKET SECTOR 20 DWK	660509-DWR226A	630	RESIDENTIAL		Functional	100%	0	0.00			
G-7 DWARKA GRID	WG7PN121	11kV FDR S/STN NO-1 MARBEL MARKET SECTOR 20 DWK	660509-DWR224A	630	MIXED		Functional	100%	0	0.00			
G-7 DWARKA GRID	WG7PN121	11kV FDR S/STN NO-1 MARBEL MARKET SECTOR 20 DWK	660509-DWR226A	630	MIXED		Functional	100%	0	0.00			
G-7 DWARKA GRID	WG7PN130	11kV FDR SPG COMPLEX SEC-21 NO-3	TP-DWR050A-1	400	RESIDENTIAL		Functional	100%	585	0.33	5.04	0.07	1.33%
G-7 DWARKA GRID	WG7PN112	11kV FDR INDIAN HOTEL SEC-21 PLM	TI-DWR001A-1	500	RESIDENTIAL		Functional	100%	190	0.25			
66 kV G - 6 P.P.K GRID	WG6PN102	11kV FDR SEC-23, POLICE STATION	TI-DWR002A-1	400	RESIDENTIAL		Functional	100%	203	0.24			
66 kV G - 6 P.P.K GRID	WG6PN102	11kV FDR SEC-23, POLICE STATION	TP-DWR158A-1	400	RESIDENTIAL		Functional	100%	148	0.21			
66 kV G - 6 P.P.K GRID	WG6PN102	11kV FDR SEC-23, POLICE STATION	TI-DWR145A-2	630	RESIDENTIAL		Functional	100%	0	0.19			
66 kV G - 6 P.P.K GRID	WG6PN126	11kV FDR RANJEET VIHAR(SEC-23)	TG-DWR188A-1	630	RESIDENTIAL		Functional	100%	0	0.16			
66 kV G - 6 P.P.K GRID	WG6PN102	11kV FDR SEC-23, POLICE STATION	TP-DWR073A-2	400	RESIDENTIAL		Functional	100%	95	0.14			
G-7 DWARKA GRID	WG7PN112	11kV FDR INDIAN HOTEL SEC-21 PLM	TG-MNP111A-1	630	RESIDENTIAL		Functional	100%	47	0.14			
66 kV G - 6 P.P.K GRID	WG6PN102	11kV FDR SEC-23, POLICE STATION	TG-DWR133A-2	630	RESIDENTIAL		Functional	100%	65	0.13			
G-7 DWARKA GRID	WG7PN130	11kV FDR SPG COMPLEX SEC-21 NO-3	660509-DWR050A	630	MIXED		Functional	100%	0	0.13			
66 kV G - 6 P.P.K GRID	WG6PN102	11kV FDR SEC-23, POLICE STATION	TG-DWR233A-2	630	RESIDENTIAL		Functional	100%	81	0.13			
66 kV G - 6 P.P.K GRID	WG6PN120	11kV FDR D.D.A FLATS,SEC-23	TG-DWR215A-1	630	RESIDENTIAL		Functional	100%	67	0.12			
66 kV G - 6 P.P.K GRID	WG6PN112	11kV FDR EPFO SEC-23	TG-DWR067A-2	630	RESIDENTIAL		Functional	100%	0	0.12			
66 kV G - 6 P.P.K GRID	WG6PN112	11kV FDR EPFO SEC-23	TI-DWR088A-1	630	RESIDENTIAL		Functional	100%	43	0.11			
66 kV G - 6 P.P.K GRID	WG6PN112	11kV FDR SECTOR-23 EPFO	TI-DWR021B-1	630	RESIDENTIAL		Functional	100%	0	0.11			
66 kV G - 6 P.P.K GRID	WG6PN126	11kV FDR RANJEET VIHAR(SEC-23)	TI-DWR047A-2	630	RESIDENTIAL		Functional	100%	150	0.11			
66 kV G - 6 P.P.K GRID	WG6PN102	11kV FDR SEC-23, POLICE STATION	TG-DWR233A-1	630	RESIDENTIAL		Functional	100%	87	0.10			
66 kV G - 6 P.P.K GRID	WG6PN102	11kV FDR SEC-23, POLICE STATION	TI-DWR145A-1	630	RESIDENTIAL		Functional	100%	214	0.10			
66 kV G - 6 P.P.K GRID	WG6PN112	11kV FDR EPFO SEC-23	TI-DWR088A-2	630	RESIDENTIAL		Functional	100%	36	0.09			
66 kV G - 6 P.P.K GRID	WG6PN112	11kV FDR EPFO SEC-23	TG-DWR201A-3	630	RESIDENTIAL		Functional	100%	0	0.09			
66 kV G - 6 P.P.K GRID	WG6PN112	11kV FDR EPFO SEC-23	TG-DWR058A-2	630	RESIDENTIAL		Functional	100%	1	0.09			
66 kV G - 6 P.P.K GRID	WG6PN112	11kV FDR EPFO SEC-23	TG-DWR201A-1	630	RESIDENTIAL		Functional	100%	182	0.09			
66 kV G - 6 P.P.K GRID	WG6PN112	11kV FDR EPFO SEC-23	TG-DWR058A-1	630	RESIDENTIAL		Functional	100%	0	0.09			
66 kV G - 6 P.P.K GRID	WG6PN126	11kV FDR RANJEET VIHAR(SEC-23)	TI-DWR048A-2	630	RESIDENTIAL		Functional	100%	109	0.09			
66 kV G - 6 P.P.K GRID	WG6PN126	11kV FDR RANJEET VIHAR(SEC-23)	TG-DWR188A-2	630	RESIDENTIAL		Functional	100%	0	0.08			
66 kV G - 6 P.P.K GRID	WG6PN112	11kV FDR EPFO SEC-23	TG-DWR058A-3	630	RESIDENTIAL		Functional	100%	103	0.08			
66 kV G - 6 P.P.K GRID	WG6PN112	11kV FDR EPFO SEC-23	TG-DWR067A-3	630	RESIDENTIAL		Functional	100%	166	0.08			
66 kV G - 6 P.P.K GRID	WG6PN112	11kV FDR EPFO SEC-23	TI-DWR021A-2	630	RESIDENTIAL		Functional	100%	164	0.08			
66 kV G - 6 P.P.K GRID	WG6PN102	11kV FDR SEC-23, POLICE STATION	TG-DWR133A-1	630	RESIDENTIAL		Functional	100%	60	0.08			
66 kV G - 6 P.P.K GRID	WG6PN102	11kV FDR SEC-23, POLICE STATION	TP-DWR187A-1	400	RESIDENTIAL		Functional	100%	17	0.08			
66 kV G - 6 P.P.K GRID	WG6PN126	11kV FDR RANJEET VIHAR(SEC-23)	TG-DWR188A-3	630	RESIDENTIAL		Functional	100%	0	0.07			
66 kV G - 6 P.P.K GRID	WG6PN126	11kV FDR RANJEET VIHAR(SEC-23)	TI-DWR031A-1	630	RESIDENTIAL		Functional	100%	0	0.07			
66 kV G - 6 P.P.K GRID	WG6PN102	11kV FDR SEC-23, POLICE STATION	TP-DWR073A-1	400	RESIDENTIAL		Functional	100%	82	0.07			
66 kV G - 6 P.P.K GRID	WG6PN126	11kV FDR RANJEET VIHAR(SEC-23)	TG-DWR188A-4	630	RESIDENTIAL		Functional	100%	221	0.07			
66 kV G - 6 P.P.K GRID	WG6PN120	11kV FDR D.D.A FLATS,SEC-23	TI-DWR143A-1	400	RESIDENTIAL		Functional	100%	100	0.07			

66 kv G - 6 P.P.K GRID	WG6PN126	11kv FDR RANJEET VIHAR(SEC-23)	TG-DWR202A-2	400	RESIDENTIAL		Functional	100%	22	0.07			
66 kv G - 6 P.P.K GRID	WG6PN126	11kv FDR RANJEET VIHAR(SEC-23)	TG-DWR202A-1	400	RESIDENTIAL		Functional	100%	46	0.06			
66 kv G - 6 P.P.K GRID	WG6PN112	11kv FDR EPFO SEC-23	TG-DWR201A-2	630	RESIDENTIAL		Functional	100%	0	0.06			
G-7 DWARKA GRID	WG7PN112	11kv FDR INDIAN HOTEL SEC-21 PLM	TP-DWR065A-1	400	RESIDENTIAL		Functional	100%	98	0.06			
66 kv G - 6 P.P.K GRID	WG6PN126	11kv FDR RANJEET VIHAR(SEC-23)	TI-DWR047A-1	630	RESIDENTIAL		Functional	100%	0	0.06			
66 kv G - 6 P.P.K GRID	WG6PN126	11kv FDR RANJEET VIHAR(SEC-23)	TI-DWR048A-1	630	RESIDENTIAL		Functional	100%	0	0.06			
66 kv G - 6 P.P.K GRID	WG6PN126	11kv FDR RANJEET VIHAR(SEC-23)	TI-DWR031A-2	630	RESIDENTIAL		Functional	100%	85	0.05			
G-7 DWARKA GRID	WG7PN112	11kv FDR INDIAN HOTEL SEC-21 PLM	TP-DWR070A-2	400	RESIDENTIAL		Functional	100%	82	0.05			
66 kv G - 6 P.P.K GRID	WG6PN120	11kv FDR D.D.A FLATS,SEC-23	TG-DWR143A-2	400	RESIDENTIAL		Functional	100%	0	0.05			
66 kv G - 6 P.P.K GRID	WG6PN120	11kv FDR D.D.A FLATS,SEC-23	TG-DWR215A-2	630	RESIDENTIAL		Functional	100%	56	0.05			
66 kv G - 6 P.P.K GRID	WG6PN120	11kv FDR D.D.A FLATS,SEC-23	TP-DWR185A-1	400	RESIDENTIAL		Functional	100%	1	0.05			
66 kv G - 6 P.P.K GRID	WG6PN120	11kv FDR D.D.A FLATS,SEC-23	TP-DWR186A-1	100	RESIDENTIAL		Functional	100%	1	0.05			
66 kv G - 6 P.P.K GRID	WG6PN126	11kv FDR RANJEET VIHAR(SEC-23)	TI-DWR049A-1	630	RESIDENTIAL		Functional	100%	0	0.05			
66 kv G - 6 P.P.K GRID	WG6PN126	11kv FDR RANJEET VIHAR(SEC-23)	TI-DWR049A-2	630	RESIDENTIAL		Functional	100%	66	0.05			
66 kv G - 6 P.P.K GRID	WG6PN112	11kv FDR EPFO SEC-23	TG-DWR067A-1	630	RESIDENTIAL		Functional	100%	0	0.04			
G-7 DWARKA GRID	WG7PN112	11kv FDR INDIAN HOTEL SEC-21 PLM	TP-DWR065A-2	400	RESIDENTIAL		Functional	100%	0	0.04			
66 kv G - 6 P.P.K GRID	WG6PN112	11kv FDR EPFO SEC-23	TI-DWR021A-1	630	RESIDENTIAL		Functional	100%	0	0.03			
G-7 DWARKA GRID	WG7PN112	11kv FDR INDIAN HOTEL SEC-21 PLM	TP-DWR070A-1	400	RESIDENTIAL		Functional	100%	0	0.03			
66 kv G - 6 P.P.K GRID	WG6PN102	11kv FDR SEC-23, POLICE STATION	TI-DWR144A-1	630	RESIDENTIAL		Functional	100%	10	0.02			
66 kv G - 6 P.P.K GRID	WG6PN120	11kv FDR D.D.A FLATS,SEC-23	TP-DWR063A-1	400	RESIDENTIAL	AMR	Functional	100%	7	0.02			
G-7 DWARKA GRID	WG7PN130	11kv FDR SPG COMPLEX SEC-21 NO-3	TP-DWR190A-1	100	RESIDENTIAL		Functional	100%	4	0.02			
G-7 DWARKA GRID	WG7PN112	11kv FDR INDIAN HOTEL SEC-21 PLM	TG-MNP111A-2	630	MIXED		Functional	100%	53	0.00			
66 kv G - 4 DWARKA GRID	WG4PN103	11kv FDR MANISH PLAZA SECTOR-23	TI-DWR151A-1	630	RESIDENTIAL		Functional	100%	20	0.22	2.65	0.03	1.30%
66 kv G - 6 P.P.K GRID	WG6PN102	11kv FDR SEC-23, POLICE STATION	TP-DWR125A-2	400	RESIDENTIAL		Functional	100%	177	0.22			
66 kv G - 6 P.P.K GRID	WG6PN103	11kv FDR CAMMAND TANK-4, SECTOR-20	TP-DWR189A-1	400	RESIDENTIAL		Functional	100%	26	0.21			
66 kv G - 6 P.P.K GRID	WG6PN103	11kv FDR CAMMAND TANK-4, SECTOR-20	TG-DWR101A-1	400	RESIDENTIAL		Functional	100%	52	0.21			
66 kv G - 6 P.P.K GRID	WG6PN120	11kv FDR D.D.A FLATS,SEC-23	TI-DWR023A-2	630	RESIDENTIAL		Functional	100%	23	0.18			
66 kv G - 4 DWARKA GRID	WG4PN103	11kv FDR MANISH PLAZA SECTOR-23	TI-DWR024A-1	630	COMMERCIAL		Functional	100%	116	0.13			
66 kv G - 6 P.P.K GRID	WG6PN120	11kv FDR D.D.A FLATS,SEC-23	TI-DWR023A-1	630	RESIDENTIAL		Functional	100%	288	0.13			
66 kv G - 4 DWARKA GRID	WG4PN103	11kv FDR MANISH PLAZA SECTOR-23	TG-DWR026A-1	630	RESIDENTIAL		Functional	100%	0	0.10			
66 kv G - 6 P.P.K GRID	WG6PN103	11kv FDR CAMMAND TANK-4, SECTOR-20	TI-DWR149A-3	630	RESIDENTIAL		Functional	100%	0	0.09			
66 kv G - 4 DWARKA GRID	WG4PN103	11kv FDR MANISH PLAZA SECTOR-23	TG-DWR026A-2	630	RESIDENTIAL		Functional	100%	160	0.09			
66 kv G - 6 P.P.K GRID	WG6PN120	11kv FDR D.D.A FLATS,SEC-23	TI-DWR022A-1	400	RESIDENTIAL		Functional	100%	216	0.08			
66 kv G - 6 P.P.K GRID	WG6PN103	11kv FDR CAMMAND TANK-4, SECTOR-20	TI-DWR149A-1	630	RESIDENTIAL		Functional	100%	187	0.08			
66 kv G - 6 P.P.K GRID	WG6PN103	11kv FDR CAMMAND TANK-4, SECTOR-20	TP-DWR062A-1	400	RESIDENTIAL		Functional	100%	0	0.08			
66 kv G - 6 P.P.K GRID	WG6PN103	11kv FDR CAMMAND TANK-4, SECTOR-20	TI-DWR148A-1	630	RESIDENTIAL		Functional	100%	98	0.07			
66 kv G - 6 P.P.K GRID	WG6PN103	11kv FDR CAMMAND TANK-4, SECTOR-20	TG-DWR030A-1	630	RESIDENTIAL		Functional	100%	183	0.07			
66 kv G - 6 P.P.K GRID	WG6PN103	11kv FDR CAMMAND TANK-4, SECTOR-20	TI-DWR149A-2	630	RESIDENTIAL		Functional	100%	0	0.07			
66 kv G - 6 P.P.K GRID	WG6PN102	11kv FDR SEC-23, POLICE STATION	TP-DWR036A-1	400	RESIDENTIAL		Functional	100%	1	0.07			
66 kv G - 4 DWARKA GRID	WG4PN103	11kv FDR MANISH PLAZA SECTOR-23	TI-DWR025A-2	400	RESIDENTIAL		Functional	100%	67	0.06			
66 kv G - 6 P.P.K GRID	WG6PN120	11kv FDR D.D.A FLATS,SEC-23	TI-DWR022A-2	630	RESIDENTIAL		Functional	100%	0	0.06			
66 kv G - 6 P.P.K GRID	WG6PN103	11kv FDR CAMMAND TANK-4, SECTOR-20	TI-DWR148A-2	630	RESIDENTIAL		Functional	100%	0	0.06			
66 kv G - 6 P.P.K GRID	WG6PN103	11kv FDR CAMMAND TANK-4, SECTOR-20	660509-DWR030A	630	RESIDENTIAL		Functional	100%	0	0.05			
66 kv G - 4 DWARKA GRID	WG4PN103	11kv FDR MANISH PLAZA SECTOR-23	TI-DWR025A-1	400	RESIDENTIAL		Functional	100%	2	0.05			
66 kv G - 4 DWARKA GRID	WG4PN103	11kv FDR MANISH PLAZA SECTOR-23	TG-DWR205A-1	630	COMMERCIAL		Functional	100%	78	0.05			
66 kv G - 6 P.P.K GRID	WG6PN112	11kv FDR EPFO SEC-23	TG-DWR169A-1	400	RESIDENTIAL		Functional	100%	33	0.05			
66 kv G - 4 DWARKA GRID	WG4PN103	11kv FDR MANISH PLAZA SECTOR-23	TG-DWR205A-2	630	RESIDENTIAL		Functional	100%	0	0.04			
66 kv G - 6 P.P.K GRID	WG6PN112	11kv FDR EPFO SEC-23	TP-DWR194A-1	250	RESIDENTIAL		Functional	100%	2	0.04			
66 kv G - 6 P.P.K GRID	WG6PN112	11kv FDR EPFO SEC-23	TP-DWR195A-1	250	RESIDENTIAL		Functional	100%	1	0.03			
66 kv G - 6 P.P.K GRID	WG6PN103	11kv FDR CAMMAND TANK-4, SECTOR-20	TP-DWR062A-2	400	MIXED		Functional	100%	61	0.03			

66 kv G - 6 P.P.K GRID	WG6PN102	11kv FDR SEC-23, POLICE STATION	TP-DWR036A-2	400	RESIDENTIAL	Functional	100%	18	0.02			
66 kv G - 6 P.P.K GRID	WG6PN103	11kv FDR CAMMAND TANK-4, SECTOR-20	TP-DWR130A-1	100	RESIDENTIAL	Functional	100%	162	0.01			
66 kv G - 6 P.P.K GRID	WG6PN102	11kv FDR SEC-23, POLICE STATION	660509-DWR261A	400	RESIDENTIAL	Functional	100%	0	0.01			
G-7 DWARKA GRID	WG7PN108	11kv FDR DTC DEPOT	TG-DWR208A-1	630	RESIDENTIAL	Functional	100%	12	0.26	0.49	0.03	6.00%
G-7 DWARKA GRID	WG7PN108	11kv FDR DTC DEPOT	TP-DWR179A-1	400	COMMERCIAL	Functional	100%	1	0.12			
G-7 DWARKA GRID	WG7PN108	11kv FDR DTC DEPOT	TP-DWR177A-2	315	COMMERCIAL	Functional	100%	0	0.08			
66 kv G - 6 P.P.K GRID	WG6PN119	11kv FDR ARMY QTRS. SEC-21	TP-DWR057A-1	100	RESIDENTIAL	Functional	100%	2	0.03			
G-7 DWARKA GRID	WG7PN108	11kv FDR DTC DEPOT	TP-DWR175A-1	100	COMMERCIAL	Functional	100%	4	0.01			
G-7 DWARKA GRID	WG7PN108	11kv FDR DTC DEPOT	TP-DWR176A-1	100	RESIDENTIAL	Functional	100%	4	0.01			
G-7 DWARKA GRID	WG7PN108	11kv FDR DTC DEPOT	TP-DWR177A-1	100	COMMERCIAL	Functional	100%	2	0.01			
66 kv G - 6 P.P.K GRID	WG6PN107	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	TP-DWR142A-1	100	COMMERCIAL	Functional	100%	2	0.01			
66 kv G - 6 P.P.K GRID	WG6PN129	11kv FDR OLD G-BLOCK RAJ NAGAR	TG-DWR111A-1	630	RESIDENTIAL	Functional	100%	148	0.40	3.70	0.06	1.50%
66 kv G - 6 P.P.K GRID	WG6PN107	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	TI-DWR043A-2	400	RESIDENTIAL	Functional	100%	169	0.17			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	TP-DWR180A-1	250	RESIDENTIAL	Functional	100%	2	0.16			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	TI-DWR038A-1	400	RESIDENTIAL	Functional	100%	159	0.16			
66 kv G - 6 P.P.K GRID	WG6PN107	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	TI-DWR043A-1	630	RESIDENTIAL	Functional	100%	0	0.15			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	TI-DWR040A-1	400	RESIDENTIAL	Functional	100%	188	0.12			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	TI-DWR039A-2	630	RESIDENTIAL	Functional	100%	0	0.12			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	TI-DWR034A-1	630	RESIDENTIAL	Functional	100%	135	0.11			
66 kv G - 6 P.P.K GRID	WG6PN127	11kv FDR PARADISE APPT. SEC.-9	TI-DWR046A-1	630	RESIDENTIAL	Functional	100%	114	0.11			
66 kv G - 6 P.P.K GRID	WG6PN107	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	TI-DWR041A-2	630	RESIDENTIAL	Functional	100%	195	0.10			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	TI-DWR039A-1	400	RESIDENTIAL	Functional	100%	171	0.10			
66 kv G - 6 P.P.K GRID	WG6PN127	11kv FDR PARADISE APPT. SEC.-9	TI-DWR045A-1	630	RESIDENTIAL	Functional	100%	109	0.10			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	TI-DWR034A-2	630	RESIDENTIAL	Functional	100%	0	0.10			
66 kv G - 6 P.P.K GRID	WG6PN107	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	TP-DWR018A-1	400	RESIDENTIAL	Functional	100%	0	0.10			
66 kv G - 6 P.P.K GRID	WG6PN107	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	TI-DWR042A-2	630	RESIDENTIAL	Functional	100%	0	0.09			
66 kv G - 6 P.P.K GRID	WG6PN127	11kv FDR PARADISE APPT. SEC.-9	TI-DWR044A-2	630	RESIDENTIAL	Functional	100%	106	0.09			
66 kv G - 6 P.P.K GRID	WG6PN127	11kv FDR PARADISE APPT. SEC.-9	TI-DWR152A-1	630	RESIDENTIAL	Functional	100%	0	0.09			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	660509-DWR086A	630	RESIDENTIAL	Functional	100%	0	0.08			
66 kv G - 6 P.P.K GRID	WG6PN127	11kv FDR PARADISE APPT. SEC.-9	TG-DWR035A-2	630	RESIDENTIAL	Functional	100%	0	0.08			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	TI-DWR038A-2	630	RESIDENTIAL	Functional	100%	0	0.07			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	660509-DWR086A	630	RESIDENTIAL	Functional	100%	99	0.07			
66 kv G - 6 P.P.K GRID	WG6PN127	11kv FDR PARADISE APPT. SEC.-9	TI-DWR045A-2	630	RESIDENTIAL	Functional	100%	0	0.07			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	TI-DWR040A-2	630	RESIDENTIAL	Functional	100%	0	0.07			
66 kv G - 6 P.P.K GRID	WG6PN107	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	TI-DWR041A-1	630	RESIDENTIAL	Functional	100%	0	0.07			
66 kv G - 6 P.P.K GRID	WG6PN107	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	TP-DWR095A-2	400	RESIDENTIAL	Functional	100%	36	0.07			
66 kv G - 6 P.P.K GRID	WG6PN107	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	TP-DWR018A-2	400	RESIDENTIAL	Functional	100%	123	0.06			
66 kv G - 6 P.P.K GRID	WG6PN127	11kv FDR PARADISE APPT. SEC.-9	TI-DWR044A-1	400	RESIDENTIAL	Functional	100%	0	0.06			
66 kv G - 6 P.P.K GRID	WG6PN127	11kv FDR PARADISE APPT. SEC.-9	TG-DWR035A-1	630	RESIDENTIAL	Functional	100%	135	0.06			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	TG-DWR126A-2	630	RESIDENTIAL	Functional	100%	0	0.06			
66 kv G - 6 P.P.K GRID	WG6PN127	11kv FDR PARADISE APPT. SEC.-9	TI-DWR152A-2	630	RESIDENTIAL	Functional	100%	104	0.06			
66 kv G - 6 P.P.K GRID	WG6PN107	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	TP-DWR098A-1	400	RESIDENTIAL	Functional	100%	36	0.06			
66 kv G - 6 P.P.K GRID	WG6PN107	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	TI-DWR042A-1	630	RESIDENTIAL	Functional	100%	199	0.06			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	TG-DWR126A-1	630	RESIDENTIAL	Functional	100%	89	0.06			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	TI-DWR053A-2	400	RESIDENTIAL	Functional	100%	68	0.05			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	TI-DWR053A-1	400	RESIDENTIAL	Functional	100%	0	0.05			
G-7 DWARKA GRID	WG7PN118	11kv FDR POLICE TRAINING CENTRE SEC -9	TG-DWR231A-3	630	RESIDENTIAL	Functional	100%	0	0.05			
G-7 DWARKA GRID	WG7PN118	11kv FDR POLICE TRAINING CENTRE SEC -9	TG-DWR231A-2	630	RESIDENTIAL	Functional	100%	0	0.05			
G-7 DWARKA GRID	WG7PN118	11kv FDR POLICE TRAINING CENTRE SEC -9	TG-DWR231A-4	630	RESIDENTIAL	Functional	100%	0	0.04			
66 kv G - 6 P.P.K GRID	WG6PN118	11kv FDR RAJ NAGAR	660509-DWR259A	250	MIXED	Functional	100%	0	0.03			

66 kv G - 6 P.P.K GRID	WG6PN106	11kv STR 400KVA STATION TRANSFORMER	PM-WTC114A-1	400	RESIDENTIAL		Functional	100%	1	0.03			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	TG-DWR005A-2	630	RESIDENTIAL		Functional	100%	0	0.03			
G-7 DWARKA GRID	WG7PN119	11kv FDR INTELLIGENCE BUREAU SECTOR-9	660509-DWR244A	630	MIXED		Functional	100%	0	0.02			
66 kv G - 6 P.P.K GRID	WG6PN111	11kv FDR SEC-9, PKT-1	TG-DWR005A-1	630	MIXED		Functional	100%	14	0.02			
66 kv G - 6 P.P.K GRID	WG6PN107	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	TP-DWR095A-1	400	RESIDENTIAL		Functional	100%	0	0.02			
G-7 DWARKA GRID	WG7PN118	11kv FDR POLICE TRAINING CENTRE SEC -9	TG-DWR231A-1	630	RESIDENTIAL		Functional	100%	0	0.01			
220kv PAPPAN KALAN 2 GRID	WPK12104	11kv STR 400KVA STATION TRANSFORMER-2	TG-WTC023A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.01			
66 kv G - 6 P.P.K GRID	WG6PN107	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	660509-DWR248A	100	RESIDENTIAL		Functional	100%	8	0.01			
G-7 DWARKA GRID	WG7PN108	11kv FDR DTC DEPOT	660509-DWR257A	250	RESIDENTIAL		Functional	100%	1	0.01			
66 kv G - 6 P.P.K GRID	WG6PN107	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	TG-DWR006A-1	400	RESIDENTIAL		Functional	100%	1	0.00			
66 kv G - 6 P.P.K GRID	WG6PN107	11kv FDR SEC-8 DP + 11kv FDR SEC-9 PKT-2	TP-DWR219A-1	250	COMMERCIAL		Functional	100%	1	0.00			
66 kv G - 6 P.P.K GRID	WG6PN124	11kv FDR CROWN APPTS. SEC-7 PLM	TI-MNP060A-2	630	RESIDENTIAL		Functional	100%	896	0.55	2.23	0.22	9.06%
66 kv G - 6 P.P.K GRID	WG6PN124	11kv FDR CROWN APPTS. SEC-7 PLM	TI-MNP060A-1	630	RESIDENTIAL		Functional	100%	0	0.37			
66 kv G - 6 P.P.K GRID	WG6PN124	11kv FDR CROWN APPTS. SEC-7 PLM	TI-MNP061A-2	630	RESIDENTIAL		Functional	100%	773	0.30			
66 kv G - 6 P.P.K GRID	WG6PN124	11kv FDR CROWN APPTS. SEC-7 PLM	TI-MNP061A-1	400	RESIDENTIAL		Functional	100%	45	0.28			
G-7 DWARKA GRID	WG7PN129	11kv FDR SARGODHA VIHAR SEC-7 (PLM)	TG-MNP114A-1	630	RESIDENTIAL		Functional	100%	161	0.19			
66 kv G - 6 P.P.K GRID	WG6PN124	11kv FDR CROWN APPTS. SEC-7 PLM	TP-MNP082A-1	400	RESIDENTIAL		Functional	100%	94	0.15			
66 kv G - 6 P.P.K GRID	WG6PN124	11kv FDR CROWN APPTS. SEC-7 PLM	TI-MNP074A-1	630	RESIDENTIAL		Functional	100%	112	0.14			
66 kv G - 6 P.P.K GRID	WG6PN124	11kv FDR CROWN APPTS. SEC-7 PLM	TI-DWR059A-2	630	RESIDENTIAL		Functional	100%	0	0.14			
G-7 DWARKA GRID	WG7PN129	11kv FDR SARGODHA VIHAR SEC-7 (PLM)	TG-MNP073A-1	630	RESIDENTIAL		Functional	100%	141	0.13			
66 kv G - 6 P.P.K GRID	WG6PN124	11kv FDR CROWN APPTS. SEC-7 PLM	TI-MNP074A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.10			
66 kv G - 6 P.P.K GRID	WG6PN124	11kv FDR CROWN APPTS. SEC-7 PLM	TI-DWR059A-1	630	RESIDENTIAL		Functional	100%	196	0.09			
66 kv G - 6 P.P.K GRID	WG6PN124	11kv FDR CROWN APPTS. SEC-7 PLM	TP-MNP072A-1	100	RESIDENTIAL		Functional	100%	1	0.01			
G-7 DWARKA GRID	WG7PN106	11kv FDR HARIJAN BASTI EXT.	TG-MNP055A-1	1600	RESIDENTIAL		Functional	100%	0	1.23	10.37	1.05	9.22%
G-7 DWARKA GRID	WG7PN128	11kv FDR MANGLAPURI NO-2 VIA RAMPHAL CHOWK	TG-MNP054A-1	990	RESIDENTIAL	AMR	Functional	100%	935	0.97			
G-7 DWARKA GRID	WG7PN106	11kv FDR HARIJAN BASTI EXT.	TG-MNP055A-2	990	RESIDENTIAL		Functional	100%	1041	0.88			
G-7 DWARKA GRID	WG7PN106	11kv FDR HARIJAN BASTI EXT.	TG-MNP080A-1	990	RESIDENTIAL		Functional	100%	561	0.81			
G-7 DWARKA GRID	WG7PN129	11kv FDR SARGODHA VIHAR SEC-7 (PLM)	TG-MNP081A-1	990	RESIDENTIAL	AMR	Functional	100%	529	0.70			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN111	11kv FDR RMU NO.-2	TG-MNP130A-1	630	RESIDENTIAL		Functional	100%	561	0.59			
G-7 DWARKA GRID	WG7PN114	11kv FDR HARIJAN BASTI NEW GADDEWALA	TG-MNP056A-1	990	RESIDENTIAL		Functional	100%	16	0.59			
G-7 DWARKA GRID	WG7PN114	11kv FDR HARIJAN BASTI NEW GADDEWALA	TG-MNP056A-3	990	RESIDENTIAL		Functional	100%	0	0.57			
G-7 DWARKA GRID	WG7PN106	11kv FDR HARIJAN BASTI EXT.	560MLP-MNP145A	630	RESIDENTIAL		Functional	100%	270	0.56			
220kv PAPPAN KALAN-1 GRID	TDTPG113	11kv FDR EVERGEEN	TG-MNP132A-1	630	RESIDENTIAL		Functional	100%	540	0.50			
220kv PAPPAN KALAN-1 GRID	TDTPG113	11kv FDR EVERGEEN	TG-MNP078A-1	990	RESIDENTIAL		Functional	100%	218	0.48			
G-7 DWARKA GRID	WG7PN114	11kv FDR HARIJAN BASTI NEW GADDEWALA	TG-MNP056A-2	990	RESIDENTIAL		Functional	100%	701	0.44			
G-7 DWARKA GRID	WG7PN106	11kv FDR HARIJAN BASTI EXT.	TP-MNP137A-1	400	RESIDENTIAL		Functional	100%	260	0.43			
G-7 DWARKA GRID	WG7PN107	11kv FDR S/STN.2 SEC-7	TI-MNP075A-1	400	RESIDENTIAL		Functional	100%	288	0.34			
G-7 DWARKA GRID	WG7PN129	11kv FDR SARGODHA VIHAR SEC-7 (PLM)	TP-MNP131A-1	400	RESIDENTIAL		Functional	100%	183	0.33			
220kv PAPPAN KALAN-1 GRID	TDTPG112	11kv FDR PAPPANKALAN SECTOR-7	TI-DWR014A-1	400	RESIDENTIAL		Functional	100%	210	0.23			
220kv PAPPAN KALAN-1 GRID	TDTPG113	11kv FDR EVERGEEN	TI-DWR016A-1	400	RESIDENTIAL		Functional	100%	191	0.22			
G-7 DWARKA GRID	WG7PN129	11kv FDR SARGODHA VIHAR SEC-7 (PLM)	TP-MNP131A-2	400	RESIDENTIAL		Functional	100%	174	0.21			
G-7 DWARKA GRID	WG7PN106	11kv FDR HARIJAN BASTI EXT.	TG-MNP077A-1	630	RESIDENTIAL		Functional	100%	0	0.18			
220kv PAPPAN KALAN-1 GRID	TDTPG112	11kv FDR PAPPANKALAN SECTOR-7	TI-DWR015A-1	630	RESIDENTIAL		Functional	100%	121	0.17			
G-7 DWARKA GRID	WG7PN129	11kv FDR SARGODHA VIHAR SEC-7 (PLM)	TG-MNP085A-1	630	RESIDENTIAL		Functional	100%	205	0.16			
G-7 DWARKA GRID	WG7PN107	11kv FDR S/STN.2 SEC-7	TI-DWR028A-1	400	RESIDENTIAL		Functional	100%	397	0.12			
G-7 DWARKA GRID	WG7PN107	11kv FDR S/STN.2 SEC-7	560MLP-DWR028A	630	MIXED		Functional	100%	0	0.09			
G-7 DWARKA GRID	WG7PN114	11kv FDR HARIJAN BASTI NEW GADDEWALA	TI-MNP084A-2	400	RESIDENTIAL		Functional	100%	0	0.09			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN104	11kv FDR HARSUKH APPTT.	TP-MNP083A-1	400	RESIDENTIAL		Functional	100%	0	0.08			
220kv PAPPAN KALAN-1 GRID	TDTPG112	11kv FDR PAPPANKALAN SECTOR-7	TI-DWR015A-2	400	RESIDENTIAL		Functional	100%	0	0.07			

G-7 DWARKA GRID	WG7PN114	11kV FDR HARIJAN BASTI NEW GADDEWALA	TI-MNP084A-1	400	RESIDENTIAL		Functional	100%	184	0.06			
G-7 DWARKA GRID	WG7PN114	11kV FDR HARIJAN BASTI NEW GADDEWALA	TI-MNP089A-2	400	RESIDENTIAL		Functional	100%	3	0.06			
G-7 DWARKA GRID	WG7PN106	11kV FDR HARIJAN BASTI EXT.	TG-MNP077A-2	630	RESIDENTIAL		Functional	100%	11	0.06			
G-7 DWARKA GRID	WG7PN114	11kV FDR HARIJAN BASTI NEW GADDEWALA	TI-MNP089A-1	400	RESIDENTIAL		Functional	100%	64	0.05			
G-7 DWARKA GRID	WG7PN114	11kV FDR HARIJAN BASTI NEW GADDEWALA	TP-MNP115A-1	100	RESIDENTIAL		Functional	100%	4	0.04			
G-7 DWARKA GRID	WG7PN117	11kV STR 400KVA STATION TRANSFORMER	660MLP-WTC120A	400	COMMERCIAL	AMR	Functional	100%	1	0.04			
220kV PAPPAN KALAN-1 GRID	TDTPG112	11kV FDR PAPPANKALAN SECTOR-7	TP-MNP090A-1	100	RESIDENTIAL		Functional	100%	1	0.04			
220kV PAPPAN KALAN-1 GRID	TDTPG113	11kV FDR EVERGEEN	TP-MNP091A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN104	11kV FDR HARSUKH APPTT.	TP-MNP083A-2	400	RESIDENTIAL		Functional	100%	54	0.01			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN123	11kV FDR PALAM CHOWK	TG-MNP051A-1	990	RESIDENTIAL		Functional	100%	1842	0.96	8.37	0.02	0.30%
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN122	11kV FDR PURAN NAGAR	TP-MNP049A-1	990	RESIDENTIAL		Functional	100%	1240	0.87			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN123	11kV FDR PALAM CHOWK	TG-MNP050A-1	990	RESIDENTIAL		Functional	100%	1320	0.72			
G-7 DWARKA GRID	WG7PN107	11kV FDR SSTN.NO.-2 SECTOR-7 (PLM.)	660MLP-MNP057B	990	RESIDENTIAL		Functional	100%	0	0.71			
G-7 DWARKA GRID	WG7PN107	11kV FDR S/STN.2 SEC-7	TG-MNP121A-1	630	RESIDENTIAL		Functional	100%	374	0.59			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN130	11kV FDR COMMAND TANK 1 DWK 7	TG-MNP119A-1	990	RESIDENTIAL		Functional	100%	291	0.57			
G-7 DWARKA GRID	WG7PN107	11kV FDR S/STN.2 SEC-7	TG-MNP086A-1	990	RESIDENTIAL		Functional	100%	1263	0.55			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN123	11kV FDR PALAM CHOWK	TP-MNP052A-1	990	RESIDENTIAL		Functional	100%	515	0.53			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN130	11kV FDR COMMAND TANK 1 DWK 7	TG-MNP053A-1	630	RESIDENTIAL		Functional	100%	670	0.44			
G-7 DWARKA GRID	WG7PN107	11kV FDR S/STN.2 SEC-7	TG-MNP086A-2	990	RESIDENTIAL		Functional	100%	0	0.41			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN123	11kV FDR PALAM CHOWK	TG-MNP051A-2	990	RESIDENTIAL		Functional	100%	28	0.35			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN123	11kV FDR PALAM CHOWK	660MLP-MNP141A	630	RESIDENTIAL		Functional	100%	199	0.32			
220kV PAPPAN KALAN-1 GRID	TDTPG112	11kV FDR PAPPANKALAN SECTOR-7	TG-MNP079A-1	400	RESIDENTIAL		Functional	100%	389	0.25			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN111	11kV FDR RMU NO.-2	660MLP-MNP147A	400	RESIDENTIAL		Functional	100%	6	0.25			
220kV PAPPAN KALAN-1 GRID	TDTPG112	11kV FDR PAPPANKALAN SECTOR-7	660MLP-MNP079A	630	MIXED		Functional	100%	0	0.22			
G-7 DWARKA GRID	WG7PN107	11kV FDR S/STN.2 SEC-7	660MLP-MNP057A	990	RESIDENTIAL		Functional	100%	873	0.12			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN111	11kV FDR RMU NO.-2	660MLP-MNP148A	400	RESIDENTIAL		Functional	100%	0	0.11			
G-7 DWARKA GRID	WG7PN121	11kV FDR S/STN NO-1 MARBEL MARKET SECTOR 20 DWK	660MLP-MNP151A	630	MIXED		Functional	100%	0	0.00			
G-7 DWARKA GRID	WG7PN121	11kV FDR S/STN NO-1 MARBEL MARKET SECTOR 20 DWK	660KLP-KLP032A-1		MIXED		Functional	100%	0	0.42			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN110	11kV FDR DDA OFFICE MANGLAPURI	TI-KLP039A-1	990	RESIDENTIAL		Functional	100%	612	0.88	2.21	0.03	1.26%
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN110	11kV FDR DDA OFFICE MANGLAPURI	TI-KLP039A-2	630	RESIDENTIAL		Functional	100%	1446	0.49			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN122	11kV FDR PURAN NAGAR	TI-KLP089A-1	630	RESIDENTIAL		Functional	100%	390	0.19			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN122	11kV FDR PURAN NAGAR	TI-KLP089A-2	630	RESIDENTIAL		Functional	100%	0	0.18			
220kV PAPPAN KALAN-1 GRID	TDTPG113	11kV FDR EVERGEEN	660MLP-MNP150A	400	MIXED		Functional	100%	0	0.18			
220kV PAPPAN KALAN-1 GRID	TDTPG109	11kV FDR BENGALI COLONY	660MLP-MNP149A	630	MIXED		Functional	100%	0	0.15			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN122	11kV FDR PURAN NAGAR	TI-KLP090A-1	400	RESIDENTIAL		Functional	100%	259	0.10			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN122	11kV FDR PURAN NAGAR	TI-KLP090A-2	400	RESIDENTIAL		Functional	100%	0	0.07			
220kV PAPPAN KALAN-1 GRID	TDTPG111	11kV FDR PALAM VILLAGE	TI-MNP024A-1	990	RESIDENTIAL		Functional	100%	983	0.47	3.50	0.05	1.47%
220kV PAPPAN KALAN-1 GRID	TDTPG111	11kV FDR PALAM VILLAGE	TI-MNP027A-2	630	RESIDENTIAL		Functional	100%	345	0.38			
220kV PAPPAN KALAN-1 GRID	TDTPG111	11kV FDR PALAM VILLAGE	TG-MNP024A-2	400	RESIDENTIAL		Functional	100%	0	0.33			
220kV PAPPAN KALAN-1 GRID	TDTPG111	11kV FDR PALAM VILLAGE	TI-MNP023A-1	630	RESIDENTIAL		Functional	100%	1055	0.32			
220kV PAPPAN KALAN-1 GRID	TDTPG111	11kV FDR PALAM VILLAGE	TI-MNP028A-2	630	RESIDENTIAL		Functional	100%	0	0.29			

220kV PAPPAN KALAN-1 GRID	TDTPG111	11kV FDR PALAM VILLAGE	560MLP-MNP023A	630	MIXED		Functional	100%	0	0.28			
220kV PAPPAN KALAN-1 GRID	TDTPG111	11kV FDR PALAM VILLAGE	TI-MNP027A-1	630	RESIDENTIAL		Functional	100%	483	0.26			
220kV PAPPAN KALAN-1 GRID	TDTPG103	11kV FDR PERIPEHERIAL-1	TI-MNP031A-1	630	RESIDENTIAL	AMR	Functional	100%	191	0.23			
220kV PAPPAN KALAN-1 GRID	TDTPG111	11kV FDR PALAM VILLAGE	TI-MNP028A-1	400	RESIDENTIAL		Functional	100%	691	0.22			
220kV PAPPAN KALAN-1 GRID	TDTPG103	11kV FDR PERIPEHERIAL-1	TI-MNP030A-1	400	RESIDENTIAL		Functional	100%	317	0.21			
220kV PAPPAN KALAN-1 GRID	TDTPG103	11kV FDR PERIPEHERIAL-1	TG-MNP030A-2	630	COMMERCIAL		Functional	100%	0	0.19			
220kV PAPPAN KALAN-1 GRID	TDTPG103	11kV FDR PERIPEHERIAL-1	TP-MNP092A-1	250	RESIDENTIAL		Functional	100%	2	0.16			
220kV PAPPAN KALAN-1 GRID	TDTPG103	11kV FDR PERIPEHERIAL-1	PM-MNP029A-1	630	RESIDENTIAL		Functional	100%	135	0.15			
220kV PAPPAN KALAN-1 GRID	TDTPG112	11kV FDR PAPPANKALAN SECTOR-7	TI-MNP032A-1	400	RESIDENTIAL		Functional	100%	76	0.06			
220kV PAPPAN KALAN-1 GRID	TDTPG114	11kV FDR VINODPURI	TI-MNP018A-1	1600	RESIDENTIAL	AMR	Functional	100%	1830	1.06	13.30	0.41	3.02%
220kV PAPPAN KALAN-1 GRID	TDTPG115	11kV FDR C-2 MAHAVIR ENCLAVE FDR	TI-MNP019A-1	1600	RESIDENTIAL		Functional	100%	2249	0.95			
66 kV G - 2 P.P.K (NASEERPUR) GRID	WG2PN127	11kV FDR PURAN JAILDAR	TG-MNP014A-1	990	RESIDENTIAL		Functional	100%	591	0.89			
66 kV G - 2 P.P.K (NASEERPUR) GRID	WG2PN127	11kV FDR PURAN JAILDAR	TG-MNP015A-1	990	RESIDENTIAL		Functional	100%	1074	0.81			
220kV PAPPAN KALAN-1 GRID	TDTPG103	11kV FDR PERIPEHERIAL-1	TG-MNP124A-1	990	RESIDENTIAL	AMR	Functional	100%	500	0.75			
220kV PAPPAN KALAN-1 GRID	TDTPG103	11kV FDR PERIPEHERIAL-1	TG-MNP076A-1	630	RESIDENTIAL		Functional	100%	191	0.74			
220kV PAPPAN KALAN-1 GRID	TDTPG115	11kV FDR C-2 MAHAVIR ENCLAVE FDR	TG-MNP019A-3	990	RESIDENTIAL		Functional	100%	0	0.73			
220kV PAPPAN KALAN-1 GRID	TDTPG115	11kV FDR C-2 MAHAVIR ENCLAVE FDR	TI-MNP019A-2	1600	RESIDENTIAL		Functional	100%	1367	0.69			
66 kV G - 2 P.P.K (NASEERPUR) GRID	WG2PN121	11kV FDR MANDIR MARG	560MLP-MNP016A	990	RESIDENTIAL		Functional	100%	1977	0.67			
66 kV G - 2 P.P.K (NASEERPUR) GRID	WG2PN121	11kV FDR MANDIR MARG	TI-MNP017A-2	990	RESIDENTIAL		Functional	100%	1291	0.63			
220kV PAPPAN KALAN-1 GRID	TDTPG109	11kV FDR BENGALI COLONY	TG-MNP118A-1	990	RESIDENTIAL		Functional	100%	898	0.61			
66 kV G - 2 P.P.K (NASEERPUR) GRID	WG2PN121	11kV FDR MANDIR MARG	TI-MNP017A-1	990	RESIDENTIAL		Functional	100%	614	0.59			
220kV PAPPAN KALAN-1 GRID	TDTPG109	11kV FDR BENGALI COLONY	PM-HVD013A-2	1475	RESIDENTIAL		Functional	100%	853	0.54			
66 kV G - 2 P.P.K (NASEERPUR) GRID	WG2PN121	11kV FDR MANDIR MARG	560MLP-MNP016A	990	RESIDENTIAL		Functional	100%	684	0.54			
66 kV G - 2 P.P.K (NASEERPUR) GRID	WG2PN121	11kV FDR MANDIR MARG	560MLP-MNP016A	990	RESIDENTIAL		Functional	100%	0	0.50			
220kV PAPPAN KALAN-1 GRID	TDTPG109	11kV FDR BENGALI COLONY	TP-MNP095A-1	630	RESIDENTIAL		Functional	100%	387	0.47			
220kV PAPPAN KALAN-1 GRID	TDTPG108	11kV FDR PERIPHERAL-2	TI-MNP021A-1	990	RESIDENTIAL		Functional	100%	811	0.45			
220kV PAPPAN KALAN-1 GRID	TDTPG115	11kV FDR C-2 MAHAVIR ENCLAVE FDR	PM-HVD014A-1	1250	RESIDENTIAL		Functional	100%	909	0.40			
220kV PAPPAN KALAN-1 GRID	TDTPG109	11kV FDR BENGALI COLONY	TG-MNP127A-1	630	RESIDENTIAL		Functional	100%	17	0.37			
220kV PAPPAN KALAN-1 GRID	TDTPG114	11kV FDR VINODPURI	TG-MNP134A-1	630	RESIDENTIAL		Functional	100%	293	0.28			
220kV PAPPAN KALAN-1 GRID	TDTPG108	11kV FDR PERIPHERAL-2	TG-MNP021A-2	630	RESIDENTIAL		Functional	100%	0	0.23			
220kV PAPPAN KALAN-1 GRID	TDTPG109	11kV FDR BENGALI COLONY	TI-MNP013A-2	630	RESIDENTIAL		Functional	100%	679	0.22			
220kV PAPPAN KALAN-1 GRID	TDTPG103	11kV FDR PERIPEHERIAL-1	TP-MNP020A-1	400	RESIDENTIAL		Functional	100%	483	0.21			
220kV PAPPAN KALAN-1 GRID	TDTPG109	11kV FDR BENGALI COLONY	TI-MNP013A-1	990	RESIDENTIAL		Functional	100%	0	0.20			
220kV PAPPAN KALAN-1 GRID	TDTPG115	11kV FDR C-2 MAHAVIR ENCLAVE FDR	PM-HVD009A-1	425	RESIDENTIAL		Functional	100%	338	0.18			
220kV PAPPAN KALAN-1 GRID	TDTPG109	11kV FDR BENGALI COLONY	560MLP-MNP127A	630	MIXED		Functional	100%	0	0.01			
220kV PAPPAN KALAN-1 GRID	TDTPG108	11kV FDR PERIPHERAL-2	TP-MNP010A-1	990	RESIDENTIAL		Functional	100%	544	0.84	4.90	0.51	9.42%
66 kV G - 2 P.P.K (NASEERPUR) GRID	WG2PN128	11kV FDR PURAN JAILDAR NO.-2	TI-MNP009A-2	1600	RESIDENTIAL		Functional	100%	753	0.81			
66 kV G - 2 P.P.K (NASEERPUR) GRID	WG2PN127	11kV FDR PURAN JAILDAR	TI-MNP007A-1	990	RESIDENTIAL		Functional	100%	606	0.78			
220kV PAPPAN KALAN-1 GRID	TDTPG108	11kV FDR PERIPHERAL-2	TI-MNP012A-1	990	RESIDENTIAL		Functional	100%	1274	0.78			
66 kV G - 2 P.P.K (NASEERPUR) GRID	WG2PN128	11kV FDR PURAN JAILDAR NO.-2	TI-MNP009A-1	990	RESIDENTIAL		Functional	100%	1771	0.59			
66 kV G - 2 P.P.K (NASEERPUR) GRID	WG2PN127	11kV FDR PURAN JAILDAR	TP-HVD012A-1	1350	RESIDENTIAL		Functional	100%	553	0.53			
66 kV G - 2 P.P.K (NASEERPUR) GRID	WG2PN127	11kV FDR PURAN JAILDAR	560MLP-MNP008A	630	RESIDENTIAL		Functional	100%	0	0.31			
220kV PAPPAN KALAN-1 GRID	TDTPG114	11kV FDR VINODPURI	TG-MNP133A-1	630	RESIDENTIAL		Functional	100%	427	0.28			
220kV PAPPAN KALAN-1 GRID	TDTPG108	11kV FDR PERIPHERAL-2	TI-MNP011A-1	400	RESIDENTIAL		Functional	100%	0	0.23			

66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN127	11kv FDR PURAN JAILDAR	TI-MNP008A-1	400	RESIDENTIAL		Functional	100%	802	0.17			
220kv PAPPAN KALAN-1 GRID	TDTPG108	11kv FDR PERIPHERAL-2	TI-MNP011A-2	400	RESIDENTIAL		Functional	100%	594	0.10			
66 kv PANKHA ROAD GRID	WPNRD104	11kv FDR SITAPURI D BLOCK	TI-MNP004A-1	1600	RESIDENTIAL		Functional	100%	1119	1.05	5.85	0.23	3.81%
66 kv PANKHA ROAD GRID	WPNRD104	11kv FDR SITAPURI D BLOCK	TI-MNP004A-2	1600	RESIDENTIAL		Functional	100%	1543	0.94			
66 kv PANKHA ROAD GRID	WPNRD628	11kv FDR A-BLOCK SITAPURI	TG-MNP001A-1	990	RESIDENTIAL		Functional	100%	1049	0.87			
66 kv PANKHA ROAD GRID	WPNRD104	11kv FDR SITAPURI D BLOCK	TI-MNP002A-1	990	RESIDENTIAL		Functional	100%	44	0.87			
66 kv PANKHA ROAD GRID	WPNRD108	11kv FDR SITAPURI HARIJAN BASTI	TI-MNP003A-1	630	RESIDENTIAL		Functional	100%	1265	0.60			
66 kv PANKHA ROAD GRID	WPNRD104	11kv FDR SITAPURI D BLOCK	TI-MNP002A-2	990	RESIDENTIAL		Functional	100%	1504	0.60			
66 kv PANKHA ROAD GRID	WPNRD108	11kv FDR SITAPURI HARIJAN BASTI	TG-MNP005A-1	990	RESIDENTIAL	AMR	Functional	100%	560	0.41			
66 kv PANKHA ROAD GRID	WPNRD108	11kv FDR SITAPURI HARIJAN BASTI	TI-MNP003A-2	630	RESIDENTIAL		Functional	100%	0	0.36			
66 kv PANKHA ROAD GRID	WPNRD628	11kv FDR A-BLOCK SITAPURI	TG-MNP120A-1	630	RESIDENTIAL	AMR	Functional	100%	561	0.29			
66 kv PANKHA ROAD GRID	WPNRD117	11kv FDR RAGHU NAGAR (NEW)	660KLP-MNP143A	250	MIXED		Functional	100%	44	0.04			
66 kv PANKHA ROAD GRID	WPNRD117	11kv FDR RAGHU NAGAR (NEW)	660KLP-MNP143A	250	MIXED		Functional	100%	0	0.04			
66 kv PANKHA ROAD GRID	WPNRD113	11kv FDR RAGHU NAGAR (OLD)	TI-KLP053A-1	1500	RESIDENTIAL	AMR	Functional	100%	930	1.12	11.11	0.29	2.57%
66 kv PANKHA ROAD GRID	WPNRD113	11kv FDR RAGHU NAGAR (OLD)	TI-KLP007A-1	1600	RESIDENTIAL		Functional	100%	1629	1.05			
66 kv PANKHA ROAD GRID	WPNRD117	11kv FDR RAGHU NAGAR (NEW)	TI-KLP054A-1	1600	RESIDENTIAL	AMR	Functional	100%	1215	0.89			
66 kv PANKHA ROAD GRID	WPNRD113	11kv FDR RAGHU NAGAR (OLD)	TG-KLP102A-2	990	RESIDENTIAL		Functional	100%	0	0.88			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP114	11kv FDR DABRI NO 2	TI-KLP076A-1	990	RESIDENTIAL		Functional	100%	442	0.81			
66 kv PANKHA ROAD GRID	WPNRD108	11kv FDR SITAPURI HARIJAN BASTI	TI-KLP003A-1	1600	RESIDENTIAL	AMR	Functional	100%	456	0.74			
66 kv PANKHA ROAD GRID	WPNRD113	11kv FDR RAGHU NAGAR (OLD)	660DBR-KLP101A	630	RESIDENTIAL		Functional	100%	0	0.61			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP115	11kv FDR DABRI NO 1	TP-KLP004A-1	990	RESIDENTIAL	AMR	Functional	100%	773	0.60			
66 kv PANKHA ROAD GRID	WPNRD113	11kv FDR RAGHU NAGAR (OLD)	TI-KLP007A-2	1600	RESIDENTIAL		Functional	100%	1096	0.59			
66 kv PANKHA ROAD GRID	WPNRD113	11kv FDR RAGHU NAGAR (OLD)	TI-KLP006A-1	990	RESIDENTIAL	AMR	Functional	100%	1661	0.56			
66 kv PANKHA ROAD GRID	WPNRD113	11kv FDR RAGHU NAGAR (OLD)	TG-KLP102A-1	990	RESIDENTIAL		Functional	100%	502	0.52			
66 kv PANKHA ROAD GRID	WPNRD113	11kv FDR RAGHU NAGAR (OLD)	TG-KLP101A-1	630	RESIDENTIAL		Functional	100%	174	0.49			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP114	11kv FDR DABRI NO 2	TI-KLP002A-2	990	RESIDENTIAL		Functional	100%	0	0.48			
66 kv PANKHA ROAD GRID	WPNRD113	11kv FDR RAGHU NAGAR (OLD)	TP-KLP056A-1	630	RESIDENTIAL		Functional	100%	1071	0.47			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP114	11kv FDR DABRI NO 2	TP-KLP005A-1	990	RESIDENTIAL	AMR	Functional	100%	899	0.45			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP115	11kv FDR DABRI NO 1	TI-KLP002A-1	990	RESIDENTIAL		Functional	100%	411	0.40			
66 kv PANKHA ROAD GRID	WPNRD113	11kv FDR RAGHU NAGAR (OLD)	TP-KLP055A-1	400	RESIDENTIAL		Functional	100%	380	0.32			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN129	11kv FDR DABRI ZONAL OFFICE	TG-KLP076A-2	630	RESIDENTIAL		Functional	100%	264	0.22			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP114	11kv FDR DABRI NO 2	PM-HVD006A-1	375	RESIDENTIAL		Functional	100%	236	0.19			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN129	11kv FDR DABRI ZONAL OFFICE	TI-MNP087A-1	990	RESIDENTIAL		Functional	100%	35	0.03			
66 kv PANKHA ROAD GRID	WPNRD113	11kv FDR RAGHU NAGAR (OLD)	660DBR-KLP101A	990	MIXED		Functional	100%	0	0.00			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN119	11kv FDR POCKET-10 NASIR PUR	660KLP-HVD009A	1050	MIXED		Functional	100%	0	0.69	7.02	0.03	0.46%
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP115	11kv FDR DABRI NO 1	TG-KLP101A-1	630	RESIDENTIAL	AMR	Functional	100%	823	0.64			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN131	11kv FDR A-BLK DASRATH PURI	TI-KLP013A-1	630	RESIDENTIAL		Functional	100%	788	0.60			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN131	11kv FDR A-BLK DASRATH PURI	660DBR-KLP014A	990	RESIDENTIAL		Functional	100%	0	0.60			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN113	11kv FDR PINK APPT.	PM-HVD004A-1	1442	RESIDENTIAL		Functional	100%	1823	0.58			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP115	11kv FDR DABRI NO 1	TI-KLP008A-1	990	RESIDENTIAL		Functional	100%	1334	0.58			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN131	11kv FDR A-BLK DASRATH PURI	TG-KLP012A-1	990	RESIDENTIAL		Functional	100%	927	0.58			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN131	11kv FDR A-BLK DASRATH PURI	TI-KLP014A-1	990	RESIDENTIAL		Functional	100%	1076	0.52			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP115	11kv FDR DABRI NO 1	TI-KLP008A-3	630	RESIDENTIAL		Functional	100%	0	0.48			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP115	11kv FDR DABRI NO 1	PM-HVD008A-2	1075	RESIDENTIAL		Functional	100%	360	0.35			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP115	11kv FDR DABRI NO 1	TI-KLP008A-2	630	RESIDENTIAL		Functional	100%	1043	0.34			

66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN113	11kv FDR PINK APPT.	TG-KLP011A-2	630	RESIDENTIAL		Functional	100%	0	0.33			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN103	11kv FDR DWARKA PURI	660KLP-DBR003A-	400	RESIDENTIAL		Functional	100%	316	0.30			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN126	11kv FDR DURGAPAK GALI NO.4	TI-KLP081A-1	400	RESIDENTIAL	AMR	Functional	100%	424	0.25			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN113	11kv FDR PINK APPT.	TP-KLP011A-1	400	RESIDENTIAL		Functional	100%	802	0.20			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP115	11kv FDR DABRI NO 1	TP-KLP009A-1	400	RESIDENTIAL	AMR	Functional	100%	163	0.02			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP105	11kv FDR I-BLOCK SAGARPUR	TI-KLP023A-2	1600	RESIDENTIAL		Functional	100%	1754	1.11	6.56	0.09	1.42%
66 kv PANKHA ROAD GRID	WPNRD117	11kv FDR RAGHU NAGAR (NEW)	TI-KLP035A-1	1600	RESIDENTIAL		Functional	100%	2603	0.90			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP105	11kv FDR I-BLOCK SAGARPUR	TI-KLP023A-1	1600	RESIDENTIAL		Functional	100%	952	0.84			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP105	11kv FDR I-BLOCK SAGARPUR	TG-KLP035A-2	990	RESIDENTIAL		Functional	100%	0	0.65			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN119	11kv FDR POCKET-10 NASIR PUR	TI-KLP028A-2	990	RESIDENTIAL		Functional	100%	460	0.59			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN119	11kv FDR POCKET-10 NASIR PUR	TI-KLP027A-2	630	RESIDENTIAL		Functional	100%	2340	0.52			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN119	11kv FDR POCKET-10 NASIR PUR	TI-KLP028A-1	630	RESIDENTIAL		Functional	100%	548	0.51			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN119	11kv FDR POCKET-10 NASIR PUR	PM-HVD007A-1	1150	RESIDENTIAL		Functional	100%	513	0.46			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN119	11kv FDR POCKET-10 NASIR PUR	660DBR-KLP061A-	990	RESIDENTIAL		Functional	100%	0	0.45			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN119	11kv FDR POCKET-10 NASIR PUR	TI-KLP061A-1	630	RESIDENTIAL		Functional	100%	958	0.39			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN119	11kv FDR POCKET-10 NASIR PUR	TI-KLP027A-1	990	RESIDENTIAL		Functional	100%	0	0.25			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP112	11kv FDR MADANPURI HANS PARK	TG-KLP034A-2	1600	RESIDENTIAL		Functional	100%	2404	1.29	19.66	0.25	1.24%
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP107	11kv FDR F-BLOCK SAGARPUR + (11kv FDR RAGHU NAGAR NEW NO. 2)	TG-KLP083A-1	1600	RESIDENTIAL		Functional	100%	1053	1.21			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP103	11kv FDR SAGARPUR MAIN	TI-KLP059A-1	1600	RESIDENTIAL	AMR	Functional	100%	1869	1.08			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN106	11kv FDR KAILASH PURI-2	PM-HVD005A-1	2067	RESIDENTIAL		Functional	100%	409	1.01			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP129	11kv FDR GEETANJALI PARK PLM SSTN + (11kv FDR MEHTAWALA)	TI-KLP017A-1	990	RESIDENTIAL		Functional	100%	1877	1.01			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN117	11kv FDR MCD SCHOOL NASIR PUR	TI-KLP063A-2	1600	RESIDENTIAL		Functional	100%	1257	0.95			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP129	11kv FDR GEETANJALI PARK PLM SSTN + (11kv FDR MEHTAWALA)	TK-KLP021A-1	990	RESIDENTIAL	AMR	Functional	100%	908	0.90			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN117	11kv FDR MCD SCHOOL NASIR PUR	TI-KLP063A-1	1600	RESIDENTIAL		Functional	100%	1412	0.79			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP129	11kv FDR GEETANJALI PARK PLM SSTN + (11kv FDR MEHTAWALA)	TG-KLP018A-2	990	RESIDENTIAL		Functional	100%	1906	0.78			
220 kv NARAINA GRID	TDNR101	11kv FDR OLD NANGAL	TG-KLP062A-1	990	RESIDENTIAL	AMR	Functional	100%	1543	0.77			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP107	11kv FDR F-BLOCK SAGARPUR + (11kv FDR RAGHU NAGAR NEW NO. 2)	TI-KLP019A-1	990	RESIDENTIAL		Functional	100%	1200	0.72			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP103	11kv FDR SAGARPUR MAIN	TG-KLP058A-1	1600	RESIDENTIAL		Functional	100%	1365	0.72			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP129	11kv FDR GEETANJALI PARK PLM SSTN + (11kv FDR MEHTAWALA)	TG-KLP018A-1	1600	RESIDENTIAL		Functional	100%	658	0.70			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP112	11kv FDR MADANPURI HANS PARK	TI-KLP034A-1	990	RESIDENTIAL		Functional	100%	1445	0.69			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN117	11kv FDR MCD SCHOOL NASIR PUR	TG-KLP064A-2	990	RESIDENTIAL		Functional	100%	1479	0.68			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP107	11kv FDR F-BLOCK SAGARPUR + (11kv FDR RAGHU NAGAR NEW NO. 2)	TI-KLP019A-2	990	RESIDENTIAL		Functional	100%	250	0.67			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN117	11kv FDR MCD SCHOOL NASIR PUR	TG-KLP064A-1	990	RESIDENTIAL		Functional	100%	0	0.66			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP112	11kv FDR MADANPURI HANS PARK	660KLP-KLP001A-	990	RESIDENTIAL		Functional	100%	1932	0.66			

220 kv NARAINA GRID	TDNTR101	11kv FDR OLD NANGAL	2660KLP-KLP108A-1	630	RESIDENTIAL	AMR	Functional	100%	148	0.53			
220 kv NARAINA GRID	TDNTR101	11kv FDR OLD NANGAL	TG-KLP057A-1	990	RESIDENTIAL		Functional	100%	0	0.52			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP107	11kv FDR F-BLOCK SAGARPUR + (11kv FDR RAGHU NAGAR NEW NO. 2)	TG-KLP020A-2	630	RESIDENTIAL		Functional	100%	0	0.50			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN119	11kv FDR POCKET-10 NASIR PUR	TG-KLP060A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.49			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP112	11kv FDR MADANPURI HANS PARK	2660KLP-KLP034A-1	990	RESIDENTIAL		Functional	100%	0	0.48			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP103	11kv FDR SAGARPUR MAIN	TG-KLP057A-2	990	RESIDENTIAL		Functional	100%	2636	0.43			
220 kv NARAINA GRID	TDNTR101	11kv FDR OLD NANGAL	2660KLP-KLP103A-1	630	RESIDENTIAL		Functional	100%	39	0.42			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP129	11kv FDR GEETANJALI PARK PLM SSTN + (11kv FDR MEHTAWALA)	2660KLP-KLP017A-1	630	RESIDENTIAL		Functional	100%	0	0.34			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP107	11kv FDR F-BLOCK SAGARPUR + (11kv FDR RAGHU NAGAR NEW NO. 2)	TG-KLP020A-1	630	RESIDENTIAL		Functional	100%	915	0.28			
220 kv NARAINA GRID	TDNTR101	11kv FDR OLD NANGAL	2660KLP-KLP103A-1	630	RESIDENTIAL		Functional	100%	82	0.24			
220 kv NARAINA GRID	TDNTR101	11kv FDR OLD NANGAL	2660KLP-KLP057A-1	990	RESIDENTIAL		Functional	100%	0	0.22			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN119	11kv FDR POCKET-10 NASIR PUR	TG-KLP060A-1	630	MIXED		Functional	100%	2098	0.16			
66 kv INST. AREA JKP (SAGARPUR) GRID	WSGRP112	11kv FDR MADANPURI HANS PARK	2660KLP-KLP001A-1	990	RESIDENTIAL		Functional	100%	0	0.00			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN124	11KV FDR KAILASH PURI EXTENSION	PM-HVD001A-1	3659	RESIDENTIAL		Functional	100%	2975	1.70	7.49	0.18	2.33%
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN124	11KV FDR KAILASH PURI EXTENSION	PM-HVD003A-1	2785	RESIDENTIAL		Functional	100%	2012	1.18			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN102	11kv FDR KAILASH PURI-1	TI-KLP025A-1	1600	RESIDENTIAL		Functional	100%	1692	1.09			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN102	11kv FDR KAILASH PURI-1	TG-KLP024A-1	990	RESIDENTIAL		Functional	100%	0	0.76			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN106	11kv FDR KAILASH PURI-2	TI-KLP030A-1	990	RESIDENTIAL		Functional	100%	1464	0.73			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN106	11kv FDR KAILASH PURI-2	TI-KLP030A-2	990	RESIDENTIAL		Functional	100%	541	0.72			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN124	11kv FDR KAILASH PURI EXTENSION	TG-KLP015A-1	630	RESIDENTIAL		Functional	100%	988	0.48			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN102	11kv FDR KAILASH PURI-1	TG-KLP024A-2	990	RESIDENTIAL		Functional	100%	1187	0.40			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN124	11kv FDR KAILASH PURI EXTENSION	2660KLP-KLP031A-1	630	RESIDENTIAL		Functional	100%	184	0.22			
G-7 DWARKA GRID	WG7PN127	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	2660KLP-KLP110A-1	400	RESIDENTIAL		Functional	100%	63	0.16			
G-7 DWARKA GRID	WG7PN127	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	2660KLP-KLP111A-1	400	RESIDENTIAL		Functional	100%	88	0.13			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN124	11KV FDR KAILASH PURI EXTENSION	2660KLP-KLP015A-1	630	MIXED		Functional	100%	0	0.10			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN113	11kv FDR PINK APPT.	TI-KLP094A-1	630	RESIDENTIAL		Functional	100%	302	0.34	2.10	0.01	0.35%
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN617	11kv FDR NISHKAM APPTT	TI-KLP078A-1	400	RESIDENTIAL		Functional	100%	448	0.22			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN617	11kv FDR NISHKAM APPTT	2660DBR-KLP047A-1	400	RESIDENTIAL		Functional	100%	0	0.15			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN617	11kv FDR NISHKAM APPTT	TI-KLP047A-1	400	RESIDENTIAL		Functional	100%	288	0.15			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN113	11kv FDR PINK APPT.	TI-KLP045A-1	630	RESIDENTIAL		Functional	100%	167	0.13			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN112	11kv FDR VARDHMAN PLAZA	TI-KLP050A-1	400	RESIDENTIAL		Functional	100%	256	0.13			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN617	11kv FDR NISHKAM APPTT	TI-KLP080A-1	400	RESIDENTIAL		Functional	100%	224	0.12			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN113	11kv FDR PINK APPT.	TI-KLP046A-1	400	RESIDENTIAL		Functional	100%	262	0.11			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN112	11kv FDR VARDHMAN PLAZA	TI-KLP049A-1	400	RESIDENTIAL		Functional	100%	169	0.11			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN112	11kv FDR VARDHMAN PLAZA	TI-KLP088A-1	400	RESIDENTIAL		Functional	100%	0	0.10			

66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN112	11KV FDR VARDHMAN PLAZA	TI-KLP077A-1	400	RESIDENTIAL		Functional	100%	75	0.09			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN112	11KV FDR VARDHMAN PLAZA	TI-KLP051A-1	400	RESIDENTIAL		Functional	100%	99	0.07			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN112	11KV FDR VARDHMAN PLAZA	TI-KLP093A-2	400	RESIDENTIAL		Functional	100%	73	0.06			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN112	11KV FDR VARDHMAN PLAZA	TI-KLP093A-1	400	RESIDENTIAL		Functional	100%	0	0.06			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN112	11KV FDR VARDHMAN PLAZA	TI-KLP095A-2	400	RESIDENTIAL		Functional	100%	0	0.05			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN112	11KV FDR VARDHMAN PLAZA	TI-KLP079A-2	400	RESIDENTIAL		Functional	100%	62	0.05			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN112	11KV FDR VARDHMAN PLAZA	TI-KLP095A-1	400	RESIDENTIAL		Functional	100%	63	0.05			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN112	11KV FDR VARDHMAN PLAZA	TI-KLP088A-2	400	RESIDENTIAL		Functional	100%	137	0.04			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN112	11KV FDR VARDHMAN PLAZA	TI-KLP079A-1	400	RESIDENTIAL		Functional	100%	0	0.04			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN109	11KV STR 400KVA STATION TRANSFORMER	PM-WTC006A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.04			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN101	11KV FDR MAHAVIR ENCLAVE D-3	660KLP-HVD012A-	1890	RESIDENTIAL		Functional	100%	0	1.11	11.32	1.12	8.98%
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN101	11KV FDR MAHAVIR ENCLAVE D-3	PM-HVD011A-2	2463	RESIDENTIAL		Functional	100%	1062	0.96			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN107	11KV FDR D-1 D-2 MAHAVIR ENCALE	PM-HVD010A-1	1456	RESIDENTIAL		Functional	100%	1572	0.91			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN621	11KV FDR D1 & D2 MAHAVIR ENCLAVE NO-2	TI-KLP036A-1	1600	RESIDENTIAL		Functional	100%	1595	0.85			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN621	11KV FDR D1 & D2 MAHAVIR ENCLAVE NO-2	TI-KLP036A-2	1600	RESIDENTIAL		Functional	100%	720	0.83			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN125	11KV FDR MAHAVIR ENCLAVE GALI-2	TI-KLP038A-1	990	COMMERCIAL		Functional	100%	519	0.70			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN107	11KV FDR D-1 D-2 MAHAVIR ENCALE	PM-HVD010A-2	1000	RESIDENTIAL		Functional	100%	0	0.67			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN101	11KV FDR MAHAVIR ENCLAVE D-3	TI-KLP037A-1	630	RESIDENTIAL		Functional	100%	0	0.57			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN101	11KV FDR MAHAVIR ENCLAVE D-3	TI-KLP037A-2	630	RESIDENTIAL		Functional	100%	979	0.50			
220KV PAPPAN KALAN-1 GRID	TDTPG110	11KV FDR NASIRPUR VILLAGE	TP-KLP085A-1	990	RESIDENTIAL		Functional	100%	852	0.50			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN125	11KV FDR MAHAVIR ENCLAVE GALI-2	PM-HVD002A-1	1992	RESIDENTIAL		Functional	100%	3386	0.50			
G-2 PAPPANKALAN GRID SSTN	WG2PN107	11KV D-1 & D-2, MAHAVIR ENCLAVE	TG-KLP038B-2	990	COMMERCIAL		Functional	100%	0	0.49			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN125	11KV FDR MAHAVIR ENCLAVE GALI-2	660KLP-KLP038A-	990	MIXED		Functional	100%	0	0.48			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN110	11KV FDR DDA OFFICE MANGLAPURI	660KLP-KLP107A-	400	RESIDENTIAL		Functional	100%	60	0.47			
220KV PAPPAN KALAN-1 GRID	TDTPG110	11KV FDR NASIRPUR VILLAGE	TI-KLP087A-1	990	RESIDENTIAL	AMR	Functional	100%	191	0.45			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN125	11KV FDR MAHAVIR ENCLAVE GALI-2	TI-KLP038A-2	990	RESIDENTIAL		Functional	100%	1950	0.37			
220KV PAPPAN KALAN-1 GRID	TDTPG110	11KV FDR NASIRPUR VILLAGE	660KLP-KLP104A-	990	RESIDENTIAL		Functional	100%	0	0.35			
220KV PAPPAN KALAN-1 GRID	TDTPG110	11KV FDR NASIRPUR VILLAGE	660KLP-KLP104A-	630	RESIDENTIAL		Functional	100%	522	0.34			
220KV PAPPAN KALAN-1 GRID	TDTPG110	11KV FDR NASIRPUR VILLAGE	TP-KLP085A-2	990	RESIDENTIAL		Functional	100%	0	0.34			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN112	11KV FDR VARDHMAN PLAZA	TP-KLP091A-1	630	RESIDENTIAL		Functional	100%	59	0.28			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN107	11KV FDR D-1 D-2 MAHAVIR ENCALE	660KLP-HVD010A-	400	RESIDENTIAL		Functional	100%	0	0.21			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN617	11KV FDR NISHKAM APPTT	TI-KLP086A-1	400	RESIDENTIAL		Functional	100%	50	0.20			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN107	11KV FDR D-1 D-2 MAHAVIR ENCALE	660KLP-HVD010A-	400	RESIDENTIAL		Functional	100%	0	0.16			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN617	11KV FDR NISHKAM APPTT	TI-KLP097A-1	400	RESIDENTIAL		Functional	100%	569	0.13			
66 KV G - 2 P.P.K (NASEERPUR) GRID	WG2PN112	11KV FDR VARDHMAN PLAZA	TP-KLP091A-2	630	MIXED		Functional	100%	0	0.09			

66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN118	11kv FDR GALI NO-22 SADH NAGAR	TG-KLP052A-1	1600	RESIDENTIAL	AMR	Functional	100%	1989	1.37	7.16	0.41	5.39%			
G-7 DWARKA GRID	WG7PN127	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	TI-KLP069A-1	990	RESIDENTIAL	AMR	Functional	100%	1441	0.86						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN102	11kv FDR KAILASH PURI-1	TI-KLP074A-1	1600	RESIDENTIAL		Functional	100%	1286	0.83						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN118	11kv FDR GALI NO-22 SADH NAGAR	TI-KLP075A-1	990	RESIDENTIAL	AMR	Functional	100%	1138	0.71						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN118	11kv FDR GALI NO-22 SADH NAGAR	TG-KLP068A-2	990	RESIDENTIAL		Functional	100%	0	0.63						
220kv PAPPAN KALAN-1 GRID	TDTPG105	11kv FDR MANGLA PURI PHASE-2	TG-KLP073A-2	990	RESIDENTIAL		Functional	100%	0	0.46						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN118	11kv FDR GALI NO-22 SADH NAGAR	2660KLP-KLP082A-1	990	MIXED		Functional	100%	0	0.35						
G-7 DWARKA GRID	WG7PN127	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	TP-KLP067A-2	400	RESIDENTIAL		Functional	100%	0	0.32						
G-7 DWARKA GRID	WG7PN127	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	TP-KLP067A-3	400	RESIDENTIAL		Functional	100%	0	0.30						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN118	11kv FDR GALI NO-22 SADH NAGAR	TG-KLP082A-1	990	RESIDENTIAL		Functional	100%	1267	0.29						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN617	11kv FDR NISHKAM APPTT	TG-KLP073A-1	990	RESIDENTIAL		Functional	100%	964	0.29						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN118	11kv FDR GALI NO-22 SADH NAGAR	2660KLP-KLP113A-1	630	MIXED		Functional	100%	0	0.24						
G-7 DWARKA GRID	WG7PN127	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	TP-KLP067A-1	400	RESIDENTIAL		Functional	100%	1195	0.22						
G-7 DWARKA GRID	WG7PN127	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	TP-KLP100A-1	400	RESIDENTIAL		Functional	100%	353	0.17						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN617	11kv FDR NISHKAM APPTT	TP-KLP072A-1	400	RESIDENTIAL	AMR	Functional	100%	281	0.17						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN118	11kv FDR GALI NO-22 SADH NAGAR	TI-KLP068A-1	630	RESIDENTIAL		Functional	100%	1147	0.16						
G-7 DWARKA GRID	WG7PN127	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	2660KLP-KLP067A-1	400	MIXED		Functional	100%	0	0.13						
G-7 DWARKA GRID	WG7PN127	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	2660KLP-KLP100A-1	400	MIXED		Functional	100%	0	0.06						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN617	11kv FDR NISHKAM APPTT	TI-KLP040A-1	990	RESIDENTIAL		Functional	100%	1073	0.55	2.81	0.35	11.14%			
220kv PAPPAN KALAN-1 GRID	TDTPG105	11kv FDR MANGLA PURI PHASE-2	TI-KLP041A-1	990	RESIDENTIAL		Functional	100%	952	0.52						
220kv PAPPAN KALAN-1 GRID	TDTPG105	11kv FDR MANGLA PURI PHASE-2	TI-KLP042A-1	990	RESIDENTIAL		Functional	100%	703	0.45						
220kv PAPPAN KALAN-1 GRID	TDTPG105	11kv FDR MANGLA PURI PHASE-2	TG-KLP041A-2	990	RESIDENTIAL		Functional	100%	0	0.28						
220kv PAPPAN KALAN-1 GRID	TDTPG105	11kv FDR MANGLA PURI PHASE-2	TI-KLP042A-2	630	RESIDENTIAL		Functional	100%	26	0.26						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN113	11kv FDR PINK APPT.	TI-KLP040A-2	630	RESIDENTIAL		Functional	100%	82	0.24						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN106	11kv FDR KAILASH PURI-2	2660KLP-KLP033A-1	990	MIXED		Functional	100%	526	0.72						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN110	11kv FDR DDA OFFICE MANGLAPURI	TG-KLP016A-1	400	RESIDENTIAL	AMR	Functional	100%	8	0.04						
G-7 DWARKA GRID	WG7PN127	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	2660KLP-KLP109A-1	630	RESIDENTIAL		Functional	100%	20	0.03						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN101	11kv FDR MAHAVIR ENCLAVE D-3	660KLP-HVD013A-1	100	MIXED		Functional	100%	66	0.03						
G-7 DWARKA GRID	WG7PN127	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	2660KLP-KLP109A-1	630	MIXED		Functional	100%	19	0.02						
G-7 DWARKA GRID	WG7PN121	11kv FDR S/STN NO-1 MARBEL MARKET SECTOR 20 DWK	2660KLP-KLP033A-1	990	MIXED		Functional	100%	0	0.00						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN103	11kv FDR DWARKA PURI	TI-MNP025A-1	990	RESIDENTIAL		Functional	100%	1664	0.88				3.33	0.05	1.52%
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN103	11kv FDR DWARKA PURI	TI-MNP025A-2	990	RESIDENTIAL		Functional	100%	133	0.62						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN103	11kv FDR DWARKA PURI	TI-MNP026A-2	990	RESIDENTIAL		Functional	100%	2891	0.59						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN103	11kv FDR DWARKA PURI	660DBR-MNP026A-1	630	MIXED		Functional	100%	0	0.56						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN103	11kv FDR DWARKA PURI	660DBR-MNP026A-2	630	MIXED		Functional	100%	0	0.49						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN103	11kv FDR DWARKA PURI	TI-MNP026A-1	630	RESIDENTIAL		Functional	100%	0	0.23						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN103	11kv FDR DWARKA PURI	TP-MNP094A-1	100	RESIDENTIAL		Functional	100%	6	0.01						
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN120	11kv FDR SADH NAGAR GALI NO.-9	TG-KLP071A-1	1600	RESIDENTIAL		Functional	100%	0	1.19	5.98	0.14	2.26%			

66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN120	11kv FDR SADH NAGAR GALI NO.-9	TG-KLP071A-2	1600	RESIDENTIAL		Functional	100%	3410	1.12			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN104	11kv FDR HARSUKH APPTT.	TG-KLP070A-1	990	RESIDENTIAL		Functional	100%	1252	0.88			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN104	11kv FDR HARSUKH APPTT.	TG-KLP070A-2	990	RESIDENTIAL		Functional	100%	881	0.58			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN104	11kv FDR HARSUKH APPTT.	TG-KLP070A-3	990	RESIDENTIAL		Functional	100%	0	0.49			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN110	11kv FDR DDA OFFICE MANGLAPURI	660MLP-MNP140A	990	RESIDENTIAL		Functional	100%	28	0.49			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN120	11kv FDR SADH NAGAR GALI NO.-9	TP-KLP065A-1	990	RESIDENTIAL		Functional	100%	765	0.35			
G-7 DWARKA GRID	WG7PN127	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	TP-KLP084A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.32			
G-7 DWARKA GRID	WG7PN127	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	TP-KLP084A-1	400	RESIDENTIAL	AMR	Functional	100%	645	0.29			
G-7 DWARKA GRID	WG7PN127	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	TP-MNP136A-1	400	RESIDENTIAL	AMR	Functional	100%	764	0.23			
G-7 DWARKA GRID	WG7PN127	11kv FDR MANGLAPURI NO-1 VIA PALAM VIHAR	TP-KLP066A-1	400	RESIDENTIAL	AMR	Functional	100%	349	0.17			
220kv PAPPAN KALAN-1 GRID	TDTPG110	11kv FDR NASIRPUR VILLAGE	TK-KLP043A-2	990	RESIDENTIAL		Functional	100%	997	0.65	2.07	0.03	1.41%
220kv PAPPAN KALAN-1 GRID	TDTPG110	11kv FDR NASIRPUR VILLAGE	TG-KLP092A-1	990	RESIDENTIAL		Functional	100%	0	0.53			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN117	11kv FDR MCD SCHOOL NASIR PUR	TG-KLP044A-2	630	RESIDENTIAL		Functional	100%	0	0.34			
66 kv G - 2 P.P.K (NASEERPUR) GRID	WG2PN117	11kv FDR MCD SCHOOL NASIR PUR	TG-KLP044A-1	630	RESIDENTIAL		Functional	100%	427	0.28			
220kv PAPPAN KALAN-1 GRID	TDTPG110	11kv FDR NASIRPUR VILLAGE	TK-KLP043A-1	630	RESIDENTIAL		Functional	100%	0	0.22			
220kv PAPPAN KALAN-1 GRID	TDTPG110	11kv FDR NASIRPUR VILLAGE	TG-KLP092A-2	400	RESIDENTIAL		Functional	100%	601	0.08			
66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	661MTY-DWK275A	630	MIXED		Functional	100%	0	0.04	9.43	0.52	5.20%
66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	661MTY-DWK275A	630	MIXED		Functional	100%	0	0.03			
66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	661MTY-DWK518A	400	MIXED		Functional	100%	0	0.01			
66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	661MTY-DWK518A	400	MIXED		Functional	100%	0	0.00			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA127	11kv FDR SEC-3 SSTN NO-1	661S04-DWK114A	500	RESIDENTIAL		Functional	100%	105	0.09			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA111	11kv FDR SECTOR-4 DWARKA	661S04-DWK069A	400	MIXED		Functional	100%	0	0.07			
G-7 DWARKA GRID	WG7PN105	11kv FDR UNIQUE APPT.	661S04-DWK360A	400	MIXED		Functional	100%	0	0.07			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA127	11kv FDR SEC-3 SSTN NO-1	661S04-DWK114A	500	COMMERCIAL		Functional	100%	0	0.07			
66 kv G - 6 P.P.K GRID	WG6PN113	11kv FDR SECTOR-10 HILANSH	661S04-DWK164A	315	MIXED		Functional	100%	0	0.06			
G-7 DWARKA GRID	WG7PN105	11kv FDR UNIQUE APPT.	661S04-DWK360A	400	MIXED		Functional	100%	0	0.06			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA111	11kv FDR SECTOR-4 DWARKA	661S04-DWK069A	400	MIXED		Functional	100%	0	0.06			
66 kv G - 6 P.P.K GRID	WG6PN113	11kv FDR SECTOR-10 HILANSH	661S04-DWK164A	315	MIXED		Functional	100%	1	0.04			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA111	11kv FDR SECTOR-4 DWARKA	661S04-DWK081A	630	MIXED		Functional	100%	0	0.01			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA111	11kv FDR SECTOR-4 DWARKA	661S04-DWK081A	630	MIXED		Functional	100%	0	0.01			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA111	11kv FDR SECTOR-4 DWARKA	661S04-DWK828A	630	MIXED		Functional	100%	0	0.00			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA111	11kv FDR SECTOR-4 DWARKA	661S04-DWK828A	630	MIXED		Functional	100%	0	0.00			
220kv PAPPAN KALAN-1 GRID	TDTPG104	11kv FDR MAHALAXMI SEC-6	DW-HTC196A-1	990	MIXED		Functional	100%	0	0.00			
220kv PAPPAN KALAN-1 GRID	TDTPG104	11kv FDR MAHALAXMI SEC-6	661MVR-DWK259A	250	MIXED		Functional	100%	0	0.00			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP109	11kv FDR MAHAVIR ENCLAVE S/S NO-4	TI-DWK025A-2	1600	COMMERCIAL	AMR	Functional	100%	1179	1.13			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP109	11kv FDR MAHAVIR ENCLAVE S/S NO-4	TI-DWK025A-1	1600	COMMERCIAL	AMR	Functional	100%	1169	1.13			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP111	11kv FDR MAHAVIR ENCLAVE S/STN-2	DW-HVD021A-1	2350	RESIDENTIAL		Functional	100%	1435	0.97			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP131	11kv FDR O/G-7 ROHTAS NAGAR DWK	TP-DWK029A-1	990	COMMERCIAL	AMR	Functional	100%	528	0.93			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP111	11kv FDR MAHAVIR ENCLAVE S/STN-2	TI-DWK011A-2	1600	COMMERCIAL	AMR	Functional	100%	1762	0.89			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP111	11kv FDR MAHAVIR ENCLAVE S/STN-2	TI-DWK011A-1	1600	COMMERCIAL	AMR	Functional	100%	1841	0.81			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP109	11kv FDR MAHAVIR ENCLAVE S/S NO-4	TI-DWK010A-1	630	COMMERCIAL		Functional	100%	1458	0.67			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP131	11kv FDR O/G-7 ROHTAS NAGAR DWK	TI-DWK026A-2	630	COMMERCIAL		Functional	100%	663	0.60			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP109	11kv FDR MAHAVIR ENCLAVE S/S NO-4	TI-DWK009A-1	630	COMMERCIAL		Functional	100%	1361	0.48			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP109	11kv FDR MAHAVIR ENCLAVE S/S NO-4	TI-DWK009A-2	990	COMMERCIAL	AMR	Functional	100%	327	0.46			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP109	11kv FDR MAHAVIR ENCLAVE S/S NO-4	TG-DWK010A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.40			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP131	11kv FDR O/G-7 ROHTAS NAGAR DWK	TI-DWK026A-1	630	COMMERCIAL	AMR	Functional	100%	1022	0.35			

66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP131	11kv FDR O/G-7 ROHTAS NAGAR DWK	TG-DWK465A-1	400	COMMERCIAL	AMR	Functional	100%	662	0.27			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP110	11kv FDR MADHU VIHAR	TI-DWK008A-1	630	COMMERCIAL	AMR	Functional	100%	440	0.26			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP126	11kv FDR VISWAS PARK NO2	TI-DWK016A-2	1600	RESIDENTIAL		Functional	100%	1519	1.20	6.47	0.08	1.26%
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA115	11kv FDR G AND S RAJAPURI	DW-HVD029A-1	2125	RESIDENTIAL		Functional	100%	1899	1.19			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA138	11kv FDR T-EXTENSION	DW-HVD004A-1	2025	RESIDENTIAL		Functional	100%	929	0.97			
66 kv G - 3 P.P.K (BINDAPUR) GRID	WBNDP126	11kv FDR VISWAS PARK NO2	TI-DWK016A-1	1600	RESIDENTIAL		Functional	100%	2777	0.95			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA137	11kv FDR PRAGYA CGHS SEC-2 DWARKA	TI-DWK041A-1	1550	RESIDENTIAL		Functional	100%	14	0.92			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA138	11kv FDR T-EXTENSION	TG-DWK030A-1	990	RESIDENTIAL	AMR	Functional	100%	2183	0.62			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA138	11kv FDR T-EXTENSION	TG-DWK030A-2	990	MIXED	AMR	Functional	100%	0	0.29			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA137	11kv FDR PRAGYA CGHS SEC-2 DWARKA	561MVR-DWK041A	630	MIXED		Functional	100%	0	0.21			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA137	11kv FDR PRAGYA CGHS SEC-2 DWARKA	561MVR-DWK041A	630	MIXED		Functional	100%	0	0.21			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA125	11kv FDR 210 DDA FLATS SEC-3	TG-DWK051A-1	990	RESIDENTIAL	AMR	Functional	100%	1330	0.72	5.48	0.21	3.65%
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA125	11kv FDR 210 DDA FLATS SEC-3	TG-DWK051A-2	990	RESIDENTIAL	AMR	Functional	100%	0	0.64			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA125	11kv FDR 210 DDA FLATS SEC-3	TG-DWK053A-1	990	RESIDENTIAL		Functional	100%	352	0.53			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA125	11kv FDR 210 DDA FLATS SEC-3	TG-DWK053A-2	990	RESIDENTIAL	AMR	Functional	100%	406	0.51			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA128	11kv FDR PHASE-1 JJ CLY	DW-HVD016A-1	1375	RESIDENTIAL		Functional	100%	1449	0.49			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA113	11kv FDR MATIALA	TG-DWK055B-1	990	RESIDENTIAL	AMR	Functional	100%	0	0.43			
220kv PAPPAN KALAN 2 GRID	WPKL2103	11kv FDR KAKROLA VILLAGE	561MTY-DWK817A	990	MIXED		Functional	100%	0	0.34			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA125	11kv FDR 210 DDA FLATS SEC-3	TG-DWK052A-1	990	RESIDENTIAL	AMR	Functional	100%	17	0.32			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA122	11kv FDR KAKROLA-2	TG-DWK722A-1	990	RESIDENTIAL		Functional	100%	1	0.31			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA128	11kv FDR PHASE-1 JJ CLY	TP-DWK718A-1	400	RESIDENTIAL	AMR	Functional	100%	213	0.24			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA128	11kv FDR PHASE-1 JJ CLY	561MTY-DWK793A	630	RESIDENTIAL	AMR	Functional	100%	255	0.23			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA123	11kv FDR JJ COLONY SEC-3	TP-DWK764A-1	400	RESIDENTIAL		Functional	100%	115	0.22			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA113	11kv FDR MATIALA	TP-DWK054A-1	400	RESIDENTIAL		Functional	100%	308	0.19			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA128	11kv FDR PHASE-1 JJ CLY	561MTY-DWK807A	250	RESIDENTIAL	AMR	Functional	100%	0	0.17			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA128	11kv FDR PHASE-1 JJ CLY	561MTY-DWK793A	630	RESIDENTIAL	AMR	Functional	100%	196	0.17			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA113	11kv FDR MATIALA	TG-DWK055A-1	990	RESIDENTIAL	AMR	Functional	100%	286	0.12			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA128	11kv FDR PHASE-1 JJ CLY	561MTY-DWK796A	100	RESIDENTIAL	AMR	Functional	100%	2	0.03			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA102	11kv STR 400KVA STATION TRANSFORMER	PM-WTC007A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA123	11kv FDR JJ COLONY SEC-3	TI-DWK189A-1	630	RESIDENTIAL	AMR	Functional	100%	916	0.63	3.75	0.16	4.20%
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA145	11kv FDR COMMAND TANK NO-2	TI-DWK012A-2	630	RESIDENTIAL	AMR	Functional	100%	545	0.51			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA142	11kv FDR MANSARAM PARK	TG-DWK476A-1	630	RESIDENTIAL	AMR	Functional	100%	1025	0.49			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA123	11kv FDR JJ COLONY SEC-3	TI-DWK189A-2	630	RESIDENTIAL	AMR	Functional	100%	400	0.45			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA142	11kv FDR MANSARAM PARK	TI-DWK013A-1	630	RESIDENTIAL		Functional	100%	862	0.44			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA124	11kv FDR SAINIK NAGAR	TI-DWK188A-1	400	RESIDENTIAL	AMR	Functional	100%	327	0.39			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA142	11kv FDR MANSARAM PARK	561MTY-DWK476A	630	RESIDENTIAL		Functional	100%	0	0.39			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA145	11kv FDR COMMAND TANK NO-2	TI-DWK012A-1	400	RESIDENTIAL	AMR	Functional	100%	492	0.33			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA124	11kv FDR SAINIK NAGAR	TI-DWK188A-2	400	RESIDENTIAL	AMR	Functional	100%	45	0.19			
66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	TG-DWK475A-1	630	RESIDENTIAL	AMR	Functional	100%	153	0.08			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA123	11kv FDR JJ COLONY SEC-3	TG-DWK756A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA124	11kv FDR SAINIK NAGAR	TP-DWK042A-1	1600	RESIDENTIAL	AMR	Functional	100%	888	1.37	7.56	0.19	2.47%
66/11 kv G-1 DWARKA GRID	WG1PN130	11kv FDR VIKAS (SONIA WALA)	TI-DWK014A-1	1600	RESIDENTIAL	AMR	Functional	100%	2653	1.06			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA124	11kv FDR SAINIK NAGAR	TP-DWK043A-1	990	RESIDENTIAL	AMR	Functional	100%	1426	0.90			
66/11 kv G-1 DWARKA GRID	WG1PN130	11kv FDR VIKAS (SONIA WALA)	561MTY-DWK014A	990	RESIDENTIAL		Functional	100%	0	0.89			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA142	11kv FDR MANSARAM PARK	DW-HVD023A-1	1025	RESIDENTIAL		Functional	100%	1720	0.88			
66/11 kv G-1 DWARKA GRID	WG1PN130	11kv FDR VIKAS (SONIA WALA)	TI-DWK015A-1	990	RESIDENTIAL	AMR	Functional	100%	3052	0.75			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA124	11kv FDR SAINIK NAGAR	TP-DWK044A-1	990	RESIDENTIAL	AMR	Functional	100%	848	0.69			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA142	11kv FDR MANSARAM PARK	561MTY-HVD023A	1000	RESIDENTIAL		Functional	100%	0	0.56			
66/11 kv G-1 DWARKA GRID	WG1PN130	11kv FDR VIKAS (SONIA WALA)	TP-DWK015A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.38			
66/11 kv G-1 DWARKA GRID	WG1PN130	11kv FDR VIKAS (SONIA WALA)	561MTY-DWK015A	990	RESIDENTIAL	AMR	Functional	100%	0	0.20			

66/11 KV G-1 DWARKA GRID	WG1PN130	11KV FDR VIKAS SONIYAWALA	661MTY-DWK015B	990	RESIDENTIAL	AMR	Functional	100%	0	0.07			
220KV PAPPAN KALAN 2 GRID	WPKL2103	11KV FDR KAKROLA VILLAGE	TK-DWK038A-1	1600	RESIDENTIAL	AMR	Functional	100%	721	0.74	3.23	0.13	3.85%
220KV PAPPAN KALAN 2 GRID	WPKL2103	11KV FDR KAKROLA VILLAGE	TG-DWK037A-1	990	RESIDENTIAL	AMR	Functional	100%	777	0.73			
220KV PAPPAN KALAN 2 GRID	WPKL2101	11KV FDR NAND VIHAR	TK-DWK036A-2	990	RESIDENTIAL	AMR	Functional	100%	416	0.63			
220KV PAPPAN KALAN 2 GRID	WPKL2103	11KV FDR KAKROLA VILLAGE	TK-DWK039A-1	990	RESIDENTIAL		Functional	100%	246	0.62			
220KV PAPPAN KALAN 2 GRID	WPKL2114	11KV FDR GGSIP UNIVERSITY	TP-DWK316A-1	630	RESIDENTIAL	AMR	Functional	100%	800	0.46			
220KV PAPPAN KALAN 2 GRID	WPKL2101	11KV FDR NAND VIHAR	TK-DWK036A-1	400	RESIDENTIAL		Functional	100%	176	0.17			
220KV PAPPAN KALAN-1 GRID	TDTPG102	11KV FDR SEC-10	TI-DWK002A-2	990	RESIDENTIAL	AMR	Functional	100%	718	0.84	5.29	0.08	1.44%
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP110	11KV FDR MADHU VIHAR	TI-DWK004A-2	990	RESIDENTIAL	AMR	Functional	100%	0	0.80			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA116	11KV FDR COMMAND TANK SEC-3 MADHU VIHAR	DW-HVD018A-1	1650	RESIDENTIAL		Functional	100%	1036	0.72			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA116	11KV FDR COMMAND TANK SEC-3 MADHU VIHAR	661MVR-HVD030A	1900	RESIDENTIAL		Functional	100%	873	0.67			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP110	11KV FDR MADHU VIHAR	TI-DWK003A-1	630	RESIDENTIAL	AMR	Functional	100%	694	0.61			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP110	11KV FDR MADHU VIHAR	DW-HVD028A-1	1400	RESIDENTIAL		Functional	100%	516	0.42			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP110	11KV FDR MADHU VIHAR	TI-DWK004A-1	990	RESIDENTIAL	AMR	Functional	100%	2739	0.41			
220KV PAPPAN KALAN-1 GRID	TDTPG101	11KV FDR SEC-2	TI-DWK190A-1	630	RESIDENTIAL	AMR	Functional	100%	314	0.31			
220KV PAPPAN KALAN-1 GRID	TDTPG102	11KV FDR SEC-10	TI-DWK002A-1	630	RESIDENTIAL	AMR	Functional	100%	1420	0.30			
220KV PAPPAN KALAN-1 GRID	TDTPG101	11KV FDR SEC-2	TI-DWK001A-1	630	RESIDENTIAL	AMR	Functional	100%	219	0.28			
220KV PAPPAN KALAN-1 GRID	TDTPG107	11KV FDR NSIT	TP-DWK355A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.00			
220KV PAPPAN KALAN-1 GRID	TDTPG101	11KV FDR SEC-2	TP-DWK560A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.00			
66/11 KV G-1 DWARKA GRID	WG1PN140	11KV FDR NETAJI SUBHAS CHAND APARTMENT SEC-13 PH-1 PKT-1	TI-DWK058A-2	990	RESIDENTIAL	AMR	Functional	100%	1761	0.94	4.76	0.11	2.31%
66/11 KV G-1 DWARKA GRID	WG1PN108	11KV FDR SHIV PARK KAKROLA	TP-DWK462A-1	1600	RESIDENTIAL	AMR	Functional	100%	860	0.79			
66/11 KV G-1 DWARKA GRID	WG1PN140	11KV FDR NETAJI SUBHAS CHAND APARTMENT SEC-13 PH-1 PKT-1	TI-DWK058A-1	990	RESIDENTIAL	AMR	Functional	100%	0	0.70			
66/11 KV G-1 DWARKA GRID	WG1PN108	11KV FDR SHIV PARK KAKROLA	TG-DWK463A-1	990	RESIDENTIAL	AMR	Functional	100%	979	0.70			
220KV PAPPAN KALAN 2 GRID	WPKL2101	11KV FDR NAND VIHAR	DW-HVD010A-1	1000	RESIDENTIAL		Functional	100%	1030	0.68			
66 KV G - 15 P.P.K GRID	WG15P106	11KV FDR SEC-3/13 RED LIGHT	TG-DWK618A-1	990	RESIDENTIAL	AMR	Functional	100%	442	0.60			
66/11 KV G-1 DWARKA GRID	WG1PN108	11KV FDR SHIV PARK KAKROLA	TP-DWK464A-2	990	RESIDENTIAL	AMR	Functional	100%	270	0.24			
66/11 KV G-1 DWARKA GRID	WG1PN108	11KV FDR SHIV PARK KAKROLA	TP-DWK464A-1	990	RESIDENTIAL	AMR	Functional	100%	1441	0.23			
220KV PAPPAN KALAN 2 GRID	WPKL2101	11KV FDR NAND VIHAR	TP-DWK310A-1	100	RESIDENTIAL		Functional	100%	2	0.00			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP607	11KV FDR S/STN NO-2 RAJAPURI (OLD)	DW-HVD020A-1	2900	RESIDENTIAL		Functional	100%	502	1.54	11.76	0.34	2.81%
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP610	11KV FDR S/STN BHARAT VIHAR	TI-DWK006A-2	1600	RESIDENTIAL		Functional	100%	1906	1.27			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP130	11KV FDR O/G-2RAJAPURI S/STN.NO-1	661MVR-HVD019A	2000	RESIDENTIAL		Functional	100%	0	1.13			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP129	11KV FDR O/G-5 AAKASH HOSPITAL SEC-3 DWARKA	TI-DWK040A-2	1600	RESIDENTIAL	AMR	Functional	100%	455	0.95			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA137	11KV FDR PRAGYA CGHS SEC-2 DWARKA	DW-HVD003A-1	3100	RESIDENTIAL		Functional	100%	1634	0.93			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA137	11KV FDR PRAGYA CGHS SEC-2 DWARKA	TG-DWK478A-1	1600	RESIDENTIAL		Functional	100%	955	0.89			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP610	11KV FDR S/STN BHARAT VIHAR	TP-DWK028A-2	1600	COMMERCIAL		Functional	100%	0	0.86			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP610	11KV FDR S/STN BHARAT VIHAR	TI-DWK006A-1	1600	RESIDENTIAL	AMR	Functional	100%	888	0.85			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP129	11KV FDR O/G-5 AAKASH HOSPITAL SEC-3 DWARKA	TG-DWK479A-1	990	RESIDENTIAL	AMR	Functional	100%	3524	0.76			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP130	11KV FDR O/G-2RAJAPURI S/STN.NO-1	DW-HVD019A-1	2175	RESIDENTIAL		Functional	100%	2434	0.74			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA115	11KV FDR G AND S RAJAPURI	TI-DWK027A-1	630	RESIDENTIAL	AMR	Functional	100%	435	0.52			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP129	11KV FDR O/G-5 AAKASH HOSPITAL SEC-3 DWARKA	TG-DWK480A-1	990	RESIDENTIAL		Functional	100%	1446	0.50			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP610	11KV FDR S/STN BHARAT VIHAR	TI-DWK028A-1	1600	RESIDENTIAL	AMR	Functional	100%	1433	0.43			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP129	11KV FDR O/G-5 AAKASH HOSPITAL SEC-3 DWARKA	TG-DWK479A-2	630	RESIDENTIAL		Functional	100%	0	0.41			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP129	11KV FDR O/G-5 AAKASH HOSPITAL SEC-3 DWARKA	TI-DWK040A-1	990	RESIDENTIAL	AMR	Functional	100%	790	0.26			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA115	11KV FDR G AND S RAJAPURI	TP-DWK737A-1	100	RESIDENTIAL		Functional	100%	16	0.04			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP129	11KV FDR O/G-5 AAKASH HOSPITAL SEC-3 DWARKA	TP-DWK321A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP130	11KV FDR O/G-2RAJAPURI S/STN.NO-1	661MVR-DWK007A	990	MIXED		Functional	100%	0	0.00			
66 KV G - 3 P.P.K (BINDAPUR) GRID	WBNDP130	11KV FDR O/G-2RAJAPURI S/STN.NO-1	661MVR-DWK007A	990	MIXED		Functional	100%	0	0.00			
66/11 KV G-1 DWARKA GRID	WG1PN126	11KV FDR SEC-13 PARKWALA	TI-DWK059A-1	630	RESIDENTIAL	AMR	Functional	100%	530	0.22	2.53	0.03	1.04%
66/11 KV G-1 DWARKA GRID	WG1PN126	11KV FDR SEC-13 PARKWALA	TI-DWK215A-1	630	RESIDENTIAL	AMR	Functional	100%	187	0.18			
66 KV G - 15 P.P.K GRID	WG15P113	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-13	TI-DWK061A-1	400	RESIDENTIAL		Functional	100%	210	0.18			

220kV PAPPAN KALAN 2 GRID	WPKL2101	11kV FDR NAND VIHAR	661S13-DWK812A	630	MIXED		Functional	100%	0	0.17			
66/11 kv G-1 DWARKA GRID	WG1PN126	11kV FDR SEC-13 PARKWALA	TI-DWK214A-2	400	RESIDENTIAL	AMR	Functional	100%	179	0.13			
66 kv G - 15 P.P.K GRID	WG15P112	11kV FDR DJA. APPT. SEC-13	TG-DWK760A-2	630	RESIDENTIAL	AMR	Functional	100%	21	0.12			
66/11 kv G-1 DWARKA GRID	WG1PN126	11kV FDR SEC-13 PARKWALA	TI-DWK213A-2	400	RESIDENTIAL	AMR	Functional	100%	137	0.12			
66 kv G - 15 P.P.K GRID	WG15P113	11kV FDR S/STN NO-1 PLOTTED AREA, SEC-13	TI-DWK218A-2	630	RESIDENTIAL		Functional	100%	337	0.12			
220kV PAPPAN KALAN 2 GRID	WPKL2101	11kV FDR NAND VIHAR	661S13-DWK812A	630	MIXED		Functional	100%	0	0.12			
66 kv G - 15 P.P.K GRID	WG15P112	11kV FDR DJA. APPT. SEC-13	TG-DWK072A-2	630	RESIDENTIAL	AMR	Functional	100%	147	0.11			
66 kv G - 15 P.P.K GRID	WG15P113	11kV FDR S/STN NO-1 PLOTTED AREA, SEC-13	TI-DWK218A-1	630	RESIDENTIAL		Functional	100%	5	0.09			
66 kv G - 15 P.P.K GRID	WG15P122	11kV FDR SEC-13 PLOTTED AREA NO-2	TI-DWK217A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.09			
66 kv G - 15 P.P.K GRID	WG15P122	11kV FDR SEC-13 PLOTTED AREA NO-2	TI-DWK217A-2	630	RESIDENTIAL		Functional	100%	48	0.09			
66/11 kv G-1 DWARKA GRID	WG1PN126	11kV FDR SEC-13 PARKWALA	TI-DWK213A-1	400	RESIDENTIAL	AMR	Functional	100%	35	0.08			
66 kv G - 15 P.P.K GRID	WG15P112	11kV FDR DJA. APPT. SEC-13	TP-DWK294A-1	630	RESIDENTIAL	AMR	Functional	100%	35	0.06			
66 kv G - 15 P.P.K GRID	WG15P112	11kV FDR DJA. APPT. SEC-13	TG-DWK627A-1	250	RESIDENTIAL	AMR	Functional	100%	3	0.06			
66/11 kv G-1 DWARKA GRID	WG1PN132	11kV FDR 346/348 M.S. APPT SEC-16 B	661S13-DWK822A	630	MIXED		Functional	100%	0	0.05			
66/11 kv G-1 DWARKA GRID	WG1PN132	11kV FDR 346/348 M.S. APPT SEC-16 B	661S13-DWK822A	630	MIXED		Functional	100%	0	0.05			
66/11 kv G-1 DWARKA GRID	WG1PN132	11kV FDR 346/348 M.S. APPT SEC-16 B	661S13-DWK821A	630	MIXED		Functional	100%	0	0.05			
66/11 kv G-1 DWARKA GRID	WG1PN132	11kV FDR 346/348 M.S. APPT SEC-16 B	661S13-DWK821A	630	MIXED		Functional	100%	0	0.05			
66/11 kv G-1 DWARKA GRID	WG1PN132	11kV FDR 346/348 M.S. APPT SEC-16 B	661S13-DWK820A	630	MIXED		Functional	100%	0	0.05			
66/11 kv G-1 DWARKA GRID	WG1PN132	11kV FDR 346/348 M.S. APPT SEC-16 B	661S13-DWK820A	630	MIXED		Functional	100%	0	0.05			
66/11 kv G-1 DWARKA GRID	WG1PN126	11kV FDR SEC-13 PARKWALA	TI-DWK214A-1	400	RESIDENTIAL	AMR	Functional	100%	52	0.05			
66 kv G - 15 P.P.K GRID	WG15P112	11kV FDR DJA. APPT. SEC-13	TG-DWK072A-3	630	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66/11 kv G-1 DWARKA GRID	WG1PN126	11kV FDR SEC-13 PARKWALA	TG-DWK215A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66 kv G - 15 P.P.K GRID	WG15P112	11kV FDR DJA. APPT. SEC-13	TP-DWK294A-2	630	RESIDENTIAL	AMR	Functional	100%	37	0.04			
66 kv G - 15 P.P.K GRID	WG15P112	11kV FDR DJA. APPT. SEC-13	TP-DWK249A-1	100	RESIDENTIAL		Functional	100%	5	0.03			
220kV PAPPAN KALAN 2 GRID	WPKL2101	11kV FDR NAND VIHAR	661S13-DWK824A	250	MIXED		Functional	100%	0	0.03			
66 kv G - 15 P.P.K GRID	WG15P112	11kV FDR DJA. APPT. SEC-13	TG-DWK760A-1	630	RESIDENTIAL	AMR	Functional	100%	5	0.02			
66 kv G - 15 P.P.K GRID	WG15P122	11kV FDR SEC-13 PLOTTED AREA NO-2	661S13-DWK779A	100	RESIDENTIAL	AMR	Functional	100%	2	0.00			
66 kv G - 15 P.P.K GRID	WG15P112	11kV FDR DJA. APPT. SEC-13	TG-DWK744A-1	630	MIXED	AMR	Functional	100%	2	0.00			
66 kv G - 15 P.P.K GRID	WG15P112	11kV FDR DJA. APPT. SEC-13	TG-DWK744A-2	630	MIXED	AMR	Functional	100%	0	0.00			
66 kv G - 15 P.P.K GRID	WG15P112	11kV FDR DJA. APPT. SEC-13	TG-DWK744A-3	630	MIXED	AMR	Functional	100%	0	0.00			
220kV PAPPAN KALAN 2 GRID	WPKL2101	11kV FDR NAND VIHAR	661S13-DWK809A	990	MIXED		Functional	100%	0	0.51	3.59	0.04	1.01%
66/11 kv G-1 DWARKA GRID	WG1PN140	11kV FDR NETAJI SUBHAS CHAND APARTMENT SEC-13 PH-1 PKT-1	661S13-DWK803A	400	RESIDENTIAL		Functional	100%	157	0.41			
66/11 kv G-1 DWARKA GRID	WG1PN109	11kV FDR SEC-15 J.J. COLONY	661S13-DWK804A	630	RESIDENTIAL		Functional	100%	256	0.27			
220kV PAPPAN KALAN 2 GRID	WPKL2101	11kV FDR NAND VIHAR	661S13-DWK658A	630	RESIDENTIAL	AMR	Functional	100%	182	0.20			
66 kv G - 15 P.P.K GRID	WG15P122	11kV FDR SEC-13 PLOTTED AREA NO-2	TG-DWK492A-2	630	RESIDENTIAL	AMR	Functional	100%	103	0.19			
66 kv G - 15 P.P.K GRID	WG15P113	11kV FDR S/STN NO-1 PLOTTED AREA, SEC-13	TI-DWK060A-2	630	RESIDENTIAL	AMR	Functional	100%	171	0.19			
66 kv G - 15 P.P.K GRID	WG15P122	11kV FDR SEC-13 PLOTTED AREA NO-2	TI-DWK256A-1	630	RESIDENTIAL		Functional	100%	133	0.19			
66 kv G - 15 P.P.K GRID	WG15P113	11kV FDR S/STN NO-1 PLOTTED AREA, SEC-13	TI-DWK060A-1	400	RESIDENTIAL	AMR	Functional	100%	54	0.15			
66 kv G - 15 P.P.K GRID	WG15P122	11kV FDR SEC-13 PLOTTED AREA NO-2	TG-DWK559A-2	630	RESIDENTIAL		Functional	100%	11	0.11			
66/11 kv G-1 DWARKA GRID	WG1PN109	11kV FDR SEC-15 J.J. COLONY	661S13-DWK815A	630	MIXED		Functional	100%	0	0.10			
66/11 kv G-1 DWARKA GRID	WG1PN132	11kV FDR 346/348 M.S. APPT SEC-16 B	661S13-DWK785A	630	RESIDENTIAL	AMR	Functional	100%	22	0.09			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA118	11kV FDR ADARSH PRODYOGIKI + JAINPARK ID SSTN	661S13-DWK818A	250	MIXED		Functional	100%	0	0.09			
66 kv G - 15 P.P.K GRID	WG15P113	11kV FDR S/STN NO-1 PLOTTED AREA, SEC-13	TI-DWK216A-1	630	RESIDENTIAL	AMR	Functional	100%	85	0.09			
66 kv G - 15 P.P.K GRID	WG15P122	11kV FDR SEC-13 PLOTTED AREA NO-2	TI-DWK558A-1	630	RESIDENTIAL		Functional	100%	7	0.09			
66 kv G - 15 P.P.K GRID	WG15P113	11kV FDR S/STN NO-1 PLOTTED AREA, SEC-13	TI-DWK216A-2	630	RESIDENTIAL		Functional	100%	397	0.09			
66 kv G - 15 P.P.K GRID	WG15P112	11kV FDR DJA. APPT. SEC-13	TI-DWK394A-1	630	RESIDENTIAL	AMR	Functional	100%	63	0.07			
66/11 kv G-1 DWARKA GRID	WG1PN132	11kV FDR 346/348 M.S. APPT SEC-16 B	661S13-DWK786A	630	RESIDENTIAL	AMR	Functional	100%	3	0.07			
66 kv G - 15 P.P.K GRID	WG15P112	11kV FDR DJA. APPT. SEC-13	TG-DWK639A-1	630	RESIDENTIAL		Functional	100%	90	0.06			
66 kv G - 15 P.P.K GRID	WG15P112	11kV FDR DJA. APPT. SEC-13	TG-DWK612A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.06			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA113	11kV FDR MATIALA	661S13-DWK826A	250	MIXED		Functional	100%	0	0.06			

66/11 kv G-1 DWARKA GRID	WG1PN132	11kv FDR 346/348 M.S. APPT SEC-16 B	661S13-DWK786A	630	RESIDENTIAL		Functional	100%	0	0.06			
66 kv G - 15 P.P.K GRID	WG15P112	11kv FDR DJA. APPT. SEC-13	TG-DWK394A-2	630	RESIDENTIAL		Functional	100%	0	0.05			
66 kv G - 15 P.P.K GRID	WG15P112	11kv FDR DJA. APPT. SEC-13	TG-DWK639A-2	630	RESIDENTIAL		Functional	100%	0	0.05			
66 kv G - 15 P.P.K GRID	WG15P113	11kv FDR S/STN NO-1 PLOTTED AREA, SEC-13	TG-DWK492A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66 kv G - 15 P.P.K GRID	WG15P112	11kv FDR DJA. APPT. SEC-13	TI-DWK394A-3	630	RESIDENTIAL	AMR	Functional	100%	78	0.04			
66 kv G - 15 P.P.K GRID	WG15P113	11kv FDR S/STN NO-1 PLOTTED AREA, SEC-13	TP-DWK687A-1	250	COMMERCIAL	AMR	Functional	100%	1	0.03			
66 kv G - 15 P.P.K GRID	WG15P112	11kv FDR DJA. APPT. SEC-13	TG-DWK612A-1	630	RESIDENTIAL	AMR	Functional	100%	65	0.03			
66/11 kv G-1 DWARKA GRID	WG1PN132	11kv FDR 346/348 M.S. APPT SEC-16 B	661S13-DWK785A	630	RESIDENTIAL		Functional	100%	13	0.03			
66 kv G - 15 P.P.K GRID	WG15P112	11kv FDR DJA. APPT. SEC-13	661S13-DWK776A	400	COMMERCIAL		Functional	100%	1	0.02			
220kv PAPPAN KALAN 2 GRID	WPKL2110	11kv FDR PP SEC-17	TG-DWK727A-1	400	COMMERCIAL	AMR	Functional	100%	1	0.02			
66 kv G - 15 P.P.K GRID	WG15P112	11kv FDR DJA. APPT. SEC-13	TP-DWK252A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.02			
66 kv G - 15 P.P.K GRID	WG15P112	11kv FDR DJA. APPT. SEC-13	661S13-DWK795A	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kv G - 4 DWARKA GRID	WG4PN118	11kv FDR RELIANCE AMBIT NO-2 SEC-13	661S13-DWK801A	100	RESIDENTIAL		Functional	100%	0	0.01			
66 kv G - 4 DWARKA GRID	WG4PN118	11kv FDR RELIANCE AMBIT NO-2 SEC-13	661S13-DWK801A	100	RESIDENTIAL	AMR	Functional	100%	2	0.01			
66 kv G - 15 P.P.K GRID	WG15P122	11kv FDR SEC-13 PLOTTED AREA NO-2	TG-DWK559A-1	630	RESIDENTIAL		Functional	100%	0	0.00			
66 kv G - 15 P.P.K GRID	WG15P103	11kv FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S13-DWK816A	630	MIXED		Functional	100%	0	0.00			
66 kv G - 15 P.P.K GRID	WG15P103	11kv FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S13-HVD011A-2		MIXED		Functional	100%	0	0.09			
66 kv G - 4 DWARKA GRID	WG4PN117	11kv FDR DDA GROUND-1 SEC-10 RMU NO-1	TI-DWK142A-1	630	RESIDENTIAL		Functional	100%	576	0.28	2.25	0.03	1.26%
66 kv G - 4 DWARKA GRID	WG4PN117	11kv FDR DDA GROUND-1 SEC-10 RMU NO-1	TI-DWK143A-1	400	RESIDENTIAL		Functional	100%	126	0.28			
66 kv G - 4 DWARKA GRID	WG4PN117	11kv FDR DDA GROUND-1 SEC-10 RMU NO-1	TG-DWK142A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.27			
66 kv G - 6 P.P.K GRID	WG6PN122	11kv FDR PERIPHERAL-1 SEC-10(P.P.-1)	TI-DWK149A-1	400	RESIDENTIAL	AMR	Functional	100%	89	0.14			
66 kv G - 6 P.P.K GRID	WG6PN122	11kv FDR PERIPHERAL-1 SEC-10(P.P.-1)	TI-DWK470A-2	630	RESIDENTIAL	AMR	Functional	100%	81	0.09			
G-7 DWARKA GRID	WG7PN113	11kv FDR GODREJ APPT.	TI-DWK395A-1	400	RESIDENTIAL	AMR	Functional	100%	4	0.08			
66 kv G - 6 P.P.K GRID	WG6PN114	11kv FDR DISTRIC COURT-1 SEC-10	TG-DWK626A-2	990	MIXED		Functional	100%	268	0.08			
66 kv G - 6 P.P.K GRID	WG6PN122	11kv FDR PERIPHERAL-1 SEC-10(P.P.-1)	TG-DWK573A-2	630	RESIDENTIAL	AMR	Functional	100%	102	0.07			
66 kv G - 6 P.P.K GRID	WG6PN114	11kv FDR DISTRIC COURT-1 SEC-10	TG-DWK626A-1	990	RESIDENTIAL	AMR	Functional	100%	0	0.07			
66 kv G - 6 P.P.K GRID	WG6PN130	11kv FDR NHAI SEC-10	TI-DWK096A-1	630	RESIDENTIAL	AMR	Functional	100%	6	0.07			
66 kv G - 6 P.P.K GRID	WG6PN122	11kv FDR PERIPHERAL-1 SEC-10(P.P.-1)	TP-DWK178A-2	400	RESIDENTIAL	AMR	Functional	100%	44	0.07			
G-7 DWARKA GRID	WG7PN113	11kv FDR GODREJ APPT.	TI-DWK396A-2	400	RESIDENTIAL	AMR	Functional	100%	75	0.07			
66 kv G - 6 P.P.K GRID	WG6PN122	11kv FDR PERIPHERAL-1 SEC-10(P.P.-1)	TP-DWK178A-3	400	RESIDENTIAL		Functional	100%	39	0.06			
66 kv G - 6 P.P.K GRID	WG6PN122	11kv FDR PERIPHERAL-1 SEC-10(P.P.-1)	TI-DWK470A-1	630	RESIDENTIAL		Functional	100%	83	0.06			
66 kv G - 6 P.P.K GRID	WG6PN121	11kv FDR P.P.NO-2 SEC-10	661S04-DWK182A	400	COMMERCIAL	AMR	Functional	100%	36	0.06			
66 kv G - 6 P.P.K GRID	WG6PN122	11kv FDR PERIPHERAL-1 SEC-10(P.P.-1)	TP-DWK257A-1	400	RESIDENTIAL	AMR	Functional	100%	4	0.06			
66 kv G - 6 P.P.K GRID	WG6PN122	11kv FDR PERIPHERAL-1 SEC-10(P.P.-1)	TG-DWK573A-1	630	RESIDENTIAL		Functional	100%	0	0.05			
66 kv G - 6 P.P.K GRID	WG6PN121	11kv FDR P.P.NO-2 SEC-10	TI-DWK397A-1	630	RESIDENTIAL	AMR	Functional	100%	3	0.05			
66 kv G - 6 P.P.K GRID	WG6PN113	11kv FDR SECTOR-10 HILANSH	TG-DWK144A-2	400	RESIDENTIAL	AMR	Functional	100%	13	0.05			
66 kv G - 6 P.P.K GRID	WG6PN121	11kv FDR P.P.NO-2 SEC-10	TI-DWK397A-2	630	RESIDENTIAL	AMR	Functional	100%	75	0.05			
66 kv G - 6 P.P.K GRID	WG6PN130	11kv FDR NHAI SEC-10	TI-DWK096A-2	630	RESIDENTIAL	AMR	Functional	100%	242	0.05			
66 kv G - 6 P.P.K GRID	WG6PN113	11kv FDR SECTOR-10 HILANSH	TG-DWK144A-1	400	RESIDENTIAL	AMR	Functional	100%	71	0.05			
66 kv G - 6 P.P.K GRID	WG6PN121	11kv FDR P.P.NO-2 SEC-10	661S04-DWK182A	400	RESIDENTIAL	AMR	Functional	100%	38	0.04			
G-7 DWARKA GRID	WG7PN113	11kv FDR GODREJ APPT.	TI-DWK396A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kv G - 15 P.P.K GRID	WG15P108	11kv STR 400KVA STATION TRANSFORMER	VP-WTC118A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.03			
G-7 DWARKA GRID	WG7PN113	11kv FDR GODREJ APPT.	TI-DWK395A-2	400	RESIDENTIAL	AMR	Functional	100%	78	0.03			
66 kv G - 6 P.P.K GRID	WG6PN122	11kv FDR PERIPHERAL-1 SEC-10(P.P.-1)	TP-DWK742A-1	400	MIXED		Functional	100%	1	0.02			
66 kv G - 6 P.P.K GRID	WG6PN122	11kv FDR PERIPHERAL-1 SEC-10(P.P.-1)	TP-DWK742A-2	400	MIXED		Functional	100%	0	0.02			
66 kv G - 6 P.P.K GRID	WG6PN121	11kv FDR P.P.NO-2 SEC-10	TP-DWK757A-1	250	RESIDENTIAL	AMR	Functional	100%	2	0.02			
220kv PAPPAN KALAN 2 GRID	WPKL2114	11kv FDR GGSIP UNIVERSITY	TP-DWK227A-1	990	RESIDENTIAL	AMR	Functional	100%	843	0.54	2.42	0.10	3.93%
220kv PAPPAN KALAN 2 GRID	WPKL2101	11kv FDR NAND VIHAR	TP-DWK226A-1	400	RESIDENTIAL		Functional	100%	633	0.41			
66/11 kv G-1 DWARKA GRID	WG1PN109	11kv FDR SEC-15 J.J. COLONY	TP-DWK046A-1	400	RESIDENTIAL	AMR	Functional	100%	602	0.37			
220kv PAPPAN KALAN 2 GRID	WPKL2114	11kv FDR GGSIP UNIVERSITY	TP-DWK228A-1	400	RESIDENTIAL	AMR	Functional	100%	680	0.36			

220KV PAPPAN KALAN 2 GRID	WPKL2113	11KV FDR EROS MALL + 11KV FDR 736 EWS SEC-16B	TP-DWK048A-1	400	RESIDENTIAL		Functional	100%	479	0.33			
66/11 kv G-1 DWARKA GRID	WG1PN109	11KV FDR SEC-15 J.J. COLONY	TP-DWK047A-1	400	RESIDENTIAL		Functional	100%	437	0.29			
66/11 kv G-1 DWARKA GRID	WG1PN133	11KV FDR SEC-15 SHYAM VIHAR	TP-DWK260A-1	400	RESIDENTIAL	AMR	Functional	100%	263	0.21			
220KV PAPPAN KALAN 2 GRID	WPKL2114	11KV FDR GGSIP UNIVERSITY	TG-DWK502A-1	400	RESIDENTIAL	AMR	Functional	100%	7	0.00			
66 kv G - 4 DWARKA GRID	WG4PN119	11KV FDR SEC-16C DELHI POLICE QUARTERS	TG-DWK713A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			
66/11 kv G-1 DWARKA GRID	WG1PN140	11KV FDR NETAJI SUBHAS CHAND APARTMENT SEC-13 PH-1 PKT-1	TG-DWK766A-1	990	RESIDENTIAL	AMR	Functional	100%	1489	0.86	4.34	0.02	0.47%
66/11 kv G-1 DWARKA GRID	WG1PN110	11KV FDR KAKROLA HOUSING	TG-DWK473A-1	630	COMMERCIAL		Functional	100%	390	0.55			
66/11 kv G-1 DWARKA GRID	WG1PN110	11KV FDR KAKROLA HOUSING	661S13-DWK792A	990	RESIDENTIAL	AMR	Functional	100%	339	0.53			
66/11 kv G-1 DWARKA GRID	WG1PN110	11KV FDR KAKROLA HOUSING	661S13-DWK792A	990	RESIDENTIAL	AMR	Functional	100%	712	0.40			
66/11 kv G-1 DWARKA GRID	WG1PN110	11KV FDR KAKROLA HOUSING	TG-DWK472A-2	630	COMMERCIAL		Functional	100%	137	0.32			
66/11 kv G-1 DWARKA GRID	WG1PN110	11KV FDR KAKROLA HOUSING	TG-DWK472A-1	630	COMMERCIAL		Functional	100%	546	0.31			
66/11 kv G-1 DWARKA GRID	WG1PN110	11KV FDR KAKROLA HOUSING	TG-DWK471A-2	400	COMMERCIAL	AMR	Functional	100%	370	0.29			
220KV PAPPAN KALAN 2 GRID	WPKL2101	11KV FDR NAND VIHAR	TG-DWK333B-1	990	RESIDENTIAL	AMR	Functional	100%	0	0.26			
220KV PAPPAN KALAN 2 GRID	WPKL2101	11KV FDR NAND VIHAR	TP-DWK333A-1	990	COMMERCIAL	AMR	Functional	100%	265	0.24			
220KV PAPPAN KALAN 2 GRID	WPKL2101	11KV FDR NAND VIHAR	TP-DWK312A-1	400	COMMERCIAL	AMR	Functional	100%	3	0.23			
66/11 kv G-1 DWARKA GRID	WG1PN110	11KV FDR KAKROLA HOUSING	TG-DWK471A-1	400	COMMERCIAL		Functional	100%	159	0.20			
66/11 kv G-1 DWARKA GRID	WG1PN110	11KV FDR KAKROLA HOUSING	TG-DWK473A-2	400	COMMERCIAL	AMR	Functional	100%	36	0.18			
66 kv G - 4 DWARKA GRID	WG4PN116	11KV FDR DDA GROUND SEC-10 RMU NO-2	TI-DWK138A-2	630	RESIDENTIAL	AMR	Functional	100%	365	0.19	2.51	0.14	5.35%
66 kv G - 4 DWARKA GRID	WG4PN116	11KV FDR DDA GROUND SEC-10 RMU NO-2	TI-DWK138A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.16			
G-7 DWARKA GRID	WG7PN105	11KV FDR UNIQUE APPT.	TI-DWK129A-1	630	RESIDENTIAL		Functional	100%	124	0.15			
66 kv G - 4 DWARKA GRID	WG4PN116	11KV FDR DDA GROUND SEC-10 RMU NO-2	661S04-DWK137A	400	MIXED	AMR	Functional	100%	121	0.15			
G-7 DWARKA GRID	WG7PN105	11KV FDR UNIQUE APPT.	TI-DWK433A-1	630	RESIDENTIAL	AMR	Functional	100%	4	0.13			
G-7 DWARKA GRID	WG7PN105	11KV FDR UNIQUE APPT.	TI-DWK433A-3	630	RESIDENTIAL	AMR	Functional	100%	49	0.12			
66 kv G - 4 DWARKA GRID	WG4PN116	11KV FDR DDA GROUND SEC-10 RMU NO-2	TI-DWK499A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.11			
220KV PAPPAN KALAN-1 GRID	TDTPG102	11KV FDR SEC-10	TG-DWK258A-1	630	COMMERCIAL	AMR	Functional	100%	128	0.10			
220KV PAPPAN KALAN-1 GRID	TDTPG104	11KV FDR MAHALAXMI SEC-6	TG-DWK356A-2	630	COMMERCIAL		Functional	100%	0	0.10			
220KV PAPPAN KALAN-1 GRID	TDTPG102	11KV FDR SEC-10	TG-DWK258A-2	630	COMMERCIAL	AMR	Functional	100%	0	0.09			
220KV PAPPAN KALAN-1 GRID	TDTPG102	11KV FDR SEC-10	TI-DWK132A-2	630	RESIDENTIAL	AMR	Functional	100%	123	0.09			
66 kv G - 4 DWARKA GRID	WG4PN116	11KV FDR DDA GROUND SEC-10 RMU NO-2	TP-DWK137A-1	400	RESIDENTIAL	AMR	Functional	100%	7	0.09			
G-7 DWARKA GRID	WG7PN105	11KV FDR UNIQUE APPT.	TI-DWK363A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.09			
220KV PAPPAN KALAN-1 GRID	TDTPG106	11KV FDR SEC-19	TI-DWK432A-1	630	RESIDENTIAL	AMR	Functional	100%	137	0.09			
220KV PAPPAN KALAN-1 GRID	TDTPG104	11KV FDR MAHALAXMI SEC-6	TI-DWK133A-2	630	RESIDENTIAL	AMR	Functional	100%	127	0.09			
220KV PAPPAN KALAN-1 GRID	TDTPG102	11KV FDR SEC-10	TI-DWK132A-1	630	RESIDENTIAL		Functional	100%	10	0.09			
220KV PAPPAN KALAN-1 GRID	TDTPG104	11KV FDR MAHALAXMI SEC-6	TG-DWK356A-1	630	COMMERCIAL	AMR	Functional	100%	135	0.08			
220KV PAPPAN KALAN-1 GRID	TDTPG106	11KV FDR SEC-19	TI-DWK432A-2	630	RESIDENTIAL		Functional	100%	0	0.08			
66 kv G - 4 DWARKA GRID	WG4PN116	11KV FDR DDA GROUND SEC-10 RMU NO-2	TI-DWK499A-2	630	RESIDENTIAL	AMR	Functional	100%	136	0.08			
220KV PAPPAN KALAN-1 GRID	TDTPG104	11KV FDR MAHALAXMI SEC-6	TI-DWK133A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.07			
G-7 DWARKA GRID	WG7PN105	11KV FDR UNIQUE APPT.	TI-DWK363A-2	630	RESIDENTIAL	AMR	Functional	100%	154	0.07			
G-7 DWARKA GRID	WG7PN105	11KV FDR UNIQUE APPT.	TG-DWK362A-1	400	RESIDENTIAL	AMR	Functional	100%	61	0.05			
G-7 DWARKA GRID	WG7PN105	11KV FDR UNIQUE APPT.	TG-DWK362A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.05			
G-7 DWARKA GRID	WG7PN105	11KV FDR UNIQUE APPT.	TI-DWK433A-2	630	MIXED		Functional	100%	89	0.05			
220KV PAPPAN KALAN-1 GRID	TDTPG104	11KV FDR MAHALAXMI SEC-6	TG-DWK617A-1	400	COMMERCIAL		Functional	100%	1	0.05			
66 kv G - 4 DWARKA GRID	WG4PN116	11KV FDR DDA GROUND SEC-10 RMU NO-2	TG-DWK159A-1	400	RESIDENTIAL	AMR	Functional	100%	50	0.05			
220KV PAPPAN KALAN-1 GRID	TDTPG104	11KV FDR MAHALAXMI SEC-6	TG-DWK483A-1	400	RESIDENTIAL	AMR	Functional	100%	9	0.04			
G-7 DWARKA GRID	WG7PN105	11KV FDR UNIQUE APPT.	TP-DWK104A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.04			
G-7 DWARKA GRID	WG7PN105	11KV FDR UNIQUE APPT.	TP-DWK434A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.03			
66 kv G - 4 DWARKA GRID	WG4PN116	11KV FDR DDA GROUND SEC-10 RMU NO-2	TG-DWK159A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.03			
220KV PAPPAN KALAN-1 GRID	TDTPG106	11KV FDR SEC-19	TP-DWK699A-1	400	RESIDENTIAL	AMR	Functional	100%	2	0.03			
220KV PAPPAN KALAN-1 GRID	TDTPG106	11KV FDR SEC-19	TP-DWK641A-1	100	RESIDENTIAL		Functional	100%	1	0.02			
66 kv G - 15 P.P.K GRID	WG15P109	11KV FDR KM CHOWK, SEC-11	TI-DWK103A-2	630	RESIDENTIAL	AMR	Functional	100%	199	0.27	3.11	0.04	1.15%

66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TI-DWK101A-1	400	RESIDENTIAL	AMR	Functional	100%	140	0.22			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TI-DWK295A-1	630	RESIDENTIAL	AMR	Functional	100%	147	0.19			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TI-DWK102A-1	630	RESIDENTIAL	AMR	Functional	100%	109	0.18			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TI-DWK271A-1	630	RESIDENTIAL	AMR	Functional	100%	145	0.15			
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	TG-DWK406A-2	630	RESIDENTIAL	AMR	Functional	100%	2	0.11			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S04-DWK403A	630	MIXED	AMR	Functional	100%	1	0.10			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S04-DWK468A	400	RESIDENTIAL	AMR	Functional	100%	72	0.10			
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	TG-DWK406A-3	630	RESIDENTIAL	AMR	Functional	100%	184	0.09			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S04-DWK403A	630	MIXED	AMR	Functional	100%	13	0.09			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TG-DWK562A-1	630	RESIDENTIAL	AMR	Functional	100%	105	0.09			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TG-DWK562A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.09			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TI-DWK103A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.07			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	661S04-DWK636A	500	RESIDENTIAL		Functional	100%	2	0.07			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S04-DWK402A	630	MIXED	AMR	Functional	100%	119	0.07			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK404A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.07			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S04-DWK468A	400	RESIDENTIAL		Functional	100%	0	0.07			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S04-DWK402A	630	MIXED	AMR	Functional	100%	17	0.06			
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	TG-DWK406A-1	630	RESIDENTIAL	AMR	Functional	100%	30	0.06			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S04-DWK402A	630	MIXED	AMR	Functional	100%	18	0.06			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK405A-2	630	RESIDENTIAL	AMR	Functional	100%	32	0.06			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK405A-1	630	RESIDENTIAL		Functional	100%	29	0.06			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TG-DWK494A-2	400	RESIDENTIAL		Functional	100%	53	0.06			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TG-DWK404A-1	400	RESIDENTIAL	AMR	Functional	100%	78	0.06			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S04-DWK403A	630	MIXED		Functional	100%	60	0.06			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK493A-2	400	RESIDENTIAL	AMR	Functional	100%	68	0.06			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK405A-3	630	RESIDENTIAL	AMR	Functional	100%	129	0.05			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TG-DWK554A-1	400	RESIDENTIAL		Functional	100%	0	0.05			
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	661S04-DWK568A	100	RESIDENTIAL	AMR	Functional	100%	8	0.05			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TG-DWK553A-2	400	RESIDENTIAL	AMR	Functional	100%	85	0.05			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TI-DWK241A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TG-DWK494A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK493A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.05			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TG-DWK553A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.04			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TI-DWK241A-1	400	RESIDENTIAL	AMR	Functional	100%	55	0.04			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	661S04-DWK636A	500	RESIDENTIAL		Functional	100%	3	0.04			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TG-DWK554A-2	400	RESIDENTIAL	AMR	Functional	100%	59	0.03			
66 kV G - 4 DWARKA GRID	WG4PN117	11kV FDR DDA GROUND-1 SEC-10 RMU NO-1	661S04-DWK780A	250	RESIDENTIAL	AMR	Functional	100%	1	0.03			
66 kV G - 4 DWARKA GRID	WG4PN119	11kV FDR SEC-16C DELHI POLICE QUARTERS	TI-DWK230A-1	630	RESIDENTIAL		Functional	100%	674	0.27	3.16	0.13	3.83%
66 kV G - 4 DWARKA GRID	WG4PN119	11kV FDR SEC-16C DELHI POLICE QUARTERS	TI-DWK233A-1	630	RESIDENTIAL	AMR	Functional	100%	173	0.21			
66 kV G - 4 DWARKA GRID	WG4PN119	11kV FDR SEC-16C DELHI POLICE QUARTERS	TG-DWK231A-1	630	RESIDENTIAL		Functional	100%	319	0.18			
66 kV G - 4 DWARKA GRID	WG4PN119	11kV FDR SEC-16C DELHI POLICE QUARTERS	TI-DWK234A-1	630	RESIDENTIAL	AMR	Functional	100%	302	0.16			
66 kV G - 4 DWARKA GRID	WG4PN119	11kV FDR SEC-16C DELHI POLICE QUARTERS	TI-DWK232A-1	630	RESIDENTIAL	AMR	Functional	100%	344	0.15			
220kV PAPPAN KALAN 2 GRID	WPKL2113	11kV FDR EROS MALL + 11kV FDR 736 EWS SEC-16B	TG-DWK643A-4	630	COMMERCIAL	AMR	Functional	100%	150	0.14			
220kV PAPPAN KALAN 2 GRID	WPKL2113	11kV FDR EROS MALL + 11kV FDR 736 EWS SEC-16B	TG-DWK643A-3	630	RESIDENTIAL		Functional	100%	262	0.13			
220kV PAPPAN KALAN 2 GRID	WPKL2114	11kV FDR GGSIP UNIVERSITY	TG-DWK572A-1	630	RESIDENTIAL	AMR	Functional	100%	111	0.12			
220kV PAPPAN KALAN 2 GRID	WPKL2101	11kV FDR NAND VIHAR	TI-DWK225A-1	630	RESIDENTIAL	AMR	Functional	100%	84	0.11			
220kV PAPPAN KALAN 2 GRID	WPKL2110	11kV FDR PP SEC-17	TG-DWK589A-1	630	RESIDENTIAL		Functional	100%	2	0.11			
220kV PAPPAN KALAN 2 GRID	WPKL2103	11kV FDR KAKROLA VILLAGE	TI-DWK382A-1	630	RESIDENTIAL	AMR	Functional	100%	328	0.11			
220kV PAPPAN KALAN 2 GRID	WPKL2101	11kV FDR NAND VIHAR	TI-DWK224A-1	630	RESIDENTIAL	AMR	Functional	100%	55	0.11			
220kV PAPPAN KALAN 2 GRID	WPKL2107	11kV FDR JUDICIAL ACADEMY-1	TG-DWK752A-4	630	RESIDENTIAL	AMR	Functional	100%	0	0.10			

220kV PAPPAN KALAN 2 GRID	WPKL2103	11kV FDR KAKROLA VILLAGE	TI-DWK382A-2	990	RESIDENTIAL	AMR	Functional	100%	243	0.10			
220kV PAPPAN KALAN 2 GRID	WPKL2113	11kV FDR EROS MALL + 11kV FDR 736 EWS SEC-16B	TG-DWK643A-1	630	RESIDENTIAL		Functional	100%	217	0.09			
66 kV G - 4 DWARKA GRID	WG4PN118	11kV FDR RELIANCE AMBIT NO-2 SEC-13	TG-DWK591A-1	630	COMMERCIAL	AMR	Functional	100%	1	0.09			
220kV PAPPAN KALAN 2 GRID	WPKL2107	11kV FDR JUDICIAL ACADEMY-1	TG-DWK752A-1	630	RESIDENTIAL	AMR	Functional	100%	261	0.09			
220kV PAPPAN KALAN 2 GRID	WPKL2114	11kV FDR GGSIP UNIVERSITY	TI-DWK451A-2	400	RESIDENTIAL		Functional	100%	62	0.09			
220kV PAPPAN KALAN 2 GRID	WPKL2107	11kV FDR JUDICIAL ACADEMY-1	TG-DWK752A-3	630	RESIDENTIAL	AMR	Functional	100%	0	0.09			
66 kV G - 4 DWARKA GRID	WG4PN118	11kV FDR RELIANCE AMBIT NO-2 SEC-13	TG-DWK591A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.08			
220kV PAPPAN KALAN 2 GRID	WPKL2113	11kV FDR EROS MALL + 11kV FDR 736 EWS SEC-16B	TG-DWK643A-2	630	RESIDENTIAL		Functional	100%	277	0.07			
220kV PAPPAN KALAN 2 GRID	WPKL2103	11kV FDR KAKROLA VILLAGE	TI-DWK381A-1	400	RESIDENTIAL		Functional	100%	508	0.07			
66 kV G - 4 DWARKA GRID	WG4PN119	11kV FDR SEC-16C DELHI POLICE QUARTERS	TG-DWK730A-1	630	RESIDENTIAL	AMR	Functional	100%	38	0.06			
220kV PAPPAN KALAN 2 GRID	WPKL2103	11kV FDR KAKROLA VILLAGE	TI-DWK381A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.06			
220kV PAPPAN KALAN 2 GRID	WPKL2114	11kV FDR GGSIP UNIVERSITY	TI-DWK379A-2	400	RESIDENTIAL		Functional	100%	138	0.05			
220kV PAPPAN KALAN 2 GRID	WPKL2107	11kV FDR JUDICIAL ACADEMY-1	TG-DWK630A-1	400	RESIDENTIAL	AMR	Functional	100%	40	0.05			
220kV PAPPAN KALAN 2 GRID	WPKL2107	11kV FDR JUDICIAL ACADEMY-1	TG-DWK752A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66 kV G - 4 DWARKA GRID	WG4PN119	11kV FDR SEC-16C DELHI POLICE QUARTERS	TP-DWK339A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.05			
220kV PAPPAN KALAN 2 GRID	WPKL2114	11kV FDR GGSIP UNIVERSITY	TI-DWK380A-1	400	RESIDENTIAL		Functional	100%	67	0.04			
220kV PAPPAN KALAN 2 GRID	WPKL2110	11kV FDR PP SEC-17	TG-DWK589A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.04			
220kV PAPPAN KALAN 2 GRID	WPKL2114	11kV FDR GGSIP UNIVERSITY	TI-DWK379A-1	400	RESIDENTIAL		Functional	100%	110	0.04			
220kV PAPPAN KALAN 2 GRID	WPKL2110	11kV FDR PP SEC-17	TP-DWK705A-1	250	COMMERCIAL	AMR	Functional	100%	4	0.03			
66 kV G - 4 DWARKA GRID	WG4PN114	11kV STR 400KVA STATION TRANSFORMER	TP-WTC119A-1	400	COMMERCIAL	AMR	Functional	100%	1	0.03			
220kV PAPPAN KALAN 2 GRID	WPKL2114	11kV FDR GGSIP UNIVERSITY	TI-DWK451A-1	400	RESIDENTIAL	AMR	Functional	100%	134	0.03			
220kV PAPPAN KALAN 2 GRID	WPKL2110	11kV FDR PP SEC-17	TP-DWK690A-1	100	INDUSTRIAL		Functional	100%	6	0.03			
66/11 kV G-1 DWARKA GRID	WG1PN132	11kV FDR 346/348 M.S. APPT SEC-16 B	661S13-DWK787A	630	COMMERCIAL		Functional	100%	11	0.02			
220kV PAPPAN KALAN 2 GRID	WPKL2113	11kV FDR EROS MALL + 11kV FDR 736 EWS SEC-16B	TI-DWK569A-1	630	MIXED	AMR	Functional	100%	44	0.02			
220kV PAPPAN KALAN 2 GRID	WPKL2113	11kV FDR EROS MALL + 11kV FDR 736 EWS SEC-16B	TI-DWK570A-1	630	MIXED		Functional	100%	12	0.01			
220kV PAPPAN KALAN 2 GRID	WPKL2113	11kV FDR EROS MALL + 11kV FDR 736 EWS SEC-16B	TI-DWK570A-2	630	MIXED	AMR	Functional	100%	10	0.01			
220kV PAPPAN KALAN 2 GRID	WPKL2107	11kV FDR JUDICIAL ACADEMY-1	TG-DWK630A-2	400	MIXED	AMR	Functional	100%	0	0.00			
66/11 kV G-1 DWARKA GRID	WG1PN132	11kV FDR 346/348 M.S. APPT SEC-16 B	661S13-DWK787A	630	RESIDENTIAL	AMR	Functional	100%	56	0.00			
220kV PAPPAN KALAN-1 GRID	TDTPG101	11kV FDR SEC-2	TI-DWK108A-1	400	RESIDENTIAL	AMR	Functional	100%	246	0.20	1.14	0.00	0.05%
220kV PAPPAN KALAN-1 GRID	TDTPG101	11kV FDR SEC-2	TI-DWK106A-1	400	RESIDENTIAL		Functional	100%	167	0.17			
220kV PAPPAN KALAN-1 GRID	TDTPG101	11kV FDR SEC-2	TI-DWK368A-2	630	RESIDENTIAL	AMR	Functional	100%	12	0.11			
220kV PAPPAN KALAN-1 GRID	TDTPG101	11kV FDR SEC-2	TI-DWK423A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.10			
220kV PAPPAN KALAN-1 GRID	TDTPG101	11kV FDR SEC-2	TI-DWK424A-1	630	RESIDENTIAL	AMR	Functional	100%	5	0.10			
220kV PAPPAN KALAN-1 GRID	TDTPG101	11kV FDR SEC-2	TI-DWK423A-1	630	RESIDENTIAL	AMR	Functional	100%	125	0.10			
220kV PAPPAN KALAN-1 GRID	TDTPG101	11kV FDR SEC-2	TI-DWK369A-2	630	RESIDENTIAL	AMR	Functional	100%	95	0.09			
220kV PAPPAN KALAN-1 GRID	TDTPG101	11kV FDR SEC-2	TI-DWK371A-1	400	RESIDENTIAL	AMR	Functional	100%	69	0.07			
220kV PAPPAN KALAN-1 GRID	TDTPG101	11kV FDR SEC-2	TI-DWK368A-1	630	RESIDENTIAL	AMR	Functional	100%	99	0.07			
220kV PAPPAN KALAN-1 GRID	TDTPG101	11kV FDR SEC-2	TI-DWK424A-2	630	RESIDENTIAL	AMR	Functional	100%	98	0.05			
220kV PAPPAN KALAN-1 GRID	TDTPG101	11kV FDR SEC-2	TI-DWK369A-1	630	RESIDENTIAL	AMR	Functional	100%	17	0.04			
220kV PAPPAN KALAN-1 GRID	TDTPG101	11kV FDR SEC-2	TI-DWK458A-1	400	RESIDENTIAL	AMR	Functional	100%	10	0.03			
220kV PAPPAN KALAN-1 GRID	TDTPG101	11kV FDR SEC-2	TP-DWK292A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
220kV PAPPAN KALAN-1 GRID	TDTPG107	11kV FDR NSIT	661MVR-DWK805A	250	COMMERCIAL		Functional	100%	1	0.00			
66 kV G - 4 DWARKA GRID	WG4PN108	11kV FDR DDA MEGA HOUSING SEC-18-B	TI-DWK236A-2	400	COMMERCIAL	AMR	Functional	100%	79	0.14	3.04	0.01	0.20%
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK387A-1	630	COMMERCIAL	AMR	Functional	100%	124	0.13			
66 kV G - 4 DWARKA GRID	WG4PN108	11kV FDR DDA MEGA HOUSING SEC-18-B	TI-DWK392A-1	400	COMMERCIAL	AMR	Functional	100%	60	0.13			
66 kV G - 4 DWARKA GRID	WG4PN108	11kV FDR DDA MEGA HOUSING SEC-18-B	TI-DWK392A-2	630	COMMERCIAL	AMR	Functional	100%	254	0.12			
66 kV G - 4 DWARKA GRID	WG4PN108	11kV FDR DDA MEGA HOUSING SEC-18-B	TI-DWK647A-2	630	COMMERCIAL	AMR	Functional	100%	103	0.10			
66 kV G - 4 DWARKA GRID	WG4PN108	11kV FDR DDA MEGA HOUSING SEC-18-B	TI-DWK391A-2	400	COMMERCIAL	AMR	Functional	100%	27	0.10			
66 kV G - 4 DWARKA GRID	WG4PN108	11kV FDR DDA MEGA HOUSING SEC-18-B	TI-DWK646A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.10			
66 kV G - 4 DWARKA GRID	WG4PN108	11kV FDR DDA MEGA HOUSING SEC-18-B	TI-DWK650A-2	630	RESIDENTIAL	AMR	Functional	100%	118	0.10			

66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK646A-1	630	RESIDENTIAL	AMR	Functional	100%	290	0.10			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK391A-1	400	COMMERCIAL	AMR	Functional	100%	200	0.09			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK389A-2	630	COMMERCIAL	AMR	Functional	100%	22	0.09			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK387A-2	630	COMMERCIAL	AMR	Functional	100%	5	0.09			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK386A-2	630	COMMERCIAL	AMR	Functional	100%	14	0.09			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK384A-1	750	COMMERCIAL		Functional	100%	79	0.09			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK236A-1	400	COMMERCIAL	AMR	Functional	100%	23	0.09			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK652A-2	630	RESIDENTIAL		Functional	100%	26	0.08			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK647A-1	630	COMMERCIAL	AMR	Functional	100%	0	0.08			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK651A-1	630	RESIDENTIAL		Functional	100%	0	0.08			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK389A-1	630	COMMERCIAL	AMR	Functional	100%	120	0.07			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK655A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.07			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TG-DWK531A-1	400	RESIDENTIAL	AMR	Functional	100%	63	0.07			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK386A-1	750	COMMERCIAL		Functional	100%	108	0.07			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK649A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.07			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK648A-1	630	COMMERCIAL		Functional	100%	0	0.06			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK654A-2	630	RESIDENTIAL	AMR	Functional	100%	94	0.06			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK648A-2	630	RESIDENTIAL	AMR	Functional	100%	52	0.06			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK385A-1	400	COMMERCIAL	AMR	Functional	100%	82	0.05			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK651A-2	630	RESIDENTIAL	AMR	Functional	100%	63	0.05			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK655A-2	630	RESIDENTIAL		Functional	100%	43	0.05			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK384A-2	630	COMMERCIAL	AMR	Functional	100%	29	0.05			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TG-DWK531A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK654A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK652A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK653A-2	630	RESIDENTIAL	AMR	Functional	100%	59	0.05			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK649A-2	630	RESIDENTIAL	AMR	Functional	100%	225	0.05			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK385A-2	400	COMMERCIAL	AMR	Functional	100%	17	0.04			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK388A-2	400	COMMERCIAL		Functional	100%	50	0.04			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK388A-1	400	COMMERCIAL	AMR	Functional	100%	25	0.04			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK650A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.04			
66 kv G - 4 DWARKA GRID	WG4PN108	11kv FDR DDA MEGA HOUSING SEC-18-B	TI-DWK653A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.04			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK390A-2	400	COMMERCIAL	AMR	Functional	100%	6	0.03			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK390A-1	400	COMMERCIAL	AMR	Functional	100%	30	0.02			
66 kv G - 4 DWARKA GRID	WG4PN107	11kv FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TI-DWK496A-2	630	RESIDENTIAL	AMR	Functional	100%	2	0.18	2.32	0.03	1.29%
66 kv G - 4 DWARKA GRID	WG4PN107	11kv FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TI-DWK412A-2	630	RESIDENTIAL		Functional	100%	121	0.17			
66 kv G - 15 P.P.K GRID	WG15P113	11kv FDR S/STN NO-1 PLOTTED AREA, SEC-13	TG-DWK411A-2	630	RESIDENTIAL	AMR	Functional	100%	92	0.13			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK416A-1	630	RESIDENTIAL	AMR	Functional	100%	63	0.13			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TG-DWK417A-1	630	RESIDENTIAL		Functional	100%	7	0.12			
66 kv G - 4 DWARKA GRID	WG4PN107	11kv FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TG-DWK495A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.11			
66 kv G - 4 DWARKA GRID	WG4PN104	11kv FDR VANKETSWAR HOSPITAL NO-3	TI-DWK251A-1	630	RESIDENTIAL		Functional	100%	29	0.09			
66 kv G - 4 DWARKA GRID	WG4PN107	11kv FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TG-DWK537A-1	630	RESIDENTIAL	AMR	Functional	100%	108	0.08			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TG-DWK417A-2	630	RESIDENTIAL	AMR	Functional	100%	105	0.08			
66 kv G - 4 DWARKA GRID	WG4PN107	11kv FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TG-DWK495A-2	630	RESIDENTIAL	AMR	Functional	100%	106	0.08			
66 kv G - 15 P.P.K GRID	WG15P113	11kv FDR S/STN NO-1 PLOTTED AREA, SEC-13	TG-DWK411A-1	630	RESIDENTIAL	AMR	Functional	100%	18	0.07			
66 kv G - 4 DWARKA GRID	WG4PN104	11kv FDR VANKETSWAR HOSPITAL NO-3	TI-DWK563A-2	400	RESIDENTIAL	AMR	Functional	100%	60	0.07			
66 kv G - 4 DWARKA GRID	WG4PN107	11kv FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TG-DWK497A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.07			
66 kv G - 4 DWARKA GRID	WG4PN107	11kv FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TI-DWK457A-1	400	RESIDENTIAL	AMR	Functional	100%	3	0.06			
66 kv G - 4 DWARKA GRID	WG4PN107	11kv FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TI-DWK414A-1	400	RESIDENTIAL	AMR	Functional	100%	4	0.06			
66 kv G - 15 P.P.K GRID	WG15P120	11kv FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK269A-2	400	RESIDENTIAL	AMR	Functional	100%	57	0.06			

66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK416A-2	630	RESIDENTIAL	AMR	Functional	100%	59	0.06			
66 kV G - 4 DWARKA GRID	WG4PN104	11kV FDR VANKETSWAR HOSPITAL NO-3	TP-DWK324A-1	400	RESIDENTIAL	AMR	Functional	100%	4	0.06			
66 kV G - 4 DWARKA GRID	WG4PN107	11kV FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TI-DWK418A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.06			
66 kV G - 4 DWARKA GRID	WG4PN107	11kV FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TI-DWK457A-2	400	RESIDENTIAL	AMR	Functional	100%	105	0.05			
66 kV G - 4 DWARKA GRID	WG4PN107	11kV FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TI-DWK415A-1	400	RESIDENTIAL		Functional	100%	15	0.05			
66 kV G - 4 DWARKA GRID	WG4PN104	11kV FDR VANKETSWAR HOSPITAL NO-3	TI-DWK251A-2	630	RESIDENTIAL		Functional	100%	83	0.05			
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK413A-1	630	RESIDENTIAL	AMR	Functional	100%	4	0.05			
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	661S13-DWK571A	400	RESIDENTIAL	AMR	Functional	100%	13	0.05			
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	661S13-DWK571A	400	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66 kV G - 4 DWARKA GRID	WG4PN107	11kV FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TI-DWK414A-2	400	RESIDENTIAL	AMR	Functional	100%	64	0.05			
66 kV G - 4 DWARKA GRID	WG4PN107	11kV FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TI-DWK418A-1	400	RESIDENTIAL		Functional	100%	70	0.05			
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK269A-1	400	RESIDENTIAL	AMR	Functional	100%	31	0.04			
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK413A-2	400	RESIDENTIAL	AMR	Functional	100%	79	0.04			
66 kV G - 4 DWARKA GRID	WG4PN107	11kV FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TI-DWK415A-2	400	RESIDENTIAL		Functional	100%	65	0.04			
66 kV G - 4 DWARKA GRID	WG4PN104	11kV FDR VANKETSWAR HOSPITAL NO-3	TG-DWK563A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.04			
66 kV G - 4 DWARKA GRID	WG4PN107	11kV FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	661S13-DWK537A	630	RESIDENTIAL	AMR	Functional	100%	0	0.03			
66 kV G - 4 DWARKA GRID	WG4PN107	11kV FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TG-DWK497A-1	400	RESIDENTIAL	AMR	Functional	100%	71	0.03			
66 kV G - 4 DWARKA GRID	WG4PN107	11kV FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TI-DWK496A-1	630	RESIDENTIAL	AMR	Functional	100%	97	0.00			
66 kV G - 4 DWARKA GRID	WG4PN107	11kV FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TI-DWK412A-1	630	RESIDENTIAL		Functional	100%	14	0.00			
66 kV G - 6 P.P.K GRID	WG6PN101	11kV FDR SEC-19 PKT-1	TP-DWK449A-1	250	RESIDENTIAL	AMR	Functional	100%	2	0.13	3.00	0.00	0.07%
66 kV G - 6 P.P.K GRID	WG6PN101	11kV FDR SEC-19 PKT-1	TG-DWK594A-1	630	RESIDENTIAL		Functional	100%	91	0.12			
66 kV G - 4 DWARKA GRID	WG4PN109	11kV FDR OPG SCHOOL SEC-19-B	TG-DWK561A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.12			
66 kV G - 4 DWARKA GRID	WG4PN109	11kV FDR OPG SCHOOL SEC-19-B	TG-DWK624A-1	630	COMMERCIAL	AMR	Functional	100%	0	0.11			
66 kV G - 6 P.P.K GRID	WG6PN101	11kV FDR SEC-19 PKT-1	TG-DWK628A-2	400	RESIDENTIAL		Functional	100%	53	0.10			
66 kV G - 6 P.P.K GRID	WG6PN101	11kV FDR SEC-19 PKT-1	TI-DWK301A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.10			
66 kV G - 4 DWARKA GRID	WG4PN109	11kV FDR OPG SCHOOL SEC-19-B	TG-DWK549A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.09			
66 kV G - 4 DWARKA GRID	WG4PN106	11kV FDR GULSAN A-IQBAAL	TP-DWK326A-1	400	RESIDENTIAL		Functional	100%	29	0.09			
66 kV G - 4 DWARKA GRID	WG4PN109	11kV FDR OPG SCHOOL SEC-19-B	TI-DWK540A-4	630	RESIDENTIAL	AMR	Functional	100%	0	0.09			
66 kV G - 4 DWARKA GRID	WG4PN106	11kV FDR GULSAN A-IQBAAL	TG-DWK486A-1	400	RESIDENTIAL	AMR	Functional	100%	8	0.08			
66 kV G - 4 DWARKA GRID	WG4PN106	11kV FDR GULSAN A-IQBAAL	TI-DWK445A-1	630	RESIDENTIAL	AMR	Functional	100%	40	0.08			
66 kV G - 4 DWARKA GRID	WG4PN106	11kV FDR GULSAN A-IQBAAL	TI-DWK447A-1	630	RESIDENTIAL		Functional	100%	0	0.08			
66 kV G - 4 DWARKA GRID	WG4PN106	11kV FDR GULSAN A-IQBAAL	TI-DWK447A-2	630	RESIDENTIAL	AMR	Functional	100%	71	0.08			
66 kV G - 4 DWARKA GRID	WG4PN106	11kV FDR GULSAN A-IQBAAL	TI-DWK448A-1	630	RESIDENTIAL		Functional	100%	0	0.08			
66 kV G - 4 DWARKA GRID	WG4PN106	11kV FDR GULSAN A-IQBAAL	TI-DWK625A-2	400	MIXED	AMR	Functional	100%	88	0.08			
66 kV G - 6 P.P.K GRID	WG6PN101	11kV FDR SEC-19 PKT-1	TG-DWK489A-1	400	RESIDENTIAL	AMR	Functional	100%	2	0.08			
66 kV G - 4 DWARKA GRID	WG4PN109	11kV FDR OPG SCHOOL SEC-19-B	TI-DWK539A-1	400	MIXED	AMR	Functional	100%	45	0.08			
66 kV G - 6 P.P.K GRID	WG6PN101	11kV FDR SEC-19 PKT-1	661S13-DWK484A	100	MIXED	AMR	Functional	100%	49	0.08			
66 kV G - 4 DWARKA GRID	WG4PN109	11kV FDR OPG SCHOOL SEC-19-B	TI-DWK540A-1	630	RESIDENTIAL	AMR	Functional	100%	139	0.07			
66 kV G - 4 DWARKA GRID	WG4PN106	11kV FDR GULSAN A-IQBAAL	TG-DWK486A-2	400	RESIDENTIAL	AMR	Functional	100%	78	0.07			
66 kV G - 4 DWARKA GRID	WG4PN106	11kV FDR GULSAN A-IQBAAL	TI-DWK445A-2	630	RESIDENTIAL	AMR	Functional	100%	362	0.07			
66 kV G - 4 DWARKA GRID	WG4PN106	11kV FDR GULSAN A-IQBAAL	TG-DWK564A-2	400	RESIDENTIAL	AMR	Functional	100%	92	0.07			
66 kV G - 4 DWARKA GRID	WG4PN109	11kV FDR OPG SCHOOL SEC-19-B	TG-DWK624A-2	630	COMMERCIAL	AMR	Functional	100%	112	0.07			
66 kV G - 4 DWARKA GRID	WG4PN106	11kV FDR GULSAN A-IQBAAL	TP-DWK326A-2	400	COMMERCIAL		Functional	100%	52	0.07			
66 kV G - 4 DWARKA GRID	WG4PN106	11kV FDR GULSAN A-IQBAAL	TG-DWK510A-1	400	RESIDENTIAL	AMR	Functional	100%	92	0.07			
66 kV G - 4 DWARKA GRID	WG4PN106	11kV FDR GULSAN A-IQBAAL	TI-DWK448A-2	630	RESIDENTIAL	AMR	Functional	100%	53	0.07			
66 kV G - 4 DWARKA GRID	WG4PN109	11kV FDR OPG SCHOOL SEC-19-B	TG-DWK691A-1	630	RESIDENTIAL	AMR	Functional	100%	8	0.07			
66 kV G - 4 DWARKA GRID	WG4PN109	11kV FDR OPG SCHOOL SEC-19-B	TP-DWK719A-1	100	RESIDENTIAL		Functional	100%	2	0.06			
66 kV G - 6 P.P.K GRID	WG6PN101	11kV FDR SEC-19 PKT-1	TG-DWK628A-1	400	RESIDENTIAL		Functional	100%	0	0.06			
66 kV G - 4 DWARKA GRID	WG4PN109	11kV FDR OPG SCHOOL SEC-19-B	TG-DWK561A-2	630	RESIDENTIAL	AMR	Functional	100%	94	0.05			
66 kV G - 4 DWARKA GRID	WG4PN109	11kV FDR OPG SCHOOL SEC-19-B	TI-DWK539A-2	400	RESIDENTIAL	AMR	Functional	100%	27	0.05			

66 kv G - 4 DWARKA GRID	WG4PN106	11kv FDR GULSAN A-IQBAAL	TI-DWK625A-1	400	MIXED	AMR	Functional	100%	0	0.05			
66 kv G - 4 DWARKA GRID	WG4PN106	11kv FDR GULSAN A-IQBAAL	TG-DWK564A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66 kv G - 4 DWARKA GRID	WG4PN106	11kv FDR GULSAN A-IQBAAL	TI-DWK446A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66 kv G - 4 DWARKA GRID	WG4PN109	11kv FDR OPG SCHOOL SEC-19-B	TG-DWK549A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.04			
66 kv G - 4 DWARKA GRID	WG4PN106	11kv FDR GULSAN A-IQBAAL	TI-DWK446A-2	630	RESIDENTIAL	AMR	Functional	100%	94	0.04			
66 kv G - 4 DWARKA GRID	WG4PN109	11kv FDR OPG SCHOOL SEC-19-B	TG-DWK549A-3	630	RESIDENTIAL	AMR	Functional	100%	134	0.04			
66 kv G - 4 DWARKA GRID	WG4PN109	11kv FDR OPG SCHOOL SEC-19-B	TG-DWK692A-1	630	RESIDENTIAL	AMR	Functional	100%	10	0.04			
66 kv G - 6 P.P.K GRID	WG6PN101	11kv FDR SEC-19 PKT-1	TI-DWK301A-1	630	RESIDENTIAL	AMR	Functional	100%	13	0.03			
66 kv G - 4 DWARKA GRID	WG4PN130	11kv FDR 352 DDA FLATS 19 B DWK	661S13-DWK777A	630	RESIDENTIAL		Functional	100%	11	0.03			
66 kv G - 4 DWARKA GRID	WG4PN130	11kv FDR 352 DDA FLATS 19 B DWK	661S13-DWK778A	630	RESIDENTIAL		Functional	100%	6	0.02			
66 kv G - 6 P.P.K GRID	WG6PN101	11kv FDR SEC-19 PKT-1	TG-DWK311A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kv G - 4 DWARKA GRID	WG4PN106	11kv FDR GULSAN A-IQBAAL	661S13-DWK510A	630	MIXED		Functional	100%	0	0.02			
66 kv G - 4 DWARKA GRID	WG4PN130	11kv FDR 352 DDA FLATS 19 B DWK	661S13-DWK777A	630	RESIDENTIAL		Functional	100%	10	0.02			
66 kv G - 4 DWARKA GRID	WG4PN130	11kv FDR 352 DDA FLATS 19 B DWK	661S13-DWK778A	630	RESIDENTIAL		Functional	100%	7	0.01			
66 kv G - 15 P.P.K GRID	WG15P116	11kv FDR WYN DHAM HOTEL SEC-10	661S13-DWK825A	990	MIXED		Functional	100%	0	0.00			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TG-DWK748A-2	630	MIXED		Functional	100%	38	0.00			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TG-DWK748A-3	630	MIXED	AMR	Functional	100%	0	0.00			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TP-DWK748A-1	630	MIXED	AMR	Functional	100%	0	0.00			
66 kv G - 15 P.P.K GRID	WG15P116	11kv FDR WYN DHAM HOTEL SEC-10	661S13-DWK825A	990	MIXED		Functional	100%	0	0.00			
66 kv G - 15 P.P.K GRID	WG15P124	11kv FDR HUMAN CARE SEC-6 VIA SEC-5 S/STN NO-3	TI-DWK193A-2	630	RESIDENTIAL	AMR	Functional	100%	24	0.30	3.22	0.14	4.04%
66 kv G - 15 P.P.K GRID	WG15P124	11kv FDR HUMAN CARE SEC-6 VIA SEC-5 S/STN NO-3	TI-DWK192A-1	630	RESIDENTIAL	AMR	Functional	100%	32	0.18			
66 kv G - 15 P.P.K GRID	WG15P620	11kv FDR BHAWALPUR CGHS SEC-4	TI-DWK264A-1	630	RESIDENTIAL	AMR	Functional	100%	122	0.18			
66 kv G - 15 P.P.K GRID	WG15P124	11kv FDR HUMAN CARE SEC-6 VIA SEC-5 S/STN NO-3	TI-DWK193A-1	630	RESIDENTIAL	AMR	Functional	100%	240	0.15			
66 kv G - 15 P.P.K GRID	WG15P620	11kv FDR BHAWALPUR CGHS SEC-4	661S04-DWK244A	630	RESIDENTIAL		Functional	100%	232	0.13			
66 kv G - 15 P.P.K GRID	WG15P124	11kv FDR HUMAN CARE SEC-6 VIA SEC-5 S/STN NO-3	TI-DWK020A-1	400	RESIDENTIAL	AMR	Functional	100%	164	0.13			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA111	11kv FDR SECTOR-4 DWARKA	TI-DWK435A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.12			
220kv PAPPAN KALAN-1 GRID	TDTPG107	11kv FDR NSIT	661S04-DWK118A	400	RESIDENTIAL		Functional	100%	0	0.11			
66 kv G - 15 P.P.K GRID	WG15P124	11kv FDR HUMAN CARE SEC-6 VIA SEC-5 S/STN NO-3	TI-DWK192A-2	630	RESIDENTIAL	AMR	Functional	100%	152	0.11			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA114	11kv FDR IES	TI-DWK056A-1	400	RESIDENTIAL	AMR	Functional	100%	119	0.11			
66 kv G - 15 P.P.K GRID	WG15P121	11kv FDR S/S NO-3, D.D.A MEGA HOUSES SEC-18	TI-DWK437A-1	630	RESIDENTIAL	AMR	Functional	100%	4	0.11			
66 kv G - 15 P.P.K GRID	WG15P620	11kv FDR BHAWALPUR CGHS SEC-4	661S04-DWK244A	630	RESIDENTIAL		Functional	100%	0	0.11			
66 kv G - 15 P.P.K GRID	WG15P121	11kv FDR S/S NO-3, D.D.A MEGA HOUSES SEC-18	TI-DWK437A-3	630	RESIDENTIAL	AMR	Functional	100%	155	0.10			
66 kv G - 15 P.P.K GRID	WG15P620	11kv FDR BHAWALPUR CGHS SEC-4	TI-DWK303A-2	630	RESIDENTIAL	AMR	Functional	100%	105	0.10			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA114	11kv FDR IES	TI-DWK503A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.10			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA114	11kv FDR IES	TI-DWK503A-2	630	RESIDENTIAL	AMR	Functional	100%	118	0.09			
66 kv G - 15 P.P.K GRID	WG15P620	11kv FDR BHAWALPUR CGHS SEC-4	661S04-DWK244A	630	RESIDENTIAL	AMR	Functional	100%	0	0.09			
66 kv G - 15 P.P.K GRID	WG15P620	11kv FDR BHAWALPUR CGHS SEC-4	TI-DWK095A-1	400	RESIDENTIAL	AMR	Functional	100%	22	0.08			
66 kv G - 15 P.P.K GRID	WG15P620	11kv FDR BHAWALPUR CGHS SEC-4	TI-DWK303A-1	630	RESIDENTIAL	AMR	Functional	100%	21	0.08			
66 kv G - 15 P.P.K GRID	WG15P121	11kv FDR S/S NO-3, D.D.A MEGA HOUSES SEC-18	TP-DWK086A-1	400	RESIDENTIAL		Functional	100%	93	0.08			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA111	11kv FDR SECTOR-4 DWARKA	661S04-DWK268A	500	COMMERCIAL	AMR	Functional	100%	96	0.07			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA111	11kv FDR SECTOR-4 DWARKA	661S04-DWK268A	500	COMMERCIAL	AMR	Functional	100%	0	0.07			
220kv PAPPAN KALAN-1 GRID	TDTPG107	11kv FDR NSIT	661S04-DWK593A	400	MIXED		Functional	100%	0	0.07			
66 kv G - 15 P.P.K GRID	WG15P121	11kv FDR S/S NO-3, D.D.A MEGA HOUSES SEC-18	TP-DWK086A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.07			
220kv PAPPAN KALAN-1 GRID	TDTPG107	11kv FDR NSIT	661S04-DWK118A	400	RESIDENTIAL	AMR	Functional	100%	1	0.07			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA111	11kv FDR SECTOR-4 DWARKA	TI-DWK435A-1	630	RESIDENTIAL	AMR	Functional	100%	103	0.06			
66 kv G - 15 P.P.K GRID	WG15P620	11kv FDR BHAWALPUR CGHS SEC-4	TI-DWK095A-2	400	RESIDENTIAL	AMR	Functional	100%	83	0.06			
66 kv G - 15 P.P.K GRID	WG15P121	11kv FDR S/S NO-3, D.D.A MEGA HOUSES SEC-18	TG-DWK506A-2	630	RESIDENTIAL	AMR	Functional	100%	148	0.05			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA111	11kv FDR SECTOR-4 DWARKA	TI-DWK065A-2	400	RESIDENTIAL	AMR	Functional	100%	93	0.05			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA111	11kv FDR SECTOR-4 DWARKA	TG-DWK439A-1	400	RESIDENTIAL	AMR	Functional	100%	11	0.05			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA111	11kv FDR SECTOR-4 DWARKA	TI-DWK065A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.05			

66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA114	11kv FDR IES	TI-DWK438A-1	400	RESIDENTIAL	AMR	Functional	100%	8	0.04			
66 kv G - 15 P.P.K GRID	WG15P121	11kv FDR S/S NO-3, D.D.A MEGA HOUSES SEC-18	TG-DWK506A-1	630	RESIDENTIAL		Functional	100%	0	0.04			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA114	11kv FDR IES	TI-DWK436A-1	400	RESIDENTIAL		Functional	100%	0	0.04			
66 kv G - 15 P.P.K GRID	WG15P121	11kv FDR S/S NO-3, D.D.A MEGA HOUSES SEC-18	TI-DWK437A-2	630	RESIDENTIAL	AMR	Functional	100%	14	0.04			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA114	11kv FDR IES	TI-DWK436A-2	400	RESIDENTIAL	AMR	Functional	100%	59	0.02			
66 kv G - 15 P.P.K GRID	WG15P121	11kv FDR S/S NO-3, D.D.A MEGA HOUSES SEC-18	TP-DWK440A-1	100	RESIDENTIAL		Functional	100%	1	0.02			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA127	11kv FDR SEC-3 SSTN NO-1	TP-DWK709A-1	100	COMMERCIAL	AMR	Functional	100%	3	0.02			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA111	11kv FDR SECTOR-4 DWARKA	TP-DWK322A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kv G - 15 P.P.K GRID	WG15P620	11kv FDR BHAWALPUR CGHS SEC-4	661504-DWK244A	630	RESIDENTIAL		Functional	100%	0	0.00			
220kv PAPPAN KALAN-1 GRID	TDTPG106	11kv FDR SEC-19	TI-DWK140A-1	630	RESIDENTIAL	AMR	Functional	100%	415	0.43	3.02	0.04	1.19%
220kv PAPPAN KALAN-1 GRID	TDTPG104	11kv FDR MAHALAXMI SEC-6	TI-DWK425A-1	630	RESIDENTIAL	AMR	Functional	100%	125	0.18			
220kv PAPPAN KALAN-1 GRID	TDTPG106	11kv FDR SEC-19	TI-DWK128A-1	400	RESIDENTIAL		Functional	100%	134	0.16			
220kv PAPPAN KALAN-1 GRID	TDTPG106	11kv FDR SEC-19	TI-DWK130A-1	630	RESIDENTIAL	AMR	Functional	100%	130	0.16			
220kv PAPPAN KALAN-1 GRID	TDTPG104	11kv FDR MAHALAXMI SEC-6	TI-DWK426A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.16			
66 kv G - 4 DWARKA GRID	WG4PN116	11kv FDR DDA GROUND SEC-10 RMU NO-2	661504-DWK152A	630	MIXED		Functional	100%	0	0.15			
220kv PAPPAN KALAN-1 GRID	TDTPG106	11kv FDR SEC-19	TG-DWK141A-1	400	RESIDENTIAL	AMR	Functional	100%	213	0.15			
220kv PAPPAN KALAN-1 GRID	TDTPG104	11kv FDR MAHALAXMI SEC-6	TG-DWK358A-1	630	RESIDENTIAL		Functional	100%	119	0.14			
220kv PAPPAN KALAN-1 GRID	TDTPG106	11kv FDR SEC-19	TI-DWK431A-1	630	RESIDENTIAL	AMR	Functional	100%	107	0.13			
220kv PAPPAN KALAN-1 GRID	TDTPG106	11kv FDR SEC-19	TI-DWK427A-1	630	RESIDENTIAL	AMR	Functional	100%	33	0.12			
66 kv G - 4 DWARKA GRID	WG4PN116	11kv FDR DDA GROUND SEC-10 RMU NO-2	661504-DWK300A	630	COMMERCIAL	AMR	Functional	100%	0	0.09			
66 kv G - 4 DWARKA GRID	WG4PN116	11kv FDR DDA GROUND SEC-10 RMU NO-2	661504-DWK300A	630	COMMERCIAL	AMR	Functional	100%	105	0.09			
220kv PAPPAN KALAN-1 GRID	TDTPG104	11kv FDR MAHALAXMI SEC-6	TI-DWK370A-2	630	RESIDENTIAL	AMR	Functional	100%	145	0.08			
220kv PAPPAN KALAN-1 GRID	TDTPG104	11kv FDR MAHALAXMI SEC-6	TG-DWK359A-2	630	RESIDENTIAL		Functional	100%	117	0.08			
220kv PAPPAN KALAN-1 GRID	TDTPG104	11kv FDR MAHALAXMI SEC-6	TG-DWK359A-3	630	RESIDENTIAL		Functional	100%	0	0.08			
220kv PAPPAN KALAN-1 GRID	TDTPG106	11kv FDR SEC-19	TI-DWK136A-1	630	RESIDENTIAL	AMR	Functional	100%	11	0.08			
220kv PAPPAN KALAN-1 GRID	TDTPG106	11kv FDR SEC-19	TI-DWK431A-2	630	RESIDENTIAL	AMR	Functional	100%	16	0.07			
220kv PAPPAN KALAN-1 GRID	TDTPG106	11kv FDR SEC-19	TI-DWK428A-2	400	RESIDENTIAL	AMR	Functional	100%	67	0.07			
220kv PAPPAN KALAN-1 GRID	TDTPG106	11kv FDR SEC-19	TI-DWK131A-1	630	RESIDENTIAL	AMR	Functional	100%	14	0.07			
220kv PAPPAN KALAN-1 GRID	TDTPG106	11kv FDR SEC-19	TG-DWK427A-2	630	MIXED		Functional	100%	89	0.07			
220kv PAPPAN KALAN-1 GRID	TDTPG104	11kv FDR MAHALAXMI SEC-6	TI-DWK490A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.07			
220kv PAPPAN KALAN-1 GRID	TDTPG106	11kv FDR SEC-19	TI-DWK131A-2	630	RESIDENTIAL	AMR	Functional	100%	108	0.07			
220kv PAPPAN KALAN-1 GRID	TDTPG106	11kv FDR SEC-19	TI-DWK136A-2	630	RESIDENTIAL	AMR	Functional	100%	96	0.06			
220kv PAPPAN KALAN-1 GRID	TDTPG104	11kv FDR MAHALAXMI SEC-6	TI-DWK459A-2	630	RESIDENTIAL		Functional	100%	22	0.06			
220kv PAPPAN KALAN-1 GRID	TDTPG104	11kv FDR MAHALAXMI SEC-6	TI-DWK426A-2	400	RESIDENTIAL		Functional	100%	81	0.06			
220kv PAPPAN KALAN-1 GRID	TDTPG104	11kv FDR MAHALAXMI SEC-6	TI-DWK490A-2	400	RESIDENTIAL	AMR	Functional	100%	76	0.05			
220kv PAPPAN KALAN-1 GRID	TDTPG104	11kv FDR MAHALAXMI SEC-6	TG-DWK358A-2	630	MIXED		Functional	100%	0	0.05			
220kv PAPPAN KALAN-1 GRID	TDTPG106	11kv FDR SEC-19	TI-DWK428A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.04			
220kv PAPPAN KALAN-1 GRID	TDTPG104	11kv FDR MAHALAXMI SEC-6	TI-DWK370A-1	630	MIXED		Functional	100%	82	0.03			
220kv PAPPAN KALAN-1 GRID	TDTPG104	11kv FDR MAHALAXMI SEC-6	TI-DWK459A-1	630	RESIDENTIAL	AMR	Functional	100%	5	0.01			
220kv PAPPAN KALAN-1 GRID	TDTPG106	11kv FDR SEC-19	TP-DWK430A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kv G - 4 DWARKA GRID	WG4PN116	11kv FDR DDA GROUND SEC-10 RMU NO-2	661504-DWK152A	630	MIXED		Functional	100%	0	0.00			
66 kv G - 15 P.P.K GRID	WG15P122	11kv FDR SEC-13 PLOTTED AREA NO-2	TI-DWK221A-1	630	RESIDENTIAL	AMR	Functional	100%	293	0.29	2.30	0.11	4.67%
66 kv G - 15 P.P.K GRID	WG15P122	11kv FDR SEC-13 PLOTTED AREA NO-2	TI-DWK222A-1	630	RESIDENTIAL	AMR	Functional	100%	176	0.23			
66 kv G - 15 P.P.K GRID	WG15P122	11kv FDR SEC-13 PLOTTED AREA NO-2	TI-DWK219A-1	630	RESIDENTIAL		Functional	100%	726	0.21			
66 kv G - 15 P.P.K GRID	WG15P122	11kv FDR SEC-13 PLOTTED AREA NO-2	TI-DWK223A-2	630	RESIDENTIAL	AMR	Functional	100%	195	0.21			
66 kv G - 15 P.P.K GRID	WG15P122	11kv FDR SEC-13 PLOTTED AREA NO-2	TI-DWK219A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.17			
66 kv G - 15 P.P.K GRID	WG15P122	11kv FDR SEC-13 PLOTTED AREA NO-2	TG-DWK220A-1	400	RESIDENTIAL	AMR	Functional	100%	133	0.16			
66 kv G - 15 P.P.K GRID	WG15P122	11kv FDR SEC-13 PLOTTED AREA NO-2	TG-DWK220A-2	400	RESIDENTIAL	AMR	Functional	100%	483	0.16			
66 kv G - 15 P.P.K GRID	WG15P122	11kv FDR SEC-13 PLOTTED AREA NO-2	TG-DWK222A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.16			
66 kv G - 15 P.P.K GRID	WG15P122	11kv FDR SEC-13 PLOTTED AREA NO-2	TI-DWK223A-1	630	RESIDENTIAL	AMR	Functional	100%	51	0.11			

66/11 kv G-1 DWARKA GRID	WG1PN123	11kv FDR SAHEED BHAGAT SINGH	TG-DWK566A-2	630	RESIDENTIAL		Functional	100%	307	0.10			
66/11 kv G-1 DWARKA GRID	WG1PN123	11kv FDR SAHEED BHAGAT SINGH	TG-DWK566A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.09			
66/11 kv G-1 DWARKA GRID	WG1PN123	11kv FDR SAHEED BHAGAT SINGH	TG-DWK565A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.09			
66/11 kv G-1 DWARKA GRID	WG1PN132	11kv FDR 346/348 M.S. APPT SEC-16 B	661S13-DWK819A	630	MIXED		Functional	100%	0	0.08			
66/11 kv G-1 DWARKA GRID	WG1PN132	11kv FDR 346/348 M.S. APPT SEC-16 B	661S13-DWK819A	630	MIXED		Functional	100%	0	0.08			
66/11 kv G-1 DWARKA GRID	WG1PN123	11kv FDR SAHEED BHAGAT SINGH	TG-DWK565A-2	400	RESIDENTIAL	AMR	Functional	100%	368	0.06			
66/11 kv G-1 DWARKA GRID	WG1PN123	11kv FDR SAHEED BHAGAT SINGH	TG-DWK567A-2	400	RESIDENTIAL		Functional	100%	205	0.05			
66/11 kv G-1 DWARKA GRID	WG1PN123	11kv FDR SAHEED BHAGAT SINGH	TG-DWK567A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66/11 kv G-1 DWARKA GRID	WG1PN118	11kv STR 400kVA STATION TRANSFORMER	TG-WTC129A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.05			
66 kv G - 4 DWARKA GRID	WG4PN119	11kv FDR SEC-16C DELHI POLICE QUARTERS	TP-DWK689A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66/11 kv G-1 DWARKA GRID	WG1PN121	11kv FDR DMRC SHOPPING COMPLEX	TP-DWK509A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.01			
66 kv G - 4 DWARKA GRID	WG4PN119	11kv FDR SEC-16C DELHI POLICE QUARTERS	TP-DWK640A-1	100	RESIDENTIAL	AMR	Functional	100%	1	0.00			
66 kv G - 15 P.P.K GRID	WG15P113	11kv FDR S/STN NO-1 PLOTTED AREA, SEC-13	TI-DWK017A-1	630	RESIDENTIAL	AMR	Functional	100%	238	0.34	2.29	0.03	1.37%
220kv PAPPAN KALAN 2 GRID	WPKL2110	11kv FDR PP SEC-17	TI-DWK235A-1	630	RESIDENTIAL	AMR	Functional	100%	393	0.33			
220kv PAPPAN KALAN 2 GRID	WPKL2110	11kv FDR PP SEC-17	TI-DWK378A-1	630	RESIDENTIAL		Functional	100%	305	0.30			
66 kv G - 15 P.P.K GRID	WG15P113	11kv FDR S/STN NO-1 PLOTTED AREA, SEC-13	TP-DWK018A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.17			
220kv PAPPAN KALAN 2 GRID	WPKL2110	11kv FDR PP SEC-17	TI-DWK377A-1	630	RESIDENTIAL	AMR	Functional	100%	92	0.16			
220kv PAPPAN KALAN 2 GRID	WPKL2110	11kv FDR PP SEC-17	TI-DWK019A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.15			
220kv PAPPAN KALAN 2 GRID	WPKL2110	11kv FDR PP SEC-17	TI-DWK376A-1	630	RESIDENTIAL	AMR	Functional	100%	68	0.13			
66 kv G - 15 P.P.K GRID	WG15P113	11kv FDR S/STN NO-1 PLOTTED AREA, SEC-13	TI-DWK018A-1	400	RESIDENTIAL	AMR	Functional	100%	318	0.12			
66 kv G - 4 DWARKA GRID	WG4PN118	11kv FDR RELIANCE AMBIT NO-2 SEC-13	TG-DWK588A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.11			
220kv PAPPAN KALAN 2 GRID	WPKL2110	11kv FDR PP SEC-17	TI-DWK019A-2	400	RESIDENTIAL	AMR	Functional	100%	341	0.11			
66 kv G - 4 DWARKA GRID	WG4PN118	11kv FDR RELIANCE AMBIT NO-2 SEC-13	TP-DWK590A-1	630	RESIDENTIAL	AMR	Functional	100%	169	0.07			
220kv PAPPAN KALAN 2 GRID	WPKL2110	11kv FDR PP SEC-17	TG-DWK694A-1	630	RESIDENTIAL		Functional	100%	21	0.07			
66 kv G - 4 DWARKA GRID	WG4PN118	11kv FDR RELIANCE AMBIT NO-2 SEC-13	TP-DWK590A-2	630	RESIDENTIAL	AMR	Functional	100%	20	0.07			
66 kv G - 4 DWARKA GRID	WG4PN118	11kv FDR RELIANCE AMBIT NO-2 SEC-13	TG-DWK588A-1	630	RESIDENTIAL	AMR	Functional	100%	89	0.05			
220kv PAPPAN KALAN 2 GRID	WPKL2110	11kv FDR PP SEC-17	TP-DWK721A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.04			
66 kv G - 15 P.P.K GRID	WG15P113	11kv FDR S/STN NO-1 PLOTTED AREA, SEC-13	TG-DWK609A-2	630	RESIDENTIAL	AMR	Functional	100%	1	0.02			
220kv PAPPAN KALAN 2 GRID	WPKL2110	11kv FDR PP SEC-17	TG-DWK460A-2	400	RESIDENTIAL		Functional	100%	0	0.02			
66 kv G - 15 P.P.K GRID	WG15P113	11kv FDR S/STN NO-1 PLOTTED AREA, SEC-13	661S13-DWK631A	250	RESIDENTIAL	AMR	Functional	100%	2	0.02			
66 kv G - 4 DWARKA GRID	WG4PN107	11kv FDR KRISHNA RESIDENCE SECTOR-18 PLOT-17 DWK	TP-DWK676A-1	100	RESIDENTIAL		Functional	100%	13	0.01			
220kv PAPPAN KALAN 2 GRID	WPKL2110	11kv FDR PP SEC-17	TG-DWK460A-1	630	RESIDENTIAL		Functional	100%	5	0.01			
66 kv G - 15 P.P.K GRID	WG15P113	11kv FDR S/STN NO-1 PLOTTED AREA, SEC-13	661S13-DWK631A	250	RESIDENTIAL	AMR	Functional	100%	25	0.01			
66 kv G - 4 DWARKA GRID	WG4PN118	11kv FDR RELIANCE AMBIT NO-2 SEC-13	TG-DWK613A-1	630	MIXED		Functional	100%	1	0.00			
66 kv G - 15 P.P.K GRID	WG15P113	11kv FDR S/STN NO-1 PLOTTED AREA, SEC-13	TP-DWK461A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.00			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA110	11kv FDR SECTOR-3 DWARKA	TI-DWK186A-1	630	RESIDENTIAL	AMR	Functional	100%	264	0.26	2.50	0.21	7.82%
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA110	11kv FDR SECTOR-3 DWARKA	TI-DWK187A-1	630	RESIDENTIAL	AMR	Functional	100%	487	0.25			
66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	TG-DWK517A-1	630	RESIDENTIAL	AMR	Functional	100%	2	0.22			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA110	11kv FDR SECTOR-3 DWARKA	TI-DWK481A-2	630	RESIDENTIAL		Functional	100%	0	0.18			
66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	TG-DWK517A-2	630	RESIDENTIAL	AMR	Functional	100%	209	0.14			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA110	11kv FDR SECTOR-3 DWARKA	TG-DWK482A-1	630	RESIDENTIAL		Functional	100%	194	0.14			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA122	11kv FDR KAKROLA-2	TG-DWK521A-1	630	RESIDENTIAL	AMR	Functional	100%	115	0.13			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA122	11kv FDR KAKROLA-2	TI-DWK284A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.12			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA125	11kv FDR 210 DDA FLATS SEC-3	TP-DWK637A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.11			
66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	TI-DWK066A-2	630	RESIDENTIAL	AMR	Functional	100%	141	0.10			
66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	TI-DWK066A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.10			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA110	11kv FDR SECTOR-3 DWARKA	TI-DWK481A-1	630	RESIDENTIAL		Functional	100%	100	0.09			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA122	11kv FDR KAKROLA-2	TI-DWK284A-2	630	RESIDENTIAL	AMR	Functional	100%	135	0.09			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA122	11kv FDR KAKROLA-2	TG-DWK521A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.08			
66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	TG-DWK516A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.08			

66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	TG-DWK474A-2	400	RESIDENTIAL		Functional	100%	62	0.08			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA125	11kv FDR 210 DDA FLATS SEC-3	TG-DWK637A-1	630	RESIDENTIAL		Functional	100%	138	0.08			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA122	11kv FDR KAKROLA-2	TG-DWK522A-1	630	RESIDENTIAL	AMR	Functional	100%	19	0.08			
66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	TI-DWK307A-2	630	RESIDENTIAL	AMR	Functional	100%	6	0.08			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA125	11kv FDR 210 DDA FLATS SEC-3	TG-DWK638A-1	630	RESIDENTIAL		Functional	100%	199	0.08			
66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	TI-DWK307A-3	630	RESIDENTIAL	AMR	Functional	100%	112	0.07			
66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	TI-DWK307A-1	630	MIXED		Functional	100%	5	0.06			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA122	11kv FDR KAKROLA-2	TG-DWK522A-2	630	RESIDENTIAL	AMR	Functional	100%	131	0.03			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA122	11kv FDR KAKROLA-2	TP-DWK746A-1	400	COMMERCIAL	AMR	Functional	100%	13	0.03			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA136	11kv FDR DEEN DAYAL UPADHYAYA COLLEGE SEC-3 DWK	661MTY-DWK800A	400	MIXED		Functional	100%	0	0.02			
66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	TG-DWK516A-2	630	RESIDENTIAL	AMR	Functional	100%	95	0.01			
66/11 kv G-1 DWARKA GRID	WG1PN131	11kv FDR VARDHMAN MKT SEC-3	TG-DWK474A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.01			
220kv PAPPAN KALAN-1 GRID	TDTPG101	11kv FDR SEC-2	TI-DWK253A-1	630	COMMERCIAL	AMR	Functional	100%	284	0.13	0.43	0.01	1.36%
220kv PAPPAN KALAN-1 GRID	TDTPG101	11kv FDR SEC-2	TI-DWK253A-2	630	COMMERCIAL	AMR	Functional	100%	17	0.10			
220kv PAPPAN KALAN-1 GRID	TDTPG101	11kv FDR SEC-2	TI-DWK331A-2	400	COMMERCIAL	AMR	Functional	100%	73	0.06			
220kv PAPPAN KALAN-1 GRID	TDTPG101	11kv FDR SEC-2	TI-DWK288A-1	400	COMMERCIAL		Functional	100%	0	0.06			
220kv PAPPAN KALAN-1 GRID	TDTPG101	11kv FDR SEC-2	TI-DWK331A-1	400	COMMERCIAL		Functional	100%	1	0.04			
220kv PAPPAN KALAN-1 GRID	TDTPG107	11kv FDR NSIT	TP-DWK320A-1	100	COMMERCIAL		Functional	100%	8	0.03			
220kv PAPPAN KALAN-1 GRID	TDTPG101	11kv FDR SEC-2	TI-DWK288A-2	400	COMMERCIAL	AMR	Functional	100%	53	0.02			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TI-DWK122A-1	630	RESIDENTIAL		Functional	100%	26	0.44	4.14	0.11	2.61%
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TI-DWK122A-2	630	RESIDENTIAL	AMR	Functional	100%	498	0.31			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	661S13-DWK656A	630	RESIDENTIAL		Functional	100%	2	0.30			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TI-DWK239A-1	630	RESIDENTIAL	AMR	Functional	100%	290	0.26			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TI-DWK123A-2	630	RESIDENTIAL		Functional	100%	349	0.23			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TI-DWK121A-1	630	RESIDENTIAL		Functional	100%	904	0.19			
66 kv G - 6 P.P.K GRID	WG6PN101	11kv FDR SEC-19 PKT-1	TI-DWK127A-1	630	RESIDENTIAL	AMR	Functional	100%	47	0.19			
66 kv G - 6 P.P.K GRID	WG6PN101	11kv FDR SEC-19 PKT-1	TI-DWK237A-1	630	RESIDENTIAL	AMR	Functional	100%	120	0.18			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TI-DWK121A-2	630	RESIDENTIAL		Functional	100%	0	0.18			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TI-DWK151A-1	630	RESIDENTIAL	AMR	Functional	100%	25	0.18			
66 kv G - 6 P.P.K GRID	WG6PN101	11kv FDR SEC-19 PKT-1	TI-DWK127A-2	630	RESIDENTIAL	AMR	Functional	100%	336	0.16			
66 kv G - 6 P.P.K GRID	WG6PN101	11kv FDR SEC-19 PKT-1	TP-DWK488A-1	630	RESIDENTIAL	AMR	Functional	100%	54	0.15			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TI-DWK124A-1	630	RESIDENTIAL	AMR	Functional	100%	189	0.14			
66 kv G - 6 P.P.K GRID	WG6PN122	11kv FDR PERIPHERAL-1 SEC-10(P.P.-1)	TP-DWK328A-1	400	RESIDENTIAL	AMR	Functional	100%	3	0.13			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TI-DWK151A-2	630	RESIDENTIAL	AMR	Functional	100%	366	0.13			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TI-DWK123A-1	630	RESIDENTIAL	AMR	Functional	100%	139	0.13			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TI-DWK124A-2	630	RESIDENTIAL		Functional	100%	23	0.13			
66 kv G - 6 P.P.K GRID	WG6PN101	11kv FDR SEC-19 PKT-1	TI-DWK125A-2	400	RESIDENTIAL	AMR	Functional	100%	184	0.12			
66 kv G - 6 P.P.K GRID	WG6PN101	11kv FDR SEC-19 PKT-1	TI-DWK125A-1	630	RESIDENTIAL	AMR	Functional	100%	17	0.09			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TG-DWK240A-2	400	RESIDENTIAL		Functional	100%	0	0.09			
66 kv G - 6 P.P.K GRID	WG6PN101	11kv FDR SEC-19 PKT-1	TG-DWK487A-1	630	RESIDENTIAL		Functional	100%	127	0.09			
66 kv G - 6 P.P.K GRID	WG6PN101	11kv FDR SEC-19 PKT-1	TG-DWK487A-2	630	RESIDENTIAL		Functional	100%	0	0.09			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TI-DWK240A-1	400	RESIDENTIAL	AMR	Functional	100%	232	0.09			
66 kv G - 6 P.P.K GRID	WG6PN101	11kv FDR SEC-19 PKT-1	TI-DWK238A-2	630	RESIDENTIAL		Functional	100%	290	0.08			
66 kv G - 6 P.P.K GRID	WG6PN101	11kv FDR SEC-19 PKT-1	TI-DWK126A-2	400	RESIDENTIAL	AMR	Functional	100%	80	0.05			
66 kv G - 6 P.P.K GRID	WG6PN101	11kv FDR SEC-19 PKT-1	TI-DWK126A-1	400	RESIDENTIAL	AMR	Functional	100%	15	0.05			
66 kv G - 6 P.P.K GRID	WG6PN101	11kv FDR SEC-19 PKT-1	TI-DWK238A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.03			
66 kv G - 4 DWARKA GRID	WG4PN109	11kv FDR OPG SCHOOL SEC-19-B	661S13-DWK707A	100	RESIDENTIAL	AMR	Functional	100%	0	0.03			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TP-DWK750A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TP-DWK695A-1	100	RESIDENTIAL	AMR	Functional	100%	3	0.01			
66 kv G - 15 P.P.K GRID	WG15P117	11kv FDR PERI PHERAL SEC-19	TG-DWK749A-1	990	MIXED	AMR	Functional	100%	14	0.00			

66 KV G - 15 P.P.K GRID	WG15P117	11KV FDR PERI PHERAL SEC-19	TG-DWK749A-2	990	MIXED		Functional	100%	0	0.00	1.41	0.02	1.42%
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK208A-2	630	COMMERCIAL		Functional	100%	9	0.11			
66 KV G - 15 P.P.K GRID	WG15P103	11KV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK374A-1	630	COMMERCIAL	AMR	Functional	100%	7	0.10			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK207A-1	630	COMMERCIAL	AMR	Functional	100%	21	0.10			
66 KV G - 15 P.P.K GRID	WG15P103	11KV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TG-DWK450A-1	630	COMMERCIAL	AMR	Functional	100%	484	0.09			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK207A-2	630	COMMERCIAL		Functional	100%	33	0.09			
66 KV G - 15 P.P.K GRID	WG15P103	11KV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK373A-2	500	COMMERCIAL	AMR	Functional	100%	11	0.09			
66 KV G - 15 P.P.K GRID	WG15P103	11KV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK372A-2	630	COMMERCIAL	AMR	Functional	100%	47	0.09			
66 KV G - 15 P.P.K GRID	WG15P103	11KV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK204A-1	400	COMMERCIAL	AMR	Functional	100%	31	0.08			
66 KV G - 15 P.P.K GRID	WG15P103	11KV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK205A-1	630	COMMERCIAL		Functional	100%	228	0.08			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK208A-1	630	COMMERCIAL		Functional	100%	513	0.08			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK209A-2	400	COMMERCIAL	AMR	Functional	100%	18	0.06			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK209A-1	400	COMMERCIAL	AMR	Functional	100%	22	0.06			
66 KV G - 15 P.P.K GRID	WG15P103	11KV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK372A-1	630	COMMERCIAL	AMR	Functional	100%	18	0.06			
66 KV G - 15 P.P.K GRID	WG15P103	11KV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK204A-2	400	COMMERCIAL	AMR	Functional	100%	48	0.06			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK206A-1	400	COMMERCIAL		Functional	100%	1	0.05			
66 KV G - 15 P.P.K GRID	WG15P110	11KV FDR PARK PLAZA HOTEL-1 SEC-13	TP-DWK668A-1	630	RESIDENTIAL	AMR	Functional	100%	12	0.05			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK206A-2	400	COMMERCIAL	AMR	Functional	100%	13	0.05			
66 KV G - 15 P.P.K GRID	WG15P103	11KV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK373A-1	400	COMMERCIAL	AMR	Functional	100%	20	0.05			
66 KV G - 15 P.P.K GRID	WG15P103	11KV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK205A-2	630	COMMERCIAL	AMR	Functional	100%	0	0.04			
66 KV G - 15 P.P.K GRID	WG15P103	11KV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TI-DWK374A-2	400	COMMERCIAL	AMR	Functional	100%	47	0.03			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TP-DWK302A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.02			
66 KV G - 15 P.P.K GRID	WG15P110	11KV FDR PARK PLAZA HOTEL-1 SEC-13	TI-DWK210A-1	630	RESIDENTIAL	AMR	Functional	100%	36	0.48	2.64	0.20	6.90%
66 KV G - 15 P.P.K GRID	WG15P110	11KV FDR PARK PLAZA HOTEL-1 SEC-13	TI-DWK210A-2	630	RESIDENTIAL	AMR	Functional	100%	56	0.33			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TG-DWK576A-1	630	RESIDENTIAL	AMR	Functional	100%	203	0.17			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK452A-2	630	RESIDENTIAL	AMR	Functional	100%	110	0.16			
66 KV G - 15 P.P.K GRID	WG15P110	11KV FDR PARK PLAZA HOTEL-1 SEC-13	TI-DWK211A-1	630	RESIDENTIAL	AMR	Functional	100%	49	0.14			
66 KV G - 15 P.P.K GRID	WG15P110	11KV FDR PARK PLAZA HOTEL-1 SEC-13	TI-DWK212A-2	630	RESIDENTIAL	AMR	Functional	100%	78	0.13			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TG-DWK332A-2	630	RESIDENTIAL		Functional	100%	107	0.13			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK309A-2	400	RESIDENTIAL	AMR	Functional	100%	157	0.12			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK309A-1	400	RESIDENTIAL	AMR	Functional	100%	3	0.11			
66 KV G - 15 P.P.K GRID	WG15P110	11KV FDR PARK PLAZA HOTEL-1 SEC-13	TI-DWK134A-2	400	RESIDENTIAL	AMR	Functional	100%	41	0.10			
66 KV G - 4 DWARKA GRID	WG4PN104	11KV FDR VANKETSWAR HOSPITAL NO-3	TI-DWK393A-2	630	RESIDENTIAL		Functional	100%	97	0.09			
66 KV G - 15 P.P.K GRID	WG15P110	11KV FDR PARK PLAZA HOTEL-1 SEC-13	TI-DWK212A-1	630	RESIDENTIAL		Functional	100%	0	0.08			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK285A-1	400	RESIDENTIAL		Functional	100%	24	0.08			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TG-DWK469A-1	400	RESIDENTIAL		Functional	100%	74	0.08			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TG-DWK576A-4	400	RESIDENTIAL	AMR	Functional	100%	0	0.07			
66 KV G - 4 DWARKA GRID	WG4PN104	11KV FDR VANKETSWAR HOSPITAL NO-3	TI-DWK393A-1	630	RESIDENTIAL	AMR	Functional	100%	21	0.07			
66 KV G - 4 DWARKA GRID	WG4PN104	11KV FDR VANKETSWAR HOSPITAL NO-3	TP-DWK441A-1	400	RESIDENTIAL		Functional	100%	1	0.07			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TG-DWK511A-1	630	MIXED	AMR	Functional	100%	59	0.07			
66 KV G - 15 P.P.K GRID	WG15P110	11KV FDR PARK PLAZA HOTEL-1 SEC-13	TI-DWK211A-2	630	RESIDENTIAL	AMR	Functional	100%	21	0.06			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TG-DWK469A-2	400	RESIDENTIAL	AMR	Functional	100%	3	0.06			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TG-DWK576A-3	400	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66 KV G - 4 DWARKA GRID	WG4PN104	11KV FDR VANKETSWAR HOSPITAL NO-3	TP-DWK442A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.05			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK285A-2	400	RESIDENTIAL	AMR	Functional	100%	78	0.04			
66 KV G - 15 P.P.K GRID	WG15P110	11KV FDR PARK PLAZA HOTEL-1 SEC-13	661S04-DWK738A	100	COMMERCIAL		Functional	100%	4	0.03			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TG-DWK332A-3	630	RESIDENTIAL		Functional	100%	0	0.03			
66 KV G - 15 P.P.K GRID	WG15P110	11KV FDR PARK PLAZA HOTEL-1 SEC-13	TI-DWK134A-1	400	RESIDENTIAL	AMR	Functional	100%	14	0.02			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TP-DWK443A-1	100	RESIDENTIAL		Functional	100%	3	0.02			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK452A-1	630	MIXED	AMR	Functional	100%	13	0.00			

66 kV G - 6 P.P.K GRID	WG6PN104	11kV FDR COURT-2 SEC-10 DIST + 11kV FDR PARADISE APTT. SEC-9	TI-DWK398A-1	630	RESIDENTIAL	AMR	Functional	100%	23	0.17	1.58	0.02	1.07%			
66 kV G - 6 P.P.K GRID	WG6PN104	11kV FDR COURT-2 SEC-10 DIST + 11kV FDR PARADISE APTT. SEC-9	661S04-DWK146A	630	RESIDENTIAL	AMR	Functional	100%	0	0.11						
66 kV G - 6 P.P.K GRID	WG6PN104	11kV FDR COURT-2 SEC-10 DIST + 11kV FDR PARADISE APTT. SEC-9	TI-DWK146A-1	630	RESIDENTIAL	AMR	Functional	100%	144	0.11						
66 kV G - 6 P.P.K GRID	WG6PN113	11kV FDR SECTOR-10 HILANSH	TI-DWK147A-1	400	RESIDENTIAL	AMR	Functional	100%	78	0.10						
66 kV G - 6 P.P.K GRID	WG6PN130	11kV FDR NHAI SEC-10	TI-DWK148A-1	400	RESIDENTIAL		Functional	100%	103	0.10						
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	TI-DWK150A-1	630	RESIDENTIAL	AMR	Functional	100%	124	0.10						
66 kV G - 6 P.P.K GRID	WG6PN104	11kV FDR COURT-2 SEC-10 DIST + 11kV FDR PARADISE APTT. SEC-9	TG-DWK286A-1	400	RESIDENTIAL	AMR	Functional	100%	75	0.09						
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	TI-DWK150A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.08						
66 kV G - 6 P.P.K GRID	WG6PN104	11kV FDR COURT-2 SEC-10 DIST + 11kV FDR PARADISE APTT. SEC-9	TI-DWK398A-2	630	RESIDENTIAL		Functional	100%	19	0.07						
66 kV G - 6 P.P.K GRID	WG6PN122	11kV FDR PERIPHERAL-1 SEC-10(P.P.-1)	TI-DWK454A-1	630	MIXED		Functional	100%	70	0.07						
66 kV G - 6 P.P.K GRID	WG6PN122	11kV FDR PERIPHERAL-1 SEC-10(P.P.-1)	TI-DWK145A-1	400	RESIDENTIAL		Functional	100%	8	0.06						
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	TI-DWK399A-1	400	RESIDENTIAL	AMR	Functional	100%	7	0.05						
66 kV G - 6 P.P.K GRID	WG6PN104	11kV FDR COURT-2 SEC-10 DIST + 11kV FDR PARADISE APTT. SEC-9	TG-DWK286A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.05						
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	TI-DWK400A-1	630	RESIDENTIAL		Functional	100%	56	0.05						
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	TI-DWK399A-2	400	RESIDENTIAL		Functional	100%	103	0.05						
66 kV G - 6 P.P.K GRID	WG6PN101	11kV FDR SEC-19 PKT-1	TP-DWK526A-1	100	COMMERCIAL	AMR	Functional	100%	1	0.05						
66 kV G - 6 P.P.K GRID	WG6PN113	11kV FDR SECTOR-10 HILANSH	661S04-DWK165A	400	RESIDENTIAL	AMR	Functional	100%	73	0.04						
66 kV G - 6 P.P.K GRID	WG6PN122	11kV FDR PERIPHERAL-1 SEC-10(P.P.-1)	TI-DWK454A-2	630	RESIDENTIAL	AMR	Functional	100%	58	0.04						
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	TP-DWK401A-1	100	RESIDENTIAL	AMR	Functional	100%	4	0.03						
66 kV G - 6 P.P.K GRID	WG6PN122	11kV FDR PERIPHERAL-1 SEC-10(P.P.-1)	TI-DWK145A-2	400	RESIDENTIAL		Functional	100%	53	0.03						
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	661S04-DWK635A	100	RESIDENTIAL	AMR	Functional	100%	2	0.03						
66 kV G - 6 P.P.K GRID	WG6PN113	11kV FDR SECTOR-10 HILANSH	TG-DWK661A-1	400	RESIDENTIAL	AMR	Functional	100%	29	0.03						
66 kV G - 6 P.P.K GRID	WG6PN130	11kV FDR NHAI SEC-10	TP-DWK319A-1	100	RESIDENTIAL		Functional	100%	1	0.02						
66 kV G - 6 P.P.K GRID	WG6PN113	11kV FDR SECTOR-10 HILANSH	661S04-DWK165A	400	RESIDENTIAL	AMR	Functional	100%	0	0.02						
66 kV G - 6 P.P.K GRID	WG6PN101	11kV FDR SEC-19 PKT-1	TP-DWK338A-1	400	COMMERCIAL	AMR	Functional	100%	7	0.02						
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	661S04-DWK774A	400	RESIDENTIAL		Functional	100%	2	0.01						
66 kV G - 6 P.P.K GRID	WG6PN122	11kV FDR PERIPHERAL-1 SEC-10(P.P.-1)	TP-DWK245A-1	100	RESIDENTIAL		Functional	100%	1	0.01						
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK420A-2	630	RESIDENTIAL	AMR	Functional	100%	4	0.15				1.36	0.13	8.75%
66 kV G - 15 P.P.K GRID	WG15P101	11kV FDR KGL APPT. SEC-18	TI-DWK033A-2	630	RESIDENTIAL		Functional	100%	66	0.14						
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK419A-1	630	RESIDENTIAL	AMR	Functional	100%	2	0.12						
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK419A-2	500	RESIDENTIAL	AMR	Functional	100%	125	0.12						
66 kV G - 15 P.P.K GRID	WG15P101	11kV FDR KGL APPT. SEC-18	TI-DWK032A-2	400	RESIDENTIAL	AMR	Functional	100%	146	0.11						
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK422A-1	500	RESIDENTIAL	AMR	Functional	100%	0	0.11						
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK421A-1	500	RESIDENTIAL	AMR	Functional	100%	0	0.11						
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK421A-2	630	RESIDENTIAL	AMR	Functional	100%	156	0.11						
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK422A-2	630	RESIDENTIAL	AMR	Functional	100%	197	0.11						
66 kV G - 15 P.P.K GRID	WG15P101	11kV FDR KGL APPT. SEC-18	TG-DWK031A-2	630	RESIDENTIAL	AMR	Functional	100%	66	0.10						
66 kV G - 15 P.P.K GRID	WG15P101	11kV FDR KGL APPT. SEC-18	TI-DWK031A-1	630	RESIDENTIAL	AMR	Functional	100%	92	0.10						
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TI-DWK420A-1	500	RESIDENTIAL	AMR	Functional	100%	237	0.05						
66 kV G - 15 P.P.K GRID	WG15P101	11kV FDR KGL APPT. SEC-18	TI-DWK032A-1	400	RESIDENTIAL	AMR	Functional	100%	6	0.05						
66 kV G - 15 P.P.K GRID	WG15P101	11kV FDR KGL APPT. SEC-18	TI-DWK033A-1	630	RESIDENTIAL		Functional	100%	127	0.05						
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TG-DWK679A-1	400	RESIDENTIAL		Functional	100%	1	0.02						
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TP-DWK677A-1	100	RESIDENTIAL	AMR	Functional	100%	7	0.01						
66 kV G - 15 P.P.K GRID	WG15P120	11kV FDR S/STN NO-4 L & T FLATS SEC-18	TP-DWK533A-1	400	RESIDENTIAL		Functional	100%	2	0.01						
66 kV G - 15 P.P.K GRID	WG15P110	11kV FDR PARK PLAZA HOTEL-1 SEC-13	TG-DWK276A-1	630	RESIDENTIAL		Functional	100%	45	0.45	4.09	0.03	0.74%			
66 kV G - 15 P.P.K GRID	WG15P111	11kV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TG-DWK280A-1	630	RESIDENTIAL	AMR	Functional	100%	197	0.38						
66 kV G - 15 P.P.K GRID	WG15P110	11kV FDR PARK PLAZA HOTEL-1 SEC-13	TI-DWK203A-1	630	RESIDENTIAL		Functional	100%	23	0.25						
66 kV G - 15 P.P.K GRID	WG15P121	11kV FDR S/S NO-3, D.D.A MEGA HOUSES SEC-18	TI-DWK198A-1	630	RESIDENTIAL	AMR	Functional	100%	232	0.23						
66 kV G - 15 P.P.K GRID	WG15P110	11kV FDR PARK PLAZA HOTEL-1 SEC-13	TG-DWK023A-1	500	RESIDENTIAL	AMR	Functional	100%	242	0.23						
66 kV G - 15 P.P.K GRID	WG15P121	11kV FDR S/S NO-3, D.D.A MEGA HOUSES SEC-18	TP-DWK199A-1	400	RESIDENTIAL	AMR	Functional	100%	219	0.22						

66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TP-DWK615A-1	400	RESIDENTIAL	AMR	Functional	100%	3	0.18			
66 KV G - 15 P.P.K GRID	WG15P110	11KV FDR PARK PLAZA HOTEL-1 SEC-13	TI-DWK024A-1	630	RESIDENTIAL		Functional	100%	279	0.17			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TI-DWK021A-3	630	RESIDENTIAL	AMR	Functional	100%	196	0.16			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TI-DWK200A-1	630	RESIDENTIAL	AMR	Functional	100%	177	0.16			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TI-DWK200A-2	630	RESIDENTIAL	AMR	Functional	100%	18	0.15			
66 KV G - 15 P.P.K GRID	WG15P110	11KV FDR PARK PLAZA HOTEL-1 SEC-13	TP-DWK023A-2	400	RESIDENTIAL	AMR	Functional	100%	0	0.14			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TI-DWK021A-2	630	RESIDENTIAL	AMR	Functional	100%	14	0.13			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TI-DWK200A-3	630	RESIDENTIAL	AMR	Functional	100%	56	0.13			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TI-DWK022A-1	400	RESIDENTIAL	AMR	Functional	100%	233	0.13			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TI-DWK062A-2	630	RESIDENTIAL	AMR	Functional	100%	118	0.11			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TI-DWK022A-2	400	RESIDENTIAL	AMR	Functional	100%	9	0.10			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TI-DWK201A-1	400	RESIDENTIAL	AMR	Functional	100%	182	0.09			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TG-DWK611A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.08			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TI-DWK021A-1	630	RESIDENTIAL	AMR	Functional	100%	2	0.07			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TG-DWK611A-2	400	RESIDENTIAL	AMR	Functional	100%	116	0.07			
66 KV G - 15 P.P.K GRID	WG15P110	11KV FDR PARK PLAZA HOTEL-1 SEC-13	TI-DWK614A-2	630	RESIDENTIAL	AMR	Functional	100%	40	0.07			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TI-DWK367A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.07			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TI-DWK201A-2	400	RESIDENTIAL	AMR	Functional	100%	107	0.06			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TI-DWK367A-1	630	RESIDENTIAL	AMR	Functional	100%	188	0.05			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TP-DWK491A-1	400	RESIDENTIAL	AMR	Functional	100%	0	0.05			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TI-DWK062A-1	630	RESIDENTIAL		Functional	100%	0	0.05			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TP-DWK491A-2	400	RESIDENTIAL	AMR	Functional	100%	10	0.05			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TP-DWK336A-1	100	RESIDENTIAL		Functional	100%	2	0.03			
66 KV G - 15 P.P.K GRID	WG15P110	11KV FDR PARK PLAZA HOTEL-1 SEC-13	TI-DWK614A-1	630	RESIDENTIAL	AMR	Functional	100%	1	0.02			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK287A-1	400	RESIDENTIAL	AMR	Functional	100%	49	0.01			
66 KV G - 15 P.P.K GRID	WG15P111	11KV FDR S/STN NO-1 PLOTTED AREA, SEC-12	TP-DWK335A-1	100	RESIDENTIAL		Functional	100%	1	0.01			
66 KV G - 15 P.P.K GRID	WG15P104	11KV FDR BAIRWA BHARTI APPT.	TI-DWK287A-2	400	RESIDENTIAL	AMR	Functional	100%	29	0.00			
66 KV G - 4 DWARKA GRID	WG4PN116	11KV FDR DDA GROUND SEC-10 RMU NO-2	TP-DWK261A-1	630	COMMERCIAL	AMR	Functional	100%	7	0.41	3.31	0.04	1.19%
66 KV G - 15 P.P.K GRID	WG15P109	11KV FDR KM CHOWK, SEC-11	TI-DWK100A-1	630	RESIDENTIAL	AMR	Functional	100%	17	0.23			
66 KV G - 15 P.P.K GRID	WG15P109	11KV FDR KM CHOWK, SEC-11	TI-DWK197A-1	630	RESIDENTIAL	AMR	Functional	100%	172	0.17			
66 KV G - 15 P.P.K GRID	WG15P109	11KV FDR KM CHOWK, SEC-11	TI-DWK099A-1	630	RESIDENTIAL	AMR	Functional	100%	107	0.17			
66 KV G - 15 P.P.K GRID	WG15P109	11KV FDR KM CHOWK, SEC-11	TI-DWK196A-1	400	RESIDENTIAL	AMR	Functional	100%	2	0.16			
66 KV G - 15 P.P.K GRID	WG15P109	11KV FDR KM CHOWK, SEC-11	TI-DWK100A-2	630	RESIDENTIAL	AMR	Functional	100%	390	0.15			
66 KV G - 15 P.P.K GRID	WG15P109	11KV FDR KM CHOWK, SEC-11	TI-DWK194A-2	630	RESIDENTIAL	AMR	Functional	100%	14	0.14			
220KV PAPPAN KALAN-1 GRID	TDTPG107	11KV FDR NSIT	TI-DWK098A-1	400	RESIDENTIAL	AMR	Functional	100%	87	0.13			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA127	11KV FDR SEC-3 SSTN NO-1	TG-DWK034A-2	630	RESIDENTIAL		Functional	100%	0	0.12			
66 KV G - 15 P.P.K GRID	WG15P109	11KV FDR KM CHOWK, SEC-11	TI-DWK195A-1	630	RESIDENTIAL		Functional	100%	111	0.11			
66 KV G - 15 P.P.K GRID	WG15P109	11KV FDR KM CHOWK, SEC-11	TI-DWK194A-1	630	RESIDENTIAL	AMR	Functional	100%	41	0.11			
66 KV G - 15 P.P.K GRID	WG15P620	11KV FDR BHAWALPUR CGHS SEC-4	TG-DWK057A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.09			
220KV PAPPAN KALAN-1 GRID	TDTPG107	11KV FDR NSIT	TI-DWK109A-2	630	RESIDENTIAL	AMR	Functional	100%	123	0.09			
220KV PAPPAN KALAN-1 GRID	TDTPG107	11KV FDR NSIT	TI-DWK109A-1	630	RESIDENTIAL	AMR	Functional	100%	11	0.09			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA127	11KV FDR SEC-3 SSTN NO-1	661S04-DWK115A	400	RESIDENTIAL		Functional	100%	104	0.09			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA127	11KV FDR SEC-3 SSTN NO-1	661S04-DWK293A	500	RESIDENTIAL		Functional	100%	0	0.09			
66 KV G - 4 DWARKA GRID	WG4PN116	11KV FDR DDA GROUND SEC-10 RMU NO-2	661S04-DWK261A	400	MIXED	AMR	Functional	100%	202	0.08			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA127	11KV FDR SEC-3 SSTN NO-1	TG-DWK035A-2	630	RESIDENTIAL	AMR	Functional	100%	111	0.08			
220KV PAPPAN KALAN-1 GRID	TDTPG107	11KV FDR NSIT	TI-DWK375A-2	630	RESIDENTIAL	AMR	Functional	100%	100	0.08			
220KV PAPPAN KALAN-1 GRID	TDTPG107	11KV FDR NSIT	TI-DWK304A-2	630	RESIDENTIAL		Functional	100%	89	0.07			
66 KV G - 5 P.P.K (MATIALA) GRID	WMTLA127	11KV FDR SEC-3 SSTN NO-1	661S04-DWK293A	500	RESIDENTIAL		Functional	100%	0	0.07			
66 KV G - 15 P.P.K GRID	WG15P620	11KV FDR BHAWALPUR CGHS SEC-4	TG-DWK057A-1	630	COMMERCIAL	AMR	Functional	100%	182	0.07			
220KV PAPPAN KALAN-1 GRID	TDTPG107	11KV FDR NSIT	TI-DWK375A-1	630	RESIDENTIAL	AMR	Functional	100%	6	0.07			

220kV PAPPAN KALAN-1 GRID	TDTPG107	11kV FDR NSIT	TI-DWK304A-1	630	RESIDENTIAL	AMR	Functional	100%	27	0.07			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TI-DWK195A-2	630	RESIDENTIAL	AMR	Functional	100%	32	0.07			
220kV PAPPAN KALAN-1 GRID	TDTPG107	11kV FDR NSIT	TI-DWK466A-1	400	RESIDENTIAL	AMR	Functional	100%	1	0.06			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TI-DWK196A-2	400	RESIDENTIAL		Functional	100%	114	0.06			
66 kV G - 5 P.P.K (MATIALA) GRID	WMTLA127	11kV FDR SEC-3 SSTN NO-1	661S04-DWK115A	400	RESIDENTIAL		Functional	100%	0	0.06			
66 kV G - 5 P.P.K (MATIALA) GRID	WMTLA127	11kV FDR SEC-3 SSTN NO-1	TG-DWK035A-1	630	RESIDENTIAL	AMR	Functional	100%	0	0.06			
66 kV G - 5 P.P.K (MATIALA) GRID	WMTLA127	11kV FDR SEC-3 SSTN NO-1	TG-DWK034A-1	630	RESIDENTIAL		Functional	100%	121	0.05			
220kV PAPPAN KALAN-1 GRID	TDTPG107	11kV FDR NSIT	TP-DWK467A-1	250	RESIDENTIAL	AMR	Functional	100%	7	0.05			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TP-DWK755A-1	400	COMMERCIAL	AMR	Functional	100%	1	0.02			
220kV PAPPAN KALAN-1 GRID	TDTPG107	11kV FDR NSIT	661S04-DWK710A	100	COMMERCIAL	AMR	Functional	100%	1	0.01			
66 kV G - 15 P.P.K GRID	WG15P102	11kV FDR SEC-11 O/H KGL CHK	TI-DWK097A-1	400	RESIDENTIAL	AMR	Functional	100%	211	0.25	2.91	0.12	3.94%
66 kV G - 15 P.P.K GRID	WG15P102	11kV FDR SEC-11 O/H KGL CHK	TI-DWK456A-1	630	RESIDENTIAL		Functional	100%	204	0.22			
66 kV G - 15 P.P.K GRID	WG15P102	11kV FDR SEC-11 O/H KGL CHK	TI-DWK455A-2	630	RESIDENTIAL	AMR	Functional	100%	142	0.19			
66 kV G - 15 P.P.K GRID	WG15P102	11kV FDR SEC-11 O/H KGL CHK	TI-DWK455A-1	630	RESIDENTIAL	AMR	Functional	100%	6	0.17			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S04-DWK352A	630	RESIDENTIAL	AMR	Functional	100%	51	0.16			
66 kV G - 15 P.P.K GRID	WG15P102	11kV FDR SEC-11 O/H KGL CHK	TI-DWK107A-1	630	RESIDENTIAL		Functional	100%	226	0.15			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S04-DWK352A	630	RESIDENTIAL		Functional	100%	0	0.14			
66 kV G - 15 P.P.K GRID	WG15P102	11kV FDR SEC-11 O/H KGL CHK	TI-DWK409A-1	630	RESIDENTIAL	AMR	Functional	100%	10	0.13			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S04-DWK352A	630	RESIDENTIAL	AMR	Functional	100%	95	0.12			
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	TG-DWK407A-1	630	RESIDENTIAL	AMR	Functional	100%	6	0.11			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TI-DWK620A-1	630	MIXED	AMR	Functional	100%	111	0.11			
66 kV G - 15 P.P.K GRID	WG15P102	11kV FDR SEC-11 O/H KGL CHK	TI-DWK410A-1	630	RESIDENTIAL	AMR	Functional	100%	78	0.10			
66 kV G - 15 P.P.K GRID	WG15P102	11kV FDR SEC-11 O/H KGL CHK	TI-DWK410A-2	630	RESIDENTIAL	AMR	Functional	100%	314	0.10			
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	TI-DWK407A-2	630	RESIDENTIAL	AMR	Functional	100%	77	0.10			
66 kV G - 15 P.P.K GRID	WG15P102	11kV FDR SEC-11 O/H KGL CHK	TI-DWK107A-2	630	RESIDENTIAL		Functional	100%	45	0.10			
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	TG-DWK329A-1	400	RESIDENTIAL	AMR	Functional	100%	59	0.10			
66 kV G - 15 P.P.K GRID	WG15P102	11kV FDR SEC-11 O/H KGL CHK	TG-DWK574A-2	630	RESIDENTIAL		Functional	100%	0	0.10			
66 kV G - 15 P.P.K GRID	WG15P102	11kV FDR SEC-11 O/H KGL CHK	TI-DWK409A-2	630	RESIDENTIAL		Functional	100%	109	0.09			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TI-DWK620A-3	630	RESIDENTIAL	AMR	Functional	100%	0	0.08			
66 kV G - 15 P.P.K GRID	WG15P109	11kV FDR KM CHOWK, SEC-11	TI-DWK620A-2	630	RESIDENTIAL	AMR	Functional	100%	0	0.08			
66 kV G - 15 P.P.K GRID	WG15P102	11kV FDR SEC-11 O/H KGL CHK	TG-DWK574A-1	630	RESIDENTIAL	AMR	Functional	100%	73	0.07			
66 kV G - 15 P.P.K GRID	WG15P102	11kV FDR SEC-11 O/H KGL CHK	TG-DWK575A-1	630	RESIDENTIAL		Functional	100%	57	0.06			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	TP-DWK323A-1	100	RESIDENTIAL		Functional	100%	3	0.06			
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	TG-DWK408A-2	400	RESIDENTIAL	AMR	Functional	100%	12	0.05			
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	TG-DWK408A-1	400	RESIDENTIAL	AMR	Functional	100%	3	0.05			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S04-DWK352A	630	RESIDENTIAL		Functional	100%	49	0.04			
66 kV G - 6 P.P.K GRID	WG6PN121	11kV FDR P.P.NO-2 SEC-10	TG-DWK330A-1	100	RESIDENTIAL	AMR	Functional	100%	2	0.03			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S04-DWK735A	100	RESIDENTIAL		Functional	100%	5	0.03			
66 kV G - 15 P.P.K GRID	WG15P102	11kV FDR SEC-11 O/H KGL CHK	661S04-DWK808A	250	MIXED		Functional	100%	0	0.02			
66 kV G - 15 P.P.K GRID	WG15P102	11kV FDR SEC-11 O/H KGL CHK	661S04-DWK575A	630	RESIDENTIAL	AMR	Functional	100%	0	0.01			
66 kV G - 15 P.P.K GRID	WG15P103	11kV FDR S/STN NO-4 PKT-7 SEC-12 DWK	661S04-DWK811A	990	MIXED		Functional	100%	0	0.01			
66 kV G - 5 P.P.K (MATIALA) GRID	WMTLA113	11kV FDR MATIALA	DW-HVD017A-1	4550	RESIDENTIAL		Functional	100%	5640	1.27	9.88	0.11	1.13%
66 kV G - 5 P.P.K (MATIALA) GRID	WMTLA128	11kV FDR PHASE-1 JJ CLY	DW-HVD001A-1	2525	RESIDENTIAL		Functional	100%	3153	1.09			
66 kV G - 5 P.P.K (MATIALA) GRID	WMTLA104	11kV FDR JAIN COLONY	DW-HVD027A-1	2375	RESIDENTIAL		Functional	100%	816	0.94			
66 kV G - 5 P.P.K (MATIALA) GRID	WMTLA122	11kV FDR KAKROLA-2	DW-HVD015A-1	2475	RESIDENTIAL		Functional	100%	1831	0.91			
66 kV G - 5 P.P.K (MATIALA) GRID	WMTLA118	11kV FDR ADARSH PRODYOGIKI + JAINPARK ID SSTN	661MTY-HVD002A	990	RESIDENTIAL		Functional	100%	1313	0.88			
66 kV G - 5 P.P.K (MATIALA) GRID	WMTLA118	11kV FDR ADARSH PRODYOGIKI + JAINPARK ID SSTN	661MTY-DWK050A	990	RESIDENTIAL	AMR	Functional	100%	341	0.80			
66 kV G - 5 P.P.K (MATIALA) GRID	WMTLA118	11kV FDR ADARSH PRODYOGIKI + JAINPARK ID SSTN	TI-DWK045A-1	990	RESIDENTIAL		Functional	100%	0	0.73			
66 kV G - 5 P.P.K (MATIALA) GRID	WMTLA104	11kV FDR JAIN COLONY	TG-DWK063A-1	630	RESIDENTIAL		Functional	100%	648	0.63			
66 kV G - 5 P.P.K (MATIALA) GRID	WMTLA118	11kV FDR ADARSH PRODYOGIKI + JAINPARK ID SSTN	TI-DWK045A-2	990	RESIDENTIAL		Functional	100%	2003	0.55			

66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA113	11kv FDR MATIALA	TI-DWK064A-2	990	RESIDENTIAL	AMR	Functional	100%	914	0.51			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA122	11kv FDR KAKROLA-2	DW-HVD022A-1	900	RESIDENTIAL		Functional	100%	785	0.43			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA128	11kv FDR PHASE-1 JJ CLY	661MTY-HVD001A	625	MIXED		Functional	100%	0	0.41			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA122	11kv FDR KAKROLA-2	TI-DWK049A-2	400	RESIDENTIAL	AMR	Functional	100%	244	0.30			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA113	11kv FDR MATIALA	TI-DWK064A-1	400	COMMERCIAL	AMR	Functional	100%	0	0.26			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA128	11kv FDR PHASE-1 JJ CLY	661MTY-DWK781A	630	RESIDENTIAL	AMR	Functional	100%	241	0.17			
66 kv G - 5 P.P.K (MATIALA) GRID	WMTLA122	11kv FDR KAKROLA-2	TI-DWK049A-1	400	RESIDENTIAL	AMR	Functional	100%	192	0.10			
220kv PAPPAN KALAN 2 GRID	WPKL2101	11kv FDR NAND VIHAR	DK-HVD024A-1	1800	RESIDENTIAL		Functional	100%	970	0.80	1.82	0.02	1.29%
66/11 kv G-1 DWARKA GRID	WG1PN140	11kv FDR NETAJI SUBHAS CHAND APARTMENT SEC-13 PH-1 PKT-1	DK-HVD026A-1	1550	RESIDENTIAL		Functional	100%	983	0.69			
220kv PAPPAN KALAN 2 GRID	WPKL2101	11kv FDR NAND VIHAR	DW-HVD013A-1	900	RESIDENTIAL		Functional	100%	426	0.36			
66 kv G - 15 P.P.K GRID	WG15P106	11kv FDR SEC-3/13 RED LIGHT	DW-HVD005A-1	3175	RESIDENTIAL		Functional	100%	1975	1.44	5.27	0.06	1.18%
66 kv G - 15 P.P.K GRID	WG15P106	11kv FDR SEC-3/13 RED LIGHT	DL-HVD025A-1	1375	RESIDENTIAL		Functional	100%	987	0.77			
66/11 kv G-1 DWARKA GRID	WG1PN108	11kv FDR SHIV PARK KAKROLA	TP-DWK525A-1	990	RESIDENTIAL	AMR	Functional	100%	416	0.61			
66/11 kv G-1 DWARKA GRID	WG1PN109	11kv FDR SEC-15 J.J. COLONY	DW-HVD008A-1	2850	RESIDENTIAL		Functional	100%	1628	0.49			
66/11 kv G-1 DWARKA GRID	WG1PN109	11kv FDR SEC-15 J.J. COLONY	661S13-HVD008A	625	MIXED		Functional	100%	0	0.42			
66/11 kv G-1 DWARKA GRID	WG1PN109	11kv FDR SEC-15 J.J. COLONY	661S13-HVD007A	630	MIXED		Functional	100%	0	0.41			
66/11 kv G-1 DWARKA GRID	WG1PN109	11kv FDR SEC-15 J.J. COLONY	DW-HVD007A-1	2025	RESIDENTIAL		Functional	100%	1551	0.40			
66/11 kv G-1 DWARKA GRID	WG1PN109	11kv FDR SEC-15 J.J. COLONY	DW-HVD006A-1	775	RESIDENTIAL		Functional	100%	1285	0.32			
220kv PAPPAN KALAN 2 GRID	WPKL2113	11kv FDR EROS MALL + 11kv FDR 736 EWS SEC-16B	661S13-HVD009A	525	MIXED		Functional	100%	70	0.29			
66/11 kv G-1 DWARKA GRID	WG1PN109	11kv FDR SEC-15 J.J. COLONY	661S13-HVD031A	900	MIXED		Functional	100%	590	0.18			
66 kv G - 4 DWARKA GRID	WG4PN118	11kv FDR RELIANCE AMBIT NO-2 SEC-13	TG-DWK579A-1	630	RESIDENTIAL	AMR	Functional	100%	31	0.15	0.35	0.00	1.39%
66 kv G - 4 DWARKA GRID	WG4PN118	11kv FDR RELIANCE AMBIT NO-2 SEC-13	TG-DWK577A-1	630	RESIDENTIAL		Functional	100%	36	0.10			
66 kv G - 4 DWARKA GRID	WG4PN118	11kv FDR RELIANCE AMBIT NO-2 SEC-13	TG-DWK578A-1	630	RESIDENTIAL		Functional	100%	0	0.06			
66 kv G - 4 DWARKA GRID	WG4PN118	11kv FDR RELIANCE AMBIT NO-2 SEC-13	TG-DWK578A-2	630	RESIDENTIAL	AMR	Functional	100%	36	0.04			
66 kv G - 4 DWARKA GRID	WG4PN118	11kv FDR RELIANCE AMBIT NO-2 SEC-13	TG-DWK579A-2	630	RESIDENTIAL	AMR	Functional	100%	22	0.01			