

## General Information

1	Name of the DISCOM	Tata Steel Limited		
2	i) Year of Establishment	26-08-1907 (As per PAN Card)		
	ii) Government/Public/Private	Private		
3	DISCOM's Contact details & Address			
i	City/Town/Village	Northern Town, Bistupur Jamshedpur Jharkhand 831001		
ii	District	East Singhbhum		
iii	State	Jharkhand	Pin	831001
iv	Telephone	0657-6652118	Fax	
4	Registered Office			
i	Company's Chief Executive Name	Mr. T V Narendran		
ii	Designation	Managing Director		
iii	Address	Bombay House 24 Homi Mody Street Fort		
iv	City/Town/Village	Mumbai	P.O.	
v	District			
vi	State	Maharashtra	Pin	400001
vii	Telephone	91 22 66658282	Fax	91 22 66658282
5	Nodal Officer Details*			
i	Nodal Officer Name (Designated at DISCOM's)	Mr. Harendra Verma		
ii	Designation	Head LDC & Power Management, Electrical T & D		
iii	Address	Tata Steel Limited, Bistupur Jamshedpur		
iv	City/Town/Village	Jamshedpur	P.O.	Bistupur
v	District	East Singhbhum		
vi	State	Jharkhand	Pin	831001
vii	Telephone	0657-6645530	Fax	
6	Energy Manager Details*			
i	Name	Mr. Pradeep Kumar		
ii	Designation	Energy Auditor	Whether EA or EM	NA
iii	EA/EM Registration No.	NA		
iv	Telephone	0657-6644915	Fax	
v	Mobile	9204058293	E-mail ID	<a href="mailto:prakumar@tatasteel.com">prakumar@tatasteel.com</a>
7	Period of Information			
	Year of (FY) information including Date and Month (Start & End)	1st July 2023 to 30th Sept 2023		

Performance Summary of Electricity Distribution Companies		1st July 2023- 30th Sept 2023
1	Period of Information Year of (FY) information including Date and Month (Start & End)	
2	Technical Details	
(a)	Energy Input Details	
(i)	Input Energy Purchase (From Generation Source)	Million kwh 814.14
(ii)	Net input energy (at DISCOM Periphery after adjusting the transmission losses and energy traded)	Million kwh 771.59
(iii)	Total Energy billed (is the Net energy billed, adjusted for energy traded))	Million kwh 750.20
(b)	Transmission and Distribution (T&D) loss Details	Million kwh 21.40 % 2.77%
(c)	Collection Efficiency	% 104.34%
	Aggregate Technical & Commercial Loss	% -1.45%

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such

Authorised Signatory and Seal


f saroj (saroj kumar)

Name of Authorised Signatory HARENDRA VERMA  
Name of the DISCOM: TATA STEEL LIMITED  
Full Address:- BISTUPUR, JAMSHEDPUR

Signature:-

Name of AEA\*:

Registration Number:

  
PRADEEP KUMAR  
NA



Seal

Form-Details of Input Infrastructure					
1	Parameters	Total	Covered during In audit	Verified by Auditor In Sample Check	Remarks (Source of data)
i	Number of circles	1			
ii	Number of divisions	1			
iii	Number of sub-divisions	NA			
iv	Number of Sub-stations	14			
v	Number of Power Transformers	30			
vi	Total capacity of the PTRs in MVA	1508			
vii	Number of Capacitor banks	0			
viii	Total capacity of the Capacitor Banks in MVar	0			
ix	Number of feeders	4043			
x	Number of DTs	344			
xi	Total Capacity of DTs in MVA	231.14			
xii	Number of consumers	50178			
2	Parameters	66kV and above	33kV	11kV, 22kV, 20kV, 6.6kV, 3.3kV	LT
a. i.	Number of conventional metered consumers	2			38087
ii	Number of consumers with 'smart' meters				240
iii	Number of consumers with 'smart prepaid' meters				
iv	Number of consumers with 'AMR' meters		15	306	11728
v	Number of consumers with 'non-smart prepaid' meters				
vi	Number of unmetered consumers				
vii	Number of total consumers	2	15	306	50055
b.i.	Number of conventionally metered Distribution Transformers				
ii	Number of DTs with communicable meters		2	342	
iii	Number of unmetered DTs				
iv	Number of total Transformers		2	342	0
c.i.	Number of metered feeders	2	70	1157	0
ii	Number of feeders with communicable meters	0	70	1157	0
iii	Number of unmetered feeders	0	0	0	2814
iv	Number of total feeders	2	70	1157	2814
d.	Line length (in km)	21.5	133	804	806
e.	Length of Aerial Bunched Cables				84.00
f.	Length of Underground Cables		133	804	722
3	Voltage levels	Particulars	MU	Reference	Remarks (Source of data)
i	66kV and above	Long-Term Conventional	667.54		Includes input energy for franchisees
		Medium Conventional	68.53		132 kV Source
		Short Term Conventional	35.52		Thr Exchange
		Banking			
		Long-Term Renewable energy			
		Medium and Short-Term RE			Includes power from bilateral/ PK/ DEEP
		Captive, open access Input	0.00		Any power wheeled for any purchase other than sale to DISCOM. Does not include input for franchisee.
		Sale of surplus power			
		Quantum of inter-state transmission loss			As confirmed by Si DC, RI DC etc
		Power procured from inter-state sources	771.59		Based on data from Form 5
Power at state transmission boundary	771.59				
ii	33kV	Long-Term Conventional			
		Medium Conventional			
		Short Term Conventional			
		Banking			
		Long-Term Renewable energy			
		Medium and Short-Term RE			
		Captive, open access Input			
		Sale of surplus power			
		Quantum of intra-state transmission loss	0.00		
		Power procured from intra-state sources	0.00		
Input in DISCOM wires network	771.59				
iii	33 kV	Renewable Energy Procurement			
		Small capacity conventional/ biomass/ hydro plants Procurement			
v	11 kV	Captive, open access Input			
		Renewable Energy Procurement			
vi	LT	Small capacity conventional/ biomass/ hydro plants Procurement			
		Sales Migration input			
vii		Renewable Energy Procurement			
		Sales Migration input			
viii		Energy Embedded within DISCOM wires network	0.00		
		Total Energy Available/ Input	771.59		
4	Voltage level	Energy Sales Particulars	MU	Reference	

A	Voltage level	Energy Sales Particulars		Reference
			MU	
i	LT Level	DISCOM' consumers	89.54	Include sales to consumers in franchisee areas, unmetered consumers
		Demand from open access, captive		Non DISCOM's sales
		Embedded generation used at LT level		Demand from embedded generation at LT level
		Sale at LT level	89.54	
		Quantum of LT level losses	9.95	
		Energy input at LT level	99.49	10% Theoretical Loss considered
ii	6.6 kV Level	DISCOM' consumers	73.22	Include sales to consumers in franchisee areas, unmetered consumers
		Demand from open access, captive		Non DISCOM's sales
		Embedded generation at 6.6 kV level used		Demand from embedded generation at 6.6kV level
		Sales at 6.6 kV level	73.22	
		Quantum of Losses at 6.6 kV	1.88	
		Energy input at 6.6 kV level	75.10	2.5% Theoretical Loss considered
iii	33 kV Level	DISCOM' consumers	456	Include sales to consumers in franchisee areas, unmetered consumers
		Demand from open access, captive		Non DISCOM's sales
		Embedded generation at 33 kV or below level		This is DISCOM and OA demand met via energy generated at same voltage level
		Sales at 33 kV level	457.69	
		Quantum of Losses at 33 kV	8.98	
		Energy input at 33kV Level	466.67	1.93 % Theoretical Loss considered
iv	> 33 kv	DISCOM' consumers	129.75	Include sales to consumers in franchisee areas, unmetered consumers
		Demand from open access, captive		Non DISCOM's sales
		Cross border sale of energy		
		Sale to other DISCOMs		
		Banking		
		Energy input at > 33kV Level	130.33	0.45% Theoretical Loss considered
		Sales at 66kV and above (EHV)		
		Total Energy Requirement	771.59	
		Total Energy Sales	750.20	

**Energy Accounting Summary**

S	DISCOM	Input (in MU)	Sale (in MU)	Loss (in MU)	Loss %
i	LT	99.48	89.54	9.95	10.00%
ii	11 Kv	75.10	73.22	1.88	2.50%
iii	33 kv	466.67	457.69	8.98	1.93%
iv	> 33 kv	130.33	129.75	0.59	0.45%
6	Open Access, Captive	Input (in MU)	Sale (in MU)	Loss (in MU)	Loss %
i	LT	0.00		0.00	#Div/0!
ii	11 Kv	0.00		0.00	#Div/0!
iii	33 kv	0.00		0.00	#Div/0!
iv	> 33 kv	0.00		0.00	#Div/0!

**Loss Estimation for DISCOM**

T&D loss	21.40
D loss	21.40
T&D loss (%)	2.77%
D loss (%)	2.77%

Details of Division Wise Losses (See note below)\*\*

Division Wise Losses

Period From 1st July To 30th Sept 2023

S. No of circle	Name of Division	Division Type (Urban/Rural)	Consumer profile				Energy parameters				Losses		Commercial Parameter			AT & C loss (%)			
			No of connection metered (Nos)	No of connection Un metered (Nos)	Total Number of connections (Nos)	% of number of connections	Connected metered (MW)	Connect ed Un- metered (MW)	Total Connect ed Load (MW)	% of connect ed load	Input energy (MU)	Meter ed energy	Unmet ess same nt energy	Total energy consum ption	T&D loss (MU)		T&D loss (%)	Billed Amount in Rs. Crore	Collected Amount in Rs. Crore
1	Residential		39104	0	39104	78%	260.61	0	260.61	35%	87.23	0	87.23	12%		45.34	49.61	109.43%	
	Agricultural		0	0	0	0%	0.00	0	0.00	0%	0.00	0	0.00	0%		-	-	0.00%	
	Commercial/Indust rial-LT		10593	0	10593	21%	69.16	0	69.16	9%	25.21	0	25.21	3%	21.40	16.90	16.06	95.03%	
	Commercial/Indust rial-HT		169	0	169	0%	416.56	0	416.56	56%	635.86	0	635.86	85%		487.38	507.84	104.20%	
	Others		512	0	512	1%	2.81	0	2.81	0%	1.89	0	1.89	0%		1.19	1.20	100.99%	
	<b>Sub total</b>		<b>50378</b>	<b>0</b>	<b>50378</b>	<b>100%</b>	<b>749</b>	<b>0</b>	<b>749</b>	<b>100%</b>	<b>771.59</b>	<b>750.20</b>	<b>750.20</b>	<b>100%</b>	<b>21.40</b>	<b>550.80</b>	<b>574.71</b>	<b>104.34%</b>	
76	Residential		39104	0	39104	78%	260.60806	0	260.61	35%	87.229	0	87.229	12%		45.33563	49.61156	109.43%	
	Agricultural		0	0	0	0%	0	0	0	0%	0	0	0	0%		0	0	0.00%	
	Commercial/Indust rial-LT		10593	0	10593	21%	69.15555	0	69.156	9%	25.212	0	25.212	3%	21.3959	16.89988	16.05942	95.03%	
	Commercial/Indust rial-HT		169	0	169	0%	416.56425	0	416.56	56%	635.86	0	635.86	85%		487.3762	507.8392	104.20%	
	Others		512	0	512	1%	2.81	0	2.81	0%	1.8891	0	1.8891	0%		1.190171	1.201922	100.99%	
	<b>Total</b>		<b>50378</b>	<b>0</b>	<b>50378</b>	<b>100%</b>	<b>749</b>	<b>0</b>	<b>749</b>	<b>100%</b>	<b>771.59</b>	<b>750.20</b>	<b>750.2</b>	<b>100%</b>	<b>21.40</b>	<b>550.80</b>	<b>574.71</b>	<b>104.34%</b>	
77	At company level																		<b>-1.45%</b>

\*\* Note - It shall be mandatory to record the energy supplied separately for each category of consumers which is being provided a separate rate of subsidy in the tariff, by the state government, so that the subsidy due for the electricity distribution

Co	Parameter
lor	
co	Please enter name of circle
de	Please enter circle code
	0 Please enter numeric value or 0
	Formula protected

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result in losses to the Authorised Signatory and Seal

Authorised Signatory and Seal

f saroj (saroj kumar)

Name of Authorised Signatory: HARENDRA VERMA

Name of the DISCOM: TATA STEEL LIMITED

Full Address: BISTUPUR, JAMSHEDPUR

Seal



Signature:-

Name of Energy Manager: PRADEEP KUMAR

Registration Number: NA

**Form-Input energy(Details of Input energy & Infrastructure)**  
**A. Summary of energy input & Infrastructure**

S.No	Parameters	Period From 1st April 2023 To 30th June 2023	Remarks (Source of data)
A.1	Input Energy purchased (MU)	814.14	
A.2	Transmission loss (%)	0%	No Transmission charge applicable as we have considered input energy at
A.3	Transmission loss (MU)	0.00	
A.4	Energy sold outside the periphery(MU)	42.55	Sold in Exchange
A.5	Open access sale (MU)	0.00	
A.6	EHT sale		
A.7	Net input energy (received at DISCOM periphery or at distribution point)-(MU)	771.59	After Sale in exchange net input at DISCOM Pheiphey
A.8	Is 100% metering available at 66/33 kV (Select yes or no from list)	Yes	
A.9	Is 100% metering available at 11 kV (Select yes or no from list)	Yes	
A.10	% of metering available at DT	100%	Internal MIS Data
A.11	% of metering available at consumer end	100%	Internal MIS Data
A.12	No of feeders at 66kV and above voltage level	2	132kV voltage Level
A.13	No of feeders at 33kV voltage level	70	Internal MIS Data
A.14	No of feeders at 11kV voltage level	1157	6.6 Kv data is provided because 11kv line is not available in TSL area
A.15	No of LT feeders level	2814	Internal GIS Data
A.16	Line length (ckt. km) at 66kV and above voltage level	21.5	132kV voltage Level
A.17	Line length (ckt. km) at 33kV voltage level	132.90	Internal GIS Data
A.18	Line length (ckt. km) at 6.6kV voltage level	804.43	6.6 Kv data is provided because 11kv line is not available in TSL area
A.19	Line length (km) at LT level	806.15	Internal GIS Data
A.20	Length of Aerial Bunched Cables	84	
A.21	Length of Underground Cables	1659	Total length includes at 33kV,6.6kV , LT voltage level
A.22	HT/LT ratio	1.19	

B. Meter reading of input energy at injection points

S.No	Zone	Circle	Voltage Level	Division	Sub-Division	Sub-Station	Feeder ID	Feeder Name	Feeder Metering Status (Metered/Non-metered/AMR/AMI)	Status of Meter (functional/Non-functional)	Metering Date (Date of last actual meter reading/communication)	Status of Communication			Period from 1st July 2023 to 30th Sept 2023						Remarks (Source of data)			
												% data received through automatic AMR/AMI	Number of hours when meter was unable to communicate in period	Total Number of hours to the period	External CT ratio	Meter CT ratio	External PT ratio	Meter PT ratio	MF	Import (MU)		Export (MU)	Sales (MU)	
B.1	Jamshedpur	Jamshedpur	400 kv	Jamshedpur	Jamshedpur	NA	NA	DVC400 kv	Metered	Functional	30th Sept 2023 24:00 Hrs	100%	0 Hrs	8760	DVC40029 and DVC40028	500	500	3636	3636	1	266.68		This includes 35.52 Mts Purchased through Exchange	
B.2	Jamshedpur	Jamshedpur	132 kv	Jamshedpur	Jamshedpur	NA	NA	DVC132 kv	Metered	Functional	30th Sept 2023 24:00 Hrs	100%	0 Hrs	8760	SMU1015	80	80	1200	1200	1	68.53			
B.3	Jamshedpur	Jamshedpur	132 kv	Jamshedpur	Jamshedpur	NA	NA	TPCL UR2	Metered	Functional	30th Sept 2023 24:00 Hrs	100%	0 Hrs	8760	600121503	800	800	1200	1200	1	225.82			
B.4	Jamshedpur	Jamshedpur	132 kv	Jamshedpur	Jamshedpur	NA	NA	TPCL UR3	Metered	Functional	30th Sept 2023 24:00 Hrs	100%	0 Hrs	8760	PS-0203A041-01	800	800	1200	1200	1	210.56			
B.5	Jamshedpur	Jamshedpur	132 kv	Jamshedpur	Jamshedpur	NA	NA	Transfer from capacitor	Metered	Functional	30th Sept 2023 24:00 Hrs	100%	0 Hrs	8760	NA	NA	NA	NA	NA	NA	0.00			
B.13	Total (MU)																							
B.13	Energy at DISCOM																							
B.13	DISCOM																							

Col or code	Parameter
0	Please enter voltage level or leave blank
	Please enter feeder id and name or leave blank
	Enter meter no or leave blank
	Enter CT/PT ratio or leave blank
	Please enter numeric value or 0
	Please select yes or no from list
	Formula protected

I/We undertake that the information supplied in this Document and Pro-forma is accurate to the best of my knowledge and if any of the information supplied is found to be incorrect and such information result into loss to the Central Government or State Government or any of the authority under them or any other person affected, I/we undertake to indemnify such loss.

Authorised Signatory and Seal

f saroj (saroj kumar)

HARENDRA VERMA  
TATA STEEL LIMITED  
BISTUPUR, JAMSHEDPUR

Name of Authorised Signatory  
Name of the DISCOM:  
Full Address:-

Signature:-  
Name of Energy Manager: PRADEEP KUMAR  
Registration Number: NA



Seal

### Details of Input Energy Sources

Period From 1st July 2023 To 30th Sept 2023

A. Generation at Transmission Periphery (Details)

S.No.	Name of Generation Station	Generation Capacity (In MW)	Type of Station Generation (Based- Solid ( Coal ,Lignite)/Liquid/Gas/Rene wable ( biomass- bagasse)/Others)	Type of Contract (in years/months/days)	Type of Grid (Intra- state/Inter-state)	Point of Connection (POC) Loss MU	Voltage Level ( At input)	Remarks (Source of data)
1	DVC MTPS 7&8	500	Coal	Long Term Contract	Inter-State	3.34%	400 kv	Loss is NLDC Weekly loss
2	DVC DSTPS U#1 &2	500	Coal	Long Term Contract	Inter-State	3.34%	400 kv	Loss is NLDC Weekly loss
3	TPCL Jojobera U#2	102	Coal	Long Term Contract	Intra-state	NA	132 kv	NA
4	TPCL Jojobera U#3	102	Coal	Long Term Contract	Intra-state	NA	132 kv	NA
5	DVC-132 Kv Source	88	others	Long Term Contract	Intra-state	NA	132 kv	NA



(Details of Consumers)						
Summary of Energy						
Period From 1st July To 30th Sept 2023						
S.No	Type of Consumers	Category of Consumers (EHT/HT/LT/Others)	Voltage Level (In kV) 220kV/132kV/ 110kV/66kV/33 kV/22kv/20kV/ 11kV/6.6kV/3k V/00.4kV/0.23k V	No of Consumers	Total Consumption (In MU)	Remarks (Source of data)
1	Domestic	LT Domestic	400 V	38963	62.43	From SAP control Report
2	Commercial	LTCS	400 V	10592	25.15	From SAP control Report
3	IP Sets					
4	Hor. & Nur. & Coffee/Tea & Rubber (Metered)					
5	Hor. & Nur. & Coffee/Tea & Rubber (Flat)					
6	Heating and Motive Power					
7	Water Supply					
8	Public Lighting	Street Light	400 V	402	1.47	From SAP control Report
9	HT Water Supply (TSL doesnot have separate Category)					
10	HT Industrial	HT-IS	33kV & above	16	471.04	From SAP control Report
11	Industrial (Small)	LTIS	400 V	1	0.07	From SAP control Report
12	Industrial (Medium)	HT-IS	6.6kV	32	21.99	From SAP control Report
13	HT Commercial (including HT Water Supply)	HT-IS	6.6kV	119	26.25	From SAP control Report
14	Applicable to Government Hospitals & Hospitals					
15	Lift Irrigation Schemes/Lift Irrigation Societies					
16	HT Res. Apartments Applicable to all areas	DSHT	6.6 kV	141	24.79	From SAP control Report
17	Mixed Load					
18	Government offices and department					
19	Others-1 (Temporary Power Connection)	Temp. Connection	400 V	110	0.42	From SAP control Report
20	Others-2 (Sales to other Licesnsee)	EHT	132kv	1	116.40	From SAP control Report
21	Others-3 (Military Engineering Services)	MESRTODL	6.6 kV	1	0.19	From SAP control Report
22	Others-4 (if any , specify in remarks)					
23	Others-5 (if any , specify in remarks)					
	<b>Total</b>			<b>50378</b>	<b>750.20</b>	

Annexure - 1 : Proforma for Quarterly Consumer Category-wise Subsidy Billed/Received/Due for period 1st July 2023 to 30th Sept 2023

Consumer Category (Separate for each subsidized consumer category)	Billed Energy			Subsidized Billed Energy			Applicable rate of Subsidy as notified by State Govt.			Subsidy Due from State Govt.			Subsidy Actually Billed/claimed from State Govt. (As against col.12)	Subsidy Received from State Govt. (As against col.13)	Balance Subsidy yet to be Received from State Govt.
	Metered	Un-metered*	Total	Metered (out of col.2)	Un-metered* (Out of col.3)	Total	Metered Energy**	Un-metered Energy**	Total	Metered Energy	Un-metered Energy	Total			
	(In kwh)			(In kwh)			(In Rs/Kwh)			(In Rs. Cr.)					
1	2	3	4=2+3	5	6	7=5+6	8	9	10=5x8	11=6x9	12=10+11	13	14	15=13-14	
Residential	87														
Agriculture	0														
Commercial/Industrial- LT	25														
Commercial/Industrial- HT	636														
Other (Specify) WW	2														
<b>Total</b>	<b>750.20</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	

Quarter-2

NIL





35	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	KFA FLAT, BH AREA	K-17-1	500	DOMESTIC	Communicable				
36	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	KFA FLAT, BH AREA	K-17-2	1000	DOMESTIC	Communicable				
37	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	KFA FLAT, BH AREA	K-19	500	DOMESTIC	Communicable				
38	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	KADMA WORKERS FLAT	K-20	500	DOMESTIC	Communicable				
39	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	KADMA WORKERS FLAT	K-21	250	DOMESTIC	Communicable				
40	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	KADMA WORKERS FLAT	K-23	1000	DOMESTIC	Communicable				
41	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	FLATLET G.P. SLOPE NEAR KADMA THANA	K-24	500	DOMESTIC	Communicable				
42	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	WORKERS FLAT G.P. SLOPE	K-25-1	1000	DOMESTIC	Communicable				
43	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	DINDLEE ENCLAVE PUNSA ROAD	K-25-2	1000	DOMESTIC	Communicable				
44	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	DINDLEE ENCLAVE PUNSA ROAD	K-26	500	DOMESTIC	Communicable				
45	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	VIHAR ROAD KADMA	K-27	300	DOMESTIC	Communicable				
46	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	OLD PROF. FLAT KADMA	K-28	750	DOMESTIC	Communicable				
47	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	1500 FLAT ULTIYAN	K-29	750	DOMESTIC	Communicable				
48	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	1500 FLAT ULTIYAN	K-30	750	DOMESTIC	Communicable				
49	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	1500 FLAT ULTIYAN	K-31	1000	DOMESTIC	Communicable				
50	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	NEW PHE. FLAT NEAR F. LINK ROAD	K-3-1-1	500	DOMESTIC	Communicable				
51	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	NEW PHE. FLAT NEAR F. LINK ROAD	K-3-1-2	500	DOMESTIC	Communicable				
52	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	KADMA WATER TOWER	K-16	250	COMMERCIAL	Communicable				
53	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	(G-1,3) BE-SIDE GREEN ENCLAVE	K-1B-2	1,350	DOMESTIC	Communicable				
54	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	(G-1,3) BE-SIDE GREEN ENCLAVE	K-1B-3	500	DOMESTIC	Communicable				
55	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	(G-1,3) BE-SIDE GREEN ENCLAVE	K-19	500	DOMESTIC	Communicable				
56	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	Toll Bridge, Kadma	K-40	150	COMMERCIAL	Communicable				
57	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	District Hostel, Kadma	K-41	1000	DOMESTIC	Communicable				
58	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	JUSCO CORPORATE OFFICE	N-1-1	1000	COMMERCIAL	Communicable				
59	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	JUSCO CORPORATE OFFICE	N-1-2	250	COMMERCIAL	Communicable				
60	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	JUSCO CORPORATE OFFICE	N-1-3	250	COMMERCIAL	Communicable				
61	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	JUSCO CORPORATE OFFICE	N-1-4	300	COMMERCIAL	Communicable				
62	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	NEAR WILDIN CLUN	N-4-1	300	COMMERCIAL	Communicable				
63	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	NEAR REDDIH CLUN	N-4-2	300	COMMERCIAL	Communicable				
64	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	CH AREA NORTH (NEAR N-TOWN T.O.P.)	N-4-3	250	DOMESTIC	Communicable				
65	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	CH AREA NORTH (NEAR N-TOWN T.O.P.)	N-4-2	300	COMMERCIAL	Communicable				
66	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	TOWN HALL	N-10	750	DOMESTIC	Communicable				
67	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	MURLES HOSTEL	N-11	600	MIXED	Communicable				
68	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	PAIK'S GARDEN	N-14	300	COMMERCIAL	Communicable				
69	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	REDE BUNGALOW T.C. ROAD	N-17	250	DOMESTIC	Communicable				
70	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	PIPE LINE FLAT	N-18	250	DOMESTIC	Communicable				
71	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	JUBILEE PARK SAKCHI GATE	N-21	300	COMMERCIAL	Communicable				
72	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	INSIDE GUEST HOUSE	N-23	250	COMMERCIAL	Communicable				
73	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	REDDI KALI BADI	N-24	500	MIXED	Communicable				
74	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	DHAKTIDIH WORKERS FLAT	N-30-2	1000	DOMESTIC	Communicable				
75	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	BACK SIDE OF OLD TMDC	N-35	1000	COMMERCIAL	Communicable				
76	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	TISCO HOTEL (ANNEXE BUILDING)	N-35	410	COMMERCIAL	Communicable				
77	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	JUBILEE OFFICERS FLAT	N-39-1	500	DOMESTIC	Communicable				
78	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	JUBILEE OFFICERS FLAT	N-39-2	500	DOMESTIC	Communicable				
79	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	ARANGAN (C. H. AREA) (NORTH WEST)	N-40	300	DOMESTIC	Communicable				
80	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	JRD - SPORTS COMPLEX WEST WINGS	N-47	1,750	COMMERCIAL	Communicable				
81	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	JRD - SPORTS COMPLEX EAST WINGS	N-47A	1,750	COMMERCIAL	Communicable				
82	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	DHAKTIDIH MARKET	N-49	1000	MIXED	Communicable				
83	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	CH AREA OLD SW HOUSE NEAR CRICKET GROUND	N-50	250	DOMESTIC	Communicable				
84	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	JUBILEE PARK NEAR LAJER SHOW	N-51	1000	COMMERCIAL	Communicable				
85	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	MARRIE DRIVE (N-NORTH WEST)	N-54	500	COMMERCIAL	Communicable				
86	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	MILLS & GODDOWN AREA SAKCHI	L-3	750	MARKET	Communicable				
87	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	AMBAGAN ROAD SAKCHI	L-8-2	1000	MIXED	Communicable				
88	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	AMBAGAN ROAD SAKCHI	L-8-1	1000	MIXED	Communicable				
89	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	L-4 QUARTERS KASIDHI NORTH	L-11	300	DOMESTIC	Communicable				
90	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	HUAME PIPE WASTE	L-15	1000	MIXED	Communicable				
91	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	RU FRONT UP SAKCHI COURT	L-16	500	MIXED	Communicable				
92	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	KA IDH EAST	L-17	1000	MIXED	Communicable				
93	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	BACK SIDE OF FIVE HOSPITAL TRF. ON ROOF	L-18-1	250	COMMERCIAL	Communicable				
94	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUISL-33KV-AROGYA BHAVAN	TSUISL-33KV-AROGYA BHAVAN	Jamshedpur	RAJENDRA NAGAR	L-19-1	1000	DOMESTIC	Communicable				

Work in Progress



155	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Burma minse water tower			NAMDHI ROAD BURMAMINES	B-2	500	COMMERCIAL	Communicable							
156	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Burma minse water tower			INFRONT OF TRF GATE	B-3	500	DOMESTIC	Communicable							
157	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Burma minse water tower			STATION ROAD BURMAMINES	B-4	250	MARKET	Communicable							
158	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Burma minse water tower			S- TYPE QRT.BURMANINES	B-5	500	MIXED	Communicable							
159	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Burma minse water tower			BURMAMINES MARKET	B-6	500	MARKET	Communicable							
160	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Burma minse water tower			BURMAMINES SEWAGE PUMPING STN	B-7	250	COMMERCIAL	Communicable							
161	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Burma minse water tower			TATA NAGAR FOUNDRY	B-8	1000	COMMERCIAL	Communicable							
162	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Burma minse water tower			MILLS & GODOWN AREA B-MINES	B-10	1000	COMMERCIAL	Communicable							
163	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Burma minse water tower			MILLS & GODOWN AREA B-MINES	B-10A	1000	COMMERCIAL	Communicable							
164	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Fast Zone			NAMDA BUSTEE	B-11A	1000	DOMESTIC	Communicable							
165	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Fast Zone			MANIFIT BUSTEE	B-12	1000	DOMESTIC	Communicable							
166	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Burma minse water tower			EAST PLANT BUSTEE BURMAMINES	B-14	1250	DOMESTIC	Communicable							
167	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Burma minse water tower			SECURITY FLAT	B-18	500	DOMESTIC	Communicable							
168	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Fast Zone			BURMA MINES COMMUNITY CENTRE	B-19	500	DOMESTIC	Communicable							
169	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-BISTUPUR			CABLE BOYS CLUB	B-20	500	DOMESTIC	Communicable							
170	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-T01			TILJUGA ROAD, SAKCHI	G-1	750	DOMESTIC	Communicable							
171	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-T02			DAMDAR ROAD SAKCHI	G-3	250	DOMESTIC	Communicable							
172	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-T02			GARAMNALA NEAR UTKAL ASSOCIATION	G-5	500	MIXED	Communicable							
173	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-5			Tube Baridih-1	TB-1	1000	DOMESTIC	Communicable							
174	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-5			Tube Baridih-2 DB 1	TB-2-1	1000	DOMESTIC	Communicable							
175	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-5			Tube Baridih-3	TB-3	500	DOMESTIC	Communicable							
176	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Fast Zone			Tube Nilidih-1	T-N-1	1000	DOMESTIC	Communicable							
177	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Fast Zone			Tube Nilidih-2	T-N-2	250	DOMESTIC	Communicable							
178	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Fast Zone			Tube Nilidih-3	T-N-3	1000	DOMESTIC	Communicable							
179	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L TOWN			AAMBAGHAN NEAR L-33	CS-1	1000	COMMERCIAL	Communicable							
180	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV- AROGYA BHAVAN			GANGOTRI ENCLAVE C.S.S.	CS-2	1000	DOMESTIC	Communicable							
181	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV- BISTUPUR			GHASHI CLUB BISTUPUR	CS-3	1000	COMMERCIAL	Communicable							
182	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-T05			KHATIYA MARKET, SAKCHI	CS-5	1000	COMMERCIAL	Communicable							
183	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV- SONARI			BHARAT SEVASHARAM SANGH SONARI	CS-6	1000	DOMESTIC	Communicable							
184	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV- AROGYA BHAVAN			EDEN PARK KADMA	CS-7	1000	DOMESTIC	Communicable							
185	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV- AROGYA BHAVAN			SAPNA COMPLEX KADMA	CS-8	1000	DOMESTIC	Communicable							
186	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV- L TOWN			GANGA INTERNATIONAL, SAKCHI	CS-9	1000	COMMERCIAL	Communicable							
187	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV- AROGYA BHAVAN			GITA BHAVAN	CS-11	1000	COMMERCIAL	Communicable							
188	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV- SONARI			FAB YRD MARINE DRIVE	CS-12	1000	COMMERCIAL	Communicable							
189	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV- SONARI			FAB YRD MARINE DRIVE	CS-13	1000	COMMERCIAL	Communicable							
190	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV- BISTUPUR			CONTRACTORS AREA (INSIDE DAV SCHOOL	CS-14	1000	DOMESTIC	Communicable							
191	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-6			GOLMURI (IN SIDE PARK)	CS-17	1000	DOMESTIC	Communicable							
192	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV- AROGYA BHAVAN			Uliyan	CS-18	1000	DOMESTIC	Communicable							
193	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-6			L-35 BARADWARI SEWAGE	CS-19	1000	COMMERCIAL	Communicable							
194	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-6			PATELNAGAR (S-POLCKET)	CS-20	1000	DOMESTIC	Communicable							
195	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-6			In front of INCAB	CS-21	1000	DOMESTIC	Communicable							
196	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-6			VIDYAPATI NAGAR BARIDIH	CS-22	1000	DOMESTIC	Communicable							
197	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-6			At A-10A	CS-23	1000	DOMESTIC	Communicable							
198	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV- L TOWN			Beside Howrah Bridge	CS-24	1000	MIXED	Communicable							
199	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-5			Inside KF-4 Flat	CS-25	1000	DOMESTIC	Communicable							
200	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Fast Zone			B-12 ,MANIFIT BUSTEE	CS-26	1000	DOMESTIC	Communicable							
201	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Burma mines water tower			B-2 CPSS, Backside of Burmamines Water Tower	CS-27	1000	DOMESTIC	Communicable							
202	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-6			Bhaduldh Gowala Bustee CPSS	CS-30	1000	DOMESTIC	Communicable							
203	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-T02			Kashidh	CS-31	1000	DOMESTIC	Communicable							
204	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-6			Garabasa	CS-32	1000	DOMESTIC	Communicable							
205	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV- AROGYA BHAVAN			B Rd Ramnagar	CS-33	1000	DOMESTIC	Communicable							
206	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-6			Sitaramdera Bustee	CS-35	1000	DOMESTIC	Communicable							
207	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-6			Ramadin baghan Nidih	CS-36	1000	COMMERCIAL	Communicable							
208	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV- L TOWN			Bengal Club Sakchi, Sakchi	CS-37	1000	COMMERCIAL	Communicable							
209	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-6			A-7 CPSS, Rd.8, Sidhgora	CS-38	1000	DOMESTIC	Communicable							
210	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-BR'S 3			PARVATI BURNING GHAT	S-14-1	250	Commercial	Communicable							
211	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-BR'S 1			SOUTHERN SEWAGE TREATMENT PLANT	S-19-1	500	Commercial	Communicable							
212	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-BR'S 1			SOUTHERN SEWAGE TREATMENT PLANT	S-19-2	500	Commercial	Communicable							
213	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV- BISTUPUR			Mukdum	S-24	1250	Commercial	Communicable							
214	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-BR'S 2			(G-3.1) BESIDE GREEN ENCLAVE	K-3B-1	1250	DOMESTIC	Communicable							
215	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-T03			CENTRE FOR EXCELLENCE	N-1	500	COMMERCIAL	Communicable							
216	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE			2007 GL OFFICE	N-8-1	500	COMMERCIAL	Communicable							

217	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							2007 GL OFFICE					N-8-2	500	COMMERCIAL	Communicable	
218	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							2007 GL OFFICE						N-8-3	1000	COMMERCIAL	Communicable
219	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							2007 GL OFFICE						N-8-4	1000	COMMERCIAL	Communicable
220	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							NEW C/O						N-19-1	500	COMMERCIAL	Communicable
221	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							NEW C/O						N-19-2	500	COMMERCIAL	Communicable
222	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							NEW C/O						N-19-3	500	COMMERCIAL	Communicable
223	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							NEW TEL EXCHANGE						N-28	1000	COMMERCIAL	Communicable
224	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							IN FRONT OF CE.ROD ANNEXE GARAGE						N-37-1	1000	COMMERCIAL	Communicable
225	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							IN FRONT OF CE.ROD ANNEXE GARAGE						N-37-2	500	COMMERCIAL	Communicable
226	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							CE.ROD ANNEXE						N-38-1	500	COMMERCIAL	Communicable
227	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							CE.ROD ANNEXE						N-38-2	500	COMMERCIAL	Communicable
228	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							CT Scan						N-41-1	250	COMMERCIAL	Communicable
229	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							CT Scan						N-41-2	250	COMMERCIAL	Communicable
230	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							BACK SIDE OF NEW CE & DD BUILDING						N-46	500	COMMERCIAL	Communicable
231	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							BACK SIDE OF CE.ROD BUILDING						N-52	1000	COMMERCIAL	Communicable
232	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUJSL-33KV-CH AREA							Near JUC						N-55	250	COMMERCIAL	Communicable
233	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							WATER WORKS						L-9	750	COMMERCIAL	Communicable
234	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							WATER WORKS						L-10	1000	COMMERCIAL	Communicable
235	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							INFRONT OF SAKHI GRADUATE COLLEGE						L-13	350	COMMERCIAL	Communicable
236	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							BACK SIDE OF TYE HOSPITAL TRF ON ROOF						L-18-2	250	COMMERCIAL	Communicable
237	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							RAJENDRA MAGAR						L-19-2	1000	DOMESTIC	Communicable
238	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							L-TOWN						L-24	500	COMMERCIAL	Communicable
239	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							5A FLAT						L-25	500	COMMERCIAL	Communicable
240	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							4 MID WATER WORKS						L-36	1000	COMMERCIAL	Communicable
241	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-GL OFFICE							H.NO.10811 SNP AREA UNDER BASEMENT						L-44	500	COMMERCIAL	Communicable
242	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-3.3KV-L-5							R D TATA GOLMURI						A-53/A	500	DOMESTIC	Communicable
243	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-3.3KV-L-5							TK COMPLEX GOLMURI						A-64	250	COMMERCIAL	Communicable
244	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-3.3KV-L-5							Teleswabhga						A-65	500	COMMERCIAL	Communicable
245	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-3.3KV-L-6							JAWAHA R TOLA						JAWAHA R TOLA	250	DOMESTIC	Communicable
246	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-3.3KV-L-5							Polke line, Golmuri						A-65	750	MIXED	Communicable
247	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-3.3KV-L-5							Tube Bariloh-2 DB 2						TB-2/2	1000	DOMESTIC	Communicable
248	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUJSL- 33KV- ARGVYA BHAVAN							VISHAL APPARMENT						CS-10	1000	DOMESTIC	Communicable
249	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-3.3KV-L TOWN							RHEMPA (JWA Hotel)						CS-15	1000	COMMERCIAL	Communicable
250	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-3.3KV-L TOWN							P-ROAD BILTUPUR						CS-16	500	COMMERCIAL	Communicable
251	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-3.3KV-L TOWN							Sonari 132KV Yard						CS-28	1000	COMMERCIAL	Communicable
252	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-3.3KV-L TOWN							LIC Colony Sonari						CS-29	1000	DOMESTIC	Communicable
253	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUJSL- 33KV- ARGVYA BHAVAN							Sarmath Park, Avil Sur Path						CS-34	1000	DOMESTIC	Communicable
254	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-6.6KV-Burma mines water tower							Burmamines, Road No 5						CPSS-39	500	DOMESTIC	Communicable
255	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-6							CRM Bara pond						CRM CANTEE N	250	COMMERCIAL	Communicable
256	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSL-33KV-L-6							CRM Bara pond						CRM Bara Pond main gate	500	COMMERCIAL	Communicable
257	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUJSL-33KV- CH AREA							Sakchi main gate						Sakchi main gate	500	COMMERCIAL	Communicable
258	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUJSL-33KV- CH AREA							Chenab Road						Chenab Road Picnic spot	500	COMMERCIAL	Communicable
259	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUJSL-33KV- CH AREA							plenic spot jubilee park						TATA RAYSON	250	COMMERCIAL	Communicable
260	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	Jamshedpur	TSUJSL-33KV- CH AREA							BLOOD BANK						TSUJSL- 33KV- CH AREA	250	COMMERCIAL	Communicable

Note: Current level of T&D Loss of TSL is hovering around a level of Technical Loss Limit. Whatever Variation is observed, basically depend on the loading patterns of the consumers which varies time to time depending on the external factor such as weathers, economic performances etc. Previously, we have replied that, full time additional organisation is required to undertake DT wise/ feeder wise analysis for all Feeder/DTs. It is planned to build the organisation in FY24 and it will undertake the same thereafter. However, with the existing resources, we have started DT wise loss monitoring and completed for 84 Nos of DTs for Q-2, FY24 whose results are given above. Work for energy accounting of balance DTs are in progress and will be updated.

This accounting has been done based on sum of consumption of all consumers connected to a DT and input energy recorded by the DT meter connected on LV side of the DT. The reason for variation / negative loss may be as follows.

1. Shifting of consumer from one DT to another DT during normal breakdown.
2. Incorrect tagging of consumer with the DT.
3. Difference in timing (0-4 days) of the DT reading and the consumers reading.
4. Average reading booked against consumer due to door lock (varies between 0 to 10% of the total consumer base month on month). The overall T&D loss of the Licensee varies between 2 to 3%. Significant additional resources / cost will be required to resolve above issues.